

Investigation Guideline

Product: Smoke Alarms, Fire Sprinklers, and Fire

Extinguishers
Appendix #: 129

Date: September 2004

I. Introduction

Use this guideline as an adjunct to an investigation of any fire, regardless of size, in which any of these products are present in the household. If none of these products were present, or if it is unknown if they were present, a statement in the investigation stating their absence is sufficient and the Data Record Sheet on page 4 of this guideline, does not need to be completed. Even if the fire is too small to expect operation of a smoke alarm or sprinkler, a fire extinguisher may be appropriate and its use would be of interest. This guideline is limited to the description and role of these products during the fire. It assumes that information on fire cause will be included as a result of the original assignment and normal investigative procedures and reporting should be followed.

A. Background Information

Smoke alarms (also called smoke detectors when in residential occupancies), fire sprinklers, and fire extinguishers are thought to be effective fire safety devices capable of preventing fire deaths and injuries. Their effectiveness, however, can be evaluated only when it is possible to evaluate their performance in a fire. As a result, we need to obtain information about them from fires that originated in other sources.

B. Product Descriptions

Smoke alarms:

<u>Power source</u>: 1) battery only, 2) direct connection to the electrical distribution system (hard-wired), or 3) hard-wired with a battery backup.

<u>Type</u>: 1) photoelectric, 2) ionization (will have a label somewhere including a radioactive symbol), or 3) a combination of the two.

Safety Standard: UL 217 Single and Multiple Station Smoke Alarms

Fire Sprinklers:

Type:

- 1) Wet pipe- contains water at all times, installed only where pipes will not freeze. Most residential sprinklers are of this type.
- 2) Dry pipe mostly non-residential, water fills pipes only as needed

3) Preaction- operates only after being activated by a separate sensing device such as a smoke alarm. Mostly used in locations where accidental discharge is of special concern, e.g. a computer room.

Safety Standard: NFPA 13: Installation of Sprinkler Systems

NFPA 25: Inspection, Testing and Maintenance of Water-Based Fire Protection Systems

UL 199, Automatic Sprinklers for Fire Protection Service UL 1626, Residential Sprinklers for Fire Service Protection

Fire Extinguishers:

<u>Rating</u>: Fire extinguishers are rated and labeled for the type of fire in which they are effective.

Class A – for fires involving wood, paper, plastics, and ordinary combustibles

Class B – for fires involving flammable liquids

Class C – for fires involving energized electrical equipment

Some extinguishers are appropriate for multiple uses.

Extinguishers need to be kept charged, which can usually be determined by a gauge incorporated into the top assembly.

Safety Standard: NFPA 10, Portable Fire Extinguishers

UL 711, Fire Testing of Portable Fire Extinguishers

C. Specific Items of Interest

<u>Smoke Alarms</u>: The smoke alarm's only purpose is to provide early warning of the fire.

- 1) Did a smoke alarm contribute to the occupant's recognition that there was a fire?
- 2) If not, did smoke reach one of the alarms soon enough that it should have sounded?
- 3) If it did not sound when it should have, did the alarm powered at the time? If not, why not?
- 4) For all occupants who were asleep when the alarm sounded, indicate their ages and whether they were awakened by the alarm. Also indicate their location in relationship to the nearest smoke alarm sounding and any circumstances, such as a closed door, that would have reduced the sound heard by the occupant.
- 5) Indicate number and placement of alarms in the household, in relation to coverage of each floor and each bedroom, particularly the room of origin.

Fire Sprinklers:

- 1) Did the room of origin have sprinkler heads? If so, did they operate?
- 2) Did the fire extend to other rooms?
- 3) Was the water to the system turned on? If not, why not?
- 4) If the system did not operate when it should have, specify its age, manufacturer(s), model, and type of system

Fire Extinguishers:

- 1) Was the extinguisher effective in containing the fire? If not, describe what happened when the extinguisher was used.
- 2) Was the extinguisher in operable condition?
- 3) Did the occupant know how to use it?
- 4) How many extinguishers did the occupant use/try to use?

D. Headquarters Contacts

Linda Smith, EPHA, (301) 504-7310 Arthur Lee, ES, (301) 504-7539 Rikki Khanna, ES, (301) 504-7546

II. Instructions for Collecting Specific Information

A. Synopsis

Indicate the presence/absence of each of these products and their role in containing the fire or contributing to its recognition.

B. Description of Incident Environment

Include a description of whether these products were present in the household. If so, describe their locations in relation to the fire origin. If a closed door prevented smoke from reaching a nearby alarm, it should be indicated.

C. Description of Interaction between Injured Person(s) and Product

For fire extinguishers, describe any problems that the occupant had in using the extinguisher. Describe any problems with smoke alarms or fire sprinklers that may have affected operational status at the time of the fire.

D. Description of Product

Describe brand name, age, condition, etc. on any product that failed to operate properly.

III. Photographs/ Diagrams of Incident Scene

Include diagrams as needed to convey the locations of the products involved in relation to fire origin. Photographs may be particularly useful to convey the condition and characteristics of the products involved.

IV. Obtaining samples and documents related to the investigation

No samples are required.

September 2004

DATA RECORD SHEET Investigation Guideline

PRODUCT: Smoke Alarms, Fire Sprinklers, and Fire Extinguishers To be used as a supplement to investigations of all residential fires, regardless of size, where one or more of these products was present.

TASK NUMBER _	INCIDENT DATE
A. Smoke Alarms (Detectors):
1. Were there any sr	noke alarms present in this occupancy?
Yes, con	
	IP to section B
	vn, SKIP to section B
2. Did a smoke alarr	n sound during the fire?
Yes→ 1	Did the alarm contribute to initial recognition of the fire?
	Yes
	No
	Unknown
$No \rightarrow$	SKIP to Question A. 4
	vn SKIP to Section B
_	bant who was asleep when the alarm sounded , list the age of that he/she was awakened by the alarm.
Age	Awakened by Smoke Alarm (enter yes, no, unknown)
	
	
	
	
If the alarm nearest	the fire origin sounded during the fire, skip to Section B.
it should have so	e reach the alarm nearest to the fire origin that the occupant thought unded during the fire?
Yes	
No SKIP t	
Unknown	SKIP to Section B

5. Was the alarm nearest to the fire origin powered at the time of the fire? Yes SKIP to Question A.7
No
Unknown SKIP to Question A7
6. What was the condition that resulted in lack of power?
No battery
Battery dead,
Battery present but disconnected
Alarm disconnected from electrical system (120 VAC)
Electrical system inoperable,
Other, describe
7. Did the occupant have any problems with this alarm? Yes, describe
No
Unknown
8. What are the characteristics of the alarm nearest the fire origin?
a. Type:
Ionization (radioactive symbol)
Photoelectric
Combination
Unknown
b. Power source:
Battery only
Connected to electrical system (120 VAC) – Skip to 8d.
Combination (120 VAC with battery back-up)
Unknown, SKIP to Question .8d
c. If the alarm contained a battery, was it a lithium battery?
Yes
No
Unknown
d. Manufacturer/Model:
e. Approximate age:years
f. If there were multiple alarms in the occupancy, were they interconnected? (When one alarm sounds, they all sound. Ask the homeowner.) Yes No Unknown

9. Additional comments:		
B. Fire Sprinklers		
Was there a fire sprinkler system in this occupancy? Yes, continue No, SKIP to Section C Unknown, SKIP to Section C		
2. Did the room of origin have sprinkler heads installed? YesNoUnknown		
3. Did the sprinkler system operate during the fire? YesNoUnknown		
4. Did flame damage extend outside the room of origin? YesNoUnknown		
5. Was the water to the system turned on at the time of the fire? YesNo→ Why not?Unknown		
6. Sprinkler System Characteristics: a) Type Wet PipeDry PipePreactionOther, describeUnknown b) Age:years c) Manufacturer/Model		
7. Additional comments:		

C. Fire Extinguishers

1. Was there a fire extinguisher in this occupancy?
Yes
No End of Data Record Sheet
Unknown End of Data Record Sheet
2. Did the occupant try to use a fire extinguisher to control the fire?
Yes→ Describe degree of success
No
Unknown
3. Fire Extinguisher Characteristics:
a) Rating
Class A
Class B
Class C
Combination., specify
Other, specify
Unknown
b) Age:years
c) Manufacturer/Model
4. Describe any problems the occupant had in using the extinguisher
5. Additional comments: