

---

---

**UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION**

**NORTH AMERICAN ELECTRIC            )     Docket No. RD13-\_\_\_\_\_**  
**RELIABILITY CORPORATION         )**

**PETITION OF THE  
NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION  
FOR APPROVAL OF PROPOSED RELIABILITY STANDARD  
EOP-004-2 – EVENT REPORTING**

Gerald W. Cauley  
President and Chief Executive Officer  
North American Electric Reliability  
Corporation  
3353 Peachtree Road, N.E.  
Suite 600, North Tower  
Atlanta, GA 30326  
(404) 446-2560  
(404) 446-2595– facsimile

Charles A. Berardesco  
Senior Vice President and General Counsel  
Holly A. Hawkins  
Assistant General Counsel  
Stacey Tyrewala  
Attorney  
North American Electric Reliability  
Corporation  
1325 G Street, N.W., Suite 600  
Washington, D.C. 20005  
(202) 400-3000  
(202) 644-8099– facsimile  
[charlie.berardesco@nerc.net](mailto:charlie.berardesco@nerc.net)  
[holly.hawkins@nerc.net](mailto:holly.hawkins@nerc.net)  
[stacey.tyrewala@nerc.net](mailto:stacey.tyrewala@nerc.net)

*Counsel for the North American Electric  
Reliability Corporation*

December 31, 2012

---

---

## TABLE OF CONTENTS

<b>I. Executive Summary.....</b>	<b>3</b>
<b>II. Notices and Communications.....</b>	<b>6</b>
<b>III. Background .....</b>	<b>6</b>
a. Regulatory Framework	
b. NERC Reliability Standards Development Procedure	
c. History of Project 2009-01, Disturbance and Sabotage Reporting	
<b>IV. Justification for Approval of the Proposed Reliability Standard.....</b>	<b>10</b>
a. Basis and Purpose of Proposed Standard and Improvements in this Revision	
b. Enforceability of the Proposed Reliability Standard	
<b>V. Summary of the Reliability Standard Development Proceedings.....</b>	<b>19</b>
a. Overview of the Standard Drafting Team	
b. Standard Authorization Request Development	
c. First Posting – Informal Comment Period	
d. Second Posting – Informal Comment Period	
e. Third Posting – Formal Comment Period and Initial Ballot and Non-Binding Poll	
f. Fourth Posting – Formal Comment Period and Successive Ballot and Non-Binding Poll	
g. Fifth Posting – Formal Comment Period and Successive Ballot and Non-Binding Poll	
h. Sixth Posting – Recirculation Ballot and Non-Binding Poll	
i. Board of Trustees Approval of EOP-004-2	
<b>VI. Conclusion.....</b>	<b>26</b>
<b>Exhibit A — Order No. 672 Criteria</b>	
<b>Exhibit B — Proposed Reliability Standard EOP-004-2 Submitted for Approval</b>	
<b>Exhibit C — Implementation Plan for Proposed Reliability Standard EOP-004-2 Submitted for Approval</b>	
<b>Exhibit D — Consideration of Comments</b>	
<b>Exhibit E — Analysis of how VRFs and VSLs Were Determined Using Commission Guidelines</b>	
<b>Exhibit F — Record of Development of Proposed Reliability Standard</b>	
<b>Exhibit G — Standard Drafting Team Roster for NERC Standards Development Project 2009-01</b>	

**UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION**

**NORTH AMERICAN ELECTRIC            )       Docket No. RD13-\_\_\_\_**  
**RELIABILITY CORPORATION         )**

**PETITION OF THE  
NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION  
FOR APPROVAL OF PROPOSED RELIABILITY STANDARD  
EOP-004-2 – EVENT REPORTING**

The North American Electric Reliability Corporation (“NERC”)<sup>1</sup> hereby requests the Federal Energy Regulatory Commission (“FERC” or the “Commission”) approve, in accordance with Section 215(d)(1) of the Federal Power Act (“FPA”)<sup>2</sup> and Section 39.5 of the Commission’s regulations, 18 C.F.R. § 39.5 (2012), the proposed Reliability Standard —EOP-004-2—Event Reporting, and find that the proposed Reliability Standard is just, reasonable, not unduly discriminatory or preferential, and in the public interest. EOP-004-2 was approved by the NERC Board of Trustees on November 7, 2012.<sup>3</sup>

NERC is hereby requesting approval of the proposed Reliability Standard, the associated implementation plan, Violation Risk Factors (“VRFs”) and Violation Severity Levels (“VSLs”), and retirement of the currently effective Reliability Standard as detailed below. Specifically, NERC requests approval of the following:

- Approval of proposed Reliability Standard EOP-004-2 included in **Exhibit B**, effective the first day of the first calendar quarter that is six months following the effective date of a Final Rule in this docket;

---

<sup>1</sup> NERC has been certified by the Commission as the electric reliability organization (“ERO”) in accordance with Section 215 of the Federal Power Act. The Commission certified NERC as the ERO in its order issued July 20, 2006 in Docket No. RR06-1-000. *North American Electric Reliability Corp.*, 116 FERC ¶ 61,062 (2006) (“ERO Certification Order”).

<sup>2</sup> 16 U.S.C. § 824o (2012).

<sup>3</sup> Unless otherwise designated, all capitalized terms shall have the meaning set forth in the Glossary of Terms Used in NERC Reliability Standards, available here: [http://www.nerc.com/files/Glossary\\_of\\_Terms.pdf](http://www.nerc.com/files/Glossary_of_Terms.pdf).

- Retirement of the following standards at midnight of the day immediately prior to the effective date of EOP-004-2:<sup>4</sup>
  - EOP-004-1 – Disturbance Reporting
  - CIP-001-2a – Sabotage Reporting
- Approval of the implementation plan for the proposed EOP-004-2 Reliability Standard which is included in **Exhibit C**.

The proposed effective date for the standard is just and reasonable and appropriately balances the urgency in the need to implement the standards against the reasonableness of the time allowed for those who must comply to develop necessary procedures, software, facilities, staffing or other relevant capability. The proposed effective date will allow applicable entities adequate time to ensure compliance with the requirements in accordance with Order No. 672.<sup>5</sup> As required by Section 39.5 of the Commission’s regulations, this petition presents the technical basis and purpose of the proposed Reliability Standard EOP-004-2 and a demonstration that the proposed Reliability Standard meets the criteria identified by the Commission in Order No. 672.

## **I. EXECUTIVE SUMMARY**

The proposed Reliability Standard provides a comprehensive approach to reporting disturbances and events that have the potential to impact the reliability of the Bulk Electric System in accordance with several Commission directives. The principal goal of NERC is to promote the reliability of the Bulk-Power System in North America and this goal is directly supported by evaluating events, undertaking appropriate levels of analysis to determine the

---

<sup>4</sup> Note, Compliance Application Notice CAN-0016 CIP-001 R1: Sabotage Reporting Procedure will be deemed to have been retired on midnight of the day immediately prior to the effective date of EOP-004-2.

<sup>5</sup> *Rules Concerning Certification of the Electric Reliability Organization; and Procedures for the Establishment, Approval, and Enforcement of Electric Reliability Standards*, Order No. 672, FERC Stats. & Regs. ¶ 31,204 at P 333, *order on reh’g*, Order No. 672-A, FERC Stats. & Regs. ¶ 31,212 (2006) (“In considering whether a proposed Reliability Standard is just and reasonable, FERC will consider also the timetable for implementation of the new requirements, including how the proposal balances any urgency in the need to implement it against the reasonableness of the time allowed for those who must comply to develop the necessary procedures, software, facilities, staffing or other relevant capability.”).

causes of the events, promptly assuring tracking of corrective actions to prevent recurrence, and providing lessons learned to the industry.

The proposed Reliability Standard requires Responsible Entities to have an Operating Plan for reporting applicable events to NERC and others (*e.g.*, Regional Entities, applicable Reliability Coordinators and law enforcement) within 24 hours of the event according to the procedure specified in their Operating Plan. This requires Responsible Entities to report events in a timely manner to allow governmental authorities and critical infrastructure members the opportunity to react in a meaningful manner to such information<sup>6</sup> which supports reliability principles and ultimately helps protect against future malicious physical attacks. The results-based approach of EOP-004-2 includes clear criteria for reporting, consistent reporting timelines, and encourages the development of an internal corporate culture of compliance that is focused on reliability and communication. The proposed Reliability Standard provides for timely event analysis and ensures that NERC can develop trends and prepare for a possible next event.

The requirements of the proposed Reliability Standard complement the efforts of the NERC Bulk-Power System Awareness group and event analysis programs, and the standard drafting team worked in coordination with the Event Analysis Working Group to develop a list of the events that are required to be reported for reliability purposes.<sup>7</sup> This list is incorporated into the proposed EOP-004-2 standard as Attachment 1. Attachment 2 (or alternatively Department of Energy (“DOE”) Form OE-417) is the form to be used by Responsible Entities for reporting when the threshold for an event listed in Attachment 1 is met.

NERC’s Bulk-Power System Awareness group seeks to provide timely, accurate and complete information regarding the current status of the Bulk-Power System and threats to its

---

<sup>6</sup> See Order No. 693 at P 470.

<sup>7</sup> See *e.g.*, Event Analysis Process Document – Version 1 at Appendix E, Categorization of Events, available at: <http://www.nerc.com/page.php?cid=5|365>.

reliable operation, enabling NERC and the industry to understand and learn from events and ultimately improve the reliability of the Bulk-Power System. The event analysis process also provides valuable input for training and education, reliability trend analysis efforts and reliability standards development, all of which support continued reliability improvement.

Proposed Reliability Standard EOP-004-2 is a result of merging EOP-004-1 and CIP-001-2a and represents a significant improvement in the identification and reporting of events. Successful event analysis depends on a collaborative approach in which registered entities, Regional Entities and NERC work together to achieve a common goal. NERC respectfully requests that the Commission approve the proposed Reliability Standard as just, reasonable, not unduly discriminatory or preferential and in the public interest.

## **II. NOTICES AND COMMUNICATIONS**

Notices and communications with respect to this filing may be addressed to the following:<sup>8</sup>

Gerald W. Cauley  
President and Chief Executive Officer  
North American Electric Reliability  
Corporation  
3353 Peachtree Road, N.E.  
Suite 600, North Tower  
Atlanta, GA 30326  
(404) 446-2560  
(404) 446-2595– facsimile

Charles A. Berardesco\*  
Senior Vice President and General Counsel  
Holly A. Hawkins\*  
Assistant General Counsel  
Stacey Tyrewala\*  
Attorney  
North American Electric Reliability  
Corporation  
1325 G Street, N.W., Suite 600  
Washington, D.C. 20005  
(202) 400-3000  
(202) 644-8099– facsimile  
[charlie.berardesco@nerc.net](mailto:charlie.berardesco@nerc.net)  
[holly.hawkins@nerc.net](mailto:holly.hawkins@nerc.net)  
[stacey.tyrewala@nerc.net](mailto:stacey.tyrewala@nerc.net)

---

<sup>8</sup> Persons to be included on the Commission's service list are indicated with an asterisk. NERC requests waiver of the Commission's rules and regulations to permit the inclusion of more than two people on the service list.

### **III. BACKGROUND**

#### **a. Regulatory Framework**

By enacting the Energy Policy Act of 2005,<sup>9</sup> Congress entrusted the Commission with the duties of approving and enforcing rules to ensure the reliability of the Nation’s Bulk-Power System, and with the duty of certifying an ERO that would be charged with developing and enforcing mandatory Reliability Standards, subject to Commission approval. Section 215 of the FPA states that all users, owners, and operators of the Bulk-Power System in the United States will be subject to Commission-approved Reliability Standards.<sup>10</sup>

Section 215(d)(5) of the FPA authorizes the Commission to order the ERO to submit a new or modified Reliability Standard. Pursuant to Section 215(d)(2) of the FPA and Section 39.5(c)(1) of the Commission’s regulations, the Commission will give due weight to the technical expertise of the ERO with respect to the content of a Reliability Standard. In Order No. 693, the Commission noted that it would defer to the “technical expertise” of the ERO with respect to the content of a Reliability Standard and explained that, through the use of directives, it provides guidance but does not dictate an outcome. Rather, the Commission will consider an equivalent alternative approach provided that the ERO demonstrates that the alternative will address the Commission’s underlying concern or goal as efficiently and effectively as the Commission’s proposal, example, or directive.<sup>11</sup>

Section 39.5(a) of the Commission’s regulations requires the ERO to file with the Commission for its approval each Reliability Standard that the ERO proposes to become mandatory and enforceable in the United States, and each modification to a Reliability Standard

---

<sup>9</sup> 16 U.S.C. § 824o (2012).

<sup>10</sup> See Section 215(b)(1) (“All users, owners and operators of the bulk-power system shall comply with reliability standards that take effect under this section.”).

<sup>11</sup> See *Mandatory Reliability Standards for the Bulk-Power System*, Order No. 693, FERC Stats. & Regs. ¶ 31,242 at PP 31, 186-187, *order on reh’g*, Order No. 693-A, 120 FERC ¶ 61,053 (2007).

that the ERO proposes to be made effective. The Commission has the regulatory responsibility to approve standards that protect the reliability of the Bulk-Power System and to ensure that such standards are just, reasonable, not unduly discriminatory or preferential, and in the public interest.

#### **b. NERC Reliability Standards Development Procedure**

The proposed Reliability Standard was developed in an open and fair manner and in accordance with the Commission-approved Reliability Standard development process.<sup>12</sup> NERC develops Reliability Standards in accordance with Section 300 (Reliability Standards Development) of its Rules of Procedure and the NERC Standard Processes Manual.<sup>13</sup> In its ERO Certification Order, the Commission found that NERC's proposed rules provide for reasonable notice and opportunity for public comment, due process, openness, and a balance of interests in developing Reliability Standards and thus satisfies certain of the criteria for approving Reliability Standards. The development process is open to any person or entity with a legitimate interest in the reliability of the Bulk-Power System. NERC considers the comments of all stakeholders, and a vote of stakeholders and the NERC Board of Trustees is required to approve a Reliability Standard before the Reliability Standard is submitted to the Commission for approval.

#### **c. History of Project 2009-01, Disturbance and Sabotage Reporting**

Project 2009-01—Disturbance and Sabotage Reporting, was initiated on April 2, 2009, by PJM Interconnection, L.L.C. as a request for revision to existing standards CIP-001-1,

---

<sup>12</sup> Order No. 672 at P 334 (“Further, in considering whether a proposed Reliability Standard meets the legal standard of review, we will entertain comments about whether the ERO implemented its Commission-approved Reliability Standard development process for the development of the particular proposed Reliability Standard in a proper manner, especially whether the process was open and fair. However, we caution that we will not be sympathetic to arguments by interested parties that choose, for whatever reason, not to participate in the ERO’s Reliability Standard development process if it is conducted in good faith in accordance with the procedures approved by FERC.”).

<sup>13</sup> The NERC Rules of Procedure are available here: <http://www.nerc.com/page.php?cid=1%7C8%7C169>. The current NERC Standard Processes Manual is available here: [http://www.nerc.com/files/Appendix\\_3A\\_StandardsProcessesManual\\_20120131.pdf](http://www.nerc.com/files/Appendix_3A_StandardsProcessesManual_20120131.pdf).



Sabotage Reporting, and EOP-004-1, Disturbance Reporting. The Standard Authorization Request was initiated to provide clarity on an appropriate threshold for reporting potential acts of sabotage as required by CIP-001-1, and to revise several requirements in currently effective EOP-004-1 that reference out-of-date Department of Energy forms and to eliminate “fill-in-the-blank” components.

The Disturbance and Sabotage Reporting drafting team was formed in late 2009. The drafting team developed EOP-004-2, Event Reporting, by combining the requirements of EOP-004-1 and CIP-001-2a into a single reporting standard using the results-based standard development approach.<sup>14</sup> The EOP-004-1 standard contains the requirements for reporting and analyzing disturbances while the CIP-001-2a standard addresses sabotage procedures and reporting. The drafting team used the NERC Security Guideline for the Electricity Sector: Threat and Incident Reporting as a resource.<sup>15</sup> In 2010, the drafting team developed a concept paper that identified the major concepts that the team proposed to be incorporated into the EOP-004-2 standard and posted the paper for comments. Additionally, the drafting team worked in coordination with the Events Analysis Working Group to develop a list of the events that would be required to be reported for reliability purposes and incorporated that list into Attachment 1 of the EOP-004-2 standard.

**i. Issues With Respect to Defining the Term “Sabotage”**

The drafting team considered the directive by the Commission in Order No. 693 to “further define the term [sabotage] and provide guidance on triggering events that would cause

---

<sup>14</sup> The results-based initiative is intended to focus the collective effort of NERC and industry participants on improving the clarity and quality of NERC Reliability Standards by developing performance, risk and competency-based requirements that accomplish a reliability objective through a defense-in-depth strategy, while eliminating documentation-driven requirements that do not benefit Bulk-Power System reliability.

<sup>15</sup> Available here: <http://www.nerc.com/files/Incident-Reporting.pdf>.

an entity to report an event.”<sup>16</sup> However, there was concern among stakeholders that such a definition could be ambiguous or otherwise subject to interpretation.<sup>17</sup> The drafting team determined that it was almost impossible to determine if a particular act constituted sabotage without the intervention of law enforcement. There is an inherently subjective component to the determination of whether or not any particular event is caused by a malicious act and this determination may vary based on various factors, including the local jurisdiction, given that there is also a legal component to whether or not a particular act is considered to be deliberate or malicious. Further, the definition of the term “sabotage” would have to exclude events such as unintentional operator error, whereas an action by a third party with the same exact consequences or outcome might be considered “sabotage.” The drafting team thus determined that attempting to define the term “sabotage” would result in further ambiguity with respect to the reporting of events. Instead, the drafting team developed a list of events included in Attachment 1 to provide guidance for reporting events. The drafting team determined that this method is an equally effective and efficient means of addressing the Commission directive in accordance with Order No. 693.<sup>18</sup>

#### **IV. JUSTIFICATION FOR APPROVAL OF THE PROPOSED RELIABILITY STANDARD**

##### **a. Basis and Purpose of Reliability Standard and Improvements in this Revision**

---

<sup>16</sup> Order No. 693 at P 461 (internal citation omitted).

<sup>17</sup> See e.g., Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) Reporting Concepts Paper at 3 (“One thing became clear in the [drafting team’s] discussion concerning sabotage: everyone has a different definition.”). Available here: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html).

<sup>18</sup> Order No. 693 at P 31 (“we do expect the ERO to respond with an equivalent alternative and adequate support that fully explains how the alternative produces a result that is as effective as or more effective than the Commission’s example or directive.”).

As noted herein, EOP-004-2 merges CIP-001-2a, which addresses sabotage procedures and reporting, and EOP-004-1,<sup>19</sup> which addresses the reporting and analyzing of disturbances, into a single comprehensive Reliability Standard.<sup>20</sup> EOP-004 is part of the Emergency Preparedness and Operations (“EOP”) body of Reliability Standards. The EOP group of Reliability Standards consists of eight Reliability Standards that address preparation for emergencies, necessary actions during emergencies and system restoration and reporting following disturbances.<sup>21</sup> CIP-001 is part of the Critical Infrastructure Protection body of standards.<sup>22</sup>

**i. Proposed Reliability Standard, EOP-004-2**

Proposed Reliability Standard EOP-004-2 requires reporting of events that impact or may impact the reliability of the Bulk Electric System, provides clear criteria for reporting, includes consistent reporting timelines, including a reporting hierarchy for reporting of disturbances, and

---

<sup>19</sup> The Commission approved EOP-004-1 in Order No. 693. *See* Order No. 693 at P 617.

<sup>20</sup> Requirement R2 of existing Reliability Standard EOP-004-1, which provides that each Reliability Coordinator, Balancing Authority, Transmission Operator, Generation Operator and Load-Serving Entity must promptly analyze Bulk Electric System disturbances on its system or facilities, is incorporated into Requirement R1 of the proposed EOP-004-2 Reliability Standard and is addressed by the NERC Bulk-Power System Awareness group and the NERC events analysis program. The Requirements of EOP-004-2 specify that certain types of events are to be reported, but do not include explicit provisions to analyze events. However, events reported under EOP-004-2 are incorporated into the real-time understanding of the grid that is maintained by the Bulk-Power System Awareness group. Further, such reports may trigger further scrutiny by the NERC event analysis program. If warranted, the events analysis program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event.

<sup>21</sup> EOP-001 is dedicated to Emergency Operations Planning. EOP-002 is dedicated to Capacity and Energy Emergencies. EOP-003 is dedicated to Load Shedding Plans. EOP-004 is dedicated to Event Reporting. EOP-005 is dedicated to System Restoration Plans and Blackstart Resources. EOP-006 is dedicated to System Restoration Coordination, [note there is no EOP-007]. EOP-008 is dedicated to Loss of Control Center Functionality and EOP-009 is dedicated to Documentation of Blackstart Generating Unit Test Results.

<sup>22</sup> The Commission approved CIP-001-1 in Order No. 693. *See* Order No. 693 at P 471. On April 21, 2010, NERC filed a petition for approval of an interpretation to Requirement R2 of CIP-001-1, which was approved in a letter order issued by the Commission on February 2, 2011. *North American Electric Reliability Corporation*, Letter order approving interpretation to CIP-001-1, Docket No. RD10-11-000, (February 2, 2011). On June 21, 2011, NERC submitted a Petition for Approval of Reliability Standards CIP-001-2a – Sabotage Reporting with a Regional Variance for Texas Reliability Entity, which was approved in a letter order issued by the Commission on August 2, 2011. *North American Electric Reliability Corporation*, Letter order approving Petition of the North American Electric Reliability Corporation for Approval of the Reliability Standard CIP-001-2a – Sabotage Reporting with a Regional Variance for Texas Reliability Entity, Docket No. RD11-6-000 (August 2, 2011).

provides clarity regarding who will receive the reported information. The proposed Reliability Standard consists of three Requirements. Requirement R1 mandates that Responsible Entities will have an event reporting Operating Plan for reporting specific types of events. Requirement R2 establishes a timeframe for reporting of events, and Requirement R3 states that Responsible Entities must validate the contact information contained in the Operating Plan each calendar year. The proposed Reliability Standard provides a comprehensive approach to disturbance and event reporting as explained in further detail below.

### **Proposed Requirements**

**R1.** Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the Regional Entity, company personnel, the Responsible Entity's Reliability Coordinator, law enforcement, or governmental authority). *[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]*

**R2.** Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*

**R3.** Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*

### **Requirement R1**

Requirement R1 of proposed Reliability Standard EOP-004-2 requires Responsible Entities to have an event reporting Operating Plan that includes, but is not limited to the protocol(s) for reporting, and each organization identified to receive an event report, for event types specified in Attachment 1 of EOP-004-2. Attachment 1 of EOP-004-2, Reportable Events, lists: (i) events, (ii) the relevant entity with reporting responsibility and (iii) the threshold for reporting the event. In these situations, Responsible Entities are requirement to submit EOP-004-2 (or DOE Form OE-417) Attachment 2, pursuant to Requirements R1 and R2. The last

column of Attachment 1, “Threshold for Reporting” is a bright line that, if reached, triggers the obligation for the entity to report that they experienced the applicable event per Requirement 1.

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; *e.g.*, Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC event analysis program. The results-based approach of EOP-004-2 encourages the development of a culture of compliance that is focused on reliability and communication.

It is generally accepted that as a good business practice, every Registered Entity that owns or operates elements or devices on the grid should have a formal or informal process, procedure, or steps it takes to gather information necessary to analyze events.<sup>23</sup> Requirement R1 mandates that the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective.

The communication protocol(s) could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information. An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.<sup>24</sup>

---

<sup>23</sup> See *e.g.*, PJM Manual 13, Emergency Operations, available at: <http://www.pjm.com/~media/documents/manuals/m13.ashx>; see also, Midwest ISO Disturbance Reporting Procedure RTO-OP-023-r9.1, available at: <https://www.midwestiso.org/Library/Repository/Procedure/RTO-OP-023-r9%201%20Disturbance%20Reporting%20Procedure.pdf>.

<sup>24</sup> Proposed Reliability Standard EOP-004-2 incorporates existing Reliability Standard CIP-001-2a in its entirety. CIP-001-2a requires that each Reliability Coordinator, Balancing Authority, Transmission Operator, Generation Operator and Load-Serving Entity have procedures for recognizing and for making operating personnel

## Requirement R2

Requirement R2 of proposed Reliability Standard EOP-004-2 requires Responsible Entities to report events within 24 hours of recognition of meeting an event type threshold for reporting, or, if an event occurs on a weekend, by the end of the next business day.<sup>25</sup> This incorporation of a deadline for reporting satisfies the Commission directive in Order No. 693 to “require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specified period of time.”<sup>26</sup> Requirement R2 is based on “recognition” of meeting an event type threshold because basing the reporting of events on when the events actually occur would be impractical. In practice, an entity may not be immediately aware of destruction or damage to a remote piece of equipment.<sup>27</sup> Further, requiring Responsible Entities to constantly monitor all equipment and property for destruction or damage would be a waste of resources and would not serve the best interests of the reliability of the Bulk Electric System. For these reasons, the drafting team’s incorporation of the term “recognition” is reasonable and is consistent with the Commission’s support in Order No. 693 for defining the specified period of time for reporting an event based on when an event is discovered or suspected to be sabotage.<sup>28</sup>

---

aware of sabotage events (Requirement R1 of CIP-001-2a), and communicating information concerning sabotage events to appropriate “parties” in the Interconnection (Requirements R2 through R4 of CIP-001-2a). The requirements of CIP-001-2a are encompassed by Requirement R1 of EOP-004-2 and Attachment 1.

<sup>25</sup> Holidays are not specifically recognized in Requirement R2.

<sup>26</sup> Order No. 693 at P 471.

<sup>27</sup> See e.g., *Comments of Xcel Energy Services, Inc.*, Docket No. RM06-16-000 (January 3, 2007) at p. 24 (“The triggering event for disclosure of an act of sabotage often will be unclear. That is, it is often not clear whether an event is the result of an act of sabotage, the result of negligent misconduct by an individual, or by equipment failure for other reasons. The Xcel Energy Operating Companies operate thousands of miles of bulk power transmission facilities, and many of these facilities are in remote locations. For this reason, it may require investigation to determine whether the triggering event was an act of sabotage, or the result of some other cause (such as weather or unintentional vehicle contact). This investigation will take time –especially if the event occurs at an unstaffed and/or remote station or facility.”)(internal citation omitted).

<sup>28</sup> Order No. 693 at P 470 (“Thus, the Commission directs the ERO to modify CIP-001-1 to require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specified period of time, even if it is a preliminary report. The ERO, through its Reliability Standards development process, is directed to determine the proper reporting period. In doing so, the ERO should consider suggestions raised by

Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in Attachment 1 of EOP-004-2. By implementing the event reporting Operating Plan, the Responsible Entity will assure that NERC has situational awareness so that NERC can develop trends and prepare for a possible next event, and mitigate the current event through the event analysis program.

Responsible Entities that have multiple registrations will only have to submit one report for any individual event.<sup>29</sup> For example, if an entity is registered as a Reliability Coordinator, Balancing Authority and Transmission Operator, the entity would only submit one report for a particular event rather submitting three reports as each individual registered entity. However, there may be several reports as a result of any individual event and this is appropriate as it will provide NERC with a better understanding of the depth and breadth of system conditions based on the given event.

Requirement R3 of existing Reliability Standard EOP-004-1, which requires each Reliability Coordinator, Balancing Authority, Transmission Operator, Generation Operator and Load-Serving Entity experiencing a reportable incident to provide a preliminary written report, has been incorporated into Requirement R2 of proposed Reliability Standard EOP-004-2.

### **Requirement R3**

Requirement R3 of proposed Reliability Standard EOP-004-2 calls for the Responsible Entity to validate the contact information contained in the Operating Plan each calendar year. This requirement helps ensure that the event reporting Operating Plan is up to date and

---

commenters such as FirstEnergy and Xcel to define the specified period for reporting an incident beginning from when an event is discovered or suspected to be sabotage, and APPA's concerns regarding events at unstaffed or remote facilities, and triggering events occurring outside staffed hours at small entities.").

<sup>29</sup> See Guideline and Technical Basis for EOP-004-2, Multiple Reports for a Single Organization.

Responsible Entities will be able to effectively report events to NERC to assure situational awareness.

The incorporation of this annual validation in Requirement R3 satisfies the Commission directive in Order No. 693 to “incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”<sup>30</sup>

### **Attachment 1: Reportable Events**

Attachment 1 of EOP-004-2, Reportable Events, lists (i) events, (ii) the relevant entity with reporting responsibility and (iii) the threshold for reporting the event. In these situations, entities are required to submit EOP-004-2 Attachment 2, pursuant to Requirements R1 and R2. The events addressed in Attachment 1 include, among others: damage or destruction of a Facility, transmission loss, generation loss and a BES Emergency<sup>31</sup> requiring public appeal for load reduction. Such events and the thresholds identified for reporting these events, are an equivalent alternative approach that ensures that Responsible Entities respond to events. Therefore, Attachment 1 addresses the Commission’s underlying concern as efficiently and effectively as the Commission’s directive to define the term “sabotage.” Collectively, Requirement R1 and Attachment 1 require entities to properly identify and respond to events to minimize the adverse impact on the Bulk Electric System.<sup>32</sup>

In Attachment 1, the drafting team used the term “Facility” as defined in the Glossary of Terms Used in NERC Reliability Standards.<sup>33</sup> A Facility is defined as: “A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a

---

<sup>30</sup> Order No. 693 at P 466.

<sup>31</sup> “BES Emergency” as used in EOP-004-2 is a defined term set forth in the Glossary of Terms Used in NERC Reliability Standards, available here: [http://www.nerc.com/files/Glossary\\_of\\_Terms.pdf](http://www.nerc.com/files/Glossary_of_Terms.pdf).

<sup>32</sup> This is responsive to the Commission directive at P471 of Order No. 693 requiring NERC to “specify baseline requirements regarding what issues should be addressed in the procedures for recognizing sabotage events and making personnel aware of such events”).

<sup>33</sup> Available here: [http://www.nerc.com/files/Glossary\\_of\\_Terms.pdf](http://www.nerc.com/files/Glossary_of_Terms.pdf).



shunt compensator, transformer, etc.)” The drafting team does not intend the use of the term “Facility” to mean a substation or any other facility that one might consider in everyday discussions regarding the grid. This is intended to mean *only* a Facility as defined above. The use of the defined term provides greater clarity for entities regarding the specific types of events that are to be reported. Through the use of the term “Facility,” all of the equipment within a substation that is critical to reliability is included.

## **Attachment 2: Event Reporting Form**

Attachment 2 (or alternatively DOE Form OE-417) is the form to be used by Responsible Entities for reporting when the threshold for an event listed in Attachment 1 is met.

The DOE Office of Electricity Delivery and Energy Reliability uses Form OE-417, “Emergency Incident and Disturbance Report,” to monitor major system incidents on electric power systems. Tracking disturbances that impact the integrated generating and transmission facilities is an important part of DOE’s responsibilities, along with examining issues associated with insufficient capacity reserves. The form collects information on electric emergency incidents and disturbances for DOE’s use in fulfilling its overall national security and other energy management responsibilities. The form is a mandatory filing whenever an electrical incident or disturbance is sufficiently large enough to cross the reporting thresholds. Reporting coverage for the Form OE-417 includes all 50 States, the District of Columbia, Puerto Rico, the U.S. Virgin Islands, and the U.S. Trust Territories.

In an effort to minimize administrative burden, U.S. entities may use the DOE OE-417 form, rather than Attachment 2, to report under EOP-004.<sup>34</sup> Pursuant to the DOE’s new online process, entities may record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses,

---

<sup>34</sup> Canadian entities are required to use Attachment 2 to report events.

thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.<sup>35</sup> This approach is consistent with the Commission’s suggestion in Order No. 693 for NERC to “consider consolidation of the sabotage reporting forms and the sabotage reporting channels with the appropriate governmental authorities to minimize the impact of these reporting requirements on all entities.”<sup>36</sup>

#### **b. Enforceability of the Proposed Reliability Standard, EOP-004-2**

The proposed Reliability Standard contains measures that support each standard requirement by clearly identifying what is required and how the requirement will be enforced. These measures help provide clarity regarding how the requirements will be enforced, and ensure that the requirements will be enforced in a clear, consistent, and non-preferential manner and without prejudice to any party.<sup>37</sup> The VSLs also provide further guidance on how NERC will enforce the requirements of the standard.

##### **i. Violation Risk Factors and Violation Severity Levels**

There are three requirements in EOP-004-2. Requirement R1 was assigned a Lower VRF while Requirements R2 and R3 were assigned a Medium VRF. The VRFs and VSLs for the proposed standard comport with NERC and Commission guidelines related to their assignment. For a detailed review of the VRFs, the VSLs, and the analysis of how the VRFs and VSLs were determined using these guidelines, please see **Exhibit E**.

## **V. SUMMARY OF THE RELIABILITY STANDARD DEVELOPMENT PROCEEDINGS**

---

<sup>35</sup> See <http://www.oe.netl.doe.gov/oe417.aspx>.

<sup>36</sup> Order No. 693 at P 471.

<sup>37</sup> Order No. 672 at P 327 (“There should be a clear criterion or measure of whether an entity is in compliance with a proposed Reliability Standard. It should contain or be accompanied by an objective measure of compliance so that it can be enforced and so that enforcement can be applied in a consistent and non-preferential manner.”).

The development record for proposed Reliability Standard EOP-004-2 is summarized below. **Exhibit D** contains the Consideration of Comments Reports created during the development of the Reliability Standards. **Exhibit F** contains the complete record of development for the standards.

**a. Overview of the Drafting Team**

When evaluating proposed Reliability Standard, the Commission is expected to give “due weight” to the technical expertise of the ERO.<sup>38</sup> The technical expertise of the ERO is derived from the drafting team. For this project, the drafting team consisted of four industry experts with a diversity of experience. A detailed set of biographical information for each of the team members is included along with the drafting team roster in **Exhibit G**. The development record for the proposed EOP-004-2 standard is summarized below.

**b. Standard Authorization Request Development**

The first draft of the Standard Authorization Request was posted for a 30-day public comment from April 22, 2009 to May 21, 2009. The drafting team received 40 sets of comments from 120 people from more than 60 companies representing 9 of the 10 industry segments. Most commenters agreed on the need for revisions to CIP-001-1 and EOP-004-1, but voiced concerns on issues including:

- The applicability of the final requirements;
- Whether or not the standards should be merged;
- The inclusion of vandalism and the thresholds for defining sabotage; and
- Onerous or duplicative reporting required by the current standards.

---

<sup>38</sup> Section 215(d)(2) of the Federal Power Act; 16 U.S.C. § 824o(d)(2) (2012).

The Disturbance and Sabotage Reporting drafting team was formed in late 2009. In 2010, the drafting team developed a concept paper that identified the major concepts that the team proposed to be incorporated into the EOP-004-2 standard and posted the paper for a 30-day public comment period from March 17, 2010 to April 16, 2010. NERC received 41 sets of comments from 95 different people from approximately 50 companies representing 8 of the 10 industry segments. Most commenters agreed that the guidance in the concept paper should be used as a foundation for revising the standards. In the concept paper, the drafting team proposed to consolidate disturbance and event reporting under a single standard in EOP-004.

**c. The First Posting – Informal Comment Period**

The first draft of EOP-004-2 was posted for a 30-day informal comment period from September 15, 2010 to October 15, 2010. A mapping document that showed the translation of CIP-001-1 and EOP-004-1 into EOP-004-2 was posted for guidance with the first draft. There were 60 sets of comments, with comments from more than 175 different people from approximately 100 companies representing 9 of the 10 industry segments. In response to comments, the drafting team made several changes to the draft standard including:

- Revised the purpose statement to address the concern that the drafting team went beyond the reliability intent of the standard by concentrating too much on event analysis;
- Added a proposed working definition for “impact events” to the NERC Glossary of Terms;
- Deleted all references to “situational awareness” and instead using the terms “industry awareness” where appropriate;
- Added Load Serving Entities as applicable entities;
- Deleted Requirement R1 and proposed revisions to the NERC Rules of Procedure to include a central system with responsibility for receiving and distributing impact event reports;
- Revised Requirement R2 to include Operating Plan, Operating Process and Operating Procedure;

- Removed Parts 2.5 through 2.9 of Requirement R2 and replaced with Requirement R1, Part 1.4 to require updates to the Impact Event Operating Plan within 90 days of any change to content;
- Rewrote Requirement R3 to eliminate the need to assess the probable cause of an impact event;
- Rewrote Requirement R4 by taking out prescriptive guidance;
- Removed Requirement 5, Parts 5.3 and 5.4 and removed Requirements R7 and R8;
- Removed several bright-line criteria from Attachment 1, modifying it to assign clear responsibility for reporting for each category of impact event, and clarifying the types of events included in Attachment 1; and
- Clarified that NERC will accept DOE OE-417 form in lieu of Attachment 2 if the responsible entity is required to submit an OE-417 form, and added a process for the reporting of a Cyber Security Incident.

**d. The Second Posting – Informal Comment Period**

The second draft of the standard was posted with the implementation plan for a public 30-day informal comment period from March 9, 2011 to April 8, 2011. The drafting team received 60 sets of comments from 188 different people from approximately 132 different companies representing all 10 industry segments. Several changes were made to the draft of the EOP-004-2 standard including:

- Deleted proposed definition of “Impact Event”;
- Revised the reporting time to 24 hours from 1 hour for most events
- Rewrote Requirement R1 to specify that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1;
- Revised the wording in Requirement R2 and R3 to more closely track the actions that need to be taken for reporting events and communications involving the Operating Plan;
- Rewrote Requirement R4 to more closely match the rationale language on annually verifying the communication process in its Operating Plan to provide better guidance to responsible entities; and
- Added clarity on which entities report and to whom events should be reported to.

**e. Third Posting – Formal Comment Period and Initial Ballot and Non-Binding Poll**

The third draft of the standard was posted for a public 45-day formal comment period from October 28, 2011 to December 12, 2011, and included an initial ballot and non-binding poll from December 2, 2011 to December 12, 2011. A mapping document and the VRF/VSL justification document were provided to aid in the review. The initial ballot for the draft of EOP-004-2 received a quorum of 87.97% and a 36.21% approval. The non-binding poll received a quorum of 85.28% and a 45% approval. The drafting team received 76 sets of comments from 171 individuals from 140 different companies representing nine of the ten industry segments. As a result of the comments, the drafting team made changes to the draft standard including:

- Revised the purpose statement to remove ambiguous language “with the potential to impact reliability”;
- Revised Requirement R1 for clarity and matched the language more closely to FERC Order No. 693, Paragraph 471, and eliminated Part 1.2 and reworded Part 1.3 (now 1.2);
- Removed Part 1.4 and made Part 1.5 a new Requirement R4;
- Revised Requirement R4 and made it R3;
- Deleted Requirement R2 and merged with R3 to eliminate redundancy;
- Reformatted the table in Attachment 1 to separate one hour reporting requirements from 24-hour reporting requirements; and
- Revised the language and eliminated redundancy in types of events included in Attachment 1.

In response to comments on the third draft, the drafting team also addressed in depth the different processes and reasons for using either the DOE OE-417 form or EOP-004-2 Attachment 2 to report events, and why it was necessary for standard EOP-004-2 to retain Attachment 2 as a reporting option.

**f. Fourth Posting – Formal Comment Period and Successive Ballot and Non-Binding Poll**

The fourth draft of the EOP-004-2 standard was posted for a public formal comment period from April 25, 2012 to May 24, 2012 with a ten day successive ballot and non-binding poll held from May 15, 2012 to May 24, 2012. The mapping document, a “Consideration of Issues and Directives” document, a VRF/VSL justification document, and a proposed NERC Rules of Procedure Section 812 document were posted to assist in review. The successive ballot received a quorum of 84.43% and an approval of 46.18%. The non-binding poll results achieved a 79.95% quorum and a 52.67% supportive opinion. The drafting team received 87 sets of comments from 210 different people from approximately 135 different companies representing 9 of the 10 industry segments. Based on the comments received, NERC made the following changes to the draft standard:

- Removed the reporting of Cyber Security Incidents from EOP-004 and directed the team developing CIP-008-5 to retain this reporting;
- Removed Interchange Coordinator, Transmission Service Providers, Load-Serving Entity, Electric Reliability Organization and Regional Entity as Responsible Entities;
- Moved most of the “Background” Section language to the “Guidelines and Technical Basis” Section;
- Made minor language changes to the measures and the data retention section.
- Revised Attachment 2 to list events in the same order in which they appear in Attachment 1;
- Revised requirement R1 to include the Parts in the main body of the Requirement;
- Deleted Requirement R3 and R4 and established a new Requirement R3 to have the Registered Entity “validate” the contact information in the contact list(s) they may have for the events applicable to them;
- Updated Attachment 1 by assigning event titles and entity responsibilities.

In this iteration, the drafting team noted that NERC had initiated a new effort to forward event reports to applicable government authorities, so the proposed Section 812 of the NERC Rules of Procedure was no longer needed and was removed from the project. Due to suggestions received

during this comment period to improve the standard, the drafting team decided to post the standard for a second successive ballot period.<sup>39</sup>

**g. Fifth Posting – Formal Comment Period and Successive Ballot and Non-Binding Poll**

A fifth draft of the EOP-004-2 standard was posted for a 30-day public formal comment period from August 29, 2012 to September 27, 2012, with a second ten-day successive ballot and non-binding poll held during the last ten days of the comment period, from September 18, 2012 to September 27, 2012. The mapping document, the “Consideration of Issues and Directives” document, and the VRF/VSL justification document were posted to assist in review. The second successive ballot received a quorum of 78.54% and an approval of 63.40%, and the non-binding poll received a 72.59% quorum and a 63.05% supportive opinion. The drafting team received 56 sets of comments from 181 different people from 125 companies, representing 9 of the ten industry segments. In response to comments received, the drafting team made several changes:

- Added language to the Guidelines and Technical Basis section to clarify the applicability of Requirement R1 and R3 to Distribution Providers;
- Added language to the Guidelines and Technical Basis section to clarify that only one report per event is necessary for entities that are registered in several different categories of industry segments;
- Added clarifying language to Requirement R2 on 24-hour reporting; and
- Revised the VSL language for Requirement R1 to address the case in which the event reporting Operating Plan fails to include event types.

In response to the fifth round of comments, the drafting team explained that the investigation and analysis portions of the current mandatory and enforceable standards EOP-004-1 and CIP-001-2a will not be incorporated in EOP-004-2. Instead, the analysis provisions will be addressed in the NERC event analysis program upon regulatory approval of EOP-004-2.

---

<sup>39</sup> On July 30, 2012, the drafting team hosted a webinar in order to receive informal feedback and to explain proposed changes to the standard. The slides are available on the project page: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting\\_RF.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting_RF.html).



#### **h. Sixth Posting – Recirculation Ballot and Non-Binding Poll**

Given that EOP-004-2 failed the second successive ballot with 63.4% support, on October 22, 2012, the drafting team conducted an industry webinar to explain several issues, including the applicability to Distribution Providers, duplicative reporting, the role of the Paragraph 81 project and the reporting burden of the standard.<sup>40</sup>

The sixth and final draft of the EOP-004-2 standard was posted for a recirculation ballot and non-binding poll from October 24, 2012 to November 5, 2012. The standard received a quorum of 85.14% and an approval of 71.39%. The non-binding poll resulted in a quorum of 78.93% and an approval of 71.04%.

#### **i. Board of Trustees Approval of EOP-004-2**

The final proposed EOP-004-2 standard was presented to the NERC Board of Trustees on November 7, 2012. NERC staff provided a summary of the proposed standard, as well as a summary of minority issues and associated drafting team responses. The NERC Board of Trustees approved the standard, and NERC staff recommended that it be filed with applicable regulatory authorities.

---

<sup>40</sup> Slides from the webinar are available here: [http://www.nerc.com/docs/standards/dt/Disturbance\\_and\\_Sabotage\\_Reporting\\_Webinar\\_20121022\\_final.pdf](http://www.nerc.com/docs/standards/dt/Disturbance_and_Sabotage_Reporting_Webinar_20121022_final.pdf).

## VI. CONCLUSION

For the reasons set forth above, NERC respectfully requests that the Commission:

- approve the proposed EOP-004-2 Reliability Standard included in **Exhibit B**, effective as proposed herein;
- approve the implementation plan included in **Exhibit C**;
- approve the retirement of Reliability Standards, effective as proposed herein.

Respectfully submitted,

*/s/ Stacey Tyrewala*

Gerald W. Cauley  
President and Chief Executive Officer  
North American Electric Reliability  
Corporation  
3353 Peachtree Road, N.E.  
Suite 600, North Tower  
Atlanta, GA 30326  
(404) 446-2560  
(404) 446-2595– facsimile

Charles A. Berardesco  
Senior Vice President and General Counsel  
Holly A. Hawkins  
Assistant General Counsel  
Stacey Tyrewala  
Attorney  
North American Electric Reliability  
Corporation  
1325 G Street, N.W., Suite 600  
Washington, D.C. 20005  
(202) 400-3000  
(202) 644-8099– facsimile  
[charlie.berardesco@nerc.net](mailto:charlie.berardesco@nerc.net)  
[holly.hawkins@nerc.net](mailto:holly.hawkins@nerc.net)  
[stacey.tyrewala@nerc.net](mailto:stacey.tyrewala@nerc.net)

*Counsel for the North American Electric  
Reliability Corporation*

**December 31, 2012**

**CERTIFICATE OF SERVICE**

I hereby certify that I have served a copy of the foregoing document upon all parties listed on the official service list compiled by the Secretary in this proceeding.

Dated at Washington, D.C. this 31st day of December, 2012.

*/s/ Stacey Tyrewala*  
Stacey Tyrewala  
*Attorney for North American Electric  
Reliability Corporation*

**Exhibit A**

Order No. 672 Criteria

## EXHIBIT A

### Order No. 672 Criteria

In Order No. 672,<sup>1</sup> the Commission identified a number of criteria it will use to analyze Reliability Standards proposed for approval to ensure they are just, reasonable, not unduly discriminatory or preferential, and in the public interest. The discussion below identifies these factors and explains how the proposed Reliability Standard has met or exceeded the criteria:

**1. Proposed Reliability Standards must be designed to achieve a specified reliability goal and must contain a technically sound means to achieve that goal.<sup>2</sup>**

The proposed standard achieves the specific reliability goal of ensuring that events that may impact the reliability of the Bulk Electric System are reported. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the Bulk Electric System. The

---

<sup>1</sup> *Rules Concerning Certification of the Electric Reliability Organization; and Procedures for the Establishment, Approval, and Enforcement of Electric Reliability Standards*, Order No. 672, FERC Stats. & Regs. ¶ 31,204, *order on reh'g*, Order No. 672-A, FERC Stats. & Regs. ¶ 31,212 (2006).

<sup>2</sup> Order No. 672 at P 321. The proposed Reliability Standard must address a reliability concern that falls within the requirements of section 215 of the FPA. That is, it must provide for the reliable operation of Bulk-Power System facilities. It may not extend beyond reliable operation of such facilities or apply to other facilities. Such facilities include all those necessary for operating an interconnected electric energy transmission network, or any portion of that network, including control systems. The proposed Reliability Standard may apply to any design of planned additions or modifications of such facilities that is necessary to provide for reliable operation. It may also apply to Cybersecurity protection.

Order No. 672 at P 324. The proposed Reliability Standard must be designed to achieve a specified reliability goal and must contain a technically sound means to achieve this goal. Although any person may propose a topic for a Reliability Standard to the ERO, in the ERO's process, the specific proposed Reliability Standard should be developed initially by persons within the electric power industry and community with a high level of technical expertise and be based on sound technical and engineering criteria. It should be based on actual data and lessons learned from past operating incidents, where appropriate. The process for ERO approval of a proposed Reliability Standard should be fair and open to all interested persons.

inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical attack. The proposed Reliability Standard includes clear criteria for reporting and consistent reporting timelines.

**2. Proposed Reliability Standards must be applicable only to users, owners and operators of the bulk power system, and must be clear and unambiguous as to what is required and who is required to comply.<sup>3</sup>**

The proposed revisions to this Reliability Standard apply to the following Functional Entities: Reliability Coordinators; Balancing Authorities; Transmission Owners; Transmission Operators; Generator Owners; Generator Operators; and Distribution Providers. Section 4.1 of proposed Reliability Standard EOP-004-2 is clear and unambiguous as to who is required to comply, in accordance with Order No. 672. Further, Requirements R1 through R3 are clear and unambiguous as to what is required, in accordance with Order No. 672. Requirements R1 through R3 provide clear criteria for reporting and consistent reporting timelines and provide clarity around who will receive the information.

**3. A proposed Reliability Standard must include clear and understandable consequences and a range of penalties (monetary and/or non-monetary) for a violation.<sup>4</sup>**

The VRFs and VSLs for the proposed standard comport with NERC and Commission guidelines related to their assignment. The assignment of the severity level for each VSL is consistent with the corresponding Requirement and the VSLs should

---

<sup>3</sup> Order No. 672 at P 322. The proposed Reliability Standard may impose a requirement on any user, owner, or operator of such facilities, but not on others.

Order No. 672 at P 325. The proposed Reliability Standard should be clear and unambiguous regarding what is required and who is required to comply. Users, owners, and operators of the Bulk-Power System must know what they are required to do to maintain reliability.

<sup>4</sup> Order No. 672 at P 326. The possible consequences, including range of possible penalties, for violating a proposed Reliability Standard should be clear and understandable by those who must comply.

ensure uniformity and consistency in the determination of penalties. The VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations. For these reasons, the proposed Reliability Standard includes clear and understandable consequences in accordance with Order No. 672.

**4. A proposed Reliability Standard must identify clear and objective criterion or measure for compliance, so that it can be enforced in a consistent and non-preferential manner.**<sup>5</sup>

The proposed Reliability Standard contains measures that support each requirement by clearly identifying what is required and how the requirement will be enforced. These measures help provide clarity regarding how the requirements will be enforced, and ensure that the requirements will be enforced in a clear, consistent, and non-preferential manner and without prejudice to any party.

**5. Proposed Reliability Standards should achieve a reliability goal effectively and efficiently — but do not necessarily have to reflect “best practices” without regard to implementation cost or historical regional infrastructure design.**<sup>6</sup>

The proposed Reliability Standard achieves its reliability goals effectively and efficiently in accordance with Order No. 672. The proposed standard requires Functional Entities to report incidents and provide known information at the time of the report and also includes an illustrated example of a reporting process in an attached flowchart.

**6. Proposed Reliability Standards cannot be “lowest common denominator,”**

---

<sup>5</sup> Order No. 672 at P 327. There should be a clear criterion or measure of whether an entity is in compliance with a proposed Reliability Standard. It should contain or be accompanied by an objective measure of compliance so that it can be enforced and so that enforcement can be applied in a consistent and non-preferential manner.

<sup>6</sup> Order No. 672 at P 328. The proposed Reliability Standard does not necessarily have to reflect the optimal method, or “best practice,” for achieving its reliability goal without regard to implementation cost or historical regional infrastructure design. It should however achieve its reliability goal effectively and efficiently.

***i.e.*, cannot reflect a compromise that does not adequately protect Bulk-Power System reliability. Proposed Reliability Standards can consider costs to implement for smaller entities, but not at consequences of less than excellence in operating system reliability.<sup>7</sup>**

The proposed Reliability Standard does not reflect a “lowest common denominator” approach. To the contrary, the proposed standard represents a significant improvement over the previous version as described herein. Specifically, Attachment 1 provides greater clarity of the types of events that are to be reported as compared to the previous version of the standard.

**7. Proposed Reliability Standards must be designed to apply throughout North America to the maximum extent achievable with a single Reliability Standard while not favoring one geographic area or regional model. It should take into account regional variations in the organization and corporate structures of transmission owners and operators, variations in generation fuel type and ownership patterns, and regional variations in market design if these affect the proposed Reliability Standard.<sup>8</sup>**

The proposed Reliability Standard, EOP-004-2, applies throughout North America and does not favor one geographic area or regional model.

---

<sup>7</sup> Order No. 672 at P 329. The proposed Reliability Standard must not simply reflect a compromise in the ERO’s Reliability Standard development process based on the least effective North American practice — the so-called “lowest common denominator” — if such practice does not adequately protect Bulk-Power System reliability. Although FERC will give due weight to the technical expertise of the ERO, we will not hesitate to remand a proposed Reliability Standard if we are convinced it is not adequate to protect reliability.

Order No. 672 at P 330. A proposed Reliability Standard may take into account the size of the entity that must comply with the Reliability Standard and the cost to those entities of implementing the proposed Reliability Standard. However, the ERO should not propose a “lowest common denominator” Reliability Standard that would achieve less than excellence in operating system reliability solely to protect against reasonable expenses for supporting this vital national infrastructure. For example, a small owner or operator of the Bulk-Power System must bear the cost of complying with each Reliability Standard that applies to it.

<sup>8</sup> Order No. 672 at P 331. A proposed Reliability Standard should be designed to apply throughout the interconnected North American Bulk-Power System, to the maximum extent this is achievable with a single Reliability Standard. The proposed Reliability Standard should not be based on a single geographic or regional model but should take into account geographic variations in grid characteristics, terrain, weather, and other such factors; it should also take into account regional variations in the organizational and corporate structures of transmission owners and operators, variations in generation fuel type and ownership patterns, and regional variations in market design if these affect the proposed Reliability Standard.



**8. Proposed Reliability Standards should cause no undue negative effect on competition or restriction of the grid beyond any restriction necessary for reliability.<sup>9</sup>**

The proposed Reliability Standard does not restrict the available transmission capability or limit use of the Bulk-Power System in a preferential manner.

**9. The implementation time for the proposed Reliability Standard is reasonable.<sup>10</sup>**

The proposed effective dates for the standard are just and reasonable and appropriately balance the urgency in the need to implement the standards against the reasonableness of the time allowed for those who must comply to develop necessary procedures, software, facilities, staffing or other relevant capability.

The implementation plan proposes that EOP-004-2 become effective: (i) in those jurisdictions where regulatory approval is required, on the on the first day of the first calendar quarter that is six months after applicable regulatory approval, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities; and (ii) in those jurisdictions where no regulatory approval is required, on the first day of the first calendar quarter that is six months beyond the date the standard is approved by the Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

---

<sup>9</sup> Order No. 672 at P 332. As directed by section 215 of the FPA, FERC itself will give special attention to the effect of a proposed Reliability Standard on competition. The ERO should attempt to develop a proposed Reliability Standard that has no undue negative effect on competition. Among other possible considerations, a proposed Reliability Standard should not unreasonably restrict available transmission capability on the Bulk-Power System beyond any restriction necessary for reliability and should not limit use of the Bulk-Power System in an unduly preferential manner. It should not create an undue advantage for one competitor over another.

<sup>10</sup> Order No. 672 at P 333. In considering whether a proposed Reliability Standard is just and reasonable, FERC will consider also the timetable for implementation of the new requirements, including how the proposal balances any urgency in the need to implement it against the reasonableness of the time allowed for those who must comply to develop the necessary procedures, software, facilities, staffing or other relevant capability.

This will allow applicable entities adequate time to ensure compliance with the requirements. The proposed effective dates are explained in the proposed Implementation Plan, attached as **Exhibit C**.

**10. The Reliability Standard was developed in an open and fair manner and in accordance with the Commission-approved Reliability Standard development process.<sup>11</sup>**

The proposed Reliability Standard was developed in accordance with NERC's Commission-approved, ANSI- accredited processes for developing and approving Reliability Standards. Section V, *Summary of the Reliability Standard Development Proceedings*, details the processes followed to develop the standard (for a more thorough review, please see the complete development history included as **Exhibit F**).

These processes included, among other things, multiple comment periods, pre-ballot review periods, and balloting periods. Additionally, all drafting team meetings were properly noticed and open to the public. The initial and recirculation ballots both achieved a quorum and exceeded the required ballot pool approval levels.

**11. NERC must explain any balancing of vital public interests in the development of proposed Reliability Standards.<sup>12</sup>**

NERC has identified no competing public interests regarding the request for approval of this proposed Reliability Standard. No comments were received that indicated the proposed standard conflicts with other vital public interests.

---

<sup>11</sup> Order No. 672 at P 334. Further, in considering whether a proposed Reliability Standard meets the legal standard of review, we will entertain comments about whether the ERO implemented its Commission-approved Reliability Standard development process for the development of the particular proposed Reliability Standard in a proper manner, especially whether the process was open and fair. However, we caution that we will not be sympathetic to arguments by interested parties that choose, for whatever reason, not to participate in the ERO's Reliability Standard development process if it is conducted in good faith in accordance with the procedures approved by FERC.

<sup>12</sup> Order No. 672 at P 335. Finally, we understand that at times development of a proposed Reliability Standard may require that a particular reliability goal must be balanced against other vital public interests, such as environmental, social and other goals. We expect the ERO to explain any such balancing in its application for approval of a proposed Reliability Standard.

**12. Proposed Reliability Standards must consider any other appropriate factors.<sup>13</sup>**

No other negative factors relevant to whether the proposed Reliability Standard is just and reasonable were identified.

---

<sup>13</sup> Order No. 672 at P 323. In considering whether a proposed Reliability Standard is just and reasonable, we will consider the following general factors, as well as other factors that are appropriate for the particular Reliability Standard proposed.

**Exhibit B**

Proposed Reliability Standard EOP-004-2 Submitted for Approval

### A. Introduction

- 1. Title:** Event Reporting
- 2. Number:** EOP-004-2
- 3. Purpose:** To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.
- 4. Applicability:**
  - 4.1. Functional Entities:** For the purpose of the Requirements and the EOP-004 Attachment 1 contained herein, the following functional entities will be collectively referred to as “Responsible Entity.”
    - 4.1.1.** Reliability Coordinator
    - 4.1.2.** Balancing Authority
    - 4.1.3.** Transmission Owner
    - 4.1.4.** Transmission Operator
    - 4.1.5.** Generator Owner
    - 4.1.6.** Generator Operator
    - 4.1.7.** Distribution Provider

### 5. Effective Dates:

The first day of the first calendar quarter that is six months beyond the date that this standard is approved by applicable regulatory authorities. In those jurisdictions where regulatory approval is not required, the standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the NERC Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

### 6. Background:

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient Bulk Electric System reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

### **B. Requirements and Measures**

- R1.** Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the Regional Entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). *[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]*
  
- M1.** Each Responsible Entity will have a dated event reporting Operating Plan that includes, but is not limited to the protocol(s) and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1 and in accordance with the entity responsible for reporting.
  
- R2.** Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*
  
- M2.** Each Responsible Entity will have as evidence of reporting an event, copy of the completed EOP-004-2 Attachment 2 form or a DOE-OE-417 form; and evidence of submittal (e.g., operator log or other operating documentation, voice recording, electronic mail message, or confirmation of facsimile) demonstrating the event report was submitted within 24 hours of recognition of meeting the threshold for reporting or by the

end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). (R2)

- R3.** Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. [*Violation Risk Factor: Medium*] [*Time Horizon: Operations Planning*]
- M3.** Each Responsible Entity will have dated records to show that it validated all contact information contained in the Operating Plan each calendar year. Such evidence may include, but are not limited to, dated voice recordings and operating logs or other communication documentation. (R3)

### C. Compliance

#### 1. Compliance Monitoring Process

##### 1.1 Compliance Enforcement Authority

The Regional Entity shall serve as the Compliance Enforcement Authority (CEA) unless the applicable entity is owned, operated, or controlled by the Regional Entity. In such cases the ERO or a Regional Entity approved by FERC or other applicable governmental authority shall serve as the CEA.

##### 1.2 Evidence Retention

The Responsible Entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

- Each Responsible Entity shall retain the current Operating Plan plus each version issued since the last audit for Requirements R1, and Measure M1.
- Each Responsible Entity shall retain evidence of compliance since the last audit for Requirements R2, R3 and Measure M2, M3.

If a Responsible Entity is found non-compliant, it shall keep information related to the non-compliance until mitigation is complete and approved or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

**1.3 Compliance Monitoring and Enforcement Processes:**

Compliance Audit

Self-Certification

Spot Checking

Compliance Investigation

Self-Reporting

Complaint

**1.4 Additional Compliance Information**

None



Table of Compliance Elements

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	Operations Planning	Lower	The Responsible Entity had an Operating Plan, but failed to include one applicable event type.	The Responsible Entity had an Operating Plan, but failed to include two applicable event types.	The Responsible Entity had an Operating Plan, but failed to include three applicable event types.	The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.  OR The Responsible Entity failed to have an event reporting Operating Plan.

EOP-004-2 — Event Reporting

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R2	Operations Assessment	Medium	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 24 hours but less than or equal to 36 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to one entity identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 36 hours but less than or equal to 48 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to two entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours but less than or equal to 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to three entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to four or more entities identified in its event reporting Operating Plan within 24 hours.</p> <p>OR</p> <p>The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R3	Operations Planning	Medium	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by less than one calendar month.</p> <p>OR</p> <p>The Responsible Entity validated 75% but less than 100% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by one calendar month or more but less than two calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 50% and less than 75% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by two calendar months or more but less than three calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 25% and less than 50% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by three calendar months or more.</p> <p>OR</p> <p>The Responsible Entity validated less than 25% of contact information contained in the Operating Plan.</p>

**D. Variances**

None.

**E. Interpretations**

None.

**F. References**

Guideline and Technical Basis (attached)

**EOP-004 - Attachment 1: Reportable Events**

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R2 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: [systemawareness@nerc.net](mailto:systemawareness@nerc.net), Facsimile 404-446-9770 or Voice: 404-446-9780.

**Submit EOP-004 Attachment 2 (or DOE-OE-417) pursuant to Requirements R1 and R2.**

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Damage or destruction of a Facility	RC, BA, TOP	Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency.
Damage or destruction of a Facility	BA, TO, TOP, GO, GOP, DP	Damage or destruction of its Facility that results from actual or suspected intentional human action.
Physical threats to a Facility	BA, TO, TOP, GO, GOP, DP	Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility. OR Suspicious device or activity at a Facility. Do not report theft unless it degrades normal operation of a Facility.

**EOP-004-2 — Event Reporting**

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Physical threats to a BES control center	RC, BA, TOP	Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center. OR Suspicious device or activity at a BES control center.
BES Emergency requiring public appeal for load reduction	Initiating entity is responsible for reporting	Public appeal for load reduction event.
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more.
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq$ 100 MW.
BES Emergency resulting in automatic firm load shedding	DP, TOP	Automatic firm load shedding $\geq$ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS).
Voltage deviation on a Facility	TOP	Observed within its area a voltage deviation of $\pm$ 10% of nominal voltage sustained for $\geq$ 15 continuous minutes.

**EOP-004-2 — Event Reporting**

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)	RC	Operate outside the IROL for time greater than IROL $T_v$ (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only).
Loss of firm load	BA, TOP, DP	Loss of firm load for $\geq 15$ Minutes: $\geq 300$ MW for entities with previous year's demand $\geq 3,000$ OR $\geq 200$ MW for all other entities
System separation (islanding)	RC, BA, TOP	Each separation resulting in an island $\geq 100$ MW
Generation loss	BA, GOP	Total generation loss, within one minute, of : $\geq 2,000$ MW for entities in the Eastern or Western Interconnection OR $\geq 1,000$ MW for entities in the ERCOT or Quebec Interconnection
Complete loss of off-site power to a nuclear generating plant (grid supply)	TO, TOP	Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement

## EOP-004-2 — Event Reporting

---

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Transmission loss	TOP	Unexpected loss within its area, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).
Unplanned BES control center evacuation	RC, BA, TOP	Unplanned evacuation from BES control center facility for 30 continuous minutes or more.
Complete loss of voice communication capability	RC, BA, TOP	Complete loss of voice communication capability affecting a BES control center for 30 continuous minutes or more.
Complete loss of monitoring capability	RC, BA, TOP	Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (i.e., State Estimator or Contingency Analysis) is rendered inoperable.

EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004 Attachment 2: Event Reporting Form</b>			
<p>Use this form to report events. The Electric Reliability Organization will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> , Facsimile 404-446-9770 or voice: 404-446-9780.</p>			
Task	Comments		
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):		
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:		
3.	Did the event originate in your system?      Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>		
4.	<p style="text-align: center;"><b>Event Identification and Description:</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; vertical-align: top;">                             (Check applicable box)  <input type="checkbox"/> Damage or destruction of a Facility  <input type="checkbox"/> Physical Threat to a Facility  <input type="checkbox"/> Physical Threat to a control center  <input type="checkbox"/> BES Emergency:                                  <input type="checkbox"/> public appeal for load reduction                                  <input type="checkbox"/> system-wide voltage reduction                                  <input type="checkbox"/> manual firm load shedding                                  <input type="checkbox"/> automatic firm load shedding  <input type="checkbox"/> Voltage deviation on a Facility  <input type="checkbox"/> IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)  <input type="checkbox"/> Loss of firm load  <input type="checkbox"/> System separation  <input type="checkbox"/> Generation loss  <input type="checkbox"/> Complete loss of off-site power to a nuclear generating plant (grid supply)  <input type="checkbox"/> Transmission loss  <input type="checkbox"/> unplanned control center evacuation  <input type="checkbox"/> Complete loss of voice communication capability  <input type="checkbox"/> Complete loss of monitoring capability                         </td> <td style="width: 50%; vertical-align: top;">                             Written description (optional):                         </td> </tr> </table>	(Check applicable box) <input type="checkbox"/> Damage or destruction of a Facility <input type="checkbox"/> Physical Threat to a Facility <input type="checkbox"/> Physical Threat to a control center <input type="checkbox"/> BES Emergency: <input type="checkbox"/> public appeal for load reduction <input type="checkbox"/> system-wide voltage reduction <input type="checkbox"/> manual firm load shedding <input type="checkbox"/> automatic firm load shedding <input type="checkbox"/> Voltage deviation on a Facility <input type="checkbox"/> IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only) <input type="checkbox"/> Loss of firm load <input type="checkbox"/> System separation <input type="checkbox"/> Generation loss <input type="checkbox"/> Complete loss of off-site power to a nuclear generating plant (grid supply) <input type="checkbox"/> Transmission loss <input type="checkbox"/> unplanned control center evacuation <input type="checkbox"/> Complete loss of voice communication capability <input type="checkbox"/> Complete loss of monitoring capability	Written description (optional):
(Check applicable box) <input type="checkbox"/> Damage or destruction of a Facility <input type="checkbox"/> Physical Threat to a Facility <input type="checkbox"/> Physical Threat to a control center <input type="checkbox"/> BES Emergency: <input type="checkbox"/> public appeal for load reduction <input type="checkbox"/> system-wide voltage reduction <input type="checkbox"/> manual firm load shedding <input type="checkbox"/> automatic firm load shedding <input type="checkbox"/> Voltage deviation on a Facility <input type="checkbox"/> IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only) <input type="checkbox"/> Loss of firm load <input type="checkbox"/> System separation <input type="checkbox"/> Generation loss <input type="checkbox"/> Complete loss of off-site power to a nuclear generating plant (grid supply) <input type="checkbox"/> Transmission loss <input type="checkbox"/> unplanned control center evacuation <input type="checkbox"/> Complete loss of voice communication capability <input type="checkbox"/> Complete loss of monitoring capability	Written description (optional):		



### Guideline and Technical Basis

#### Distribution Provider Applicability Discussion

The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more than 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.

#### Multiple Reports for a Single Organization

For entities that have multiple registrations, the DSR SDT intends that these entities will only have to submit one report for any individual event. For example, if an entity is registered as a Reliability Coordinator, Balancing Authority and Transmission Operator, the entity would only submit one report for a particular event rather submitting three reports as each individual registered entity.

#### Summary of Key Concepts

The DSR SDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the Bulk Electric System
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to

reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1 pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. EOP-004 Attachment 1 covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.

The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time communication is achieved is covered in other standards. The proposed standard deals exclusively with after-the-fact reporting.

### **Data Gathering**

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### **Law Enforcement Reporting**

The reliability objective of EOP-004-2 is to improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical attack. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### **Stakeholders in the Reporting Process**

- Industry

- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at a Facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. These requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, Responsible Entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF

coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**


A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

### **Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts**

#### **Introduction**

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### **Summary of Concepts and Assumptions:**

##### ***The Standard:***

- Requires reporting of “events” that impact or may impact the reliability of the Bulk Electric System
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

##### **Discussion of Disturbance Reporting**

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.

3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (EOP-004 Attachment 1).

### **Discussion of Event Reporting**

There are situations worthy of reporting because they have the potential to impact reliability.

Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- Train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center)
- Destruction of Bulk Electric System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: *“. . . the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.”*

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electric System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering necessary for event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in EOP-004 Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be sent to the NERC in lieu of entering that information on the NERC report.

### **Rationale:**

During development of this standard, text boxes were embedded within the standard to explain the rationale for various parts of the standard. Upon BOT approval, the text from the rationale text boxes was moved to this section.

### **Rationale for R1:**

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; e.g., Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC Events Analysis Program. These other parties use this information to promote reliability, develop a culture of reliability excellence, provide industry collaboration and promote a learning organization.

Every Registered Entity that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on



how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective. The communication protocol(s) could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information. An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.

### **Rationale for R2:**

Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004-2 Attachment 1. By implementing the event reporting Operating Plan the Responsible Entity will assure situational awareness to the Electric Reliability Organization so that they may develop trends and prepare for a possible next event and mitigate the current event. This will assure that the BES remains secure and stable by mitigation actions that the Responsible Entity has within its function. By communicating events per the Operating Plan, the Responsible Entity will assure that people/agencies are aware of the current situation and they may prepare to mitigate current and further events.

### **Rationale for R3:**

Requirement 3 calls for the Responsible Entity to validate the contact information contained in the Operating Plan each calendar year. This requirement helps ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.

### **Rationale for EOP-004 Attachment 1:**

The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:

“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”

The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

### Version History

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting.	Revision to entire standard (Project 2009-01)
2	November 7, 2012	Adopted by the NERC Board of Trustees	

## **Exhibit C**

Implementation Plan for Proposed Reliability Standard EOP-004-2 Submitted for Approval

## Implementation Plan

### Project 2009-01 Disturbance and Sabotage Reporting

#### Implementation Plan for EOP-004-2 – Event Reporting

##### *Approvals Required*

EOP-004-2 – Event Reporting

##### *Prerequisite Approvals*

None

##### *Revisions to Glossary Terms*

None

##### *Applicable Entities*

Reliability Coordinator  
Balancing Authority  
Transmission Owner  
Transmission Operator  
Generator Owner  
Generator Operator  
Distribution Provider

##### *Conforming Changes to Other Standards*

None

##### *Effective Dates*

In those jurisdictions where regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months after applicable regulatory approval or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

*Retirements*

**EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting** should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.

## **Exhibit D**

### Consideration of Comments

## Project 2009-01 Disturbance and Sabotage Reporting

### Related Files

**Status:**

Adopted by the Board of Trustees on November 6, 2012, pending regulatory approval.

**Background:**

This project will entail revision to the following existing standards:

- CIP-001-1 – Sabotage Reporting
- EOP-004-1 – Disturbance Reporting

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Draft	Action	Dates	Results	Consideration of Comments
<p><b>Draft 6</b></p> <p><b>EOP-004-2</b>  <a href="#">Clean   Redline</a>  <a href="#">to last posted</a></p> <p>Implementation            Plan  <a href="#">Clean</a></p> <p><b>Supporting            Materials:</b>  <a href="#">Mapping</a></p>	<p>Recirculation Ballot            and Non-binding poll</p> <p style="text-align: center;"><a href="#">Info&gt;&gt;</a></p> <p style="text-align: center;"><a href="#">Vote&gt;&gt;</a></p>	<p>10/24/12 -            11/05/12            (closed)</p>	<p><a href="#">Summary&gt;&gt;</a></p> <p><a href="#">Ballot            Results&gt;&gt;</a></p> <p><a href="#">Non-binding            Poll            Results&gt;&gt;</a></p>	

<p>Document</p> <p>Consideration of Issues and Directives</p> <p>VRF/VSL Justification</p> <p>CIP-001-2a</p> <p>EOP-004-1</p>				
<p><b>Draft 5</b> EOP-004-2 Clean   Redline to Last Posted</p> <p>Implementation Plan Clean   Redline to Last Posted</p>	<p>Successive Ballot and Non-binding Poll</p> <p><a href="#">Info&gt;&gt;</a></p> <p><a href="#">Vote&gt;&gt;</a></p>	<p>09/18/12 - 09/27/12 (closed)</p>	<p><a href="#">Updated Summary&gt;&gt;</a></p> <p><a href="#">Ballot Results&gt;&gt;</a></p> <p><a href="#">Non-binding Poll Results&gt;&gt;</a></p>	
<p><b>Supporting Materials:</b></p> <p>Comment Form (Word)</p> <p>Mapping Document</p> <p>Consideration of Issues and Directives</p> <p>VRF/VSL Justification</p>	<p>Comment Period</p> <p><a href="#">Info&gt;&gt;</a></p> <p><a href="#">Submit Comments&gt;&gt;</a></p>	<p>08/29/12 - 09/27/12 (closed)</p>	<p><a href="#">Comments Received&gt;&gt;</a></p> <p><a href="#">Meeting Results&gt;&gt;</a></p>	<p>Consideration of Comments <b>(7)</b></p>



<p>CIP-001-2a</p> <p>EOP-004-1</p>				
<p><b>Draft 4</b> <b>EOP-004-2</b> Clean   Redline to Last Posted</p> <p><b>Supporting Materials:</b> Comment Form (Word)</p> <p>Implementation Plan Clean   Redline to Last Posted</p> <p>Mapping Document</p> <p>Consideration of Issues and Directives</p> <p>VRF/VSL Justification</p> <p>Proposed NERC RoP Section 812</p> <p>CIP-001-2a</p> <p>CIP-008-3</p> <p>EOP-004-1</p>	<p>Successive Ballot and Non-binding Poll</p> <p>Updated Info&gt;&gt; Info&gt;&gt;</p> <p>Vote&gt;&gt;</p>	<p>05/15/12- 05/24/12 (closed)</p>	<p>Summary&gt;&gt;</p> <p>Ballot Results&gt;&gt;</p> <p>Non-binding Poll Results&gt;&gt;</p>	
	<p>Comment Period Info&gt;&gt;</p> <p>Submit Comments&gt;&gt;</p>	<p>04/25/12 - 05/24/12 (closed)</p>	<p>Comments Received&gt;&gt;</p>	<p>Consideration of Comments <b>(6)</b></p>
<p><b>Draft 3</b> <b>EOP-004-2</b> Clean   Redline</p>	<p>Join Ballot Pools&gt;&gt;</p>	<p>10/28/11 - 11/28/11 (closed)</p>		
	<p>Formal Comment</p>	<p>10/28/11 -</p>	<p>Comments</p>	

<p>to Last Posted</p> <p><b>Supporting Materials:</b> Comment Form (Word)</p> <p>Implementation Plan Clean   Redline to Last Posted</p> <p>Mapping Document</p> <p>VRF/VSL Justification</p> <p>CIP-001-1</p> <p>EOP-004-1</p>	<p>Period</p> <p><a href="#">Info&gt;&gt;</a></p> <p><a href="#">Submit Comments&gt;&gt;</a></p> <p>Initial Ballot and Non-Binding Poll</p> <p><a href="#">Updated Info&gt;&gt;</a> <a href="#">Info&gt;&gt;</a></p> <p><a href="#">Vote&gt;&gt;</a></p>	<p>12/12/11 (closed)</p> <p>12/02/11 - 12/12/11 (closed)</p>	<p><a href="#">Received&gt;&gt;</a></p> <p><a href="#">Summary&gt;&gt;</a></p> <p><a href="#">Full Record&gt;&gt;</a></p> <p><a href="#">Non-Binding Poll Results&gt;&gt;</a></p>	<p>Consideration of Comments <b>(5)</b></p>
<p><b>Draft 2 EOP-004-2</b> clean   redline to last posted</p> <p><b>Supporting Materials:</b> Comment Form (Word)</p> <p>Implementation Plan</p> <p>CIP-001-1</p> <p>EOP-004-1</p>	<p><a href="#">Info&gt;&gt;</a></p> <p><a href="#">Formal Comment Period&gt;&gt;</a></p>	<p>03/09/11 - 04/08/11</p>	<p><a href="#">Comments Received&gt;&gt;</a></p>	<p>Consideration of Comments <b>(4)</b></p>
<p><b>Draft 1 EOP-004-2</b></p>	<p>Informal Comment</p>	<p>09/15/10 -</p>	<p><a href="#">Comments Received&gt;&gt;</a></p>	

<p>EOP-004-2</p> <p><b>Supporting Materials:</b> Comment Form (Word)</p> <p>Mapping Document</p>	<p>Period</p> <p><a href="#">Submit Comments&gt;&gt;</a></p> <p><a href="#">Info&gt;&gt;</a></p>	<p>10/15/10</p>		<p>Consideration of Comments <b>(3)</b></p>
<p>Concept Paper Supporting Disturbance and Sabotage Reporting</p> <p><a href="#">Concept Paper</a></p> <p><b>Supporting Materials:</b> Comment Form (Word) CIP-001-1 - Sabotage Reporting EOP-004-1 - Disturbance Reporting</p>	<p>Comment Period</p> <p><a href="#">Submit Comments&gt;&gt;</a></p> <p><a href="#">Info&gt;&gt;</a></p>	<p>03/17/10 - 04/16/10 (closed)</p>	<p><a href="#">Comments Received &gt;&gt;</a></p>	<p>Consideration of Comments <b>(2)</b></p>
<p>Nominations for Standard Drafting Team</p> <p><b>Supporting Materials:</b> Nomination Form (Word)</p>	<p><a href="#">Info&gt;&gt;</a></p> <p><a href="#">Submit Nomination&gt;&gt;</a></p>	<p>09/16/09 - 09/30/09 (closed)</p>		
<p>Draft 2</p>				

<p>Disturbance and Sabotage Reporting SAR 2</p> <p><a href="#">Clean   Redline to Last Posting</a></p>				
<p>Nominations for SAR Drafting Team</p> <p><b>Supporting Materials:</b> <a href="#">Nomination Form (Word)</a></p>	<p><a href="#">Info&gt;&gt;</a></p> <p><a href="#">Submit Nomination&gt;&gt;</a></p>	<p>04/29/09 - 05/13/09 (closed)</p>		
<p>Proposed SAR</p> <p><a href="#">Draft SAR Version 1</a></p> <p><b>Supporting Materials:</b> <a href="#">Comment Form (Word)</a></p>	<p>Comment Period</p> <p><a href="#">Info&gt;&gt;</a></p> <p><a href="#">Submit Comments&gt;&gt;</a></p>	<p>04/22/09 - 05/21/09 (closed)</p>	<p><a href="#">Comments Received&gt;&gt;</a></p>	<p><a href="#">Consideration of Comments(1)</a></p>

## Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

The Disturbance and Sabotage Reporting SAR Drafting Team (DSR SAR DT) thanks all commenters who submitted comments on the first draft SAR. The SAR was posted for a 30-day public comment period from April 22, 2009 through May 21, 2009. The stakeholders were asked to provide feedback on the documents through a special Electronic Comment Form. There were 40 sets of comments, including comments from more than 120 different people from over 60 companies representing 9 of the 10 Industry Segments as shown in the table on the following pages.

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

The majority of stakeholders agree that there is a reliability related need to support modifying CIP-001-1 and EOP-004-1. Of those stakeholders providing comments, they predominantly agreed with the reliability-related reason for the SAR but offered the following concerns:

- 1) Concerns with applicability of the requirements: The SAR DT notes that applicability will be determined by the final requirements that are written for the standard.
- 2) Concerns on combining the standards: The SAR DT notes that the Purpose of the SAR indicates that the standards *may* be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).
- 3) Concerns with the definition of sabotage and the inclusion of vandalism, thresholds for defining sabotage, etc.
- 4) Concerns on onerous or duplicative reporting: The Brief Description section of the SAR states "Specific references to the DOE form need to be eliminated". This should address its concerns.

The SAR DT does not feel that the SAR should be revised based on these comments. The SAR DT will forward these comments to the Standard Drafting Team for its consideration in the drafting of the standards.

The majority of stakeholders agree with the scope of the SAR. Several stakeholders offered suggestions for items to include in the SAR, however the SAR DT believes that these comments may be too prescriptive to include with the SAR. The team feels that inclusion of these types of comments would prevent the Standard Drafting Team from having the ability to develop standard(s) based on stakeholder consensus. The SAR DT will forward these comments to the Standard Drafting Team for its consideration. Some of the comments received include:

- 1) The inclusion of specific definitions in the SAR (operating personnel, sabotage events, obligations): The SAR DT believes that this would be too prescriptive and believe that this should be addressed by the Standard Drafting Team.
- 2) Consolidate documents covering reporting requirements: The SAR DT agrees and suggests that the Standard Drafting Team investigate a "one-stop-shopping" solution for the various reports required, including the DOE report.

Stakeholders did not identify any associated business practices for consideration under the SAR. One stakeholder identified a related standard that references multi-site sabotage. The team has included a reference to TOP-005, section 2.9 (Appendix 1) in the SAR under Related Standards. Two stakeholders suggested that Business Practices should not be considered in a standard. The SAR DT notes that standard development projects must not invalidate business practices that are already in place and aids in coordination with North American Energy Standards Board (NAESB).

Many stakeholders had comments regarding applicability of the two standards. Based on these comments, the SAR DT has added Transmission Owner, Generator Owner and Distribution Provider to the Applicability section of the SAR as *possible* entities in the standard(s) developed under this SAR as the Standard Drafting team may have a need to include them in the standard(s). The applicability of Load-Serving Entity or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process. The three main comments were:

- 1) Regional Reliability Organization applicability: Several commenters do not feel the RRO should be in the standards. The DSR SAR DT concurs and notes that the SAR states that "EOP-004 has some 'fill-in-the-blank' components to eliminate". This will remove the RRO from applicability.
- 2) Load-Serving Entity/Distribution Provider: Several stakeholders do not feel that the standards should be applicable to LSEs, but should apply to Distribution Providers. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.
- 3) Transmission Owner/Generator Owner: Several stakeholders have indicated a need to include the TO as an applicable entity. A couple of those would also include the GO. The SAR DT discussed the addition of the TO and GO. The team has a concern that there may be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.

Stakeholders provided many good comments that should be considered in the development of the standards under this project. The SAR DT does not believe that these comments require any significant revisions to the SAR, but will forward these comments to the Standard Drafting Team for its consideration in drafting the standard(s). The comments include:

- 1) Consolidation of reports: The SAR DT agrees with this concept and will forward the comment to the Standard Drafting Team for its consideration.
- 2) Concerns about pre-determination of combining CIP-001 and EOP-004 into one standard: The SAR states: CIP-001 may be merged with EOP-004 to eliminate redundancies. The two standards may be left separate.

- 3) Reporting criteria in multiple tables: The team agrees that it would be easier if there were only one table. Part of this scope of this project is to eliminate redundancies and make general improvements to the standard. The team also agrees that the requirements developed should be clear in their reliability objective.

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Gerry Adamski, at 609-452-8060 or at [gerry.adamski@nerc.net](mailto:gerry.adamski@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

---

<sup>1</sup> The appeals process is in the Reliability Standards Development Procedures: <http://www.nerc.com/standards/newstandardsprocess.html>.

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

---

**Index to Questions, Comments, and Responses**

1. Do you agree that there is a reliability-related reason to support modifying CIP-001-1 and EOP-004-1? If not, please explain in the comment area. ....12

2. Do you agree with the scope of the proposed SAR? If not, please explain what should be added or deleted to the proposed scope. ....20

3. Are you aware of any associated business practices that we should consider with this SAR? If yes, please explain in the comment area. ....38

4. CIP-001-1 applies to the Reliability Coordinator, Transmission Operator, Balancing Authority, Generator Operator, and the Load-serving Entity. EOP-004-1 applies to the same entities, plus the Regional Reliability Organization. Do you agree with the applicability of the existing CIP-001-1 and the existing EOP-004-1? If no, please identify what you believe should be modified.....43

5. If you have any other comments on the SAR or proposed modifications to CIP-001-1 and EOP-004-1 that you haven't provided in response to the previous questions, please provide them here. ....51



## Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	Jim Case	SERC OC Standards Review Group	X		X								
Additional Member		Additional Organization		Region			Segment Selection							
1.	Al McMeekin	SCE&G		SERC			1, 3, 5							
2.	Eugene Warnecke	Ameren		SERC			1, 3, 5							
3.	Gary Hutson	SMEPA		SERC			1, 3, 5							
4.	Melinda Montgomery	Entergy		SERC			1, 3							
5.	Tom Sims	Southern		SERC			1, 3, 5							
6.	Marc Butts	Southern		SERC			1, 3, 5							
7.	Chris Bradley	BREC		SERC			1, 3, 5							
8.	Tom Kanzlik	SCE&G		SERC			1, 3, 5							
9.	Paul Turner	Ga Systems Operations Corp.		SERC			3							
10.	Phil Creech	Progress Energy Carolinas		SERC			1, 3, 5							
11.	Vicky Budreau	SCPSA		SERC			1, 3, 5, 9							
12.	Renee Free	SCPSCA		SERC			9							
13.	Mike Clements	TVA		SERC			1, 3, 5, 9							
14.	Travis Sykes	TVA		SERC			1, 3, 5							

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

	Commenter	Organization	Industry Segment										
			1	2	3	4	5	6	7	8	9	10	
15.	John Troha	SERC	RFC							10			
2.	Group	Harry Tom	Project 2007-02 Operating Personnel Comms Protocols SDT	X	X			X				X	X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>					
1.	Lloyd Snyder	GSOC	SERC									1	
2.	Tom Irvine	HydroOne	NPCC									1, 9	
3.	Alan Allgower	ERCOT	ERCOT									10	
4.	Harvie Beavers	Colmac Clarion/Piney Creek LP	RFC									5	
5.	Mark L. Bradley	ITC	MRO									1	
6.	Mike Brost	JEA	FRCC									1	
7.	William D Ellard	CAISO	WECC									10	
8.	Ronald Goins	MISO	MRO									10	
9.	Leanne Harrison	PJM	RFC									10	
10.	James McGovern	ISO-NE	NPCC									10	
11.	Wayne Mitchell	Entergy	SERC									1	
12.	John Stephens	City Utilities of Springfield	RFC									1	
13.	Fred Waites	Southern Company	SERC									1	
3.	Group	Kenneth D. Brown	PSEG Enterprise Group Inc Companies	X		X							
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>					
1.	Clint Bogan	PSEG Fossil LLC	RFC									5	
2.	James Hebson	PSEG Energy Resources & Trade	RFC									6	
3.	Gary Grysko	PSEG Power Connecticut	NPCC									5	
4.	Dominic DiBari	PSEG Texas LLC	ERCOT									5	
4.	Group	Guy Zito	Northeast Power Coordinating Council										X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>					
1.	Ralph Rufrano	New York Power Authority	NPCC									5	
2.	Alan Adamson	New York State Reliability Council	NPCC									10	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

	Commenter	Organization	Industry Segment											
			1	2	3	4	5	6	7	8	9	10		
3.	Greg Campoli	New York Independent System Operator	NPCC								2			
4.	Roger Champagne	Hydro-Quebec TransEnergie	NPCC								2			
5.	Kurtis Chong	Independent Electricity System Operator	NPCC								2			
6.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC								1			
7.	Manuel Couto	National Grid	NPCC								1			
8.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC								1			
9.	Brian Evans-Mongeon	Utility Services	NPCC								8			
10.	Mike Garton	Dominion Resources Services, inc.	NPCC								5			
11.	Mike Gildea	Constellation Energy	NPCC								6			
12.	Brian Gooder	Ontario Power Generation Incorporated	NPCC								5			
13.	Kathleen Goodman	ISO - New England	NPCC								2			
14.	David Kiguel	Hydro One Networks, Inc.	NPCC								1			
15.	Michael Lombardi	Northeast Utilities	NPCC								1			
16.	Randy MacDonald	New Brunswick System Operator	NPCC								2			
17.	Bruce Metruck	New York Power Authority	NPCC								6			
18.	Robert Pellegrini	The United Illuminating Company	NPCC								1			
19.	Michael Schiavone	National Grid	NPCC								1			
20.	Michael Sonnelitter	FPL Energy/NextEra Energy	NPCC								5			
21.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC								3			
22.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC								10			
23.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC								10			
5.	Group	Michael Gammon	Kansas City Power & Light	X		X		X	X					
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>			<b>Segment Selection</b>							
1.	Joe Doetzl	Kansas City Power & Light	SPP								1, 3, 5, 6			
2.	John Breckenridge	Kansas City Power & Light	SPP								1, 3, 5, 6			
6.	Group	Ben Li	IRC Standards Review Committee		X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>			<b>Segment Selection</b>							

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

	Commenter	Organization	Industry Segment									
			1	2	3	4	5	6	7	8	9	10
1.	James Castle	NYISO	NPCC						2			
2.	Charles Yeung	SPP	SPP						2			
3.	Anita Lee	AESO	WECC						2			
4.	Matt Goldberg	ISO-NE	NPCC						2			
5.	Bill Phillips	MISO	MRO						2			
6.	Steve Myers	ERCOT	ERCOT						2			
7.	Lourdes Estrada-Salineró	CAISO	WECC						2			
7.	Group	Richard Kafka	Pepco Holdings, Inc. - Affiliates									
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>				<b>Segment Selection</b>					
1.	Kara Dundas	Conectiv Energy Supply, Inc.	RFC				5					
2.	Tony Gabrielli	Conectiv Energy Supply, Inc.	RFC				5					
3.	George Gacser	Potomac Electric Power Co.	RFC				1, 3, 5					
4.	E. W. Stowe	Pepco Holdings, Inc	RFC				1, 3, 5					
5.	Mark Godfrey	Pepco Holdings, Inc	RFC				1, 3					
8.	Group	Sam Ciccone	FirstEnergy									
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>				<b>Segment Selection</b>					
1.	Jim Eckels	FE	RFC				1					
2.	John Martinez	FE	RFC				1					
3.	John Reed	FE	RFC				1					
4.	Dave Folk	FE	RFC				1, 3, 4, 5, 6					
5.	Doug Hohlbaugh	FE	RFC				1, 3, 4, 5, 6					
6.	Larry Hartley	FE	RFC				3					
9.	Group	Jalal Babik	Electric Market Policy									
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>				<b>Segment Selection</b>					
1.	Louis Slade		SERC				6					
2.	Mike Garton		NPCC				5					

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
10.	Group	Denise Koehn	Bonneville Power Administration	X		X		X	X					
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>						<b>Segment Selection</b>				
		1. Theodore Snodgrass	Dispatch	WECC						1				
11.	Group	Michael Brytowski	MRO NERC Standards Review Subcommittee											X
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>						<b>Segment Selection</b>				
		1. Carol Gerou	MRO	MRO						10				
		2. Neal Balu	WPS	MRO						3, 4, 5, 6				
		3. Pam Sordet	XCEL	MRO						1, 3, 5, 6				
		4. Joe DePoorter	MGE	MRO						3, 4, 5, 6				
		5. Ken Goldsmith	ALTW	MRO						4				
		6. Jim Haigh	WAPA	MRO						1, 6				
		7. Terry Harbour	MEC	MRO						1, 3, 5, 6				
		8. Joseph Knight	GRE	MRO						1, 3, 5, 6				
		9. Scott Nickels	RPU	MRO						3, 4, 5, 6				
		10. Dave Rudolph	BEPC	MRO						1, 3, 5, 6				
		11. Eric Ruskamp	LES	MRO						1, 3, 5, 6				
12.	Individual	Stephen V. Fisher	Lands Energy Consulting											
13.	Individual	Brent Hebert	Calpine Corporation					X						
14.	Individual	Steve Toth	Covanta					X						
15.	Individual	Harvie Beavers	Colmac Clarion					X						
16.	Individual	Russell A. Noble	Cowlitz County PUD			X								
17.	Individual	Michael Puscas	United Illuminating	X		X								
18.	Individual	George Pettyjohn	Reliant Energy					X						

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

		Commenter	Organization	Industry Segment												
				1	2	3	4	5	6	7	8	9	10			
19.	Individual	Judith A. James	Texas Regional Entity													
20.	Individual	Edward C. Stein	self									X				
21.	Individual	Chris Scanlon	Exelon	X		X		X	X							
22.	Individual	Mike Davis	WECC													X
23.	Individual	Jimmy Hartmann	ERCOT ISO		X											
24.	Individual	Rick Terrill	Luminant Power					X								
25.	Individual	Rao Somayajula	ReliabilityFirst Corporation													X
26.	Individual	Tony Kroskey	Brazos Electric Power Cooperative, Inc.	X												
27.	Individual	Paul Golden	PacifiCorp	X		X		X	X							
28.	Individual	Terry Harbour	MidAmerican Energy	X												
29.	Individual	Darryl Curtis	Oncor Electric Delivery	X												
30.	Individual	Chris de Graffenried on behalf of Con Edison & O&R	Consolidated Edison Co. of New York, Inc.	X		X			X							
31.	Individual	Wayne Pourciau	Georgia System Operations Corp.			X										
32.	Individual	Bob Thomas	Illinois Municipal Electric Agency				X									
33.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X							
34.	Individual	Jim Sorrels	AEP	X		X		X	X							

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
35.	Individual	Greg Rowland	Duke Energy	X		X		X	X					
36.	Individual	Howard Rulf	We Energies			X	X	X						
37.	Individual	Jianmei Chai	Consumers Energy Company			X	X	X						
38.	Individual	Mike Sonnelitter	NextEra Energy Resources, LLC					X						
39.	Individual	D. Bryan Guy	Progress Energy	X		X		X						
40.	Individual	Kirit Shah	Ameren	X		X		X	X					

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**1. Do you agree that there is a reliability-related reason to support modifying CIP-001-1 and EOP-004-1? If not, please explain in the comment area.**

**Summary Consideration:** The majority of stakeholders agree that there is a reliability related need to support modifying CIP-001-1 and EOP-004-1. Of those stakeholders providing comments, they predominantly agreed with the reliability-related reason for the SAR but offered the following concerns:

- 1) Applicability of the requirements: The SAR DT notes that applicability will be determined by the final requirements that are written for the standard.
- 2) Combining the standards: The SAR DT notes that the Purpose of the SAR indicates that the standards *may* be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).
- 3) Definition of sabotage and the inclusion of vandalism, thresholds for defining sabotage, etc.
- 4) Onerous or duplicative reporting: The Brief Description section of the SAR states “Specific references to the DOE form need to be eliminated”. This should address any concerns.

The SAR DT will forward these comments to the Standard Drafting Team for its consideration in the drafting of the standards.

Organization	Yes or No	Question 1 Comment
SERC OC Standards Review Group	No	The EOP-004-1 standard is an unnecessary duplication of existing DOE reporting requirements. This essentially exposes an entity to fines by NERC, enforced by FERC, for failure to comply with a DOE regulation, which seems improper to us. In addition, reporting requirements do not have an impact on the reliability of the BES
<p><b>Response: The DSR SAR DT thanks you for your comment. The Brief Description section of the SAR states “Specific references to the DOE form need to be eliminated”.</b></p>		
MidAmerican Energy	No	MidAmerican Energy believes only EOP-004-1 is confusing and needs to be modified or clarified. There is no need to combine the two standards. Standard EOP-004 could be clarified to eliminate references to sabotage which are already covered by CIP-001-1. Standard EOP-004 should be strictly limited to system events, not sabotage.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT notes that the Purpose of the SAR indicates that the standards <i>may</i> be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting Team to make this determination through the Standard Development Process (with stakeholder input).</b></p>		



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
Bonneville Power Administration	No	Eliminating a single standard by consolidating two standards does not improve reliability. All of the defined actions are indeed being taken now.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT notes that the Purpose of the SAR indicates that the standards <i>may</i> be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).</b></p>		
Progress Energy	No	No. It is not clear that the issues listed in a revised standard will improve reliability. Revision based on redundancy is not sufficient reason for combination. Extensive documentation efforts have been made to comply with the current Standards. Unless combining these Standards provides compelling Reliability benefit, it is not worth the industry's resources to revise existing documentation and processes for the sake of eliminating redundancy. Redundancy issues were raised prior to the ERO adopting the initial Standard set into law. We have noted the other issues raised in the SAR, however, it is still unclear where the Reliability benefit of this SAR is evidenced.
<p><b>Response: The DSR SAR DT thanks you for your comment. Industry consensus indicates that eliminating redundancy between standards is required to avoid potential double jeopardy issues with compliance to the standards. Furthermore, one of the FERC Order 693 directives for CIP-001 is:</b></p> <p><b>Explore ways to reduce redundant reporting, including central coordination of sabotage reports and a uniform reporting format.</b></p>		
Kansas City Power & Light	Yes	Agree with the SAR that clarity would be helpful in establishing criteria regarding what constitutes sabotage reporting.
<p><b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for CIP-001 is:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p>		
Pepco Holdings, Inc. - Affiliates	Yes	PHI recommends merging these two standards into one.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT notes that the Purpose of the SAR indicates that the standards <i>may</i> be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).</b></p>		
Electric Market Policy	Yes	Comments: Agree with the statement that sabotage is hard to determine in real time by operations staffs. The determination of sabotage should be left up to law enforcement. They have the knowledge and peer contacts needed to adequately determine whether physical or cyber intrusions are merely malicious acts or coordinated efforts (sabotage).

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 1 Comment
		<p>The operators should only be required to report physical and cyber intrusions to law enforcement. All other reporting requirements should apply to law enforcement once a determination of sabotage has been made. If the recommendations above are not to be accepted, then we have the following comments:</p> <p>CIP-001-1</p> <p>1) R1 states entities shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection. The SAR notes that the industry objects to the multi-site requirement, most likely because the term is ambiguous. If this term remains in the standard, it needs to be clearly defined and responsibilities for obtaining (how do you get this information and from whom?) and distributing need to be included.</p> <p>2) R1 audits have shown confusion over the requirement to make operating personnel aware of sabotage events. The term operating personnel needs to be defined. Are they the individuals responsible for operating the facility, coordinating with other entities (i.e., RC, BA, TOP, GOP, and LSE)? It has been suggested that notification is required to all personnel at a facility. Keep in mind the purpose of the standard is to ensure sabotage events are properly reported, not to address emergency response.</p> <p>3) R1 The SAR (NERC Audit and Observation Team) notes that Registered Entities have processes and procedures in place, but not all personnel have been trained. There is no specific training requirement in the standard.</p> <p>4) R2 &amp; R3 I agree with the SAR that sabotage needs to be defined and these requirements should be more specific with respect to the information to be communicated. It seems to me that the standard should mirror the criteria contained in DOE OE-417. The emphasis should be placed on ensuring that the same information communicated to DOE is shared with the appropriate parties in the Interconnection.</p> <p>5) R4 I agree with the SAR (NERC Audit and Observation Team) comments regarding the intention of this requirement. There is no language that directs contact with FBI or RCMP although that is what is implied by the Purpose statement.</p> <p>6) VRF Comments I'm not sure what is intended by the statement Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures? The purpose of the standard is that of communication. No operational decisions or actions are directed by this standard, nor does it require entities to address operational aspects resulting from sabotage.</p> <p>7) The potential exists for overlapping sabotage reporting requirements at nuclear power plants due to multiple regulators (Nuclear Regulatory Commission (NRC) 10 CFR 73 and Federal Energy Regulatory Commission (FERC) NUC-001-1). Some entities may have revised existing NRC driven procedures to accommodate reporting requirements of both regulators. Because of the restrictions placed on NRC driven documents (i.e., procedures are classified as safeguards information), it can be difficult to demonstrate compliance to NERC and/or FERC without ensuring that the individuals are qualified for receipt of such information per 10 CFR 73. Additionally, multiple procedures may have the unintended consequence of delaying appropriate communication.EOP-004-1Consider removing Attachment 2 as the information is</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
		duplicated in DOE Form OE-417. A simple reference to the form should suffice.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team notes that your comments relate directly to potential revisions of the standard requirements. The team will pass your comments along to the Standards Drafting Team for its consideration. For item 4, one of the FERC Order 693 directives for CIP-001 is:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p>		
Lands Energy Consulting	Yes	<p>I have worked with 5 Northwest public utilities on developing procedures related to CIP-001-1 and EOP-004-1. All 5 utilities operate electric systems in fairly remote locations and are embedded in a larger utility's Balancing Authority/Transmission Operator area.</p> <p>A. CIP-001-1 - Developing procedures to unambiguously identify acts of sabotage has been particularly challenging for these systems. In general, it's hard for them to determine whether the most prevalent forms of malicious and intentional system damage that they incur - copper theft and gun shot insulators/equipment - should qualify as acts of sabotage. Although none of the systems consider copper theft to be acts of sabotage, two of the systems consider gun shot insulators/equipment to be acts of sabotage. The other systems look for intent to disrupt electric system operations as a key component of their sabotage identification procedures. Additional guidance from NERC in the form of CIP-001-1 modifications or a companion guidelines document on sabotage identification would provide much needed guidance for these procedures.</p> <p>B. EOP-004-1 - This standard was clearly drafted with the larger electric systems in mind. I have one client that serves 3300 commercial/residential customers from 4-115/13 kV substation transformers and one large industrial customer (80% of its energy load) from a 230/13 kV substation. 75% of the client's load is served from three substations attached to a long, 115 kV transmission line operated by the Bonneville Power Administration. Whenever the line relays open on a permanent fault (which happens 2-3 times per year), the client loses over 50% of its customers (but no more than 10-15 MW during winter peak), thereby necessitating the preparation of a Disturbance Report. To allow utilities to concentrate on operating their systems, without fear of violating EOP-004-1 for failure to report trivial outages, I would remove LSEs from the obligation to report disturbances - leave the reporting to the BA/TOP for large outages in their footprint.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>A. The team notes that your comments relate directly to potential revisions of the standard requirements. The team will pass your comments along to the Standards Drafting Team for its consideration.</b></p> <p><b>B. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process. The team</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
<b>will pass your comments along to the Standards Drafting Team for its consideration.</b>		
Calpine Corporation	Yes	Communication of facility status or emergencies between merchant generators registered as GOP and the RC, BA, GOP, or LSE in which the facility resides should be coordinated for EOP -004 reporting. The reporting to NERC/DOE should come from the RC, BA, GOP, or LSE.
<b>Response: The DSR SAR DT thanks you for your comment. The team concurs that reporting should be coordinated and will pass your comments along to the Standards Drafting Team for its consideration.</b>		
Covanta	Yes	Yes - the key to Sabotage reporting requirements is identifying what the 'definition' is of an actual or potential 'Sabotage' event. Like any other standard, if FERC/NERC leave it up to 2000+ entities to establish their own definitions of 'Sabotage', you may likely get 2000+ answers. That is not a controlled and coordinated approach. I offer the following definition, "Sabotage - Deliberate or malicious destruction of property, obstruction of normal operations, or injury to personnel by outside agents." Examples of sabotage events could include, but are not limited to, suspicious packages left near site electrical generating or electrical transmission assets, identified destruction of generating assets, telephone/e mail received threats to destroy or interrupt electrical generating efforts, etc." These have passed multiple NERC regional audits and reviews to date.
<b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for CIP-001 is: Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event. The team will pass your comments along to the Standards Drafting Team for its consideration.</b>		
Cowlitz County PUD	Yes	The standards as written now create reporting on local customer quality of service outage events not related to BPS disturbances. Sabotage reporting has degenerated into reporting of mischievous vandalism and minor theft occurrences. This creates compliance documentation overburden and waste of limited funds needed for true BPS reliability concerns, and also adds nuisance calls to the FBI and Homeland Security.
<b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for CIP-001 is: Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event. This should address the concern of sabotage vs. vandalism/theft reporting.</b>		
Reliant Energy	Yes	EOP-004-1 indicates that Generators should analyze disturbances on the bulk electrical system or their facilities. Generators do not have the capability of analyzing the bulk electrical system other than Frequency. Even so, generators can not unilaterally respond to what it thinks are disturbances. In the case of CAISO The Participating Generator

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
		Agreement prevents me from making any unilateral moves save for the direst frequency emergencies. If the System operator or Reliability Coordinator informs the generator that there is a disturbance and that logs and readouts etc. are required then the generator should respond with all available information for the subject hours or time. Clearer responsibilities provide clearer results.
<p><b>Response: The DSR SAR DT thanks you for your comment. While the team agrees that generators may not have the capability to analyze events, the team note that you concern is regarding applicability of requirements. The final wording of the requirements developed by the Standard Drafting Team will determine the applicability.</b></p>		
Georgia System Operations Corp.	Yes	There is a need to eliminate burdensome reporting deadlines which interfere with the reliable operations or recovery of the BES. There is also a need to move requirements for reporting to NERC or Regional Entities (except for reporting of threats to physical or cyber security) from the Requirements section of Reliability Standards to elsewhere.
<p><b>Response: The DSR SAR DT thanks you for your comment. Specific revisions to the requirements will be vetted during the standard development process.</b></p>		
Illinois Municipal Electric Agency	Yes	Simplification of reporting requirements should facilitate reliability.
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p>		
Duke Energy	Yes	We agree that additional clarity is needed regarding sabotage and disturbance reporting. Requirements should be tightened up and triggering events/thresholds of materiality need to be better defined.
<p><b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for this project is:</b> Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</p>		
MRO NERC Standards Review Subcommittee	Yes	
Colmac Clarion	Yes	
United Illuminating	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
PSEG Enterprise Group Inc Companies	Yes	
Northeast Power Coordinating Council	Yes	
IRC Standards Review Committee	Yes	
FirstEnergy	Yes	
Texas Regional Entity	Yes	
Edward C. Stein	Yes	
Exelon	Yes	
WECC	Yes	
ERCOT ISO	Yes	
Luminant Power	Yes	
ReliabilityFirst Corporation	Yes	
Brazos Electric Power Cooperative, Inc.	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
PacifiCorp	Yes	
Oncor Electric Delivery	Yes	
Consolidated Edison Co. of New York, Inc.	Yes	
Manitoba Hydro	Yes	
AEP	Yes	
We Energies	Yes	
Consumers Energy Company	Yes	
NextEra Energy Resources, LLC	Yes	
Ameren	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

2. Do you agree with the scope of the proposed SAR? If not, please explain what should be added or deleted to the proposed scope.

**Summary Consideration:** The majority of stakeholders agree with the scope of the SAR. Several stakeholders offered suggestions for items to include in the SAR, however the SAR DT believes that these comments may be too prescriptive to include with the SAR. The team feels that inclusion of these types of comments would prevent the Standard Drafting Team from having the ability to develop standard(s) based on stakeholder consensus. The SAR DT will forward these comments to the Standard Drafting Team for its consideration. Some of the comments received include:

- 1 The inclusion of specific definitions in the SAR (operating personnel, sabotage events, obligations): The SAR DT believes that this would be too prescriptive and believe that this should be addressed by the Standard Drafting Team.
- 2 Consolidate documents covering reporting requirements: The SAR DT agrees and suggests that the Standard Drafting Team investigate a “one-stop-shopping” solution for the various reports required, including the DOE report.

Organization	Yes or No	Question 2 Comment
Project 2007-02 Operating Personnel Comms Protocols SDT	No	<p>The Operating Personnel Communication Protocols standard drafting team respectfully requests that the Sabotage Reporting SAR Drafting Team incorporate the following into your proposed SAR: “Each Reliability Coordinator, Balancing Authority, and Transmission Operator shall have procedures for the communication of information concerning the Cyber and Physical emergency alerts in accordance with the conditions described in “Attachment 1 Security Emergency Alerts.”</p> <p>The Operating Personnel Communications Protocols Project 2007-02 was initiated to ensure that real time system operators use standardized communication protocols during normal and emergency operations to improve situational awareness and shorten response time. The SDT developed a new COM-003-1 Standard that has yet to be posted and is dependent upon revising at least two other standards (CIP-001 and TOP Standard).</p> <p>COM-003 contains requirements that specify:</p> <ol style="list-style-type: none"> <li>1. Use of three-part communication;</li> <li>2. English language;</li> <li>3. Common time zone;</li> <li>4. NATO alpha-numeric alphabet;</li> <li>5. Mutually agreed line identifiers;</li> <li>6. The use of pre-defined system condition terminology such as those contained in the RCWG Alert Level Guide and EOP-002-2.</li> </ol>



Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>This request is based on recent NERC Standards Committee direction to our team to incorporate the Reliability Coordinator Working Group’s (RCWG) Alert Level Guide into a Standard. The consensus of our team is that a TOP Standard is the most appropriate location for the Transmission Emergency Alert language from the Guide as the energy emergency alert language is currently described in EOP-002-2. The RCWG Guide proposes the use of pre-defined system condition descriptions for use during emergencies for reliability related formation. This guide was developed in response to a Blackout Report recommendation. Our team placed the Transmission Emergency Alert language into a TOP standard.</p> <p>Since the Sabotage Reporting SAR DT intends to modify CIP-001, we seek your consent to incorporate the cyber and physical security alert language to comply with the wishes of the Standards Committee. We believe that the CIP-001 Standard is the most appropriate location for this language for the following reasons:</p> <ul style="list-style-type: none"> <li>• The levels of emergency conditions related to the cyber and physical security of the electric system is directly related to Critical Infrastructure Protection.</li> <li>• The current version of CIP-001 already requires the timely reporting of actual and suspected security emergency conditions and the use of pre-defined terminology supports the efficient handling of such information.</li> </ul> <p>The OPCP SDT includes the following text for the record. It is a proposed draft revision of CIP-001.</p> <p><b>A. Introduction</b></p> <ol style="list-style-type: none"> <li>1. Title: Security Incidents</li> <li>2. Number: CIP-001-2</li> <li>3. Purpose: To ensure the recognition, communication and response to cyber and physical security incidents suspected or determined to be caused by sabotage.</li> <li>4. Applicability             <ol style="list-style-type: none"> <li>4.1. Reliability Coordinators.</li> <li>4.2. Balancing Authorities.</li> <li>4.3. Transmission Operators.</li> <li>4.4. Generator Operators.</li> <li>4.5. Load Serving Entities.</li> </ol> </li> <li>5. Effective Date: The standard is effective the first day of the first calendar quarter after applicable regulatory approvals (or the standard otherwise becomes effective the first day of the first calendar quarter after NERC OT adoption in those jurisdictions where regulatory approval is not required).</li> </ol>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p><b>B. Requirements</b></p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of security threats on its facilities and multi site security threats affecting larger portions of the Interconnection.</p> <p>R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning the physical and cyber security status of their facilities in accordance with the conditions described in Attachment 1-CIP-001-1.</p> <p>R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with security threat or incident response guidelines, including personnel to contact, for reporting security threats and incidents.</p> <p>R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.</p> <p><b>C. Measures</b></p> <p>M1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1</p> <p>M2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.</p> <p>M3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited o procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or CMP officials to communicate sabotage events (Requirement 4).</p> <p><b>D. Compliance</b></p> <p>1. Compliance Monitoring Process</p> <p>1.1. Compliance Enforcement Authority Regional Entity</p> <p>1.2. Compliance Monitoring Period and Reset</p> <p>One or more of the following methods will be used to verify compliance:</p> <p>- Compliance Audits</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<ul style="list-style-type: none"> <li>- Self-Certifications</li> <li>- Spot Checking</li> <li>- Compliance Violation Investigations</li> <li>- Self-Reporting</li> <li>- Complaints</li> </ul> <p>1.3. Data Retention</p> <p>The Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator and Distribution Provider shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:</p> <ul style="list-style-type: none"> <li>o The Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator and Distribution Provider shall retain its current, in force document and any documents in force since the last compliance audit.</li> <li>o If a Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator or Distribution Provider is found non-compliant, it shall keep information related to the non-compliance until found compliant.</li> <li>o The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.</li> </ul> <p>1.4. Additional Compliance Information</p> <p>None.</p> <p>2. Levels of Non-Compliance:</p> <p>2.1. Level 1: There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:</p> <ul style="list-style-type: none"> <li>2.1.1 Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).</li> <li>2.1.2 Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).</li> <li>2.1.3 Has not established communications contacts, as specified in R4.</li> </ul> <p>2.2. Level 2: Not applicable.</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>2.3. Level 3: Has not provided its operating personnel with sabotage response procedures or guidelines (R3).</p> <p>2.4. Level 4:.Not applicable.</p> <p>E. Regional Differences None.</p> <p>Version History Version Date Action Change Tracking 0 April 1, 2005 Effective Date New 0 August 8, 2005 Removed "Proposed" from Effective ate Errata 1 November 1, 2006 Adopted by Board of Trustees Amended 1 April 4, 2007 Regulatory approval — Effective Date New 2 March 2009 Added SEA attachment and updates to Effective Date and compliance sections. New</p> <p><b>Attachment 1-CIP-001-2 Physical Security Emergency Alerts</b></p> <p>General requirements</p> <p>1. Initiation by Reliability Coordinator.</p> <p>A Physical Security Emergency Alert may be initiated only by a Reliability Coordinator at:</p> <ul style="list-style-type: none"> <li>a. The Reliability Coordinator's own decision,</li> <li>b. By request from a Transmission Operator,</li> <li>c. By request from a Balancing Authority, or</li> <li>d. By request from federal, state, or cal Law Enforcement Officials.</li> </ul> <p>2. Situations for initiating alert.</p> <p>An Alert may be initiated for the following reasons:</p> <ul style="list-style-type: none"> <li>a. A physical threat affecting a control center, grid or generator asset has been identified, or</li> <li>b. A physical attack affecting a control center, grid or generator asset has occurred or is imminent.</li> </ul> <p>3. Notification.</p> <p>A Reliability Coordinator who initiates a Physical Security Emergency Alert shall notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify other Reliability Coordinators of the situation via the Reliability Coordinator Information System (RCIS) using the "CIP" category. Additionally, conference calls between Reliability Coordinators shall be held as necessary to communicate system conditions.</p> <p>The Reliability Coordinator shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area and other Reliability Coordinators hen the alert has changed levels or ended.</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>Physical Security Emergency Alert Levels</p> <p>To ensure that all Reliability Coordinators clearly understand potential and actual Physical Security Emergency Alerts, NERC as established three levels of Security Emergency Alerts. The Reliability Coordinators will use these terms when explaining security alerts to each other. The Reliability Coordinator may declare whatever alert level is necessary, and need not proceed through the alerts sequentially.</p> <p>1. Alert 1 – “Control Center / Bulk Electric system asset threat identified” Circumstances: A credible threat of physical attack on a Bulk Electric System asset has been communicated to the Reliability Coordinator. No physical attack has occurred at this point. Determining the credibility of any threat is a subjective process, but the following factors should be considered:</p> <ul style="list-style-type: none"> <li>a. The nature and specificity of the threat,</li> <li>b. The timing of the threat,</li> <li>c. Mode of threat communication, and</li> <li>d. The criticality of the threatened asset. During a Physical Security Emergency Alert Level 1, Reliability Coordinators, Transmission Operators and Balancing Authorities shall have the following responsibilities: <ul style="list-style-type: none"> <li>i. Notification: The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area.</li> <li>ii. Updating Status during the Physical Security Emergency Alert The declaring Entity shall update the reliability Coordinator of any changes in the situation until the Alert Level 1 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> </li> </ul> <p>2. Alert 2 – “Verified Physical attack at a single site” circumstances: A Reliability Coordinator, Transmission Operator, or Balancing Authority has identified a physical attack upon a control center, generator asset, or other bulk electric system asset. During a Physical Security Emergency Alert Level 2, Reliability Coordinators, Transmission Operators and Balancing Authorities shall have the following responsibilities:</p> <ul style="list-style-type: none"> <li>i. Notification: The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area.</li> <li>ii. Updating Status during the Physical Security Emergency Alert The Declaring Entity shall update the Reliability Coordinator of the situation a minimum of once per hour until the Alert Level 2 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> <p>3. Alert 3– “Verified Physical attack at multiple sites” Circumstances: Multiple attacks have been confirmed on control centers, generator assets or other bulk electric system assets. A Reliability Coordinator shall declare Physical Security</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>Emergency Alert 3 whenever:</p> <ul style="list-style-type: none"> <li>a. A Transmission Operator or Balancing Authority reports multiple physical attacks on bulk electric system assets,</li> <li>b. Multiple Transmission Operators or Balancing authorities report one or more physical attacks on their bulk electric system assets.</li> <li>i. Notification: The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area.</li> <li>ii. Updating Status during the Physical Security Emergency Alert The declaring Entity(ies) shall update the Reliability Coordinator of the situation a minimum of once per hour until the Alert Level 3 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> <p>4. Alert 0 – “Termination of Alert Level” Circumstances: The threat which prompted the Physical Security Emergency Alert Level has diminished or has been removed.</p> <ul style="list-style-type: none"> <li>i. Notification The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall notify all other Reliability Coordinators via the RCIS, and it shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area that the Alert Level has been terminated.</li> </ul> <p>Cyber Security Emergency Alerts Cyber Assets – Those programmable electronic devices and communication networks, including hardware, software, and data, associated with bulk electric system assets.</p> <p>Cyber Security Incident - Any malicious act or suspicious event that compromises, or attempts to compromise, the electronic or physical security perimeter of a critical cyber asset or disrupts or attempts to disrupt the operation of a critical cyber asset.</p> <p>Critical Cyber Asset – Those cyber assets essential to the reliable operation of critical assets.</p> <p>Electronic Security Perimeter – The logical border surrounding the network or group of sub-networks to which the critical cyber assets are connected, and for which access is controlled.</p> <p>Physical Security Perimeter – The physical border surrounding computer rooms, telecommunications rooms, operations centers and other locations in which critical cyber assets are housed and for which access is controlled.</p> <p>General Requirements</p> <p>1. Initiation - A Cyber Security Emergency Alert shall be initiated by:</p> <ul style="list-style-type: none"> <li>a. The Reliability Coordinator’s analysis,</li> <li>b. By request from any NERC functional Model entity that Com-003-0 is applicable to.</li> </ul>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>c. By request from federal, state, or local Law Enforcement Officials.</p> <p>2. Situations for initiating alert. An Alert shall be initiated for the following reasons:</p> <p>a. A cyber threat affecting a control center or bulk electric system asset has been identified, or</p> <p>b. A cyber attack affecting a control center or bulk electric system has occurred or is imminent.</p> <p>3. Notification.</p> <p>An entity who initiates a Cyber Security Emergency Alert shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator shall notify FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security. The Reliability Coordinator shall also notify as necessary other Reliability Coordinators of the situation via the Reliability Coordinator Information System (RCIS) using the “CIP” category. The Reliability Coordinator shall notify all Transmission Operators and Balancing Authorities in its Reliability Area and other Reliability Coordinators when the alert has changed levels or ended.</p> <p>Cyber Security Emergency Alert Levels</p> <p>To ensure that all applicable entities clearly understand potential and actual Cyber Security Emergency Alerts, three levels of Security Emergency Alerts shall be used.</p> <p>The Reliability Coordinators will use these terms when communicating security alerts to each other. When declaring the applicable alert level it is important to note that the applicable level can be determined without sequentially proceeding through levels.</p> <p>As an example given circumstances an Alert Level 3 could be called without previously being in an Alert Level 1 or Level 2 state.</p> <p>1. Alert 1 – “Verified Control Center / Bulk Electric System Cyber Asset threat identified or imminent” What is “verified” - unknown or unauthorized access to a cyber device, unknown or unauthorized change to a cyber device (i.e., config file, I/S, firmware change. ‘Verified’ could mean the elimination of a false positive in your security monitoring system. ‘Verified’ could also be the differentiation between malicious and non-malicious (ie human error, not following policy, etc) intent. What is a “threat” - A threat can be perceived as any action or event that occurs where the monitoring authority was not previously made aware that that action would occur. With flimsy change control or access controls, field staff or technical staff performing troubleshooting or other maintenance may access or change devices without notifying the monitoring entity. The monitoring entity would have to treat this as a threat and take appropriate action to either isolate that device from the rest of the system, notify appropriate authority, dispatch a crew, etc.</p> <p>Examples of threats - Over and above the examples above, another threat example could be a notification from DHS or other security agency that they have reason to believe a hack, virus or other cyber terrorism activity could occur. Also, noticing a distinct change in network traffic which could imply someone has intercepted your data and can manipulate</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>before sending it from the control room to the device being controlled or manipulating the data coming from the device before a controller seeing it and forcing them to perform an incorrect control event in reaction to erroneous data.</p> <p>Circumstances: A credible threat of Cyber attack on a Control Center or Bulk Electric System asset has been communicated to the Reliability Coordinator. No cyber attack has occurred t this point. Determining the credibility of any threat is a subjective process, but the following factors should be considered:</p> <ul style="list-style-type: none"> <li>a. The nature and specificity of the threat,</li> <li>b. The timing of the threat,</li> <li>c. Mode of threat communication, and</li> <li>d. The criticality of the threatened asset. During a Cyber Security Emergency Alert Level 1, applicable entities shall have the following responsibilities: <ul style="list-style-type: none"> <li>i. Notification An entity who initiates a Cyber Security Emergency Alert Level 1 shall make notification as per the NERC Functional model r as Regional / local instruction. The Reliability Coordinator shall post the declaration of the alert level long with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify as necessary the BI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security.</li> <li>ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity shall update those applicable entities of any changes in the situation until the Alert Level 1 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> </li> </ul> <p>2. Alert 2 – “Verified Cyber attack on a Control Center or Bulk Electric System asset”</p> <p>Circumstances: An applicable entity has identified a cyber attack upon a control center or bulk electric system asset. During a Cyber Security Emergency Alert Level 2, applicable entities shall have the following responsibilities:</p> <ul style="list-style-type: none"> <li>i. Notification An entity who initiates a Cyber Security Emergency Alert Level 2 shall make notification as per the NERC Functional model or as Regional / cal instruction. The Reliability Coordinator responsible shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify the FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security.</li> <li>ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity shall provide updates of the situation a minimum of once per hour until the Alert Level 2 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul>



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
		<p>3. Alert 3 – “Verified Cyber attack at one or more Control Center or Bulk Electric System cyber asset”</p> <p>Circumstances: An applicable entity has identified a cyber attack upon a control center or bulk electric system asset and shall declare a Cyber Security Emergency Alert 3 whenever:</p> <ul style="list-style-type: none"> <li>a. A Transmission Operator or Balancing Authority reports one or more cyber attacks on bulk electric system that render an asset(s) unavailable.</li> <li>i. Notification An entity who initiates a Cyber Security Emergency Alert Level 3 shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities its Reliability Area. The Reliability Coordinator shall also notify the FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security.</li> <li>ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity(ies) shall provide an update of the situation minimum of once per hour until the Alert Level 3 is terminated. The Reliability Coordinator shall update he RCIS as changes occur.</li> </ul> <p>4. Alert 0 – “Termination of Alert Level” Circumstances: The threat which prompted the Cyber Security Emergency Alert Level has diminished or has been removed. i. Notification An entity who initiates a Cyber Security Emergency Alert shall make notification as per the NERC Functional model or as Regional / local instruction when situation has diminished or returned to normal. The Reliability Coordinator shall notify all other Reliability Coordinators via the RCIS, and it shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area that the Alert Level has been terminated.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The standards in this Project 2009-01 SAR are designed to specify reporting requirements for disturbance and sabotage events. The DSR SAR DT believes that the suggested additions go beyond the intended scope of the revisions to the standards, and do not feel that communications protocols belong in these reporting standards. The proposed revisions and Alert Levels are real-time requirements, and the team feels that these would be more appropriately addressed in an IRO or COM standard.</b></p>		
Northeast Power Coordinating Council	No	<p>The SAR needs to be more specific in defining its objectives.</p> <p>CIP-001Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <p>1. Develop clear definitions for the terms “operating personnel” and “sabotage events.” The definition of “operating personnel,” should be clarified and limited to staff at BES facilities. Operating personnel should report only those events</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term “sabotage event” needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</p> <p>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such “sabotage events,” e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term “aware” in the standard. “Aware” can be interpreted in accordance with its largely passive, dictionary-based meaning, where being “aware” simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of “aware” could refer to more active wording, involving more than mere awareness, e.g., “alert and quick to respond,” pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</p> <p>EOP-004 - The SDT needs to work on the following areas.</p> <p>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states: Introduction “The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance - The sense of Attachment 1 is internally inconsistent between the introduction (“occurs”) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase “or could have resulted in” a potential system disturbance. This inconsistency should be clarified.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>CIP-001: The inclusion of specific definitions in the SAR as you suggest (operating personnel, sabotage events, obligations) are too prescriptive and could prevent better definitions from being developed during the Standards Development stage of the project. The team will pass your comments along to the standard drafting team for its consideration.</b></p> <p><b>EOP-004: Your comment addresses specific revisions to the standard. The team will pass your comments along to the standard drafting team for its consideration.</b></p>		
Kansas City Power & Light	No	Agree with the scope of the SAR except for the applicable entities. See response to question #4.
<p><b>Response: The DSR SAR DT thanks you for your comment. Please see response to Q4.</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
MRO NERC Standards Review Subcommittee	No	The MRO NSRS would like to keep the references to the DOE reporting form.
<p><b>Response: The DSR SAR DT thanks you for your comment. The DSR SAR DT understands your comment to indicate that you would like to see a “one stop” reporting form for disturbances and sabotage events. The DSR SAR DT agrees with you and will pass this comment along to the standard drafting team for its consideration in developing the standard(s).</b></p>		
Lands Energy Consulting	No	I would like to see the SAR expanded to cover the issues I mentioned in my prior comment. Otherwise, the scope of the SAR looks fine to me.
<p><b>Response: The DSR SAR DT thanks you for your comment. Please see response to Q1 on other issues.</b></p>		
Bonneville Power Administration	No	Leave as is, all requirements for reporting are now covered. A common definition of sabotage is already widely available.
<p><b>Response: The DSR SAR DT thanks you for your comment. Most stakeholders desire more clarity around the definition of sabotage as well as examples of what is and is not sabotage as opposed to vandalism.</b></p>		
Cowlitz County PUD	No	<p>Added to the scope:</p> <p>For EOP-004 add a provision for a reporting flow rather than everything going to the RE and NERC. That is something going like the DP and TOP reports to the BA, the BA to the RE, and the RE to NERC. This would allow for multiple related reports to be combined into a single coherent report as the reporting goes up the chain.</p> <p>For CIP-001 consider reporting flow as above with local law enforcement notification. Let an upper entity in the reporting chain decide when to contact Federal Agencies such as the BA or the RC.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The DSR SAR DT feels that your comments are “how” comments that should be addressed in standard drafting stage. The team will pass this comment along to the standard drafting team for its consideration.</b></p>		
Reliant Energy	No	I think Generator operators should be excluded except to provide requested information from the System Operator or Reliability coordinator.
<p><b>Response: The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
<p><b>determine the applicability to GOPs. The team will pass your comment on to the Standard Drafting Team for its consideration.</b></p>		
ERCOT ISO	No	<p>The scope should be modified to provide for a different treatment of reporting requirements that are administrative in nature, or that are after-the-fact (thus cannot impact reliability unless analysis and follow-up is not performed; even then, the impact would be at some future time). Reporting requirements which are of the nature to assist in identification of system concerns or which serve to prevent or mitigate on-going system problems (including, but not limited to, actual or attempted sabotage activity) should remain in standards, but should be separate and apart from the administrative reporting.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs with the concepts on reporting as you suggest, however the team does not feel that this should be addressed in the SAR. The team suggests that this is more appropriately addressed in the standard drafting process, and the team will pass your comment along to the standard drafting team for its consideration in drafting the standard.</b></p>		
MidAmerican Energy	No	<p>See the responses to questions 1 and 5.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. Please see responses to Q1 and Q5.</b></p>		
We Energies	No	<p>Consider including the sabotage issues in IRO-014-1 R 1.1.1 footnote 1 and TOP-005-1 Attachment 1, 2.9.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team has added references to these two standards in the “Related Standards” section for the SAR.</b></p>		
NextEra Energy Resources, LLC	No	<p>The scope of the SAR should not include Generator Operators.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will determine the applicability to GOPs. The team will pass your comment on to the Standards Drafting Team for its consideration.</b></p>		
Progress Energy	No	<p>No. If this SAR moves forward other standards may need to be considered. For example, in CIP-008, incident reporting for cyber incidents leads to filing of the OE-417 form.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states “Specific references to the DOE form need to be eliminated.” This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states:</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
<p>Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</p> <p><b>This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>		
Ameren	No	<p>There seems to be an open slate including the following language in the scope. The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information). The unnamed improvements should be limited to those requirements that relate only to Disturbance and Sabotage NOT a general wish list (or witch hunt).</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The passage that you mention is the intent of each SAR and is a stock statement that is included in almost every SAR. The SAR is limited to the standards listed in the SAR which is approved by the NERC SC to move to standards development.</b></p>		
Consolidated Edison Co. of New York, Inc.	No	<p>GENERAL CECONY and ORU support the general objectives of the SAR to merge existing standards CIP-001-1 Sabotage Reporting and EOP-004-1 Disturbance Reporting to improve clarity and remove redundancy.</p> <p>However, the SAR needs to be more specific in defining its objectives.</p> <p>CIP-001Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <ol style="list-style-type: none"> <li>1. Develop clear definitions for the terms operating personnel and sabotage events. The definition of operating personnel, should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term sabotage event needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</li> <li>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such sabotage events, e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term aware in the standard. Aware can be interpreted in accordance with its largely passive, dictionary-</li> </ol>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>based meaning, where being aware simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of aware could refer to more active wording, involving more than mere awareness, e.g., alert and quick to respond, pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</p> <p>EOP-004 - The SDT needs to work on the following areas.</p> <p>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states:</p> <p>Introduction The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: ?c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance.</p> <p>The sense of Attachment 1 is internally inconsistent between the introduction (occurs) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase or could have resulted in a potential system disturbance. This inconsistency should be clarified.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>CIP-001: The inclusion of specific definitions in the SAR as you suggest (operating personnel, sabotage events, obligations) are too prescriptive and could prevent better definitions from being developed during the standard drafting stage of the project. The team will pass your comments along to the standard drafting team for its consideration.</b></p> <p><b>EOP-004: Your comment addresses specific revisions to the standard. The team will pass your comments along to the standard drafting team for its consideration.</b></p>		
Georgia System Operations Corp.	No	<p>The scope of the SAR should be to move all requirements to report to NERC or Regional Entities out of the Requirements section of all Reliability Standards to elsewhere. This does not include reporting, communicating, or coordinating between reliability entities. The NERC/Region reporting requirements could be consolidated in another document and referenced in the Supporting References section of the Reliability Standards. The deadlines for reporting should be changed to realistic timeframes that do not interfere with operating the BES or responding to incidents yet still allow NERC and the Regions to accomplish their missions.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team does not feel that this should be addressed explicitly in the SAR, but suggests that this is more appropriately addressed in the standard drafting stage for full industry vetting of the concepts. The team will pass your comment along to the standard drafting team for its consideration in developing the standard.</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
AEP	No	Sabotage is a term of intent that is often determined after the fact by the registered entity and/or law enforcement officials. In fact, it is often difficult to determine in real-time the intent of a suspicious event. We would suggest that suspicious events become reportable at the point that the event is determined to have had sabotage intent. The entities should have a methodology to collect evidence, to have the evidence analyzed, and to report those events that are determined to have had the intent of sabotage.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs that it is difficult to determine sabotage in real-time. The team does not feel that this should be addressed explicitly in the SAR and suggests that this is more appropriately addressed in the standard drafting stage for full industry vetting of the concepts. The team will pass your comment along to the standard drafting team for its consideration in developing the standard.</b></p>		
Duke Energy	No	While we agree with the need for clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities. Also, requirements to report possible non-compliances should be eliminated. We strongly support voluntary self-reporting, but not mandatory self-reporting.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs that each requirement should be evaluated for its reliability need, and the team will pass your comment along to the standard drafting team for its consideration in the drafting stage of the standard.</b></p>		
FirstEnergy	Yes	<p>We agree with the scope but would also like to see the following considered:</p> <ol style="list-style-type: none"> <li>1. References to the DOE reporting process in EOP-004 need to be revised. They currently refer to the old EIA form.</li> <li>2. Besides "sabotage", it may be helpful to clearly define "vandalism". It is vaguely written in the standards. Also, the process of "public appeals" for the DOE reportable requirements needs to be more clearly defined.</li> <li>3. Consolidate documents covering reporting requirements. There are currently several documents that require reporting (EOP-004, CIP-001, DOE oe-417, and NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting). NERC also has the "Bulk Power System Disturbance Classification Scale" that does not completely align with all the reporting requirements. Therefore we recommend keeping this as simple as possible by combining all the reporting requirements into one standard. It would be beneficial to not require operators to have to go to 4 different documents to determine what to report on.</li> </ol>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
<p><b>The Brief Description of the SAR states:</b> Specific references to the DOE form need to be eliminated.</p> <p><b>The team will pass your comment along to the standard drafting team for its consideration.</b></p> <p><b>The team concurs that this should be considered in drafting the standards. The team will pass your comment along to the standard drafting team for its consideration.</b></p>		
Exelon	Yes	Consolidation of redundant requirements and clarifications of difficult to follow / interpret standards should be a high priority at NERC.
<p><b>Response: The DSR SAR DT thanks you for your comment. One of the FERC directives for CIP-001 is: Explore ways to reduce redundant reporting, including central coordination of sabotage reports and a uniform reporting format.</b></p>		
Electric Market Policy	Yes	
SERC OC Standards Review Group	Yes	
PSEG Enterprise Group Inc Companies	Yes	
IRC Standards Review Committee	Yes	
Pepco Holdings, Inc. - Affiliates	Yes	
Calpine Corporation	Yes	
Covanta	Yes	
Colmac Clarion	Yes	



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
United Illuminating	Yes	
Texas Regional Entity	Yes	
Edward C. Stein	Yes	
WECC	Yes	
Luminant Power	Yes	
ReliabilityFirst Corporation	Yes	
Brazos Electric Power Cooperative, Inc.	Yes	
PacifiCorp	Yes	
Oncor Electric Delivery	Yes	
Illinois Municipal Electric Agency	Yes	
Manitoba Hydro	Yes	
Consumers Energy Company	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**3. Are you aware of any associated business practices that we should consider with this SAR? If yes, please explain in the comment area.**

**Summary Consideration:** Stakeholders did not identify any associated business practices for consideration under the SAR. One stakeholder identified a related standard that references multi-site sabotage. The team has included a reference to TOP-005, section 2.9 (Appendix 1) in the SAR under Related Standards. Two stakeholders suggested that Business Practices should not be considered in a standard. The SAR DT notes that standard development projects must not invalidate business practices that are already in place. This question is required to be asked per the Standard Drafting Team Guidelines (page 8) and aids in coordination with North American Energy Standards Board. One stakeholder suggested a “one-stop-shopping” solution. The SAR DT agrees with this approach and will forward this comment to the Standard Drafting Team.

Organization	Yes or No	Question 3 Comment
MRO NERC Standards Review Subcommittee	Yes	
Luminant Power	Yes	The SAR drafting team should include in the SAR scope a review of the NRC sabotage and event reporting requirements to ensure there are no overlapping or conflicting requirements between NERC, FERC, and the NRC. The SAR scope should include a review of the CIP Cyber Security Standards and coordination with the CIP SDT to ensure that cyber sabotage reporting definitions are in concert, and ensure that cyber sabotage reporting requirements are not duplicated in multiple standards.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team notes that your comments relate directly to potential revisions of the standard itself. Part of this SAR is to eliminate redundancies as well. The team will pass your comments along to the Standards Drafting Team for its consideration. This project is designed to address physical asset reporting, not cyber assets. Therefore, cyber assets will not be included in this SAR.</p>		
MidAmerican Energy	Yes	Attachment TOP-005, section 2.9 speaks of “Multi-site sabotage” with no definition. The ES-ISAC 2008 advisory is an associated standard or practice on sabotage. All references to sabotage should be eliminated or retired except for CIP-001.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team has included a reference to TOP-005, section 2.9 (Appendix 1) in the SAR under Related Standards. Project 2009-01 is designed to address physical asset reporting, not cyber asset sabotage and disturbance reporting. The standard drafting team will remove redundancies per the SAR.</p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 3 Comment
Illinois Municipal Electric Agency	Yes	A one-stop reporting tool/site would facilitate efficient reporting and compliance; e.g., further development of the ES-ISAC/CIPIS to include all reportable categories and automatic notification of required parties. A single report form would be best.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees with your suggestion and will pass this along to the Standard Drafting Team for its consideration in developing standards.</b></p>		
AEP	Yes	The current reporting process necessitates multiple reports be sent to multiple parties, which is inefficient and may, inadvertently, result in alignment issues between the separate reports. We would recommend that a single report that combines NERC (CIPIS) and NERC ESISAC information be provided to NERC (CIPIS) that is systematically (programmatically) forwarded to all necessary entities. Further, updates to incidents would also go through NERC with the same electronic processing. Currently, we are not aware of a formal method to report incidents to the FBI, which should be also included in the distribution. The current reporting mechanism to the FBI JTTF is by telephone and the NERC platform described would provide more consistent reporting.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees with your suggestion and will pass this along to the Standard Drafting Team for its consideration in developing standards. This project is designed to address physical asset reporting, not cyber assets.</b></p>		
Progress Energy	Yes	Yes. If this SAR moves forward other practices such as those required by CIP-008 (cyber incident reporting via the OE-417 form) may need to be considered.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states “Specific references to the DOE form need to be eliminated.” This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states: Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality. This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that the general layout and sequencing of requirements in CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>		
Exelon	No	We are not sure what this question means. Who's Associated Business practices, NERC, Applicable Entities in the Standard, our business practices?
<p><b>Response: The DSR SAR DT thanks you for your comment. “Business practices” refers to any business practice of any stakeholder (e.g. North American Energy Standards Board business practices).</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

---

Organization	Yes or No	Question 3 Comment
SERC OC Standards Review Group	No	Business practices should not be considered in a standard.
<p><b>Response: The DSR SAR DT thanks you for your comment. Standard development projects must not invalidate business practices that are already in place. This question is required to be asked per the Standard Drafting Team Guidelines (page 8) and aids in coordination with North American Energy Standards Board.</b></p>		
FirstEnergy	No	Although we are not aware of any NAESB business practices that need to be reviewed in conjunction with these proposed revisions, the SDT should consider reviewing current RTO procedures and practices that may require the need for variances in the revised standards.
<p><b>Response: The DSR SAR DT thanks you for your comment. The Standard Drafting Team will review any procedures or practices that are identified for potential variances.</b></p>		
Georgia System Operations Corp.	No	Business practices should not be part of a Reliability Standard. Neither should NERC/Region reporting requirements (except for reporting of threats to physical or cyber security). NERC may need to take some action in the case of threats but does not and cannot take any operational action for most of the reporting requirements that are presently in the Requirements section of the Reliability Standards.
<p><b>Response: The DSR SAR DT thanks you for your comment. Standard development projects must not invalidate business practices that are already in place. This question is required to be asked per the Standard Drafting Team Guidelines (page 8) and aids in coordination with North American Energy Standards Board. The team disagrees with your assertion about reporting. Instances of sabotage are often not identified until after the fact, and these should be reported to alert other entities of the sabotage and for “lessons learned”.</b></p>		
PSEG Enterprise Group Inc Companies	No	
Northeast Power Coordinating Council	No	
Kansas City Power & Light	No	
IRC Standards Review Committee	No	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 3 Comment
Pepco Holdings, Inc. - Affiliates	No	
Electric Market Policy	No	
Bonneville Power Administration	No	
Lands Energy Consulting	No	
Covanta	No	
Colmac Clarion	No	
Cowlitz County PUD	No	
United Illuminating	No	
Reliant Energy	No	
Texas Regional Entity	No	
Edward C. Stein	No	
PacifiCorp	No	
WECC	No	
ERCOT ISO	No	
ReliabilityFirst Corporation	No	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 3 Comment
Brazos Electric Power Cooperative, Inc.	No	
Oncor Electric Delivery	No	
Consolidated Edison Co. of New York, Inc.	No	
Manitoba Hydro	No	
Duke Energy	No	
We Energies	No	
Consumers Energy Company	No	
NextEra Energy Resources, LLC	No	
Ameren	No	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**4. CIP-001-1 applies to the Reliability Coordinator, Transmission Operator, Balancing Authority, Generator Operator, and the Load-serving Entity. EOP-004-1 applies to the same entities, plus the Regional Reliability Organization. Do you agree with the applicability of the existing CIP-001-1 and the existing EOP-004-1? If no, please identify what you believe should be modified.**

**Summary Consideration: Many stakeholders had comments regarding applicability of the two standards. The three main concerns were:**

- 1 Regional Reliability Organization applicability: Many commenters do not feel the RRO should be in the standards. The DSR SAR DT concurs and notes that the SAR states that “EOP-004 has some ‘fill-in-the-blank’ components to eliminate”. This will remove the RRO from applicability.
- 2 Load-Serving Entity/Distribution Provider: Many stakeholders do not feel that the standards should be applicable to LSEs, but should apply to Distribution Providers. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.
- 3 Transmission Owner/Generator Owner: Many stakeholders have indicated a need to include the TO as an applicable entity. A couple of those would also include the GO. The SAR DT discussed the addition of both the TO and GO. The team has a concern that there will be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.

Organization	Yes or No	Question 4 Comment
SERC OC Standards Review Group	No	The EOP-004-1 standard should not apply to the RRO.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
Kansas City Power &	No	Do not agree Load Serving Entities need to continue to be included for sabotage. According the NERC Functional Model,

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
Light		an LSE provides for estimating customer load and provides for the acquisition of transmission and energy to meet customer load demand. An LSE has no real impact on maintaining the reliability of electric network short of their planning function. Unfortunately, an LSE needs to be included for disturbance reporting to the DOE under certain conditions for loss of customer load. This may be a reason to maintain a separation of CIP-001 and EOP-004 so as not to unnecessarily include an LSE when it is not needed.
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration.</b></p>		
IRC Standards Review Committee	No	We agree with the applicability of CIP-001-1 but question the need to include the RRO in EOP-004-1. Requirement R1 of EOP-004-1 can be turned into an industry developed and approved procedural requirement with details included in an appendix; whereas R5 can be changed to a requirement for the responsible entities to act on recommendations and to self-report compliance. Tracking and reviewing status of recommendation do not need to be performed by the RRO, or any entity for that matter, if a self-reporting mechanism is developed.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
Pepco Holdings, Inc. - Affiliates	No	As specified in Order 693, Regional Reliability Organizations are not to be assigned applicability. The revised standard(s) should contain the reporting form either directly or by reference and the RRO should be removed. The other EOP-004 requirements for RROs are now considered normal monitoring activities of the Regional Entities.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
FirstEnergy	No	The Regional Reliability Organization should be removed from the applicability of EOP-004-1. Any report they receive would be from the other entities listed. For consistency, the entities should report to the appropriate law enforcement agency. A report to the Reliability Entity should also be made for that entities information only.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
Electric Market Policy	No	Applicability should not apply to LSE unless they have physical assets. If they do not have such assets, they are unable to



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
		<p>determine how many customers are out, how much load was lost or the duration of an outage. We continue to question the need for the LSE entity in reliability standards. End use customer load is either connected to transmission or distribution facilities. So, the applicable planner has to plan for that load when designing its facilities or the load will not have reliable service. To the extent that energy and capacity for that load is supplied by an entity other than the TO or DP, the TO or DP should have interconnection requirements that compel the supplier to provide any and all data necessary to meet the requirements of reliability standards.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration.</b></p>		
MRO NERC Standards Review Subcommittee	No	As FERC has directed, the RRO should be removed since they are not owners or operators of the BES.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some 'fill-in-the-blank' components to eliminate. This will remove the RRO from applicability.</b></p>		
Lands Energy Consulting	No	<p>CIP-001-1 - Yes. In many cases, the staff of an LSE embedded in another entity's BA/TOP area is more likely to discover an act of sabotage directed toward a BA/TOP-owned facility that could affect the BES than the asset owner. This is because the LSE likely has more operating staff in the area. I have included a requirement in my clients' Sabotage Identification and Reporting Procedures that the client treat acts of sabotage to a third party's system discovered by client employees as though the act was directed toward client facilities. EOP-004-1 - As mentioned before, I would eliminate the LSE from the applicability list and leave the responsibility for disturbance reporting and response to the TOP/BA. However, I would retain a responsibility for the LSEs to cooperate (when requested) with any disturbance investigation.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration.</b></p>		
Calpine Corporation	No	<p>The reporting requirements of EOP - 004 are needed for the RC, BA, LSE and the GOP that operates or controls generation in a system as defined by NERC. (System - A combination of generation, transmission, and distribution components). A disturbance is described as an unplanned event that produces and abnormal system condition, any</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
		<p>perturbation to the electric system, and the unexpected change in ACE that is caused by the sudden failure of generation or interruption of load. The GOP operating/controlling generation within a system has the ability to analyze system conditions to determine if reporting is necessary. A NERC registered GOP that is a merchant generator within another company's system does not have the ability for a wide area view and cannot analyze system conditions beyond the interconnection point of the facility. Moreover, in most cases the reporting requirements outlined in the Interconnection Reliability Operating Limits and Preliminary Disturbance Report do not apply to the merchant generator that is not a generation only BA. The applicability of the standard does encompass the true merchant generation entities required to register as GOP. Similarly, the OE-417 table 1 reporting requirements generally do not apply to a true merchant generating entity that is required to register as a GOP.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees that generators may not have a wide area view and the capability to analyze events. The final wording of the requirements developed by the Standard Drafting Team will determine the applicability. The team will pass your comment on to the Standards Drafting Team for its consideration. The SAR calls for the removal of references to the DOE form OE-417.</b></p>		
Cowlitz County PUD	No	Replace LSE with DP, and the Regional Reliability Organization with the Regional Entity.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team has added DP to the applicability of the SAR. The SAR calls for removing the fill-in-the-blank standard elements which will remove the RRO.</b></p>		
United Illuminating	No	Add Distribution Provider
<p><b>Response: The DSR SAR DT thanks you for your comment. The team has added DP to the applicability of the SAR.</b></p>		
Reliant Energy	No	EOOP-004-1 should exclude the generator operator from disturbance reporting except providing the system operator or reliability coordinator with appropriate unit operation information upon request. Acts of sabotage should be identified clearly and reported to the indicated authorities.
<p><b>Response: The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will determine the applicability to GOPs. The team will pass your comment on to the Standards Drafting Team for its consideration.</b></p>		
Texas Regional Entity	No	Add GO and TO to the list of applicability. The intent of CIP-001-1 when it was first written was to have the proper and most likely entities associated directly with operations to be the ones to begin the reporting process in the case of sabotage on the system. In the ERCOT Region and other regions in the US, the GOP may not be physically located at the site. The GOP is often removed from the minute-by-minute responsibilities of plant operations and, therefore, may be less

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
		<p>able to react to physical sabotage at the location/plant/facility in a timely manner. The concern is that, in the case of an actual sabotage event, the failure to report to the appropriate authorities in a timely manner may jeopardize the reliability of the BPS. Therefore, the Generator Owner (GO) should be added to the list of applicability for CIP-001-1, because it is the GO that is more likely to be on location at the generation site and thus aware of sabotage when it first occurs. This would disallow for any possible communication gap and put responsibility on all of the appropriate entities to report such an event. Additionally, and for the same reasons as adding the GO, the Transmission Owner (TO) should also be added to the list of applicability for reporting sabotage on its facilities.</p>
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The SAR DT discussed the addition of the TO and GO. The team was concerned that there may be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting Process. The team will pass your comment along to the Standard Drafting Team for its consideration concerning applicability.</p>		
NextEra Energy Resources, LLC	No	<p>The scope of the proposed SAR should not include the Generator Operator.</p>
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will determine the applicability to GOPs. The team will pass your comment on to the Standards Drafting Team for its consideration.</p>		
Exelon	No	<p>CIP-001, remove LSE's from the standard for the reasons identified in the FERC LSE order. Ad TO and DP. EOP-004, remove LSE's from the standard for the reasons identified in the FERC LSE order. Remove RRO's, they are not a user, owner, operator of the BES. Add DP or TO. Consider conditional applicability as in the UFLS standards, " the TO or DP who performs the functions specified in the standard..."</p>
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The SAR DT discussed the addition of the TO. The team is concerned that there may be duplication of requirements between the TO/TOP if the TO is added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting Process. The SAR calls for elimination of fill in the blanks elements, which will remove the RRO from the standard. The team will pass your comment along to the Standard Drafting Team for its consideration concerning conditional applicability.</p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
ERCOT ISO	No	The Regional Reliability Organization is not a registered Functional Entity in the NERC registry. The applicability must be revised to more appropriately assign the requirements to registered functional entities. Also, the industry needs to recognize that there are other resources than generation for which the operators need to be included. Perhaps a demand-side resource should have a resource operator. This particular SAR may not be the appropriate venue for this, but control of resources which can be used to mitigate sabotage events or disturbance events may need to be addressed.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR calls for elimination of fill-in-the-blank elements, which will remove the RRO from the standard. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration concerning conditional applicability. This SAR is for reporting rather than control actions as you mention.</b></p>		
Brazos Electric Power Cooperative, Inc.	No	May need to consider adding Transmission Owner. I don't see a need for the RRO to be included as they are not owner/operators of grid facilities.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT discussed the addition of the TO. The team is concerned that there may be duplication of requirements between the TO/TOP if the TO is added to the SAR. That being said, the TO has been added to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The SAR calls for elimination of fill in the blank elements, which will remove the RRO from the standard. The team will pass your comment along to the Standard Drafting Team for its consideration concerning conditional applicability.</b></p>		
PacifiCorp	No	LSE's don't generally own/operate facilities/systems that would experience a logical or physical sabotage event.
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process.</b></p>		
MidAmerican Energy	No	MidAmerican Energy believes the requirement for the Regional Reliability Organization should be removed from EOP-004-1 since the RRO is a holdover from making the standards enforceable. It is no longer appropriate for the regions to be named as responsible entities within the standards.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR calls for elimination of fill-in-the-blank elements, which will remove the RRO from the standard.</b></p>		

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 4 Comment
Georgia System Operations Corp.	No	EOP-004 should be retired. CIP-001 should not apply to LSEs other than those that are retail marketers.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The SAR calls for EOP-004 to be revised. The Standard Drafting Team may, with stakeholder approval, retire it. CIP-001: NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting process.</p>		
AEP	No	We would recommend that the Load Serving Entity (LSE) be removed from both standards, and that the Generator Owner and Transmission Owner be added to the resulting standard.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The SAR DT discussed the addition of the TO and GO. The team has a concern that there may be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting Process. The team will pass your comment along to the Standard Drafting Team for its consideration concerning applicability.</p>		
Duke Energy	No	It's unclear to us that the RRO should continue to be an applicable entity.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some 'fill-in-the-blank' components to eliminate. This will remove the RRO from applicability.</p>		
Covanta	Yes	It would be a welcome enhancement to the end users to understand to communication link between all "appropriate parties" who shall be notified of potential or actual sabotage events.... which also needs to be defined.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team concurs, and will pass this comment on to the standard drafting team for its consideration.</p>		
Edward C. Stein	Yes	
WECC	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
Luminant Power	Yes	
ReliabilityFirst Corporation	Yes	
Oncor Electric Delivery	Yes	
Consolidated Edison Co. of New York, Inc.	Yes	
Illinois Municipal Electric Agency	Yes	
Manitoba Hydro	Yes	
We Energies	Yes	
Consumers Energy Company	Yes	
PSEG Enterprise Group Inc Companies	Yes	
Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Colmac Clarion	Yes	
Progress Energy	Yes	
Ameren	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**5. If you have any other comments on the SAR or proposed modifications to CIP-001-1 and EOP-004-1 that you haven't provided in response to the previous questions, please provide them here.**

**Summary Consideration:** Stakeholders provided many good comments that should be considered in the development of the standards under this project. The SAR DT does not believe that these require any revisions to the SAR and will forward these comments to the Standard Drafting Team for its consideration in developing the standard(s). These include:

- 1 Consolidation of reports: The SAR DT agrees with this concept and will forward the comment to the Standard Drafting Team for its consideration.
- 2 Concerns about pre-determination of combining CIP-001 and EOP-004 into one standard: The SAR states: CIP-001 *may* be merged with EOP-004 to eliminate redundancies. The two standards may be left separate.
- 3 Reporting criteria in multiple tables: The team agrees that it would be easier if there were only one table. Part of this SAR is to eliminate redundancies and make general improvements to the standard. The team also agrees that the requirements developed should be clear in their reliability objective.

Organization	Question 5 Comment
PSEG Enterprise Group Inc Companies	<p>The PSEG Companies ask that the drafting team allow sufficient flexibility for sabotage recognition and reporting requirements such that nothing precludes utilizing a single corporate-wide program for both bulk electric system assets and other businesses. PSEG's Sabotage Recognition, Response and Reporting Program is directed to all business areas which are directed to follow the same internal protocol that also satisfies the NERC Standards requirements. For example, for gas assets, PSEG's gas distribution business follows the PSEG corporate-wide program for sabotage recognition and response. PSEG agrees that some modifications should be made to CIP-001 (ex. better define or give examples of sabotage) and EOP-004 to make them clearer? If they are merged, then Sabotage will not be in the title (or the primary focus) because several of the Disturbances that reporting is required for in EOP-004 have nothing to do with sabotage. EOP-004 has criteria listed in 4 places to determine when to send a report:</p> <ul style="list-style-type: none"> <li>o Criteria listed in EOP-004 Attachment 1</li> <li>o Criteria listed in EOP-004 Attachment 2</li> <li>o Criteria listed in top portion of Table 1-EOP-004</li> <li>o Criteria listed in bottom portion of Table 1-EOP-004</li> </ul> <p>Therefore, it would be much easier if there was one table of criteria for reference that addressed all of the reportable conditions and all of the applicable reports. If the 2 standards are merged as suggested in the SAR, any differences in the reporting obligation for actual or attempted sabotage and reporting of disturbances must be clear.</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Question 5 Comment
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees that it would be easier if there were only one table. Part of this project is to eliminate redundancies and make general improvements to the standard. The team also agrees that the requirements developed should be clear in their reliability objective. The team will forward your comment to the standard drafting team for its consideration in the drafting of the standard.</b></p>	
Kansas City Power & Light	<p>If it is desirable to keep CIP-001 and EOP-004 separate, it is recommended the SDT consider adding a reference in CIP-001 to the DOE reporting form either by name or by internet link in the standard.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR SDT recommends eliminating all references to the DOE report, so there won't be a reference to it in CIP-001.</b></p>	
IRC Standards Review Committee	<p>We suggest that the revision not be conducted with a preconceived notion that the two standards must be combined since there are some differences between sabotage and emergency system conditions, and in the communication and reporting processes and channels. We suggest the SDT start off with a neutral position to focus on improving the standards, then assess the pros and cons of merging the two based on technical merit only.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states: CIP-001 may be merged with EOP-004 to eliminate redundancies. The two standards may be left separate.</b></p>	
Pepco Holdings, Inc. - Affiliates	<p>Consider CIP-008-2 as potentially having overlaps with the proposed standard</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states "Specific references to the DOE form need to be eliminated." This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states: Consider FirstEnergy's suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality. This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>	
FirstEnergy	<ol style="list-style-type: none"> <li>1. Under Industry Need it states: "The existing requirements need to be revised to be more specific and there needs to be more clarity in what sabotage looks like." The use of the phrase "more specific" should be qualified by adding "while not being too prescriptive". As with other reliability standards, we do not want a standard that causes unwarranted and unnecessary additional work and costs to an entity to comply.</li> <li>2. As pointed out by the NERC Audit and Observation Team in the "Issues to be considered" for CIP-001, clarification is needed regarding contacting the FBI. Prior audits dwelled heavily on FBI notification. For example, our policy states that Corporate Security notifies the FBI. In recent events it appears that local law enforcement handles day to day activities. The notification process for</li> </ol>



Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Question 5 Comment
	<p>contacting the FBI needs clarification along with specific instances in which to call them. Who should make the call to the FBI? It appears that a protocol needs to be developed to clarify what events require notifying the FBI. It could be as simple as after an incident a standard form is completed and forwarded to the FBI, letting them decide if follow up is needed.</p> <p>3. We suggest aligning all reporting requirements for consistency. The items requiring reporting and the timelines to report are very inconsistent between NERC and the DOE. NERC's timelines are also not consistent with their own Security Guideline for the Electricity Sector: Threat and Incident Reporting.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p>The team concurs that the standards should provide the “what” without the “how”. The standard drafting team will develop the standards using the NERC Standard Development Process that includes stakeholder consensus. The team does not feel it is necessary to add the “not too prescriptive” qualifier to the SAR.</p> <p>The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</p> <p>The team concurs with your comment and notes that other commenters have suggested “one stop shopping” reporting for disturbances and sabotage. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</p>	
Electric Market Policy	CIP-008-1 Incident Reporting and Response Planning include some requirements that require coordination with the requirements addressed in this project.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states “Specific references to the DOE form need to be eliminated.” This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states:</b></p> <p><b>Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</b></p> <p><b>This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>	
MRO NERC Standards Review Subcommittee	<p>A. The SAR states that there may be impact on a related standard, COM-003-1 (page SAR-5). Is the SDT referring to Project 2007-02, Operating Personnel Communication Protocols? If so, this is a SAR too and should not be used as a reference.</p> <p>B. CIP-001-1 and EOP-004-1 should be combined into one EOP Standard.</p> <p>C. Within EOP-004-1 there is industry confusion on what form to submit in the event of an event. There should only be one form for the new combination Standard eliminating the need for reporting form attachments. It should be the DOE Form, OE-417. Although it is beyond the scope of this SAR, it would greatly benefit industry if there was a central location on the NERC website containing ALL reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable the System Operators to efficiently locate the most current version of the appropriate form in order to report events.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

---

Organization	Question 5 Comment
	<p>D. The word Disturbance is primarily used in other Standards as in, Disturbance Control Standard or system separation due to a disturbance. Should the NERC definition be updated? Should the word "Sabotage" be defined by NERC? Additionally, we recommend that one definition of "Sabotage" be utilized industry-wide, instead of varying definitions by multiple groups like the DOE, ESIAC, etc.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>A. It does reference project 2007-02, and it has been noted in the SAR.</b></p> <p><b>B. Will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p> <p><b>C. The team concurs with your comment and notes that other commenters have suggested "one stop shopping" reporting for disturbances and sabotage. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p> <p><b>D. References to DOE are to be removed from the standards per the SAR. FERC Order 693 directives include definition of sabotage for CIP-001.</b></p>	
Lands Energy Consulting	<p>One final comment on CIP-001-1. My clients received universally rude treatment from the FBI field offices when they attempted to establish the contacts required by the Standard. If the FBI doesn't see value in establishing these contacts, remove the requirement from the Standard. Making sure the LSE knows the FBI field office phone number is probably all the Standard should require.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
Colmac Clarion	<p>Need single report for Sabotage so whatever is required results in notification of all parties (State Emergency Management, Homeland Security, FBI, Grid Reliability Chain of Command). Any and all of these can 'expand' knowledge later but all seem to require 'instant' notification.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concur with your comment and notes that other commenters have suggested "one stop shopping" reporting for disturbances and sabotage. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
Cowlitz County PUD	<p>Local Law enforcement agencies often are not friendly to Federal involvement with smaller problems they consider their "turf." Need to make sure the small stuff stays with them, however have a system of internal reporting that will catch coordinated sabotage efforts (multiple attacks on DPs and small BAs) at the RC or RE level who then can report to the Federal agencies. Currently EOP-004-1 requires small entities to report a "disturbance" if half of their firm customer load is lost. For some entities, this can be one small substation going down due to a bird. The "50% of total demand" requirement should be removed or improved to better define a true BPS disturbance.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Question 5 Comment
<p><b>Response: The DSR SAR DT thanks you for your comment. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
<p>Exelon</p>	<p>Exelon agrees this is a worthwhile project and that reliability will be enhanced and the compliance process will be simplified by clarifying terminology and reporting requirements in these standards. If nothing else, defining "Sabotage" so as to end interpretations of this term and the related requirements is necessary.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p>	
<p>ERCOT ISO</p>	<p>Due to the fact that both the CIP-001-1 and EOP-004-1 have similar reporting standards, initially combining the two sounds like a correct analysis. However, after further consideration and due to the critical nature of its intended function involving Security aspects, the CIP-001 should be intensely evaluated to determine if its intended purpose meets the threshold or criteria to stand alone. The existing standards for CIP-001-1 Sabotage Reporting may help prevent future mitigation actions caused by sabotage events. EOP-004-1 Disturbance Reporting is administrative in nature, thus the jeopardy of the Bulk Electric System reliability is impacted only if analysis is not performed or if corrective follow-up actions are not implemented. Combining EOP-004 Standard requirements under the umbrella of the CIP -001 Standard would create a high profile Disturbance Reporting Standard. The industry would be better served if information defining sabotage was provided as well as a technical reference document on recognizing sabotage that would also clarify or state any personnel training requirements. All aspects of the intended functions must be reviewed before merging the two standards. At a minimum, we must consider modification that provides improved understanding of the reporting standards and implications as they are currently written.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states: CIP-001 <i>may</i> be merged with EOP-004 to eliminate redundancies. The two standards may be left separate. One of the FERC Order 693 directives for CIP-001 states:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p> <p><b>The Standard Drafting Team will follow the NERC Standard Development Process in making revisions under this SAR, including a thorough review of the requirements of both standards. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
<p>MidAmerican Energy</p>	<p>Conflicting time frames exist from document updates. Reporting should be consolidated to one form and / or site to minimize conflicts, confusion, and errors. 1) Reporting requirements for the outage of 50,000 or more customers in EOP-004-1 requires a report to be made within one hour while the form OE-417 requires a report be made within six hours of the outage. The six hour reference on the updated OE-417 form is the correct reference. 2) Reporting for either CIP-001 or EOP-004 should center on the DOE Form OE-417. This would eliminate confusion and simplify reporting for system operators thereby directly enhancing reliability during system events. This would also eliminate much of the duplicate material and attachments in EOP-004. 3) Although it is beyond the scope of this SAR, the industry would benefit if there was a central location or link on the NERC website containing all</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Question 5 Comment
	reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable System Operators to more efficiently locate and report events.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team notes that other commenters have suggested “one stop shopping” reporting for disturbances and sabotage. The team concurs that timeframes for similar reports should be the same. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
Georgia System Operations Corp.	Entity reporting to NERC/Regions is needed by NERC and the Regions to accomplish their missions of overseeing the reliability of the BES and enforcing compliance with Reliability Standards. An entity not reporting as quickly as possible does not harm the integrity of the Interconnection. In fact, it increases the risk to the BES to be investigating details and filling out forms during a time when attention should be on correcting or mitigating an incident.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees that non-reporting, in the administrative sense, may not harm the integrity of the Interconnection. The team suggests that the appropriate avenue for addressing this concern is through the development of Violation Risk Factors and Violation Severity Levels for each requirement. These compliance elements will be developed during the standard drafting stage of the development process.</b></p>	
Illinois Municipal Electric Agency	IMEA recommends the following considerations: Simplification of reportable events and the reporting process should be the overriding objective. NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting (Version 2.0) should be updated to support this standards development initiative. At some point in the process, it may help if examples are given of events actually reported that did not need to be reported.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team notes that other commenters have suggested “one stop shopping” reporting for disturbances and sabotage. The team agrees that NERC’s Security Guide should be in sync with the standards. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s). One of the FERC Order 693 directives for CIP-001 states:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p> <p><b>Events that were reported, but didn’t need to be, may be identified in “lessons learned”.</b></p>	
WECC	No
Luminant Power	None
Oncor Electric Delivery	No Additional Comments

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

---

Organization	Question 5 Comment
NextEra Energy Resources, LLC	No comment.
Ameren	None

## **Consideration of Comments on Disturbance and Sabotage Reporting — Project 2009-01**

The Disturbance and Sabotage Reporting Standard Drafting Team thanks all commenters who submitted comments on the proposed Concepts Paper for Disturbance and Sabotage Reporting. The document was posted for a 30-day public comment period from March 17, 2010 through April 16, 2010. Stakeholders were asked to provide feedback on the standards through a special Electronic Comment Form. There were 41 sets of comments, including comments from more than 95 different people from approximately 50 companies representing 8 of the 10 Industry Segments as shown in the table on the following pages.

The comments have been sorted and organized by question number in this report; the comments are shown in the original format on the following project web page:

[http://www.nerc.com/filez/standards/Project2009-1\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-1_Disturbance_Sabotage_Reporting.html)

### **Summary Consideration:**

#### **Use of “NERC Guideline: Threat and Incident Reporting”**

Most stakeholders agree that existing guidance should be used as the foundation for disturbance reporting. Most commenters felt that the “NERC Guideline: Threat and Incident Reporting” document contains a lot of detailed information which greatly assists in determining reporting events and weaning out non important events. The most common desire was one, common form to be used for reporting and the OE-417 was considered to be a good starting point. Most respondents thought the form could be streamlined. The DSR SDT was urged to focus on applicable events and reporting timelines which are not clear now and to report items that are clearly essential to the reliability of the BES. There was some concern expressed about “over-reporting”, out of fear of non-compliance rather than the over the reliability of the BES. There was also a clear desire to separate out vandalism & copper theft from reporting requirements.

#### **Hierarchy for Reporting Disturbances**

Most stakeholders (about 2/3) agree with the concept of developing a reporting hierarchy for disturbances. Stakeholders who disagreed believed that the RC should be one of many to receive information on impact events (DOE, RRO, etc.). Such a hierarchy would lead to reporting delays (leading to lack of situational awareness), be cumbersome and complicated and clouds responsibility for who is to report what to whom. Other negative comments believed that a hierarchy would distract the RC’s focus from its primary responsibility. Those stakeholders who agreed commented that the RC should be the collection point for reports and information and take the responsibility to forward as required. This is from the concept that the RC has the “wider view” and can recognize patterns, and has the ability to “escalate” the reporting process. This would also minimize duplication of reports and information.

#### **Single Form for All Agencies**

Most stakeholders agreed with the concept of having one reporting form for all entities. Several commenters suggested that there is no need for a standard on reporting as they considered it administrative in nature. Most dissenters thought there should be a guideline, rather than an enforceable standard. There is widespread agreement that the one-size-fits-all approach would be very difficult to get agreement on, given the different countries and

agencies involved. Many stakeholders pointed out that consistency and simplification were drivers for one report form. Having multiple recipients, with different information requirements, seems to support an electronic format that would guide information only to those who need it. The concept of an electronic reporting tool will need to be further vetted and developed.

### **Supplements to NERC Form**

Most stakeholders agreed with the concept of entities being able to use information from other sources such as the OE-417 form, to supplement the NERC report form. Some thought that duplicate reports were acceptable, as long as the information was not duplicated (if # of customers lost is required on form A, don't ask on forms B & C). Several stakeholders commented on the need for an electronic, one stop reporting tool. This would avoid duplication while ensuring that the information reported goes only to intended recipients. With an electronic, one stop reporting tool, reports can be updated/corrected instantly, without repeating previously submitted information. Some stakeholders cautioned that the OE-417 can change every three years and this should be taken into account when developing an electronic reporting tool. Again, such a reporting tool would need to be vetted and developed to meet reliability needs.

### **Impact Events**

The majority of stakeholders agreed with the concept of "impact events." Some stakeholders felt that the introduction of impact events increased the risk that some items will go unreported. However, most felt that impact events would dramatically increase the number of reports being submitted, and it would be difficult to separate important information from background noise. Several respondents felt that the SDT ignored the FERC Directive, and did not define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event. Many respondents supplied the SDT with their own definition of "Sabotage". The DSR SDT believes that the concept of impact events and the specificity of what needs to be reported in the standard will be an equally efficient and effective means of address the FERC directive regarding sabotage. Some stakeholders felt that impact events add another layer of uncertainty to the reporting. Even with the switch from sabotage to impact events, several felt that "intent" was still key to determining reportability.

### **Regional Differences**

Several commenters provided information on regional reporting. The SDT will consider whether these should be included in the continent-wide standard. These include:

1. NPCC maintains a document and reporting form (Document C-17 - Procedures for Monitoring and Reporting Critical Operating Tool Failures) that outlines the reporting requirements, responsibilities, and obligations of NPCC RCs in response to unforeseen critical operating tool failures.
2. For other events that do not meet the OE-417 and EOP-004 reporting criteria, ReliabilityFirst expects to receive notification of any events involving a sustained outage of multiple BES facilities (buses, lines, generators, and/or transformers, etc.) that are in close proximity (electrically) to one another and occur in a short time frame (such as a few minutes).
3. WECC sets its loss of load criteria for disturbance reporting at 200 MW rather than the 300 MW in the NERC reporting form.
4. SERC and RFC are developing additional requirements at this time. We suggest that reporting be based on impact to reliability, not on 'newsworthy'

events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirements.

5. Some entities identified some in-force Regional Standards and other regional reporting requirements.

### **Project Scope**

Some stakeholders suggested that the SDT has gone beyond its approved scope to “further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” Further, there is no requirement to create a Reporting Standard to define sabotage. The SDT contends that the development of impact events and the reporting requirements for them will provide the clarity sought in the directive. Other stakeholders suggested that the SDT should seek to retire sanctionable requirements that require event reporting in favor of guidelines for reporting. Several commenters suggested that the introduction of impact events actually expands the reporting requirements. It should be noted that the list of impact events is expected to be explicit as to who is to report what to whom and within certain timelines.

### **Electronic Tool**

Several stakeholders provided input as to what they believed an electronic reporting tool should contain:

- 1 If the decision is made to go to a single reporting form, it should be developed to cover any foreseeable event.
- 2 The SDT should work toward a single form, located in a central location, and submitted to one common entity (NERC)
- 3 Reports should be forwarded to the ES-ISAC, not NERC, as the infrastructure is already in place for efficient sharing with Federal agencies, with the regional entities and with neighboring asset owners. Reports should flow to all affected entities in parallel, rather than series (timing issues).

Commenters also suggested that the SDT should consider the impacts of the reporting requirements on the small and very small utilities.

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Herbert Schrayshuen, at 609-452-8060 or at [Herb.Schrayshuen@nerc.net](mailto:Herb.Schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

---

<sup>1</sup> The appeals process is in the Reliability Standards Development Procedures: <http://www.nerc.com/standards/newstandardsprocess.html>.



## Index to Questions, Comments, and Responses

1. The details of reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and will consider guidance found in the document “NERC Guideline: Threat and Incident Reporting” in the development of requirements. Do you agree with using the existing guidance as the foundation for disturbance reporting? Please explain your response (yes or no) in the comment area..... 12
2. The DSR SDT is considering developing a reporting hierarchy for disturbances that requires entities to submit information to the Reliability Coordinator and then for the Reliability Coordinator to submit the report. Do you agree with this hierarchy concept? Please explain your response (yes or no) in the comment area..... 24
3. The goal of the DSR SDT is to have one report form for all functional entities (US, Canada, Mexico) to submit to NERC. Do you agree with this change? Please explain your response (yes or no) in the comment area. .... 34
4. The goal of the DSR SDT is to eliminate the need to file duplicate reports. The standards will specify information required by NERC for reliability. To the extent that this information is also required for other reports (e.g. DOE OE-417), those reports will be allowed to supplement the NERC report in lieu of duplicating the entries in the NERC report. Do you agree with this concept? Please explain your response (yes or no) in the comment area. .... 42
5. In its discussion concerning sabotage, the DSR SDT has determined that the spectrum of all sabotage-type events is not well understood throughout the industry. In an effort to provide clarity and guidance, the DSR SDT developed the concept of an impact event. By developing impact events, it allows us to identify situations in the “gray area” where sabotage is not clearly defined. Other types of events may need to be reported for situational awareness and trend identification. Do you agree with this concept? Please explain your response (yes or no) in the comment area. .... 51
6. If you are aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004 please provide them here..... 61
7. If you have any other comments on the Concepts Paper that you haven’t already provided in response to the previous questions, please provide them here..... 65

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	John Bee	Exelon	X		X		X						
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>					<b>Segment Selection</b>					
		1. Dan Brotzman	ComEd	RFC					1					
		2. Dave Weaver	PECO	RFC					1					
		3. Ron Schloendorn	PECO	RFC					1					
		4. John Garavaglia	ComEd	RFC					1					
		5. Karl Perman	Exelon	NA - Not Applicable					NA					
		6. Dave Belanger	Exelon Generation Co., LLC	RFC					5					
		7. Alison MacKellar	Exelon Generation Co., LLC	RFC					5					
		8. Tom Leeming	ComEd	RFC					1					
		9. Tom Hunt	PECO	RFC					1					
2.	Group	Guy Zito	Northeast Power Coordinating Council											X
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>					<b>Segment Selection</b>					
		1. Alan Adamson	New York State Reliability Council, LLC	NPCC					NA					
		2. Michael Schiavone	National Grid	NPCC					1					

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

	Commenter	Organization	Industry Segment											
			1	2	3	4	5	6	7	8	9	10		
3.	Roger Champagne	Hydro-Quebec TransEnergie	NPCC						2					
4.	Kurtis Chong	Independent Electricity System Operator	NPCC						2					
5.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC						1					
6.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC						1					
7.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC						10					
8.	Ben Eng	New York Power Authority	NPCC						4					
9.	Brian Evans-Mongeon	Utility Services	NPCC						8					
10.	Mike Garton	Dominion Resources Services, Inc.	NPCC						5					
11.	Brian L. Gooder	Ontario Power Generation Incorporated	NPCC						5					
12.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC						3					
13.	David Kiguel	Hydro One Networks Inc.	NPCC						1					
14.	Michael R. Lombardi	Northeast Utilities	NPCC						1					
15.	Randy MacDonald	New Brunswick System Operator	NPCC						2					
16.	Bruce Metruck	New York Power Authority	NPCC						6					
17.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC						10					
18.	Robert Pellegrini	The United Illuminating Company	NPCC						1					
19.	Saurabh Saksena	National Grid	NPCC						1					
20.	Kathleen Goodman	ISO - New England	NPCC						2					
21.	Greg Campoli	New York ISO	NPCC						2					
3.	Group	Wes Davis (SERC Staff) and Steve Corbin (Chair of SERC RCS)	SERC Reliability Coordinator Sub-committee (RCS)											X
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.	Steve Corbin	Southeastern RC	SERC	NA										
2.	Joel Wise	TVA RC	SERC	NA										
3.	Don Reichenbach	VACAR South RC	SERC	NA										
4.	Don Shipley	ICTE RC	SERC	NA										
5.	Robert Rhodes	SPP RC	SERC	NA										
6.	Stan Williams	PJM RC	SERC											

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting – Project 2009-01

	Commenter	Organization	Industry Segment										
			1	2	3	4	5	6	7	8	9	10	
7.	Tim Aliff	Midwest ISO RC	SERC					NA					
4.	Group	Mike Garton	Electric Market Policy	X		X		X	X				
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>					<b>Segment Selection</b>				
1.	Michael Gildea	Dominion Resources Services, Inc.		RFC					3				
2.	Louis Slade	Dominion Resources Services, Inc.		SERC					6				
5.	Group	Carol Gerou	MRO's NERC Standards Review Subcommittee										X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>					<b>Segment Selection</b>				
1.	Chuck Lawrence	American Transmission Company		MRO					1				
2.	Tom Webb	WPS Corporation		MRO					3, 4, 5, 6				
3.	Terry Bilke	Midwest ISO Inc.		MRO					2				
4.	Jodi Jenson	Western Area Power Administration		MRO					1, 6				
5.	Ken Goldsmith	Alliant Energy		MRO					4				
6.	Dave Rudolph	Basin Electric Power Cooperative		MRO					1, 3, 5, 6				
7.	Eric Ruskamp	Lincoln Electric System		MRO					1, 3, 5, 6				
8.	Joseph Knight	Great River Energy		MRO					1, 3, 5, 6				
9.	Scott Nickels	Rochester Public Utilities		MRO					4				
10.	Terry Harbour	MidAmerican Energy Company		MRO					1, 3, 5, 6				
6.	Group	Linda Perea	Western Electricity Coordinating Council										X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>					<b>Segment Selection</b>				
1.	Steve Rueckert	WECC		WECC					10				
7.	Group	Kenneth D. Brown	Public Service Enterprise Group Companies	X		X		X	X				
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>					<b>Segment Selection</b>				
1.	Ron Wharton	PSE&G		RFC					1, 3				
2.	Dave Murray	PSEG Power Connecticut		NPCC					5				
3.	Jim Hebson	PSEG Energy Resource & Trade		ERCOT					6				
4.	Jerzy Sluarz	PSEG Fossil		RFC					5				

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

	Commenter	Organization	Industry Segment											
			1	2	3	4	5	6	7	8	9	10		
5	Bruce Wertz	Odessa Ector Power Partners	ERCOT					5						
6	Peter Dolan	PSEG Energy Resource & Trade	RFC					6						
8.	Group	Laura Zotter	ERCOT ISO		X									X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						
1.	Steve Myers	ERCOT ISO	ERCOT					2, 10						
2.	Jimmy Hartmann	ERCOT ISO	ERCOT					2, 10						
3.	Christine Hasha	ERCOT ISO	ERCOT					2, 10						
9.	Group	Ben Li	ISO RTO Council Standards Review Committee		X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						
1.	Al Dicaprio	PJM	RFC					2						
2.	Jame Castle	NYISO	NPCC					2						
3.	Lourdes Estrada-Salinerio	CAISO	WECC					2						
4.	Matt Goldberg	ISO-NE	NPCC					2						
5.	Steve Myers	ERCOT	ERCOT					2						
6.	Bill Phillips	MISO	RFC					2						
7.	Mark Thompson	AESO	WECC					2						
8.	Charles Yeung	SPP	SPP					2						
10.	Group	Denise Koehn	Bonneville Power Administration	X		X		X	X					
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						
1.	Tedd Snodgrass	BPA, Transmission Dispatch	WECC					1						
2.	Jim Burns	BPA, Transmission Technical Operations	WECC					1						
3.	Jeff Millenor	BPA, Security & Emergency Response	WECC					1, 3, 5, 6						
11.	Group	Jason L. Marshall	Midwest ISO Standards Collaborators		X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting – Project 2009-01**

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
1.		Bob Thomas	IMEA	SERC					4					
2.		Jim Cyrulewski	JDRJC Associates, LLC	RFC					8					
3.		Joe Knight	Great River Energy	MRO					1, 3, 5, 6					
4.		Randi Woodward	Minnesota Power	MRO					1					
5.		Kirit Shah	Ameren	SERC					1					
12.	Group	Sam Ciccone	FirstEnergy	X		X	X	X	X					
Additional Member		Additional Organization		Region					Segment Selection					
1.		Doug Hohlbaugh	FE	RFC					1, 3, 4, 5, 6					
2.		Dave Folk	FE	RFC					1, 3, 4, 5, 6					
13.	Individual	Thomas Glock	Arizona Public Service Company	X		X		X						
14.	Individual	Sandra Shaffer	PacifiCorp	X		X		X	X					
15.	Individual	Brent Ingebrigtsen	E.ON U.S. LLC	X		X		X	X					
16.	Individual	Steve Fisher	Lands Energy Consulting											
17.	Individual	David Kahly	Kootenai Electric Cooperative			X								
18.	Individual	Darryl Curtis	Oncor Electric Delivery Company LLC	X										
19.	Individual	Edward Bedder	Orange and Rockland Utilities, Inc.	X										
20.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X					
21.	Individual	Brian Bartos	Bandera Electric Cooperative, Inc.	X		X								
22.	Individual	John T. Walker	Portland General Electric	X										
23.	Individual	Gregory Miller	BGE	X										

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
24.	Individual	Dan Roethemeyer	Dynegey Inc.					X						
25.	Individual	Rick Terrill	Luminant					X						
26.	Individual	James Stanton	SPS Consulting Group Inc.								X			
27.	Individual	Andrew Gallo	Calpine Corp.					X						
28.	Individual	Steve Alexanderson	Central Lincoln			X								
29.	Individual	Brenda Frazer	Edison Mission Marketing & Trading					X						
30.	Individual	Martin Bauer	USBR					X						
31.	Individual	John Alberts	Wolverine Power Supply Cooperative, Inc.	X		X	X	X	X					
32.	Individual	Thad Ness	American Electric Power	X		X		X	X					
33.	Individual	James McCloskey	Central Hudson Gas & Electric	X		X								
34.	Individual	Deborah Schaneman	Platte River Power Authority	X		X		X						
35.	Individual	Howard Rulf	We Energies			X	X	X						
36.	Individual	Jianmei Chai	Consumers Energy Company			X	X							
37.	Individual	Amir Hammad	Constellation Power Source Generation					X						
38.	Individual	Greg Rowland	Duke Energy	X		X		X	X					
39.	Individual	Kirit Shah	Ameren	X		X		X	X					
40.	Individual	Dan Rochester	Independent Electricity System Operator		X									

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

---

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
41.	Individual	Roger Champagne	Hydro-Québec TransEnergie (HQT)	X										



1. The details of reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and will consider guidance found in the document “NERC Guideline: Threat and Incident Reporting” in the development of requirements. Do you agree with using the existing guidance as the foundation for disturbance reporting? Please explain your response (yes or no) in the comment area.

**Summary Consideration:** Most stakeholders agree that existing guidance should be used as the foundation for disturbance reporting. Most commenters felt that the “NERC Guideline: Threat and Incident Reporting” document contains a lot of detailed information which greatly assists in determining reporting events and weaning out non important events. The most common desire expressed was to have one common form for all reporting, and the OE-417 was suggested as a good starting point. Most respondents thought the form could be streamlined. The DSR SDT was urged to focus on applicable events and reporting timelines which are not clear now and to report items that are clearly essential to the reliability of the BES. There was some concern expressed about “over-reporting”, out of fear of non-compliance rather reporting based on the reliability of the BES. There was also a clear desire to exclude vandalism & copper theft from reporting requirements.

Several specific suggestions were made to modify existing reporting requirements, and the drafting team will consider these when developing the proposed requirements.

Organization	Yes or No	Question 1 Comment
ERCOT ISO	Possible Yes	Parts of the Guideline are helpful, but the guideline goes beyond the scope of the requirements of the current standards, which could pose potential audit concerns. ERCOT ISO strongly feels this approach for reporting should be focused on physical events only and cyber event reporting should be contained within CIP-008 only. Continue to keep physical separate from cyber.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). The DSR SDT will take into consideration your comment on keeping cyber and physical events separate.</p>		
Arizona Public Service Company	No  Then Yes	APS supports standard revisions which streamline the reporting process for security incidents with a single form, which aligns both with EIA reporting and NERC Standards requirements, particularly those identified in the NERC Threat and Incident Reporting Guidelines. This would eliminate users issuing reports to multiple locations/government entities without a standard form or format. The DOE 417 form which is currently utilized

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>for reporting purposes is out-dated and does not account for the types of incidents as identified in the NERC Threat and Incident Reporting Guidelines. The guidelines state that an entity can report security incidents to the ESISAC , through CIPIS (Critical Infrastructure Protection Information System), and or RCIS (Reliability Coordinator Information Center). CIPIS refers an entity to the NICC and to the WECC. Additionally, APS proposes that the terms and timelines of reporting security incidents be clearly identified. Events are often detected quickly or immediately. Determining whether or not the event was sabotage and/or a reportable event; however, typically takes much longer. There is no time allowance for an entity to investigate the event to determine what actually occurred. Currently, DOE 417 provides that acts of sabotage should be reported within one hour of detection if the impact could affect the reliable operation of the bulk power system. This may affect the accuracy of the information being provided by an entity on it's initial reporting. Finally, provisions should be incorporated to address the privacy of information being submitted, including handling and storage.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s) which should streamline the reporting process (what events and what timeline should be used). c</b></p>		
SPS Consulting Group Inc.	No	<p>At least not exclusively. The current standards and the guidance fail to consider that different registered entities will have different scopes of awareness for when disturbances may take place. We want to avoid the situation where a generator (for example) is cited for failure to report a disturbance of which they have way of knowing occurred.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT will take into consideration what Registered Entities are to be included within the yet to be written standard(s) based on the SAR and the facilities each type of Registered Entity is required to have.</b></p>		
Bonneville Power Administration	No Then Yes	<p>BPA likes the idea of consolidating information and eliminating duplication of reported information. In the report, don't include every detail possible found in the “Threat Guideline”. TOP's are supposed to be operating the electrical system, not doing investigative work for copper theft incidents (see comment on #5).</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). We will consider your specific suggestion for not requiring reporting of incidents such as copper threat, when we develop the proposed requirements.</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
Lands Energy Consulting	No	<p>My firm provides compliance consulting services to a number of smaller (50-700 MW peak load) LSE/DP registered entities. EOP-004 creates an obligation for LSEs to report "disturbances" that affect their systems. A few of the smaller of these systems receive service from Bonneville-owned transmission lines that serve only 4-6 substations. The NERC Form establishes loss of 50% of the LSE's retail customers as a reportable disturbances. One of my clients receives service from BPA at 5 substations. A single industrial customer with a substantially dedicated substation comprises 90% of the utility's MWH load. Were it not for this customer, the utility would have been well below the registration requirement for a DP/LSE. The balance of the load, about 15 MW of peak and 4000 retail customers, is served from 5 substations. Four of these substations serving 3000 customers are served from a long Bonneville 115 kV BES transmission line that runs through a heavily treed right of way. Every time this single line experiences a permanent outage (which will happen a few times a year), the utility loses less than 10 MW of load, but 75% of its retail customers. Under the disturbance reporting criteria, this outage would constitute a reportable disturbance for the utility. When the NERC disturbance reporting criteria were adopted, I doubt that anyone conceived that they would apply to cases like I just described. Reporting trivial events like I've just described constitutes a nuisance to the entity making the report and NERC/WECC for having to process the report. The outage has no earthly effect on the reliability of the BES and certainly doesn't warrant preparation of any kind of disturbance report.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT will take into consideration what Registered Entities are to be included within the yet to be written standard(s) based on the NERC Standards Committee approved SAR. The DSR SDT will review the Commissions concern that, an adversary might determine that a small LSE is the appropriate target when the adversary aims at a particular population or facility, as stated in FERC Order 693, paragraph 459. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b></p>		
SERC Reliability Coordinator Sub-committee (RCS)	No	<p>Routine minor incidents such as copper theft and gun shots to insulators should not be reported. These types of minor events do not affect the reliability of the BPS. Existing reporting requirements are satisfactory. The focus of reporting should be on reliability related incidents and not incidents related to vandalism as such.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). Reporting thresholds will be determined during the next step of the Standards Development process. The DSR SDT agrees with your comments on vandalism but a balance must be further explored to meet industry and regulatory requirements specifically under FERC Order 693.</b></p>		
Consumers Energy Company	No	<p>The existing guidelines ignore the fact that there are currently three overlapping and inconsistent reporting requirements for disturbances of various types: CIP-001, EOP-004, and DOE OE-417. The reporting should be such that any single event type needs to be reported only once, and to only a single agency, for any</p>

Organization	Yes or No	Question 1 Comment
		<p>disturbance. First, CIP-001 events should be reported to the ES-ISAC under one specific requirement (or set of requirements) and removed from OE-417 and EOP-004, such that all interested agencies obtain their information from only that one source. Second, OE-417 events should be reportable ONLY to DOE, and, again, other agencies should obtain their information from only that one source. If NERC wishes to make such reporting mandatory and enforceable, the NERC requirements should indicate ONLY that such reporting should be made in accordance with OE-417. Finally, EOP-004 (or similar requirements) should require reporting to NERC ONLY in the case of events that don't fit under CIP-001 or OE-417 requirements. Alternatively, OE-417 should be submitted ONLY to NERC and they should disseminate the information. EOP-004 has several issues and inconsistencies:</p> <p>a. EOP-004 requires that the entity that submits form DOE-417 to provide copies to NERC. The DOE-417 form intermixes NERC entity definitions (e.g. BA, LSE, TO) with generic terms such as "<u>Electric Utilities</u>" and "<u>Generating Entities</u>". Is it the Generator Owner or Generator Operator that is required to submit the information? There should be one form or at least well defined definitions that apply to both forms.</p> <p>b. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change this requirement to 1 hour for several disturbances. Additionally, it incorrectly summarizes the reporting time for 50,000 customers, which is 6 hours in DOE-417 and summarized in Table 1-EOP-004-0 as 1-hour. An attachment to a standard should not be allowed to supersede the standard or create additional rules.</p> <p>c. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change the standard. R3.1 clearly states that events are to be reported within 24 hours of identification, however Table 1-EOP-004-0 state that the events are to be reported on the basis of the start of the disturbance. An attachment to a standard should not be allowed to supersede the standard or create additional rules.</p> <p>d. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change the standard. R3.1 clearly states that events are to be reported within 24 hours of identification, however Table 1-EOP-004-0 states that copies of DOE-417 are required to be submitted "simultaneously". It also states that schedules 1 and 2 are due within 24 hours of start of the event instead of 48 hours for per DOE-417 for schedule 2. An attachment to a standard should not be allowed to supersede the standard or create additional rules.</p> <p>e. The requirement of loss of customers should be scaled based on customers served. Loss of 50,000 customers to a utility that serves 100,000 customers is different than loss of 50,000 customers to a utility that serves 2,000,000 customers.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted "NERC Guideline: Threat and Incident Reporting" and</b></p>		

Organization	Yes or No	Question 1 Comment
<p>ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT agrees that present Reliability Standards can be complicated and lead to confusion when working on maintaining system reliability in the area of reporting per CIP-001-1 and EOP-004-1. We will consider the disagreements you've identified in existing reporting requirements when we develop the proposed requirements.</p>		
Central Lincoln	No	<p>The guidance document makes no distinction between entities that operate 24/7 dispatch and those that don't. The 1 hour and even the 24 hour reporting requirements in some cases will be impossible for entities without 24/7 dispatch to meet without changing business practices. These are the same entities that present little or no risk to the BES.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted "NERC Guideline: Threat and Incident Reporting" and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT will take into consideration what Registered Entities are to be included within the yet to be written standard(s) based on the SAR. The DSR SDT will establish the "requirements necessary for users, owners, and operators of the Bulk-Power-System" as stated in FERC Order 693, paragraph 617 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</p>		
MRO's NERC Standards Review Subcommittee	No Then Yes	<p>We agree with using the present documentation but would like just one reporting form. We are concerned that the guidelines and reporting periods specified within the DOE OE-417 report conflict with the NERC Guidelines. For example, DOE OE-417 report requires "Suspected Physical or Cyber Impairment" to be reported within 6 hours. The NERC guidelines indicate "Suspected Activities" are to be reported within 1 hour. We recommend the SDT use the DOE OE-417 report as a guiding document, and then determine additional reporting requirements using guidance from the NERC Guideline. FERC Order 693 appears to indicate conflicts and confusion with NERC reporting requirements and DOE reporting requirements should be eliminated.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted "NERC Guideline: Threat and Incident Reporting" and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT is looking to streamline required reporting actions and remove any redundant reporting requirements if at all possible. The DOE Form OE-417 is currently mandatory under Public Law 93-275 for entities within the jurisdiction of the U.S Department of Energy. We will consider the disagreements you've identified in existing reporting requirements when we develop the proposed requirements.</p>		
Luminant	No Then Yes	<p>While the guidance is generally ok in the "NERC Guideline: Threat and Incidence Reporting", the reporting timelines include 1 hour, 2 hours, 4 hours, 6 hours, 8 hours, 24 hours, and 48 hours. Please simplify and reduce the variation in timelines. When it comes to Sabotage reporting, some time requirements start with detection, some start with determination of sabotage and some events do not specify the trigger for the reporting clock to start. Again, please provide clarity and consistency around the start of the timeline for</p>

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
		reporting. Generally, the reporting timing should start with the recognition or determination that a suspected or known sabotage event occurred.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to streamline required reporting actions and remove any redundant reporting requirements if at all possible. The DSR SDT agrees that present Reliability Standards can be complicated and lead to confusion when working on maintaining system reliability in the area of reporting per CIP-001-1 and EOP-004-1. We will consider your specific suggestion for less variation in reporting timeframes, when we develop the proposed requirements.</b></p>		
We Energies	No Then Yes	While the NERC Guideline includes readily discernible information (and we would like to see that format carried forward into any future documentation), utilize OE-417 as the foundation document in order to eliminate reporting redundancies. If supplemental references are necessary for the proposed resolution, list the document as an official attachment to the standard. Minimize the need to search in multiple locations for guideline information - some may not be aware supporting documentation exists without explicit reference within the standard.
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT is looking to streamline required reporting actions and remove any redundant reporting requirements if at all possible. The DSR SDT agrees that present Reliability Standards can be complicated and lead to confusion when working on maintaining system reliability in the area of reporting per CIP-001-1 and EOP-004-1. The DOE Form OE-417 is currently mandatory under Public Law 93-275 for entities within the jurisdiction of the U.S Department of Energy. We will consider your recommendation regarding listing supplemental references within the body of the standard when we draft the proposed standard(s).</b></p>		
American Electric Power	Yes	
Bandera Electric Cooperative, Inc.	Yes	
Calpine Corp.	Yes	
Duke Energy	Yes	
Edison Mission Marketing & Trading	Yes	

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
Exelon	Yes	
Independent Electricity System Operator	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	
Central Hudson Gas & Electric	Yes	<p>Central Hudson agrees with using the “NERC Guideline: Threat and Incident Reporting” in the development of requirements. Central Hudson has currently in place a NERC-DOE Threat and Incident Reporting Table developed from this NERC Guideline that allows for a quick-reference to all threat and incident reporting criteria (arranged by category) with a cross-reference to the specific reporting form (NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report, DOE Form OE-417, or NERC ES-ISAC Threat and Incident Report Form). Central Hudson recommends maintaining the option of utilizing only 1 form, the DOE Form OE-417, for incidents that require reporting to the DOE and NERC to maintain the streamlined approach to this reporting process.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to have a single reporting report form (per question 3) and streamline the reporting processes that may be developed within a yet to be written requirement(s).</b></p>		
E.ON U.S. LLC	Yes	<p>E.ON U.S. believe that the guidelines provide greater clarity for reporting forced outages caused by disturbances and sabotage but there remains issues that in need of further clarification. For example, there remains too much subjectivity on the reporting of forced outages when there is “identification of valuable lessons learned”</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT concurs that further clarification is required with the ambiguous statement “identification of valuable lessons learned” contained in the guideline – use of this phrase does not meet the technical writing threshold required for inclusion in a NERC Standard. The DSR SDT’s intent was to look at the posted NERC Guideline and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). Recommendation of changes to the “NERC Guideline: Threat and Incident Reporting” should be submitted to NERC via the Critical Infrastructure Protection Committee. I</b></p>		
Public Service Enterprise Group Companies	Yes	<p>EOP reportable disturbances are familiar concepts in the industry.</p>

Organization	Yes or No	Question 1 Comment
<b>Response: The DSR SDT thanks you for your comment and support.</b>		
Orange and Rockland Utilities, Inc.	Yes	However, the SDT needs to maintain clear demarcation for the criteria for reporting events, and only those events that directly effect the reliability of the BES.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT has been directed to review all disturbance type activities and submit to the industry a well thought out set of requirements that clearly define disturbance events and what information is required to enhance an entity's situational awareness. Clear demarcation for the criteria for reporting will be determined in the near future based on the approved SAR and industry feedback. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b>		
Wolverine Power Supply Cooperative, Inc.	Yes	I agree with referencing existing guidelines - However: My concern is that, until all reportable incidents are analyzed by the parties to which they are reported, their "impact" on the BES will not be quantified. Therefore, the tendency to want to "report all events so that their impact can be determined" or "report all events because the information can be utilized for informational purposes, regardless of impact on BES" might lead to expanded reporting requirements, some of which may have questionable value from a reliability standpoint.
<b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has been directed to review all disturbance type activities and submit to the industry a well thought out set of requirements that clearly define reportable events and what information is required to enhance an entity's situational awareness. Clear demarcation for the criteria for reporting will be determined in the near future based on the approved SAR and industry feedback. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b>		
Hydro-Québec TransEnergie (HQT)	Yes	In considering guidance found in the document “NERC Guideline: Threat and Incident Reporting”, the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
Northeast Power Coordinating Council	Yes	In considering guidance found in the document “NERC Guideline: Threat and Incident Reporting”, the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will establish the “requirements necessary for users, owners, and operators of</b>		



Organization	Yes or No	Question 1 Comment
<p><b>the Bulk-Power-System” as stated in FERC Order 693, paragraph 617 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b></p>		
Western Electricity Coordinating Council	Yes	It is comprehensive; however, we must keep in mind that the OE-417 is required under Public Law 93-275 and needs to be attached if applicable in the US.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Oncor Electric Delivery Company LLC	Yes	NERC Guideline: Threat and Incident Reporting" document should be used for guidance as it identifies best practices for reporting.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Manitoba Hydro	Yes	The “Threat and Incident Reporting” document contains a lot of detailed information which greatly assists in determining reporting events and weaning out non important events. The document contains some examples and expected reporting time lines. Attachment 1-EOP-004, though considerably smaller and condensed it does contain some detail not mentioned in “Threat and Incident Reporting”. Integrating the “Threat and Incident Reporting” into Attachment 1-EOP-004, though large in size, has lots of information and is easy to follow would be a large improvement to existing protocol OR SEE QUESTION 3 COMMENTS. Incidences we have experienced on our system, in past were difficult to delineate as reportable, who to report to and when. An improvement to this Standard is welcome.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to streamline and remove any redundancies within the NERC Standard’s requirements.</b></p>		
Constellation Power Source Generation	Yes	The existing guidance is an excellent base on which to build changes to EOP-004 and CIP-001. However, the SDT must challenge each item in the different event categories and clarify or omit bullet points that are seemingly vague. For example, under System Disturbances, a forced outage report is needed when “a generation asset of 500 MW or above is on a forced outage for unknown reasons, or a forced outage of generation of 2,000 MW occurs...” Simply removing the 500 MW criteria would make this criterion less vague. There are other examples of this in the guideline.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to streamline and remove any redundancies within the NERC Standard’s requirements. It is the intent of the SDT to carefully review the different event categories and provide clarity where needed to remove ambiguity.</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
ISO RTO Council Standards Review Committee	Yes	<p>The guidelines in EOP-004 and its attachments should be retained as the foundation for reporting disturbances. One would note that such EOP Disturbances are relatively well defined reliability impacts. Thus EOP-004 disturbances are based on HOW certain events impacted the BES. [Sabotage on the other hand requires an implication of WHY an event occurred.]The original EOP-004 represents a common sense approach to defining reliability events that may be useful to analyze on a regional basis. In the current environment, Regions are not sanctionable entities but they still are valuable sources to collect, analyze and trend the few disturbances that occur in each region. To make use of Regions, however, precludes the use of sanctionable NERC standards. EOP-004 as written does not meet the NERC requirements for standards but it does meet the Industry needs for a guideline for reporting events that deserve to be reviewed. The SDT should propose deleting EOP-004 and use it as a Disturbance Reporting Guideline.</p>
<p><b>Response: The DSR SDT thanks you for your comment. Regions are required to comply with requirements in NERC Reliability Standards – however Regions are not sanctioned the same way as users, owners and operators of the bulk power system – if a Region fails to comply with a NERC Reliability Standard, it can be fined for failure to comply under the ERO’s Rules of Procedure.</b></p>		
USBR	Yes	<p>The reporting outlined in the proposed plan does not include a clear indication of how NERC will use the information they collect from the entities. Care needs to be taken in addressing the reporting requirements to not create a more confusing or onerous reporting process.</p>
<p><b>Response: The DSR SDT thanks you for your comment. It is anticipated that NERC will analyze events to assess trends and identify lessons learned for industry feedback and reliability improvement.</b></p>		
FirstEnergy	Yes	<p>This guideline appears to be a good starting point for developing consistency in reporting. However, we believe that after-the-fact event reporting is administrative in nature and seldom rises to the level of mandated reliability standard requirements. It is not clear what reporting would be made through this effort and how it differs from reporting made through the NERC Reliability Coordinator Information System (RCIS). With the initiative for more results-based standards being the goal of NERC, true after the fact reporting-type requirements should become administrative procedures and only be included in standards if they are truly required for preserving an Adequate Level of Reliability. If there are aspects that rise to be retained in a mandatory and enforceable reliability standard, we propose that those associated with sabotage be moved to CIP-001 and that EOP-004 be focused on operational disturbances that warrant wide-area knowledge. However, if the RCIS is the mechanism to convey real-time information and that is presently occurring outside of reliability standards, it is unclear what the delta improvement this project aims to achieve.</p>
<p><b>Response: The DSR SDT thanks you for your comment. As stated in FERC Order, 693, paragraph 611, “Complete and timely data is essential for analyzing system disturbances” and in paragraph 617, “the Commission directs the ERO to develop a modification to EOP-004-1 through the</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
<p>Reliability Standards development process that includes any requirements necessary for users, owners, and operators of the Bulk-Power-System to provide data that will assist NERC in the investigation of a blackout or disturbance”. Some data is needed, therefore, for after-the-fact analyses. In addition, some data is needed much more quickly for situational awareness. The DSR SDT will analyze and determine what constitutes a reportable event and what information is required for situational awareness as opposed to after the fact analyses of events.</p>		
Portland General Electric	Yes	This process is in place and utilities are familiar with it. This is a good place to start.
<p><b>Response: The DSR SDT thanks you for your comment and support.</b></p>		
Ameren	Yes	We agree that it makes sense to build upon existing documentation. However, we do not believe it is necessary to require event reporting to be in an enforceable standard. Rather the drafting team should consider developing a reporting guideline document and retiring the EOP-004 standard.
<p><b>Response: The DSR SDT thanks you for your comment. As stated in FERC Order, 693, paragraph 611, “Complete and timely data is essential for analyzing system disturbances” and in paragraph 617, “the Commission directs the ERO to develop a modification to EOP-004-1 through the Reliability Standards development process that includes any requirements necessary for users, owners, and operators of the Bulk-Power-System to provide data that will assist NERC in the investigation of a blackout or disturbance”. Some data is needed, therefore, for after-the-fact analyses. In addition, some data is needed much more quickly for situational awareness. As envisioned, the requirements developed under this project will address both types of reporting requirements.</b></p>		
Midwest ISO Standards Collaborators	Yes	We agree that it makes sense to build upon existing documentation. However, we do not believe it is necessary to require event reporting to be in an enforceable standard. Rather the drafting team should consider developing a reporting guideline document and retiring the EOP-004 standard. This is further supported by the fact that there is a role in the existing standard for the Regional Entities even though these requirements can’t be enforced against the Regional Entities because they are not a user, owner or operator of the system.
<p><b>Response: The DSR SDT thanks you for your comment. As stated in FERC Order, 693, paragraph 611, “Complete and timely data is essential for analyzing system disturbances” and in paragraph 617, “the Commission directs the ERO to develop a modification to EOP-004-1 through the Reliability Standards development process that includes any requirements necessary for users, owners, and operators of the Bulk-Power-System to provide data that will assist NERC in the investigation of a blackout or disturbance”. Some data is needed, therefore, for after-the-fact analyses. In addition, some data is needed much more quickly for situational awareness. As envisioned, the requirements developed under this project will address both types of reporting requirements.</b></p>		
Dynergy Inc.	Yes	We agree with using the guidance; however, please consider revising the NERC Guideline: Threat and Incident Reporting document to (i) lengthen the reporting timelines related to attempted sabotage to allow for

Organization	Yes or No	Question 1 Comment
		additional time to deem the threat credible, (ii) expand the description of forced outage of generation greater than 2000 MW to include whether it is at the BA or GO level and if GO level, whether it is for one site or the combined GO's sites in a Region, and (iii) add a Responsible Party column to the Appendix A matrix.
<p><b>Response: The DSR SDT thanks you for your comment. Recommendation of changes to the “NERC Guideline: Threat and Incident Reporting” should be submitted to NERC via the Critical Infrastructure Protection Committee since that falls outside the scope of the SAR.</b></p> <p><b>We will consider your specific suggestions for revisions to reporting requirements when we develop the proposed requirements.</b></p>		
BGE	Yes	We have no problem with NERC using the existing guidance as the foundation for disturbance reporting; however, since this project proposes to investigate incorporation of the Cyber Incident reporting aspects of CIP-008, we feel that if adopted, this concept should be added to the NERC Guideline document "Threat and Incident Reporting".
<p><b>Response: The DSR SDT thanks you for your comment. Recommendation of changes to the “NERC Guideline: Threat and Incident Reporting” should be submitted to NERC via the Critical Infrastructure Protection Committee since that falls outside the scope of the SAR.</b></p>		
Electric Market Policy	Yes	Yes; however, in considering guidance found in the document “NERC Guideline: Threat and Incident Reporting” the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will establish the “requirements necessary for users, owners, and operators of the Bulk-Power-System” as stated in FERC Order 693, paragraph 617 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1. As envisioned, the requirements developed under this project will address reporting requirements that are used for after-the-fact analyses as well as reporting requirements that are associated with situational awareness.</b></p>		

**2. The DSR SDT is considering developing a reporting hierarchy for disturbances that requires entities to submit information to the Reliability Coordinator and then for the Reliability Coordinator to submit the report. Do you agree with this hierarchy concept? Please explain your response (yes or no) in the comment area.**

**Summary Consideration:** Most stakeholders (about 2/3) agree with the concept of developing a reporting hierarchy for disturbances. Stakeholders who disagreed believed that the RC should be one of many to receive information on impact events (DOE, RRO, etc.). Such a hierarchy would lead to reporting delays (leading to lack of situational awareness), be cumbersome and complicated and clouds responsibility for who is to report what to whom. Other negative comments believed that a hierarchy would distract the RC’s focus from its primary responsibility. Those stakeholders who agreed commented that the RC should be the collection point for reports and information and take the responsibility to forward as required. This is from the concept that the RC has the “wider view” and can recognize patterns, and has the ability to “escalate” the reporting process. This would also minimize duplication of reports and information.

Organization	Yes or No	Question 2 Comment
BGE	No	As currently worded, BGE opposes the reporting hierarchy concept, since insufficient guidelines were proposed to prevent translation errors between the responsible entity (RE) and the RC. In addition to creating possible reporting errors, this also opens a risk that the RC could misrepresent the true intent of an RE’s report contents if called upon to explain/justify a submitted report. Reporting delays are another concern with this proposal because the RE would basically be relinquishing control of the reporting process to the RC, while ultimately retaining the responsibility for ensuring the report gets submitted within the required timeframe. However, BGE recognizes that avoiding duplication and conflicting reports as well as encouraging communication are valuable. To make the reporting hierarchy concept acceptable to BGE, the DSR SDT must develop proper controls to ensure the RE has the ability to control or approve the information submitted and/or subsequently discussed with the respective authorities, and that it is done within the permissible timeframe to satisfy compliance requirements.
<p>Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk is not transferred, and a mechanism to ensure the Responsible Entity’s reported information remains as submitted.</p>		

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
Consumers Energy Company	No	It would be inefficient for RC's to accumulate ALL disturbance data and submit it, and to bifurcate the reporting based on type of disturbance above and beyond OE-417 data (which should go ONLY to DOE) would make a standard very involved for an entity to comply with. We're discussing after-event data here, not data needed for current operations - and there's no reason to make it any more complicated than necessary.	
Response: The DSR SDT thanks you for your comment. In order for a reporting hierarchy concept to be adopted, it will result in real efficiency gains by eliminating duplication of reports. It will not be pursued if the result is a complicated or burdensome process for responsible entities.			
Exelon	No	Some of the DOE related reporting is driven by distribution events, i.e. outages greater than 50,000 customers, is it realistic to expect the RC, whose focus is on the transmission system to perform distribution related reporting?	
Response: The DSR SDT thanks you for your comment. The DOE Reporting Form OE 417 is currently mandatory by Public Law and only applies to US entities and contains reporting thresholds that are not required by NERC. Our goal is to derive reporting thresholds that meet NERC's needs for information on bulk electric system disturbances and real-time events, not distribution level-only problems.			
USBR	No	The existing reporting methods collect reports of disturbances and analyze them by committees of the respective coordinating councils. The new process would introduce a duplicate layer and associated staffing. It would be better to ensure communication between the existing committees of the respective coordinating councils and the RC rather than creating a new layer of review tracking and analysis. While the layered reporting hierarchy discussed in the Disturbance Reporting section of the paper will eventually help with overall event awareness, the additional delays the hierarchical approach could result in a decrease in situational (timely) awareness. Having more comprehensive information as a result of the potential enhancements each layer adds to the chain of reporting may not be more valuable than timely and well disseminated information in an actual disturbance situation. We would suggest the SDT give careful consideration to this proposed direction. It may be appropriate to consider that expedited reporting of operational impacts would outweigh the benefit of administratively intensive reporting procedures. The events reported through the existing process have not yielded material feedback other than statistical analysis. Statistical analysis is not as sensitive to timely reporting. Operational impacts which may be the result of possible sabotage may be evident through assessment of widespread outage patterns or following event analysis. Comprehensive event analysis can take anywhere from 15 days to 90 days depending on the event.	
Response: The DSR SDT thanks you for your comment. We agree that reporting timeliness must be weighed against the perceived benefits of a reporting hierarchy. If the reporting hierarchy concept is adopted, it should include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted. Also it must result in real efficiency gains and support the reliability of the bulk electric system.			

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 2 Comment
ISO RTO Council Standards Review Committee	No	<p>The idea of a reporting hierarchy provides an easy to follow pro forma approach. But disturbance reports should not always follow a common reporting path. A disturbance on the transmission system for example need not be routed through an “if applicable” Balancing Authority. To mandate that a BA be in the path is inappropriate. To leave the applicability open is to create a subjective compliance problem for the impacted BA. Copper theft is another example that should not require reporting up through the RC. It is a local issue and the Transmission Owner should be able to report this directly to the appropriate parties. How would a DP, LSE or GO know if an event is an “impact event”? The posed impact events are a series of conditions for sabotage but not for EOP-type disturbances. The aforementioned entities have no requirement to monitor and analyze the BES, which then means every event would be an impact event for those entities (not an EOP disturbance but an impact event). Thus every theft of copper is an impact event mandating a Disturbance Report even though the SDT notes the RC only has to send it to the “local authorities”. This seems to be a misuse of the RC resources; every train derailment is an impact event requiring a Disturbance report (is that a commercial train, regional rail line a local trolley car); every teenage prank would also generate an impact event mandating a disturbance report. The SDT defined impact events are not appropriate for use in defining disturbances. There is a big difference from creating a set of guidelines to follow as opposed to creating sanctionable standards</p>
<p>Response: The DSR SDT thanks you for your comment. Furthermore, impact events should not include copper theft or other conditions that pose no threat to the reliability of the BES. A train derailment is only an impact event if it threatens some element of the bulk electric system such as a transmission line corridor - the derailment in itself is not an impact event. See more on impact events under the responses to Question 3.</p>		
Bonneville Power Administration	No	<p>The RC is made aware of these type of incidents and goes right back to incorporating that in their awareness and to focusing on system reliability. If the RC is the recipient for further distribution of information of this type they will be forever going back for more information. Eliminate the middleman in whatever concept you propose, folks have plenty to do now. Let people make good judgments with the direct field people on the seriousness of the breach with their security personnel contacting the appropriate law enforcement agency. (Or are you looking to do a simple RE reports to the RC who marks various category items on a secure website Yes/No category item indicator that can be rolled up in ES-ISAC map board?)</p>
<p>Response: The DSR SDT thanks you for your comment. The Reliability Coordinator’s suggested role in this is to allow them to incorporate the relevant data from responsible entities in their footprint for further analysis.</p>		
Duke Energy	No	<p>The RC should not be responsible for submitting the report to FERC, NERC or the RRO. The RC may not have the necessary first hand information concerning the facts of the event. Situation awareness can be maintained by including the RC in the distribution of any sabotage related reporting.</p>

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
SERC Reliability Coordinator Sub-committee (RCS)	No	The RC should not be responsible for submitting the report to FERC, NERC or the RRO. The RC may not have the necessary first hand information concerning the facts of the event. Situation awareness can be maintained by including the RC in the distribution of any sabotage related reporting.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted. Also it must result in real efficiency gains and support the reliability of the bulk electric system.			
ERCOT ISO	No	There are some events that are truly local and should be handled by local entities and reported to local authorities (i.e. theft). If there is an impact or potential to have an impact to the BES or to the region, then hierarchical reporting would be appropriate.	
Response: The DSR SDT thanks you for your comment. We agree - a clearly defined impact event criteria would do just as you suggest - leave local issues on the local level.			
Northeast Power Coordinating Council	No	This is not a standards issue, and NERC should not dictate the reporting structure. It should be left to the RCs and their members.	
Response: The DSR SDT thanks you for your comment. In defining a disturbance reporting hierarchy we sought to realize efficiencies. If the reporting hierarchy concept is adopted, it must result in real efficiency gains and support the reliability of the bulk electric system. It will not be adopted if the result in a complicated or burdensome process for responsible entities.			
MRO's NERC Standards Review Subcommittee	No	We agree a coordinated reporting process is beneficial for the entity and the Reliability Coordinator (RC). However, a hierarchy would likely lengthen the reporting timeframe, or reduce the allotted time for each entity to provide notification to the RC in order to meet DOE or NERC timelines. Communication and coordination with the RC would likely provide more accurate and complete data submissions within a timely process and create shared accountability for the report being submitted.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and some mechanism to ensure the responsible entities' reported information remains as submitted.			



**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
Midwest ISO Standards Collaborators	No	We do not agree with developing a hierarchy for reporting for all disturbances and impacting events. For instance, copper theft is an example of an item that should be reported to the appropriate entities directly by the Transmission Owner. The RC does not need to be made aware of every copper theft unless it has a direct impact on reliability (affects rating, protection system, etc.) and the RC should not be burdened with expending resources for this reporting. A further example in which the hierarchy is not needed would be the case in which only one entity is impacted. If a significant event occurs on one TOP's system, then the TOP should be able to handle the reporting of all entities under its purview. If more than one TOP is involved, then it would be necessary to involve the RC in the reporting.	
Response: The DSR SDT thanks you for your comment. The reporting hierarchy concept is meant to apply only to disturbance reporting. We agree that copper theft and other situations that do not pose a direct threat to reliability shouldn't be reported to NERC through this standard.			
FirstEnergy	No	While we appreciate the team's effort to serialize the reporting process, with the electronic communication methods available today, it seems that reporting can be accomplished simultaneously to multiple entities without shifting the burden of reporting to others along the communications path. This is particularly true if the reporting format is standardized to a one-size-fits-all report. Additionally, it would be a great burden to the Reliability Coordinator to review all events perceived by entities to be malicious sabotage events.	
Response: The DSR SDT thanks you for your comment. The reporting hierarchy concept would only apply to disturbance reporting, not impact events. The Reliability Coordinator's suggested role in this to allow them to incorporate the relevant data from responsible entities in their footprint for further analysis. We will consider your suggestion of simultaneous submissions as a means to effectively notify the necessary parties.			
Edison Mission Marketing & Trading	Yes		
PacifiCorp	Yes		
SPS Consulting Group Inc.	Yes		
Calpine Corp.	Yes	A Functional Entity such as a Generator Owner/Operator is not always aware that an event, such as a plant trip, is part of a wider system disturbance that rises to the level of a reportable event under EOP-004. A reporting hierarchy that allows a Generator to report the facts to its Transmission Operator and have that entity take a wider view to determine whether there is a disturbance should facilitate the reporting of actual disturbances. The SDT needs to ensure that some thought goes into the flow of information within the hierarchy and what triggers are needed to drive the reporting up the hierarchy.	

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting – Project 2009-01**

Organization	Yes or No	Question 2 Comment
<p>Response: The DSR SDT thanks you for your comment. A reporting hierarchy process must include clear triggers for reporting and provide an efficient, well-defined information flow.</p>		
We Energies	Yes	<p>A hierarchical approach in conjunction with a single, electronic form would provide consistent reporting timelines, provide clarity in the reporting process, and provide more accurate and meaningful data submissions while having shared accountability. Confusion in the current method could be alleviated while providing more consistency in the reporting of an "impact event".</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Arizona Public Service Company	Yes	<p>All disturbance reporting should go through the RC.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Constellation Power Source Generation	Yes	<p>As stated in the concept paper, a hierarchy ensures proper communications, but it has the added benefit of reducing redundancy on the Registered Entities, so long as responsibilities and accountability are clearly established.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Central Hudson Gas & Electric	Yes	<p>Central Hudson agrees with this reporting hierarchy for disturbances given the "wider-view" of the Reliability Coordinator as opposed to an entity such as a Transmission Owner or Load-Serving Entity. While, based on past experience, the current process works if reports are filed to the DOE, RRO, and RC simultaneously via email for example. However, the RC is in a better position to identify multi-site incidents and escalate the reporting process if necessary.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Wolverine Power Supply Cooperative, Inc.	Yes	<p>From the perspective of a TOP, this seems to alleviate reporting burden and move it up line. I can understand the logic in wanting the reporting to flow through the RC for awareness purposes, but I can understand the RC's reluctance to bear the additional potential burden. Again, a focused effort to minimize the necessary reporting to "true impact events" should be kept in mind, regardless of who has to report. Collecting reams of data and figuring out what impact it has later should not be the goal.</p>

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 2 Comment
<p>Response: The DSR SDT thanks you for your comment. We agree that regardless of any reporting hierarchy, the goal is to report on disturbances and events with meaningful impact on the bulk electric system. See Question 3 responses for more information on how we view impact events.</p>		
Electric Market Policy	Yes	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System.
Hydro-Québec TransEnergie (HQT)	Yes	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System. The reporting hierarchy should be to submit the information to the Reliability Coordinator, and to have the RC submit the report. This would eliminate the duplication of information.
Orange and Rockland Utilities, Inc.	Yes	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System. The reporting hierarchy should be to submit the information to the Reliability Coordinator, and to have the RC submit the report. This would eliminate the duplication of information.
<p>Response: The DSR SDT thanks you for your comment.</p>		
Lands Energy Consulting	Yes	I would give the RC the authority to establish impact thresholds for reporting. Consistent with my earlier comment, I would set the materiality threshold for disturbance reporting purposes at LSEs (or a combination of LSEs in the case of BPA) serving at least 90,000 customers.
<p>Response: The DSR SDT thanks you for your comment. Reporting thresholds in the standard will meet NERC requirements: Reliability Coordinator's may have different reporting criteria to meet Regional requirements, but they will not appear in this yet to be written Standard.</p>		
Central Lincoln	Yes	<p>In the west at least, this hierarchy should be extended to include BA's as indicated in the Concepts Paper. See: <a href="http://www.bpa.gov/corporate/business/reliability/Docs/2007/PNSC_RE_Data_Letter_2_070723.pdf">http://www.bpa.gov/corporate/business/reliability/Docs/2007/PNSC_RE_Data_Letter_2_070723.pdf</a></p> <p>for the RC's policy on which entities it chooses to communicate with.</p>

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 2 Comment
Response: The DSR SDT thanks you for your comment. The hierarchy concept includes BAs as appropriate in the reporting structure.		
Luminant	Yes	Luminant believes that one report should be filed with the Reliability Coordinator or one responsible entity, who then files the report with all applicable entities.
Response: The DSR SDT thanks you for your comment.		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that with this reporting hierarchy, in that dual reporting should be eliminated
Response: The DSR SDT thanks you for your comment.		
Portland General Electric	Yes	PGE is familiar with and works closely with WECC today so the hierarchial consideration makes sense.
Response: The DSR SDT thanks you for your comment.		
Platte River Power Authority	Yes	Situational awareness would be enhanced. All affected entities would be aware of the disturbance and relevant information. Also, the flow of information between entities would be enhanced and a more comprehensive report could be developed.
Response: The DSR SDT thanks you for your comment.		
Ameren	Yes	The hierarchy is appealing in the fact that the TOP/BA will be kept in the loop and receive critical information from the Generators, Distribution, LSE, etc. But there will be an inherent delay in reporting due to the fact that at every hand-off of information there will be questions for additional and/or clarified information, and there is always a possibility for the loss of information due to the transfer from one entity to the next. Further, this reporting through a hierarchy could also take away from the operators ability to respond to system events due to being tied to an information transfer ladder.
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and some process to ensure the responsible entities' reported information remains as submitted. It must also ensure that it does not place any extra burden on operators that could create an additional risk to reliability.		

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
E.ON U.S. LLC	Yes	The hierarchy will simplify reporting from the entity in that the RC is always notified and then the RC notifies other parties as required, (with the exception of OE-417, which still has to be filled out per law) E.ON U.S. recommends that the drafting team pay particular attention to the report process to make sure that duplicate reports are not being required. Currently information on forced outages is already communicated to the RC so formalizing a requirement to provide data to the RC may represent duplication to reports already provided.	
Response: The DSR SDT thanks you for your comment. Avoiding duplication is a key goal of the drafting team.			
Public Service Enterprise Group Companies	Yes	The PSEG Companies believe that all entities with a reportable disturbance should report to the RC. The RC is best positioned to evaluate the impact of the event and forward the information to the appropriate entities. There should not be any intermediate entities to relay information to the RC as that can introduce delay and has the potential to introduce transcription errors. Sabotage events should be reported to the RC as well as to law enforcement. CIP-008 reporting is highly specialized and should be retained in the set of cyber security standards, not merged with CIP-001 and EOP-004.	
Response: The DSR SDT thanks you for your comment. Detection of cyber events may be specialized but report of them is not. Threats to reliability must be reported no matter what the cause. The DSR SDT proposes using the thresholds found in CIP-008 - this standard would provide a one stop form to submit the information. Note that the current CIP-008 has a reporting requirement to the ES-ISAC only.			
Manitoba Hydro	Yes	The Reporting Concept states that the new hierarchy is, "Affected entity to TOP/ BA to RC. Then the RC will then submit to NERC and DOE (if required)". This will enhance the existing requirement EOP-004-1 R4 which states that the RC shall assist the affected entity by providing representatives to assist in the investigation (this is also all reiterated in Attachment 1-EOP-004) .In an disturbance, the local resources would be tied up in the rectification of the problem. Analyzing and reporting the event (is it reportable, who to report to, what is the timeline) is distracting and time consuming. By leaving the final upper level steps of reporting to NERC/DOE by the RC would be efficient.	
Response: The DSR SDT thanks you for your comment.			
Western Electricity Coordinating Council	Yes	There should be an established time sequence that allows the RC to review the entities material prior to forwarding to NERC. By channeling all reports through the RC situational awareness will be enhanced. Instead of "submit information", it should be clarified that entities submit complete written reports to RC in electronic format.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted.			

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
American Electric Power	Yes	This approach may work as long as there is a uniform process across all of the Reliability Coordinators. AEP owns and operates BES facilities under three separate RCs and having differing rules and processes would create confusion and additional burdens. There are some concerns about the time lag of reporting the information and this might not work well in all cases especially if the information and knowledge are at the local level. AEP recommends that the standard could have a default hierarchy, but this should not prohibit any entity from reporting directly.	
Response: The DSR SDT thanks you for your comment. Our goal is uniform reporting criteria to meet specified requirements. We will consider the risks and benefits of allowing a default hierarchical reporting structure with the ability for responsible entities to report directly to NERC.			
Bandera Electric Cooperative, Inc.	Yes	This approach, while I suspect will not be universally agreed to, should provide some definitive guidance in reporting.	
Response: The DSR SDT thanks you for your comment.			
Dynegy Inc.	Yes	This seems to be straightforward approach in that the RC is the best judge of threats to the overall system and could eliminate multiple reports of a single event.	
Response: The DSR SDT thanks you for your comment.			
Independent Electricity System Operator	Yes	We do not agree with the need of such a hierarchy setup solely for the purpose of making reports to the need-to-know entities. All responsible entities (RC, BA, TOP, etc.) need to file a report. With the proposed set up noted under Q3, which we support, these reports should go directly to NERC. The RC should not be held responsible for forwarding other entities' reports to NERC, and in doing so subject itself to potential non-compliance.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted.			

**3. The goal of the DSR SDT is to have one report form for all functional entities (US, Canada, Mexico) to submit to NERC. Do you agree with this change? Please explain your response (yes or no) in the comment area.**

**Summary Consideration:** Most stakeholders agreed with the concept of having one reporting form for all entities. Several commenters suggested that there is no need for a standard on reporting as they considered it administrative in nature. Most thought it should be a guideline, rather than an enforceable standard. There is widespread agreement that the one-size-fits-all approach would be very difficult to get agreement on, given the different countries and agencies involved. Many stakeholders pointed out that consistency and simplification were drivers for one report form. Having multiple recipients, with different information requirements, seem to support an electronic format that would guide information only to those who need it. The concept of an electronic reporting tool would need to be further vetted and developed.

Organization	Yes or No	Question 3 Comment
Bandera Electric Cooperative, Inc.		No preference in this area.
ISO RTO Council Standards Review Committee	No	The SRC supports NERC’s initiative for Results Based Standards. The SRC understood RBS to mean the results were reliability based quantities not administrative quantities. There is no need for a NERC Reliability standard on reporting. The idea that all functional entities in each of the said countries will use one form would be a good idea if and only if all the countries and all of their agencies were willing to accept that form. The SRC does not believe that those agencies will be willing to cede what information they ask for to NERC; nor that NERC will be able to create a single form that all such agencies will accept.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The set of results-based standards is intended to provide a ‘defense-in-depth’ approach to protecting reliability of the bulk power system. While many reports are administrative and are only used to assess compliance with specific requirements, the reporting addressed in this project is focused on providing data needed to support</p>		

Organization	Yes or No	Question 3 Comment
<p>after-the-fact analyses of events, and reporting information needed to maintain situational awareness. As such, the SDT believes that these reporting requirements do need to be enforceable.</p>		
FirstEnergy	No	<p>While one consistent form for reporting may simplify reporting requirements, it would be very difficult to get all governmental agencies to agree to a one-size-fits all approach.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</p>		
Public Service Enterprise Group Companies	No	<p>While simplification and consistency is a laudable goal, it should not be applied to different governmental agencies (USA, Canada, Mexico) which may have different structures and processes. Moreover, results based standards should not include administrative matters such as reporting forms.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The set of results-based standards is intended to provide a ‘defense-in-depth’ approach to protecting reliability of the bulk power system. While many reports are administrative and are only used to assess compliance with specific requirements, the reporting addressed in this project is focused on providing data needed to support after-the-fact analyses of events, and reporting information needed to maintain situational awareness. As such, the SDT believes that these reporting requirements do need to be enforceable.</p>		
American Electric Power	Yes	
Constellation Power Source Generation	Yes	
Exelon	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	



Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
Calpine Corp.	Yes	A single approach is desirable, particularly for those entities that find themselves in multiple regions or countries.
<b>Response: The DSR SDT thanks you for your comment.</b>		
We Energies	Yes	Agree in conjunction with proposed concept that DOE OE-417 will be allowed to supplement the NERC report in lieu of duplicating entries.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		
Consumers Energy Company	Yes	Agreed - to the extent that it’s consistent with the concept that any specific type of data is submitted to ONLY one entity.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		
Arizona Public Service Company	Yes	APS supports the standardization of the form for consistency and format.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Bonneville Power Administration	Yes	As long as we don’t make one form that requires extraneous information for the sake of having agreement.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
Western Electricity Coordinating Council	Yes	Canadian and Mexican entities should be consulted on content of report form to assure their "buy in".
<p><b>Response: The DSR SDT thanks you for your comment. It is DSR SDT’s intent to discuss the need for information with appropriate jurisdictional agencies.</b></p>		
Central Hudson Gas & Electric	Yes	Central Hudson agrees with this goal if the intent is to develop and implement an electronic version that would meet DOE requirements as well.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b></p>		
E.ON U.S. LLC	Yes	E.ON U.S. supports the proposal.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
MRO's NERC Standards Review Subcommittee	Yes	However, We believe the primary goal should focus on “each entity” being able to submit one report for all functional requirements. Entities in the US that are required to submit the DOE OE-417 form should not be required to submit an additional form developed for other entities (Canada & Mexico). One approach to satisfy this goal is for NERC to require all entities (US, Canada, & Mexico) to complete the DOE OE-417 form as their report.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Wolverine Power Supply Cooperative, Inc.	Yes	I can't see how anyone would disagree with this concept - However - I question how practical it will be to implement, since various agencies would have to collaborate and coordinate to accomplish this task.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
Lands Energy Consulting	Yes	I think that the impact approach makes sense and that EOP-004 and CIP-001 are logically connected. Many entities of which I am aware link Sabotage Reporting Training to Disturbance Reporting obligation awareness already.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that by using the same type reporting format, there should be consistency in regard to each functional entity's expectations.
<b>Response: The DSR SDT thanks you for your comment.</b>		
BGE	Yes	One form makes sense to us; less is better is the sense that it makes filing reports easier by not creating unnecessary complications.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Ameren	Yes	One report would be great for this standard. While this standard needs simplification and automation, we strongly suggest developing a guideline for reporting rather than enforceable standards.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The set of results-based standards is intended to provide a ‘defense-in-depth’ approach to protecting reliability of the bulk power system. While many reports are administrative and are only used to assess compliance with specific requirements, the reporting addressed in this project is focused on providing data needed to support after-the-fact analyses of events, and reporting information needed to maintain situational awareness. As such, the SDT believes that these reporting requirements do need to be enforceable.</b>		
Portland General Electric	Yes	PGE supports the efforts of the Standards Drafting Team on the SAR for Project 2009-01 to consolidate the disturbance and sabotage reporting processes as outlined in the concept paper.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Dynegy Inc.	Yes	Please keep it short and simple.

Organization	Yes or No	Question 3 Comment
<b>Response: The DSR SDT thanks you for your comment.</b>		
ERCOT ISO	Yes	Standardization ensures consistency and relevance of the information received.
<b>Response: The DSR SDT thanks you for your comment.</b>		
USBR	Yes	The Bureau of Reclamation utilizes a form for tracking unexpected events. This form contains information which the agency considers important for its one reliability improvement program. The form is also used to meet NERC standard requirements for protection system operations analysis. This form contains most of information required by DOE. The SDT should consider requiring the submission of specific information rather than lock responses in one specific form. In this manner the agency would be avoid duplicate forms, one for NERC, the other for agency purposes.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Central Lincoln	Yes	The existing reporting is needlessly complex. We appreciate the SDT's goal.
<b>Response: The DSR SDT thanks you for your comment.</b>		
SPS Consulting Group Inc.	Yes	There should have probably been one report all along.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Duke Energy	Yes	There should only be one report for all functional entities to submit to NERC.
<b>Response: The DSR SDT thanks you for your comment.</b>		
SERC Reliability Coordinator Sub-committee (RCS)	Yes	There should only be one report for all functional entities.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Manitoba Hydro	Yes	This is a promising idea, though there would be different requirements for the three countries, this could easily be rectified with "drop down menus". This electronic form could contain a lot of information without distracting clutter as you "tree" down the menu depending on the event that occurred. This could also contain electronic

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
		references to information located in Attachment 1-EOP-004 and Threat and Incident Reporting.
<b>Response: The DSR SDT thanks you for your comment. We will consider your specific suggestions when we develop the reporting requirements.</b>		
Hydro-Québec TransEnergie (HQT)	Yes	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Northeast Power Coordinating Council	Yes	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Orange and Rockland Utilities, Inc.	Yes	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Midwest ISO Standards Collaborators	Yes	We agree with the goal of having a single report form but believe there will be a significant challenge to get varying governmental agencies to agree on single report format.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		
Edison Mission Marketing & Trading	Yes	With the realization that having a common report form may be difficult to coordinate between differen agencies.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide</b>		

Organization	Yes or No	Question 3 Comment
<p>contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</p>		
Independent Electricity System Operator	Yes	Yes, this will simplify the reporting effort. NERC may forward the reports to the other need-to-know entities.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Electric Market Policy	Yes	Yes, we agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		

4. The goal of the DSR SDT is to eliminate the need to file duplicate reports. The standards will specify information required by NERC for reliability. To the extent that this information is also required for other reports (e.g. DOE OE-417), those reports will be allowed to supplement the NERC report in lieu of duplicating the entries in the NERC report. Do you agree with this concept? Please explain your response (yes or no) in the comment area.

**Summary Consideration:** Most stakeholders agreed with the concept of entities being able to use information from other sources such as the OE-417 form, to supplement the NERC report form. Some thought that duplicate reports were acceptable, as long as the information was not duplicated (if # of customers lost is required on form A, don't ask on forms B & C). Several stakeholders commented on the need for an electronic, one stop reporting tool. This would avoid duplication while ensuring that the information reported goes only to intended recipients. With an electronic, one stop reporting tool, reports can be updated/corrected instantly, without repeating previously submitted information. Some stakeholders cautioned that the OE-417 can change every three years and this should be taken into account when developing an electronic reporting tool. Again, such a reporting tool would need to be vetted and developed to meet reliability needs.

Organization	Yes or No	Question 4 Comment
ERCOT ISO		ERCOT ISO agrees with the concept of eliminating the need to file duplicate reports, but as stated in the Concept Paper, the DOE form (OE-417) is required by law. Based on this, the elimination of EOP-004 (after the fact reporting) is essential, since the OE-417 is mandatory and all-inclusive.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We agree that the OE-417 compiles a baseline set of information for disturbances, however, it does not function as an all-inclusive report of sabotage and cyber security incidents. The DSR SDT certainly seeks to gain efficiencies through the modification of EOP-004 and CIP-001, which may include the elimination of one or both. Further, the OE-417 is only mandatory for US entities.</p>		
Midwest ISO Standards Collaborators	No	It certainly makes sense to eliminate duplication in reporting and to allow supplemental information to be submitted in other reports. However, it does not make sense to require reporting to other governmental agencies through NERC enforceable NERC standards. Those governmental agencies already have legal authority to compel reporting. Again, we support developing a guideline for reporting rather than enforceable standards. The guideline could certainly explain the various reporting requirements and supplemental reporting requirements mentioned in the question without causing the issues we have identified in our comments.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an</p>		

Organization	Yes or No	Question 4 Comment
<p>option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</p>		
Consumers Energy Company	No	NERC should either coordinate with DOE for a single reporting process or simply adopt the DOE's standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements. The DOE report does not collect all the information that NERC needs.</p>		
E.ON U.S. LLC	No	<p>Reliability standards are federal law enforced by fines that can reach up to \$1,000,000 per day of violation. There is no reason to deliberately include ambiguity, i.e. "gray areas," in requirements such that registered entities are left unable to determine what it is they must do or refrain from doing to remain compliant. "Sabotage" for the purposes of these standards must be defined.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the DSR SDT is to develop requirements for reporting that will be clear and unambiguous with respect to compliance issues. Sabotage will be included in the reporting for "impact events", but may not be called 'sabotage' as there are many different interpretations of "sabotage".</p>		
ISO RTO Council Standards Review Committee	No	<p>The concept of eliminating duplication is laudable, but the idea of writing a standard to mandate reporting that involves reporting to governmental areas does not make sense unless NERC will do all of the reporting for the Industry. A governmental agency is as likely as not to change the forms they require which would then mean two different reports (one for NERC and one for the given agency) or that the standard would have to be re-written every time there is a change.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</p>		
Ameren	No	<p>The DOE OE-417 report should not supplement the NERC report due to the fact that the majority of reportable events are defined in/come from the OE-417 report. The NERC reporting form should be based on the OE-417 report and then include additional reporting requirements defined by NERC. However, it does not make sense to require reporting to the governmental agencies through enforceable NERC standards. The governmental agencies already have legal authority to compel reporting.</p>



Organization	Yes or No	Question 4 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</p>		
SERC Reliability Coordinator Sub-committee (RCS)	No	The requirement should be a single report that satisfies the need for all US governmental agencies as well as NERC and the RRO's.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the DSR SDT is to develop standards to address the reliability needs for NERC and not governmental agency reporting criteria.</p>		
Western Electricity Coordinating Council	No	This will work well for the USA entities to save us time in re-entering the same information. We believe that FERC and NERC and the Regions should have one common reporting form for North America. The OE-417 is not required by law outside of the United States. Canadian and Mexican entities may feel that US DOE has no jurisdiction in these countries, and therefore no right to required reporting as is stated on the OE-417.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We agree that the OE-417 report is not required for Canadian or Mexican entities. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted (or not) to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</p>		
American Electric Power	Yes	
Edison Mission Marketing & Trading	Yes	
Exelon	Yes	
Orange and Rockland Utilities, Inc.	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting – Project 2009-01**

Organization	Yes or No	Question 4 Comment
Arizona Public Service Company	Yes	APS supports eliminating the need to file duplicate reports. This standardized form should generate and send the DOE OE-417 report, totally eliminating duplicate work. Streamline the process.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Central Hudson Gas & Electric	Yes	Central Hudson agrees with this concept and, as stated in a previous response, recommends that the ability of utilizing the DOE OE-417 to supplement the NERC report be maintained.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Calpine Corp.	Yes	Clarification, simplicity and the removal of duplicate reporting is beneficial.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Constellation Power Source Generation	Yes	Constellation agrees with the concept of eliminating the need to file duplicate reports. If the single NERC reporting form is both comprehensive and easy to use, then using a single report should not be an issue. It is essential that all elements of DOE OE-417, and any similar documents, be incorporated into this single report. Not incorporating all elements will result in gaps in reporting for all Registered Entities.
<b>Response: The DSR SDT thanks you for your comment.</b>		
SPS Consulting Group Inc.	Yes	Duplication is inefficient and casts the whole reporting mechanism in a questionable light.
<b>Response: The DSR SDT thanks you for your comment.</b>		
We Energies	Yes	However, also evaluate whether or not DOE OE-417 is sufficient in lieu of a NERC report. If additional information is required, duplicate format of DOE-OE-417 with additional NERC information listed at the end of the form.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Wolverine Power Supply Cooperative, Inc.	Yes	I agree with the concept of minimizing duplication - See previous question 3 for concerns.
<b>Response: The DSR SDT thanks you for your comment.</b>		

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 4 Comment
USBR	Yes	It should be clear what information is to be supplemented. The fewer times the information has to be handled the more efficient the process becomes. If the information exists on a required form, that legal form should be allowed. Also, if the form is already submitted, then reference to it should be sufficient rather than requiring resubmission of the form. That would require handling the information again. As explained in the previous answer, the SDT should recognize that responsible entities have already developed internal reporting processes which utilize forms for consistent responses. Those forms may contain more information than is needed by the new standard to be proposed. The entity should be allowed to submit the internal form or else duplication would be created, which may reduce the effectiveness of an entities reliability improvement program.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT envisions a one-stop-shopping form that allows reports to be saved, revised and resubmitted at a later date without re-entry of data or information. However, as a caution the DSR SDT cannot guarantee the possibility to submit custom forms.</b></p>		
Lands Energy Consulting	Yes	Less paperwork and fewer requirements to keep in mind during what may be once in a lifetime events are always good.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Luminant	Yes	Luminant agrees with the concept of reducing reporting requirements, but asks the SDT to go even further. In the concept paper, the SDT discussed that information would not be duplicated on the NERC report and the DOE OE-417 report. The concept paper described a process where one report would simply supplement the other, but two reports would still be filed when required. Can the NERC SDT work with the DOE to develop one report to meet the needs of NERC and the DOE?
<p><b>Response: The DSR SDT thanks you for your comment. We will consult with the DOE to see if one report will meet the reporting needs for NERC and the DOE. NERC reliability needs will take precedence.</b></p>		
Bonneville Power Administration	Yes	Minimizing the number of reports is a good thing. The concept of actually sharing information should be utilized as much as practical.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that this effort should eliminate file duplication

Organization	Yes or No	Question 4 Comment
<b>Response: The DSR SDT thanks you for your comment.</b>		
Bandera Electric Cooperative, Inc.	Yes	One can only assume the number of reports required in this area will continue to increase in terms of scope and to which agency wants this data. The SDT is encouraged to attempt to find a reporting format and scope that does not needlessly duplicate or complicate overall reporting obligations.
<b>Response: The DSR SDT thanks you for your comment. We will consult with the DOE and FERC to see if it one report will meet the reporting needs for NERC, FERC and the DOE. NERC reliability needs will take precedence.</b>		
Portland General Electric	Yes	PGE supports reducing the duplication of reporting.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Dynergy Inc.	Yes	Short and simple should be the goal.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Duke Energy	Yes	Since the OE-417 is a DOE required report, it must be submitted. Including the OE-417 as part of the NERC electronic form will facilitate reporting to NERC.
<b>Response: The DSR SDT thanks you for your comment. We will consult with the DOE to see if it one report will meet the reporting needs for NERC and the DOE. NERC reliability needs will take precedence.</b>		
Central Lincoln	Yes	The existing reporting is needlessly complex. We appreciate the SDT's goal.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Public Service Enterprise Group Companies	Yes	The PSEG Companies agree with the avoidance of duplicate reports. NERC report forms should not include anything in the DOE form, and NERC Regional report forms should not include anything in the DOE or NERC forms. Hence, a DOE report should not "supplement" a NERC form, but rather replace it unless the NERC form calls for other information for the same reportable incident, and likewise for the DOE - NERC - Regional form structure. DOE forms would be filed with DOE, NERC and the Regional Entity where the event originated. NERC forms would be filed with NERC and the region where the event originated and the Regional form filed only with the Region. In designing the NERC and Regional forms, the need to file multiple reports should be minimized, and in no event should any of the three (DOE, NERC, Region) forms contain

Organization	Yes or No	Question 4 Comment
		duplicative information requests.
<b>Response: The DSR SDT thanks you for your comment. We will consider your comment in the development of the reporting structure / forms.</b>		
Manitoba Hydro	Yes	This could be easily incorporated into the electronic form. You could be prompted for information required immediately, and notified for information that could be entered later. This form could contain all the enterable data that all agencies could require. If the form is live and on line, all entities could be notified (depending on the entries) of an going event immediately. Form could be web based similar to ARS program or even integrated into the ARS program.
<b>Response: The DSR SDT thanks you for your comment. We will consider your comment in the development of the reporting structure / forms.</b>		
FirstEnergy	Yes	We agree that the simplification and consistency of reporting will improve the reporting of this information. We support the drafting team's efforts in this area and hope that all regulatory agencies will as well. However, as we have mentioned in our other comments, the reporting requirements should not be in a reliability standard unless they are proven to be necessary to maintain an Adequate Level of Reliability of the BES. Reporting of these events should be required by NERC in arenas outside of the standards.
<b>Response: The DSR SDT thanks you for your comment. The information provided in the reports is either used after the fact for analyses or used to maintain situational awareness, and is needed for reliability.</b>		
MRO's NERC Standards Review Subcommittee	Yes	We agree with the concept to eliminate duplicate reports. However, we are concerned with the reference of the DOE OE-417 report being a "supplement" of the NERC report rather than "accepted" as the NERC report.
<b>Response: The DSR SDT thanks you for your comment. Future NERC reliability reporting needs may not totally align with DOE report information. Therefore, the OE-417 report would not necessarily substitute for the NERC report. The DOE Reporting Form OE 417 is currently mandatory by Public for US entities.</b>		
Hydro-Québec TransEnergie (HQT)	Yes	We agree with the objective of eliminating duplicate reporting. However, EOP-004 currently allows substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today. We agree with the recommendation to eliminate the need for filing duplicate reports such as the DOE form OE-417. There is no benefit with regard to CIP-001 in filing separate reports. Duplicate reports introduce the potential for incomplete information to be supplied to responsible parties.

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 4 Comment
		Removing jurisdictional agencies from the Standard, and having NERC provide either query or situational awareness to those agencies being considered, might not be easy to achieve. There is an obligation under law to require entities to report to the DOE on the OE-417 form as amended or modified. This might drive the “omitted” agencies to have reporting laws enacted as well.
Northeast Power Coordinating Council	Yes	<p>We agree with the objective of eliminating duplicate reporting. However, EOP-004 currently allows substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today. We agree with the recommendation to eliminate the need for filing duplicate reports such as the DOE form OE-417. There is no benefit with regard to CIP-001 in filing separate reports. Duplicate reports introduce the potential for incomplete information to be supplied to responsible parties.</p> <p>Removing jurisdictional agencies from the Standard, and having NERC provide either query or situational awareness to those agencies being considered, might not be easy to achieve. There is an obligation under law to require entities to report to the DOE on the OE-417 form as amended or modified. This might drive the “omitted” agencies to have reporting laws enacted as well.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT has discussed the possibility of consolidating CIP-001 and EOP-004 to create a single reporting standard. FERC directives require modifications to the standards which also may impose additional reporting requirements (see paragraph 470 of Order 693).</b></p> <p><b>We concur with your comments regarding the legal obligations to submit certain reports. The DSR SDT is attempting to consult with appropriate governmental agencies to address this.</b></p>		
BGE	Yes	We agree with this approach, as long as the latest version of the DOE OE-417 form is fully incorporated in the new single-reporting form, so that it maintains its credibility with the DOE.
<p><b>Response: The DSR SDT thanks you for your comment. The intent is to maintain credibility with the DOE reporting requirements.</b></p>		
Independent Electricity System Operator	Yes	We support this concept since it works well for those entities that are not required to file reports with the US agencies, e.g. the DOE.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Electric Market Policy	Yes	Yes, we agree with the objective of eliminating duplicate reporting; however, EOP-004 currently allows

Organization	Yes or No	Question 4 Comment
		substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT has discussed the possibility of consolidating CIP-001 and EOP-004 to create a single reporting standard. FERC directives require modifications to the standards which also may impose additional reporting requirements (see paragraph 470 of Order 693).</b></p>		

**5. In its discussion concerning sabotage, the DSR SDT has determined that the spectrum of all sabotage-type events is not well understood throughout the industry. In an effort to provide clarity and guidance, the DSR SDT developed the concept of an impact event. By developing impact events, it allows us to identify situations in the “gray area” where sabotage is not clearly defined. Other types of events may need to be reported for situational awareness and trend identification. Do you agree with this concept? Please explain your response (yes or no) in the comment area.**

**Summary Consideration:** The majority of stakeholders agreed with the concept of impact events. Some stakeholders felt that the introduction of impact events increased the risk that some items will go unreported. However, most felt that impact events would dramatically increase the number of reports being submitted, and it would be difficult to separate important information from background noise. Several respondents felt that the SDT ignored the FERC Directive, and did not define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event. Many respondents supplied the SDT with their own definition of “Sabotage”. The DSR SDT believes that the concept of impact events and the specificity of what needs to be reported in the standard will be an equally efficient and effective means of addressing the FERC directive regarding sabotage. Some stakeholders felt that impact events add another layer of uncertainty to the reporting. Even with the switch from sabotage to impact events, several felt that “intent” was still key to determining reportability.

Organization	Yes or No	Question 5 Comment
ERCOT ISO		ERCOT ISO recognizes the risks associated with “gray areas” not being clarified. While “gray areas” pose compliance risk due to differing interpretations, a risk remains that some items will go unreported. A more prescriptive approach raises an even greater risk of events not being reported. People will not report events that are not specifically listed, and will not use judgment in determining the need for reporting.
<p><b>Response: The DSR SDT thanks you for your comment. We agree that a more prescriptive approach could pose greater risks but we will attempt to clarify and define an approach to assist the industry and stakeholders for reporting impact events.</b></p>		
Constellation Power Source Generation	No	Although defining an impact event would bring clarity to defining sabotage events, adding another situation would further complicate things. Furthermore, the examples of impact events used all fall under the Sabotage category in the Threat and Incident Reporting Guideline. Constellation Power Generation suggests the SDT further clarifies the items in the Sabotage category to ensure all grey area situations are included. Clarification is also needed in how a Cyber Security Incident (CIP-008) would map into the categories of Disturbance/Impact Events (CIP-001). To that point, Constellation Power Generation questions whether cyber related incidents should fall under the spectrum of sabotage type events, or remain separate and be incorporated in the CIP revisions. Having cyber related incidents separate from other sabotage events would



Organization	Yes or No	Question 5 Comment
		provide the clarity and guidance that the DSR SDT is striving to achieve.
<p><b>Response: The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include all events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact the reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</b></p>		
Duke Energy	No	As FERC ordered in Order No. 693, the drafting team should further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event. Suggested definition: “Sabotage - the malicious destruction of, or damage to assets of the electric industry, with the intention of disrupting or adversely affecting the reliability of the electric grid for the purposes of weakening the critical infrastructure of our nation.”
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with deterring “intent” which may not be determined until after a lengthy investigation. We will continue to discuss for inclusion in a future draft of this project. The DSR SDT believes that the concept of impact events and the specificity of what needs to be reported in the standard will be an equally efficient and effective means of addressing the FERC directive regarding sabotage.</b></p>		
Kootenai Electric Cooperative	No	Impact events seems to add another layer of uncertainty to the reporting. Define a transmission line. Our transmission lines have very little impact on the grid. It is possible for our lines to cause a local area outage on our transmission provider - but neither is of national security interest or even regional interest. There is no power flow going on across the lines other than local power delivery supply. It seems you run more risk of losing the important reports in the snow of reporting - similar to what we have to avoid on our SCADA systems for our operators to see the key information.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT understands your concern and this was discussed a great deal. It is our belief that criteria of the “impact events” to be reported will be properly defined and discriminated from local events that have no impact on the reliability of the BES.</b></p>		
SERC Reliability Coordinator Sub-committee (RCS)	No	Impact events that do not affect reliability should not be reported.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees but a balance must be further explored to meet industry and regulatory requirements specifically under FERC Order 693.</b></p>		
Luminant	No	Luminant would prefer to report disturbances and sabotage events. The reporting of impact events could lead to unnecessary reporting. A definition of an “impact event” may be even more confusing than sabotage

Organization	Yes or No	Question 5 Comment
		events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT understands your concern and this was discussed a great deal. It is our belief that criteria of the “impact events” to be reported will be properly defined and discriminated from local events that have no impact on the reliability of the BES. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</p>		
Orange and Rockland Utilities, Inc.	No	<p>Physical and cyber events must be investigated before a determination of sabotage or impact event can be made. Impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on ‘newsworthy’ events or to gather information for trending. It is the law enforcement industry’s responsibility to make a determination of “sabotage” or other. This determination cannot definitively be made by industry (operating) personnel. If NERC's definition is expanded for CIP-001 and/or EOP-004, responsibility and timing of reporting needs to be addressed so that appropriate agencies conduct the investigation and assessment. Operating personnel need to remain focused on the primary responsibility of mitigating the effects.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT struggles with terms that deal with determining “intent” which may not be determined until after a lengthy investigation. We will continue to discuss these ideas for inclusion in a future draft of this project. Timing of the reporting process will be further clarified based upon your comments and those in the industry that have voiced similar concerns.</p>		
MRO's NERC Standards Review Subcommittee	No	<p>Rather than attempting to define a new term (impact event), we suggest that the concept of impact event be replaced with further defining sabotage and providing guidance on trigger events (impact event) that would cause an entity to report.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We will continue to discuss the FERC “Clarification of sabotage” directive and seek further guidance to meet this directive. The term sabotage has created conflict in its meaning among stakeholders as to when it is determined and by whom and how long an investigation would take to make that call on the intent of the saboteur. The DSR SDT is reviewing what a reportable disturbance actually is and sabotage may be a sub component of a reportable disturbance event.</p>		
Lands Energy Consulting	No	<p>The level of complexity described will overwhelm the 20-200 employee utilities that have yet to see - and will never see - the kind of sabotage event that scares the Department of Homeland Security.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not intend for the reporting of impact events to overwhelm smaller entities. If events do not affect the reliability of the BES, then it is our intent that they will be excluded from reporting requirements under our proposal. We will attempt to clarify and define an approach to assist the industry and stakeholders for reporting impact events. FERC cautioned the</p>		

Organization	Yes or No	Question 5 Comment
<b>industry that acts of sabotage may be “tested” on smaller entities and ultimately on larger entities.</b>		
ISO RTO Council Standards Review Committee	No	The nature of the fact that “gray areas” exists preclude the idea of using a standard to report; particularly a standard for the vague topic of motivation such as sabotage events and the more defined disturbance events.
<b>Response: The DSR SDT thanks you for your comment. We will attempt to clarify and define an approach to assist the industry and stakeholders for reporting impact events.</b>		
Edison Mission Marketing & Trading	No	There are too many special circumstances to try and capture. I feel this would be best delivered as a guideline.
<b>Response: The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</b>		
Exelon	No	We agree with the direction to identify impact events examples that would trigger reporting and not be limited to sabotage reporting only. It is important to note that when an incident occurs, some level of investigation is required before a determination can be made as to the event is sabotage or not. The focus should be on reporting events when they occur and allow follow-up investigations to make the sabotage determination. That being said, care must be taken in the development of any list of impact events so that it doesn't become or is misinterpreted to be a definitive list. Therefore if it is not on the list, it is not reportable.
<b>Response: The DSR SDT thanks you for your comment. We concur and plan to allow reports to be submitted, edited and re-submitted in the one-stop-shopping reporting tool. We are suggesting the term “Impact Event” be substituted for sabotage and include only events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</b>		
Midwest ISO Standards Collaborators	No	We agree with the idea of identifying impact events but do not support the requirement for these to be always reported through the hierarchical structure identified in question 2. If an impact event only affects one entity, that entity should have the reporting requirement.
<b>Response: The DSR SDT thanks you for your comment. The DSRSDT will continue to explore the benefits and weaknesses of the hierarchy reporting structure.</b>		
Hydro-Québec TransEnergie (HQT)	No	We believe that physical and cyber events must be investigated before a determination of sabotage or impact event can be made. The purpose of the NERC Standards is to maintain the reliability of the BES. Therefore,

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 5 Comment
		<p>impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on 'newsworthy' events or to gather information for trending. It is the law enforcement industry's responsibility to make a determination of "sabotage" or other. This determination cannot definitively be made by industry personnel, there is no expertise or time to investigate causes. It is the industry's job to mitigate effects. Examples would help provide for better guidance/direction. Industry examples would be welcomed to help reinforce developed internal processes for compliance.</p>
Northeast Power Coordinating Council	No	<p>We believe that physical and cyber events must be investigated before a determination of sabotage or impact event can be made. The purpose of the NERC Standards is to maintain the reliability of the BES. Therefore, impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on 'newsworthy' events or to gather information for trending. It is the law enforcement industry's responsibility to make a determination of "sabotage" or other. This determination cannot definitively be made by industry personnel, there is no expertise or time to investigate causes. It is the industry's job to mitigate effects. Examples would help provide for better guidance/direction. Industry examples would be welcomed to help reinforce developed internal processes for compliance.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with determining "intent" which may not be determined until after a lengthy investigation. We will continue to discuss issues with sabotage for inclusion in a future draft of this project. Timing of the reporting process will be further clarified based upon your comments and those in the industry that have voiced similar concerns.</b></p>		
American Electric Power	Yes	
Calpine Corp.	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	
Central Lincoln	Yes	<p>An act of vandalism may have impact. An act of sabotage may not be impactful alone, but may be part of a wider coordinated attack. Dictionary definitions speaking of "intent" are not helpful in this regard, since acts of vandalism and sabotage are both generally committed intentionally. Saboteurs, though, work for a higher cause. That cause may be political, social, environmental, etc. We ask that the SDT look beyond dictionary definitions in developing a definition of sabotage.</p>

Organization	Yes or No	Question 5 Comment
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with determining “intent”. The term sabotage has created conflict in its meaning among stakeholders as to when its determined and by whom and how long an investigation would take to make that call on the intent of the saboteur. We will strive to meet this challenge with the input on the right language from government agencies and industry experience expertise.</b></p>		
Bonneville Power Administration	Yes	BPA agrees with providing an industry-wide definition and guideline. We do NOT agree with requiring reports for every instance of every activity. If your definition is good, you'll get what is needed and not much chaff.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Central Hudson Gas & Electric	Yes	Central Hudson agrees with this concept, particularly if the reporting hierarchy through the RC is implemented in order to better identify trends.
<p><b>Response: The DSR SDT thanks you for your comment. The DSRSDT will continue to explore the benefits and weaknesses of the hierarchy reporting structure.</b></p>		
Wolverine Power Supply Cooperative, Inc.	Yes	I agree with the concept of focusing on impact instead of the type of event (sabotage, accident, vandalism, etc.)I hope that the reporting proposal that comes out of this project will clearly make a separation between true impact events that must be reported per the standards (enforceable), vs. "other" information that may be (electively - not enforceable) reported, per some set of guidelines.
<p><b>Response: The DSR SDT thanks you for your comment. We agree reportable items should be based on impact to reliability and with other commenters that expressed a desire to avoid reporting on ‘newsworthy’ events but to gather meaningful information for trending. We are suggesting the term “Impact Event” be substituted for sabotage to include only events that would impact the reliability of the BES.</b></p>		
Bandera Electric Cooperative, Inc.	Yes	In principle, I agree with this concept. Would like for the SDT to pursue this further and seek additional comments at that time.
<p><b>Response: The DSR SDT thanks you for your comment. We will seek further comments on the concept and will prepare the beginnings of the first draft soon.</b></p>		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that there are no broadly used guidance documents that detail how an event may be accurately defined.
<p><b>Response: The DSR SDT thanks you for your comment. We agree that further industry guidance of a clear and understandable standard should be sought under the new Results Based approach. We will attempt to clarify and define an approach to assist the industry and stakeholders in reporting</b></p>		

Organization	Yes or No	Question 5 Comment
<b>impact events.</b>		
Portland General Electric	Yes	PGE supports the DSR SDT's efforts to bring clarity and guidance to the spectrum of sabotage-type events.
<b>Response: The DSR SDT thanks you for your comment.</b>		
FirstEnergy	Yes	The concept paper makes good progress in this area and the drafting team is on the right track, and agree that better clarity needs to be developed surrounding sabotage events. However, some of the examples stated in the paper are too vague and do not address extenuating circumstances or reasons for the events. One example sighted in the paper is "Bolts removed from transmission line structures." This statement may be too broad. For instance, if the bolts are removed from the tower and the organization is not experiencing a labor dispute, it could be considered a sabotage event with wide area implications. However, if the organization is in the middle of a labor dispute, this would be vandalism and would most likely not be of a wide area concern. Also, the number and location of towers affected could be an important determination related to the risk the event imposes on the Bulk Electric System.
<b>Response: The DSR SDT thanks you for your comment. We concur with your comments that the number and location of the towers affected may have a "local" vs "wide area" concern. However, under the "impact event" reporting that we are proposing, both scenarios above should be reported as impact events as long as it affects the BES.</b>		
Public Service Enterprise Group Companies	Yes	The PSEG Companies agree with the concept, but reserve judgment on the descriptions of the impacts. There is clearly a need to better define what constitutes a sabotage incident versus common theft or vandalism. Moreover, where it may be impossible to determine if any given incident (e.g., several loose bolts on a transmission tower cross brace could be sabotage or could be human error in construction) falls within sabotage, a registered entity should not be second guessed in an audit if the registered entity determines not to report. Excessive unnecessary reporting can mask real incidents.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees with clearly defining a reportable impact versus common theft. Concern over reporting an incident and the audit process are within the discussions of the DSR SDT and will be fully explored to assist with the 1<sup>st</sup> Draft. The ability to identify trends could be very important compared to isolated incidents that do not impact the BES. Every effort to explore this balance of reporting will be taken into account.</b>		
SPS Consulting Group Inc.	Yes	The term sabotage was always too narrow a concept for the standards. At times, questionable activities are not confirmed as sabotage events until well after the fact, forcing the registered entity to speculate on whether or not to report an activity that may not be a confirmed sabotage event at the time, and hence encounter another silly violation based on imprecise terminology.

Organization	Yes or No	Question 5 Comment
<p><b>Response: The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include all events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples. Tightening the reporting criteria of impact events could possibly address the concern expressed by a “violation based on imprecise terminology.”</b></p>		
USBR	Yes	<p>There should be a clear distinction between a cyber event and a cyber event that has a material impact on the reliability of the bulk electric system. Not all CIP-008 events will carry such a distinction. That being said, CIP 008 cannot be completely incorporated in this process. Denying access to a cyber asset is noteworthy under CIP008 but may not pose a threat to the reliability of the bulk electric system. Consider recognizing the impact on the bulk electric system when modifying definitions of adding the bulk electric system description to the definitions. This will help to clarify that disturbances, as discussed in this effort, are situations that produce an abnormal condition on the electric power system, not necessarily on ancillary or supporting systems, such as SCADA systems or the water-related systems at hydroelectric dams.</p>
<p><b>Response: The DSR SDT thanks you for your comment. We are suggesting in our discusssion to consolidate the location of reporting into one standard. The industry has demonstrated by comments that it favors streamlining the reporting process to achieve a “one stop shop” approach. We will continue to explore the possibilities to achieve the best results for all stakeholders. A discussion of advantages /disadvantages will continue to discover options and alternatives with input from all stakeholders.</b></p>		
Western Electricity Coordinating Council	Yes	<p>This will help eliminate regional differences in sabotage reporting. The definition should be broad enough so it covers new types of sabotage that may evolve. Event analysis facilitates situational awareness and if it requires further investigation regarding developing patterns and severity, it should be handled by law enforcement if need be.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will continue to explore the “Impact Event” definition to allow for new types of events. Event analysis is clearly a goal of reporting as is situational awareness and hopefully this project will enhance the understanding and clearly define obligations to all stakeholders.</b></p>		
Manitoba Hydro	Yes	<p>Though there are some specific events already included in this new definition, more could be added to dissolve specific “gray areas” and as new ones come up. Again these examples could be added into the electronic form and could contain a large data base which would be available depending on the event that occurred.</p>
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		

Organization	Yes or No	Question 5 Comment
BGE	Yes	We agree that "the spectrum of all sabotage-type events is not well understood throughout the industry"; however, we feel that the proposed concept of an "Impact Event" falls short of clarifying what constitutes such events. We believe that "Impact Events" needs further clarification to eliminate "gray areas" and to provide more reporting consistency between entities.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will continue to clarify the impact events concept and eliminate “gray areas” while including language to give clarity to the reporting process.</b></p>		
Dynergy Inc.	Yes	We agree with the concept but please provide specific examples. Also, please consider whether there are any penalties for misinterpreting an incident, who would determine if an event was a threat, and whether this could result in over reporting non-threats.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT may include specific examples of impact events and types of reportable events in the 1<sup>st</sup> draft of the standard (or in supplemental guidance) to help illustrate reportable criteria.</b></p>		
Consumers Energy Company	Yes	We agree with the concept, however, based on the information provided, it may be too vague to be of value. Terms such as “potential” and “significant” can be subjective and therefore provide little direction. We would like to see something more specific. Also, inclusion of the destruction of BES assets may be too inclusive and needs to be restricted to BES assets that will cause a specific level of impact on reliability.
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with determining “potential” and “significant”. Specific examples of criteria is being explored and discussed. We will strive to meet this challenge with the input on the right language from government agencies and industry experience expertise. Your suggestion of restricting to BES assets that will cause a specific level of impact on reliability will be discussed with the DSR SDT.</b></p>		
Independent Electricity System Operator	Yes	We agree with the general concept. However, we suggest that the classification of “events” to be compatible if not identical to those which need to be reported in real time as required in CIP-001, for otherwise it will create confusion and unnecessary, extra work. Also, this proposal appears to focus on the sabotage-type events only but the SAR deals with both sabotage and other disturbances (e.g. emergency type of events) reporting. A parallel type of “impact event” is needed for non-sabotage-type of events.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT notes that impacts events include both sabotage and non-sabotage types of events and these events include CIP-001 events.</b></p>		
Electric Market Policy	Yes	We believe that physical and cyber events must be investigated before a determination of sabotage or impact



Organization	Yes or No	Question 5 Comment
		event can be made.
<p><b>Response: The DSR SDT thanks you for your comment. We agree that sabotage requires investigation. The term “impact event” was developed to allow immediate reporting of events based on impact to the BES rather than intent.</b></p>		
We Energies	Yes	We would prefer to refer to all sabotage, vandalism, cyber attacks, and other criminal behavior as impact events. Focusing more on the event's impact on reliability and its ramifications on the systems seems to be more useful than to try to determine the intent of the perpetrator.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees with your assessment and will pursue the clarity and criteria examples to achieve reporting.</b></p>		

**6. If you are aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004 please provide them here.**

**Summary Consideration:** Several commenters provided information on regional reporting. The SDT will consider whether these should be included in the continent-wide standard. These include:

1. NPCC maintains a document and reporting form (Document C-17 - Procedures for Monitoring and Reporting Critical Operating Tool Failures) that outlines the reporting requirements, responsibilities, and obligations of NPCC Reliability Coordinators in response to unforeseen critical operating tool failures.
2. For other events that do not meet the OE-417 and EOP-004 reporting criteria, ReliabilityFirst expects to receive notification of any events involving a sustained outage of multiple BES facilities (buses, lines, generators, and/or transformers, etc.) that are in close proximity (electrically) to one another and occur in a short time frame (such as a few minutes).
3. WECC sets its loss of load criteria for disturbance reporting at 200 MW rather than the 300 MW in the NERC reporting form.
4. SERC and RFC are developing additional requirements at this time.
5. We suggest that reporting be based on impact to reliability, not on 'newsworthy' events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirements.
6. MISO RC (MISO OP-023) and RFC (PRC-002-RFC-01).

Organization	Question 6 Comment
Central Hudson Gas & Electric	Although not beyond the scope of these standards, NPCC maintains a document and reporting form (Document C-17 - Procedures for Monitoring and Reporting Critical Operating Tool Failures) that outlines the reporting requirements, responsibilities, and obligations of NPCC RCs in response to unforeseen critical operating tool failures.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b></p>	
Exelon	At the 2010 RFC Spring Workshop the following disturbance reporting Criteria was rolled out: All events that are required to be reported by the OE-417 and EOP-004 criteria will use those published procedures. For other events that do not meet the OE-417 and EOP-004 reporting criteria, ReliabilityFirst expects to receive notification of any events involving a sustained outage of multiple BES facilities (buses, lines, generators, and/or transformers, etc.) that are in close proximity (electrically) to one another and occur in a short time frame (such as a few minutes).

Organization	Question 6 Comment
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b></p>	
Lands Energy Consulting	I believe WECC sets its loss of load criteria for disturbance reporting at 200 MW rather than the 300 MW in the NERC reporting form.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will consider regional criteria when developing reporting thresholds.</b></p>	
Edison Mission Marketing & Trading	I don't know of any.
Orange and Rockland Utilities, Inc.	NERC's SDT effort requires a clear, consistent, and comprehensive continent-wide approach, thus mitigating any need for regional reporting requirements.
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT feels in many instances that region specific standards may be needed. However, the SDT will provide a clear reporting standard that can be consistently followed continent-wide.</b></p>	
MRO's NERC Standards Review Subcommittee	No Comment.
Duke Energy	None
Bandera Electric Cooperative, Inc.	No.
Manitoba Hydro	No.CIP-001 contains references to NERC and the DOE.CIP-008 makes exclusions for facilities regulated by US Nuclear Regulatory Commission and Canadian Nuclear Safety Commission. It also contains references to ES ISAC (Electricity Sector Information Sharing and Analysis Center).EOP-004 contains reference to NERC and DOE. There is no reference to Homeland Security, FBI, etc or to Canadian equivalent references in any of these Standards. When NERC is notified of an event, it is likely other organizations will have to be notified. There should be some sort of consistency to cover all these Standards and all notifiable parties at a NERC Standards level.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT absolutely understands your provided comment and have had detailed conversations surrounding “who” should be notified and “when”. Most importantly, a level of consistency should exist when reporting disturbances and sabotage events negatively impacting the BES.</b></p>	

Organization	Question 6 Comment
Oncor Electric Delivery Company LLC	Oncor is not aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004.
<b>Response: The DSR SDT thanks you for your comment.</b>	
Dynergy Inc.	Please consider MISO RTO-OP-023.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard. Please provide a copy of the subject document.</b>	
Electric Market Policy	SERC and RFC are developing additional requirements at this time. We suggest that reporting be based on impact to reliability, not on 'newsworthy' events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirements.
Hydro-Québec TransEnergie (HQT)	
Northeast Power Coordinating Council	
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b>	
Public Service Enterprise Group Companies	The PSEG Companies believe that RFC is developing a regional disturbance reporting requirement for events not meeting the criteria of current DOE and NERC reports.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b>	
Western Electricity Coordinating Council	There is a need to learn what reporting requirements are required by the Mexican and Canadian entities.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT is comprised of international members and we are currently researching requirements that Mexico and Canada may have.</b>	
SERC Reliability Coordinator Sub-committee (RCS)	We are not aware of any regional reporting requirements beyond the requirements of CIP-001, CIP-008 and EOP-004. However, the SERC RRO has shared a list of events of interest that it would like to be made aware of to maintain situation

Organization	Question 6 Comment
	awareness.
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT feels there will always be a need for the Regional Entities to be kept aware of certain “hot topic” issues. However, it is the SDT’s intent to provide clear and concise reporting requirements for events impacting the BES.</b></p>	
BGE	We are not aware of any regional requirements beyond the scope of CIP-001, CIP-008 and EOP-004.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>	
We Energies	What is meant by beyond the scope of the referenced standards? We Energies also has reporting obligations with the MISO RC (MISO OP-023), RFC (PRC-002-RFC-01), and the Wisconsin and Michigan Public Service Commissions.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard. Please provide a copy of the subject reporting requirements for the SDT to review.</b></p>	

**7. If you have any other comments on the Concepts Paper that you haven't already provided in response to the previous questions, please provide them here.**

**Summary Consideration:** Several stakeholders provided comments in this section. Some stakeholders suggested that the SDT has gone beyond its approved scope to “further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” Further, there is no requirement to create a Reporting Standard to define sabotage. The SDT contends that the development of impact events and the reporting requirements for them will provide the clarity sought in the directive.

Other stakeholders suggested that the SDT should seek to retire sanctionable requirements that require event reporting in favor of guidelines for reporting.

Several commenters suggested that the introduction of impact events actually expands the reporting requirements. It should be noted that the list of impact events is expected to be explicit as to who is to report what to whom and within certain timelines.

Several stakeholders provided input as to what they believed an electronic reporting tool should contain:

- 1 If the decision is made to go to a single reporting form, it should be developed to cover any foreseeable event.
- 2 The SDT should work toward a single form, located in a central location, and submitted to one common entity (NERC)
- 3 Reports should be forwarded to the ES-ISAC, not NERC, as the infrastructure is already in place for efficient sharing with Federal agencies, with the regional entities and with neighboring asset owners. Reports should flow to all affected entities in parallel, rather than series (timing issues).

Commenters also suggested that the SDT should consider the impacts of the reporting requirements on the small, and very small utilities.

Organization	Question 7 Comment
BGE	<p>1. If we move to a "one size fits all" single reporting form, it is important that the form be properly developed to cover any foreseeable event, which appears to be the intent of the DSR SDT, as outlined on page 4 of the concept document. Such an approach should also incorporate a single point of contact for reporting information, to avoid any confusion.</p> <p>2. We would like clarification that any proposed CIP-008-related reporting requirement (including any linked reporting requirement between CIP-008 and CIP-001) is only applicable in situations where the incident/event involves a registered entity's Critical Cyber Asset.</p>

Organization	Question 7 Comment
<p><b>Response (Questions 3&amp;6):</b> The DSR SDT thanks you for your comment. The drafting team will explore clarification that any proposed CIP-008 related reporting requirement between CIP-008 and CIP-001 is only applicable where the incident/event involves a registered entity’s CCA. Note that CIP-002 through CIP-009 are undergoing revision under project 2008-06 – Order 706 SDT. Note that the current CIP-008 has a reporting requirement to the ES-ISAC only.</p>	
<p>Electric Market Policy</p>	<p>a. NERC should focus efforts on developing <u>specific event reporting criteria</u> and not base the requirement on the definition of the term ‘sabotage’ but on the reporting criteria itself.</p> <p>b. The “opportunities for efficiency” discussed in the Concept Paper would be best achieved by focusing on those items that are necessary to <u>maintain the reliability of the Bulk Electric System</u>. If there are elements that need to be reported that, do not support this objective, than that reporting should not be required in reliability standards.</p>
<p>Hydro-Québec TransEnergie (HQT)</p>	<p>a. NERC should focus efforts on developing specific event reporting criteria and not base the requirement on the definition of the term ‘sabotage’, but on the reporting criteria itself. See comments above.</p> <p>b. The “opportunities for efficiency” discussed in the Concept Paper would be best achieved by focusing on those items that are necessary to maintain the reliability of the Bulk Electric System. If there are elements that need to be reported that do not support this objective, then that reporting should not be required in reliability standards. Consider making NERC the distributor of reports to other agencies. We recognize that the key is to simplify reporting to a single form, and to the extent possible, to one agency. “Front line” reliability personnel must have the “timely” knowledge to know when a situation warrants local, area, regional, or national involvement. Finally, the SDT should keep in mind the fact that Canadian stakeholders might have some difference in the way reports are made to Security Agencies.</p>
<p>Northeast Power Coordinating Council</p>	<p>a. NERC should focus efforts on developing specific event reporting criteria and <u>not</u> base the requirement on the definition of the term ‘sabotage’, but on the reporting criteria itself. See comments above</p> <p>b. The “opportunities for efficiency” discussed in the Concept Paper would be best achieved by focusing on those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. If there are elements that need to be reported that do not support this objective, then that reporting should not be required in reliability standards. Consider making NERC the distributor of reports to other agencies. We recognize that the key is to simplify reporting to a single form, and to the extent possible, to one agency. “Front line” reliability personnel must have the “timely” knowledge to know when a situation warrants local, area, regional, or national involvement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT agrees to focus efforts to specific event reporting criteria. SDT believes that by reporting material risks to the Bulk Electrical System using the impact event categorization it will be easier to get the relevant information for mitigation, awareness, and tracking, not based on the requirement of defining “sabotage”. The SDT believes that it is the submitter’s responsibility to submit OE-417 forms to the DOE, as stated by Public Law for US entities. The DSR SDT does recognize that it may not be possible to eliminate</p>	

Organization	Question 7 Comment
<p>reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</p>	
<p>SPS Consulting Group Inc.</p>	<p>Again, please consider the unique scope of the entities to which these standards are to comply. Don't dump all the requirements on all the applicable entities and perpetuate the current practice of forcing them to parse the requirements into what is logical or illogical from their perspective. The drafting team should have the expertise to do this. Identify which requirements apply to which applicable entity.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT will take into consideration what registered entities and thresholds are to be included in the revised standard(s) based on the SAR. The DSR SDT will establish the “requirements necessary for users, owners, and operators of the Bulk-Power-System” as stated in FERC Order 693 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1.</p>	
<p>ERCOT ISO</p>	<p>All references to CIP-008 should be removed and we reassert that physical and cyber reporting should be separate. There is documentation available from the CIPC that the drafting team considered CIP-001 related physical sabotage reporting and specified cyber incident reporting requirements in CIP-008.ERCOT ISO requests the DSR SDT to continue to improve its guidelines and to post those guidelines for all to use, but not to create sanctionable standards whose good intentions could result in unintended adverse consequences for the Industry. ERCOT ISO also suggests that all reporting forms and guidance should be located in a central, easily accessible location, eliminating confusion and simplify reporting for system operators thereby directly enhancing reliability during system events. The industry would benefit from a central location or link on the NERC website containing all reporting forms.</p>
<p><b>Response:</b> The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). The DSR SDT will take into consideration your comment on keeping cyber and physical events separate. We are suggesting in our discussion to consolidate the location of reporting into one standard. The industry has demonstrated by its comments that it prefers that the reporting process be streamlined to achieve a “one stop shop” approach. We will continue to explore the possibilities to achieve the best results for all stakeholders. A discussion of advantages /disadvantages will continue to discover options and alternatives with input from all stakeholders.</p>	
<p>Western Electricity Coordinating Council</p>	<p>As stated previously, for "One stop shopping" we need "buy in" from the foreign nationals. The way to do this is to engage their opinions and respect their jurisdictional agencies as well.</p>
<p><b>Response (Question 6):</b> The DSR SDT thanks you for your comment. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The SDT acknowledges that it is possible to consolidate various reports that ask repetitive questions and through this process can work with foreign nationals to receive their “buy in” for a one report form for all functional entities to submit to NERC.</p>	



Organization	Question 7 Comment
<p>MRO's NERC Standards Review Subcommittee</p>	<p>Confusion often arises in the industry between the CIP standards and other reliability standards based on CIP-001 naming convention. We would suggest the SDT retire CIP-001 and incorporate requirements within the EOP-004 standard or a new EOP-xxx standard to avoid confusion arising from CIP and other NERC Reliability Standards. Additionally, we assume the SDT has been created to specifically address FERC Order 693 directives to the ERO which appears to include the following items:</p> <ol style="list-style-type: none"> <li>1. Applicability - “possible revisions to CIP-001-1 that address our concerns regarding the need for wider application of the Reliability Standard... the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate” (FERC, 2007, para. 460).</li> <li>2. Definition of Sabotage - “we direct that the ERO further define the term and provide guidance on triggering events that would cause an entity to report an event... we believe the term sabotage is commonly understood and that common understanding should suffice in most instances... the ERO should consider FirstEnergy’s suggestions to differentiate between cyber and physical sabotage and develop a threshold of materiality.” (FERC, 2007, para. 461-462)</li> <li>3. Periodic Review and Testing - “directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.” (FERC, 2007, para. 466)</li> <li>4. Redundant Reporting - “now direct the ERO to address our underlying concern regarding mandatory reporting of a sabotage event... Regarding the potential for redundant reporting under CIP-001-1 and other government reporting standards, and the need for greater coordination... We direct the ERO to explore ways to address these concerns - including central coordination of sabotage reports and a uniform reporting format... with the appropriate governmental agencies that have levied the reporting requirements.” (FERC, 2007, para. 468-469)</li> <li>5. Specified Time - “the Commission directs the ERO to modify CIP-001-1 to require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specified period of time... the ERO should consider suggestions raised... to define the specified period for reporting an incident beginning from when an event is discovered or suspected to be sabotage” (FERC, 2007, para. 470).</li> <li>6. Summary of CIP-001-1 - “the Commission directs the ERO to develop the following modifications... (1) further define sabotage and provide guidance as to the triggering events... (2) specify baseline requirements regarding... procedures for recognizing sabotage events... (3) incorporate a periodic review... and for the periodic testing... (4) require an applicable specified period of time. In addition... address our concerns regarding applicability to smaller entities... consolidation of the sabotage reporting forms and the sabotage reporting channels with the appropriate governmental authorities to minimize the impact of these reporting requirements on all entities.” (FERC, 2007, para. 471)</li> <li>7. Analyze Performance - “at a minimum, generator operators and LSEs should analyze the performance of their equipment and provide the data... The Commission directs the ERO to consider this concern in future revisions... that includes any Requirements necessary for users, owners and operators... to provide data that will assist NERC” (FERC,</li> </ol>

Organization	Question 7 Comment
	<p>2007, para. 613, 617).</p> <p>8. Reporting Time Frames - “The Commission directs the ERO to change its Rules of Procedures to assure that the Commission also receives these reports within the same time frames as the DOE.” (FERC, 2007, para. 618)</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees with your comments to specifically address FERC Order 693 directives to the ERO and will determine a prudent course of action with respect to these standards and pursue the suggestion to retire CIP-001 and incorporate requirements within the EOP-004 standard to avoid confusion rising from CIP and other NERC Reliability Standards.</b></p>	
<p>Constellation Power Source Generation</p>	<p>Constellation Power Generation would like clarification that any proposed CIP-008-related reporting requirement (including any linked reporting requirement between CIP-008 and CIP-001) is only applicable in situations where the incident/event involves a registered entity’s Critical Cyber Asset. In that vein, we want to emphasize the importance of the DSR SDT working with the CIP SDT on the cyber related events. If the DSR SDT is going to be adding clarity to cyber related events, then coordination with the CIP SDT is needed to ensure the same verbiage is being used. Furthermore, having any duplication of requirements will cause a double jeopardy scenario which would go against the SAR for the DSR SDT. As stated earlier, Constellation Power Generation also questions whether cyber related incidents should fall under the spectrum of sabotage type events, or remain separate and be incorporated in the CIP revisions.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). Note that CIP-002 through CIP-009 are undergoing revision under project 2008-06 – Order 706 SDT.</b></p>	
<p>We Energies</p>	<p>Give consideration to combining CIP-001 and EOP-004-1 through a common categorization. For example, “System Risk Reporting” could encompass both actual and potential events and would minimize the need to cross reference both standards, and provide one location for event and potential-event reporting. Much of the challenge in this project is in achieving a common understanding of the words sabotage and terrorism. There are nuances of meaning in the words that imply a relationship between the attacker and the victim, or a motive other than simple profit or mischief. This nuance of meaning requires the victim of the damage to discern a relationship or motive which may not be discoverable in the relatively brief time window during which the entity must report the event. In fact, they may never be known. Consequently, We Energies recommends elimination of the words sabotage and terrorism from these standards. We also recommend elimination of the word vandalism since it also implies an ability and duty to discern whether a particular act (barbed wire thrown over transformer bushings) was done out of pure mischief (vandalism) or with intent to destroy equipment for a political purpose (terrorism). And if the act was committed by a disgruntled employee, it becomes sabotage. No wonder there is confusion and indecision. Instead, We Energies recommends using the simple words “criminal damage”. One need not be a prosecuting attorney or FBI Special Agent to know what this means. Simply ask, “Does it look like somebody damaged it (or hacked in) intentionally?” and, “Did we give consent?” and you’re done. With</p>

Organization	Question 7 Comment
	<p>elimination of sabotage, terrorism and vandalism, and all of their baggage, comes the ability to integrate both CIP 001 and EOP 004. We now have criminal damage (or cyber attack) as just another event to be evaluated against certain pre-defined impact measures. No value judgments, no speculation. Another benefit of using these simple words and tests is that operating personnel, whether in the field or at the console, will not require special awareness training in discerning these nuances of meaning. They already have experience with the equipment or cyber systems and its normal performance. Operating personnel can readily assess whether an impact event is due to equipment failure, weather or animal contact vs. intentionally caused by a person. If it appears to be criminal damage, call the local police agency. Report the event and the impact. Cooperate with the investigation. Share your knowledge of the normal condition of the equipment or performance of the system. Share your experience with similar events. It will be important to highlight that the theft of all the grounding pigtailes in a substation is different from the act of simply snipping each of them to leave the equipment electrically floating. The technical condition is the same, but this allows the police to make an inference with respect to motive, suspect profile, sophistication, etc. That's their job. They may ask us to speculate on the motive or skills of the attacker. That's okay. But at least we don't have to know or guess at it for the purpose of determining whether to report the event. No training required. With respect to notification to the FBI, We Energies recommends that the standard merely state that the owner of the damaged asset ensure the local office of the FBI is notified. The standard should permit documentation of either a direct phone call by the asset owner or obtaining an assurance from the local police that they will do so. There should be no need to prove earlier establishment of a relationship with the FBI. There should be no expectation that the entity have a signed letter from the FBI Special Agent in Charge acknowledging his agency's duty. This document means nothing. With respect to reporting within the industry, We Energies recommends that the only events to be reported "up the chain" are those that we choose to characterize as "impact events". That is, the events that meet some measurable threshold with respect to BES impact. We should describe these efficiently to avoid over-reporting of trivial events. It is apparent that we are already over-reporting since DHS HITRAC recently fed back to the industry that copper thieves attacked a substation in San Bernardino, CA taking some of the grounding conductors. The industry should have the option to report non-impact events that are unusual in some respect and which may have some mutual industry benefit in terms of prevention, awareness or recovery. Attack attempts with no impact, or observations of suspicious activity could fall into this optional category. These optional reports could be aggregated by the entity for the purpose of detecting patterns or trends, or be reported ad hoc. The ES-ISAC should be the recipient of the reports. It should be the single point of contact since it has the industry insight, engineering expertise and cross-sector relationships to analyze and return valuable intelligence to the industry. With the ES-ISAC as the recipient of the reports, efficient sharing with Federal agencies, with the regional entities and with neighboring asset owners could be automated and rapid. There is much benefit to be gained from this project, primarily in the area of creating clarity and uniformity. There is some risk that the reporting requirements will become onerous and prescriptive.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is proposing to consolidate disturbance and event reporting under a single standard. The DSR SDT believes that reporting material risks to the Bulk Electrical System by using the impact event categorization, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation by the elimination of the term "sabotage". The intent is to allow potentially impacted parties to prepare for and possibly mitigate the reliability risk. The NERC Rules of</b></p>	

Organization	Question 7 Comment
	<p>Procedure (section 800) provides an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. The SDT is proposing that the new standard specify who has access to reported information and who should be notified about impact events, because agencies such as the DHS and FBI have other duties and responsibilities - an impact event that is related to copper theft may only need to be reported to the local law enforcement authorities. The goal of the DSR SDT is create clarity and uniformity by developing a single reporting form for all functional entities without regard to nationality (US, Canada, Mexico) to submit to NERC with guidance. Ideally, entities would complete a single form, which could then be distributed to jurisdictional agencies and functional entities as appropriate. The DSR SDT agrees with your assessment that there should be no expectation that the entity have a signed letter from the FBI Special Agent.</p>
<p>Bandera Electric Cooperative, Inc.</p>	<p>I commend the SDT for working on this effort and wish them success.</p>
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>	
<p>Public Service Enterprise Group Companies</p>	<p>If reporting does become the responsibility of the Reliability Coordinators, the RCIS should be made available view-only to registered entities with a notification when RC's have posted new entries. That will enhance the situational awareness of registered entities.</p> <p>The PSEG Companies disagree with inclusion of CIP-008 reporting requirements as part of the CIP-001 and EOP-004 initiative. CIP-008 reporting as part of the cyber security set of NERC standards is usually managed by specialized corporate organizations separate from those involved with the other NERC standards, and with highly specialized cyber skill sets. CIP-008 reporting requirements should remain where they are, and any perceived need for improvement addressed in the ongoing CIP Version 4 development process.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The RCIS is a real-time communication and reporting tool and is outside the scope of the SDT. The goal of the DSR SDT is to develop a form to expedite report completion, sharing and storage. Ideally, entities would complete a single form, which could then be distributed to jurisdictional agencies and functional entities as appropriate. Functional entities may include the RC, TOP, and BA for situational awareness. The DSR SDT will take into consideration your comment with inclusion to CIP-008 reporting. However, the drafting team will explore clarification that any proposed CIP-008-related reporting requirement between CIP-008 and CIP-001 is only applicable where the incident/event involves a registered entity's CCA. Note that CIP-002 through CIP-009 are undergoing revision under project 2008-06 – Order 706 SDT.</b></p>	
<p>Independent Electricity System Operator</p>	<p>In the Background Section of the comment form, it is indicated that the SDT "...is NOT seeking input or guidance on the definition of physical or cyber sabotage, what type of disturbances should be reported, who should do reporting, or to whom or what organizations will be receiving the reports." <u>Yet there are proposed definitions, with examples, in the concept paper.</u> The SDT should make it absolutely clear that by supporting the general concept as described in the paper, the commenting entities are not endorsing the proposed definitions, nor the examples as elements to be included in the standard.</p>

Organization	Question 7 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT will continue to clarify the impact events concept and eliminate “gray areas” while including language to give clarity to the reporting process. Standards developed under this project will be posted for comment on specific content.</p>	
Luminant	Luminant disagrees with the direction of utilizing impact events, as this is an expansion in scope beyond the simplification of sabotage and disturbance reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES. The DSR SDT has reviewed the existing standards, the SAR; issues from the NERC database and FERC Order 693 Directives and determine this was a prudent course of action with respect to these standards to provide clear criteria for reporting.</p>	
Dynergy Inc.	N/A
Manitoba Hydro	No
Edison Mission Marketing & Trading	No other comments.
SERC Reliability Coordinator Sub-committee (RCS)	None.
USBR	The concept of "threat" evaluation criteria is somewhat vague and a great care is needed to ensure it is clear enough that the most individuals would be able to analyze an event and end up at the same threat. Otherwise it would be almost impossible to ensure compliance with a requirement which cannot accurately describe criteria to be used to ensure that proper evaluation has occurred.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES as opposed to requiring a threat evaluation. The DSR SDT intends to develop criteria that will assist entities in determining which events should be reported.</p>	
Wolverine Power Supply Cooperative, Inc.	The concepts of removing duplication, consolidation, and focusing on "impact events" sound logical. I am concerned that the focus may drift to expanded reporting, not reduced reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DST SDT discussed the reporting of “impact events” and will consider guidance found in the document, “<a href="#">NERC Guideline: Threat and Incident Reporting</a>” which will include clear criteria to eliminate erroneous or expanded reporting.</p>	

Organization	Question 7 Comment
ISO RTO Council Standards Review Committee	<p>The FERC Order merely asked NERC to “further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” There is no requirement to create a Reporting Standard and no mention of Disturbance events. There is a strong need to avoid heavy-handed use of NERC standards particularly for such post event reporting guidelines. The SRC would urge the DSR SDT to continue to improve its guidelines and to post those guidelines for all to use, but not to create sanctionable standards whose good intentions will inevitably result in many unintended adverse consequences for the Industry. Rather, the SDT should seek to retire sanctionable requirements that require event reporting in favor of guidelines for reporting.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). The DSR SDT will take into consideration your comment on keeping cyber and physical events separate. We are suggesting in our discussion to consolidate the location of reporting into one standard. The industry has demonstrated by its comments that the reporting process be streamlined to achieve a “one stop shop” approach. We will continue to explore the possibilities to achieve the best results for all stakeholders. A discussion of advantages /disadvantages will continue to discover options and alternatives with input from all stakeholders.</b></p>	
Lands Energy Consulting	<p>The lack of common sense that leads to a 15 MW loss of load resulting from a 115 kV line outage being categorized as a "reportable disturbance" really hurts the credibility of the entire NERC Compliance Program. The smaller utilities look at application of EOP-004 in particular to their operation and conclude that either the EO/RRO is: a. stupid; or b. Out to persecute the smaller utilities. In reality, EOP-004 was drafted for application to Southern California Edison, where loss of 50% of customers would be 2-3 million customers. Now that's really disturbing!</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT intends to develop criteria that will assist entities in determining which events should be reported. Acts of sabotage may be “tested” on smaller entities before the saboteurs move on the larger entities.</b></p>	
Central Hudson Gas & Electric	<p>The NERC Guideline: Threat and Incident Reporting Attachment A matrix is an extremely beneficial document that organizes reporting criteria. However, it identifies communications systems failure sub-category under the Equipment And/Or Systems Failure category as reportable with a reference to OE-417 - Schedule 1, Item 10. Item 10 on Schedule 1 addresses only failures due to attacks (not failures for other reasons).</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). Loss of communications would be considered an impact event. The reason for the loss of communications is irrelevant.</b></p>	

Organization	Question 7 Comment
Duke Energy	<p>We don't think CIP-001, EOP-004 and cyber incident reporting aspects of CIP-008 should all be combined into one standard, because of the significant differences between sabotage and disturbances. We have suggested that the drafting team further define sabotage, and we have included a suggested definition in our response to question #5 above. Sabotage is very specific due to the intent (for the purpose of weakening the critical infrastructure), and the potential impact to the BES. We believe that sabotage and cyber incident reporting should remain a part of the CIP Standards due to the emphasis placed on the criticality and vulnerability of the assets needed to support reliable operation of the BES. Cyber Security and Physical Security could be placed together in the same standard (remain in CIP) and other disturbances (i.e., accidental, natural) in a separate standard. "One stop shopping" for reporting is still possible as long as the OE-417 form is included as part of the NERC electronic form. And while we agree with the need for additional clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is still evaluating inclusion of CIP-008 reporting requirements with CIP-001 and EOP-004 requirements, Note that the current CIP-008 has a reporting requirement to the ES-ISAC only. The DSR SDT developed the more inclusive term "impact events" to eliminate using more confusing terms like sabotage (which is not likely to be determined until after a lengthy investigation). These standards may be combined to have all reporting requirements in a single standard, not because the items to be reported are necessarily related.</b></p>	
FirstEnergy	<p>We fully agree that sabotage events need to be more clearly defined and reporting requirements need to be better coordinated. But as we have stated in previous comments, the drafting team needs to determine if standard requirements need to be developed for this type of reporting or if this is better left to administrative requirements outside the standards arena. Also, while we appreciate the team's effort to simplify reporting requirements for entities, we are concerned with the serial communication offered by the concept paper. As an example, the team proposes to have LSE report the incident to the BA and/or TOP and then have the BA and/or TOP report it to the RC and the RC to report it to NERC and the NERC report to the regulatory agencies. While this simplifies it for each individual organization, this method introduces many opportunities for errors and miscommunications. Since this is after-the-fact reporting, it is difficult to defend this type of communication path when one consistent report could be sent simultaneously to all agencies at the same time from the originating location.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The Reliability Coordinator's suggested role in this is to allow them to incorporate the relevant data from responsible entities in their footprint for further analysis. We will consider your suggestion of simultaneous submissions as a means to effectively notify the necessary parties. The SDT believes that it is the submitter's responsibility to submit OE-417 forms to the DOE. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory</b></p>	

Organization	Question 7 Comment
requirements.	
Ameren	<p>While we are not opposed to the concept of identifying impact events, we are concerned that the drafting team may actually be expanding reporting requirements. We do not support expansion of reporting requirements unless a clear reliability or legal need is identified. Some of the impact events are almost never sabotage and do not warrant reporting for reliability needs and should not be included. For example, copper theft should not require reporting, in general, because it is almost never sabotage and rarely impacts reliability. If it does, impact reliability because, for example, the protection system is impacted and causes more significant potential contingencies, then reporting could be required. Why is a train derailment near a transmission right of way significant? It would only be significant if an investigation identified sabotage as the reason. Furthermore, what is considered near?</p>
Midwest ISO Standards Collaborators	<p>While we are <u>not</u> opposed to the concept of identifying impact events, we are concerned that the drafting team may actually be expanding reporting requirements. We do not support expansion of reporting requirements unless a clear reliability or legal need is identified. Some of the impact events are almost never sabotage and do not warrant reporting for reliability needs and should not be included. For example, copper theft should not require reporting, in general, because it is almost never sabotage and rarely impacts reliability. If it does impact reliability because, for example, the protection system is impacted and causes more significant potential contingencies, then reporting could be required. Why is a train derailment near a transmission right of way significant? It would only be significant if an investigation identified sabotage as the reason. Furthermore, what is considered near?</p>
<p><b>Response: The DSR SDT thanks you for your comment. It is not the intent of the DSR SDT to expand reporting requirements but rather to attempt to clarify and define an approach to assist the industry and stakeholders in reporting impact events. Furthermore, impact events should not include copper theft or other conditions that pose no threat to the reliability of the BES. A train derailment is only an impact event if it threatens some element of the power system such as a transmission line corridor - the derailment in itself is not an impact event.</b></p>	
Exelon	<p>You should consider providing clear and concise instructions as to the expectation on submitting forms, i.e. the DOE 417. There should be no guessing as to when and how reports should be submitted and who should receive them. Specific details on reporting criteria should be included.</p>
<p><b>Response : The DSR SDT thanks you for your comment. The DSR SDT intends to develop criteria for reporting impact events.</b></p>	



## Consideration of Comments on Disturbance and Sabotage Reporting — Project 2009-01

The Disturbance and Sabotage Reporting Drafting Team thanks all commenters who submitted comments on its preliminary draft of EOP-004-2 – Impact Event and Disturbance Assessment, Analysis, and Reporting. This standard was posted for a 30-day informal comment period from September 15, 2010 through October 15, 2010. Stakeholders were asked to provide feedback on the standard through a special Electronic Comment Form. There were 60 sets of comments, including comments from more than 175 different people from approximately 100 companies representing 9 of the 10 Industry Segments as shown in the table on the following pages.

In this report, the comments have been sorted by question number so that it is easier to see where there is consensus. The comments are posted in their original format on the following project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

Based on stakeholder comments, and also on the results of the observations made by the Quality Review team, the drafting team made the following significant changes to the standard following the posting period that ended on October 15, 2011.

**Scope:** A common thread through most of the comments was that the DSR SDT went beyond the reliability intent of the standard (reporting) and concentrated too much on the analysis of the event. The DSR SDT agrees with this response, and revised the purpose as follows:

*Original Purpose:* Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES).

*Revised Purpose:* To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.

### Definitions:

**Impact Event:** The DSR SDT had proposed a working definition for “impact events” to support EOP-004 - Attachment 1 as follows:

“An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

Many stakeholders indicated that the definition should be added to the NERC Glossary and the DSR SDT adopted this suggestion.

The types of Impact Events that are required to be reported are contained within EOP-004 - Attachment 1. Only the events identified in EOP-004 – Attachment 1 are required to be reported under this Standard.

**Sabotage:** FERC Order 693, paragraph 471 states in part: “. . . the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide

guidance as to the triggering events that would cause an entity to report a sabotage event.”

The DSR SDT made a conscious, deliberate decision to exclude a strict definition of sabotage from this standard and sought stakeholder feedback on this issue. Some suggested adopting the NRC definition of the term sabotage, and the DSR SDT did consider adopting the NRC definition shown below but determined that the definition is too narrowly focused.

Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.

Most respondents agreed that in order to be labeled as an act of sabotage, the intent of the perpetrators must be known. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This would result in further ambiguity with respect to reporting events, and the timeline associated with the reporting requirements does not lend itself to the in-depth analysis required to identify a disturbance (or potential disturbance) as sabotage. The SDT felt that a likely consequence of having to meet this criterion, in the time allotted, would be an under-reporting of events. Accordingly, all references to sabotage have been deleted from the standard.

Instead, the SDT concentrated on providing clear guidance on the events that should trigger a report. The SDT believes that this more than adequately meets the reliability intent of the Commission as expressed in paragraph 471 of Order 693 in an equally efficient and effective manner.

**Situational Awareness versus Industry Awareness:** Some commenters correctly pointed out that “situational awareness” is a desirable by-product of an effective event reporting system, and not the driver of that system. Accordingly, all references to “situational awareness” have been deleted from the standard. The more generic “industry awareness” has been substituted where appropriate.

### **Applicability:**

The DSR SDT had protracted discussions on the applicability of this standard to the LSE. Per the Functional Model, the LSE does not own assets and therefore should not be an applicable entity (no equipment that could experience a “disturbance”). However, the Registry Criteria contains language that could imply that the LSE does own assets, or is at least responsible for assets. In addition, the DSR SDT modified Attachment 1 to include reporting of damage or destruction of Critical Cyber Assets per CIP-002. The LSE, as well as the Interchange Authority and Transmission Service Provider are applicable entities under CIP-002 and should be included for Impact Events under EOP-004.

There were several comments that the asset owners (GO/TO) would be less likely than the asset operators (GOP/TOP) to be aware of an impact event. The DSR SDT recognizes that this may be true in some cases, but not all. In order to meet the reliability objectives of this requirement, the applicability for GO/TO will remain as per Attachment 1.

**Requirement R1:**

Based on stakeholder comments, Requirement R1, which assigned the ERO the responsibility for collecting and distributing impact event reports was deleted. There was strong support for a central system for receiving and distributing impact event reports (a/k/a one stop shopping). There was general agreement that NERC was the most likely, logical entity to perform that function. However several respondents expressed their concern that the ERO could not be compelled to do so by a requirement in a Reliability Standard (not a User, Owner or Operator of the BES). In their own comments, NERC did not oppose the concept, but suggested that the more appropriate place to assign this responsibility would be the NERC Rules of Procedure. The DSR SDT concurs. The DSR SDT has removed the requirement from the standard and is proposing to make revisions to the NERC Rules of Procedure as follows:

812. NERC will establish a system to collect impact event reports as established for this section, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, and regulatory agencies as necessary. These reports shall be forwarded to the Federal Energy Regulatory Commission for impact events that occur in the United States. The ERO shall solicit contact information from Registered Entities appropriate governmental, law enforcement and regulatory agencies for distributing reports.

**Requirement R2 (now R1 in the revised standard):**

There were objections to the use of the term “Operating Plan” to describe the procedure to identify and report the occurrence of a disturbance. The DSR SDT believes that the use of a defined term is appropriate and has revised Requirement R1 to include Operating Plan, Operating Process and Operating Procedure.

Many commenters felt that the requirements around updating the Operating Plan were too prescriptive, and impossible to comply with during the time frame allowed. The DSR SDT agrees, and Requirement R2, Parts 2.5 through 2.9 have been eliminated. They have been replaced with Requirement R1, Part 1.4 to require updating the Impact Event Operating Plan within 90 days of any change to content.

**R1.** Each Responsible Entity shall have an Impact Event Operating Plan that includes: *[Violation Risk: Factor Medium] [Time Horizon: Long-term Planning]:*

- 1.1. An Operating Process for identifying Impact Events listed in Attachment 1.
- 1.2. An Operating Procedure for gathering information for Attachment 2 regarding observed Impact Events listed in Attachment 1.
- 1.3. An Operating Process for communicating recognized Impact Events to the following:
  - 1.3.1 Internal company personnel notification(s).

1.3.2. External organizations to notify to include but not limited to the Responsible Entities' Reliability Coordinator, NERC, Responsible Entities' Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.

1.4. Provision(s) for updating the Impact Event Operating Plan within 90 days of any change to its content.

Other requirements reference the Operating Plan as appropriate. The requirements of EOP-004-2 fit precisely into the definition of Operating Plan:

Operating Plan: A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.

**Requirement R3 (now R2 in the revised standard):**

Requirement R3 has been re-written to exclude the requirement to “assess the initial probable cause”. The only remaining reference to “cause” is in the Impact Event Reporting Form (Attachment 2). Here, there is no longer a requirement to assess the probable cause. The probable cause only needs to be identified, and only if it is known at the time of the submittal of the report.

R2. Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B). *[Violation Risk: Factor Medium] [Time Horizon: Real-time Operations and Same-day Operations]*

**Requirement R4 (now R3 in the revised standard):**

The DSR SDT did a full review based on comments that were received. R3 now is stream lined to read:

R3. Each Responsible Entity shall conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 months between such tests. .

The testing of the Operating Process for communicating recognized Impact Events (as stated in R1) is the main component of this requirement. Several commenters provided input that too much “how” was previously within R3 and the DSR DST should only provide the “what”. The DSR SDT did not provide any prescriptive guidance on how to accomplish the required testing within the rewrite. Testing of the entity’s procedure (R1) could be by an actual exercise of the process (testing as stated in FERC Order 693 section 471), a formal review process or real time implementation of the procedure. The DSR SDT reviewed Order 693 and section 465 directs that processes are “verify that they achieve the desired result”. This is the basis of R3, above.

**Requirement R5 (now R4 in the revised standard):**

The DSR SDT did a full review based on comments that were received. The major issues that

were provided by commenters involved the inclusion of Requirement R5, Part 5.3 and Part 5.4.

- 5.3 If the Operating Plan is revised (with the exception of contact information revisions), training shall be conducted within 30 days of the Operating Plan revisions.
- 5.4 For internal personnel added to the Operating Plan or those with revised responsibilities under the Operating Plan, training shall be conducted prior to assuming the responsibilities in the plan.

Upon detailed review the DSR SDT agrees with the majority of comments received regarding Requirement R5, Parts 5.3 and 5.4 and has removed Parts 5.3 and 5.4 completely from the Standard. Training is still the main theme of this requirement (now R4) as it pertains to the personnel required to implement the Impact Event Operating Plan (R1).

R4 now is stream lined to read:

- R4. Each Responsible Entity shall review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan at least annually with no more than 15 calendar months between review sessions

**Requirement R6 (now R5 in the revised standard):**

The DSR SDT did a full review based on comments that were received. Many comments received identified concerns on the reporting time lines within Attachment 1., Several commenters wanted the ability to report impact events to their responsible parties via the DOE Form OE-417. Upon discussions with the DOE and NERC, the DSR SDT has added the ability to use the DOE Form OE-417 when the same or similar items are required to be reported to NERC and the DOE. This will reduce the need to file multiple forms when the same or similar events must be reported to the DOE and NERC. The reliability intent of reporting impact events within prescribed guidelines, to provide industry awareness and to start any required analysis processes can be met without duplicate reporting R5 now is stream lined to read:

- R5. Each Responsible Entity shall report Impact Events in accordance with its Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form.

**Requirements R7 and R8:**

The DSR SDT did a full review based on comments that were received. The DSR SDT has determined that R7 and R8 are not required to be within a NERC Standard since Section 800 of the Rules of Procedure already assigns this responsibility to NERC.

**Attachment 1:**

The DSR SDT did a full review based on comments that were received. The DSR SDT, the Events Analysis Working Group (EAWG), NERC Staff (to include NERC Senior VP and Chief Reliability Officer) had an open discussion involving this topic. The EAWG and the DSR SDT aligned Attachment 1 with the Event Analysis Program category 1 analysis responsibilities. This will assure that impact events in EOP-004-2 reporting requirements are the starting vehicle for any required Event Analysis within the NERC Event Analysis Program. The DSR SDT reviewed the “hierarchy” of reporting within Attachment 1. To reduce multiple entities reporting the same impact event, the DSR SDT has stated that the entity that performs the action or is directly

affected by an action will report per EOP-004-2. As an example, during a system emergency, the TOP or RC may request manual load shedding by a DP or TOP. The DP or TOP would have the responsibility to report the action that it took if it meets or exceeds the bright-line criteria established in Attachment 1. Upon reporting, the NERC Event Analysis Program would be made aware of the impact event and start the Event Analysis Process which is outside the scope of this Standard. Several bright-line criteria were removed from Attachment 1. These criteria (DC converter station, 5 generator outages, and frequency trigger limits) were removed after discussions with the EAWG and NERC staff, who concurred that these items should be removed from a reporting standard and analysis process.

Several respondents expressed concern that the reporting requirements were redundant. The general sentiment was that unclear responsibility to report a disturbance could trigger a flood of event reports. Attachment 1 has been modified to assign clear responsibility for reporting, for each category of Impact Event.

Some commenters indicated a concern that the list of events in Attachment 1 isn't as comprehensive as the existing standard since the existing standard includes bomb threats and observations of suspicious activities. Others commented that the impact event list should include deliberate acts against infrastructure. The DSR SDT believes that "observation of suspicious activity" and "bomb threats" are addressed in Attachment 1 Part B – "Risk to BES equipment from a non-environmental physical threat". The SDT has added the phrase, "and report of suspicious device near BES equipment" to note 3 of the "Attachment 1, Potential Reliability – Part B" for additional clarity.

**Attachment 2:**

The proposed Impact Event Report (Attachment 2) generated comments regarding the duplicative nature of the form when compared to the OE-417. The DSR SDT has added language to the proposed form to clarify that NERC will accept a DOE OE-417 form in lieu of Attachment 2 if the responsible entity is required to submit an OE-417 form.

In collaboration with the NERC Event Analysis Working Group (EAWG) the DSR SDT modified the attachment to eliminate confusion. This revised form will be Attachment 2 of the Standard and collects the only information required to be reported for EOP-004-2. Further information may be requested through the Events Analysis Process (NERC Rules of Procedure), but the collection of this information is outside of the scope of EOP-004.

The DSR SDT has also clarified what the form's purpose with the following addition to the form:

"This form is to be used to report impact events to the ERO."

**Other Standard Issues:**

The DSR SDT proposed that combining EOP-004 and CIP-001 would not introduce a reliability gap between the existing standards and the proposed standard and the industry comments received confirms this.

Several entities expressed their concern with the fact that Attachment 1 contained most of the elements already called for in the OE-417. The DSR SDT agrees, and Attachment 1 part 1 has

been modified to even more closely mirror the Department of Energy’s OE-417 Emergency Incident and Disturbance Report form. Additionally, the standard has been modified to allow for the use of the OE-417.

There was some concern expressed that there could be confusion between the reporting requirements in this standard, and those found in CIP-008. The DSR SDT agrees, and Attachment 1 Part B, has been modified to provide the process for the reporting of a Cyber Security Incident.

The DSR SDT also believes NERC’s additional concern about what data is applicable is addressed by the revisions to Attachment 1, and the inclusion of the OE-417 as an acceptable interim vehicle.

**Implementation Plan:**

The DSR SDT asked stakeholders to provide feedback on the proposed effective date which provided entities at least a year following board approval of the standard. Most stakeholders supported the one year minimum, however based on the revisions made to the requirements, the drafting team is now proposing that this time period be shortened to between six months and nine months. The current CIP-001 plan is adequate for the new EOP-004 and training should be met in the proposed timeline. Note that the Implementation Plan was developed for the revised Requirements, which do not include an electronic “one-stop shopping” tool. The tool for ‘one stop shopping’ will be addressed in the proposed revisions to the NERC Rules of Procedure.

The industry commented on the need for e-mail addresses and fax numbers for back up purposes. These details were added to the standard and the implementation plan.

The proposed ballot in December was incorrect and has been deleted from the future development plan. The plan was updated with the correct project plan dates.

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Herb Schrayshuen, at 609-452-8060 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

Index to Questions, Comments, and Responses

1. ***Do you agree with the purpose statement of the proposed standard? Please explain in the comment box below. .... 19***
2. ***Do you agree with the applicable entities in the Applicability Section as well as assignment of applicable entities noted in Attachment 1? Please explain in the***

---

<sup>1</sup> The appeals process is in the Reliability Standards Development Procedures:

<http://www.nerc.com/standards/newstandardsprocess.html>.

<i>comment box below. ....</i>	<i>35</i>
<i>3. Do you agree with the requirement R1 and measure M1? Please explain in the comment box below. ....</i>	<i>53</i>
<i>4. Do you agree with the requirement R2 and measure M2? Please explain in the comment box below. ....</i>	<i>67</i>
<i>5. Do you agree with the requirement R3 and measure M3? Please explain in the comment box below. ....</i>	<i>90</i>
<i>6. Do you agree with the requirement R4 and measure M4? Please explain in the comment box below. ....</i>	<i>103</i>
<i>7. Do you agree with the requirement R5 and measure M5? Please explain in the comment box below. ....</i>	<i>115</i>
<i>8. Do you agree with the requirement R6 and measure M6? Please explain in the comment box below ....</i>	<i>132</i>
<i>9. Do you agree with the requirements for the ERO (R7-R8) or is this adequately covered in the Rules of Procedure (section 802)? Please explain in the comment box below. ....</i>	<i>143</i>
<i>10. Do you agree with the impact event list in Attachment 1? Please explain in the comment box below and provide suggestions for additions to the list of impact events. ....</i>	<i>155</i>
<i>11. Do you agree with the use of the Preliminary Impact Event Report (Attachment 2)? .....</i>	<i>182</i>
<i>12. The DSR SDT has replaced the terms “disturbance” and “sabotage” with the term “impact events”. Do you agree that the term “impact events” adequately replaces the terms “disturbance” and “sabotage” and addresses the FERC directive to “further define sabotage” in an equally efficient and effective manner? Please explain in the comment box below.....</i>	<i>192</i>
<i>13. The DSR SDT has combined EOP-004 and CIP-001 into one standard (please review the mapping document that shows the translation of requirements from the already approved versions of CIP-001 and EOP-004 to the proposed EOP-004), EOP-004-3 and retiring CIP-001. Do you agree that there is no reliability gap between the existing standards and the proposed standard?.....</i>	<i>201</i>
<i>14. Do you agree with the proposed effective dates? Please explain in the comment box below.....</i>	<i>207</i>



***15. Do you have any other comments that you have not identified above?.....213***

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
1.	Group	Guy Zito	Northeast Power Coordinating Council										X
Additional Member	Additional Organization	Region	Segment Selection										
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10									
2.	Gregory Campoli	New York Independent System Operator	NPCC	2									
3.	Kurtis Chong	Independent Electricity System Operator	NPCC	2									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment													
			1	2	3	4	5	6	7	8	9	10				
4.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1												
5.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1												
6.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10												
7.	Dean Ellis	Dynegy Generation	NPCC	5												
8.	Brian Evans-Mongeon	Utility Services	NPCC	8												
9.	Mike Garton	Dominion Resources Services, Inc.	NPCC	5												
10.	Brian L. Gooder	Ontario Power Generation Incorporated	NPCC	5												
11.	Kathleen Goodman	ISO - New England	NPCC	2												
12.	Chantel Haswell	FPL Group, Inc.	NPCC	5												
13.	David Kiguel	Hydro One Networks Inc.	NPCC	1												
14.	Michael R. Lombardi	Northeast Utilities	NPCC	1												
15.	Randy MacDonald	New Brunswick System Operator	NPCC	2												
16.	Bruce Metruck	New York Power Authority	NPCC	6												
17.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10												
18.	Robert Pellegrini	The United Illuminating Company	NPCC	1												
19.	Si Truc Phan	Hydro-Quebec TransEnergie	NPCC	1												
20.	Saurabh Saksena	National Grid	NPCC	1												
21.	Michael Schiavone	National Grid	NPCC	1												

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
22.		Peter Yost	Consolidated Edison Co. of New York, Inc. NPCC		3								
2.	Group	Jim Case, SERC OC Chair	SERC OC Standards Review Group	X		X							
Additional Member	Additional Organization	Region	Segment Selection										
1.	Mike Garton	Dominion Virginia Power	SERC	1, 3									
2.	Jim Griffith	Southern	SERC	1, 3, 5									
3.	Vicky Budreau	Santee Cooper	SERC	1, 3, 5, 9									
4.	Gerry Beckerle	Ameren	SERC	1, 3									
5.	Eugens Warnecke	Ameren	SERC	1, 3									
6.	Scott McGough	Oglethorpe Power	SERC	5									
7.	John Neagle	AEC I	SERC	1, 3, 5									
8.	Joel Wise	TVA	SERC	1, 3, 5, 9									
9.	Jennifer Weber	TVA	SERC	1, 3, 5, 9									
10.	Robert Thomasson	BREC	SERC	1, 3, 5, 9									
11.	Derek Bleye	SCE&G	SERC	1, 3, 5									
12.	Gene Delk	SCE&G	SERC	1, 3, 5									
13.	Dave Plauck	Calpine	SERC	5									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
14.	Tom Hanzlik	SCE&G	SERC	1, 3, 5																
15.	Randy Castello	Mississippi Power	SERC	1, 3, 5																
16.	Doug White	NCEMC	SERC	1, 3, 5, 9																
17.	Randy Haynes	Alcoa	SERC	1, 5																
18.	Joel Rogers	SMEPA	SERC	1, 3, 5, 9																
19.	Mike Bryson	PJM	SERC	2																
20.	Rick Meyers	EEI	SERC	1, 5																
21.	Tim Hattaway	PowerSouth	SERC	1, 3, 5, 9																
22.	Barry Warner	EKPC	SERC	1, 3, 5, 9																
23.	Jack Kerr	Dominion Virginia Power. P.	SERC	1, 3																
24.	Wes Davis	SERC Reliability Corp.	SERC	10																
25.	John Troha	SERC Reliability Corp.	SERC	10																
3.	Group	Brad Jones	Luminant Energy								X									
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Kevin Phillips	Luminant Energy	ERCOT	6																
4.	Group	David Grubbs	City of Garland		X															
<b>Additional Member Additional Organization Region Segment</b>																				

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
			<b>Selection</b>										
		1. David Grubbs	ERCOT	1									
		2. Fred Sherman	ERCOT	1									
		3. Steve Zaragoza	ERCOT	1									
		4. Billy Lee	ERCOT	1									
		5. Heather Siemens	ERCOT	1									
		6. Ronnie Hoeinghaus	ERCOT	1									
		7. Matt Carter	ERCOT	1									
5.	Group	Terry L. Blackwell	Santee Cooper		X		X		X	X			
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
		1. S. T. Abrams	Santee Cooper	SERC	1								
		2. Rene' Free	Santee Cooper	SERC	1								
		3. Vicky Budreau	Santee Cooper	SERC	1								
		4. Glenn Stephens	Santee Cooper	SERC	1								
6.	Group	Steve Alexanderson	Pacific Northwest Small Public Power Utility Comment Group				X	X					

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
Additional Member	Additional Organization	Region	Segment Selection																	
1.	Russell Noble	Cowlitz County PUD No. 1	WECC	3, 4, 5																
2.	Dave Proebstel	Clallam County PUD	WECC	3																
3.	Ronald Sporseen	Blachly-Lane Electric Cooperative	WECC	3																
4.	Ronald Sporseen	Central Electric Cooperative	WECC	3																
5.	Ronald Sporseen	Clearwater Power Company	WECC	3																
6.	Ronald Sporseen	Douglas Electric Cooperative	WECC	3																
7.	Ronald Sporseen	Consumers Power	WECC	3																
8.	Ronald Sporseen	Fall River Rural Electric Cooperative	WECC	3																
9.	Ronald Sporseen	Northern Lights	WECC	3																
10.	Ronald Sporseen	Lane Electric Cooperative	WECC	3																
11.	Ronald Sporseen	Lincoln Electric Cooperative	WECC	3																
12.	Ronald Sporseen	Raft River Rural Electric Cooperative	WECC	3																
13.	Ronald Sporseen	Lost River Electric Cooperative	WECC	3																
14.	Ronald Sporseen	Salmon River Electric Cooperative	WECC	3																
15.	Ronald Sporseen	Umatilla Electric Cooperative	WECC	3																

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization		Registered Ballot Body Segment									
					1	2	3	4	5	6	7	8	9	10
16.		Ronald Sporseen	Coos-Curry Electric Cooperative	WECC	3									
17.		Ronald Sporseen	West Oregon Electric Cooperative	WECC	3									
18.		Ronald Sporseen	Pacific Northwest Generating Cooperative	WECC	5									
19.		Ronald Sporseen	Power Resources Cooperative	WECC	5									
7.	Group	Mallory Huggins	NERC Staff											
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
	1. Earl Shockley	NERC	NA - Not Applicable NA											
	2. Dave Nevius	NERC	NA - Not Applicable NA											
	3. Gerry Adamski	NERC	NA - Not Applicable NA											
	4. Roman Carter	NERC	NA - Not Applicable NA											
8.	Group	Carol Gerou	MRO's Subcommittee	NERC Standards Review										X
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
	1.	Mahmood Safi	Omaha Public Utility District	MRO	1, 3, 5, 6									
	2.	Chuck Lawrence	American Transmission Company	MRO	1									



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
3.	Tom Webb	WPS Corporation	MRO	3, 4, 5, 6										
4.	Jodi Jenson	Western Area Power Administration	MRO	1, 6										
5.	Ken Goldsmith	Alliant Energy	MRO	4										
6.	Alice Murdock	Xcel Energy	MRO	1, 3, 5, 6										
7.	Dave Rudolph	Basin Electric Power Cooperative	MRO	1, 3, 5, 6										
8.	Eric Ruskamp	Lincoln Electric System	MRO	1, 3, 5, 6										
9.	Joseph Knight	Great River Energy	MRO	1, 3, 5, 6										
10.	Joe DePoorter	Madison Gas & Electric	MRO	3, 4, 5, 6										
11.	Scott Nickels	Rochester Public Utilities	MRO	4										
12.	Terry Harbour	MidAmerican Energy Company	MRO	1, 3, 5, 6										
9.	Group	Sam Ciccone	FirstEnergy	X		X	X	X	X					
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.	Dave Folk	FE	RFC											
2.	Doug Hohlbaugh	FE	RFC											
3.	Andy Hunter	FE	RFC											
4.	Kevin Querry	FE	RFC											
5.	Brian Orians	FE	RFC											

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
6.	John Martinez	FE	RFC										
7.	John Reed	FE	RFC										
8.	Marissa McLean	FE	RFC										
9.	Phil Bowers	FE	RFC										
10.	Group	Mike Garton	Electric Market Policy	X		X		X	X				
Additional Member	Additional Organization	Region	Segment Selection										
1.	Michael Gildea	Dominion	NPCC	5									
2.	Louis Slade	Dominion	SERC	6									
3.	John Loftis	Dominion Virginia Power	SERC	1									
11.	Group	Denise Koehn	Bonneville Power Administration	X		X		X	X				
Additional Member	Additional Organization	Region	Segment Selection										
1.	Jim Burns	BPA, Transmission, Technical Operations	WECC	1									
2.	Russell Funk	BPA, Transmission, DCC Data System Hardware	WECC	1									
3.	John Wylder	BPA, Transmission, CC HW Dsgn/Stdns Montr & Admin	WECC	1									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
12.	Group	Kenneth D. Brown	PSEG Companies	X		X		X	X				
Additional Member	Additional Organization	Region	Segment Selection										
1.	Ron Wharton	PSE&G System Ops	RFC	1, 3									
2.	Jerzy Slusarz	PSEG Fossil	RFC	5, 6									
3.	James Hebson	PSEG ER&T	ERCOT	5, 6									
4.	Dominick Grasso	PSEG Power Connecticut	NPCC	5, 6									
13.	Group	Steve Rueckert	WECC										X
Additional Member	Additional Organization	Region	Segment Selection										
1.	Tom Schneider	WECC	WECC	10									
2.	John McGee	WECC	WECC	10									
14.	Group	Richard Kafka	Pepco Holdings, Inc - Affiliates	X		X		X	X				
Additional Member	Additional Organization	Region	Segment Selection										
1.	Vic Davis	Delmarva Power & Light Co	RFC	1									
2.	Dave Thorne	Potomac Electric Power Company	RFC	1									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
15.	Group	Howard Rulf	We Energies			X	X	X					
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
	1.	Tom Eells	We Energies RFC	3, 4, 5									
	2.	Fred Hessen	We Energies RFC	3, 4, 5									
	3.	Brian Heimsch	We Energies RFC	3, 4, 5									
16.	Group	Annette M. Bannon	PPL Supply					X					
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
	1.	Mark Heimbach	PPL Martins Creek, LLC RFC	5									
17.	Group	J T Wood	Southern Company - Transmission	X		X							
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
	1.	Marc Butts	Southern Company Services	SERC 1									
	2.	Andy Tillery	Southern Company Services	SERC 1									
	3.	Jim Busbin	Southern Company Services	SERC 1									
	4.	Phil Winston	Southern Company Services	SERC 1									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization			Registered Ballot Body Segment															
					1	2	3	4	5	6	7	8	9	10						
5.	Mike Sanders	Southern Company Services	SERC	1																
6.	Bob Canada	Southern Company Services	SERC	1																
7.	Boyd Nation	Southern Company Services	SERC	1																
8.	Phil Whitmer	Georgia Power Company	SERC	3																
9.	Randy Mayfield	Alabama Power Company	SERC	3																
10.	Randy Castello	Mississippi Power Company	SERC	3																
18.	Group	Jason L. Marshall	Midwest ISO Standards Collaborators			X														
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																
1.	Jim Cyrulewski	JDRJC Associates, LLC	RFC	8																
2.	Kirit Shah	Ameren	SERC	1																
3.	Robert A. Thomasson Sr.	Big Rivers	SERC	1, 3																
19.	Group	Ben Li	IRC Standards Review Committee			X														
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																
1.	Bill Phillips	MISO	MRO	2																
2.	Matt Goldberg	ISO-NE	NPCC	2																

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter		Organization		Registered Ballot Body Segment														
						1	2	3	4	5	6	7	8	9	10					
3.		Charles Yeung	SPP	SPP	2															
4.		Mark Thompson	AESO	WECC	2															
5.		James Castle	NYISO	NPCC	2															
6.		Steve Myers	ERCOT	ERCOT	2															
7.		Greg Van Pelt	CAISO	WECC	2															
8.		Patrick Brown	PJM	RFC	2															
20.	Individual	Brian Pillittere	Tenaska							X										
21.	Individual	Sandra Shaffer	PacifiCorp			X		X		X	X									
22.	Individual	Jana Van Ness, Director Regulatory Compliance	Arizona Public Service Company			X		X		X	X									
23.	Individual	Brent Ingebrigtsen	E.ON U.S. LLC			X		X		X	X									
24.	Individual	Brenda Lyn Truhe	PPL Electric Utilities			X														
25.	Individual	Greg Froehling	Green Country Energy							X										
26.	Individual	TransAlta Centralia Generation, LLC	TransAlta Corporation							X										

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
27.	Individual	Doug Smeall	ATCO Electric Ltd.	X									
28.	Individual	Dan Roethemeyer	Dynegy Inc.					X					
29.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X				
30.	Individual	Philip Savage	PacifiCorp	X		X							
31.	Individual	Brian Reich	Idaho Power Company	X		X							
32.	Individual	Chris Hajovsky	RRI Energy, Inc.					X	X				
33.	Individual	Bill Keagle	BGE	X									
34.	Individual	John Brockhan	CenterPoint Energy	X									
35.	Individual	Joylyn Faust	Consumers Energy			X	X	X					
36.	Individual	Doug White	North Carolina Electric Coops			X	X	X					
37.	Individual	Lauri Jones	Pacific Gas and Electric Company	X		X		X					
38.	Individual	Laurie Williams	PNM Resources	X		X							
39.	Individual	Val Lehner	ATC	X									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
40.	Individual	Martin Bauer	US Bureau of Reclamation					X						
41.	Individual	Wayne Pourciau	Georgia System Operations Corporation			X	X							
42.	Individual	Rex Roehl	Indeck Energy Services					X						
43.	Individual	Jonathan Appelbaum	United Illuminating	X										
44.	Individual	Amir Y Hammad	Constellation Power Generation and Constellation Commodities Group					X	X					
45.	Individual	Carol Bowman	City of Austin dba Austin Energy	X										
46.	Individual	John Bee	Exelon	X		X		X						
47.	Individual	Kirit Shah	Ameren	X		X		X	X					
48.	Individual	Thad Ness	American Electric Power (AEP)	X		X		X	X					
49.	Individual	Joe Knight	Great River Energy	X		X		X	X					
50.	Individual	Greg Rowland	Duke Energy	X		X		X	X					
51.	Individual	Nathan Lovett	Georgia Transmission Corporation	X										



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
52.	Individual	Chris de Graffenried	Consolidated Edison Co. of NY, Inc.	X									
53.	Individual	Kathleen Goodman	ISO New England Inc.		X								
54.	Individual	Amanda Stevenson	E.ON Climate & Renewables					X					
55.	Individual	Christine Hasha	ERCOT ISO		X								
56.	Individual	Terry Harbour	MidAmerican Energy	X									
57.	Individual	Michael Gammon	Kansas City Power & Light	X		X		X	X				
58.	Individual	Ron Gunderson	Nebraska Public Power District	X		X		X					
59.	Individual	Dan Rochester	Independent Electricity System Operator		X								
60.	Individual	Catherine Koch	Puget Sound Energy	X									

**1. Do you agree with the purpose statement of the proposed standard? Please explain in the comment box below.**

**Summary Consideration:** Stakeholders who responded to this question were fairly evenly divided on acceptance of the original purpose statement with about half supporting the purpose and half suggesting revisions to the purpose. A common thread through most of the comments was that the DSR SDT went beyond the intent of the standard (reporting) and concentrated too much on the analysis of the event. Based on these comments, the SDT revised the purpose statement. The new purpose is:

To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.

Several commenters noted that the term, “impact event” is not a formally defined term. The DSR SDT has used a working definition for “impact events” to develop Attachment 1 as follows:

An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.

Many stakeholders indicated that the definition should be added to the NERC Glossary and the DSR SDT adopted this suggestion.

The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard.

Some commenters correctly pointed out that “situational awareness” was a desirable by-product of an effective event reporting system, and not driver of that system. Accordingly, all references to “situational awareness” have been deleted from the standard. The more generic “industry awareness” has been substituted where appropriate.

Many commenters noted that the SDT did not define sabotage. FERC Order 693, paragraph 471 states in part: “. . . the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” The DSR SDT made a conscious, deliberate decision to exclude a strict definition of sabotage from this standard and sought

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

stakeholder feedback on this issue. Some suggested adopting the NRC definition of the term sabotage, and the DSR SDT did consider adopting the NRC definition shown below but determined that the definition is too narrowly focused.

Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.

Most respondents agreed that in order to be labeled as an act of sabotage, the intent of the perpetrators must be known. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This would result in further ambiguity with respect to reporting events, and the timeline associated with the reporting requirements does not lend itself to the in-depth analysis required to identify a disturbance (or potential disturbance) as sabotage. The SDT felt that a likely consequence of having to meet this criterion, in the time allotted, would be an under-reporting of events. Accordingly, all references to sabotage have been deleted from the standard.

Organization	Yes or No	Question 1 Comment
Ameren	No	The purpose talks about reporting impact events and their known causes. We have no problem with this generic intent, but the purpose says nothing about the very burdensome expectation of verbal updates to NERC and Regional Entities (Attachment 1, top of first page), Preliminary Impact Event Reports (Attachment 1, top of first page, are these Attachment 2?), "Actual" Impact Event Reports (Attachment 1 - Part A) and "Potential" Impact Event Reports (Attachment 1 - Part B). These multiple levels of reporting and events need to be greatly reduced.
American Electric Power (AEP)	No	It is unclear what the relationship between this project and the newly revamped NERC Event Analysis Process. We support moving towards one process opposed to separate obligations that may be in conflict.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>In addition, AEP supports the concept of a central clearinghouse such as the RCIS that is shared by the industry. We support fewer punitive requirements and more prompting for using tools to make multiple entities aware of reliability related issues shortly after the fact.</p>
CenterPoint Energy	No	<p>CenterPoint Energy does not agree with the purpose statement of the proposed standard. The directive from the Commission in FERC Order 693 and restated in the Guideline and Technical Basis is "...the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: 1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event." Instead the SDT has introduced another term, impact event, to address concerns regarding different definitions. The term, impact event and its proposed concept is too broad. Specifically the concept that an impact event "...has the potential to impact the reliability of the Bulk Electric System" leaves too much room for an entity and a regulatory body to have a difference of opinion as to whether an event should be reported. Required reporting should be limited to actual events. The reporting to follow could become overwhelming for the Responsible Entities, the ERO, and other various organization and agencies. Furthermore, situational awareness is a term that is associated with aspects of real-time. Given the analysis required before a report can be submitted, the report will not be real-time and will not sustain a purpose of supporting situational awareness. (See also comments on Q10 regarding the "Time to Submit Report".) A purpose that is more aligned with consolidation of the EOP-004 and CIP-001 standards would be as follows: Responsible Entities shall report disturbance events and acts of sabotage to support the reliability of the BES through industry awareness.</p>
Consolidated Edison Co. of NY, Inc.	No	<p>Comments: The purpose is not clear because it uses the term "impact events". This term should be defined in the NERC glossary, and should not include words such as "potential".</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
Duke Energy	No	The Purpose statement says that reporting under this standard supports situational awareness. However this is in conflict with Section 5. Background, where the DSR SDT makes clear that this standard includes no real-time operating notifications, and that this proposed standard deals exclusively with after-the-fact reporting. We also disagree with the stated concept of “impact event”. Including the phrase “or has the potential to impact” in the concept makes it impossibly broad for practical application and compliance.
Electric Market Policy	No	The term “impact events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. As conveyed in Dominion’s comments on NERC Reliability Standards Development Plan 2011 - 2013, Dominion does not see this draft standard as needing to be in the queue while other standards having more impact to bulk electric reliability remain incomplete or unfinished.
ERCOT ISO	No	ERCOT ISO believes that according to the timelines allotted in Attachment 1, it may not be possible for the entity to identify the “known cause” of an event. The requirements list identification of “initial probable cause”. This is more reasonable under the timelines noted in Attachment 1.
Exelon	No	The purpose states that Responsible Entities SHALL report impact events - this implies that ALL impact events need to be reported regardless of magnitude, suggest rewording to say "... shall report applicable impact events ..." to allow for evaluation of each impact for applicability in accordance with Attachment 1).

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
FirstEnergy	No	<p>Since this standard is after-the-fact reporting, the phrase "situational awareness" may not be appropriate since that phrase is attributed by a large part of the industry to real-time, minute-to-minute awareness of the system. We suggest the following rewording of the purpose statement: "To ensure Applicable Entities report impact events and their known causes to enhance and support the reliability of the Bulk Electric System (BES)".</p>
Indeck Energy Services	No	<p>Suggestion: "Functional Entities identified in Section 4 shall support situational awareness of impact events and their known causes."</p>
Independent Electricity System Operator	No	<p>(1) Our understanding of the proposed revision as conveyed in the SAR was to provide clarity and reduce redundancy on reporting the latest and even on-going events on the system that may be caused by system changes and/or sabotage. The intent is to ensure the proper authorities are informed of such events so that they may take appropriate and necessary actions to identify causes and/or mitigate or limit the extent of interruptions. We also supported a suggestion in the SAR to assess the merit of merging CIP-001 and EOP-004 to remove redundancy, although we suggested that this should not be a presumption when revising the standard(s). This posting appears to indicate that only EOP-004 will be revised at this time, and CIP-001 which deals with sabotage reporting will remain in effect. With this assumption, the proposed standard appears to contain a mixture of reporting two types of events of different time frame - the first type being those events that need to be reported soon or immediately after they occur (e.g. impact events that appear to be the result of a sabotage) with an aim to curb/contain these events by the appropriate authorities; the second type being the events that can be reported sometime well after the fact, e.g. system disturbances due to weather or switching or other known causes that are not of malicious nature. Combining the two types of requirement does not appear to be clearly conveyed in the SAR. We therefore suggest the SDT review the main purpose</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>and content in the proposed EOP-004 to ensure consistency with the SAR, and in relation to the purpose and requirements already contained in CIP-004.(2) With respect to disseminating reports and related information after the fact, we wonder if a data collection process, such as RoP 1900, can serve the purpose without having to create a standard or a requirement to achieve this.(3) Most of the requirements appear to be administrative in nature and they stipulate the how but not the what, which in our view does not conform with the Results-based standard concept and does not rise to the level of a reliability standard.(4) A number of requirements proposed in the draft standard are quite vague and cannot be measured. Details of this assessment is provided below.</p>
<p>IRC Standards Review Committee</p>	<p>No</p>	<p>The proposed requirements in the standard are not focused on the core industry concern that current requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, “The existing requirements need to be revised to be more specific - and there needs to be more clarity in what sabotage looks like.” Instead this proposed standard includes requirements that are more focused on “how” to report, rather than “what” to report. The SAR states that: “The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.” The SRC believes the scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seem helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>team seems to be ignored, “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard.</p>
ISO New England Inc.	No	<p>The proposed requirements in the standard are not focused on the core industry concern that current requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, “The existing requirements need to be revised to be more specific - and there needs to be more clarity in what sabotage looks like.” Instead this proposed standard includes requirements that are more focused on “how” to report, rather than “what” to report. The draft 2 SAR has never been balloted for approval prior to standard drafting. In fact, the SAR states, “The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.” The scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seems helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting team seems to be ignored: “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard. The term “impact</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC Glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. This draft standard should not have this high a priority while other standards having a greater impact on Bulk Electric System reliability remain incomplete or unfinished. Regional reporting requirements should be in Regional Standards, and not be included in a NERC Standard.</p>
Manitoba Hydro	No	<p>Though new purpose greatly clarifies the proposed EOP-004-2 and using “situational awareness” is the key to this purpose, further clarification of specific items should be added to the purpose. “Responsible Entities shall report SIGNIFICANT events to support interconnection situational awareness on events that impact the integrity of the Bulk Electric System, such as islanding, generation, transmission and load losses, load shedding, operation errors, IROL/SOL violations, sustained voltage excursions, equipment and protection failures and on suspected or acts of sabotage.”</p>
Nebraska Public Power District	No	<p>The background states there is no real-time reporting requirement in this standard, but the purpose states a purpose is for situational awareness. This implies real-time reporting. The purpose clearly identify the standard is for after the fact reporting to permit analysis of events, trend data, and identify lessons learned.</p>
North Carolina Electric Coops	No	<p>The term “impact event” is not a defined term in the NERC glossary and does not draw a clear boundary or give concise guidance to aid in event recognition.</p>
Northeast Power Coordinating	No	<p>The proposed requirements in the standard are not focused on the core industry concern that current</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
Council		<p>requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, “The existing requirements need to be revised to be more specific - and there needs to be more clarity in what sabotage looks like.” Instead this proposed standard includes requirements that are more focused on “how” to report, rather than “what” to report. The draft 2 SAR has never been balloted for approval prior to standard drafting. In fact, the SAR states, “The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.” The scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seems helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting team seems to be ignored: “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard. The term “impact events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC Glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. This draft standard should not have this high a priority while other standards having a greater impact</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		on Bulk Electric System reliability remain incomplete or unfinished.Regional reporting requirements should be in Regional Standards, and not be included in a NERC Standard.
Pacific Gas and Electric Company	No	PG&E recognizes this is an after the fact report, however, the purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. If the future intent is for this report to replace current reporting criteria the purpose statement should be expanded to reflect the true intent of the Standard.
PNM Resources	No	PNM believes the purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. It is misleading and may have many thinking it is duplicative work.
PSEG Companies	No	The following sentence should be added. "This standard is not intended to be for real-time operations reporting."
RRI Energy, Inc.	No	The purpose does not need to mention "and the reliability of the Bulk Electric System." This is the Congressional mandate in FPA Section 215, and could be attached to every Standard, guide, notice and direction issued by FERC, NERC and Regional Entities. In addition, the purpose references "Responsible Entities." However, section 4 on "Applicability" references "Functional Entities." These terms should be consistent. Therefore, the purpose statement of the proposed standard should be corrected to read, "FunctionalEntities identified in Section 4 shall report impact events and their known causes to support situational awareness."CONSIDERATION: Is the phrase "shall report impact events and their known causes" really a purpose of the Proposed Standard, or is it instead merely a means to achieve the purpose of situational awareness? If the latter, the purpose statement can be further shortened to read, "Functional Entities identified in Section 4 shall support situational awareness of impact events and their known causes."

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 1 Comment
Santee Cooper	No	Since this standard is written to report events after-the-fact and not for a System Operator to perform corrective action, we believe the words situational awareness should be removed from the purpose. Situational Awareness is typically used for real-time operations. Also, any events that require reporting should be clearly defined in Attachment 1 and leave no room for interpretation by an entity.
SERC OC Standards Review Group	No	The term “impact events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator.
United Illuminating	No	UI suggests adding the phrase: and the ERO shall provide quarterly reports; Responsible Entities shall report impact events and their known causes, and the ERO shall provide quarterly reports, to support situational awareness and the reliability of the Bulk Electric System (BES).
US Bureau of Reclamation	No	The purpose is more closely related to the concept that "Responsible Entities shall document and analyze impact events and their known causes and disseminate the impact event documentation to support situational awareness". Not all impact events are to be reported. The analysis of the impact events is what is needed to achieve a lessons learned.
We Energies	No	Impact event needs to be clarified first, and DP references in Attachment 1 clarified. Distribution is not BES.
WECC	No	The purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. It is

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 1 Comment
		misleading and may have many thinking it is duplicative work.
ATC	Yes	ATC agrees with the purpose statement. However, we do not agree with the implied definition of “impact events” as represented in Attachment 1. (See specific comments about what is included in Attachment 1 for the type of events that qualify as an “impact event”.)
Bonneville Power Administration	Yes	Known causes are difficult under 1 hour reporting requirements (Unusual events are even harder to narrow down in 24 hours and may take weeks.) The System Operators and RC’s handle situational awareness and reliability events, this is an extra wide view and learning for reporting only.
Dynergy Inc.	Yes	Statement is broad enough to cover both Standards.
Great River Energy	Yes	Thank you for the clarification of “known causes”, this will allow entities to report what they currently know when submitting an impact report.
MRO's NERC Standards Review Subcommittee	Yes	Thank you for the clarification of “known causes”, this will allow entities to report what they currently know when submitting an impact report.
Puget Sound Energy	Yes	However, further definition of "known causes" would be helpful as sometime the root cause analysis doesn't uncover the actual cause for sometime after the timeframes outlined in Attachment 1.
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
BGE	Yes	
City of Austin dba Austin Energy	Yes	
City of Garland	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
E.ON Climate & Renewables	Yes	
Georgia System Operations Corporation	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Kansas City Power & Light	Yes	
Luminant Energy	Yes	
MidAmerican Energy	Yes	

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
Midwest ISO Standards Collaborators	Yes	
NERC Staff	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Tenaska	Yes	
TransAlta Corporation	Yes	

**2. Do you agree with the applicable entities in the Applicability Section as well as assignment of applicable entities noted in Attachment 1? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question regarding the acceptability of the proposed list of functional entities and the assignment of applicable entities in Attachment 1.

Several respondents replied with their concern that the reporting requirements were redundant. The general sentiment was that unclear responsibility to report a disturbance could trigger a flood of event reports. Attachment 1 has been modified to assign clear responsibility for reporting, for each category of Impact Event. There was some concern expressed that there could be confusion between the reporting requirements in this standard, and those found in CIP-008. The DSR SDT agrees, and Attachment 1 Part B, has been modified to provide the process for the reporting of a Cyber Security Incident.

The DSR SDT had protracted discussions on the applicability of this standard to the LSE. Per the Functional Model the LSE does not own assets and therefore should not be an applicable entity (no equipment that could experience a “disturbance”). However, the Registry Criteria contains language that could imply that the LSE does own assets, or is at least responsible for assets. In addition, the DSR SDT modified Attachment 1 to include reporting of damage or destruction of Critical Cyber Assets per CIP-002. The LSE, as well as the Interchange Authority and Transmission Service Provider are applicable entities under CIP-002 and should be included for Impact Events under EOP-004.

There were several comments that the asset owners (GO/TO) would be less likely than the asset operators (GOP/TOP) to be aware of an impact event. The DSR SDT recognizes that this may be true in some cases, but not all. In order to meet the reliability objectives of this requirement, the applicability for GO/TO will remain as per Attachment 1.

Organization	Yes or No	Question 2 Comment
--------------	-----------	--------------------



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
American Electric Power (AEP)	No	AEP does not agree with the addition of the Generator Owner to the standard. The Generator Owner does not have visibility to the real time operational status of a unit. As a result, the Generator Owner lacks the ability to recognize impact events and report them to the Regional Entity or NERC within the time frames specified in the standard. Reporting requirements for impact events should be the responsibility of the Generator Operator.
Arizona Public Service Company	No	AZPS recommends excluding 4.1.7 Distribution Providers, as Distribution Providers generally operate at levels below 100kV.
ATC	No	The Functional Entities identified in Attachment 1 do not align with the current CIP Standard obligations (e.g. Load Serving Entities are not included).
CenterPoint Energy	No	CenterPoint Energy does not agree with the addition of Transmission Owner and Distribution Provider to the Applicability section. Transmission Owner and Distribution provider are not currently applicable entities for either CIP-001 or EOP-004 and should not be included in the proposed combined standard. However, CenterPoint Energy does agree that LSE should be removed from the Applicability section. CenterPoint Energy appreciates the SDT's efforts in assigning entities to each event in Attachment 1. This is an improvement over the existing EOP-004 standard. It is clear, however, that with multiple entities responsible for reporting each event, there is no need to expand the Applicability Section to include Transmission Owner and Distribution Provider.
Consolidated Edison Co. of NY, Inc.	No	Comments: NERC's role as the Standard enforcement organization for the power industry will be in conflict if NERC is also identified as an applicable entity. What compliance organization will audit NERC's

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
		performance? This is presently not clear.
Constellation Power Generation and Constellation Commodities Group	No	Constellation Power Generation and Constellation Commodities Group disagrees with the inclusion of Generator Owners. Since one of the goals in revising this standard is to streamline impact event reporting obligations, Generator Operators are the appropriate entity to manage event reporting as the entity most aware of events should they arise. At times, the information required to complete a report may warrant input from entities connected to generation, but the operator remains the best entity to fulfill the reporting obligation.
E.ON Climate & Renewables	No	1. Voltage deviation events are too vague for GOP. How does voltage deviations apply to GOP's or specifically renewables i.e., wind farms? 2. Define what an "entity" is. 3. Define what a "generating station" is. 4. Define what a "BES facility" is. 5. Define what a control center is. 6. Renewable energy/generators should be taken into consideration when crafting the events.
E.ON U.S. LLC	No	The proposed standard does not list the Load Serving Entity as an Applicable Entity, but the possible events that the standard addresses are within the scope of the LSE. Some functions of the LSE listed within the Functional Model are addressed in the proposed standard. Existing CIP-001-1a and EOP-004-1 are both applicable to the LSE.
Electric Market Policy	No	Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. Attachment 1 is troublesome. The time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, we believe this subject is more complex than this table reveals and the table needs more clarification. Several of the events require filing a written formal report within one hour. For example, system separation certainly is going to require an “all hands on deck” response to the actual event. We note that the paragraph above the table in attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.</p>
ERCOT ISO	No	<p>ERCOT ISO recommends that the Electric Reliability Organization be removed from the standard. The Electric Reliability Organization should not be responsible for reliability functions and therefore should be excluded from reliability standards.</p>
Exelon	No	<p>Attachment 1, Part B, footnote 1. A GO is unlikely to know if a fuel supply problem would cause a reliability concern because one GO may not know the demand for an entire region. Attachment 1, Part B, footnote 1. What is the definition of an "emergency" related to problems with a fuel supply chain? What time threshold of projected need would constitute a 1 hour report? Attachment 1, Part A - Voltage Deviations - A GOP may not be able to make the determination of a +/- 10% voltage deviation for approximately 15 minutes, this should be a TOP RC function only. Attachment 1, Part A - Generation Loss of approximately 2,000 MW for a GO/GOP does not provide a time threshold. If the 2,000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? Attachment 1, Part A - Damage or destruction of BES equipment o The</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>event criteria is ambiguous and does not provide clear guidance; specifically, the note needs to provide more explicit criteria related to parts (iii) and (iv) to remove the need for interpretation especially since this is a 1 hour reportable occurrence. In addition, determination of the aggregate impact of damage may not be immediately understood - does the 1 hour report time clock start on initiation of event or following confirmation of event?</p> <ul style="list-style-type: none"> <li>o The initiating event needs to explicitly state that it is a physical and not cyber. Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security - Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard.</li> <li>o If the damage or destruction is related to a deliberate act, consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event. Attachment 1, Part B - Loss of off-site power (grid supply) affecting a nuclear generating station - this event classification should be removed from EOP-004. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design and may not result in a loss of generation (i.e., unit trip); furthermore, if a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). The 1 hour notification in EOP-004 on a loss of off-site power (grid supply) to a nuclear generating station should be commensurate with other federal required notifications. Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential transient on the unit.</li> <li>Attachment 1, Part B - Forced intrusion at a BES facility - Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event.</li> <li>Attachment 1, Part B - Risk to BES equipment from a non-environmental physical threat - this event leaves</li> </ul>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		the interpretation of what constitutes a "risk" with the reporting entity. Need more specific criteria for this event. Attachment 1, Part B - Detection of a cyber intrusion to critical cyber assets - Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security - Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard.
FirstEnergy	No	We do not support the ERO as an applicable entity of a reliability standard because they are not a user, owner or operator of the bulk electric system. Any expectation of the ERO should be defined in the Rules of Procedure.
Georgia System Operations Corporation	No	This standard should not apply to distribution systems or Distribution Providers. It should apply only to the BES.
Georgia Transmission Corporation	No	These events generally are Operator Functions and should not apply to a TO.1. Energy Emergency requiring system-wide voltage reduction2. Loss of firm load greater than 15 min.3. Transmission loss (multiple BES transmission elements)4. Damage or destruction to BES equipment ( thru operational error or equipment failure)5. Loss of off-site power affecting a nuclear generating station
Indeck Energy Services	No	---ERO should not be included in this or any other standard! FERC can decide whether NERC is doing a good job without having standards requirements to audit to. If NERC needs to be included in a standard, then it should a stand-alone one so that the RSAW for all of the other audits don't need to include those requirements. ---"Loss of off-site power (grid supply)" is important at control centers and other large generators. The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---"Footnote 1. Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability." is ambiguous. Everything in the

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
		Standards program can "Affecting BES reliability". The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---"Footnote 2. Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES)." is well intentioned but ambiguous. For example, if I know the motivation is to blow up the plant, then by this footnote, I don't have to report. The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---All terms should be used from or added to the Glossary.
Independent Electricity System Operator	No	We do not agree with the inclusion of TO and GO. They are not operating entities and do not need to collect or provide information pertaining to impact events, which are the results and phenomena observe under operating conditions in the operation horizon, and such information collection and provision are the responsibility of the TOP and GOP.
IRC Standards Review Committee	No	Entities that have information about possible sabotage events should report these to NERC after the fact and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an EEA for example?
ISO New England Inc.	No	Having the ERO as an applicable entity raises the issue that they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. NERC has also offered the opinion that since NERC is not a "user, owner, or

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>operator” Standards are not enforceable against the ERO. In Attachment 1 the time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to unnecessary and possibly conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, this subject is more complex than this table reveals, and the table needs more clarification. Entities that have information about possible sabotage events should report these to NERC after the fact, and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, it is likely that there is going to be duplicate reporting. Several of the events require filing a written formal report within one hour. For example, system separation is going to require an “all hands on deck” response to the actual event. The paragraph above the table in Attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements through NERC that cross federal agency jurisdictions.</p>
Luminant Energy	No	<p>Inclusion of both GO and GOP will result in duplicate reporting as both are responsible for reporting resource-related events such as Generation Loss, Fuel Supply Emergencies and Loss of Off-site power (grid supply). Recommend including only the GOP as it is critical that the GOP gather and communicate relevant information to the Reliability Coordinator.</p>
Manitoba Hydro	No	<p>Since this Standard is to support situational awareness, more entities should be included such as Load</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
		Serving Entities (which was removed from EOP-004-1).
MidAmerican Energy	No	While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an energy emergency requiring public appeals?
Midwest ISO Standards Collaborators	No	While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an energy emergency requiring public appeals?
North Carolina Electric Coops	No	There is a conflict between the ERO being listed as an applicable entity and the fact that the ERO is the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that other applicable entities would be required to meet. Attachment 1 has inconsistent time frames listed for similar events. For example, EEA's are either reported within one or 24 hours depending on the nuance. Also, having more than one entity reporting an EEA can lead to conflicting information for the same event. Attachment 1 has the RC and the BA both reporting the same EEA event. Attachment 1 consolidates time frames from other standards for reporting purposes. There should either be a separate standard for "reporting" that encompasses reporting requirements for all standards or leave the time frames and reporting requirements in the original individual standards. Several of the events require filing a written formal report within one hour. For large events like cascading outages or system separation, "all hands on deck" attention will need to be given to the actual event. Although a verbal report would be allowed in certain circumstances, attention to the actual event should take precedence over formal reporting requirements. There is already a



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		DOE requirement to report certain events and no need to develop redundant reporting requirements in the NERC arena when this information is already available at the federal level at other agencies.
Northeast Power Coordinating Council	No	<p>Having the ERO as an applicable entity raises the issue that they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC’s open process. NERC has also offered the opinion that since NERC is not a “user, owner, or operator” Standards are not enforceable against the ERO. In Attachment 1 the time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to unnecessary and possibly conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, this subject is more complex than this table reveals, and the table needs more clarification. Entities that have information about possible sabotage events should report these to NERC after the fact, and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, it is likely that there is going to be duplicate reporting. Several of the events require filing a written formal report within one hour. For example, system separation is going to require an “all hands on deck” response to the actual event. The paragraph above the table in Attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		requirements through NERC that cross federal agency jurisdictions.
Pacific Gas and Electric Company	No	PG&E recognizes the ERO is in R1, however, it does not see where the ERO's applicability is applied in Attachment 1.
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PNM Resources	No	PNM OTS does not see where the ERO's applicability is applied in Attachment 1.
PPL Electric Utilities	No	While we agree with the applicable entities in the Applicability Section of the revised standard, we would like the SDT to reconsider the applicable entities identified on Attachment 1, specifically regarding duplication of reporting e.g. should TO and TOP report?
PPL Supply	No	While we agree with the list of functional entities identified in the Applicability Section, we do not agree with assignment of applicable entities noted in Attachment 1. As the functional entities are identified in Attachment 1, there will likely be duplicate reporting for many impact events. By applying reporting responsibilities to both the Gen Owner and Gen Operator, this will result in duplicate reporting for plants with multiple owners. It also increases the burden on the Gen Operator who is required to report the event to NERC and to other Gen Owners in a timely manner to allow other Gen Owners to meet the NERC reporting timeline. We suggest that the reporting requirements associated with generators be applied to the Gen Operator only.
RRI Energy, Inc.	No	Agree with the "Applicability" section functional categories. Agree with the Attachment 1 lists of "Entity with Reporting Responsibility," with the following exceptions: PART A "Damage or Destruction of BES Equipment" - This item has a footnote 1 listed, but nothing at the bottom of the page for a footnote. Assuming the footnote

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>reference is intended to reference the "Examples" at the bottom of the page, the following concerns exist:(i) "critical asset" - Is this term intended to reference a "Critical Asset" identified pursuant to the CIP-002 risk-based assessment methodology? If so, it should be capitalized. If not, who determines what constitutes a lower case "critical asset"? (ii) "Significantly affects the reliability margin of the system..." - If this is intended to be enforceable, several words need significant clarification and definition, such as "Significantly," "reliability margin," "system" (BES?), "potential," and "emergency action." The combined ambiguity of just two of those phrases would most likely result in a court holding this statement as so vague as to be unenforceable. The combined lack of clarity of all the highlighted words or phrases render this sentence meaningless.(iii) "Damaged or destroyed due to a non-environmental external cause" - "Non-environmental external cause" should be a defined term because, as is the case in item (ii) above, it is vague and subject to broad, random or arbitrary interpretation. Part B provides examples of "non-environmental physical threat" for "Risk to BES equipment." Those examples could be referenced here, or different examples included that are more applicable to the Event.The items highlighted in items (ii) and (iii) above are very similar to the unintended string of CIP-001 violations that Registered Entities experienced in 2007 and 2008 for failing to provide their own definition of "sabotage" under a sabotage reporting standard that failed to provide any guidance to the industry within the standard as to what constituted "sabotage." PART B"Detection of a cyber intrusion to critical cyber assets" - Capitalize "Critical Cyber Asset."</p>
Santee Cooper	No	<p>Standards cannot be applicable to an ERO because they are the compliance enforcement authority, and the ERO is not a user, owner, or operator of the BES. Since we are reporting events that may affect the BES, why does a DP need to be included as an applicable entity for this standard? If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity. If NERC is going</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>to require a separate reporting of events from DOE, then NERC should look at these events closely to determine if any of the defined events should be eliminated or modified from the current DOE form. (For example: Is shedding 100 MW of firm load really a threat to the BES?)Why does Attachment 1 have multiple entities reporting the same event? An RC should not have to report an EEA if the BA is required to report it. This will lead to conflicting reports for the same event.Attachment 1 is just a consolidation of the time frame from other standards. It appears no review was done for consistency of time frames for similar events.</p>
<p>SERC OC Standards Review Group</p>	<p>No</p>	<p>We find it interesting that the ERO is listed as an applicable entity. The ERO can't be an applicable entity because they are the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. NERC seems to be attempting to evade FERC jurisdiction by having a standard that enables it to write new rules that don't pass through the normal standards development process with ultimate approval by FERC.Attachment 1 is troublesome. The time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does an RC have to report an EEA if the BA is going to report it? This will lead to conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, we believe this subject is more complex than this table reveals and the table needs more clarification or it should be eliminated and leave the time frames in the other standards.Several of the events require filing a written formal report within one hour. For example, system separation certainly is going to require an "all hands on deck" response to the actual event. We note that the paragraph above the table in attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements.There is already a DOE requirement to report</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Southern Company - Transmission	No	We find it interesting that the ERO is listed as an applicable entity. The ERO is responsible for multiple requirements in this standard that shapes the ultimate actual rules that the other applicable entities would be required to meet. Can the NERC/ERO be accountable for a feedback loop to the industry? Feedback is preferable but would NERC/ERO self-report a violation to the requirement?
We Energies	No	The need for a DP to be included needs to be clarified. The Purpose points to BES. A DP does not have BES equipment.
WECC	No	The ERO's applicability is not applied in Attachment 1.
Great River Energy	Yes	We believe that it is important for the ERO to provide valuable Lessons learned to our electrical industry, thus enhancing the reliability of the BES.
Kansas City Power & Light	Yes	Consideration should be given to the need for a preliminary impact event report to be filed by the Reliability Coordinator and the Registered Entity. If two reports should be filed, should they both contain the same information.
MRO's NERC Standards Review Subcommittee	Yes	The NSRS believes it is important for the ERO to provide valuable Lessons learned to our electrical industry, thus enhancing the reliability of the BES.
TransAlta Corporation	Yes	Electrical Reliability Organization (ERO) does not appear to be a defined term in the NERC Glossary of Terms on the NERC website. Last updated April 20, 2010.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
US Bureau of Reclamation	Yes	The question is focused on a limited area of Attachment A. There other problematic areas of Attachment 1 will be addressed in subsequent comments.
Ameren	Yes	
ATCO Electric Ltd.	Yes	
BGE	Yes	
Bonneville Power Administration	Yes	
City of Austin dba Austin Energy	Yes	
City of Garland	Yes	
Duke Energy	Yes	
Dynegy Inc.	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Nebraska Public Power District	Yes	
NERC Staff	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 2 Comment
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
Puget Sound Energy	Yes	
Tenaska	Yes	
United Illuminating	Yes	

**3. Do you agree with the requirement R1 and measure M1? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question. There was strong support for a central system for receiving and distributing impact event reports (a/k/a one stop shopping). There was general agreement that NERC was the most likely, logical entity to perform that function. However several respondents expressed their concern that the ERO could not be compelled to do so by a requirement in a Reliability Standard (not a User, Owner or Operator of the BES). In their own comments, NERC did not oppose the concept, but suggested that the more appropriate place to assign this responsibility would be the NERC Rules of Procedure. The DSR SDT concurs. The DSR SDT has removed the requirement from the standard and is proposing to make revisions to the NERC Rules of Procedure as follows:

812. NERC will establish a system to collect impact event reports as established for this section, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. These reports shall be forwarded to the Federal Energy Regulatory Commission for impact events that occur in the United States. This can include state, federal, and provincial organizations. The ERO shall solicit contact information from Registered Entities appropriate governmental, law enforcement and regulatory agencies contact information for distributing reports.

The DSR SDT also believes NERC’s additional concern about what data is applicable is addressed by the revisions to Attachment 1, and the inclusion of the OE-417 as an acceptable interim vehicle.

Organization	Yes or No	Question 3 Comment
WECC		R1 is appropriate for after-the-fact reporting. However, as proposed this standard eliminates all real-time notifications, including the CIP-001-1 R3 notice to appropriate parties in the Interconnection. New requirement R2.6 lists external parties to notify but it does not include the Reliability Coordinator. It is



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		important that the RC be notified of suspected sabotage. The RC's wide-area interconnection view and interaction with BAs may help recognize coordinated sabotage actions. Any "impact event" where sabotage is suspected as the root cause should require additional and real-time notifications.
ATC	No	ATC does not agree with R1 for three reasons:1. The ERO cannot be assigned obligations in NERC Standards. The requirements for the ERO should be addressed by a revision to Section 801 of the Rules of Procedure.2. This is a fill-in-the-blank requirement. The requirement, positioned as R1, does not allow for the obligations to be clearly defined. It refers to R6 which refers to R2 and Attachment 1. A clearer structure to the Standard would be to simply state that the Functional Entities have to meet the reporting obligations documented in Attachment 1 and delete the current R1.
BGE	No	R1 With the definition of "Impact Event", are we eliminating the term "Disturbance Reporting"? If we eliminate disturbance reporting, SDT should remove the reference from the Summary of Concepts and from the title, otherwise further definition on the distinction between the two terms is needed.R1. What is the "system" described here? What type of system is anticipated - electronic, programmatic or can it be better described by using "standard reporting form"?M1. Needs to seek evidence that the "system" was used for receiving reports, as well as distributing them.M1. Examples are more appropriately used in guidance documentation than in the standard. Rationale for R1 - Final statement regarding OE-417 needs to be removed. The ERO will establish the requirement in their "system" if the standard remains as is. The Requirement does not require the responsible entities to send OE-417 to DOE.
CenterPoint Energy	No	The ERO does not need to establish a "system for receiving reports" as the "system for receiving reports" is inherent given the requirements for reporting. The requirement also seems to add redundancy versus eliminating redundancy in the distribution of reports to applicable government, provincial or law enforcement

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		agencies on matters already reported by Responsible Entities. If an event is suspected to be an intentional criminal act, i.e. “sabotage”, the Responsible Entity would have contacted appropriate provincial or law enforcement agencies. The ERO is not in a position to add meaningful value to these reports as any information the ERO may provide is second hand. CenterPoint Energy recommends R1 and M1 be deleted.
City of Garland	No	Reason 1Most of this is duplication of existing processes - More “Big Government” and/or “Overhead” is not needed. There are already processes in place to notify “real time” 24 X 7 organizations that take action (RC, BA, TOP, DOE, FBI, Local Law Enforcement, etc) in response to an “impact event”. It is stated in your document on page five (5) “The proposed standard deals exclusively with after-the -fact reporting.” The combining of CIP 001 & EOP 004 should not expand on existing implemented reporting requirements nor should it result in NERC forming a 24 X 7 department to handle 1 hour (near real time) reporting requirements.Reason 2If this should go forward as drafted, NERC should not establish a “clearing house” for reporting requirements for Registered Entities without also taking legal responsibility for distributing those reports to required entities. It states in at least 2 places (Page 6 & Page 22) in the document that Responsible Entities are ultimately responsible for ensuring that OE-417 is received at the DOE. Thus, a Registered Entity could be penalized for violating this new standard if it did not file the reports with NERC or it could still be penalized (both criminal & civil) if they filed the reports with NERC but NERC (for whatever reason) did not follow through with ensuring the report was properly filed at the DOE.
Consolidated Edison Co. of NY, Inc.	No	See response to Question 2.
Duke Energy	No	The requirement again states the intent is to “enhance and support situational awareness”, which doesn’t sync with “after-the-fact reporting”. We question why NERC needs to create this report and system for

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		<p>distributing impact event reports to various organizations and agencies for after-the-fact reporting, when we are still required to make real-time reports under other standards. For example, the Rational specifically recognizes that this standard won't release us from the DOE's OE-417 reporting requirement. We don't see that this provides value, unless NERC can find a way to eliminate redundancy in reporting.</p>
Electric Market Policy	No	<p>Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of "applicable government, provincial or law enforcement agencies" for distribution as defined in R1. The "rationale for R1" states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. It seems like the better approach would be for the entities to complete OE-417 form and this standard simply require a copy.</p>
ERCOT ISO	No	<p>Recommend that requirements for the Electric Reliability Organization be removed. However, if the requirements are retained, ERCOT ISO recommends the following wording change to be consistent with other standards. "R1. The ERO shall create, implement, and maintain a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness."</p>
Exelon	No	<p>This requirement should include explicit communications to the NRC (if applicable) of any reports including a nuclear generating unit as a jurisdictional agency to ensure notifications to other external agencies are</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		coordinated with the NRC. Depending on the event, a nuclear generator operator (NRC licensee) has specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(2)(xi). In general, the DSR SDT should include discussions with the NRC to ensure communications are coordinated or consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator for consistency.
FirstEnergy	No	FirstEnergy proposes that requirement R1 and Measure M1 be deleted. A requirement assignment to the ERO is problematic and should not appear in a reliability standard. The team should keep in mind that all requirements will require VSL assignments that form the basis of sanctions. FE does not believe it is appropriate for the ERO to be exposed to a compliance violation investigation as the ERO is not a functional entity as envisioned by the Functional Model. If this "after-the-fact" reporting is truly needed for reliability then the standard must be written in a manner that does not obligate the ERO to reliability requirements. It would be acceptable and appropriate for a requirement to reference the "ERO Process" desired by R1, however, that process should be reflected in the Rules of Procedure and not a reliability standard.
Indeck Energy Services	No	This standard is an inappropriate place to define this requirement. NERC needs to be held accountable, but it should be independent of the standard. What if NERC fails to do it by the effective date of the standard, all Registered Entities will violate the standard until NERC is done. The effective date needs to be set based on NERC completing the system defined in R1.
Independent Electricity System Operator	No	R1 does not directly convey the need for reporting. The requirement could be written to require the responsible entities to report impact events to the ERO using a process to be described in the standard and according to a set of reporting criteria. Whether or not there is a "system" makes little difference if it complies with the requirement to provide the reports on time. In addition, an ERO established system which, without

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		being included in the standard and posted for public comment and eventually balloted, may not be acceptable to the entities that are responsible for reporting to the ERO. Further, a reliability standard should not need to bother with how the ERO disseminate this information to applicable government, provincial or law enforcement agencies. This is the obligation of the ERO and if required, can be included in the Rules of Procedure.
ISO New England Inc.	No	Having the ERO as an applicable entity raises a concern because they are also the Compliance Enforcement Authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC’s open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of “applicable government, provincial or law enforcement agencies” for distribution as defined in R1. The “rationale for R1” states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. The better approach would be for the entities to complete OE-417 form and this standard simply require a copy.
MidAmerican Energy	No	
NERC Staff	No	NERC staff is concerned about this requirement’s applicability to the ERO. We feel that such a responsibility needs mentioning in the Rules of Procedure, the Compliance Monitoring and Enforcement Program (CMEP), or in a guideline document rather than in a standard requirement. Further, the requirement specifies “how” to manage the event data, not “what” should be monitored.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
North Carolina Electric Coops	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority.
Northeast Power Coordinating Council	No	Having the ERO as an applicable entity raises a concern because they are also the Compliance Enforcement Authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC’s open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of “applicable government, provincial or law enforcement agencies” for distribution as defined in R1. The “rationale for R1” states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. The better approach would be for the entities to complete OE-417 form and this standard simply require a copy.
Puget Sound Energy	No	The language of R1 and M1 does not support the DSR SDT’s goal of having a single form and system for reporting. The standard should specify the form and system rather than deferring that decision to the ERO. The language of R1 and M1 leaves the form and system to the ERO’s discretion, which could lead to multiple forms and frequent revisions to them. This would lead to difficulties in tracking the reporting requirements. In addition, it is impossible to comment intelligently regarding the overall impact of the proposed standard and its requirements and measures without the reporting form and system being specified in the standard.
Santee Cooper	No	It cannot apply to the ERO.
SERC OC Standards Review	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority. The

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
Group		governance in this situation appears incomplete.
US Bureau of Reclamation	No	This standard should describe the ERO process of event documentation, analysis, and dissemination. Allowing the ERO to develop a event documentation, analysis, and dissemination process, which becomes a requirement on the Entities, must be derived through the Standards Development Process. The requirement, as it is currently worded, allows the ERO to develop standard requirements. If the intent is to only develop a means of collecting, which does not impose a requirement, the wording should state so. Otherwise, if the ERO wants to require that reports are posted to a specific location by the Entity, then it is a requirement and must go through the Standards Development Process. Secondly, there is already a single reporting form identified. It is not clear why the SDT could not accept that form as the reporting tool.
American Electric Power (AEP)	Yes	Overall we support the concepts; however, it is unclear if the ERO can be held accountable for compliance with NERC Requirements. If this requirement is removed there needs to be some mechanism for the ERO to establish a single clearinghouse.
City of Austin dba Austin Energy	Yes	Austin Energy would like to see OE-417 incorporated into the electronic form This will reduce the callout of EOP-004-2 and OE-417 forms in our checklists / documents and one form can be submitted to NERC and DOE.
E.ON Climate & Renewables	Yes	A generic ERCO approved electronic (form that can be submitted on-line) reporting form will help to add more clarity & consistency to the Impact event reporting process.
Georgia System Operations Corporation	Yes	Yes it would reduce duplication of effort and should ensure that the various entities and agencies all have consistent information. It should be simpler and quicker to file than what is needed to meet the current

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		<p>standard. However, the system should allow for partial reporting and hierarchical reporting. Entities up the ladder in a reporting hierarchy may fill in additional info (usually from a wider scope of view) than what lower level entities are aware of. It would be better for information to go up a hierarchy than for bits and pieces to go to the ERO from many entities. Terminology may be different in each of the bits and pieces yet the same idea may be intended. The ERO may mistake multiple reports as being different events when they are all related to one event. The system should give an entity the ability to select the entities that should receive the impact event report. If hierarchical reporting is not enabled by the system, then entities should be allowed to work out a reporting hierarchy as a group and entities at lower levels should not be required to report over the NERC system. Some higher level entity would enter the information on the NERC system as coordinated by the entities within a group.</p>
Idaho Power Company	Yes	the SDT must ensure that only a single form is required for compliance (such example OE-417)
IRC Standards Review Committee	Yes	Note that ERCOT does not sign on to this particular comment.
Kansas City Power & Light	Yes	Although we support situational awareness for the other registered entities, impact event reports should be distributed anonymously to communicate the information while protecting the registered entity.
Manitoba Hydro	Yes	Yes, keeping R1 generic and pointing to “government”, “Provincial”, “law” encompasses all entities in all major interconnections.
PacifiCorp	Yes	All efforts need to be made to include OE-417 reporting requirements to safeguard against duplicate reporting and / or delinquent reporting. One report for all events is more preferable than multiple reports for one event.



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 3 Comment
RRI Energy, Inc.	Yes	While including the phrase "to enhance and support situational awareness" is a good use of the Results-Based Standards development tools and framework, the phrase is already included in the purpose statement. As such, it is unnecessary in Requirement 1. If it were to be included in Requirement 1, then it would also need to be included in each of the other Requirements 2 through 8. The "Purpose" statement captures this aptly.
Southern Company - Transmission	Yes	We do have one concern in that we are hopeful that NERC will develop a system that will allow a one stop shop of reporting.
Avmeren	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
Bonneville Power Administration	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Dynergy Inc.	Yes	
Great River Energy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 3 Comment
Green Country Energy	Yes	
Luminant Energy	Yes	
Midwest ISO Standards Collaborators	Yes	
MRO's NERC Standards Review Subcommittee	Yes	
Nebraska Public Power District	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 3 Comment
Tenaska	Yes	
TransAlta Corporation	Yes	
United Illuminating	Yes	
We Energies	Yes	

**4. Do you agree with the requirement R2 and measure M2? Please explain in the comment box below.**

**Summary Consideration:** Most stakeholders who responded to this question indicated disagreement with Requirement R2 and M2 as originally proposed. There were objections to the use of the term “Operating Plan” to describe the procedure to identify and report the occurrence of a disturbance. The DSR SDT concurs, and Operating plan has been replaced with the generic term “procedure” where appropriate believe that the use of a defined term is appropriate and has revised Requirement 1 to include Operating Plan, Operating Process and Operating Procedure.

R1. Each Responsible Entity shall have an Impact Event Operating Plan that includes [Violation Risk: Factor Medium] [Time Horizon: Long-term Planning]:

- 1.1. An Operating Process for identifying Impact Events listed in Attachment 1.
- 1.2. An Operating Procedure for gathering information for Attachment 2 regarding observed Impact Events listed in Attachment 1.
- 1.3. An Operating Process for communicating recognized Impact Events to the following:
  - 1.3.1. Internal company personnel notification(s).
  - 1.3.2. External organizations to notify to include but not limited to the Responsible Entities’ Reliability Coordinator, NERC, Responsible Entities’ Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.
- 1.4. Provision(s) for updating the Impact Event Operating Plan within 90 days of any change to its content.

Other requirements reference the Operating Plan as appropriate. The requirements of EOP-004 fit precisely into the definition of Operating Plan:

Operating Plan: A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

entities, etc., is an example of an Operating Plan.

Note R2 has been moved to R1 due to elimination of original R1. Many commenters felt that the requirements around updating the Operating Plan were too prescriptive, and impossible to comply with during the time frame allowed. The DSR SDT agrees, and Requirement R2 Parts 2.5 through 2.9 have been eliminated. They have been replaced with Requirement R1, Part 1.4 to update the Operating Plan within 90 days of any change to content.

Organization	Yes or No	Question 4 Comment
Bonneville Power Administration		As long as the 2.4 list is position based, not based on each individual that fills the position. (There is a concern of listing all 2.4 monitoring/reporting personnel in the company that cover the impact event, since there are different function groups and shift work. Documentation trails are difficult with personnel changes.) Because the CIP is being added, it requires an Operating Plan (instead of procedure) with 30 day revision timelines, so it increases the burden for electrical grid event reporting function. R2.9 language refers to R8 “annual” report; however R8 language is “quarterly” reporting of past year. It appears this standard is going to be in an update status 4 times per year, plus any event modifications plus personnel changes. This could be overly burdensome due to the expanding world of cyber security.
Ameren	No	While we agree with the intent to list certain minimum requirements for the Operating Plan, the draft list is too lengthy and prescriptive. This merely creates opportunities for failure to comply rather than the real purpose of reporting data that can be used to meaningfully increase the reliability of the BES by identifying trends of events that may otherwise be ignored.
American Electric Power (AEP)	No	Component 2.2 “Method(s) of assessing cause(s) of impact events” is very vague. Furthermore, there are concerns whether these methods can be accomplished within one hour as might be required per Attachment

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>1, in addition to operating the system. Component 2.6 - need to add the statement “as appropriate for type of impact event” Components 2.7 through 2.9 - are good concepts to consider for future inclusion, but at this point in time these appear to be overreaching objectives. We recommend the SDT take smaller increments towards future progress at measure and reasonable pace. Furthermore, if Component 2.9 is retained it should only pertain to lessons learned on the reporting of impact events not all recommendations regarding remediation of the impact events themselves. Furthermore, the 30 day window to update the Operating Plans is aggressive considering the other priorities that may be present day to day.</p>
ATC	No	<p>The requirement should be rewritten to simply state that the Functional Entities has to meet the reporting obligations documented in Attachment 1. How the Functional Entity meets the obligations documented in Attachment 1 should be determined by the Functional Entity, not the requirement. The prescriptive nature of this requirement does not support the performance-based Standards that the industry and NERC are striving towards. In addition, requirement 2.9 creates an alternate method for NERC to develop Standards outside of the ANSI process. This requirement dictates that Functional Entities are required to incorporate lessons learned from NERC reports into their Plan, which is a requirement of this Standard.</p>
BGE	No	<p>R2.1 Creates the opportunity for differences in identifying impact events. BGE recommends additional clarity in the statement. Are we to use Attachment 1 as a “bright line” or can we use our Operating Plan to identify what an impact event is? R2.4 - 2.6 Does a standard need to specify both internal and external lists? 2.7 - is “component” defined anywhere? Is it a component of the BES or a component of the Operating Plan or a component of the three lists in 2.4 to 2.6? Rationale --- Parts 3.3 and 3.4?? Do you mean 2.3 and 2.4? Is the Operating Plan under scrutiny (mandatory and compensable) for all items in the last paragraph of the rationale?</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
CenterPoint Energy	No	<p>CenterPoint Energy does not agree with R2 and M2 as they are focused on process and procedure. Compliance with a reporting requirement should be based on a complete and accurate report submitted in a timely manner. The process an entity uses to accomplish that task is of no consequence. CenterPoint Energy recommends R2 and M2 be deleted. However, if the SDT feels it is necessary to include this process based requirement, CenterPoint Energy believes the SDT, in requiring an overly prescriptive Operating Plan, has expanded the requirement beyond the current CIP-001-1 and EOP-004-1 which only require "...procedures for the recognition of and for making operating personnel aware..." (CIP-001-1) and "...shall promptly analyze..." (EOP-004-1). Specifically, R2.2 is not found in the current Standards. "Methods for assessing causes(s) of impact events" would vary greatly depending upon the type and severity of the event. Responsible Entities would have a difficult time cataloging these various methods to any specific degree and if they are not specific then CenterPoint Energy questions their value in a documented method. R2.3 is not found in the current Standards and is an unnecessary requirement as the method of notification is irrelevant so long as the notification is made. R2.7, R2.8, and R2.9 are also unnecessary expansions beyond what is currently in CIP-001-1 and EOP-004-1. CIP-001-1 requires the Responsible Entity review its procedures annually and CenterPoint Energy believes this is sufficient. When taken in total, R2 requires seven (7) different processes, provisions, and methods. CenterPoint Energy recommends R2.2, R2.3, R2.7, R2.8 and R2.9 be deleted and believes this will not result in a reliability gap.</p>
City of Garland	No	<p>There are 4 "methods" and 2 "provision" required for this requirement - in other words, 6 "paperwork" items that auditors will audit and likely penalize entities for. On page 1, the statement is made "...proposed standard in accordance with Results-Based Criteria." Having to have 4 methods and 2 provisions to end with a report (all of which is paperwork) is not a "result based" standard. It is like being required to have a "plan to plan on planning on composing and filing a report". Events need to be analyzed, communicated, and reported and</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		should be audited as such (results based) - not audited on whether they have a book filled with methods and provisions.
Consolidated Edison Co. of NY, Inc.	No	<p>Requirement R2</p> <ul style="list-style-type: none"> <li>o Lead-in paragraph - Following the words "Attachment 1" add a period and the words "The Operating Plans shall" and then delete "that" and make "includes" singular.</li> <li>o R2.1, 2.2, 2.3, 2.7 - Replace the word "Method(s)" with the word "Procedure(s)".</li> <li>o 2.6 - After the word "notify" add a period, then insert the words "For example, external organizations may include" and delete the words "to include but not limited to."</li> <li>o 2.8 - After the words "Operating Plan based on" add the word "applicable".</li> </ul> <p>Rational R2 After the words "Every industry participant that owns or operates," add the words "Bulk Electric System." Then delete the words "on the grid."</p>
Constellation Power Generation and Constellation Commodities Group	No	<p>Constellation Power Generation and Constellation Commodities Group has several issues with this requirement, but in general, this requirement is heavily prescriptive, administrative in nature, and is unclear whether it will positively impact BES reliability. As examples of administrative requirements that have no impact on reliability, please consider the following comments:</p> <ul style="list-style-type: none"> <li>o Listing personnel in R2.4, - merely having a list of personnel does not add to the sufficiency of an Operating Plan, but it does create a burdensome obligation to maintain a list. As well, specifying "personnel" may limit plans from designating job titles or other designations that may more appropriately and consistently carry reporting responsibility in the Operating Plan.</li> <li>o R2.5 is unclear as to the intent of the requirement - what is threshold of notification? Is the list to be those that have a role in the event response or a list of all within the facility who may receive news notification of the event? Also, as explained above for 2.4, a list is not a beneficial to reliability, but is administratively burdensome.</li> <li>o What is the reasoning for the 30 day timeframe in R2.7 R2.8 and R2.9? The timeframe is not based on a specific necessity, and creates an unreasonable time frame for changing the Operating Plan, in</li> </ul>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>particular if lessons learned are either short turn adjustments or comprehensive programmatic changes what warrant more time to properly institute. In addition, coupled with other requirements (R4, R5, R8), the updating requirements of R2.7, R2.8 and R2.8 potentially create a continually updating Operating Plan which could create enough confusion to reduce the effectiveness of the Operating Plan. The updating and time frame requirements do not impact reliability, but again impose significant administrative burden and compliance exposure. oR2.9 is particularly problematic for its connection to R8. R8 requires NERC to create quarterly reports with lessons learned and R2.9 requires the registered entities to amend their Operating Plans? What if NERC doesn't write an annual or quarterly report? Are the registered entities out of compliance? The "summary of concepts" for this latest revision, as written by the SDT, includes the following items: oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements oClear criteria for reporting oConsistent reporting timelines oClarity around of who will receive the information and how it will be usedMany of the sub-requirements in R2 do not address any of these items and do not serve to establish a high quality, enforceable and reliability focused standard. Constellation Power Generation therefore recommends that R2 be amended to read as follows:R2. Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 2.1. Method(s) for identifying impact events listed in Attachment 12.2. Method(s) for assessing cause(s) of impact events listed in Attachment 12.3. Method(s) for making internal and external notifications should an impact event listed in Attachment 1 occur. 2.4. Method(s) for updating the Operating Plan.2.5 Method(s) for making operation personnel aware of changes to the Operating Plan.</p>
Consumers Energy	No	R 2.7, R 2.8 and R 2.9 are creating a requirement to have procedures to update procedures. Having updated

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		procedures should be the requirement, no more.
Duke Energy	No	Sections 2.4 and 2.5 should allow identification of responsible positions/job titles rather than specific people. Section 2.9 only allows 30 days for updates to our plan based upon lessons learned coming out of an annual report. 60-90 days would be more appropriate. Also, Section 2.9 says it's an annual report, while R8 only requires quarterly reports.
Dynergy Inc.	No	For 2.7, 2.8, 2.9, 30 days is to stringent. Some changes may not warrant changes until a cumulative amount of changes occur. Suggest making it no later than an annual review.
E.ON Climate & Renewables	No	Administrative burden to some of the components such as 2.5.
Electric Market Policy	No	This is an overly prescriptive requirement given the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan lacks continuity with the ERO Event Analysis Process that is currently slated to begin industry field testing on October 25, 2010. Suggest the SDT coordinate EOP-004-2 efforts with this process.R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate and how will duplicative reporting be addressed (for example, DOE, Nuclear Regulatory Commission)? Also, in the "rationale for R2", please explain the reference to Parts 3.3 and 3.4.
ERCOT ISO	No	ERCOT ISO recommends the use of "Registered Entity" in place of "Applicable Entity". This would provide consistency with other requirements and Attachment 1. Recommend the following changes to the subrequirements. "2.6. List of external organizations to notify to include but not limited to NERC, Regional

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>Entity, relevant entities within the interconnection, Law Enforcement, and Governmental or Provincial Agencies.””2.7. Process for updating the Operating Plan within 30 days of any changes not of an administrative nature. This includes updates to reflect any lessons learned as a result of an exercise or actual event.”Remove requirement 2.8 and move content to requirement 2.7.”2.8. Process for updating the Operating Plan within 30 days of publication the NERC annual report of lessons learned.”Add “2.9. Process to ensure updates are communicated to personnel responsible for under the Operating Plan within 30 days of the change being completed.”</p>
Exelon	No	<p>R.2.4 and 2.5 - should not be required to have a list of internal personnel. If an entity has an Operating Plan that covers internal and external notifications that should be sufficient.R2.2.7, 2.8, 2.9 - R4 requires an annual drill. Updating the plan if required following an annual drill should be sufficientWhy does an entity need to develop a stand alone Operating Plan if there is an existing process to address identification, assessing and reporting certain events?30 day implementation for a component change or lesson learned does not seem reasonable or commensurate with the potential impact to the BES and should not be a required element of EOP-004.What is the communication protocol for lessons learned outside of the annual NERC report? What process will be followed and who will review, evaluate, and disseminate lessons learned that warrant updating the Operating Plan?</p>
FirstEnergy	No	<p>The term Operating Plan(s) is not the appropriate term for this standard. These should be called Reporting Plan(s). Operating Plans are usually designed to be applied during the operating timeframe. Parts 2.2 and 2.6 - We suggest changes to these two subparts as well as a new 2.2.1 and 2.6.1 as follows: 2.2. Method(s) for assessing the initial probable cause(s) of impact events(Add) 2.2.1. Method(s) for assessing the external organizations to be notified.2.6. List of external organizations to notify in accordance with Part 2.2.1. to</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>include but not limited to NERC, Regional Entity, and Governmental Agencies.(Add) 2.6.1. Method(s) for notifying Law Enforcement as determined by Part 2.2.1.Parts 2.4 and 2.6: This should be a list of job titles for ease of maintenance. An entity may choose to use someone in a job position that is a 24 by 7 operation with several personnel that cover that position over the 24 by 7 period. Listing each person by name should not be required as personnel change while the operating responsibility related to the job title can remain constant. We suggest changing the wording to "2.4. List of the job titles of internal company personnel responsible for making initial notification(s) in accordance with Parts 2.5.and 2.6.2.5. List of the job titles of internal company personnel to notify."Part 2.6 - We are under the impression that the phrase "include but not limited to" should not be used according to the NEW SDT guidelines. We suggest changing this to say "List of external organizations to notify that includes at a minimum, NERC, Regional Entity, and Governmental Agencies. (A provincial agency is a governmental agency)."Part 2.7. is overly burdensome. FE suggests the team revise to simply reflect annual updates that should consider component changes and updates from lessons learned. This also permits parts 2.8 and 2.9 to be deleted. FE proposes the following text for Requirement R2.7 "Annual review, not to exceed 15 months between reviews, and update as needed of the Reporting Plan that considers component changes and continuous improvement changes from lessons learned."Parts 2.8 and 2.9 - FE proposes to delete part 2.8 and 2.9. We do not see a need for these changes since the plan must be updated annually and will cover lessons learned.</p>
Great River Energy	No	<p>A. As detailed in R2, the Operating Plan shall contain provisions for "identifying, assessing, and reporting impact events". R2.8, and R2.9 do not have a correlation to R2's Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change. We believe that the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>the components of an entity's Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the words "lessons learned" would be required to be in your Operating Plan. It is solely up to an entity to implement a "Lesson Learned" and not the place for this SDT to require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. B. In R2.8 &amp; R2.9, It may be difficult to implement lessons learned within 30 days. We suggest that lessons learned should be incorporated within 12 calendar months if lessons learned are not deleted from the R2.8 &amp; R2.9.</p>
Green Country Energy	No	<p>Highly administrative version of what could accomplish the same thing. A requirement that the applicable entity shall make appropriate notifications as required by attachment A and B events. I can see the need for review and lessons learned but that needs to be done at a higher level since many entities may be involved in an "event"</p>
Idaho Power Company	No	<p>The SDT needs to clarify Requirement 2.9 references an annual report issued pursuant to requirement R8, however Requirement 8 references a quarterly report. These requirements should have the same time frames.</p>
Indeck Energy Services	No	<p>R2 needs to state that the Operating Plan needs to only those Attachment 1 events applicable to the Registered Entity. The Operating Plan should contain a list of these events so that the other Requirements can reference the Operating Plan and not Attachment 1 for the list of events. For example a GO/GOP &lt;2,000 MW would not need to address this type of event and it wouldn't be listed in its Operating Plan. It would be unnecessarily cumbersome, to describe events which are not covered within the Operating Plan.</p>
Independent Electricity System	No	<p>R2 is not needed. An entity does not need to have an "operating plan" to identify and report on impact events;</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
Operator		it needs only to report on the events listed in Attachment 1 in a form depicted in Attachment 2. How does the entity do this, and whether or not an operating plan is in place, or whether its staff is trained to provide the report should not need to be included in a reliability standard for so long as the responsible entity provides the report in the required form on time. If the responsible entity fails to report the listed events in the depicted format, it will be found non-compliant, and that's it - no more and no less. If the "operating plan" really means an established data collection and reporting procedure, then the requirement should be revised to more clearly convey the intent.
IRC Standards Review Committee	No	The SRC suggests that this is not, in fact, an Operating Plan. At most, it may be a reporting plan or reporting procedure. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure bulk power reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. The Operating Plan requirements as proposed seem only to be suitable for real-time notifications. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Unlike the real-time operating notifications which have relatively short reporting time frames, there is sufficient time for personnel to make appropriate communications within their organizations to make timely after the fact reports under NERC Section 1600 authority. Would it be feasible for NERC to issue a standing requirement for timely after-the-fact reports under NERC Section 1600 authority?
ISO New England Inc.	No	This is an overly prescriptive requirement given that the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan is an unnecessary burden that offers no additional improvements to

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>the reliability of the Bulk Electric System, and this is not, in fact, an Operating Plan. At most, it may be a reporting plan. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure Bulk Electric System reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Stating reporting requirements directly in the standard would produce a more uniform and effective result across the industry, contributing towards a more reliable Bulk Electric System. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate, and how will duplicative reporting be addressed (for example, DOE, Nuclear Regulatory Commission)? Also, in the “rationale for R2”, please explain the reference to Parts 3.3 and 3.4.</p>
Kansas City Power & Light	No	<p>We agree with the rationale for R8 requiring NERC to analyze Impact Events that are reported through R6 and publish a report that includes lessons learned but disagree with R2.9 obligating an entity to update its Operating Plan based on applicable lessons learned from the report. Whether lessons learned are applicable to an entity is subjective. If an update based on lessons learned from an annual NERC report is required, the requirement should clearly state the necessity of the update is determined by the entity and the entity’s Reliability Coordinator or NERC can not make that determination then find the entity in violation of the requirement. In addition, if an update based on lessons learned from a NERC report is required, NERC should publish the year-end report (R8) on approximately the same day annually (i.e. January 31) and allow</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>an entity at least 60 days to analyze the report and incorporate any changes it deems necessary in its Operating Plan. In addition, the language using quarterly and annual as a requirements between R2.9 and R8 is confusing.</p>
MidAmerican Energy	No	<p>R2 and R5 coupled with R8 will drive quarterly updates (in addition to drills, etc) and training to the literally hundreds to thousands of people per company for the proper internal operating personnel and management will actually hurt the development of a culture of compliance by overwhelming personnel with constant plan changes and training. The standards drafting team should remove all 30 day references or provide the technical basis of why revising plans and training to “changes and lessons learned” quarterly all within 30 days is the right use of reliability resources to improve the grid. The addition of the 30 day constraints and new vague criteria in Attachment one such as “damage to a BES element through and external cause” or “transmission loss of multiple BES elements which could mean two or more” is the opposite of clear standards writing or results based standards. We disagree with requiring an Operating Plan for identifying, assessing, and reporting impact events. This is an administrative requirement that has no clear reliability benefit. Furthermore, it is questionable that event reporting even meets the basic definition of an Operating Plan. Per the NERC glossary of terms, Operating Plans contain Operating Procedures or Operating Processes which encompass taking action real-time on the BES not reporting on it. As detailed in R2, the Operating Plan shall contain provisions for “identifying, assessing, and reporting impact events”. R2.8, and R2.9 do not have a correlation to R2’s Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change, the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in the components of an entity’s Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>words “lessons learned” would be required to be in your Operating Plan. It is solely up to an entity to implement a “Lesson Learned” and not the place for this SDT to require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. In R2.8 &amp; R2.9, It may be difficult to implement lessons learned within 30 days. The NSRS recommends to incorporate lessons learned within 12 calendar months if lesson learned are not deleted from the R2.8 &amp; R2.9.</p>
<p>Midwest ISO Standards Collaborators</p>	<p>No</p>	<p>We disagree with requiring an Operating Plan for identifying, assessing, and reporting impact events. This is an administrative requirement that has no clear reliability benefit. Furthermore, it is questionable that event reporting even meets the basic definition of an Operating Plan. Per the NERC glossary of terms, Operating Plans contain Operating Procedures or Operating Processes which encompass taking action real-time on the BES not reporting on it. What is an impact event? It appears that this undefined, ambiguous term was substituted for sabotage which is also undefined and ambiguous. One of the SARs stated goals was to “provide clarity on sabotage events”. This does not provide clarity.</p>
<p>MRO's NERC Standards Review Subcommittee</p>	<p>No</p>	<p>A. As detailed in R2, the Operating Plan shall contain provisions for “identifying, assessing, and reporting impact events”. R2.8, and R2.9 do not have a correlation to R2’s Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change. The NSRS believes the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in the components of an entity’s Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the words “lessons learned” would be required to be in your Operating Plan. It is solely up to an entity to implement a “Lesson Learned” and not the place for this SDT to</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. B. In R2.8 & R2.9, It may be difficult to implement lessons learned within 30 days. The NSRS recommends to incorporate lessons learned within 12 calendar months if lesson learned are not deleted from the R2.8 & R2.9.
North Carolina Electric Coops	No	This requirement dictates details of documentation of after-the-fact reporting of events which cannot impact reliability of the BES and, as such, should not be a reliability standard. The cost and burden of becoming auditably compliant with this requirement can be extreme for small entities.
Northeast Power Coordinating Council	No	This is an overly prescriptive requirement given that the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan is an unnecessary burden that offers no additional improvements to the reliability of the Bulk Electric System, and this is not, in fact, an Operating Plan. At most, it may be a reporting plan. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure Bulk Electric System reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Stating reporting requirements directly in the standard would produce a more uniform and effective result across the industry, contributing towards a more reliable Bulk Electric System. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate, and how will duplicative reporting be addressed (for example, DOE,

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
		Nuclear Regulatory Commission)? Also, in the “rationale for R2”, please explain the reference to Parts 3.3 and 3.4.
Pacific Gas and Electric Company	No	PG&E would like clarification on whether the 30 days, is calendar days or business days.
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
Pepco Holdings, Inc - Affiliates	No	For R 2.7, 2.8 and 2.9, 30 days may be too short a time for large entities with multiple subsidiaries to do the necessary notice and coordination. PHI suggests 90 days.
PNM Resources	No	PNM would like clarification on whether the 30 days, is calendar days or business days.
PPL Electric Utilities	No	While we agree with documenting our process, we feel the use of the defined term Operating Plan is not required and possibly a misuse of the term. We would like to suggest using the term ‘procedure’. Additionally, we would like the SDT to confirm/clarify whether Attachment 1 is a complete list of impact events. Also, please confirm that the Proposed R2.1 language ‘Method(s) for identifying impact events’ means identifying impact event occurrence as opposed to identifying list of impact events. i.e. does R2.1 mean recognize impact event occurrence?
PPL Supply	No	While we agree with concept addressed in R2, we don't agree with use of the defined term Operating Plan. Consider working the requirement as follows: "Each Applicable Entity identified in Attachment 1 shall have a documented process or program that includes the following components:..." Also, please consider changing 2.1 to be"Method(s) for recognizing the occurrence of impact events." The current wording could be

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		interpreted to mean, "create a list of the impact events."
Puget Sound Energy	No	While the concept of an operating plan is reasonable, the requirements for update in sections 2.7, 2.8 and 2.9 will lead to an immense amount of work for the entities subject to the standard. In addition, constant revisions to the operating plan makes it difficult to cement a habit through this procedure. The proposed update schedule does not strike the appropriate balance between the need to respond to lessons learned and the value of plan continuity.
RRI Energy, Inc.	No	1. R2 includes the phrase "for identifying, assessing and reporting," followed by R2.1 which states "identifying," R2.2 which states "assessing" and both R2.3 and R2.6 state "notify" or "making internal and external notifications" (i.e., reporting). The language is unnecessarily redundant. RECOMMENDATION: Reword R2 phrase "for identifying, assessing and reporting," to simply state, "for addressing." 2. Rationale for R2 - The rationale section for R2 references in the third paragraph "Parts 3.3 and 3.4." Was this intended to reference R2.3 and R2.4?
Santee Cooper	No	The words "operating plan" should be removed from the requirement. This standard deals exclusively with after-the-fact reporting. This requirement is also overly prescriptive.
SERC OC Standards Review Group	No	This is an overly prescriptive requirement that dictates details of documentation and, as such, has no place in a reliability standard. NERC needs to trust the RCs to do their jobs; this standard and this requirement in particular seems to be attempting to codify the actions that an RC would take in response to an event. The cost and burden of becoming auditably compliant with this requirement is extreme and unrealistic, especially on small entities

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
Southern Company - Transmission	No	The Operating Plan has a different connotation for different operations folks. We suggest that we call it an Impact Event Reporting Plan.
Tenaska	No	We have adequate compliance procedures already in place for the existing CIP-001-1 and EOP-004-1 Standards. The list of required "Operating Plan" components in the proposed R2 is too specific. Maintaining the "Operating Plan" described in R2 would increase the burden on Registered Entities to comply with the Standard and this type of "laundry list" Requirement would make it more difficult to prove compliance with EOP-004-2 during an audit.
United Illuminating	No	R2.9 requires provisions to update the Operating Plan based on the annual ERO report developed in R8. The ERO report does not appear to be providing lessons learned to be applied to the Operating Plan for impact event reporting, but more focused on trends and threats to the BES. Also 30 days after the report is published by NERC is not enough time for the entity to read, and assess the report, and then to administratively update the Operating Plan. UI agrees that the Operating Plan should be reviewed annually and updated subsequent to the review within 30 days.
US Bureau of Reclamation	No	R2 does not reconcile with Attachment A or the sub paragraphs. As an example, the requirement 2.6 states "List of organizations to notify ...." All sub paragraphs use the term notify. Notify as used in Attachment A is when a report cannot be provided in the time frame listed in Attachment A. Therefore there is no requirement in this standard for the Operating Plan to have a provision for reporting. The subparagraph 2.8 indicates that the Entity must update it plan based on the lessons learned published by NERC. It would be appropriate to require a review and update of the plan based on the lessons learned.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
We Energies	No	R2.3, R2.4: "Part" is not a defined term or used in the NERC Standard Process Manual.R2: Attachments are not mentioned in the NERC Standard Process Manual. Is this a mandatory or informational part of the standard?R2.6 (and possibly R2.5): There does not seem to be discretion in notifications. Are all people or organizations on the notify lists always contacted for every impact event? Even Law Enforcement?R2.7: What is a "component? A Plan component? A BES component?R2.9: There is no annual NERC report issued pursuant to R8. R8 requires quarterly reporting.
WECC	No	Need clarification on whether the 30 days is calendar days or business days. As noted in the comment to question 3, any impact event where sabotage is suspected should be treated differently from those where sabotage is not suspected.
Arizona Public Service Company	Yes	AZPS agrees with R2, however, the use of the term "Operating Plan" is confusing. A more accurate term would be "Event Reporting Plan."
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Georgia System Operations Corporation	Yes	An entity-developed Operating Plan will allow the flexibility needed to address different entity relationships around the country, e.g., generating companies, cooperatives, munis, large IOUs, small IOUs, RTOs/ISOs, non-independent market area, and so on.However, all applicable entities should not be required to report directly to NERC or the region. The system should allow for partial reporting and hierarchical reporting. Entities within an area should be allowed to coordinate their plans to define reporting procedures within their area. They could have an entity at some wide scope top level that reports to NERC and the region the

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
		information collected from multiple narrow scope lower levels within their wide area. If every small lower level entity directly reported to NERC and the Region, it could create situational confusion rather than situation awareness.
Manitoba Hydro	Yes	R2 - 2.1 to 2.9 detail what is expected of an Operating Plan for Impact Events. The attachment 1 details the event, the threshold parameters and time line. Though the threshold parameters in the attachment may be questioned, this greatly clarifies the expectations of reporting events. Further events should be added to this list: "Detection of suspected or actual or acts or threats of physical sabotage"
Luminant Energy	Yes	
Nebraska Public Power District	Yes	
NERC Staff	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
TransAlta Corporation	Yes	

5. Do you agree with the requirement R3 and measure M3? Please explain in the comment box below.

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question. Requirement R3 has been re-written to exclude the requirement to “assess the initial probable cause”. The only remaining reference to “cause” is in the Impact Event Reporting Form (Attachment 2). Here, there is no longer a requirement to assess the probable cause. The probable cause only needs to be identified, and only if it is known at the time of the submittal of the report.

Organization	Yes or No	Question 5 Comment
Ameren	No	There are too many missing details on how this will be accomplished. As stated before, this Draft requires too much time be invested in verbal reports, "Preliminary" reports, "Final" reports and even "Confidential" reports (Attachment 2). If the goal is to report ASAP details on events which could impact BES reliability, all of these reports will need to be made at the worst possible time - when Operators are trying to collect data, analyze what they find and correct major problems on the system. And if the reports are wrong or not issued fast enough, the Operators will be keenly aware of potential fines and violations.
American Electric Power (AEP)	No	Not clear how this is different from R6 since it relies on the same timetable in Attachment 1.
ATC	No	ATC believes that this requirement should be deleted and that the SDT should coordinate its goal with the EAWG. We believe that the lessons learned process and identification of root cause is better covered under that process than through the NERC Mandatory Standards.
BGE	No	R3. Limits responsibility to Attachment 1 events only and mandates that an “initial probable cause” be identified. Are we at liberty to define “initial probable cause” and define time period for completion in the Operating Plan? BGE believes this could cause wide difference between Operating Plans and the standard



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		should be more prescriptive by relating to a time-table for the life of an impact event, including expected identification time, initial assessment time and analysis time leading to the reporting deadlines. BGE recommends not including examples of evidence in a measure but include it in a Guideline. Including in a measure will be translated as a requirement by an auditor.
CenterPoint Energy	No	CenterPoint Energy does not agree with R3 and M3 as written as the Company does not agree with the requirement to have an Operating Plan (see comments to Q4 above). However, if R2 and M2 were to be deleted, and R3 was revised to read; "Each Applicable Entity shall identify and assess initial probable cause of events listed in Attachment 1.", CenterPoint Energy could agree with this requirement.
City of Garland	No	Should be part of R2 or R6 - this is unnecessary duplication
Constellation Power Generation and Constellation Commodities Group	No	This requirement introduces double jeopardy for registered entities. If an entity does not include methods for identifying impact events and for assessing cause per R2.1 and R2.2 in their Operating Plan, they will be out of compliance with R2. Without the methods in R2 the registered entity is out of compliance with R3 as well for failing to identify and assess. Constellation Power Generation therefore recommends that R3 be amended to be incremental to R2 and read as follows: R3. Each Applicable Entity shall implement their Operating Plan(s) to identify and assess cause of impact events listed in Attachment 1.
Electric Market Policy	No	We think "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build audit ready compliant procedures.
ERCOT ISO	No	ERCOT ISO recommends the use of "Registered Entity" in place of "Applicable Entity". This would provide consistency with other requirements and Attachment 1. The measure for this requirement notes the obligation

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		for “documentation”. This is not addressed in the requirement. The measure also notes “on its Facilities”. This clarification of scope should be addressed in the requirement. R3. Each Registered Entity shall identify, assess, and document initial probable cause of impact events on its Facilities listed in Attachment 1.
Exelon	No	: Agree that Each Applicable Entity shall identify and assess initial probable cause of impact events; disagree with aspects and time requirements in Attachment 1.
FirstEnergy	No	M3 - Power flow analysis would be used to assess the impact of the event on the BES, not to determine initial probable cause. It is more likely that DME would provide the data for the initial probable cause evaluation. We suggest rewording M3 as follows: "To the extent that an Applicable Entity has an impact event on its Facilities, the Applicable Entity shall provide documentation of its assessment or analysis. Such evidence could include, but is not limited to, operator logs, voice recordings, or disturbance monitoring equipment reports. (R3)"
Green Country Energy	No	Actually yes and no... An event may be caused, analyzed and corrected by one entity but most likely it will involve more. Low Voltage or frequency may not be caused by a generator but the generator will see the event and to have the generator assess the probable cause seems inappropriate. I can see reporting the event and duration and making notifications.
Indeck Energy Services	No	R3 should reference the events covered by the Operating Plan, as listed in it, rather than in Attachment 1. If the Plan is deficient, it is a violation of R2 and not every other Requirement that references the Plan.
Independent Electricity System Operator	No	We agree that the responsible entity needs to identify and assess initial probable cause of impact events but not in accordance with any operating plan in R2. Each operating entity (RC, BA, TOP) has an inherent responsibility to identify the cause of any system events to ensure it complies with a number of related

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		operational standards. R3, in fact, could be revised to require the Responsible Entity to include the probable cause of impact events in its report, rather than asking it to “identify and assess” since this is not measurable. Also, the ERO may be removed from the Applicability Section depending on the response to our comments under Q9.
IRC Standards Review Committee	No	Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes quite some time for an actual cause to be determined. The determination process may require a root cause analysis of some complexity. Further, in the case of suspected or potential sabotage, the industry can only say it doesn’t know, but it may be possible. It really is the law enforcement agencies who make the determination of whether sabotage is involved and the info may not be made available until an investigation is completed, if indeed it is ever made available.
ISO New England Inc.	No	We think “impact event” needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditable compliance procedures. Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes a considerable amount of time for an actual cause to be determined. The determination process may require a complex root cause analysis. Further, in the case of suspected or potential sabotage, the industry can only say it doesn’t know, but it may be possible. Law enforcement agencies make the determination of whether sabotage is involved, and the information may not be made available until an investigation is completed, if indeed it is ever made available.
Kansas City Power & Light	No	We believe R3 and M3 are unnecessary as a stand alone requirement and measure and propose combining this requirement and measure with R6 and M6. Identifying and assessing the initial probable cause of an

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		impact event is the obvious starting point in the reporting process and ultimate completion of the required report. Evidence to support the identification and assessment of the impact event and evidence to support the completion and submittal of the report are really one in the same.
Manitoba Hydro	No	Though each local entity should identify and assess initial probable cause of impact events as per their Operating Plan, the creation of this Operating Plan could be labor intensive and also guidelines for consistency within an RC region should be created. So “NO” is entered simply because a large time line would be needed to properly and efficiently implement R3 and R4.
MidAmerican Energy	No	
Midwest ISO Standards Collaborators	No	While we agree that it makes sense to report on the cause of an event, we disagree with the need for an Operating Plan as identified in R2.
North Carolina Electric Coops	No	The term “impact event” needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditably compliant procedures and give guidance on what is proper to report.
Northeast Power Coordinating Council	No	"Impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditable compliance procedures. Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes a considerable amount of time for an actual cause to be determined. The determination process may require a complex root cause analysis. Further, in the case of suspected or potential sabotage, the industry can only say it doesn't know, but it may be possible. Law enforcement agencies make the determination of whether sabotage is involved, and the information may not be made

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 5 Comment
		available until an investigation is completed, if indeed it is ever made available.
Pacific Northwest Small Public Power Utility Comment Group	No	Comments: When applying R3 to row 11 of attachment 1, the comment group notes that applicable entities are expected to assess probable cause of BES equipment damage, including that which may be the result of criminal behavior. At best this would needlessly duplicate the efforts of law enforcement. A more likely result is that entity involvement would interfere with law enforcement and ultimately hinder prosecution of those responsible. Also See #15
PPL Electric Utilities	No	We believe the rationale for R3 is good and provides value. However, we feel the clarity was lost when the rationale was translated to the standards language. Please consider revising language to refocus on rationale of assess and report per Attachment 1 as opposed to identify. We suggest changing the word "identify" to "recognize" and add the Rationale statement to the requirement as follows: "Each Applicable Entity shall assess the causes of the reportable event and gather available information to the complete the report."
PPL Supply	No	Please consider changing the word "identify" to "recognize" and adding the Rationale statement to the requirement as follows: "Each Applicable Entity shall assess the causes of the reportable event and gather available information to complete the report."
RRI Energy, Inc.	No	"Identify and assess" - Auditors are as much in need of clearly worded, unambiguous Reliability Standards are as Registered Entities. This phrase leaves much too wide a range of interpretations, almost guaranteeing regular and frequent disagreements during an audit between Registered Entity and Regional Entity auditor as to what constitutes "identify and assess" sufficient to meet the intent of this Requirement. Compounding this issue is the Rationale for R3 that states an Applicable Entity (which should probably read "applicable

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 5 Comment
		<p>Functional Entity") should "gather enough information to complete the report that is required to be filed." While Rationale statements are not technically part of the standard, this emphasizes the current wording of the requirement as subject to random and arbitrary interpretation by auditors and Registered Entities. RECOMMENDATION: Change "identify and assess" to "document," so that the Requirement now reads "Each Applicable Entity shall document initial probable cause of impact events..." including an option for "cause not determined".</p>
Santee Cooper	No	<p>Does the initial probable cause have to be reported within the timing associated in Attachment 1? Entities may not have enough information that soon to report the initial probable cause. This should be done with events analysis.</p>
SERC OC Standards Review Group	No	<p>We think "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditably compliant procedures.</p>
Tenaska	No	<p>The probable cause of a reportable event is already required to be submitted on the OE-417 form. This Requirement is redundant.</p>
TransAlta Corporation	No	<p>Clarity required Does an entity have to report on the cause of every "applicable" impact event they witness even though the event did not originate at their plant, system or region and did not adversely affect them? Essentially this would require every entity that witnessed an "applicable" event to report on its cause. In most cases they will not know the cause if they did not create the event. Measure M3 should reference Attachment 1 to indicate the Time to Submit Report'.</p>
We Energies	No	<p>A DP may not have Facilities (a BES element). See NERC Glossary definition of Facility.</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
Bonneville Power Administration	Yes	Known causes are difficult under 1 hour reporting requirements. (Unusual events are even harder to narrow down in 24 hours and may take weeks.)
Consolidated Edison Co. of NY, Inc.	Yes	We agree, however, the term “impact event” must be part of the NERC glossary.
Georgia System Operations Corporation	Yes	It directly supports the purpose of the standard.
Great River Energy	Yes	While we agree that it makes sense to report on the cause of an event, we disagree with the need for an Operating Plan as identified in R2
MRO's NERC Standards Review Subcommittee	Yes	The NSRS thanks the SDT for stating “initial probable cause” as this is in direct correlation to the Purpose which states “known causes”.
Puget Sound Energy	Yes	However, this requirement doesn't address the timing required for this analysis. This may be intentional and appreciated because at times the analysis can take months when the events are complex in nature.
US Bureau of Reclamation	Yes	This is provided that the report submitted in Attachment A does not include the probable cause. It is highly unlikely that a probable cause may be determined within the reporting timelines.
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
City of Austin dba Austin Energy	Yes	
Duke Energy	Yes	
Dynergy Inc.	Yes	
Idaho Power Company	Yes	
Luminant Energy	Yes	
NERC Staff	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
Southern Company - Transmission	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 5 Comment
United Illuminating	Yes	
WECC	Yes	

**6. Do you agree with the requirement R4 and measure M4? Please explain in the comment box below.**

**Summary Consideration:** Note R4 has been moved to R3 due to rearranging of requirements. The DSR SDT did a full review based on comments that were received. R3 now is stream lined to read:

R3. Each Responsible Entity shall conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 months between such tests. The testing of the procedure (as stated in R1) is the main component of this requirement. Several commenters provided input that too much “how” was previously within R3 and the DSR DST should only provide the “what”. The DSR SDT did not provide any prescriptive guidance on how to accomplish the required verification within the rewrite. Testing of the entity’s Operating Process (R1) could be by an actual exercise of the process (testing as stated in FERC Order 693 section 471), a formal review process or real time implementation of the process. The DSR SDT reviewed Order 693 and section 465 directs that processes “verify that they achieve the desired result”. This is the basis of R3, above.

Organization	Yes or No	Question 6 Comment
Ameren	No	Establishing a program with trigger actions expected to require reporting several times a year, combined with adequate initial, and on-going, training should preclude the need for mandatory drills as an added compliance burden.
ATC	No	We do not believe that a drill that exercises a written reporting obligation will add additional reliability to the BES.
BGE	No	M4. BGE recommends not including examples of evidence in a measure but include it in a Guideline. Including in a measure will be translated as a requirement by an auditor.Rationale for R4: If multiple

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 6 Comment
		exercises are performed are all of them subject to the sub-R2 requirements and to audit/audit findings?
Bonneville Power Administration	No	There was no drill required for CIP-001 (a drill was in CIP-008, but the purpose did not list combining CIP-008). A drill is not needed for reporting Electrical Grid events, designate it as excluded in the intent of the requirement.
CenterPoint Energy	No	CenterPoint Energy does not agree with R4 and M4. See comments to Q4 above. In addition to the process vs. results based issue stated above, CenterPoint Energy believes conducting a drill to verify recognition, analysis, and reporting procedures is a waste of valuable resources and time.
City of Garland	No	Existing CIP 001 and EOP 004 are reporting standards - neither currently requires annual drills or exercises. Combining these two (2) should not entail expanding the requirements to include drills or exercises. There are existing drills / exercises that must be performed annually for compliance with CIP 008 & CIP 009 which require the same basic identifying, assessing, developing lessons learned, responding, and reporting skill sets. Requiring additional drills or exercises for this new combined standard will provide additional “business overhead” that results in basically nothing that is not obtained by the CIP 008 / 009 drills as far as securing or making the BES reliable. It does, however, result in additional audit risk at audit time.
Constellation Power Generation and Constellation Commodities Group	No	It is not clear how this requirement to conduct drills and exercises relates to the concepts spelled out by the SDT: a single form to report disturbances and impact events that threaten the reliability of the bulk electric system. Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements. Clear criteria for reporting. Consistent reporting timelines. Clarity around of who will receive the information and how it will be used. R4 does not address any of the above items and should therefore be removed from this standard.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 6 Comment
Consumers Energy	No	NERC should either standardize on a 12 month year or an annual year for reviews.
Dynergy Inc.	No	What is the basis for the drill being annual. This is too stringent. I suggest it be every 3 years.
Electric Market Policy	No	The need for a periodic drill has not been established and appears to be overly restrictive given the intent of the standard is reporting of impact events. Suggest this requirement be eliminated.
ERCOT ISO	No	ERCOT ISO believes that a drill or exercise of its Operating Plan is unnecessary. The intent of the drill can be addressed within the training requirements under R5.
Exelon	No	If drills remain as a component of the standard, an effort to consolidate updating an entities plan with a requirement to drill the plan should be made. . Each entity/utility should be able to dictate/determine if they need a drill for a particular event. Is this document implying a drill for every type of event?
FirstEnergy	No	FE suggests that this requirement be deleted. FE does not see a reliability need for conducting a drill on reporting. This is overly burdensome and should not be included within this reliability standard. Training on the plan and periodic reminder of reporting obligations should suffice.
Great River Energy	No	We disagree with the need to conduct a drill for reporting
Green Country Energy	No	Another training requirement with what benefit? We must train on all of our NERC requirements now anyway to insure compliance and that's not a requirement, that's implied and I think that's enough.
Indeck Energy Services	No	In M4, it is suggested that data from a real event would be evidence. R4 should be satisfied if the Operating

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 6 Comment
		Plan is used for a real event within 15 months of the last drill or event.
Independent Electricity System Operator	No	Along the line of our comments on R2 for an operating plan (whose need we do not agree with), a drill, exercise, or Real-time implementation of the Operating Plan for reporting is also not necessary.
IRC Standards Review Committee	No	Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are really training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in a short time frame as may be required for real-time operating notifications.
ISO New England Inc.	No	The need for a periodic drill has not been established, and appears to be overly restrictive given the intent of the standard is the reporting of impact events. Suggest this requirement be eliminated. Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in as short a time frame as may be required for real-time operating conditions notifications.
Kansas City Power & Light	No	We believe R4 and M4 are clearly unnecessary. Thoughtful preparation of an Operating Plan per R2 that specifically addresses personnel responsibilities and appropriate evidence gathering combined with the training requirement in R5 is sufficient.
Luminant Energy	No	We support the requirements outlined in R2 which create significant obligations to maintain and update the required Operating Plan. However, we believe annual drilling for a reporting process seems unnecessary, particularly given the response horizon of 24 hours for the majority of impact events. If drilling is required, the

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 6 Comment
		standard should allow actual events to fulfill a drilling requirement as stated in the Rationale for R4 and within the text of M4.
Manitoba Hydro	No	Drills and exercise for implementation of the Operating Plan are important and critical, but as in question 5, or Requirement R3, careful and detailed creation of the Operating Plan are crucial to facilitate proper training, drills and exercises. So “NO” is entered simply because a large time line would be needed to properly and efficiently implement R4 and R3.
MidAmerican Energy	No	
Midwest ISO Standards Collaborators	No	We disagree with the need to conduct a drill for reporting.
North Carolina Electric Coops	No	Requiring a drill for “reporting” is unnecessary and burdensome. Reporting is covered in processes and procedures and during the normal training cycle. We recommend the elimination of this requirement.
Northeast Power Coordinating Council	No	The need for a periodic drill has not been established, and appears to be overly restrictive given the intent of the standard is the reporting of impact events. Suggest this requirement be eliminated. Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in as short a time frame as may be required for real-time operating conditions notifications.
Pacific Gas and Electric	No	PG&E believes the addition of a drill constitutes additional training and should be added to R5. PG&E is

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 6 Comment
Company		concerned as to who the target audience for this annual training would affect.
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PNM Resources	No	PNM feels the addition of a drill or exercise constitutes additional training and believes R4 should be added to R5. The WECC OTS also is interested as to what level does the annual training target, for instance, the field personnel. Will they have to complete the exercise/drill?
RRI Energy, Inc.	No	Every employee in a Registered Entity might potentially have exposure to an impact event, and therefore result in a list of thousands of employees subject to the EOP-004-2 Operating Plan. Does this mean, for example, an applicable Functional Entity with 3,000 employees, each capable of potentially observing an impact event, must include them in the drill, exercise, or Real-Time implementation? Such an expectation would require a hypothetical email notice to be sent to 3,000 employees, advising them "This is a test - You observe a suspicious vehicle driving around the fence of your power plant. Perform the next action you should take." The result in this hypothetical might be 3,000 phone calls and emails to the responsible employee in the applicable Functional Entity, each needing to be documented and retained for the audit period. As stated above in question 5, auditors need guidance as much as Registered Entities. Otherwise, it is observed that they will seek the most stringent approach they observe from the best of the best practices over the first year of implementation and apply that expectation as the base-case, under which all other approaches will be deemed violations.
Santee Cooper	No	There is no need to drill for administrative reporting! This requirement should be deleted.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 6 Comment
SERC OC Standards Review Group	No	We think this requirement is unclear - we think it requires a drill for "reporting", which seems absurd! We recommend the elimination of this requirement.
Tenaska	No	This Requirement is too specific and places additional burdens on Registered Entities.
US Bureau of Reclamation	No	There is no rationale offered on why 15 months was selected. Without a defined basis the time period is arbitrary. It would be appropriate to let the Entity determine and document the time interval. That would allow the time frame to be sensitive to the complexity of the Operating Plan. Some entities are geographically dispersed and a single Operating Plan may be difficult to test at one time or within 15 months. The allowance for real time events or actual use is a good move and may make it easier to define a suitable time frame by the Entity.
WECC	No	The addition of a drill or exercise constitutes additional training and believes R4 should be added to R5. Clarification is needed as to what level does the annual training target, for instance, the field personnel. Will they have to complete the exercise/drill?
American Electric Power (AEP)	Yes	
Arizona Public Service Company	Yes	AZPS agrees with R4, however, the use of the term "Operating Plan" is confusing and leads one to believe an Operating Drill is necessary for a "reporting plan drill." A more accurate term to use would be "Event Reporting Plan."
Georgia System Operations Corporation	Yes	We agree with R4 with "... at least annually, with no more than 15 months ..." replaced with "... at least once per calendar year, with no more than 15 months ..." as in R5.



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 6 Comment
MRO's NERC Standards Review Subcommittee	Yes	The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be exercised once per calendar year.
United Illuminating	Yes	Suggest R4 be improved to state that a Registered Entity is only required to conduct a drill or execute real-time implementation of the Operating Pan for one impact event listed in the attachment. In other words the Registered Entity is not required to drill on reporting each type of impact event on an annual basis.
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Duke Energy	Yes	
Idaho Power Company	Yes	
NERC Staff	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 6 Comment
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Puget Sound Energy	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
We Energies	Yes	

**7. Do you agree with the requirement R5 and measure M5? Please explain in the comment box below.**

**Summary Consideration:** Most stakeholders who responded to this question indicated disagreement with the originally proposed Requirement R5 and Measure M5. (Note R5 has been moved to R4 in the revised standard. ) The DSR SDT did a full review based on comments that were received. The major issues that were provided by commenters was R5.3 and R5.4 and their contents. Upon detailed review the DSR SDT agrees with the majority of comments received with R5.3 and R5.4 and have removed them completely from the Standard. Training is still the main theme of this requirement as it pertains to the personnel in the procedure (R1). R4 now is stream lined to read:

R4. Each Responsible Entity shall review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan at least annually with no more than 15 calendar months between review sessions

Organization	Yes or No	Question 7 Comment
Green Country Energy		Same as my comment for question 6
Arizona Public Service Company	No	AZPS believes the required training is too restrictive for minor changes/edits to the Event Reporting Plan.
ATC	No	ATC believes it is an inherent obligation of all Functional Entities to train their appropriate staff to meet all applicable NERC Standards. Including a training requirement in some, but not all, Standards implies that the other Standards do not necessitate training. Although this is an important Standard and one that should be included in a Functional Entities' training program, ATC does not believe that this Standard is more important than the other NERC Standards and, therefore, requires a separate training provision
ATCO Electric Ltd.	No	R5.3 requires an entity to conduct training within 30 days of a revision to the Operating Plan. For an entity

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		that covers a wide area, 30 days may not be sufficient to reach all employees.
BGE	No	Suggested revision to clarify R5:Each Applicable Entity shall provide training to all internal personnel identified in its Operating Plan on the Operating Plan annually. Training is only on Reporting, pursuant to R2, not on the Operating Plan?BGE does not believe the SDT needs to identify sub bullets on this requirement. R5.1 is not logical --- what does it mean?
CenterPoint Energy	No	CenterPoint Energy believes that R5 and M5 are not necessary and should be deleted. CenterPoint Energy supports an entity training its staff in any reporting responsibilities; however, such training should be the responsibility of each entity and such requirements do not belong in a NERC standard. In addition, CenterPoint Energy believes any necessary training requirements are covered in the PER Standards and therefore the addition of this requirement adds redundancy to the Standards.If a majority of the industry supports such a requirement, CenterPoint Energy cannot support R5 and M5 as written as we do not agree with the requirement to develop and maintain an Operating Plan (see comments to Q4 above). CenterPoint Energy offers the following alternate language: “Each Applicable Entity shall provide training concerning reporting requirements contained in this Standard to internal personnel involved in the recognition or analysis of events listed in Attachment 1.
City of Garland	No	This expands beyond the original CIP 001 and EOP 004 - neither explicitly requires training - combining does not mean expanding. In reality, what practical skill are you going to train on? People who perform the analysis on an event are going to have job specific training external to this standard and those same folks will maintain their skill set external to this standard. If it is going to be a results based criteria standard, then let the entities be responsible. Training on methods to fill out and file paper work does not make the BES more reliable. The vast majority of other standards do not have a training requirement section and yet, entities manage to be

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		compliant with those standards. Compared to all the other reliability standards and their requirements, are penalties for training on filling out paper work really making the BES more secure and reliable?
Consolidated Edison Co. of NY, Inc.	No	Requirement 5 - Training should be targeted only at those responsible for implementing the Operating Plan (OP), not all those mentioned in the OP.R5 - After the words "internal personnel" add the words "responsible for implementing." The delete the words "identified in" and "for reporting pursuant to Requirement R2."5.4 - Following the words "For internal personnel" add the words "responsible for implementing the Operation Plan." Between the words "revised responsibilities" add the word "implementation."M5 - After the words "between the people" add the words "responsible for implementing the Operating Plan"
Constellation Power Generation and Constellation Commodities Group	No	Constellation Power Generation questions how R5 relates to the SDT's "summary of concepts":oA single form to report disturbances and impact events that threaten the reliability of the bulk electric systemoOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirementsoClear criteria for reportingoConsistent reporting timelines oClarity around of who will receive the information and how it will be usedHowever, Constellation Power Generation believes that security awareness is an important aspect of personnel security and proposes an annual training similar to what was in the previous standards. Constellation Power Generation therefore recommends two requirement changes that would achieve security awareness without the burdensome administrative aspects. First, as stated earlier, a sub requirement in R2 should be added which reads as follows: R2.5 Method(s) for making operation personnel aware of changes to the Operating Plan.Second, this training requirement should be rewritten as follows: Each Applicable Entity shall provide training to all operation personnel at least annually.
Consumers Energy	No	Again, either 12 month year or annual year, NERC needs to standardize on one or the other. Training should apply only to those that must take action relevant the reliability of the BES. A plan would likely include

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		notification of senior officers, however they don't need to be included in drills and training if they have no active role.
Duke Energy	No	Strike the word "all" in the requirement. All personnel don't need to be trained - for example, the plan may contain references to some personnel as potential sources of the information that will then be reported. Also, Section 5.3 only allows 30 days for training, which may be impossible with rotating shift personnel and training schedules. 60 days is more appropriate.
Dynergy Inc.	No	The annual training seems excessive especially if their have been no changes. You have included one exception for contact information revisions; however, it should be expanded to include exceptions for minor/non-substantial changes. Also, make training requirements (after initial training)be required for substantive changes only.
E.ON Climate & Renewables	No	Redundant with R4.
Electric Market Policy	No	The need for a periodic training has not been established and appears to be overly restrictive given the intent of the standard is reporting of impact events. Suggest this requirement be eliminated.
Exelon	No	Exelon doesn't feel that the 30 day requirement is achievable and recommends an annual review. Training for all participants in a plan should not be required. Many organizations have dozens if not hundreds of procedures that a particular individual must use in the performance of various tasks and roles. Checking a box which states someone read a procedure does not add any value, it is an administrative burden with no contribution to reliability. It is Exelon's opinion that training requirements should be covered in the PER standards and that the audience to be trained should be identified. R5.4 requires internal personnel that

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 7 Comment
		<p>have responsibilities related to the Operating Plan cannot assume the responsibilities unless they have completed training. This requirement places an unnecessary burden on the registered entities to track and maintain a data base of all personnel trained and should not be a requirement for job function. A current procedure and/or operating plan that addresses each threshold for reporting should provide adequate assurance that the notifications will be made per an individual's core job responsibilities.</p>
FirstEnergy	No	<p>Requirement R5 and Part 5.1 - The wording in Part 5.1 is too prescriptive and should not require training on the specific actions of personnel. Also, R5 should not require training for personnel that may only receive the report and are not required to do anything. Therefore we suggest rewording R5 and 5.1 as follows: "R5. Each Applicable Entity identified in Attachment 1 shall have a Reporting Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 5.1 The training includes the personnel required to respond under the Reporting Plan." Part 5.3 - We suggest removing subpart 5.3. This requirement is overly burdensome and not necessary. We believe that the requirements for annual review and update of the plan as well as training sufficiently cover reviews of changes to the plan. Part 5.4 - The last phrase "training shall be conducted prior to assuming the responsibilities in the plan" should account for emergency situations when the entity does not have time to train the replacement before they are to assume a responsibility.</p>
Great River Energy	No	<p>We believe that this task should be incorporated into the Job Task Analysis for the System Operators and that this requirement should be deleted as being redundant.</p>
Idaho Power Company	No	<p>The 30 day Requirement is limited with real time operations. Most entities with real time operations utilize a 5 or 6 week rotating schedule to comply with PER-002. the NERC Continuing Education Program allows up to 60 days to comply, this allows the operating shifts to accommodate training within the operating schedule. The</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		requirement 5.3 should allow 60 days to complete the training.
Indeck Energy Services	No	It is wholly unreasonable to re-train everyone for each change to the Operating Plan. Suggestion: Clarify that upon changes to the Operating Plan, the Registered Entity may either require full training, or instead distribute a summary of the change to affected personnel only.
Independent Electricity System Operator	No	Along the line of our comments on R2 for an Operating Plan (whose need we do not agree with), any training on developing and providing the report is unnecessary. What matters is that the report is provided to the needed organizations or entities on time and in the required format according to established procedure. How this is accomplished goes outside of the purpose of reliability standard requirements.
IRC Standards Review Committee	No	We do not agree with the need for R5. We do not see the need for a standard requirement that stipulates training the personnel on reporting events. What matters is that the reports are provided to the needed organizations or entities on time and in the required format according to established procedure. Stipulating a training requirement to achieve this reporting is micro-managing and overly prescriptive.
ISO New England Inc.	No	The need for a periodic drill has not been established, and appears to be overly restrictive given that the intent of the standard is reporting of impact events. Suggest this requirement be eliminated. There are training standards in place that cover these requirements. We agree the relevant personnel should be “aware” of the reporting requirements. But there is not a need to have a training program with specific time frames for reporting impact events. Awareness of these reporting requirements can be achieved through whatever means are available for entities to employ to train on any of the NERC standards, and need not be dictated by requirements.



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 7 Comment
Kansas City Power & Light	No	We agree with the need for the Operating plan and the provision of formal training to impacted personnel. We believe that the personnel references are too open-ended to be productive and measurable. This leaves all applicable entities open to subjectivity in assessment and may produce a large administrative burden to demonstrate compliance with no associated benefit to improved reliability.
Luminant Energy	No	Operating Plan revisions communicated through procedure updates and employee acknowledgements of the same are sufficient when coupled with a procedural training program that occurs according to a programmed schedule.
Manitoba Hydro	No	The comments in Question 6 and 7 encompass the training aspect of this requirement.
MidAmerican Energy	No	: R5.2. The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be trained once per calendar year.R5.3 As detailed in R2, the Operating Plan shall contain provisions for “identifying, assessing, and reporting impact events”. Where, R2.7 states to update the OperatingWe disagree with the need to provide formal training. We could agree with the need to communicate to System Operators and other pertinent personnel the criteria for reporting so that they know when system events need to be reported.
Midwest ISO Standards Collaborators	No	We disagree with the need to provide formal training. We could agree with the need to communicate to System Operators and other pertinent personnel the criteria for reporting so that they know when system events need to be reported.
MRO's NERC Standards Review Subcommittee	No	R5.2. The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be trained once per calendar year.R5.3 As detailed in R2, the Operating Plan shall contain provisions for

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		<p>“identifying, assessing, and reporting impact events”. Where, R2.7 states to update the Operating Plan when there is a component change. The NSRS believes the components of this Operating Plan are 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. These components relate to training when the Operating Plan is revised per, R5.3, only. As written, every memo, simulations, blog, etc that contain the words “lessons learned” would be required to be in your Operating Plan and trained on every time one was issued or heard about internally or externally. Recommend that the Operating Plan be revised and training occurs when a change occurs to the entity’s Operating Plan, consisting of 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events, only.</p>
North Carolina Electric Coops	No	<p>Requiring training to report of after-the-fact events does not improve the reliability of the BES. We recommend the elimination of this requirement.</p>
Northeast Power Coordinating Council	No	<p>The need for a periodic drill has not been established, and appears to be overly restrictive given that the intent of the standard is reporting of impact events. Suggest this requirement be eliminated. There are training standards in place that cover these requirements. The relevant personnel should be “aware” of the reporting requirements. But there is not a need to have a training program with specific time frames for reporting impact events. Awareness of these reporting requirements can be achieved through whatever means are available for entities to employ to train on any of the NERC standards, and need not be dictated by requirements.</p>
Pacific Gas and Electric Company	No	<p>PG&amp;E believes 30 days is too restrictive due to real-time operations schedule requirements. The schedule is six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Suggest extending to 60 days to meet the training criteria which follows the NERC Continuing Education revised submittal date for the Individual Learning</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		Activities (ILA).
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PacifiCorp	No	Training required within 30 days of a revision to the Operating Plan is not feasible with 5 or 6 week shift rotations. A sixty day requirement would be more realistic.
Pepco Holdings, Inc - Affiliates	No	30 days may be too short a time for large entities with multiple subsidiaries to do the necessary notice and coordination. PHI suggests 90 days.
PNM Resources	No	PNM believes 30 days is too restrictive due to real-time operations schedule requirements. Most work schedules are either five or six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Based on the NERC Continuing Education revised submittal date for the Individual Learning Activities (ILA), PNM would recommend 60 days. Creating an Impact Event Report is duplicative and redundant and the WECC OTS feels this is not necessary.
PPL Electric Utilities	No	We agree with the need for training on one's process. However, we suggest changes to R5.3. Consider expanding the exception criteria to exempt non-substantive changes such as errata changes, minor editorial changes, contact information changes, etc. We also suggest saying '...training shall be conducted, or notification of changes made, within 30 days of the procedure revisions.'
PPL Supply	No	We generally agree with R5 but recommend two changes to 5.3. Consider expanding the exception criteria to exempt non-substantive changes such as errata changes, minor editorial changes, contact information

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		changes, etc. Also, consider changing "training shall be conducted" to "training or communication/notification of changes shall be conducted."
Puget Sound Energy	No	The fact that proposed requirement R2 will require frequent updates to the operating plan means that the training required under this plan will occur quite frequently as well, leading to operator confusion. Even the comment allowing a review and "sign-off" will not completely mitigate this result.
RRI Energy, Inc.	No	<p>1. This Requirement is structured to result in the same heavy-handed, zero-tolerance approach that has made CIP-004 one of the top three violated Reliability Standards. The failure in CIP-004 is that, for example, a seven-year background check or annual training program that is tardy by one day results in a violation. There is no margin of error, proviso, or cure scenario. Likewise, the proposed R5 in EOP-004-2 makes it a violation if someone takes their newly established training on the day after the end of 15 months. Systems configurations are often based on quarterly monitoring for individuals needing to take training. In addition, when dealing with potentially thousands of employees, it is inevitable that any one of hundreds of reasons might result in an employee not being included in the tracking system, and rolling past the 15th month. RECOMMENDATION: To avoid further burden to Regional Entity audit and enforcement personnel as has been the case in CIP-004, develop a cure process that allows the Registered Entity to correct the training or background check tardiness with prompt correction, fill out a notification report to submit to NERC, and proceed with protecting the reliable operation of the BES, rather than tying up Registered Entity and Regional Entity staffs with data requests, enforcement paperwork and administrative actions.</p> <p>2. The proposed R5.3 requires the entire applicable staff to redo the entire training within 30 days of a change to the Operating Plan. These Operating Plans will not be short documents, and formal training will not involve a 5 minute soundbite. However, for such a significant procedure as the Operating Plan, frequent changes and revisions are going to</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		<p>be very common, especially given the likelihood of frequent clarifications, Compliance Action Notices ("CANs"), and lessons learned issued by NERC and Regional Entities over this very detailed set of new obligations. It is not unreasonable to expect a Registered Entity to make three or more revisions to their Operating Plan in a year, which would require training for thousands of employees three times a year, for what might amount to a single sentence revision. Furthermore, the obligation to retrain on the entire training program is not limited in this requirement to only those individuals impacted by the revision. Where a change or revision only impacts 3 possible employees, this standard would require a company with 1,500 employees subject to the Operating Plan to retake the entire training. RECOMMENDATION: Clarify that upon changes to the Operating Plan, the Registered Entity may either require full training, or instead distribute a summary of the change(s) via email to affected personnel only.</p>
Santee Cooper	No	<p>The concept of requiring training on reporting of after-the-fact events does not support or enhance bulk electric system reliability. We recommend the elimination of this requirement.</p>
SERC OC Standards Review Group	No	<p>While we support training on an annual basis for the operating plan, the concept of requiring training on reporting of after-the-fact events does not support or enhance bulk electric system reliability. We recommend the elimination of this requirement.</p>
Southern Company - Transmission	No	<p>We suggest that the time frame be changed to 60 or 90 days in 5.3. 5.4 needs to have a time frame associated with it; we suggest that it be 60 or 90 days.</p>
Tenaska	No	<p>This Requirement is too specific and places additional burdens on Registered Entities.</p>
TransAlta Corporation	No	<p>Measure M5 states applicable entities shall provide training material presented... This measure is unclear as</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 7 Comment
		to whether the meaning is for internal personnel or to be provided to external entities upon request? Please clarify.
US Bureau of Reclamation	No	The measure is vague and redundant. The Entity is required to provide information to be used to "verify content". The information may be used to demonstrate compliance but who will verify the content is adequate and on what basis. Secondly, the measure requires training information be provided twice, once to demonstrate who participated and then to show who was trained. This is all unnecessary and could be remedied by simply stating that "evidence shall demonstrate that all individuals listed in the plan have received training on their role in the plan"
We Energies	No	Please clarify who is to be trained. As written, R5 requires any internal personnel identified in the plan, including CEO, Vice Presidents, etc., to be trained.
WECC	No	Thirty days is too restrictive due to real-time operations schedule requirements. Most work schedules are either five or six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Based on the NERC Continuing Education revised submittal date for the Individual Learning Activities (ILA), the requirement should be changed to require training to be conducted within 60 days.
Bonneville Power Administration	Yes	There was no training required for CIP-001 or in CIP-008. (The proposed EOP-008 purpose did not list incorporating CIP-008). Training was not really needed for reporting Electrical Grid events.
ERCOT ISO	Yes	ERCOT ISO believes the content of training can include an exercise or drill.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 7 Comment
United Illuminating	Yes	R5.3 coupled with the rationale provided is a sensible approach. It is important that the rationale is not forgotten.
Ameren	Yes	
American Electric Power (AEP)	Yes	
City of Austin dba Austin Energy	Yes	
Georgia System Operations Corporation	Yes	
NERC Staff	Yes	
PacifiCorp	Yes	

**8. Do you agree with the requirement R6 and measure M6? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question regarding agreement with the originally proposed Requirement R6 and Measure M6. (Note R6 been moved to R5 in the revised standard.) The DSR SDT did a full review based on comments that were received. Many comments indicated concerns with the reporting timelines within Attachment 1. (The DSR SDT has addressed those comments in response to Question 10).

Several commenters wanted the ability to report impact events to their responsible parties via the DOE Form OE-417. Following discussions with the DOE and NERC, the DSR SDT has added the ability to use of the DOE Form OE-417 when the same or similar items are required to be reported to NERC and the DOE. This will reduce the need to file multiple forms when like items must be reported to the DOE and NERC for the same impact event. The underlying fact is that impact events are to be reported within prescribed guidelines, thus providing industry awareness and starting of any analysis process. R5 now is stream lined to read:

R5. Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form.

Organization	Yes or No	Question 8 Comment
American Electric Power (AEP)	No	It is not clear how this is different from R3 since it relies on the same timetable in Attachment 1.
CenterPoint Energy	No	CenterPoint Energy does not agree with R6 and M6 as written as we do not agree with the requirement to develop and maintain an Operating Plan (see comments to Q4 above) In addition CenterPoint Energy does not agree with the timelines required in Attachment 1 (see comments on Q10). CenterPoint Energy offers the following alternate language: "Each Applicable Entity shall report events outlined in Attachment 1 to applicable entities including but not limited to; NERC, and appropriate law enforcement agencies."



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 8 Comment
City of Garland	No	<p>1. The reporting requirements should not be expanded beyond CIP 001 and EOP 004-1. The goal for combining the two should be to make the process more efficient - not add on extra requirements for procedures on how to report, drills on reporting, training on reporting, etc. 2. The timelines requiring 1 hour reporting to the ERO are not needed and provide little realtime benefit to the BES. Real time or near real time reporting for “people on the ground” such as the RC, BA, TOP, FBI, Local Law Enforcement, DOE, etc. is necessary. They are in a position to take action in response to an event. On page 5, it states “The proposed standard deals exclusively with after-the-fact reporting. 1 Hour reporting requirements to the ERO in addition to existing reporting are not reasonable “after-the-fact” reporting requirements in the midst of an emergency. Also, there is not a 24X7 ERO center to report events to - why build and staff one when they already exists at the RC, BA, TOP, DOE, FBI, Local Law Enforcement, etc. - An ERO 24X7 center would be extra overhead that would provide no additional benefit in the first hour or hours of an emergency.</p>
Consolidated Edison Co. of NY, Inc.	No	<p>R2 requires applicable entities to have an Operating Plan which are company specific procedures and process required to be compliant with EOP-004. Therefore, R6 should be deleted since it is redundant with R2.</p>
Electric Market Policy	No	<p>Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.</p>
ERCOT ISO	No	<p>ISO recommends the following changes to the language of the requirement.R6. Each Applicable Entity shall report impact events in accordance with Attachment 1.</p>
Exelon	No	<p>The time durations in the attachment are too short, it would be impossible to collect all the data necessary to report out on an impact event in the defined time to report.The SDT should evaluate each event for the most</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
		appropriate entity responsible to ensure there is minimal confusion on who has the responsibility and eliminate duplication of reporting when feasible.
FirstEnergy	No	M6 - NERC's system should be capable of making this evidence available for the entities and provide a "return-receipt" of the reports that we send them. Also, M6 should be revised to state "Applicable Entities" as opposed to "Registered Entities".
Great River Energy	No	We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
Indeck Energy Services	No	---This is the first mention of the time lines in Attachment 1. If they are part of the standard, then they should be incorporated to the Operating Plan in R2 and then need not be mentioned again, only compliance with the plan. ---In M6, the last part, "evidence to support the type of impact event experienced; the date and time of the impact event ; as well as evidence of report submittal that includes date and time" is redundant. All of that should be in the report to NERC. If not, then it's not important to keep.
Independent Electricity System Operator	No	We agree with having a requirement to report impact events in accordance with the timelines outlined in Attachment 1, but not with the requirements indicated in R2.
IRC Standards Review Committee	No	There is not a need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
ISO New England Inc.	No	Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements for NERC that cross other federal agency jurisdictions. There is no need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations which is implied by the label "Operating Plan."
Kansas City Power & Light	No	We believe R3 and M3 are unnecessary as a stand alone requirement and measure and propose combining these requirements with R6 and M6. Identifying and assessing the initial probable cause of an impact event is the obvious starting point in the reporting process and ultimate completion of the required report. Evidence to support the identification and assessment of the impact event and evidence to support the completion and submittal of the report are really one in the same.
MidAmerican Energy	No	We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
Midwest ISO Standards Collaborators	No	We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
North Carolina Electric Coops	No	There is already a DOE requirement to report certain events. NERC should not be developing redundant reporting requirements when this information is already available at the federal level from other agencies.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 8 Comment
Northeast Power Coordinating Council	No	Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements for NERC that cross other federal agency jurisdictions. There is no need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations which is implied by the label "Operating Plan".
Pacific Gas and Electric Company	No	PG&E believes that if the standard is intended to be an after the fact report, we question the one and/or twenty-four hour reporting criteria and then the 30 day criteria?
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PNM Resources	No	PNM believes there seems to be redundancy in reporting based on the time frames in Attachment 1, i.e. OE-417 and other required reports. If this standard is intended to be an after the fact report, why is there one/twenty-four hour reporting criteria?
PPL Electric Utilities	No	We understand the rationale for this standard and support the project to combine EOP-004 and CIP-001 as well as the reporting requirement in CIP-008. We are concerned that it may be difficult to meet Attachment 1 Part B Potential Reliability Impact submittal times as the time to submit is 1 or 24 hour after occurrence. E.g. Risk to BES equipment, the example given is a major event and easy to conclude. Consider forced intrusion, risk to BES equipment (increased violence in remote area), or cyber intrusion - should Attachment 1 state 'report within 24 hours after detection'?

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
PPL Supply	No	It may be difficult to meet Attachment 1 Part B Potential Reliability Impact submittal times as the time to submit is 1 or 24 hours after occurrence. Consider changing the Time to Submit Report for Forced intrusion, Risk to BES equipment, and Detection of a cyber intrusion to be "report within 24 hours after detection".
RRI Energy, Inc.	No	RECOMMENDATION: Clarify that the reporting of impact events shall be to those entities identified in the Operation Plan section developed specifically in Section 2.6. Reference to Attachment 1 indicates reporting to "external" parties is the intent for R6.
Santee Cooper	No	If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity
SERC OC Standards Review Group	No	There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Southern Company - Transmission	No	The time to submit report column needs to be more flexible with time frames.
Tenaska	No	The reporting timelines are currently listed on the OE-417 form. This Requirement is redundant.
TransAlta Corporation	No	R6 should reference Attachment 2 to make it clear that this report form must be used.M6 seems to be requesting evidence that the Confidential Impact Event Report was submitted. TransAlta suggests the submission of the actual report is evidence the report was submitted.Records of this submission can be provided on request.Web Reports Project 2009-01 has indicated online reporting is the direction they are

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 8 Comment
		going.If the impact report becomes an online Web report the entity submitting the report has no way of confirming the report ended up at the Compliance Enforcement Authority office after it is submitted. There needs to be some method that demonstrates the report was submitted and received.
We Energies	No	The proposed definition of “impact event” needs to be clarified.
WECC	No	There seems to be redundancy in reporting based on the time frames in Attachment 1, i.e. OE-417 and other required reports. If this standard is intended to be an after the fact report, why is there one/twenty-four hour reporting criteria?
Arizona Public Service Company	Yes	AZPS believes that Operating Plan should be replaced with "Event Reporting Plan."
ATC	Yes	ATC does agree that applicable entities report on events identified in Attachment 1 (See our comments about Attachment 1), but we do not agree that applicable entities should be required by this standard to have an Operational Plan. Please see our comments to question 4.
BGE	Yes	Comments for clarification:R6. Use of Capital letters in Operating Plan makes it unnecessary to state "created pursuant to Requirement 2
Bonneville Power Administration	Yes	The requirement needs to specify who (ERO) to report to. Attachment 1 doesn't say to report to the ERO either. Clarify or remove the difference between the report submitted and evidence of the type of impact event required in the measurement.
Georgia System Operations Corporation	Yes	It directly supports the purpose of the standard.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
Green Country Energy	Yes	Now this is an excellent example of all that is needed for this requirement!
Manitoba Hydro	Yes	Attachment 1 details the impact events and the thresholds of which they should be reported.
Puget Sound Energy	Yes	It is assumed that for the purposes of M6, NERC and the regions would already have access to these reports.
Ameren	Yes	
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Duke Energy	Yes	
Dynergy Inc.	Yes	
Idaho Power Company	Yes	
Luminant Energy	Yes	
MRO's NERC Standards Review	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 8 Comment
Subcommittee		
NERC Staff	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
United Illuminating	Yes	
US Bureau of Reclamation	Yes	



9. Do you agree with the requirements for the ERO (R7-R8) or is this adequately covered in the Rules of Procedure (section 802)?  
Please explain in the comment box below.

**Summary Consideration:** There was no consensus amongst the commenters who responded to this question. The DSR SDT did a full review based on comments that were received. The DSR SDT has determined that R7 and R8 are not required to be within a NERC Standard since Section 800 of the Rules of Procedure already assigns this responsibility to NERC. The DSR SDT, the Events Analysis Working Group (EAWG), NERC Staff (to include NERC Senior VP and Chief Reliability Officer) had an open discussion with this item being a major topic. The DSR SDT and EAWG are working in coordination with each other to provide NERC Staff with updated language for future inclusion into the Rules of Procedure. NERC Staff, the EAWG and the DSR SDT all supported this new initiative.

Organization	Yes or No	Question 9 Comment
Ameren	No	NERC's current heavy case load should justify reviewing the impact review table only once every 2 years.
ATC	No	ATC feels the ERO obligations should be covered in the Rules of Procedure. We do not agree with the requirements assigned to the ERO, but believe that they should be incorporated into the ERO's Rules of Procedure
BGE	No	R7. Make Impact Event Table all Capital Letters(it is a title). R8. Is the term "reportable impact events" new or is impact event intended to be capitalized? R8. Does a quarterly report of the year's reportable impact events include 12 months of "reportable impact events"? This is confusing. R8. In the Rationale for R8 Impact Events appears with Capital letters - why now? Shouldn't it appear with all Capital letters throughout the document as it is a defined term? R8. There are no previous requirements to report threats (R8.3) or

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		lessons learned (R8.5) or trends (R8.2) to an ERO. Is this information from reports to the ERO or from ERO research?
CenterPoint Energy	No	CenterPoint Energy does not believe this requirement is necessary; however, if the SDT insists on keeping this requirement then CenterPoint Energy believes it should remain as written. Any change to Attachment 1 should go through the Reliability Standards Development Procedure.
Consolidated Edison Co. of NY, Inc.	No	See response to Question 2Requirement 7Delete the words “and propose revisions to”Following the words (Attachment 1) add a period.Following that period add the words “The ERO shall revise the table”Requirement 8RECOMMEND DELETION OF R8 - CONFIDENTIALITY CONCERNS WILL MAKE ESTABLISHING A PUBLICATION REQUIRMENT EXTREMELY CHALLENGING.
Constellation Power Generation and Constellation Commodities Group	No	The impact event table (Attachment #1), as part of a standard, would have to be FERC approved every time it is edited. That would cause it to go through NERC’s Standard Development Process, and would cause a revision to the standard each time. This will also cause revisions to each and every registered entity’s Operating Plan. Overall, this requirement causes a large administrative burden on all entities, and does not improve reliability. As stated earlier, the “summary of concepts” for this latest revision, as written by the SDT, includes the following items: <ul style="list-style-type: none"> <li>oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system</li> <li>oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements</li> <li>oClear criteria for reporting</li> <li>oConsistent reporting timelines</li> <li>oClarity around of who will receive the information and how it will be used</li> </ul> Requirement 7 and 8 do not address any of these items. Furthermore, for R8, it is requiring NERC to send out quarterly reports, yet entities are supposed to amend their Operating Plans based on an annual NERC report. This requirement is confusing and is not consistent with earlier requirements. Constellation Power Generation

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		believes that these two requirements should be removed.
Electric Market Policy	No	Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority.
ERCOT ISO	No	Recommend that the Electric Reliability Organization be removed. The Electric Reliability Organization should not be responsible for reliability functions and therefore should be excluded from reliability standards.
FirstEnergy	No	FE disagrees with the ERO as an applicable entity within a reliability standard. See our responses to Questions 2 and 3 above. We do not believe the desired ERO process is adequately covered in section 802. Section 802 deals with assessments and not event reporting.
Georgia System Operations Corporation	No	It should not be necessary for the ERO to require itself to do these things. NERC's authority should be sufficient to do these things as part of its mission. With quarterly trending and analysis of threats, vulnerabilities, lessons learned, and recommended actions in R8, R7 (an annual review) should not be necessary. The quarterly activity could include proposing revisions to Attachment 1 if warranted. An alternative would be to perform annual trending and analysis of threats, vulnerabilities, lessons learned, recommended actions, and proposed revisions to Attachment 1 if warranted. Also, the Reliability Standards Development Procedure has been replaced with the Standard Processes Manual.
Indeck Energy Services	No	Reviewing Attachment 1 annually is unnecessary. Events don't change much and if they do, a SAR is needed to consider the changes. NERC should not be included in any standard!
Independent Electricity System Operator	No	We agree with the need to update the list as needed, but it does not have to be the ERO who takes on a reliability standard to do so. It can simply be an annual project in the standards development work plan to review Attachment 1 as part of a standard. The industry will then be provided an opportunity to weigh on the

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		<p>changes. Also, we do not see the reliability results or benefits of R8. The ERO can issue the report quarterly but who are audiences? What reliability purpose does it serve if no further actions are pursued upon receiving the report? Can this be done as a standing item for the ERO at, say, the BoT meeting? Or, can this be a part of the quarterly communication from the ERO to the industry? To make this a reliability standard is an over-kill, and does not conform with the results-based standard concept. From our perspective, both R7 and R8 can be removed, and the ERO can be removed from the Applicability Section as well.</p>
<p>IRC Standards Review Committee</p>	<p>No</p>	<p>We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.</p>
<p>ISO New England Inc.</p>	<p>No</p>	<p>Having the ERO as an applicable entity raises concern as it is also the compliance enforcement authority. Requirement R7 is unnecessary as there are already requirements in place for three year reviews of all Standards. R8 contains requirements to release information that should be protected, such as identification of trends and threats against the Bulk Electric System. This may trigger more threats because it will be published to unwanted persons in the private sector. We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.</p>
<p>Kansas City Power &amp; Light</p>	<p>No</p>	<p>We agree with the rationale for R8 requiring NERC to analyze Impact Events that are reported through R6 and publish a report that includes lessons learned but disagree with R2.9 obligating an entity to update its Operating Plan based on applicable lessons learned from the report. Whether lessons learned are applicable</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		<p>to an entity is subjective. If an update based on lessons learned from an annual NERC report is required, the requirement should clearly state the necessity of the update is determined by the entity and the entity's Reliability Coordinator or NERC can not make that determination then find the entity in violation of the requirement. In addition, if an update based on lessons learned from a NERC report is required, NERC should publish the year-end report (R8) on approximately the same day annually (i.e. January 31) and allow an entity at least 60 days to analyze the report and incorporate any changes it deems necessary in its Operating Plan. Again, the language referencing annual and quarterly in these two requirements in confusing.</p>
Manitoba Hydro	No	<p>Rules of Procedure appear to have a different focus then R7 and R8. Briefing on Rules of Procedure 802 Assess, review and report on:</p> <ul style="list-style-type: none"> <li>1.1 overall electric operation</li> <li>1.2 uncertainties and risks</li> <li>1.3 self assessment of supply and reliability</li> <li>1.4 projects on customer demand</li> <li>1.5 impact of evolving electric market practices that could affect the present and future of the BES</li> </ul> <p>Briefing on R7 and R8</p> <ul style="list-style-type: none"> <li>R7 - ERO shall review and propose revisions to Attachment 1</li> <li>R8- ERO shall publish quarterly reports on trends, threats, vulnerabilities, lessons learned and recommended actions.</li> </ul>
Midwest ISO Standards Collaborators	No	<p>We do not agree with the requirements and we do not believe it is adequately covered in section 802. First, section 802 deals with assessments not event reporting. Secondly, since attachment 1 is part of a standard, it should not be modified outside of the Reliability Standards Development process.</p>
NERC Staff	No	<p>NERC staff believes that requirements R7 and R8 are not needed because they are intrinsic expectations from its Rules of Procedure. Furthermore, these elements are necessary for analysis in support of the Reliability Metrics efforts NERC is leading under its Reliability Assessment and Performance Analysis</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		program.
North Carolina Electric Coops	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority.
Northeast Power Coordinating Council	No	Having the ERO as an applicable entity raises concern as it is also the compliance enforcement authority. Requirement R7 is unnecessary as there are already requirements in place for three year reviews of all Standards. R8 contains requirements to release information that should be protected, such as identification of trends and threats against the Bulk Electric System. This may trigger more threats because it will be published to unwanted persons in the private sector. We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.
Puget Sound Energy	No	This is adequately covered by section 802 of the Rules of Procedure. There seems to be some conflict between R2.9 and R8 regarding timeframes and the specific elements required.
Santee Cooper	No	Standards cannot be applicable to an ERO because they are the compliance enforcement authority, and the ERO is not a user, owner, or operator of the BES.
SERC OC Standards Review Group	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority. The governance in this situation appears incomplete.
United Illuminating	No	The rules of procedure adequately cover this.
US Bureau of Reclamation	No	Requirements 7 and 8 are covered in the Section 801.801. Objectives of the Reliability Assessment and

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 9 Comment
		Performance Analysis Program. The objectives of the NERC reliability assessment and performance analysis program are to: (1) conduct, and report the results of, an independent assessment of the overall reliability and adequacy of the interconnected North American bulk power systems, both as existing and as planned; (2) analyze off-normal events on the bulk power system; (3) identify the root causes of events that may be precursors of potentially more serious events; (4) assess past reliability performance for lessons learned; (5) disseminate findings and lessons learned to the electric industry to improve reliability performance; and (6) develop reliability performance benchmarks. The final reliability assessment reports shall be approved by the board for publication to the electric industry and the general public.
Bonneville Power Administration	Yes	R2.9 language refers to R8 “annual” report; however R8 language is “quarterly” reporting. It appears this standard is going to be in an update status 4 times per year minimum, plus any event modifications plus personnel changes. Overly burdensome.
City of Garland	Yes	R7 - Yes as long as any changes to attachment 1 follow the “Reliability Standards Development Procedure. R8 - Yes as long as R8.6 is strictly “recommended actions.” They should not become “required actions” as this bypasses the standard development process.
Duke Energy	Yes	However, R8 only addresses quarterly reports, and R2 Section 2.9 states that there will be an annual report.
Green Country Energy	Yes	I realize this is another burden for the ERO but the information would be good to know what is going on outside the plant .
Luminant Energy	Yes	Continually refining the Impact Event table to better define which events should be reported would be extremely valuable. Section 802 does not adequately require such refinement, thus R7 and R8 are

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		appropriate inclusions to this standard.
MRO's NERC Standards Review Subcommittee	Yes	Should read "In accordance with Sections 401(2) and 405 of the Rules of Procedures, the ERO can be set as an applicable entity in a requirement or standard". As stated in the text box.
RRI Energy, Inc.	Yes	We support the concept that Reliability Standard requirements and obligations that are subject to violations and penalties should all be contained in the four-corners of the Reliability Standard. If an obligation exists in the Rules of Procedures that creates a stand-alone responsibility that is subject to violation and penalty, it should be removed from the Rules of Procedure and inserted into the appropriate Reliability Standard.
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Dynergy Inc.	Yes	
Great River Energy	Yes	
Idaho Power Company	Yes	
MidAmerican Energy	Yes	
Pacific Gas and Electric Company	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 9 Comment
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
We Energies	Yes	
WECC	Yes	

**10. Do you agree with the impact event list in Attachment 1? Please explain in the comment box below and provide suggestions for additions to the list of impact events.**

**Summary Consideration:** Most commenters who responded to this question disagreed with some aspect of Attachment 1 – most commenters provided specific suggestions for improvement. The DSR SDT did a full review based on comments that were received. The DSR SDT, the Events Analysis Working Group (EAWG), NERC Staff (to include NERC Senior VP and Chief Reliability Officer) had an open discussion with this item being a major topic. The EAWG and the DSR SDT aligned Attachment 1 with the Event Analysis Program category 1 analysis responsibilities. This will assure that impact events in EOP-004-2 reporting requirements are the starting vehicle for any required Event Analysis within the Event Analysis Program. The DSR SDT agrees that there are similar items in the DOE Form OE 417 and EOP-004-2. DOE, NERC and the DSR SDT are in initial talks to try and reduce duplicate reporting requirements. Until such time in the future that a new process is established between the DOE and NERC, the DSR SDT has revised the standard to indicate that the use of either the DOE Form OE 417 or Attachment 2 is an acceptable reporting form for applicable entities. The DSR SDT reviewed the “hierarchy” of reporting within Attachment 1. To reduce multiple entities reporting the same impact event, the DSR SDT has stated that the entity that performs the action or is directly affected by an action will report per EOP-004-2. As an example, during a system emergency, the TOP or RC may request manual load shedding by a DP or TOP. The DP or TOP would have the responsibility to report the action that they took if they meet or exceed the bright-line criteria established in Attachment 1. Upon reporting, NERC Event Analysis Program would be made aware of the impact event and start the EA Process which is outside the scope of this Standard.

Several bright-line criteria were removed from Attachment 1. These criteria (DC converter station, 5 generator outages, and frequency trigger limits) were removed after discussions with the EAWG and NERC staff, who concurred that these items should be removed from a reporting standard and analysis process.

Organization	Yes or No	Question 10 Comment
--------------	-----------	---------------------

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
WECC		For strictly after-the-fact reporting the list of Attachment 1 is appropriate. However, as noted in our earlier comments, actual or suspected sabotage events can have a potentially significant impact on reliability and should be treated differently, with additional real-time reporting requirements. It is important that such events be identified and recognized for reliability purposes and that notices include the RC.
Ameren	No	<p>We have numerous comments about the Attachments. (1) What are the requirements for "verbal" reporting to NERC and Regional entities? (2) What are the requirements for a "Preliminary" Impact Event Report? (3) The Voltage Deviations Event is unclear (a) Are these consecutive minutes? (b) Where is the voltage measured? (generator terminals? Point of Interconnections? Anywhere?) (c) must each Entity report separately? (d) What is the +/- 10% measured against (Generator Voltage Schedule?) (4) For Generation loss events how is an "entity" defined? (a corporate parent? each registered entity? other?) (5) Are the "Examples" in the Attachment 1 - Part A really Examples, or mandatory situations? (6) Can you define "Damage"? (7) Can you define "external cause"? (8) Can you give examples of "non-environmental external causes"? (9) The footnote 1 reference for "Damage or destruction of BES equipment" doesn't match up with the a. and b. footnotes or the 1. footnote of Attachment A - Part B. (10) How is the Operator supposed to determine what Event affects the reliability of the BES fast enough to decide whether or not to report? (11) is the Loss of off-site power (grid supply) event to a nuclear plant already covered by NUC-001?(12) What are "critical cyber assets" since CIP-002-4 will eliminate that term? (13) When is Attachment 2 supposed to be used? (14) What is meant by the word "Confidential" in the title of the Attachment 2 report? How would the SDT propose a GO/GOP handle the reporting for the following situation? A CTG unit is dispatched and the unit is started, synchronized and put on the bus. Immediately the Operator receives a high gas alarm from the GSU. The Operator quickly shuts the unit down and de-energizes the GSU. There are no relay targets and no obvious reason for the problem. After several weeks of analysis it's determined there was an internal fault in the GSU</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		and it must be replaced. How would the SDT recommend all the reporting requirements in this situation be addressed with the current draft?
American Electric Power (AEP)	No	Are the times listed for the initial probable reporting under R3 or the reporting under R6? Many of these items do not constitute emergency conditions. We view many of these as too onerous and would divert operating staff from monitoring and operating the BES. In addition, some terms (i.e. Frequency Trigger Limits) are not currently defined terms. Furthermore, there are existing requirements that have obligations for entities to provide this information to the RC. For example "Detection of a cyber intrusion to critical cyber assets" is already covered under CIP-008. This creates duplicate (and potentially competing) requirements. AEP also contends that some of the timelines are very aggressive and not commensurate with perceived need for the information. Transmission loss of multiple BES transmission elements (simultaneous or common-mode event) within 24 hours after occurrence is overly aggressive and should provide more specific criteria.
Arizona Public Service Company	No	AZPS believes that the list in Attachment 1 would be complete, as long as the text box of examples is included. The examples demonstrate what is necessary.
ATC	No	ATC has several areas of concern regarding Attachment 1.1. The one hour requirement for reporting will take the Functional Entities' focus off of addressing the immediate reliability issues and instead force the FE to devote valuable resources to filling out forms which will potentially reduce reliability. 2. Part A: a. Provide a definition of "system wide" for the Energy Emergency requiring system-wide voltage reduction. b. Add in the clarity that for Energy Emergency requiring firm load shed pertains to a single event, not cumulative events. c. Insert the word "continuous" for Voltage Deviations. d. Take off the TOP for IROL violations. (We believe that an IROL violation should be reported by the RC and not by the TOP based on the nature of the event. Requiring both the RC and TOP to report will only result in multiple reports for a single event. The RC is in

Organization	Yes or No	Question 10 Comment
		<p>the best position to report on an IROL violation for its RC area.)e. Take off the TO, TOP and add the LSE for Loss of Firm Load. (As a transmission only company ATC does not have contracts with end load users. Because of this the Loss of Firm Load should be the reporting obligations of the entity closes to the end load users which is the BA, DP or LSE. Failure to modify this requirement will cause confusion as to which entity has to report Loss of Firm Load. f. Define a timeframe for Generation Loss g. Multiple should be changed to “4 or more” for Transmission Loss.(ATC is concerned that this would require reporting of events that have little or no industry wide benefits but would take up considerable Registered Entity resources.)h. Provide clarity to and tighten the definition of Damage or destruction of BES equipment. The way it is written now would require over-reporting of all damaged or destroyed equipment due to a non-environmental external cause (e.g. broken insulator).3. Part B:a. Take off the TO and TOP for Loss of off-site power. (The GOP has the responsibility to acquire off-site power and we believe it is the GOP’s sole responsibility to report the Loss of off-site power. Failure to correct this would result in multiple reporting for the same event.)b. Take off RC for Risk to BES equipment. (The RC function does not own BES equipment and we believe it is impossible for them to report on risk to BES equipment if they are not the owner or operator of that equipment. This standard should be required of the entity that owns/operates BES equipment. c. Provide guidance to the phrase “reasonably determine” in footnote.d. Examples provided do not provide a clear obligation for an entity to follow. (Question: How close is the train to the substation? (Inches away from the substation fence, ten feet away from the substation fence or 500 feet away from the substation fence.) In addition, this standard is so open to interpretation that no entity can demonstrate compliance with the action. We believe that the only solution is to delete this reporting requirement. Overall:Multiple Functional Entities impacted by the same event are required to report. No lead entity is identified. This will result in multiple reports of the same event. ATC does not believe that this built-in duplicity enhances reliability?</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
ATCO Electric Ltd.	No	Attachment 1: Part A - Transmission Loss: Only sustained outages should be reportable. Also the reporting threshold needs to be quantified for impact events, for example:a) Size of DC converter Station > 200 MW.b) Impact of loss of Multiples BES transmission elements in terms of significant load (> 200 MW for > 15 min).
BGE	No	TOP determines "system-wide" voltage reductions; why place this responsibility on a TO or DP? - Load Shedding is automatic load shedding; why 100MW? Does a DP need to provide a Report when directed by the RC, BA or TOP to shed load or reduce voltage? - No examples should be included in the standard! Need to define a "BES Transmission Element". - Table shows multiple entities in "Entity with Reporting Responsibility"; is it one or is it all entities report? - In an audit who determines "reasonably determined likely motivation" - Is it justified to expect to have "motivation" knowledge within one hour of an event? - Why are the Responsible Entities reporting Interruptible Demand tripped / lost?
Bonneville Power Administration	No	BPA suggests the following:Change loss of multiple BES to 3 or more. Loss of a double circuit configuration due to lightning doesn't need a report (it's a studied contingency). Add qualifier to damage/destruction of BES equipment, since a failed PCB or a system transformer normally doesn't have a MAJOR impact to the grid.Add qualifier to Loss of "ALL" off-site power affecting nuclear...The unplanned evacuation of control center is a busy time for the backup control center, yet this standard requires 1 hour reporting. Suggest changing to 24 hours.
CenterPoint Energy	No	CenterPoint Energy appreciates the efforts of the SDT in identifying the entity with reporting responsibility. This is an improvement to the event table. CenterPoint Energy is concerned with multiple entities being listed as having Reporting Responsibility. CenterPoint Energy recommends the SDT limit this to one entity having responsibility for reporting each event. This would not preclude that entity from coordinating with other entities

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>to gather data necessary to complete the report. In addition, CenterPoint Energy believes there are several events that should be removed from the list. "Transmission Loss" is covered by the TPL standards and does not need to be identified or reported under EOP-004. The loss of a DC converter station or multiple BES transmission elements may or may not disrupt the reliable operation of the BES, i.e. result in blackout, cascading outages, or voltage collapse. Likewise "Damage or destruction of BES equipment" in and of itself should not be the subject of reporting. If the damage or destruction results in true disruption to the reliable operation of the BES, that impact would be reported under one of the other identified events. "Voltage Deviations" is another unnecessary event. CenterPoint Energy believes a voltage event of the proposed magnitude will, more than likely, result in other events identified in Attachment 1 such as; IROL Violation or Generation Loss and would be reported under one of those triggers. Another concern is the threshold trigger of +/- 10% for 15 minutes or more. CenterPoint Energy is unclear as to the starting point to determine the deviation. In other words is the 10% deviation from nominal voltage, such as 138kV or 345kV, or the actual voltage at the time of the event? Additionally, must the deviation occur over a "wide area" or is such a deviation at one buss enough to trigger a report? Based upon these ambiguities and concerns CenterPoint Energy recommends "Voltage Deviations" be deleted from Attachment 1. The examples that follow on page 14 should also be deleted.</p>
City of Garland	No	<p>This report should follow exactly the OE-417 to avoid redundant, possible conflicting, and overall confusion in reporting. Note: The table has entries that are in conflict with the OE-417 and thus can cause confusion in filing multiple reports potentially causing an entity to violate Federal Law due to the confusion. By submitting the same information on different timelines, i.e. one hour reporting under OE-417 and 24 hours under this Standard, the reports may be significantly different causing confusion from differing reports of the same event. Although we prefer the events to match the OE-417 events exactly, if the SDT decides to include a</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>seperate events table we make the following suggestions: Energy Emergency requiring system-wide voltage reduction: should be reportable at 5% not 3% voltage reduction. The standard should clearly state this was applicable for BES energy emergency conditions only, not voltage reductions for other reasons. On voltage deviations: it should be clear that this applies to widespread effects on the BES not a single distribution feeder that has a low voltage. For the Frequency deviation: Did not see a definition for the FTL (frequency trigger limit) Generation loss: the reportable loss of generation should be significantly more than 500 MW. The number of units at the locaton is irrelevant. Ten units at 50 MW each is no more critical than a single 500 MW unit. Under this standard, if the plant with ten 50 MW units trips it is reportable but an 800 MW single unit is not reportable. The trip of the 800 MW unit has much more effect on the sytem reliability. Damage or destruction of BES equipment: Should be limited to specific equipment such as a 765 kV autotransformer not a 138 kV lightning arrestor. This needs to be eliminated or significantly limited as to the equipment type that is reportable.</p>
Consolidated Edison Co. of NY, Inc.	No	<p>It is absolutely essential that the work on EOP-004 and that on the NERC Event Analysis Process (EAP) be fully coordinated. We find that there are a number of inconsistencies between these two documents. The EAP and EOP-004 are not aligned. In order to operate and report effectively entities need consistent requirements. Attachment 1 Frequency Deviations - The term "Frequency Trigger Limit (FTL)" is not defined. Only defined terms should be used, or the term should be defined. If the term is defined in another standard it should be moved to the Glossary of Terms for wider use. Loss of Firm load for 15 Minutes - The text under the rightmost column entitled, Time to Submit Report, appears to be incomplete in our copy. Transmission loss and Damage or destruction of BES equipment - At the end of the wording for both under the column entitled "Threshold for Reporting" add the words "that significantly affects the integrity of interconnected system operations." Examples - Capitalize "Critical Asset" as this is a defined term.</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Constellation Power Generation and Constellation Commodities Group	No	<p>Constellation Power Generation and Constellation Commodities Group questions why the generation loss line item includes generating facilities of 5 or more generators with an aggregate of 500 MW or greater? The number of units makes no difference for reporting, as is evident in the generation thresholds written before this inclusion. The examples of damaged or destroyed BES equipment are confusing, and do not clarify the reporting event. What if a GSU at a small plant (20 MW) were to fail? Is that reportable? Constellation Power Generation believes that equipment failures that are not suspicious do not need to be reported. Finally, Constellation Power Generation and Constellation Commodities Group believes that the “loss of offsite power affecting a nuclear generation station” should be removed for the following reasons:1)The purpose of this reliability standard is stated as being: “Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES). “ While the “situational awareness” portion of the purpose could be interpreted as all-inclusive, the real element deals with BES reliability. Off-site power sources to nuclear units have nothing to do with BES reliability. Why should nuclear units be treated differently?2)The issue of concern for a loss of offsite power at a nuclear station is continued power supply (other than emergency diesels) to power equipment to cool the reactor core. A nuclear unit automatically shuts down when off-site power supply is lost. Availability of off-site power is a reactor safety concern (i.e., NRC regulatory concern and a one-hour report to the NRC) - not a reliability concern that FERC/NERC would have jurisdiction over.3)There is a nuclear-specific reliability standard (NUC-001) that contemplated off-site power availability. That standard contained no reporting requirements outside of those that may be already established in current procedures. Why try to impose one here?4)A loss of offsite power will result in an emergency declaration at the nuclear facility. Notifications will be made to federal (NRC), state, and local authorities. The control room crew is already overly-burdened with notifications - any additional call to NERC/Regional Reliability orgs will add insult-to-injury for no beneficial reason. If NERC is interested, they should obtain info from NRC.5)If all else fails and the item is to remain on the table, it needs</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		to be clarified as a “complete” loss of off-site power lasting greater than X minutes (i.e., would we have to report a complete momentary loss that was rectified in short order by an auto-reclose or quick operator action?).
Duke Energy	No	<ul style="list-style-type: none"> <li>o General Comment - many timeframes in Attachment 1 are within one hour. This is inconsistent with the stated aim of the standard, which is after-the-fact reporting, as opposed to real-time operating notifications under RCIS and other standards (e.g. TOP). This standard should not be structured to require another layer of real-time reporting.</li> <li>o Voltage Deviation - Plus or minus 10% of what voltage?</li> <li>o Frequency Deviation - this is Interconnection-wide. Do you really want a report from every RC and BA in the Eastern Interconnection??</li> <li>o Transmission Loss - “Multiple BES transmission elements” should be changed to “Three or more BES transmission elements”. Also, the time to submit the report should be based upon 24 hours after the occurrence is identified.</li> <li>o Damage or destruction of BES equipment - need clarity on the “Examples”. Is the intent to report an event that meets any one of the four “part a.” sub-bullets?               <ul style="list-style-type: none"> <li>i. - critical asset should be capitalized. Disagree with the phrase “has the potential to result” in section iii. - it should just say “results”. Section iv. is too wide open. It should instead say “Damaged or destroyed with malicious intent to disrupt or adversely affect the reliability of the electric grid.”</li> </ul> </li> <li>o Unplanned Control Center evacuation - see our General Comment above. Clearly in this case the reporting individuals are evacuating and cannot report in one hour. 24 hours should be more than adequate for after-the-fact reporting.</li> <li>o Fuel Supply Emergency, Loss of off-site power, and Loss of all monitoring or voice communication capability - see our General Comment above. Time to report should be 24 hours after occurrence is identified.</li> <li>o Forced intrusion, Risk to BES equipment, Detection of a cyber intrusion to critical cyber assets - time to report should be 24 hours after occurrence is identified, and critical cyber assets should be capitalized.</li> </ul>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Dynergy Inc.	No	A 2000 MW loss needs to be more clearly defined by either the BA, ISO, RC, etc. for the applicable entity. Also, what is the distinction between the "damage or destruction of BES equipment" and the generation loss of $\geq$ 2000 MWs if it is a Critical Asset which is currently drafted as those greater than 1500 MW in current draft of CIP-002-4. This could lead to 2 events with different thresholds (i.e. 1500 MW and 2000 MWs). Possibly get rid of the 2000MW criteria and let the threshold level be the same as the Critical Asset MW level. Or remove the Critical Asset threshold in the footnote to Attachment 1.
E.ON Climate & Renewables	No	1. Voltage deviation events are too vague for GOP. How does voltage deviations apply to GOP's or specifically renewables i.e., wind farms? 2. Define what an "entity" is. 3. Define what a "generating station" is. 4. Define what a "BES facility" is. 6. Define what a control center is.
Electric Market Policy	No	1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would appear to overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004.
ERCOT ISO	No	ERCOT ISO requests the reporting timeframes be changed to reflect a 24 hour requirement for all events in Attachment 1. During an impact event, operating personnel are generally involved in event resolution and not available immediately to submit reports. ERCOT ISO requests that the "Detection of a cyber intrusion to a

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 10 Comment
		critical cyber asset” be removed. There are established processes defined for incident response supporting CIP-008. By including this element in Attachment 1, the Operating requirement R2 would also require procedure documents for cyber security incident response. This would be redundant and would remove the responsibility away from the subject matter experts for cyber security incident response.
Exelon	No	The listed Impact Events is lacking specific physical security related events. .In general, all impact events need to be as explicit as possible in threshold criteria to eliminate any interpretation on the part of a reporting entity. Ambiguity in what constitutes an "impact event" and what the definition of "occurrence" is will ultimately lead to confusion and differing interpretations.
FirstEnergy	No	1. The table in Att. 1 and the requirements should alleviate the potential for duplicate reporting. For example, If the RC submits a report regarding a Voltage deviation in its footprint, the report should be submitted by the RC on behalf of the RC, TOP, and GOP, and not require the TOP and GOP to submit duplicate reports.2. Regarding the "Note" before the table - We agree that under certain conditions it is not possible to issue a written report in a given time period. However, the ERO and RE should also be required to confirm receipt of the verbal communication in writing to prove that the entity communicated the event as these verbal notifications may be done by an entity using an unrecorded line.3. Organizations with many registered entities should be permitted to submit one report to cover multiple entities under one parent company name. We suggest this be made clear in the Tables, the reporting form, and in the requirements.4. Voltage Deviations Event - We suggest the team provide more clarity with regard to the types and locations of voltage deviations that constitute an event.5. Examples of BES Equipment in Part A of "Actual Reliability Impact" Table - Is the phrase "critical asset" referring to the CIP defined term? If so, this should be capitalized.6. Under the "Time to Submit Report" column of the table, we suggest that all of the phrases end in "after identification of the

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>occurrence".7. Frequency Trigger Limit (FTL) for the Frequency Deviation event should be replaced with the values the FTL represent. The FTL is part of the BAAL Standards which have not been approved by the industry and are not in effect. It is possible that these terms are not used by those not participating in the field trial of the BAAL standards.</p>
Great River Energy	No	<p>Comments: Please provide a phone number and provision within the Note of EOP-004 - Attachment 1: Impact Events table for an entity to contact NERC if unable to contact NERC within the time described.Voltage Deviations - recommend adding the word "(continuous)" after sustained in Threshold column. This could be interpreted as an aggregate value over any length of time.Frequency deviations - recommend adding the word "(continuous)" after 15 minutes' in Threshold column. This could be interpreted as an aggregate value over any length of time.CIP-008 R1.3 states the entity is to report Cyber Security Incidents to the ES_ISAC. Does the EOP-004 Attachment 2 fulfill this requirement?We request clarification on the Transmission Loss threshold events that constitute reporting. We also want clarification on what constitutes the loss of a DC Converter station and is there a time duration that constitutes the need for reporting or does each trip need to be reported? For example during a commutation spike the DC line could be lost for less than a minute. Does this loss require a report to be submitted? Is the SDT stating that each time a company loses their DC line, they are required to file a report even though it may not have an effect on the bulk system? What is the threshold for this loss?The SDT needs to clarify that duplicative reporting is not required and that only one entity needs to report. For instance, the first three categories regarding energy emergencies could be interpreted to require the BA and RC to both report. The reporting responsibilities in this table should be clarified based on who has primary reporting responsibility for the task per the NERC Functional Model and require only one report. For instance, since balancing load, generation and interchange is the primary function of a BA per the NERC Functional Model, only the BA should be required to provide this report.The</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 10 Comment
		term Frequency Trigger Limit (FTL) is not currently defined in the NERC Glossary. The term FTL needs to be introduced at the beginning of the standard and defined as a new term.
Indeck Energy Services	No	Loss of off-site power is important to more than just nuclear plants--but which ones? Control centers or other large generators. But not small generators! Should there be a common element to Attachment 1, like the potential to cause a Reportable Disturbance, or maybe there need to be multiple criteria like that.
Independent Electricity System Operator	No	We do not support the 1 hour reporting time frames for Emergency Energy, System Separation, unplanned Control Center evacuation, Loss of off-site power, Loss of monitoring or voice communication. Energy emergency is broadcast on the RCIS which also goes to the ERO so its explicit reporting is not necessary (System Operations please verify). During other events listed above, the responsible entities will likely be concentrating its effort in returning the system to a stable and reliable state. Reporting to anyone not having direct actions to control, mitigate and contain the disturbances is secondary to restoring the system to a reliable state. Since these are after the fact reports for awareness and/or analysis and not for real-time responses, these can be reported at a later time, up to 24 hours after the initial occurrence without any detriment to reliability, or at the very earliest: up to 1 hour after the system has returned to a reliable state, or after the backup control centre is fully functional, or after backup power is restored to the nuclear power plant, or after monitoring or voice communication is restored.
IRC Standards Review Committee	No	We do not agree with the requirement to report “detection of a cyber intrusion to critical cyber assets” as this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. We suggest that physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.
ISO New England Inc.	No	1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>entity to report the event. This is duplicative and would overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004. What are the examples at the bottom of page 14 supposed to illustrate? Critical Asset should have the appropriate capitalization as being a defined term. Is Critical Asset what is intended to be used here? Should the “a” list be read as ANDs or Ors? Does “loss of all monitoring communications” mean “loss of all BES monitoring “communications”? Does “loss of all voice communications” mean “loss of all BES voice communications?” Are the blue boxes footnotes or examples? Does “forced intrusion” mean “physical intrusion” (which is different from “cyber intrusion”) ? Regarding “Risk to BES Equipment,” request clarification of “non-environmental”. Regarding the train derailment example, the mixture of BES equipment and facility is confusing. Request clarification for when the clock starts ticking. Regarding “Detection of a cyber intrusion to critical cyber assets”, there is concern that this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. Suggest physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.</p>
Kansas City Power & Light	No	<p>We agree with the event descriptions listed in Attachment 1 and the review and revision of the impact table by the ERO is appropriately addressed in R7 but the time periods allowed to complete the new, longer preliminary report is insufficient. The correlation of this with the timing of the reporting quarterly and annually or pushing information for other entities' situational awareness does not allow the registered entity adequate time to thoughtfully consider the event and proposed root cause.</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Luminant Energy	No	<p>The Impact Events Table might be easier to clarify if organized by Reporting Entity rather than Event Type as events vary substantially based on the affected BES component. For example, a GO or GOP cannot adequately determine if an event will significantly affect the reliability margin of the system or if an event results in an IROL. Examples specific to Reporting Entities would assist in more appropriate report submissions. Additionally, the footnote under examples of Damage or Destruction of BES Equipment, cites “A critical asset”. This term must be clarified to indicate whether this refers to a Critical Asset as defined by CIP 002-1. Finally, the Fuel Supply Emergency item requires additional definitions as neither a GO nor a GOP can reasonably project if an individual fuel supply chain problem will result in the need for emergency actions by the RC or BA.</p>
MidAmerican Energy	No	<p>New vague criteria in Attachment one such as “damage to a BES element through and external cause” or “transmission loss of multiple BES elements which could mean two or more” is the opposite of clear standards writing or results based standards.</p>
Midwest ISO Standards Collaborators	No	<p>Several categories require duplicate reporting. For instance, the first three categories regarding energy emergencies could be interpreted to require the BA and RC to both report. The reporting responsibilities in this table should be clarified based on who has primary reporting responsibility for the task per the NERC Functional Model and require only one report. For instance, since balancing load, generation and interchange is the primary function of a BA per the NERC Functional Model, only the BA should be required to provide this report. As another option, perhaps the registered entity initiating the action should submit the report. If the BA did not take action and the RC had to direct the BA to take action, one could argue that perhaps the RC should submit the report then. However, if the BA takes action appropriately on their own, the BA should submit it. If the TOP reduces voltage for a capacity and energy emergency per a directive of the BA, then the</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		BA should report the event.
MRO's NERC Standards Review Subcommittee	No	Please provide a phone number and provision within the Note of EOP-004 - Attachment 1: Impact Events table for an entity to contact NERC if unable to contact NERC within the time described.Voltage Deviations - recommend adding the word “(continuous)” after sustained in Threshold column. This could be interpreted as an aggregate value over any length of time.Frequency deviations - recommend adding the word “(continuous)” after 15 minutes’ in Threshold column. This could be interpreted as an aggregate value over any length of time.CIP-008 R1.3 states the entity is to report Cyber Security Incidents to the ES_ISAC. Does the EOP-004 Attachment 2 fulfill this requirement?
Nebraska Public Power District	No	Since the reporting under this standard is for after the fact reporting, the minimum time to report should be the end of the next business day. The combination of the extremely short time periods to file a report and the amount of detail required in attachment 2 will lead to a reduction in the reliability of the BES. System Operators will be forced to take focus off their primary responsibility to respond to the event in order to complete the report within the required timeframe (within an hour for some events). During non-business hours the only personnel available to complete the reports will be those responsible for real-time operation of the BES. Since the background indicates this standard is only for after the fact reporting, the minimum required time to submit the report should be one business day to permit completion of the report without distracting from the real-time operation of the BES. Real-time reporting requirements are covered in other standards and should be to the Reliability Coordinator and from the Reliability Coordinator to NERC. For after the fact reporting, there is absolutely no reliability benefit for requiring reporting to be completed on such a short timeframe. This is especially true due to the amount of data required by Attachment 2.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
NERC Staff	No	<p>The SDT should clarify its use of the term “critical asset” in the Examples section under Part A of the table. The term or versions of the term are used in different contexts in the NERC Reliability Standards. For instance, in CIP-002-1, Requirement 1, the Critical Asset Identification Method is used to identify its critical assets. In EOP-008-0, Requirement 1.3, the applicable entity is required to list its “critical facilities” in its contingency plan for the loss of control center functionality. The team should confirm what it is referring to in this proposed standard. To avoid confusion, the SDT may want to consider using a different term here or better clarify its meaning. Further, there exists the potential to have disparate reporting criteria in this proposed standard relative to the criteria being proposed by the Events Analysis Working Group as part of the Events Analysis Process document dated October 1, 2010. In particular, the following areas should be reconciled between the drafting team and the EAWG to ensure a consistent set of threshold criteria:</p> <p>Voltage Deviations --EOP-004-2: Greater than or equal to 15 minutes --EAWG Process: Greater than or equal to 5 minutes</p> <p>System Separation (Islanding) --EOP-004-2: Greater than or equal to 100 MW --EAWG Process: Greater than or equal to 1000 MW</p> <p>System Separation (Islanding) --EOP-004-2: Does not address intentional islanding as in the case of Alberta, Florida, New Brunswick--EAWG Process: Addresses intentional islanding as in the case of Alberta, Florida, New Brunswick</p> <p>SPS/RAS --EOP-004-2: Does not expressly address proper SPS/RAS operations or failure, degradation, or misoperation of SPS/RAS --EAWG Process: Expressly addresses proper SPS/RAS operations or failure, degradation, or misoperation of SPS/RAS</p> <p>Transmission Loss --EOP-004-2: Identifies Multiple BES transmission elements --EAWG Process: Provides specificity in Category 1a and 1b regarding transmission events</p> <p>Damage or destruction of BES equipment --EOP-004-2: Through operational error, equipment failure, or external cause but not linked to loss of load--EAWG Process: Identifies in Category 2h equipment failures linked to loss of firm system demands</p> <p>Forced intrusion--EOP-004-2: Addressed --EAWG Process: Not addressed</p> <p>Risk to BES equipment --EOP-004-2: Addressed --EAWG Process: Not addressed</p> <p>Detection of a cyber intrusion to critical cyber assets --EOP-004-2: Addressed --</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		EAWG Process: Not addressed
North Carolina Electric Coops	No	This list is too similar and redundant to the DOE requirements and does not provide any additional clarity on recognition of sabotage.
Northeast Power Coordinating Council	No	<p>1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004. What are the examples at the bottom of page 14 supposed to illustrate? Critical Asset should have the appropriate capitalization as being a defined term. Is Critical Asset what is intended to be used here? Should the “a” list be read as ANDs or Ors? Does “loss of all monitoring communications” mean “loss of all BES monitoring “communications”? Does “loss of all voice communications” mean “loss of all BES voice communications?” Are the blue boxes footnotes or examples? Does “forced intrusion” mean “physical intrusion” (which is different from “cyber intrusion”) ? Regarding “Risk to BES Equipment,” request clarification of “non-environmental”. Regarding the train derailment example, the mixture of BES equipment and facility is confusing. Request clarification for when the clock starts ticking. Regarding “Detection of a cyber intrusion to critical cyber assets”, there is concern that this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. Suggest physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Pacific Northwest Small Public Power Utility Comment Group	No	Footnote 1 is missing from Part A, although it is referenced in column 1 row 11. Is this the Examples? The purpose of the Examples is unclear. Is it meant to limit the scope to those enumerated? This is not stated, but if not it should be removed since it adds confusion. What is meant by non-environmental? All external causes of damage or destruction come from the environment by definition. Please specify what is intended or remove the word.
PacifiCorp	No	Energy Emergency requiring firm load shedding - An SPS/RAS could operate shedding firm load but no Energy Emergency may exist. This requires clarification. Transmission Loss - Multiple BES transmission elements. Loss of two transmission lines in the same corridor due to a wildfire could qualify for this reporting. Once again clarification needed.
Pepco Holdings, Inc - Affiliates	No	Some items with one hour reporting (such as Unplanned Control Center evacuation) may be so disruptive to operations that one hour is too short. 4 hours suggested.
PPL Electric Utilities	No	While we think providing an impact event list is beneficial, we would like to see Attachment 1 revised and/or clarified. Refer to response to Question 2 considering duplicate reporting. Regarding impact event 'Damage or destruction of BES equipment' and considering the first example in the 'Examples' section, does 'example a. i.' mean if the BES equipment that is damaged is not identified as a critical asset per CIP-002 that no reporting is required? Clarify the Part A and Part B, specifically: Attachment 1 Part A is labeled 'Actual Reliability Impact'. Does this title mean that for all events listed that the 'threshold for reporting' is only met if the event occurs AND there is an actual reliability impact? As opposed to Part B where the threshold for reporting is met when the event occurs and there is a potential for reliability impact? This could be broad for event 'risk to BES equipment'. Providing as much clarity as possible on the 'threshold for reporting' is

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		beneficial to the industry and will help eliminate confusion with the existing CIP-001 standard regarding 'potential sabotage'.
PPL Supply	No	Attachment 1 Part A is labeled "Actual Reliability Impact". Does this title mean that for all events listed the "threshold for reporting" is only met if the event occurs AND there is an actual reliability impact? As opposed to Part B where the threshold for reporting is met when the event occurs and there is a potential for reliability impact? This could be broad for events like "Risk to BES equipment."
PSEG Companies	No	For many items, there are multiple entities listed with reporting obligations. For example, loss of off-site power to a nuclear plant lists RC, BA, TOP, TO, GO and GOP. This appears to result in the potential for the sending of 6 separate reports within the hour for the same event, which in wide area disturbances overload the recipients. The drafting team should consider revising the lists where possible to a single, or absolute minimum number, entity. Those items reportable OE-417 should be removed from Attachment 1. For example, voltage reduction, loss of load for greater than 15 minutes. The trigger for voltage reduction should be the time of issuance of the directive to reduce voltage in an emergency, not when "identified."
Puget Sound Energy	No	The proposed standard does not adequately ensure that the impact events subject to its requirements are limited to those listed in Attachment 1. In order to ensure that this is true, the term "impact event" should be a defined term and that definition should clearly limit impact events to those listed in Attachment 1.
Santee Cooper	No	The SDT should review the list of events closely to determine if the defined events actually impact the BES. (For example: Is shedding 100 MW of firm load really a threat to the BES?)
SERC OC Standards Review	No	Will all reporting requirements be removed from other standards to avoid duplication? And will all future

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 10 Comment
Group		standard revisions include revisions to this standard to incorporate associated reporting requirements?There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Southern Company - Transmission	No	The time to submit report column needs to be more flexible with time frames. The Entity with Reporting Responsibility column needs to be more descriptive in which there are multiple entitles with hierarchy reporting.
United Illuminating	No	UI agrees but the listing needs to be improved for clarity in certain instances. For example,EOP-004 Attachment 1 Part A - Example iii - uses the phrase “significantly affects the reliability margin of the system.” Significantly is an immeasurable concept and does not provide guidance to the Entity. The phrase “reliability margin” is not defined and is open to interpretation. Perhaps utilize “resource adequacy”, if that is all that intended, or use “adequate level of reliability”.
US Bureau of Reclamation	No	The Attachment is very vague and without modification creates a Pseudo definition of BES equipment in the example provided. The example now indicates that something is BES equipment if it is "Damaged or destroyed due to a non-environmental external cause". Perhaps the example should be reworded to "BES equipment whose operation effects or causes:" and then adjust each of the line items to clarify what was intended. Next, the Attachment A example redefines reportable levels for Risk to BES Equipment - From a non-environmental physical threat as "Report copper theft from BES equipment only if it degrades the ability of equipment to operate correctly". Who makes that determination? Not all events will be known within 24 hours. As example, Risk to BES Equipment - From a non-environmental physical threat may not be known until more thorough examination or investigation takes place. Also the reportable level appears to be defined by the Entity. While agree with that, we will end up with the same criticism from FERC when the level is set to

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>"high" in FERC's mind. The reporting times are unrealistic for complicated events. Notification is reasonable but not reporting. Many organizations's have internal processes the reports must be vetted through before they become public and subject to compliance scrutiny.</p>
We Energies	No	<p>I did not compare this standard to the OE-417 form. Please do not require operators to fill out a second form during an emergency within one hour. Energy Emergency requiring Public appeal...: "Public " is not a defined term. Energy Emergency requiring system-wide voltage...: DP does not control BES voltage. Energy Emergency requiring firm load shed...: TOP does not have load it would shed for an Energy Emergency. Frequency Deviations: Why is a BA reporting? This will be every BA in the Interconnection reporting the same Frequency Deviation. Frequency Deviations: Frequency Trigger Limit is not a defined term, and is not defined in this standard. Loss of Firm Load...: TO and TOP may coordinate or direct load shed, but they do not serve firm load. Damage or destruction of BES... There is no footnote 1 on this page. I assume it is the examples on the page. Are these "examples" of a larger set or are these all that is required? Critical Asset is a defined term. Forced Intrusion: "facility" or Facility? An RC and BA do not have Facilities.</p>
Georgia System Operations Corporation	Yes	<p>We support the concept of Impact Events and listing and describing them in a table. However, we have some concerns. Reporting of impact events should not be applicable to a DP. The timelines outlined in Attachment 1 should be targets to try to meet but it should not be a compliance violation of the reporting requirement if it is not met. Regarding the NOTE before the table, verbal reports and updates should be allowed for other than certain adverse conditions like severe weather as well as adverse conditions. The first priority for all entities should be addressing the effects of the impact event. It may not be possible to assess the damage or the cause of an impact event in the allotted time. All entities should make their best effort to quickly report under any circumstances what they know about the event even if it is not complete. They should be allowed to</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>report up through a hierarchy. The written report should not be issued until adequate information is available. Change "Preliminary Impact Event Report" to "Confidential Impact Event Report."Capitalization throughout this table is inconsistent. Sometimes an event is all capitalized. Sometimes not. It is not in synch with the NERC Glossary. All terms that remain capitalized in the next draft (other than when used as a title or heading) should be defined in the Glossary of Terms Used in NERC Reliability Standards. Examples of inconsistencies: Unplanned Control Center evacuation, Loss of off-site power, Voltage Deviations.-Energy Emergency requiring a public appeal or a system-wide voltage reduction: All The NERC Glossary defines Energy Emergency as a condition when a LSE has exhausted all other options and can no longer provide its customers' expected energy requirements. The events should not be described as an Energy Emergency requiring public appeal or system-wide voltage reductions. If public appeal and system-wide voltage reductions are still an option then all options have not been exhausted, the LSE can still provide its customers' energy requirements, and it is not an Energy Emergency. We suggest using "Energy Emergency Alert" rather than "Energy Emergency."-Energy Emergency requiring firm load shedding: load shedding via automatic UFLS or UVLS would not necessarily be due to an Energy Emergency. Other events could cause frequency or voltage to trigger a load shed. Most likely an entity would be seeing the Energy Emergency coming and would be using manual load shedding. -Forced intrusion and detection of cyber intrusion to critical cyber assets: CIP-008 is not referenced for a forced intrusion. CIP-008 is referenced for a detection of cyber intrusion impact event. Aren't there reportable events per CIP-008 that involve physical intrusion that are not intrusions at a BES facility?-Risk to BES equipment: The threshold states that it is for a non-environmental threat but the examples given are environmental threats. Please clarify.</p>
Manitoba Hydro	Yes	<p>Though R7 indicated Attachment 1 will be reviewed and revised regularly the immediate addition of:"Detection of suspected or actual or acts or threats of physical sabotage"should be added.</p>



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 10 Comment
City of Austin dba Austin Energy	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PNM Resources	Yes	
RRI Energy, Inc.	Yes	
TransAlta Corporation	Yes	

**11. Do you agree with the use of the Preliminary Impact Event Report (Attachment 2)? Please explain in the comment box below.**

**Summary Consideration:** Most commenters who responded to this question disagreed with some aspect of the Preliminary Impact Event Report. The proposed Preliminary Impact Event Report (Attachment 2) generated comments regarding the duplicative nature of the form when compared to the OE-417. The DSR SDT has added language to the proposed form to clarify that NERC will accept a DOE OE-417 form in lieu of Attachment 2 if the responsible entity is required to submit an OE-417 form.

In collaboration with the NERC Event Analysis Working Group (EAWG) the DSR SDT proposes to modify the attachment to eliminate confusion. This revised form will be used as Attachment 2 of the Standard and is the only required information for EOP-004-2 reporting. Further information may be requested through Events Analysis Process (NERC Rules of Procedure), but this information is outside of the scope of EOP-004.

The DSR SDT has also clarified what the form is to be used for with the following language added:

“This form is to be used to report impact events to the ERO.”

Organization	Yes or No	Question 11 Comment
City of Austin dba Austin Energy		Austin Energy would like to see OE-417 incorporated into the electronic form This will reduce the callout of EOP-004-2 and OE-417 forms in our checklists / documents and one form can be submitted to NERC and DOE.
Independent Electricity System Operator		TBD
Ameren	No	It is unclear when this should be used, or why.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
ATC	No	No. NERC does not have the authority to absolve the Functional Entities of the reporting obligations for the DOE Form OE-417. Therefore, there will be duplicate reporting requirements and the one hour timeframes required in Attachment 1 will take valuable resources away from mitigating the event to filling out duplicative paperwork. It is ATC's position that the OE-417 report be used as the main reporting template until NERC and the DOE can develop a single reporting template. Task #14 in the report should be modified to say, "Identify any known protection system misoperation(s)." If this report is to be filed within 24 hrs, there will not be enough time to assess all operations to determine any misoperation. As a case in point, it typically takes at least 24 hrs to receive final lightning data; therefore, not all data is available to make a determination.
ATCO Electric Ltd.	No	Attachment 2 Item 4 implies that an entity is required to analyse and report on an impact event that occurred outside its system. This is not practical as the entity will not have access to the necessary information.
BGE	No	There is considerable difference between this form and OE-417 necessitating that two forms be completed. BGE believes that the purpose of combining the standards was to reduce the number of reporting entities and number of reports to be generated by each entity. BGE believes this fails to accomplish this purpose.
City of Garland	No	The report filed should be the OE-417 ELECTRIC EMERGENCY INCIDENT AND DISTURBANCE REPORT and should be filed only on OE-417 reportable incidents. If this report is implemented as drafted, companies with multiple registration numbers and functions should only have to file one report for all functions and registrations.
Consolidated Edison Co. of NY, Inc.	No	It is not clear why the DOE form cannot be used. NERC should make every effort to minimize paper work for entities responding to system events.
Constellation Power Generation and Constellation Commodities Group	No	It is unclear if an entity has to answer all the questions. In addition, "Preliminary" is not currently included in the report title.
Electric Market Policy	No	There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
ERCOT ISO	No	ERCOT ISO requests the use of a single report format to meet all requirements from NERC and DOE. There is no value added in requiring different reporting to different agencies.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
Exelon	No	Exelon agrees with the use of the report but feels that # 5 should consist of check boxes. #12, 13, and 14 will take more time then allotted by the reporting requirements to acquire, cannot be accomplished in an hour.Attachment 2 should have a provision for the reporting entity to enter (N/A) based on function (see below)Check box #8 A GO/GOP may not have the information to determine what the frequency was prior to or immediately after an impact event. This information should be the responsibility of a TOP or RC.Check box #9A GO/GOP may not have the information to determine what transmission facilities tripped and locked out. This information should be the responsibility of a TO, TOP or RC.Check box #10A GO/GOP may not have the information to determine the number of affected customers or the demand lost (MW-Minutes). This information should be the responsibility of a TO, TOP, or RC.
Great River Energy	No	NERC and the DOE need to coordinate and decide on which report they want to use and whichever report it is needs to include all information required by both entities. The way this standard is currently written there is the potential that two government entities may need to be reported to is a relatively short period of time. It is not clear what benefit providing the Compliance Registration ID number provides. Many of the registered entities employees that will likely have to submit the report, particularly given the one-hour reporting requirement for some impact events, will not be aware of this registration ID. However, they will know for what functions they are registered. We recommend removing the need to enter this compliance registration ID or extending the time frame for reporting to allow back office personnel to complete the form. For item two, please change "Time/Zone:" with "Time (include time zone)". As written it is a little confusing.
Idaho Power Company	No	there should only be on report, utilized OE-417
Indeck Energy Services	No	The form needs to identify whether it is a preliminary or final report. An identifier should be created to tie the final to the preliminary one. Some fields, 1,2 3 5 & 6, are required for the preliminary report and should be labeled as such. With the 1 hour reporting deadline for some events, the details may not be known. 12 & 13 should be required for the final report. 13 should designate whether the cause is preliminary or final. 7-11 & 14 are optional, and the form should state this, and based on some types of events. It's confusing to have irrelevant blanks on the form.
IRC Standards Review Committee	No	Attachment 2 is not referenced in the standard requirements. Is it a part of the standard that an entity must use to file the impact event reports to a specific recipient. If so, this needs to be referenced in the standard.We question the need for using a fixed format for reports that vary from "shedding firm load" to "damaging equipment". The nature of impact events varies from one event to another and hence a fixed format or pre-determined form may not be able to provide the appropriate template that is suitable for use for

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
		all events. We urge the SDT to reconsider the use of Attachment 2 for reporting events, with due consideration to the actual intent of the standard (as pointed out in our comments under Q1).
ISO New England Inc.	No	There is already a DOE requirement to report certain events. There is no need to develop redundant reporting requirements to NERC that cross other federal agency jurisdictions. The heading on page 16 refers to EOP-002, but this is Standard EOP-004. If some questions do not require an answer all of the time, then the form should state that or provide a NA checkbox. While Attachment 1 details some cyber thresholds, Attachment 2 provides no means to report - which is acceptable if cyber incidents are handled by CIP-008 per the comment provided for Question 10. The Event Report Template in Appendix A is different from the most recent version, which is available at: <a href="http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf">http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf</a>
Kansas City Power & Light	No	For easier classification and analysis of events for both external reporting to the ERO and internal reporting for the applicable entity, the form should include Event Type. The DSR SDT should code each event type and include the codes as part of Attachment 1.
Manitoba Hydro	No	Though a “Confidential Impact Event Report” is much needed the Attachment 2 needs refinement. Provide an explanation for each “task”. Isolate and simplify the “Who, When and What” section. Isolate the description of event. Remove items 7 to 10. Modify Attachment 1, add columns to indicate time of event, quantity, restore time, etc as required. The Attachment 1 can be attached to Attachment 2. This could simply and speed the reporting process.
MidAmerican Energy	No	
Midwest ISO Standards Collaborators	No	This form differs from the DOE reporting forms. We do not believe different reporting forms should be required. The DOE form should be sufficient for NERC reporting. It is not clear what benefit providing the Compliance Registration ID number provides. Many of the registered entities employees that will likely have to submit the report, particularly given the one-hour reporting requirement for some impact events, will not be aware of this registration ID. However, they will know for what functions they are registered. We recommend removing the need to enter this compliance registration ID or extending the time frame for reporting to allow back office personnel to complete the form. For item two, please change “Time/Zone:” with “Time (include time zone)”. As written it is a little confusing.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
MRO's NERC Standards Review Subcommittee	No	Number 4 of the reporting form does not take into consideration of potential impact events. Recommend that "Did the impact event originate in your system?" to "Did the impact event originate or affect your system?". This will provide clarity to entities.
Nebraska Public Power District	No	If the standard requires submission of the report within an hour (which is not appropriate), there must be an abbreviated form that can be quickly filled out by checking boxes and not require substantial narrative. The existing form has too much free form text that takes time to enter and with the short timeframe for reporting will distract the entities responsible for real-time reliability of the BES from that task by forcing them to complete after the fact reports. It is unrealistic to expect entities to staff personnel to complete the reporting 24 x 7 for unlikely events, so the task will fall to System Operators who should be focusing on operating the BES at the time of these events instead of providing after the fact reporting to entities that do not have responsibility for real-time operation of the BES. Real-time reporting to the RC and/or BA is covered under other standards and is necessary for the RC to have situational awareness, but is not covered under this standard. The registered entities may report to the proper law enforcement entities when the situation warrants, but again this form is not the appropriate way to handle that reporting requirement.
NERC Staff	No	Item 15: A one-line diagram should be attached to assist in the understanding and evaluation of the event. Two additional items are recommended:--Ongoing reliability impacts/system vulnerability - this would capture areas where one is not able to meet operating reserves or is in an overload condition, below voltage limits, etc. in real-time--Reliability impacts with next contingency - this would capture potential impacts as outlined above with the next contingency.
North Carolina Electric Coops	No	There is already a DOE requirement to report certain events. NERC should not be developing redundant reporting requirements when this information is already available at the federal level from other agencies.
Northeast Power Coordinating Council	No	There is already a DOE requirement to report certain events. There is no need to develop redundant reporting requirements to NERC that cross other federal agency jurisdictions. The heading on page 16 refers to EOP-002, but this is Standard EOP-004. If some questions do not require an answer all of the time, then the form should state that or provide a NA checkbox. While Attachment 1 details some cyber thresholds, Attachment 2 provides no means to report - which is acceptable if cyber incidents are handled by CIP-008 per the comment provided for Question 10. The Event Report Template in Appendix A is different from the most recent version, which is available at: <a href="http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf">http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf</a>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
Pacific Gas and Electric Company	No	PG&E believes the report is duplicative to the OE-417 reporting criteria.
Pacific Northwest Small Public Power Utility Comment Group	No	We found no "Preliminary Impact Event Report" in the posted draft standard, so we assume the question is regarding the "Confidential Impact Report" (Attachment 2). It is unclear what role the form plays, since no requirement refers to it. If this is the form to report impact events per R6, then R6 should reference it. The comment group cautions that the use of the word "confidential" should be carefully considered, since many filled out forms that originally contained the word are now posted on the NERC website for all to see. If there are limits to the extent and/or duration of the confidentiality this should be clearly stated in the form, or the word should be avoided. Protection System misoperation reporting is already covered by PRC-004. Including it here is redundant, and doubly jeopardizes an entity for the same event.
PacifiCorp	No	As previously mentioned all effort should be made to ensure duplicate reporting is not required. OE-417 requirements should be covered by this one form.
Pepco Holdings, Inc - Affiliates	No	The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
PNM Resources	No	PNM believes the report is duplicative to the OE-417 reporting criteria.
PSEG Companies	No	The top of this form should have the following statement added: "This form is not required if OE-417 is required to be filed."
Puget Sound Energy	No	Attachment 2 is not referenced in the requirements of the proposed standard. As a result, it is not clear when its submission would be required.
Santee Cooper	No	If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity.
SERC OC Standards Review Group	No	There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 11 Comment
TransAlta Corporation	No	We recommend the ‘time to Submit Report’ to start when the event is recognized verses when it occurred.
United Illuminating	No	The standard does not appear to require the use of Attachment 2. Placing the form within the Standard may require the use of the Standards Development Process to modify the form. UI suggests the form is maintained outside the Standard to allow it to be adjusted. UI would prefer NERC to establish an internet based reporting tool to convey the initial reports.
US Bureau of Reclamation	No	There is already a reporting form for disturbances. The SDT should reconcile this standard with all the other reporting that is being requested and not add more.
We Energies	No	The data required to assess an impact event thoroughly will often not be available or apparent. Immediate reporting should fall to the RE with assistance/information from the affected entities. There do not seem to be provisions for when it is impossible to take the time to fill out a form or when it is impossible to send a form. I did not compare this standard to the OE-417 form. Please do not require operators to fill out a second form during an emergency within one hour.
WECC	No	The report is duplicative to the OE-417 reporting criteria.
Bonneville Power Administration	Yes	Item 8: list Hz minimum on the second line prior to Hz max since that is the typical frequency excursion order. The Operating Plan is going to have to include the Compliance Registration ID number, since Operating Personnel don’t carry that information around and it is not readily available.
Duke Energy	Yes	However, Attachment 2 is titled “Impact Event Reporting Form”.
E.ON Climate & Renewables	Yes	Suggestions on the form: if an entity has not had time to fully determine the cause of an Impact Event such as for “Question # 4: Did the impact event originate in your system, yes or no?”, perhaps more time is needed that 24 hours to determine the cause.
FirstEnergy	Yes	Although we agree with the report, it should be clear that organizations with many registered entities can submit one report to cover multiple entities under one parent company.
Georgia System Operations	Yes	We support having one form for reporting however every applicable entity should not be required to fill it out and send it to NERC. See previous comments about hierarchical reporting. The title of the report is



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
Corporation		"Confidential Impact Event Report." Some suggested modifications: The form could have a blank added to enter the event "description" as described in the first column of Attachment 1. The first seven lines contain information that would most likely be filled out every time. The other lines except line 13 may or may not be applicable every time. It is required (R3) for an entity to access the initial probable cause of all impact events so line 13 will most likely be filled out every time. Please move the probable cause line up to line 7 or 8 (depending on if the event description line is added).
PPL Electric Utilities	Yes	For ease, timeliness, and accuracy of reporting an application with an easy to use interface would be preferred. If the reporting is done via an application, the ability to enter partial data, save and add additional info prior to submission would be helpful. Additionally, an application with drop downs to select from for impact event, NERC function, etc would be helpful. #1 - Is the 'Compliance Registration ID number' the same as the NCR number? If this is required, include as separate entry. #2 - is this the date of occurrence or detection?
Arizona Public Service Company	Yes	
Dynergy Inc.	Yes	
Green Country Energy	Yes	
Luminant Energy	Yes	
PacifiCorp	Yes	
PPL Supply	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 11 Comment
RRI Energy, Inc.	Yes	
Southern Company - Transmission	Yes	

**12. The DSR SDT has replaced the terms “disturbance” and “sabotage” with the term “impact events”. Do you agree that the term “impact events” adequately replaces the terms “disturbance” and “sabotage” and addresses the FERC directive to “further define sabotage” in an equally efficient and effective manner? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst commenters who responded to this question. Several commenters expressed concern that the definition should be added to the glossary. The DSR SDT has proposed a definition for “Impact Events” to support Attachment 1 as follows:

“An Impact Event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

The DSR SDT has proposed this definition for inclusion in the NERC Glossary for “Impact Event”. The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard.

Several commenters expressed concern that the team did not define ‘Sabotage’ and FERC directed that the modifications to this standard include a definition of sabotage. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This will result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The Impact Events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

Some commenters were concerned that some of the events that require reporting that were specifically listed in the previous version of the standard are not included in the revised standard. Attachment 1, Part A is to be used for those actions that have impacted the electric system and in particular the section “Damage or destruction to equipment” clearly defines that all equipment that intentional or non intentional human error be reported. Attachment 1, Part B covers the similar items but the action has not fully occurred but may cause a risk to the electric system and is required to be reported.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
Bonneville Power Administration		The definition of an impact event in EOP-004-2 seems clear, however the term "mis-operation" still may imply intent in the action of an individual. The SDT should consider further defining that term.
Independent Electricity System Operator		We do not have a view on what name is assigned to the reportable events for so long they are listed in Attachment 1. However, the heading of the Table contains the words "Actual Reliability Impact", which does not accurately reflect the content inside the table and which may introduce confusion with the term "impact event". We suggest to change them to "Reportable Impact Events".As we read the Summary of Concept and Assumption, there appears to be a slightly different lists at the bottom of P. 21. With these events included, the meaning of "impact event" would seem to be too broad. Rather than calling those events listed in Attachment 1 "impact events", why not simply call them "reportable events"?
CenterPoint Energy	No	CenterPoint Energy does not agree that the term "impact event" adequately replaces "disturbances" and "sabotage". CenterPoint Energy suggests that just as the SDT has come to consensus on a concept for impact event, a definition could be derived for sabotage. "Potential", as used in the SDT's concept, is a vague term and indicates an occurrence that hasn't happened. Required reporting should be limited to actual events. CenterPoint Energy offers the following definition of "sabotage": "An actual or attempted act that intentionally disrupts the reliable operation of the BES or results in damage to, destruction or misuse of BES facilities that result in large scale customer outages (i.e. 300MW or more)."
City of Garland	No	<p>1 In keeping with a Results Based Standard, the impact event should be a trigger for filing a report. At the time of the event, one may not know if the event was caused by sabotage. Sabotage that does not affect the BES should not be a reportable event.</p> <p>2. To comply with the Commissioners request to define sabotage, Impact Event does not adequately replace "sabotage". If someone reports sabotage, people universally have a concept that someone(s) have taken some type of action to purposely harm, disable, cripple, etc something. Impact Event does not convey that same concept.</p> <p>3. If Sabotage is left as a "trigger," it should not include minor acts of vandalism but only acts that impact reliability of the BES</p>
Consolidated Edison Co. of NY, Inc.	No	The definition is open for interpretation beyond events identified in Attachment 1. In addition, all Standards are supposed to have Rationales. In the Draft Standard, the Rationales do not address the concept of Potential, and how it relates to an actual system event. Additional work needs to be done addressing the

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
		meaning of “potential”.
Duke Energy	No	We disagree with the stated concept of “impact event”. Including the phrase “or has the potential to significantly impact” in the concept makes it impossibly broad for practical application and compliance. By not attempting to define “sabotage”, the standard creates a broad reporting requirement. “Disturbance” is already adequately defined. “Sabotage” should be defined as “the malicious destruction of, or damage to assets of the electric industry, with the intention of disrupting or adversely affecting the reliability of the electric grid for the purposes of weakening the critical infrastructure of our nation.”
Dynergy Inc.	No	The term is fine but FERC wants more specific examples. GO/GOP can't determine the effect on the BES.
E.ON Climate & Renewables	No	Acts of Sabotage is still not defined and if the registered entities are required to reports acts of sabotage, NERC still needs to define this further.
ERCOT ISO	No	
Exelon	No	Need to better define sabotage and provide examples, the term “impact events” create confusions as to what constitutes an event. The definition of impact event is vague and needs to be quantified or qualified with a term such as “significant”. Otherwise, almost any event could be deemed to be an impact event. Attachment 1 needs to clearly define that damage or destruction of BES equipment does not include cyber sabotage. Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security - Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard. In general, all impact events need to be as explicit as possible in threshold criteria to eliminate any interpretation on the part of a reporting entity. Ambiguity in what constitutes an "impact event" and what the definition of "occurrence" is will ultimately lead to confusion and differing interpretations.
FirstEnergy	No	For the most part we support this definition of impact events. However, we have the following suggestions:1. We believe that it warrants an official NERC glossary definition. 2. The term "potential" in the definition should point to the specific events detailed in Attachment 1 Part B.3. Since the standard does not cover environmental events, the phrase "environmental conditions" in the definition is not an impact event in the context of this standard.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
Great River Energy	No	We believe the SAR scope regarding addressing sabotage has not been addressed at all. It appears that impact event essentially replaces sabotage. This standard needs to make it clear that sabotage, in some cases, cannot be identified until an investigation is performed by the appropriate policing agencies such as the FBI. Intent plays an important role in determining sabotage and only these agencies are equipped to make these assessments.
Green Country Energy	No	Yes and no ... Yes impact events is an adequate term however since it is restrained by the tables it may be helpful to define the term and scope of the term to be more inclusive of sabotage events.
Indeck Energy Services	No	Impact Events is OK. It needs to be balloted as a definition for the Glossary like Protection System.
IRC Standards Review Committee	No	This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement's and other specialized agencies', including international agencies', role in defining acts of sabotage and not hold the registered entity wholly responsible to do so.
ISO New England Inc.	No	The use of the term "impact events" has simply replaced the terms "disturbance" and "sabotage", and has not further defined sabotage as directed by FERC. We do feel that "impact events" needs to be a defined term. While we agree with the SDT's new direction, the FERC directive has not been met. This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement and other specialized agencies, including international agencies roles in defining acts of sabotage, and not hold the registered entity wholly responsible to do so.
Luminant Energy	No	The term "Impact Event" does not adequately replace the term "Sabotage" The Impact Events table seems to provide the definition of the term "Impact Event". This table does not include sufficient definition for actual sabotage events. Additionally, it does not include any provision for suspected sabotage events. Assuming the Damage or Destruction of BES Equipment event type is intended to cover actual sabotage, the Threshold for Reporting column should include specific levels of materiality that are specific to Functional Entity. For instance, a GO and GOP could have a MW level to define materiality as a GO or GOP cannot assess impact to an IROL or system reliability margin due to equipment damage. A threshold value consistent with "Generation Loss" in the proposed EOP-004 Attachment 1 would be appropriate.
Manitoba Hydro	No	The majority of the items listed in Attachment 1 are typically and historically operating events. Yes these are all "impact events". Sabotage, cyber and security are typically viewed as separate events. These events are

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
		not part of “a typical day of BES operations”. These are outside event and though qualify as “impact events” should still be treated separately.
Midwest ISO Standards Collaborators	No	We believe the SAR scope regarding addressing sabotage has not been addressed at all. It appears that impact event essentially replaces sabotage. This standard needs to make it clear that sabotage, in some cases, cannot be identified until an investigation is performed by the appropriate policing agencies such as the FBI. Intent plays an important role in determining sabotage and only these agencies are equipped to make these assessments.
NERC Staff	No	NERC staff is concerned with the ambiguity of the term “impact event.” The definition of the term is not clear, in part because it includes using the words “impact” and “event” (and thus violates the frowned-up practice of using a word to define the word itself). NERC staff recommends the SDT consider using the term “Event.” The following definition (modified from the one used the INPO Human Performance Fundamentals Desk Reference, P. 11) would apply: Event: “An unwanted, undesirable change in the state of plants, systems or components that leads to undesirable consequences to the safe and reliable operation of the Bulk Electric System. ”Supporting statement following the definition: “An event is often driven by deficiencies in barriers and defenses, latent organizational weaknesses and conditions, errors in human performance and factors, and equipment design or maintenance issues.” Further, if this is intended for use in this standard, it should be presented as an addition to Glossary to avoid confusion with the use of the term event in other standards. Of course, this would require an analysis of how the term “Event” as defined herein would affect the other standards to which the term is used. In the end, this is the cleanest manner for the standards.
Northeast Power Coordinating Council	No	The use of the term “impact events” has simply replaced the terms “disturbance” and “sabotage”, and has not further defined sabotage as directed by FERC. We do feel that “impact events” needs to be a defined term. While we agree with the SDT’s new direction, the FERC directive has not been met. This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement and other specialized agencies, including international agencies roles in defining acts of sabotage, and not hold the registered entity wholly responsible to do so.
Pacific Gas and Electric Company	No	PG&E believes Attachment 1 Part A or B do not clearly specify “sabotage” events, other than “forced entry” and the proposed definition of “impact event” does not meet FERC’s directive to “further define sabotage” nor does it take into consideration their request to address the applicability to smaller entities.
Pacific Northwest Small Public	No	The comment group fails to see how changing the words meet the directive. Sabotage implies an organized

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
Power Utility Comment Group		intentional attack that may or may not result in an electrical disturbance. The distinction between sabotage and vandalism is important since sabotage on a small system may be the first wave of an attack on many entities. The proposed standard asks us to treat insulator damage caused by a frustrated hunter (an act of vandalism) the same as attack by an unfriendly foreign government (an act of sabotage). The comment group does not agree that these should be treated equally.
Pepco Holdings, Inc - Affiliates	No	The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
PNM Resources	No	PNM believes the proposed definition of “impact event” does not meet FERC’s directive to “further define sabotage” nor does it take into consideration their request to address the applicability to smaller entities. Attachment 1 Part A or B do not clearly specify “sabotage” events, other than “forced entry”.
Puget Sound Energy	No	With some of the tight timeframes for reporting, it is reasonable to focus on impact rather than motivation. Requiring further analysis of the event in order to assess the possibility that the event was caused by sabotage, however, may be necessary to address FERC’s concerns with respect to sabotage.
Santee Cooper	No	The term "impact events" needs to be more clearly defined.
US Bureau of Reclamation	No	The two are distinctly different. Disturbances are what happened, sabotage is why. We can easily tell what happened. Determining why it happened (e.g. sabotage) takes time.
We Energies	No	Impact Event could replace disturbance and sabotage but not in its present form. The proposed definition of impact event “An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.” Is too vague. The “potential to impact the reliability” is too broad and open to interpretation. It needs to be specific so entities know what is and is not an impact event and so an auditor clearly knows what it is. Define “impact event” as the items listed in Attachment 1. As you have done, focusing on an event’s impact on reliability is more important than determining an individual’s intent (sabotage v.s. theft).
WECC	No	The proposed definition of “impact event” does not meet FERC’s directive to “further define sabotage” nor does it take into consideration their request to address the applicability to smaller entities. Attachment 1 Part A or B do not clearly specify “sabotage” events, other than “forced entry”. The purpose of CIP-001-1 and its requirements is to address the specific issue of possible sabotage of BES facilities. This is entirely different



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
		than a “disturbance” or an “event” on the BES. The proposed definition for “impact events” is essentially any event that has either impacted the BES or has the potential to impact the BES, caused only by three specific things; equipment failure or misoperation, environmental conditions, or human action. Several of these “impact events could be a result of sabotage. Actual or potential sabotage clearly poses a risk to the reliability of the BES. It is important that the risks related to sabotage be reflected in either EOP or CIP
Ameren	Yes	However, the term Impact Event should be a new defined term. When the SDT determines this, it should use the term consistently on both pages 5 and 21 of the SDT document.
ATC	Yes	Yes, if ATC’s recommended changes are made to Attachment 1 and the Standard.
BGE	Yes	The defined term “impact events” should be capitalized throughout the document to identify it as a defined term. Additionally, BGE has noted in several comments that another term is used instead of “impact events”. These terms should be eliminated and use “impact events” instead.
Electric Market Policy	Yes	The use of the term “impact events’ has simply replaced the terms “disturbance” and “sabotage” and has not further defined sabotage as directed by FERC. We do feel that impact events needs to be a defined term.
Georgia System Operations Corporation	Yes	The new term is much more clear than those two terms. This will improve uncertainty and confusion regarding whether or not something should be reported.
Kansas City Power & Light	Yes	Should the word disturbance be removed from the title of EOP004-2 to avoid confusion and simply be called Impact Event and Assessment, Analysis and Reporting.
MRO's NERC Standards Review Subcommittee	Yes	As an industry we have looked at sabotage as a sub component of a disturbance. Sabotage is hard to measure since it is based on a perpetrator's intent and thus very hard to determine.
Nebraska Public Power District	Yes	I agree there is a lot of interpretation and confusion as to what sabotage or a Cyber Incident is, so would welcome better clarity. Whether “impact events” can more effectively clarify, is yet to be seen. “it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.” “An impact event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences.” I do know that Cyber Sabotage may take time or days to become aware so not sure

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 12 Comment
		how that might expedite reporting and awareness.
PPL Electric Utilities	Yes	Refer to clarification requested in question 10 comments.
RRI Energy, Inc.	Yes	Agree. However, strongly encourage this to be made into a defined term in the Glossary of Terms.
SERC OC Standards Review Group	Yes	We do feel that this needs to be a defined term
United Illuminating	Yes	The term impact event can substitute for sabotage and disturbance. The use of Forced Intrusion is a bright line for reporting.
American Electric Power (AEP)	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Idaho Power Company	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 12 Comment
MidAmerican Energy	Yes	
North Carolina Electric Coops	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
PPL Supply	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	

13. The DSR SDT has combined EOP-004 and CIP-001 into one standard (please review the mapping document that shows the translation of requirements from the already approved versions of CIP-001 and EOP-004 to the proposed EOP-004), EOP-004-3 and retiring CIP-001. Do you agree that there is no reliability gap between the existing standards and the proposed standard? Please explain in the comment box below.

**Summary Consideration:** While a majority of commenters who responded to this question support combining the two standards, some commenters suggested that in combining the standards, the team left some gaps in coverage with respect to the types of events that must be reported. The DSR SDT believes that combining EOP-004 and CIP-001 does not introduce a reliability gap between the existing standards and the proposed standard and the industry comments received confirms this. Some events that were specifically identified in the original standard (such as a bomb threat) are covered more generically in the revised standard. This modification encourages entities to focus on the ‘types’ of events that may be impactful rather than having a finite list that may omit an event that couldn’t be anticipated when drafting the requirements.

The decision to eliminate the term sabotage from the standard and the retirement of CIP-001 should alleviate all concerns regarding the term sabotage and its definition. The DSR SDT believes that “observation of suspicious activity” and “bomb threat” is considered to be included in Part B – “Risk to BES equipment from a non-environmental physical threat”. We have added “and report of suspicious device near BES equipment” to note 3 of the “Attachment 1, Potential Reliability – Part B”.

Organization	Yes or No	Question 13 Comment
WECC		A potential gap may exist. Attacks on BES facilities, via either vandalism or sabotage, are very different events than impact events on the system. From a Compliance standpoint, a revised standard to address the FERC directive on sabotage should be developed as an EOP standard (that is grouped with 693 Standards) rather than as a CIP Standard (CIP-001-1).
Ameren	No	It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
		in the existing standards.
Bonneville Power Administration	No	BPA supports the concept behind the revisions to EOP-004-2. Creating a single reporting methodology will improve the processes and lead to more consistency. BPA recommends that the Standards Drafting Team (SDT) coordinate any revisions in the reporting requirements with those found in CIP-008-3 to ensure that there are no conflicts. BPA asks the SDT to consider the impact of these changes on CIP-008-3 and work with the CIP SDT to ensure that the wording of the two requirements is similar and clear. Based on Attachment 1 part A of EOP-004-2, certain cyber security events, intrusions for example, would have to be reported under both EOP-004-2 and CIP-008-3. That puts a burden on a Registered Entity to take additional steps to coordinate reporting or face potential compliance risk for correctly reporting an event under one standard and failing to report it under the other standard. The mapping document had errors: a. CIP-001 R1 to EOP-004 R2.9 (annual vs quarterly). b. EOP-004-1 R2 was translated to R2 & R3 of version 2. c. EOP-004-1 R3 was translated to R6 of version 2 (which doesn't say to whom to report).
City of Garland	No	EOP-004-1 R2 did not get translated to EOP-004-2 R2 - table states it is mapped to R1
E.ON U.S. LLC	No	The Version History contained with EOP-004-2 indicates that CIP-001-1 and EOP-004-1 are "Merged", however, the actions do not reflect the retirement of CIP-001-1a and therefore, it is unclear if there will be remaining redundancies or potential gaps with the new version EOP-004-2 and CIP-001-1a.
Electric Market Policy	No	Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity.
Exelon	No	Reporting form doesn't allow for investigations which result in no impact events found or identified.
Georgia Transmission Corporation	No	The only two events that apply to a TO are the ones related to CIP:1. Forced intrusion (report if motivation cannot be determined, i.e. to steal copper)2. Detection of a cyber intrusion to critical cyber assets ( criteria of CIP-008)Everything in this standard applies to a TOP and therefore E-004-2 and CIP-001 should not be combined

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
Great River Energy	No	It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than in the existing standards.
Indeck Energy Services	No	Bomb threat has totally been lost.
Independent Electricity System Operator	No	We do not agree with the mapping. The proposed mapping attempts to merge the reporting in CIP-001-1 which has more of an on-going awareness nature to alert operating and government authorities of suspected sabotage to prompt investigation with a possible aim to identify the cause and develop remedies to curb the sabotage/events. The proposed EOP-004-2 appears to be more of a post-event reporting for need-to-know purpose only. This is not consistent with the purpose of the SAR.
ISO New England Inc.	No	Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by the NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity. EOP-004-3 should be EOP-004-2.
Luminant Energy	No	CIP-001-1 R3.1 includes instructions associated with the DOE OE-417 form. EOP-004-2 R2.6 should include the DOE as an example of an external organization requiring notification. Additionally, the Rationale for R1 discusses the possibility of one electronic form satisfying US entities with related disturbance reporting requirements but does not include any information about the likelihood of this outcome. Please elaborate on the process required to combine these reports.
Midwest ISO Standards Collaborators	No	It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than in the existing standards.
North Carolina Electric Coops	No	
Northeast Power Coordinating Council	No	Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by the NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity. EOP-004-3 should be EOP-004-2.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
Pepco Holdings, Inc - Affiliates	No	The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
Santee Cooper	No	It is very difficult to assess this question with the standard as currently written.
SERC OC Standards Review Group	No	
US Bureau of Reclamation	No	The two could be combined with no reliability gap based on the concept rather than the proposed standard. As the standard is currently written, there is a reliability gap. Consider that after the fact reporting of a sabotage event (other than criminal acts which may have been witnessed) usually take some time to investigate and analyze.
ATC	Yes	ATC agrees with this effort and does not currently see a reliability gap
BGE	Yes	None.
CenterPoint Energy	Yes	CenterPoint Energy agrees that there is no reliability gap between the existing standards and the proposed standard. However, CenterPoint Energy believes that the SDT went too far in developing the proposed EOP-004-2 and added additional unnecessary requirements. If the comments made above to Q1 - Q12 were to be incorporated into the proposed Standard, CenterPoint Energy believes the product would be closer to a results based Standard with no reliability gap.
City of Austin dba Austin Energy	Yes	If we can use OE 417 for NERC and DOE we do not perceive a reliability gap.
Georgia System Operations Corporation	Yes	The new single standard will cover all necessary reporting requirements that are in the current two standards. They are being combined into EOP-004-2 not EOP-004-3.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 13 Comment
Green Country Energy	Yes	With the provision that definition and scope of "impact event" are developed and tables adjusted as needed to address FERCs concerns specifically ."(1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event."
MRO's NERC Standards Review Subcommittee	Yes	Within the above question, the SDT is asking about EOP-004-2 not -3.
Nebraska Public Power District	Yes	Appears they only changed R1 for CIP-001 and moving R2-R4 directly over to EOP-004-2. R1 adds much more detail on our part for a company operating plan but would definitely help some of the present confusion.
RRI Energy, Inc.	Yes	Assume reference to EOP-004-3 in the question 13 was meant to reference version 2 (EOP-004-2).
American Electric Power (AEP)	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Duke Energy	Yes	
Dynegy Inc.	Yes	
ERCOT ISO	Yes	
FirstEnergy	Yes	



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
Idaho Power Company	Yes	
Kansas City Power & Light	Yes	
MidAmerican Energy	Yes	
NERC Staff	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Puget Sound Energy	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
United Illuminating	Yes	
We Energies	Yes	

**14. Do you agree with the proposed effective dates? Please explain in the comment box below.**

**Summary Consideration:** While most stakeholders who responded to this question supported the 12 months originally proposed for entities to become compliant, the drafting team has revised this to 6 months. The DSR SDT feels that six months and not more than nine months is an adequate time frame. The current CIP-001 plan is adequate for the new EOP-004 and training should be met in the proposed timeline.

The Implementation Plan was developed for the revised Requirements, which do not include an electronic “one-stop shopping” tool. This topic is to be addressed in the proposed revisions to the NERC Rules of Procedure.

Organization	Yes or No	Question 14 Comment
Independent Electricity System Operator		We do not agree with the proposed standard. We therefore are unable to agree on any implementation plan.
City of Garland	No	Do not agree with this proposed draft - instead of combining 2 standards to gain efficiency, this expands the standard with unnecessary paperwork, drills, training, etc.
Constellation Power Generation and Constellation Commodities Group	No	Based on the drastic differences between the previous revisions to these standards, and this proposed revision, 24 months would be a more reasonable timeframe for an effective date.
IRC Standards Review Committee	No	If the training and Operation Plan requirements are adopted as proposed, this may not be sufficient time for some entities to comply, particularly those with limited number of staff but perform functions that have multiple event reporting requirements.
ISO New England Inc.	No	If the training and Operation Plan requirements are adopted as proposed, this may not allow sufficient time for some entities to comply, particularly those with limited number of staff, but perform functions that have multiple event reporting requirements.
Kansas City Power & Light	No	April 2011 is too soon for considerations applicable to the creation of an Operating Plan.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 14 Comment
Manitoba Hydro	No	Though CIP-001-1a already contained provisions for sabotage response guidelines, the new EOP-004-2 R2 (2.1 to 2.9) will require reexamination of existing policies to remain compliant. Upon the approval of Attachment 1, the existing disturbance guidelines will also have to be reexamined. With the addition of R3 (Identify and assess), R4 (Drills) and R5 (Training), will also require redevelopment of existing processes.
NERC Staff	No	In order to provide explicit dates, the language should be modified to state: “First calendar day of the first calendar quarter one year after the date of the order providing applicable regulatory authority approval for all requirements.”
Northeast Power Coordinating Council	No	The effective dates in Canada need to be defined. The first bullet should be sufficient. If the training and Operation Plan requirements are adopted as proposed, this may not allow sufficient time for some entities to comply, particularly those with limited number of staff, but perform functions that have multiple event reporting requirements.
Puget Sound Energy	No	There are no effective dates listed in the proposed standard. The proposed effective date should allow at least one year for entities to implement the requirements of the standard. In addition, if requirement R1 remains, then the requirement to implement an operating plan should only be triggered by the ERO’s finalization of the form and system for reporting impact events and should provide at least six months for the implementation of the operating plan.
Santee Cooper	No	With the proposed training and drill requirements in the current written standard, one year is not enough time.
United Illuminating	No	UI believes the implementation should be staged. For R1 and R2: First calendar day of the first calendar quarter one year after applicable regulatory authority approval for all. This provides sufficient time to draft a procedure Then time needs to be provided to provide training prior to implementation of R3 and R6. UI believes two calendar quarters should be provided to complete training; therefore R3and R6 is effective six calendar quarters following regulatory approval. Implementation for R4 should state that the initial calendar year begins on the date R2 is effective and entities have 12 months following that date to complete their first drill. R5 requires training once per calendar year. Implementation for R5 should state that the initial calendar year begins on the date R2 is effective and entities have 12 months following that date to complete their first drill.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 14 Comment
US Bureau of Reclamation	No	There is a 15 month training requirement. If the standard goes into effect in one year, most entities will not have had an opportunity to develop their new Operating Plans and train their staff. The effective date should recognize Operating Plans need to be revised and then training needs to be implemented. The most aggressive schedule is 18 months. Two years would be more appropriate. The implementation date could recognize the Operating Plan development as one phase and the training as the second.
ATC	Yes	Yes, if ATC's recommended changes are made to the Standard. However, if the changes are not supported then ATC recommends that the implantation time be changed to two years. Entities will need time to develop both the plan called for in this standard and to train the personnel identified in the plan.
BGE	Yes	None.
Exelon	Yes	Agree with the proposed implementation date. A 12 month implementation will provide adequate time to generate, implement and provide any necessary training by a registered entity.
Ameren	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
Bonneville Power Administration	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Duke Energy	Yes	
Dynergy Inc.	Yes	
E.ON Climate & Renewables	Yes	
Electric Market Policy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 14 Comment
ERCOT ISO	Yes	
FirstEnergy	Yes	
Georgia System Operations Corporation	Yes	
Great River Energy	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Indeck Energy Services	Yes	
Luminant Energy	Yes	
MidAmerican Energy	Yes	
Midwest ISO Standards Collaborators	Yes	
MRO's NERC Standards Review Subcommittee	Yes	
North Carolina Electric Coops	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 14 Comment
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
RRI Energy, Inc.	Yes	
SERC OC Standards Review Group	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
We Energies	Yes	
WECC	Yes	

**15. Do you have any other comments that you have not identified above?**

**Summary Consideration:** The DSR SDT has met with the EAWG and has put in place a process to ensure the cooperation and coordination between the DSR SDT and the EAWG. The impact event list is comprehensive and addresses the needs of the EAWG and EOP-004.

There were concerns expressed that the impact event list should include deliberate acts against infrastructure. The impact list includes “Risk to BES equipment from a non-environmental physical threat” the DSR SDT feels that this is inclusive of deliberate acts against infrastructure.

During discussions around the use and definition of the term sabotage, the DSR SDT considered the NRC definition and decided to eliminate the use of the term sabotage from EOP-004 and replaced it with impact events. The DSR SDT has developed a definition for “Impact Events” to support Attachment 1 as follows:

“An Impact Event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

The DSR SDT has proposed this definition for inclusion in the NERC Glossary for “Impact Event”. The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This will result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The Impact Events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive. Attachment 1, Part A is to be used for those actions that have impacted the electric system and in particular the section “Damage or destruction to equipment” clearly defines that all equipment that intentional or non intentional human error be reported. Attachment 1, Part B

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

covers the similar items but the action has not fully occurred but may cause a risk to the electric system and is required to be reported.

The industry commented on the need for e-mail addresses and fax numbers for back up purposes. These details were added to the standard and will also be covered in the implementation plan.

The proposed ballot in December was incorrect and has been deleted from the future development plan. The plan was updated with the correct project plan dates.

Organization	Yes or No	Question 15 Comment
Indeck Energy Services		Good start on a unified event reporting standard!
IRC Standards Review Committee	No	The standards should be changed to define what a “disturbance” is for reporting in EOP-004. Also, sabotage reporting requirements in CIP-001 should be rescinded as EOP-004 already has such requirements.
PSEG Companies		
Arizona Public Service Company	No	
ATCO Electric Ltd.	No	
Duke Energy	No	
Electric Market Policy	No	
FirstEnergy	No	
Independent Electricity System Operator	No	
Luminant Energy	No	



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
Manitoba Hydro	No	
PacifiCorp	No	
PPL Supply	No	
RRI Energy, Inc.	No	
United Illuminating	No	
Ameren	Yes	We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting.
American Electric Power (AEP)	Yes	The standard needs to be modified to allow the ability for one entity to report on behalf of other entities. For example the loss of Generation over the threshold could be reported by the RC opposed to the GO individually, if mutually agreed upon before the fact.
ATC	Yes	ATC believes that it is not evident in this draft that the SDT has worked collaboratively with the Events Analysis working group to leverage their work. ATC believes that NERC must coordinate this project and the EAWG efforts. The EAWG is proposing to modify NERC Rules of Procedure but the SDT is suggesting requirement for the ERO be build within the standard. We believe that the Rules of Procedure is the proper course to take to for identifying NERC obligations, but what is clear is that NERC itself does not seem to have an overall plan for event reporting and analysis. Lastly, ATC would like to see the SDT expand the mapping document to include the work of the EAWG. The industry needs to be presented with a clear picture as to how all these things will work together along with their reporting obligations. The definition of an “impact event” needs to be revised. First, if these events are to include any equipment failure or mis-operation that impacts the BES, the standard is requiring more than is intended based upon the reading of the requirements. PRC-004 already covers the reporting of protection system mis-operations, and if reading this definition verbatim, it would lead one to conclude that those same mis-operations reported under PRC-004 shall also be reported under EOP-004. The definition should be revised to something like: “An impact event is a system disturbance affecting the Bulk Electric System beyond loss of a single element under normal operating conditions and does not include events normally reported under PRC-004. Such events may be caused by...”

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
BGE	Yes	One item that is properly addressed is the removal of Load Serving Entity from the Applicable Functional Entities. There may be a need to provide some guidance to Functional Entities when there are separate Transmission Owners and Transmission Operators or Generation Owners and Generation Operators. If they are separate, there may be redundancy in reporting. From the documentation, it doesn't seem like the SDT are combining all reports into one form as we would like to see. In the rationale for R1 section, it talks of getting both forms (NERC and OE-417) together in one document (however it sounds like the forms within the document are still separate), available electronically, which only seems like a step forward. However, it does not take away the confusing process for the operators of which part of the form would need to be filled, who should be set this form depending on what part is filled, if one part of the form is filled out do the other parts need to be filled, etc. If the forms cannot be consolidated, BGE would rather the forms be separate to reduce confusion. BGE believes all these reports should require one form with one set of recipients, period. This may mean that NERC needs to get DOE to modify their OE-417 form.
Bonneville Power Administration	Yes	The document retention times in EOP-004-3 should be spelled out more clearly. The Compliance summary does so (but needs some punctuation clarification regarding investigation), the SDT should consider making that part of the requirements or clarifying the wording in the requirements.
CenterPoint Energy	Yes	CenterPoint Energy appreciates the efforts of the SDT in removing outdated and unnecessary language from the existing EOP-004 standard. Additionally, CenterPoint Energy urges the SDT to also remove the proposed "how to" prescriptive requirements. CenterPoint Energy believes the SDT team's focus should be on drafting a results-based standard for reporting actual system disturbances and acts of sabotage that disrupt the reliable operation of the BES. The SDT should not delve into trying to identify a list of events that have a potential reliability impact. As stated in response to Q10, CenterPoint Energy strongly believes that cyber-related events should not be in the scope of this standard since they are already required to be identified and reported to appropriate entities under CIP-008. Excluding cyber events from this standard further supports the elimination of redundancies within the body of standards.
City of Garland	Yes	Do not agree with this proposed draft - instead of combining 2 standards to gain efficiency, this expands the standard with unnecessary paperwork, drills, training, etc. For reports required under this standard, companies with multiple registration numbers and functions should only have to file one report for all functions and registrations.
Consolidated Edison Co. of NY, Inc.	Yes	Overriding Comment and Concern: It is absolutely essential that the work on EOP-004 and that on the NERC Event Analysis Process (EAP) be fully coordinated. We find that there are a number of inconsistencies between these two documents. The EAP and EOP-004 are not aligned. In order to operate and report

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		effectively entities need consistent requirements.
Constellation Power Generation and Constellation Commodities Group	Yes	As stated earlier, the “summary of concepts” for this latest revision, as written by the SDT, includes the following items: o A single form to report disturbances and impact events that threaten the reliability of the bulk electric system o Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements o Clear criteria for reporting o Consistent reporting timelines o Clarity around of who will receive the information and how it will be used. Each and every requirement should be mapped to one of these 5 items; otherwise, it should not be included in this standard. Summarizing all of the comments above, Constellation Power Generation proposes the following revision to EOP-004-2:1. Title: Impact Event and Disturbance Assessment, Analysis, and Reporting 2. Number: EOP-004-2 3. Purpose: Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES). 4. Applicability 4.1. Functional Entities:4.1.1. Reliability Coordinator 4.1.2. Balancing Authority 4.1.3. Transmission Operator 4.1.4. Generator Operator 4.1.5. Distribution Provider 4.1.6. Electric Reliability Organization. Requirements and Measures R1. The ERO shall establish, maintain and utilize a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness.R2. Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 2.1. Method(s) for identifying impact events listed in Attachment 2.2. Method(s) for assessing cause(s) of impact events listed in Attachment 12.3. Method(s) for making internal and external notifications should an impact event listed in Attachment 1 occur. 2.4. Method(s) for updating the Operating Plan.2.5 Method(s) for making operation personnel aware of changes to the Operating Plan.R3. Each Applicable Entity shall implement their Operating Plan(s) to identify and assess cause of impact events listed in Attachment 1.R4. Each Applicable Entity shall provide training to all operation personnel at least annually.R5. Each Applicable Entity shall report impact events in accordance with its Operating Plan created pursuant to Requirement 2 and the timelines outlined in Attachment 1.
Dynergy Inc.	Yes	This does not address the inability of a GO/GOP to determine effects on the BES. Surrounding BES knowledge is limited for a GO/GOP.
E.ON Climate & Renewables	Yes	Refrain from having redundant reporting forms if at all possible. This can create confusion and lead to unnecessary penalty amounts and violations for registered entities. Potential” impacts of an event on the BES need to be clearly defined in the standard.
E.ON U.S. LLC	Yes	The new standard should incorporate all other disturbance, sabotage, or “impact event” reporting standards, such as CIP-008-3. At the very least it should reference those other standards that have within their scope

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		same/similar events in order to ensure complete reporting and full compliance. Suggesting that one standard provides the single reporting procedure, when in actuality it does not, is counterproductive. The discussion of "impact event" clearly indicates the SDT's intent to include sabotage events in the proposed standard EOP-004-2.
ERCOT ISO	Yes	ERCOT ISO supports the comments provided by the SRC. However, if the standard is to be established, ERCOT ISO has offered the comments contained herein as improvements to the requirements proposed. The requirements listed do not take into consideration the hierarchical reporting necessary for events (i.e.: GO to GOP to BA). The current structure will lead to redundant and conflicting reporting from multiple entities. This will lead to confusion in the analysis of the event. Any system developed and used to report impact events must include notification to the other relevant entities (i.e.: Reliability Coordinator, Balancing Authority, Transmission Operator, and Generator Operator). The proposed standard should not rely on a centralized system that does not follow the established hierarchy of dissemination of information.
Exelon	Yes	The standard is lacking guidance for DOE Form OE-417 reporting as outlined in the current version of EOP-004 and doesn't contain any non-BES related reporting. What is the governing process for OE-417 reporting?. Need clarification if one entity can respond on behalf to all entities in one company. Need a provision for entities to provide one report for all entities. Radiological sabotage is a defined term within the NRC glossary of terms. It would seem that a deliberate act directed towards a plant would also constitute an "impact event." In general, the DSR SDT should include discussions with the NRC to ensure communications are coordinated or consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator for consistency. The definition of sabotage is defined by NRC is as follows: Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.
Georgia System Operations Corporation	Yes	Light years better than the current CIP-001-1 and EOP-004-1! With some changes from this comment period, we should have a clearer set of realistic requirements which could likely pass the ballot. Thanks go out to the drafting team for bringing clarity to this topic. Capitalization throughout this document is inconsistent. It is not in synch with the NERC Glossary. All terms that remain capitalized in the next draft (other than when used as a title or heading) should be defined in the Glossary of Terms Used in NERC Reliability Standards. Examples of not in synch with the Glossary: Registered Entity, Responsible Entity, Law Enforcement. These are not defined in the Glossary. The requirements that apply to entities should not use the word "analysis." "Assessment" should be used. Analysis is a different process (an ERO process) and is being addressed by

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		another group within NERC (Dave Nevius). This EOP-004 drafting team and the NERC analysis group should closely coordinate such that there are no conflicts and the combined requirements/processes are realistic (mainly regarding timelines).
Great River Energy	Yes	We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting. Please provide an e-mail address for the submittal of the report to NERC (and any other parties above a Regional Entity) within this Standard and a fax number as a backup to electronic submittal.
Green Country Energy	Yes	I think the drafting team has done a wonderful job of beginning the task of combining two related standards. I ask them to keep in mind the small generators, and others who do not have the wide view capability, that more than likely react to events that occur wih no knowledge of why they occurred, and limited staff to address administrative standard requirements. Many times the KISS approach is the best approach.
Idaho Power Company	Yes	By including training requirements in each standard, creates confusion and compliance or failure to comply potential. PER standards are in place for personel training, these standards should be utilized for adding requirements that require training for NERC Standards.
ISO New England Inc.	Yes	Request clarification on how RCIS is part of this Standard. The form should be filled out in two stages. First stage would be the immediately available information. The second stage would be the additional information such as one line diagrams. There is concern with burdening the reporting operator on filling out forms instead of operating the Bulk Electric System. Most of the draft requirements are written as administrative in nature, and this is not most effective. Changes need to be made to (or possibly elimination of) R1, R2, R3. The standards should be changed to define what a “disturbance” is for reporting in EOP-004. Sabotage reporting as per CIP-001 should be rescinded as EOP-004 already has such a requirement.
Kansas City Power & Light	Yes	The standard addressed a preliminary report it should also address the requirements of a final report.
MidAmerican Energy	Yes	This entire standard needs to be revised to consider a results based standard.
Midwest ISO Standards Collaborators	Yes	We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
MRO's NERC Standards Review Subcommittee	Yes	Please provide an e-mail address for the submittal of the report to NERC (and any other parties above a Regional Entity) within this Standard and a fax number as a backup to electronic submittal. EOP-004 Attachment 2: Impact Event Reporting Form (note in the proposed standards it states EOP-002) seems to be written for Actual Impact Events only. Perhaps another section could be added for "Potential" Impact Events.
NERC Staff	Yes	NERC staff commends the SDT on its work so far. Merging CIP-001 and EOP-004 is a significant improvement and eliminates some current redundancies for reporting events. NERC staff believes opportunities to improve the proposed standard still exist. In particular, the team should consider possible redundancies with the Reliability Coordinator Working Group (RCWG) reporting guidelines, the Electricity Sector - Information Sharing and Analysis Center (ES-ISAC) reporting requirements for sharing information across sectors, and the Events Analysis Working Group (EAWG) efforts to develop event reporting processes. Ideally, the SDT and the EAWG should work together to develop a single consistent set of reporting criteria that can be utilized in both the EAWG event reporting process and in the requirements of the EOP-004-2 Reliability Standard.
North Carolina Electric Coops	Yes	Keep in mind that redundancy in reporting requirements from the DOE does not improve or enhance bulk electric system reliability but rather creates more work for the reporting entity.
Northeast Power Coordinating Council	Yes	Request clarification on how RCIS is part of this Standard. The form should be filled out in two stages. First stage would be the immediately available information. The second stage would be the additional information such as one line diagrams. There is concern with burdening the reporting operator on filling out forms instead of operating the Bulk Electric System. Most of the draft requirements are written as administrative in nature, and this is not most effective. Changes need to be made to (or possibly elimination of) R1, R2, R3. The standards should be changed to define what a "disturbance" is for reporting in EOP-004. Sabotage reporting as per CIP-001 should be rescinded as EOP-004 already has such a requirement.
Pacific Gas and Electric Company	Yes	PG&E believes as the training requirements continue to expand, having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues.
Pacific Northwest Small Public Power Utility Comment Group	Yes	The proposed standard has a huge impact on small DPs. DPs that presently do not maintain 24/7 dispatch centers will need to begin doing so to meet the reporting deadlines such as 1 hour after an occurrence is identified (possibly identified by a third party) or 24 hour after an occurrence (regardless of when it was discovered by the DP). The planning, assessing, drilling, training, and reporting requirements (R2-R6), as well as documentation (M2-M6) by small entities will cause utility rates to rise, will reduce local level of service,

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		and will not represent a corresponding increase to the reliability of the BES. The SDT concept of clear criteria for reporting has not been met, since R2 effectively directs the applicable entities to develop their own criteria. The decision of which types of events will be reported to which external organizations has been left up to the applicable entity. The comment group notes that there is no coordination of effort required between the applicable entities and the RCs or TOs that issue reliability directives. Energy Emergencies requiring voltage reduction or load shedding are likely to be communicated to applicable entities via directives. The likely result of this lack of coordination is that entities will plan, drill, and train for an event, but when the directive comes it will not be the one planned, drilled, and trained for. Coordination between those sending and receiving directives would ensure the probable events and directed responses are the ones planned, drilled, and trained for.
PacifiCorp	Yes	This is yet another standard with training requirements not covered under any PER standards. Having different training requirements spread throughout the standards makes it increasingly difficult to ensure all training requirements are met. Developing a "Training Standard" that lists ALL required training would streamline the process and aid greatly in compliance monitoring.
Pepco Holdings, Inc - Affiliates	Yes	The EAWG is developing processes that will be enforced through the Rules of Procedure. It may be inappropriate to reference the EAWG process in the Mapping Document.
PNM Resources	Yes	PNM believes that having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues. This will become even more of an issue as training requirements continue to expand.
PPL Electric Utilities	Yes	Combining EOP-004, CIP-001 and CIP-008's reporting requirements reduces redundancy and will add clarity to the compliance activities.
Puget Sound Energy	Yes	The DSR SDT's concepts for implementing a new structure for reporting are appropriate. Proper implementation of those concepts is likely to result in a very much improved standard. However, the proposed standard falls well short of implementing the concepts and is not much of an improvement on the current standard.
Santee Cooper	Yes	We don't believe that entities should be subjected to duplicate reporting to existing DOE requirements. How does redundancy in reporting requirements improve or enhance bulk electric system reliability?
SERC OC Standards Review	Yes	We find it disturbing that NERC is headed down a path of codifying requirements that are redundant to

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 15 Comment
Group		existing DOE requirements. How does redundancy in reporting requirements improve or enhance bulk electric system reliability? Disclaimer:” The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers.”
Southern Company - Transmission	Yes	The only concern that we have with the proposed standard is that it feels like it is creating dual, not quite redundant, reporting requirements for cyber intrusions in concert with CIP-008. Hopefully, there will not have to be a redundant reporting requirement if we continue to merge efforts with the CIP Drafting Team. Since we will no longer use the word SABOTAGE in the new EOP-004, we are hoping the industry and the CIP Drafting Team will give us the criteria they wish for us to use in order to report CIP-008 incidents. We will then achieve a “ONE STOP SHOP” reporting standard.
Tenaska	Yes	Since the proposed EOP-004-2 Standard does not eliminate the OE-417 reporting requirement, it does not streamline the existing CIP-001-1 and EOP-004-1 reporting requirements for GO/GOP’s. The "laundry list" of components required in the Operating Plan described in R2 is too specific and would make it more difficult to prove compliance during an audit. We prefer that the existing CIP-001-1 and EOP-004-1 Standards remain unchanged.
TransAlta Corporation	Yes	A Confidential Impact Event Report form is included in attachment 2 but nowhere in the standard does it say to use this form. This form appears to be similar to the “Preliminary Disturbance Report” form used in EOP-004-1. Clarity is required.
US Bureau of Reclamation	Yes	The SDT should consider that in reality it would be more streamlined to require immediate notification of an event for situational awareness, and then give adequate time for analysis of the cause. Reports that have an arbitrary rush will be diseased with low quality information and not much value in the long run to the BES. The Attachment A should be constructed around notification of situational awareness. The reporting timeline should be constructed around the different levels severity. The more severe the event, usually the more complicated the event is to analyze. Simple events usually do not have a significant impact.
We Energies	Yes	Please be careful to capitalize defined terms. If the intent is to not use the defined term, use another word."Forced intrusion" (cutting a fence, breaking in a door) may not be discovered for quite some time after it occurs. Should it be reported as soon as discovered? Even if there was no impact event (disturbance)? "Destruction of a Bulk Electric System Component" seems pretty specific. However, if a transformer kicks off line due to criminal damage, yet is considered repairable, is the event reportable?



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

---

Organization	Yes or No	Question 15 Comment
WECC	Yes	<p>Having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues. This will become even more of an issue as training requirements continue to expand. CIP-001-1 has surprisingly been one of the most violated standards during the initial period. However, most entities have now developed and demonstrated a decent compliance process. Unless a revised standard to address the FERC directive on sabotage is developed (as suggested in 13 above) this proposed standard appears to eliminate sabotage reporting as a reliability standard to the potential detriment of BES reliability.</p>

## Consideration of Comments on Disturbance & Sabotage Reporting – Project 2009-01

The Disturbance & Sabotage Reporting Drafting Team (DSR SDT) thanks all commenters who submitted comments on the Second Posting of EOP-004-2, Impact Event Reporting (Project 2009-01).

This standard was posted for a 30-day public comment period from March 9, 2011 through April 8, 2011. The stakeholders were asked to provide feedback on the standard through a special Electronic Comment Form. There were 60 sets of comments, including comments from 188 different people from approximately 132 companies representing 10 of the 10 Industry Segments as shown in the table on the following pages.

In this report, comments have been organized by question to make it easier to see where there is consensus. Comments may be reviewed in their original format on the project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Herb Schrayshuen, at 404-446-2560 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

**Summary Consideration:** The DSR SDT received many comments regarding the proposed definition of “Impact Event,” the requirements, and event reporting in Attachment 1. The main stakeholder concerns were addressed as follows:

- Many stakeholders disagreed with the need for the definition of “Impact Event” and felt that the definition was ambiguous and created confusion. The DSR SDT agrees and has deleted the proposed definition from the standard. The list of events in Attachment 1 is all-inclusive and no further attempts to define “Impact Event” are necessary.
- Many stakeholders raised concerns with the 1 hour reporting requirement for certain types of events. The commenters believed that the restoration of service or the return to a stable bulk power system state may be jeopardized by having to report certain events within one hour. The DSR SDT agreed and revised the reporting time to 24 hours for most events, with the exception of damage or destruction of BES equipment, forced intrusion or cyber related incidents.
- Many stakeholders suggested that the reporting of events after the fact only justified a VRF of “lower” for each requirement. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF, as this requirement deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all “lower” with the exception of Requirement R2 which is a requirement to analyze

---

<sup>1</sup> The appeals process is in the [Standard Processes Manual](#).

events. This standard relates only to reporting events. Analysis of reported events is addressed through the NERC Events Analysis Program. Proposed changes to the Electric Reliability Organization Events Analysis Process Field Trial documents that clarify the role of the Events Analysis program in analyzing reported events will be posted for stakeholder comment separately.

- The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events to the appropriate entities in accordance with the Operating Plan based on Attachment 1. Requirement R3 makes sure that an entity can communicate information about events. Some of these events are dealing with potential sabotage events, and part of the reason to communicate these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 are consistent with the existing approved VRFs for both EOP-004 and CIP-001.
- Several commenters wanted more clarity regarding which entities report and to whom they report. Many stakeholders were confused regarding law enforcement notifications and questioned whether certain types of events (IROL, Public Appeal, etc.) needed to be reported to law enforcement. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading "Law Enforcement Reporting": "These are the types of events that should be reported to law enforcement." The entire paragraph is:
  - "The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES."
- Some commenters also questioned whether or not the existing applicability would result in multiple reports being submitted by different entities for the same event. NERC staff has indicated that this is acceptable and that having multiple types of entities report the same event may provide different types of information about the event.

Commenters also had concerns about the applicability of the standard to Load Serving Entities who may not own physical assets as well as to the ERO and Regional Entity. The DSR SDT agrees that the Distribution Provider owns the assets per the Functional Model; however the LSE is an applicable entity under CIP-002. Events relating the CIP-002 assets are to be reported by the LSE. These are envisioned to be cyber assets. The DSR SDT also include the ERO or the RE as applicable entities based on the applicability of CIP-002

Some commenters identified issues with the footnotes in Attachment 1. These were revised as suggested. There were a few instances where the word “sabotage” remained in the standard or the flowchart. The DSR SDT has removed all instance of “sabotage” and replaced them with “event,” and revised the flowchart to remove references to sabotage.

Several commenters were concerned that the DSR SDT and the NERC Events Analysis Working Group (EAWG) may not be in alignment. The DSR SDT is working in close coordination with the EAWG and will continue to develop the standard and will make the EAWG aware of the DSR SDT’s efforts.

The issue of the FERC directives relating to this project was broached by several commenters. The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure. This process is being revised by the EAWG. Discussions with FERC staff indicate that the current efforts of the DSR SDT and the EAWG are sufficient to address the intent of the directive.

After the drafting team completed its consideration of stakeholder comments, the standards and implementation plan were submitted for quality review. Based on feedback from the quality review, the drafting team has made two significant revisions to the standard. The first revision is to add a requirement for implementation of the Operating Plan listed in Requirement R1. There was only a requirement to report events, but no requirement specifically calling for updates to the Operating Plan or the annual review. This was accomplished by having two requirements. The first is Requirement R2 which specifies that an entity must implement the Operating Plan per Requirement R1, Parts 1.1, 1.2, 1.4 and 1.5:

R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.

The second Requirement is R3 which addresses Part 1.3:

R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

The second revision based on the quality review pertains to Requirement R4. The quality review suggested revising the requirement to more closely match the language in the Rationale box that the drafting team developed. This would provide better guidance for responsible entities as well as provide more clear direction to auditors. The revised requirement is:

R4. Each Responsible Entity shall verify (through actual implementation for an event, or through a drill or exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification or actual implementation.

## Index to Questions, Comments, and Responses

1. Do you agree with the revised Purpose Statement of EOP-004-2, Impact Event Reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	15
2. Do you agree with the proposed definition of Impact Event? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	23
3. Do you agree that the DSR SDT has provided an equally efficient and effective solution to the FERC Order 693 directive to “further define sabotage”? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	38
4. Do you agree with the proposed applicability of EOP-004-2 shown in Section 4 and Attachment 1 of the standard? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	46
5. Stakeholders suggested removing original Requirements 1, 7 and 8 from the standard and addressing the reliability concepts in the NERC Rules of Procedure. Do you agree with the removal of original requirements 1, 7 and 8 (which were assigned to the ERO) and the proposed language for the Rules of Procedure (Paragraph 812)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	64
6. Do you agree with the proposed revisions to Requirement 2 (now R1) including the use of defined terms Operating Plan, Operating Process and Operating Procedure? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	70
7. Do you agree with the proposed revisions to Requirement 3 (now R2)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	87
8. Do you agree with the proposed revisions to Requirement 4 (now R3)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	98
9. Do you agree with the proposed revisions to Requirement 5 (now R4)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	113
10. Do you agree with the proposed revisions to Requirement 6 (now R5) and the use of either Attachment 2 or the DOE-OE-417 form for reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	123
11. Do you agree with the proposed revisions to Attachment 1? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	134
12. Do you agree with the proposed measures for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	159
13. Do you agree with the proposed Violation Risk Factors for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	<b>Error! Bookmark n</b>
14. Do you agree with the proposed Violation Severity Levels for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	<b>Error! Bookmark n</b>
15. Do you agree with the proposed Time Horizons for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	189
16. Do you agree with the proposed Implementation Plan for EOP-004-2? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	195
17. If you have any other comments you have not already provided in response to the questions above, please provide them here. ....	201

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
1.	Group	David Revill	Georgia Transmission Corporation & Oglethorpe Power Corporation			X	X	X					
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	John Miller	Georgia Transmission Corporation	SERC	1									
2.	Greg Davis	Georgia Transmission Corporation	SERC	1									
3.	Jason Snodgrass	Georgia Transmission Corporation	SERC	1									
4.	Scott McGough	Oglethorpe Power Corporation	SERC	5									
2.	Group	Guy Zito	Northeast Power Coordinating Council					X					
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10									
2.	Gregory Campoli	New York Independent System Operator	NPCC	2									
3.	Kurtis Chong	Independent Electricity System Operator	NPCC	2									
4.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1									
5.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1									
6.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10									
7.	Si Truc Phan	Hydro-Quebec TransEnergie	NPCC	1									

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
8. Mike Garton	Dominion Resources Services, Inc.	NPCC	5																	
9. Brian L. Gooder	Ontario Power Generation Incorporated	NPCC	5																	
10. Kathleen Goodman	ISO - New England	NPCC	2																	
11. David Kiguel	Hydro One Networks Inc.	NPCC	1																	
12. Michael R. Lombardi	Northeast Utilities	NPCC	1																	
13. Randy MacDonald	New Brunswick Power Transmission	NPCC	1																	
14. Bruce Metruck	New York Power Authority	NPCC	6																	
15. Chantel Haswell	FPL Group, Inc.	NPCC	5																	
16. Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10																	
17. Robert Pellegrini	The United Illuminating Company	NPCC	1																	
18. Saurabh Saksena	National Grid	NPCC	1																	
19. Michael Schiavone	National Grid	NPCC	1																	
20. Wayne Sipperly	New York Power Authority	NPCC	5																	
21. Donald Weaver	New Brunswick System Operator	NPCC	1																	
22. Ben Wu	Orange and Rockland Utilities	NPCC	1																	
23. Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC	3																	
3.	Group	Denise Koehn	Bonneville Power Administration			X	X	X	X											
<b>Additional Member</b>				<b>Additional Organization</b>				<b>Region Segment Selection</b>												
1.	Jim Burns	BPA, Transmission, Technical Operations	WECC	1																
4.	Group	Carol Gerou	Midwest Reliability Organization	X		X		X	X											
<b>Additional Member</b>				<b>Additional Organization</b>				<b>Region Segment Selection</b>												
1.	Mahmood Safi	Omaha Public Utility District	MRO	1, 3, 5, 6																
2.	Chuck Lawrence	American Transmission Company	MRO	1																
3.	Tom Webb	Wisconsin Public Service Corporation	MRO	3, 4, 5, 6																
4.	Jodi Jenson	Western Area Power Administration	MRO	1, 6																
5.	Ken Goldsmith	Alliant Energy	MRO	4																
6.	Alice Ireland	Xcel Energy	MRO	1, 3, 5, 6																
7.	Dave Rudolph	Basin Electric Power Cooperative	MRO	1, 3, 5, 6																

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
8.	Eric Ruskamp	Lincoln Electric System	MRO	1, 3, 5, 6																
9.	Joseph Knight	Great River Energy	MRO	1, 3, 5, 6																
10.	Joe DePoorter	Madison Gas & Electric	MRO	3, 4, 5, 6																
11.	Scott Nickels	Rochester Public Utilities	MRO	4																
12.	Terry Harbour	MidAmerican Energy Company	MRO	1, 3, 5, 6																
13.	Richard Burt	Minnkota Power Cooperative, Inc.	MRO	1, 3, 5, 6																
5.	Group	Steve Rueckert	Western Electricity Coordinating Council					X												
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Don Pape	WECC	WECC	10																
2.	Phil O'Donnell	WECC	WECC	10																
6.	Group	Annette Bannon	PPL Supply		X		X		X	X										
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Mark Heimbach	PPL Martins Creek, LLC	RFC	5, 6																
7.	Group	Steve Alexanderson	Pacific Northwest Small Public Power Utility Comment Group						X										X	
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Dave Proebstel	Clallam County PUD No.1	WECC	3																
2.	Russell A. Noble	Cowlitz County PUD No. 1	WECC	3, 4, 5																
3.	Ronald Sporseen	Blachly-Lane Electric Cooperative	WECC	3																
4.	Ronald Sporseen	Central Electric Cooperative	WECC	3																
5.	Ronald Sporseen	Clearwater Power Company	WECC	3																
6.	Ronald Sporseen	Douglas Electric Cooperative	WECC	3																
7.	Ronald Sporseen	Fall River Rural Electric Cooperative	WECC	3																
8.	Ronald Sporseen	Northern Lights	WECC	3																
9.	Ronald Sporseen	Lane Electric Cooperative	WECC	3																
10.	Ronald Sporseen	Lincoln Electric Cooperative	WECC	3																
11.	Ronald Sporseen	Raft River Rural Electric Cooperative	WECC	3																



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
12. Ronald Sporseen	Lost River Electric Cooperative	WECC 3												
13. Ronald Sporseen	Salmon River Electric Cooperative	WECC 3												
14. Ronald Sporseen	Umatilla Electric Cooperative	WECC 3												
15. Ronald Sporseen	Coos-Curry Electric Cooperative	WECC 3												
16. Ronald Sporseen	West Oregon Electric Cooperative	WECC 3												
17. Ronald Sporseen	Pacific Northwest Generating Cooperative	WECC 3, 4, 8												
18. Ronald Sporseen	Power Resources Cooperative	WECC 5												
19. Ronald Sporseen	Consumers Power	WECC 1, 3												
20. Steven J. Grega	Public Utility District #1 of Lewis County	WECC 5												
8.	Group	Patricia Hervocho	PSEG Companies	X					X					
<b>Additional Member</b>			<b>Additional Organization</b>	<b>Region</b>	<b>Segment</b>	<b>Selection</b>								
1.	Jeffrey Mueller	PSE&G				3								
2.	Kenneth Brown	PSE&G				1								
3.	Peter Dolan	PSEG ER&T				6								
4.	Eric Schmidt	PSEG ER&T				6								
5.	Clint Bogan	PSEG Fossil				5								
6.	Dominic Grasso	PSEG Fossil				5								
7.	Kenneth Petroff	PSEG Nuclear				5								
8.	Patricia Hervocho	PSEG NERC Compliance				NA								
9.	Group	Louis Slade	Dominion				X	X	X					
<b>Additional Member</b>			<b>Additional Organization</b>	<b>Region</b>	<b>Segment</b>	<b>Selection</b>								
1.	Lou Roeder	Electric Transmission	SERC			1, 3								
2.	Mike Garton	Electric Market Policy	NPCC			5, 6								
3.	Connie Lowe	Electric Market Policy	RFC			5, 6								
4.	Jack Kerr	Electric Transmission	SERC			3, 1								
5.	Len Sandberg	Electric Transmission	SERC			3, 1								
10.	Group	David Thorne	Pepco Holdings Inc and Affiliates		X									

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		Mark Godfrey	RFC	1, 3										
11.	Group	Robert Rhodes	SPP Standards Review Group	X		X		X	X					
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		John Allen	City Utilities of Springfield, MO	SPP	1, 4									
2.		George Allan	Sunflower Electric Power Corporation	SPP	1									
3.		Michelle Corley	CLECO	SPP	1, 3, 5, 6									
4.		Robert Cox	Lea County Electric Cooperative	SPP	1, 3									
5.		Kevin Emery	Carthage Water and Electric	SPP	3									
6.		Denney Fales	Kansas City Power & Light	SPP	1, 3, 5, 6									
7.		Louis Guidry	CLECO	SPP	1, 3, 5, 6									
8.		Jonathan Hayes	SPP	SPP	2									
9.		Philip Huff	Arkansas Electric Cooperative Corporation	SPP	3, 4, 5, 6									
10.		Gregory McAuley	Oklahoma Gas & Electric	SPP	1, 3, 5									
11.		Terri Pyle	Oklahoma Municipal Power Authority	SPP	4									
12.		Sean Simpson	Board of Public Utilities, City of McPherson, KS	SPP	1, 3, 5									
13.		Tay Sing	Oklahoma Municipal Power Authority	SPP	4									
14.		Chad Wasinger	Sunflower Electric Power Corporation	SPP	1									
15.		Mark Wurm	Board of Public Utilities, City of McPherson, KS	SPP	1, 3, 5									
16.		Ron Gunderson	Nebraska Public Power District	MRO	1, 3, 5									
17.		Bruce Schutte	Nebraska Public Power District	MRO	1, 3, 5									
18.		Jeff Elting	Nebraska Public Power District	MRO	1, 3, 5									
12.	Group	Marie Knox	Midwest ISO Standards Collaborators		X									
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		Bob Thomas	Illinois Municipal Electric Agency	RFC	4									
2.		Jim Cyrulewski	JDRJC Associates, LLC	RFC	8									
3.		Terry Harbour	MidAmerican	MRO	1									
4.		Joe O'Brien	NIPSCO	RFC	6									

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
5. Robert Thomasson		Big Rivers Electric Corp.	SERC	1, 3									
13.	Group	Sam Ciccone	FirstEnergy	X		X		X	X				
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>								
1.		Doug Hohlbaugh	FE	RFC	1, 3, 4, 5, 6								
2.		Bill Duge	FE	RFC	5								
3.		John Reed	FE	RFC	1								
4.		Jim Eckels	FE	RFC	1								
5.		Kevin Querry	FE	RFC	5								
6.		Ken Dresner	FE	RFC	5								
14.	Group	Gerald Beckerle	SERC OC Standards Review Group					X					
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>								
1.		David Trego	Fayetteville PWC	SERC	1, 3, 4, 9								
2.		Melinda Montgomery	Entergy	SERC	1, 3								
3.		Andy Burch	EEL	SERC	1, 5								
4.		Eugene Warnecke	Ameren	SERC	1, 3								
5.		Chuck Feagans	TVA	SERC	1, 3, 5, 9								
6.		Larry Rodriquez	Entegra Power	SERC	5, 6								
7.		Gary Hutson	SMEPA	SERC	1, 3, 5, 9								
8.		Jennifer Weber	TVA	SERC	1, 3, 5, 9								
9.		Doug White	NCEMC	SERC	1, 3, 5, 9								
10.		Shaun Anders	CWLP	SERC	1, 3, 5, 9								
11.		Jake Miller	Dynegy	SERC	5, 6								
12.		Reggie Wallace	Fayette PWC	SERC	1, 3, 4, 9								
13.		Dan Roethemeyer	Dynegy	SERC	5, 6								
14.		Alvis Lanton	SIPC	SERC	1, 3, 5, 9								
15.		Marc Butts	Southern	SERC	1, 3, 5								
16.		Robert Thomasson	BREC	SERC	1, 3, 5, 9								
17.		Srinivas kappagantula	PJM	SERC	2								

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment																
				1	2	3	4	5	6	7	8	9	10							
18.	Barry Hardy	OMU	SERC 1, 3, 5, 9																	
19.	Rene' Free	Santee Cooper	SERC 1, 3, 5, 9																	
20.	Greg Matejka	CWLP	SERC 1, 3, 5, 9																	
21.	John Troha	SERC Reliability Corp.	SERC 10																	
15.	Individual	Srinivas Kappagantula	PJM Interconnection LLC	X																
16.	Individual	Cindy Martin	Southern Company				X													
17.	Individual	Cynthia Oder	SRP	X																
18.	Individual	Howard Rulf	We Energies	X				X		X										
19.	Individual	Brent Ingebrigtsen	LG&E and KU Energy LLC	X																
20.	Individual	Silvia Parada Mitchell	Compliance & Responsibility Organization			X														
21.	Individual	John Bee	Exelon	X		X		X	X											
22.	Individual	Jennifer Wright	SDG&E			X														
23.	Individual	Alan Gale	City of Tallahassee (TAL)	X																
24.	Individual	Mace Hunter	Lakeland Electric					X												
25.	Individual	Nathaniel Larson	New Harquahala Generating Co.	X		X		X	X											
26.	Individual	Brian Pillittere	Tenaska					X												
27.	Individual	Michael Johnson	APX Power Markets			X	X													

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
28.	Individual	Jonathan Appelbaum	United Illuminating Co	X		X	X	X	X				
29.	Individual	Kevin Koloini	American Municipal Power					X					
30.	Individual	Daniel Duff	Liberty Electric Power LLC	X	X	X		X					
31.	Individual	Philip Huff	Arkansas Electric Cooperative Corporation	X									
32.	Individual	Joe Petaski	Manitoba Hydro	X									
33.	Individual	Mike Albosta	Sweeny Cogeneration LP			X	X	X					
34.	Individual	Thad Ness	American Electric Power					X					
35.	Individual	Andres Lopez	USACE			X	X	X	X				
36.	Individual	Nathaniel Larson	New Harquahala Generating Co.	X		X		X	X				
37.	Individual	Eric Salsbury	Consumers Energy					X					
38.	Individual	Michael Falvo	Independent Electricity System Operator	X		X		X	X				
39.	Individual	Kirit Shah	Ameren					X				X	
40.	Individual	Kathleen Goodman	ISO New England, Inc	X				X					
41.	Individual	Deborah Schaneman	Platte River Power Authority			X	X	X					
42.	Individual	Phil Porter	Calpine Corp		X								
43.	Individual	Bill Keagle	BGE	X		X		X	X				

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
44.	Individual	Kenneth A Goldsmith	Alliant Energy		X									
45.	Individual	John Brockhan	CenterPoint Energy	X		X		X	X					
46.	Individual	Martin Kaufman	ExxonMobil Research and Engineering					X						
47.	Individual	Brenda Truhe	PPL Electric Utilities	X										
48.	Individual	Tim Soles	Occidental Power Marketing				X							
49.	Individual	Eric Ruskamp	Lincoln Electric System	X										
50.	Individual	Linda Jacobson	Farmington Electric Utility System	X				X		X				
51.	Individual	Andrew Z Puszta	American Transmission Company	X										
52.	Individual	Michelle D'Antuono	Ingleside Cogeneration LP			X								
53.	Individual	Greg Rowland	Duke Energy	X		X		X						
54.	Individual	Amir Hammad	Constellation Power Generation			X								
55.	Individual	Scott Barfield-McGinnis	Georgia System Operations Corporation	X										
56.	Individual	Max Emrick	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power					X						
57.	Individual	Rex Roehl	Indeck Energy Services	X		X		X	X					
58.	Individual	Patricia Robertson	BC Hydro					X						

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
59.	Individual	Tony Kroskey	Brazos Electric Power Cooperative			X	X							
60.	Individual	Jim Eckelkamp	Progress Energy	X										

**1. Do you agree with the revised Purpose Statement of EOP-004-2, Impact Event Reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of stakeholders agree with the purpose statement. Some commenters had concerns with the use of the words "if known" and "industry awareness" and statements on requiring information from an analysis in the report which may not be known at the time of the report. Comments on this being an "after the fact" report and not real-time reporting have been addressed by a significant revision to the change in reporting times reflected in Attachment 1.

A number of commenters offered suggestions on the use of terms "situational awareness" versus "industry awareness." The DSR SDT used "industry awareness" to address concerns about real-time reporting (which this standard does not cover) and to avoid confusion with the NERC Situational Awareness organization.

The purpose statement was slightly revised to remove the defined term "Impact Event" and replace with the phrase "events with the potential to impact reliability". No other revisions were made.

"To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities."

Organization	Yes or No	Question 1 Comment
Exelon	No	<p>Although Exelon agrees that the proposed revision to the purpose statement of EOP-004-2 is better than the original draft; the DSR SDT should consider aligning the definition with the existing OE-417 terms. "Impact Events" are not clearly defined as reportable criteria in the DOE forms and may create confusion. Suggest rewording the purpose statement to simply "Incident Reporting" to align with existing terminology in OE-417 and removing the addition of a new term.</p> <p>A Purpose Statement is defined as "The reliability outcome achieved through compliance with the requirements of the standard." Propose that the purpose should be, "To require a review, assessment and report of events that could have an adverse material impact on the Bulk Electric System."</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. Form OE-417 report is a DOE report that is not specifically related to BES reliability and is not applicable outside of the United States. The standard only requires reporting of events. Analysis occurs through the NERC Events Analysis Program.</p>		
SDG&E	No	<p>SDG&amp;E does not agree with the revised Purpose Statement because it does not reflect the standard's purpose of identifying reporting requirements for impact events. SDG&amp;E recommends the following revised Purpose Statement:</p> <p>"To identify the reporting requirements for events considered to have an impact on the reliability of the Bulk</p>



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 1 Comment
		Electric System and to allow an awareness of these Impact Events to be understood by the industry in recognizing potential enhancements that may be made to the reliability of the BES.”
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the existing purpose statement addresses most of your suggested rewording. The last phrase “recognizing potential enhancements that may be made to the reliability of the BES” is not in the scope of the standard or this project.</p>		
Dominion	No	It is not evident how Impact Event reporting will “improve industry awareness“ as suggested in the Purpose Statement. The transfer of Requirement R8 (ERO quarterly report) to the Rules of Procedure (paragraph 812) invalidates that claim within the context of this standard. Suggest removing this phrase from the Purpose Statement.
<p><b>Response:</b> The DSR DT thanks you for your comment. The ERO will issue reports for industry awareness purposes under the Rules of Procedure. If entities do not report events to the ERO, then these reports will not be issued.</p>		
SPP Standards Review Group	No	We would suggest changing the purpose to read “To improve industry awareness and effectiveness in addressing risk to the BES by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.”
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT contends that the phrase “addressing risk to the BES” applies to the analysis of events which is not covered under the standard.</p>		
United Illuminating Co	No	UI agrees with the idea but believes the statement can be improved to remove ambiguities. For example: “if known” can be modifying the word causes, or the word Impact events. To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of identified Impact Events and if known their causes, if known, by the Responsible Entities.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The words “if known” are intended to modify the word ‘causes.’ The DSR SDT has revised the existing wording (from the clean version of the standard) to:  <i>To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities.</i></p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 1 Comment
Arkansas Electric Cooperative Corporation	No	The purpose statement reads "To improve industry awareness of the BES." We suggest the purpose should state "To improve industry awareness and effectiveness in addressing risks to the BES." We feel the remaining purpose statement is unnecessary.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT contends that the phrase "addressing risk to the BES" applies to the analysis of events which is not covered under the standard.</p>		
Manitoba Hydro	No	<p>Situational Awareness was replaced by the generic "Industry awareness." Justification for this was that Situational Awareness was a byproduct of a successful event reporting system and not a driver.</p> <p>Using Industry awareness clouds the clarity of the purpose. If personal are properly trained and conscious of their responsibilities, then they are in fact situationally aware, and will therefore drive the reporting process on the detection an Impact Event. Industry awareness falsely labels this Standard as unique to the electrical industry when clearly many outside and international agencies will be notified and involved. Situational Awareness seems much more appropriate and encompassing. Other then that the Purpose is a large improvement from the original.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT changed "situational awareness" to "industry awareness" to address concerns about real-time reporting (which this standard does not cover) and to avoid confusion with the NERC Situational Awareness organization.</p>		
Ameren	No	The original Purpose wording was clear, concise and understandable.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The original purpose statement was in the form of a requirement and not a purpose statement.</p>		
ISO New England, Inc	No	The purposed states To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities. Awareness by who in the industry?
<p><b>Response:</b> The DSR SDT thanks you for your comment. The requirements of this standard require that events be reported after-the-fact. The NERC Events Analysis Program will take certain events reported under this standard and analyze them to provide information to the entire body of users, owners and operators of the BES.</p>		
Calpine Corp	No	The purpose has moved significantly from the originally approved SAR. The purpose should focus on reporting requirements for reporting electrical disturbances to the Bulk Electric System that exceed specific thresholds. Sabotage/vandalism/theft are a subset of the reportable events that could have or do cause a Bulk Electric System Electrical Disturbance. The Standards content should focus on setting requirements to

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 1 Comment
		report specific types of electrical disturbance events and providing guidance for performing that reporting. Alternative language: Purpose: To establish reporting requirements for events that either cause, or have the potential to cause, significant disturbances on the Bulk Electric System.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The purpose covers the EOP-004 and CIP-001 standards which include disturbance and sabotage. The use of the word 'events' and the definition of the specific events to be reported (see Attachment 1) is a result of combining these two standards as well as the drafting team's efforts to address FERC Order 693 Directives. The proposed purpose statement does not adequately address these items.</p>		
BGE	No	BGE believes that using the term Impact Events as currently defined is too vague. An alternative statement would be requiring the reporting of events listed in Attachment 1 and their causes, if known and making the definition change as noted in question 2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated the defined term "Impact Events" and uses the generic term "events: in the purpose statement.</p> <p><i>To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities.</i></p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	"To improve industry awareness and the reliability fo the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known by the Responsible Entities." The revised purpose statement includes the phrase, if known. This seems like a huge loophole. They should change it to when discovered or when notified.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of "if known" was to make sure that events were reported regardless of whether the cause was known. It is important for entities to report events and to return the BES to a reliable operating state. Investigation of causes can occur at a later time.</p>		
Indeck Energy Services	No	The reporting of events does not improve the reliability of the BES. If someone takes action based on the reporting, there might be an improvement. Because many of these events are not preventable, such as sabotage or weather, reporting them won't improve reliability. The original Purpose was satisfactory.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The requirements of this standard require that events be reported after-the-fact. The NERC Events Analysis Program will take certain events reported under this standard and analyze them to provide information that will lead to improvements in BES reliability.</p>		
Brazos Electric Power Cooperative	No	Instead of Impact Event could simply call it Event Information Reporting.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 1 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event."</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
Georgia Transmission Corporation & Oglethorpe Power Corporation	Yes	We find it unnecessary to state that the purpose of a Reliability Standard is to "improve the reliability of the Bulk Electric System."
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT disagrees. This is an integral part of the purpose of reporting events.</p>		
Midwest Reliability Organization	Yes	The addition of "industry awareness" adds to the scope of this Standard. Whereby an entity is required to inform the RC and others of actual and potential Impact Events.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has streamlined Attachment 1 to ensure that the proper reporting is accomplished.</p>		
American Municipal Power	Yes	The purpose is acceptable. I think it could be improved and simplified. There were not any questions on the title. Consider changing the title to Reportable Events. There were not any questions on the category. I suggest changing the category from Emergency Operations to Communications. Reporting events can trigger and be more than just Emergency Operations. I feel the reporting function performed by entities should be under the Communications category. Title: Reportable Events Purpose: To improve reliability by communicating timely information about an event or events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT revised the existing title of the standard to conform to the intended purpose of reporting events. The team discussed making this a COM standard during the initial DT discussions but decided to retain the existing EOP-004 standard category and number. This is not a real-time reporting standard but requires after the fact reporting.</p>		
Ingleside Cogeneration LP	Yes	The addition of the modifier if known to reporting the cause of an Impact Event is appropriate. It often proves counter-productive to speculate as initial conjectures of the cause of an event are easy to come up with, but difficult to back out of later.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
Duke Energy	Yes	However, as we have noted previously, the DSR SDT statement that the proposed changes do not include any real-time operating notifications is inconsistent with requiring notification within one hour for thirteen of the

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 1 Comment
		<p>twenty listed Events in Attachment 1 Impact Event Table. Also, in the Background discussion, under Law Enforcement, the DSR SDT states that the objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting Impact Events. As we have previously commented, we are still required to make real-time reports under other standards. Requiring duplicate real-time reporting under EOP-004-2 is a waste of resources which could otherwise be used to improve reliability.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have made significant revisions to Attachment 1 and the reporting time requirements to address the real-time reporting concern.</p>		
Constellation Power Generation	Yes	<p>While CPG generally agrees with the purpose statement, we believe that the term Impact Events should be removed. Please see CPGs response to Question 2 discussing the term Impact Events.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Please see responses to comments on question 2.</p>		
Georgia System Operations Corporation	Yes	<p>We agree with the purpose. However, we do not agree that the purpose will be achieved as this standard is currently drafted or that the standard is ready for balloting.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have made significant revisions to the body of the standard and Attachment 1.</p>		
Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Western Electricity Coordinating Council	Yes	
PPL Supply	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 1 Comment
Pepco Holdings Inc and Affiliates	Yes	
Midwest ISO Standards Collaborators	Yes	
FirstEnergy	Yes	
SERC OC Standards Review Group	Yes	
PJM Interconnection LLC	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	
City of Tallahassee (TAL)	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Liberty Electric Power LLC	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	
USACE	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 1 Comment
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
Platte River Power Authority	Yes	
Alliant Energy	Yes	
CenterPoint Energy	Yes	
ExxonMobil Research and Engineering	Yes	
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
BC Hydro	Yes	

**2. Do you agree with the proposed definition of Impact Event? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of the commenters do not agree with the definition and thought the definition as overly broad, too subjective and confusing. Many commenters questioned whether there was a need for a definition of Impact Event at all. The DSR SDT discussed the comments and suggestions and decided to incorporate commenters’ suggestion to delete the definition and rely on the Attachment 1 to stand on its own.

The DSR SDT has deleted the Impact Event definition.

Organization	Yes or No	Question 2 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	We do not think that Impact Event should be defined using a recursive definition, i.e. that the word "impact" should be used in the definition of the term "Impact Event." Instead, we suggest using an enumerative definition in that the tables included in Attachment 1 are themselves used to define "Impact Event." If this definition is not acceptable, we suggest replacing the word "impact" in the definition with the word reduce, reduced, or potential to reduce the reliability of the BES.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Northeast Power Coordinating Council	No	<p>Is there a need for this definition? By itself the term is not specific on the types of events that are regarded as having an impact. The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. The events that are to be reported can be called anything. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not used anywhere else in the NERC Reliability Standards. For a complete definition of Impact Event, all the elements in Attachment A must be a part of it.</p> <p>Suggest consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
Bonneville Power Administration	Yes	Agree, but note that this will add many more situations to reporting and it will require more staff time to accomplish this.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Midwest Reliability Organization	No	The proposed definition is not supported by any of the established bright line criterias that are contained within attachment 1. This Results Based Standard should close any loop-holes that could be read into any section, especially the definition. According to rules of writing a definition, a definition should not contain part of the word that is being defined. Recommend the definition be enhanced to read: Impact Event: Any Contingency which has either effected or has the potential to effect the Stability of the BES as outlined per attachment 1. Within this enhanced recommendation, presently defined NERC terms are used (Contingency and Stability), thus supporting what is current used within our industry. There is also a quantifiable aspect of as outlined per attachment 1 that clearly defines Impact Events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes the definition is embodied in Attachment 1 criteria and needs no further clarification. We have deleted the proposed defined term "Impact Events" and will use the generic term "event."</p>		
Western Electricity Coordinating Council	No	We question the need for a defined term. It appears that an Impact Event is any event identified in Attachment 1. The use of the defined term combined with the language of Requirement 2 to implement the Impact Event Operating Plan for Impact Events listed in Attachment 1 may be confusing. Is an Impact Event any event described by the proposed definition or is an Impact Event any event listed in Attachment 1?
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT agrees the definition could be confusing. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Dominion	Yes	Dominion agrees with the proposed definition of Impact Events, but notes the use of the phrase has the potential to impact is somewhat subjective. The concern being a Responsible Entity makes a judgment on an events potential impact that is viewed differently after-the-fact by an auditor.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Pepco Holdings Inc and Affiliates	No	The two sentence definition will not be adequate to serve well over the course of time. People will have to read and understand the standard without benefit of the detailed information, explanations and interpretations

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		available during the standards development process. Without additional explanation as provided in the background and the guideline and technical basis sections, to support the definition, the standard will be subject to confusion and interpretations. Consider adding a lot of the information and explanation that is in those sections to the standard. Any event could be an impact event. However, only a subset is reportable. What is really being addressed are reportable events. More specifically after the fact reporting of unplanned events.
<p><b>Response:</b> Thank you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Midwest ISO Standards Collaborators	No	The definition of Impact Event is overly broad because of the use of potential to impact and the Such as list. Consider routine switching has the potential to result in a mis-operation. This means all routine switching is an impact event. The Such as list should be struck and potential language should be struck.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.”</p>		
FirstEnergy	No	Although we agree with the definition of Impact Event, we believe that it should be clear that this term is specific to the events listed in Attachment 1 of the standard. Therefore, we suggest adding the phrase (as detailed in Attachment 1 of EOP-004-2) in the definition.
<p><b>Response:</b> Thank you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
SERC OC Standards Review Group	No	We believe the definition is too broad even considering Attachment 1, footnote1, which, for example, uses the term significantly and other ambiguous terms. Consideration should be given to limiting the definition to unplanned events.
<p><b>Response:</b> Thank you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.”</p>		
PJM Interconnection LLC	No	The term "Impact Event" has been too broadly defined. According to the current definition, any event (including routine operations) can have the potential to impact the reliability of the Bulk Electric System and hence can be an Impact Event. The definition should only include unplanned events. Attachment 1 lists the events that are reportable. It seems that the definition of Impact Event refers to the events in Attachment 1 as opposed to defining Impact Event. As such, it is best that the SDT not define Impact Event but use words to the effect that requires an entity to have a plan and implement it for reporting unplanned events outlined in Attachment 1. If Impact Event were to be defined, we suggest the following definition would be a better

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		option:"An Impact Event is any unplanned event listed in Attachment I that has either adversely impacted or has the potential to adversely impact the reliability of the Bulk Electric System."
<b>Response:</b> Thank you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event."		
SRP	No	Suggest that definition include reference to the fact that this is non-desired occurrence, as the word 'impact' has neither a positive nor negative implication. This is not a well formed definition as it contains circular references to 'impacted' and 'event' within the definition.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term "Impact Events" and will use the generic term "event."		
We Energies	No	From an on-line dictionary, an event is something that happens. Combined with the phrase has the potential to impact and the definition of Impact Event would include every routine operation performed by any entity. Taking a generator on or off line, switching a transmission line in or out, traffic driving past a substation, all have the potential to impact the BES. The Impact Event definition is overly broad and needs to be significantly narrowed.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term "Impact Events" and will use the generic term "event."		
Compliance & Responsibility Organization	No	<p>NextEra Energy Inc. (NextEra) appreciates the drafting team providing valuable ideas and a framework on how to improve and consolidate CIP-001 and EOP-004. However, NextEra also believes that the currently drafted EOP-004-2 needs to be revised and enhanced to more clearly explain the Responsible Entities' duties, the definition of sabotage and address FERC directives and concerns.</p> <p>For example, NextEra is not in favor using the term "Impact Event" which seems to add considerable confusion of what is or is not sabotage. In Order No. 693, FERC stated its interest in NERC revising CIP-001 to better define sabotage and requiring notification to the certain appropriate federal authorities, such as the Department of Homeland Security. FERC Order 693 at PP 461, 462, 467, 468, 471.</p> <p>NextEra has provided an approach that accomplishes FERC's objectives and remains within the framework of the drafting team, but also focuses the process of determining and reporting only those sabotage acts that could impact other BES systems. Today, there are too many events that are being reported as sabotage to all parties in the Interconnection, when in reality these acts have no material affect or potential impact to other BES systems other than the one that experienced it.</p> <p>For example, while the drafting team notes the issue of copper theft is a localized act, there are other localized acts of sabotage that are committed by an individual, and these acts pose little, if any, impact or threat to other BES systems other than the one experiencing the sabotage event. Reporting sabotage that</p>

Organization	Yes or No	Question 2 Comment
		<p>has no need to sent of everyone does not necessary add to the security or reliability of the BES. Related, there is a need to clarify some of the current industry confusion on who should (and has the capabilities to) be reporting to a boarder audience of entities.</p> <p>Hence, NextEra approach provides a clear definition of sabotage, as well as the process for determining and reporting sabotage. NextEra further believes that some of the requirements can be consolidated and more clearly stated, and NextEra has attempted to do that in the approach presented below.</p> <p>Lastly, NextEra comments on Attachment 1 are submitted in response to question 17. NextEra Approach Delete definition of Impact Event and its use in the requirements and in Attachment 1 Delete 13, 14, 15 and 19 in Attachment 1 Delete and replace R1 through R5 with the following: New Definition Attempted or Actual Sabotage: an intentional act that attempts to or does destroy or damage BES equipment or a Critical Cyber Asset for the purpose of disrupting the operations of BES equipment, Critical Cyber Asset or the BES, and has a potential to materially threaten or impact the reliability of one or more BES systems (i.e., is one act in a larger conspiracy to threaten the reliability of the Interconnection or other BES systems).</p> <p>R1. Each Responsible Entity shall document and implement a procedure (either individually or jointly with other Responsible Entities) to accomplish the reporting requirements, including the time frames, assigned to the Responsible Entity as set forth in Attachment 1 items 1 through 12, 16, 17 and 18 for reporting from the Responsible Entity to its Regional Entity and NERC, using the form in Attachment 2 or the DOE OE-417 reporting form.</p> <p>R2. Each Responsible Entity shall document and implement a procedure (either individually or jointly with other Responsible Entities) to report to its internal personnel with a need to know and its Reliability Coordinator an act of Attempted or Actual Sabotage, using the form in Attachment 2 or the DOE OE-417 reporting form, within one hour after a determination has been made that an act Attempted or Actual Sabotage has occurred. To make a determination that an act of Attempted or Actual Sabotage has occurred, the Responsible Entity shall document and implement a procedure that requires it, as soon as practicable after the discovering an act appearing to be Attempted or Actual Sabotage, to engage local law enforcement or the Federal Bureau of Investigation or Royal Canadian Mounted Police, as deemed appropriate, to assist the Registered Entity make such a determination. Upon receiving a report of Attempted or Actual Sabotage from a Responsible Entity, the Reliability Coordinator shall within one hour forward the report to other impacted Reliability Coordinators, Responsible Entities, Regional Entities, NERC, Department of Homeland Security, and the Federal Bureau of Investigation or the Royal Canadian Mounted Police.</p> <p>R3. Each Responsible Entity shall review (and conduct a test for sabotage only) of its documented procedure required in R1 and R2 with no more than 15 calendar months between tests for sabotage reporting. If, based on the review or test, the Responsible Entity determines there is a need to update its documented procedure, it shall update the procedures within 90 calendar days of the review or test.</p>

Organization	Yes or No	Question 2 Comment
<p><b>Response:</b> Thank you for your comments and suggestions. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Other revisions were made to the standard based on comments received on specific requirements. The DSR SDT believes that these revisions clarify the requirements and has provided additional details in response to comments from questions Q3, Q6, Q7, Q8, Q11, Q12, Q13, Q14 and Q17. Please see the revised standard.</p> <p>In regards to sabotage, the DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability.</p> <p>The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <p>“The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
Exelon	No	<p>The definition of impact events should be reworded to align with OE-417 and to explicitly reference that only events identified in EOP-004 ? Attachment 1 are to be reported. Suggest the following: “An incident that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action as defined in EOP-004 Attachment 1.” Propose the definition be changed to include material impact and read as follows; Any event which has either caused or has the potential to cause an adverse material impact to the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action?</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
City of Tallahassee (TAL)	No	<p>While I agree with the overall concept, I am concerned with “or has the potential to impact.” While the standard makes reference to Attachment 1 Parts A and B, the inclusion of the attachment is not in the definition. This leaves ambiguity in the definition that could enable second guessing by auditors.</p> <p>Proposed: “An impact event is any event that has either impacted or has the potential to impact (above the</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		thresholds described in EOP-004-2 Attachment 1) the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”
<b>Response:</b> Thank you for your comments. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.”		
American Electric Power	No	The definition is too broad and vague. The text in the comment form has the following sentence Only the events identified in EOP-004 Attachment 1 are required to be reported under this Standard. The definition should contain that caveat or something similar.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.		
USACE	No	<p>1) You cannot use the terms impact and event to define impact event.</p> <p>2) The phrase “has the potential to impact” makes the definition too vague. Every action taken to modify the system or its components has the potential to impact the Bulk Electric System.</p> <p>3) Recommend to change the definition to “Any occurrence which has adversely affected the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”</p>
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.		
Consumers Energy	No	The definition of Impact Event seems very vague and nebulous. This definition should be modified to be clear and concise, such that entities clearly understand what is included within the definition.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.		
Ameren	No	<p>The documentation from the SDT included the reliability objective for EOP-004-2 which should be included in the definition of Impact Event. Our suggested alternate definition for Impact Event:</p> <p>“An Impact Event is any event that has either caused, or has the likely potential to cause, an outage which could lead to Cascading. Such events will be identified as being caused by, to the best of the reporting entity's information: (1) equipment failure or equipment mis-operation, (2) environmental conditions, and/or (3) human actions.”</p>

Organization	Yes or No	Question 2 Comment
		This alternate wording includes the reliability objective and clarifies the three known, or likely, causes of the Impact Event.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
ISO New England, Inc	No	<p>We question the need for this definition since by itself the term is not specific on the types of events that are regarded as having an impact. The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. For that matter, these events that are to be reported can be called anything, or just simply be titled “Event to be Reported” without having to define them. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not used anywhere else in the NERC reliability standards. In fact, for the term Impact Event to be fully defined, all the elements in Attachment A must become a part of it.</p> <p>We therefore suggest the SDT to consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A. If the SDT still wishes to retain a definition despite our reservations noted above, we strongly suggest an improvement. The proposed definition of Impact Event is overly broad because of the use of “potential to impact” and the “Such as” list. Consider that routine switching has the potential to result in a mis-operation. In that regard most routine switching could be interpreted as an impact event. The “Such as” list should be struck and “potential” language should be struck.</p> <p>An alternative definition to consider:</p> <p>An Impact Event is any deliberate action designed to reduce BES reliability; unintended accident that could result in an Adverse Reliability Impact; or an unusual natural event that causes or could cause an Adverse Reliability Impact.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Calpine Corp	No	<p>Adding a definition for Impact Event is unnecessary and does not provide useful clarification of the actual reporting requirement for events that either impact the Bulk Electric System or have the potential to impact the Bulk Electric System. The all-encompassing nature of the proposed definition seems to conflict with the finite listing of events that actually require reporting. Although FERC specifically requested additional clarification of the term sabotage to clarify reporting requirements, the Drafting Team is correct in noting that sabotage implies intent and that the intent of human acts is not always easily determined. The fact that intent is not always determinable within the reporting timeframe can be dealt with more simply by requiring (in attachment</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		1) that human intrusions that have not been identified within the reporting timeframe as theft or vandalism should be reported as potential sabotage pending further clarification. This approach negates the need for an additional definition that may cause confusion regarding which events are reportable and eliminates the potential for under-reporting based on the assumption that the cause might be theft or vandalism.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
BGE	No	Change the definition of “Impact Event”, to add the following phrase to the definition “Any event (listed in Attachment 1) which has either...” Also, the phrase “...or has the potential to impact the reliability...” is too vague and broad. Such broad statement is unhelpful in clarifying entities’ compliance obligation and potentially creates conflicted reporting between entities. A clear statement of how the reliability is affected should be used, i.e., results in contingency emergency situation or IROL.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Alliant Energy	No	<p>The proposed definition is not supported by any of the established bright line criteria that are contained within attachment 1. This Results Based Standard should close any loop-holes that could be read into any section, especially the definition. We recommend the definition be enhanced to read: Impact Event: Any Contingency which has either effected or has the potential to effect the Stability of the BES as outlined per attachment 1. Within this enhanced recommendation, presently defined NERC terms are used (Contingency and Stability), thus supporting what is current used within our industry. There is also a quantifiable aspect of as outlined per attachment 1 that clearly defines Impact Events.</p> <p>If the above definition is not adopted, we believe it should be rephrased to narrow the scope to those events that result from malicious intent or human negligence/error.</p> <p>We are concerned that by using phrases like unintentional or intentional human action in combination with damage or destruction basically means everything except copper theft becomes a reportable impact event (including planned actions we must perform to comply with CIP-007 R7).</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
CenterPoint Energy	No	CenterPoint Energy suggests that the phrase “...or has the potential to impact...” be deleted as it makes the definition vague and broad. Similar issues encountered in trying to define sabotage may resurface, such as



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		<p>varying definitions or interpretations of “potential.” If this standard is to support after-the-fact reporting, the focus should be on actual events, not potential situations or events. Effective and efficient prevention would come from analysis of actual events. Resources and reporting could become overwhelmed upon having to consider “potential.” All references to “potential” should be removed from the standard, guidance, and attachments.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
ExxonMobil Research and Engineering	No	The use of the word potential is ominous.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Occidental Power Marketing	No	<p>The SDT includes in the definition the "potential to impact the reliability of the BES." This seems vague, although Attachment 1 clarifies what actually has to be reported. An LSE may have limited or no knowledge of "potential to impact." The SDT may want to refine the definition, e.g., "to the extent the entities' knowledge could reasonably reveal the impact."</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Lincoln Electric System	No	<p>As currently drafted, the proposed definition of Impact Event appears vague and provides entities minimal clarity in terms of distinguishing events of significance. Recommend the drafting team reference Attachment 1: Impact Events Tables within the definition to direct industry towards more specific criteria.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
American Transmission Company	No	<p>ATC does not agree with the proposed definition and further disagrees whether a definition is needed at all. Proposed Definition: The definition, read outside of the proposed standard, does not provide Registered Entities with a clear meaning of the purpose of the definition. It is ATCs opinion that the SDT is using the term Impact Event as an introduction phrase to Attachment 1. ATC would be more comfortable if the</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		<p>definition was dropped and the team would re-write the requirement to specifically point to Attachment 1. It is our opinion that this type of structure would achieve the goal of the team to get Registered Entities to report on events identified in Attachment 1. The other option is for the team to write into the definition that the events being discussed are limited to those identified in Attachment 1. Also the language currently being used in the definition includes potential and such as. These terms should be struck from the definition.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Ingleside Cogeneration LP	No	<p>The SDT includes in the definition the potential to impact the reliability of the BES. This seems vague, although ultimately the events which meet the threshold of a reportable Impact Event are governed by the tables under Attachment 1. We believe that there should be close, if not perfect, synchronization between the EROs Event Analysis Process and Attachment 1 since they share the same ultimate goal as EOP-004-2 to improve industry awareness and BES reliability.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Duke Energy	No	<p>The phrase “...or has the potential to impact...” makes this an impossibly broad definition, and demonstrating compliance will not be straightforward.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Constellation Power Generation	No	<p>The currently proposed definition is vague and can be easily misinterpreted. Coining a term to define the events that the DSR SDT hopes to capture in EOP-004-2 is a difficult task, one that may not be necessary. Replacing the term Impact Events with events in Attachment 1, would eliminate the need to define such a term.</p> <p>In addition, the phrase or has the potential to impact the reliability is too vague and broad. Such broad statement is unhelpful in clarifying entities compliance obligation and potentially creates conflicted reporting between entities. The language in the reporting requirements should be limited to real impact events, while information sharing on near miss or deficiency incidents should be handled as good industry practices and not subject to onerous compliance obligations.</p> <p>The drafting team should also give careful consideration to the existing reporting and information sharing currently in place in the industry. When an event occurs, partners in the electric sector are notified as part of</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		existing requirements outside of NERC compliance.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Georgia System Operations Corporation	No	It is not clear for the purposes of complying with this standard what it means to impact reliability. Impact in what way. To what degree. Do not define this term. An alternative would be to define it as those events listed in Appendix 1.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Indeck Energy Services	No	It's not a definition. It needs some quantification, such as, a Reportable Disturbance (NERC glossary), a reportable event under DOE OE-417, sabotage or bomb threat. Defining it as having or potentially having an impact is no definition. What is an impact? It needs to be quantified or auditors will have license to define it any way that they want. It shouldn't be a NERC Glossary definition if its only use is in EOP-004. Within EOP-004, it can be defined as anything in Attachment 1.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Progress Energy	No	Progress Energy appreciates the Standard Drafting Teams work on this project. Any potential impact is too vague and impossible to measure. Progress is unsure of how the ERO or Regional Entity measure impact. Potential is very subjective.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Brazos Electric Power Cooperative	No	
Southern Company	Yes	There is concern that the proposed definition for Impact Event does not allow for prudent judgment and preliminary situational assessment by the entity to declare a Potential Impact Event (especially threats) as non-credible. The thresholds for reporting established in Attachment 1 ? Part A provide a somewhat definitive bright line with regard to those events identified in Part A, but for some of the events in Part B there should be allowance for an assessment by the entity to reasonably determine whether the event poses a credible threat

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		to the reliability of the BES. This is attempted in the footnote to the Forced Intrusion event in Attachment 1 ? Part B, but we think this allowance for entity assessment and prudent judgment needs to apply more pervasively, perhaps by including the term credible in the definition of Impact Event or at least by adding the term credible wherever the term physical threat is used.
<p><b>Response:</b> Thank you for your comments. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” The word “credible” could lead to many interpretations as well. Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
American Municipal Power	Yes	The definition of Impact Event is acceptable and an improvement. I feel it could be improved and simplified further. Consider changing Impact Event to a "reportable event."
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Liberty Electric Power LLC	Yes	I am interpreting the phrase "has the potential" to exclude events which had the potential, but did not impact the BES. An example would be a generation trip - if the trip had happened during a system emergency it could have affected the BES, but since it happened under normal conditions there is no reporting responsibility. Some assurance on this interpretation would be appreciated.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Manitoba Hydro	Yes	“Disturbance” has a unique and traditional meaning in the electrical industry, basically meaning “a notable electrical event causing in imbalance of load and generation.” Attempting to include the many scenarios can that can affect reliability blurred the current vision of “Disturbance” and the addition of “unusual occurrences” just added to the confusion. It never seemed appropriate to submit an unusual occurrence on a “Disturbance Report.” “Impact Event” is very encompassing and then detailed specifically in Attachment 1.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Independent Electricity System Operator	Yes	We do not have any issue with the wording of the definition, but question the need for this definition since by itself the term is not specific on the types of events that are regarded as having an “impact.” The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. For that matter, these events that are to be reported can be called anything. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		<p>used anywhere else in the NERC reliability standards. In fact, for the term Impact Event to be fully defined, all the elements in Attachment A must become a part of it.</p> <p>We therefore suggest the SDT to consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
PPL Electric Utilities	Yes	<p>PPL EU agrees with the definition. We would like to point out that our interpretation of the definition excludes maintenance work. Our interpretation also concludes that maintenance work that does not go as planned or goes awry and impacts the reliability of the BES would be an impact event and reported as required per Attachment 1.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
SDG&E	Yes	
PPL Supply	Yes	
PSEG Companies	Yes	
SPP Standards Review Group	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
Arkansas Electric Cooperative	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 2 Comment
Corporation		
Sweeny Cogeneration LP	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
Farmington Electric Utility System	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
BC Hydro	Yes	
<p><b>Response:</b> Thank you for your response. Most commenters who responded to this question disagreed with the proposed definition and some suggested that the definition is not needed. In response, the drafting team has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		

**3. Do you agree that the DSR SDT has provided an equally efficient and effective solution to the FERC Order 693 directive to “further define sabotage”? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Most stakeholders agreed that the drafting team addressed the directive to further define sabotage. Commenters generally agreed that the DSR SDT approach in the currently proposed solution effectively addresses FERC Order 693 directive. The approach clarifies the triggering event for an entity to take action and, by deleting all references to "sabotage," in effect removes the very term that had no clear definition.

Organization	Yes or No	Question 3 Comment
Pepco Holdings Inc and Affiliates	No	See #2. With out the explanation contained in background information, over time those that have not been involved with this standard development will struggle with how to interpret the code words of non environmental and intentional human action.
<p><b>Response:</b> The DSR DT thanks you for your comment. This is a Results-based standard and the format includes all of the information, with the exception of the Rationale boxes, through the ballot and filing of the standard. The background section of the proposed standard will be retained with the standard for future reference.</p>		
Midwest ISO Standards Collaborators	No	In general, we agree that the standard drafting team has provided an equally efficient and effective alternative, but we wonder if the SDT has not in essence already defined sabotage in their description for why they cant define sabotage. It seems that sabotage involves willful intent to destroy equipment. In general, intent would have to be determined by an investigation of law enforcement. This could be part of the definition. There might be some obvious acts that could be included without investigation such as detonation of a bomb. Is it possible for the SDT to use the DOE definition for sabotage? We encourage the SDT to provide a definition for sabotage.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that sabotage may be one aspect of a single event. The intent is to report (per Thresholds of Reporting in Attachment 1) events that have an impact on BES reliability. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <ul style="list-style-type: none"> <li>o “The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely</li> </ul>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 3 Comment
<p>upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p><b>Response:</b> The DSR DT thanks you for your comment. Please see the DSR DT response above for question number 2.</p>		
Sweeny Cogeneration LP	No	<p>The threshold for reporting what could be sabotage still leaves the door open for second guessing after-the-fact. For example, if graffiti is sprayed on a BES asset, the entity is to assume that the event is not to be reported. However, intent to harm the BES may be discovered at a later point with ramifications to the entity who did not report it.</p> <p>A solution may be to strengthen footnote 3 to both reporting tables, which makes an allowance to report if you cannot reasonably determine likely motivation of sabotage. If acceptable methods to provide justifiable evidence that reporting was NOT required, then this loophole may be corrected.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Attachment 1 has been updated per comments received.</p>		
USACE	No	The DSR SDT should have defined sabotage since it helps the SDT working on CIP standards further define its action. Sabotage can be defined as the deliberate act of destruction, disruption, or damage of assets to impact the reliability of the BES.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (in Attachment 1) that have an impact on BES reliability. Attachment 1 has been updated per comments received.</p>		
Consumers Energy	No	EOP-004 does not appear to address a reliability need. Reporting after-the-fact information such as that described in Impact Events does not do anything to improve Bulk Electric System reliability. Therefore, we recommend that CIP-001 be updated to address sabotage events, and that NERC otherwise rely on the statutory reporting to the DOE that is represented by OE-417 for any after-the fact information. The remainder of our comments reflects detailed comments on the posted draft, presuming that our objection



Organization	Yes or No	Question 3 Comment
		represented above will be disregarded.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Providing event reporting information will start the event analysis process done by the current NERC Event Analysis Program. EOP-004-2 is the reporting vehicle to the ERO that will support the analysis phase of any event.</p>		
Ameren	No	<p>The SDT did not further define sabotage as directed by FERC, but instead created a new term that does not address the order. The Term Impact Event has no clarity or quantitative qualities by which an entity can determine what should be reported. The use of the phrase "has the potential to impact reliability" has such a vague scope, an auditor can interpret to mean any "off-normal" condition, which makes this standard impossible to comply with. The SDT should use the DOE definition of sabotage as follows:</p> <p>Sabotage - Defined by Department of Energy (DOE) as:</p> <ul style="list-style-type: none"> <li>An actual or suspected physical or Cyber attack that could impact electric power system adequacy or reliability</li> <li>Vandalism that targets components of any security system on the Bulk Electric System</li> <li>Actual or suspected Cyber or communications attacks that could impact electric power system adequacy or vulnerability, including ancillary systems which support networks (e.g. batteries)</li> <li>Any other event which needs to be reported by the Balancing Authority (Transmission Operations) to the Department of Energy. Sabotage can be the work of a single saboteur, a disgruntled employee or a group of individuals.</li> </ul>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Attachment 1 has been updated per comments received. EOP-004-2 sets the minimum reporting requirements for events.</p>		
Calpine Corp	No	<p>The additional definition for "Impact Event" is unnecessary and does not provide useful clarification regarding actual reporting requirements. Sabotage, whatever the exact definition used, implies intent to damage or disrupt. The committee correctly notes that determination of actual intent is not always readily available. However, adding a general expansive definition encompasses all events that might disrupt the Bulk Electric System does not add clarity to the types of events that require reporting - which are listed in detail in Attachment 1. The issue can be more simply addressed by replacing the item "Human Intrusion" on Attachment 1, as follows:</p> <p>Event: Sabotage (note 3) Entity with Reporting Responsibility: All affected Responsible Entities listed</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 3 Comment
		<p>in the Applicability Section of this Standard.</p> <p>Threshold for Reporting: Forced Intrusions at a BES facility that have not been determined within the reporting period to be theft or vandalism that does not affect the operability of BES equipment.</p> <p>Note 3 For purposes of reporting under Attachment 1, reportable sabotage includes all forced intrusions at BES facilities that have potential to cause, or cause, any of the disturbance events listed in Attachment 1 and have not been determined to be theft or vandalism that did not result in any event listed in Attachment 1.</p> <p>Responsible Entities are not required to report incidents of theft or vandalism that do not result in disturbance events. This approach also eliminates the need to reference copper theft as a particular type of theft that does not require reporting.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.”. Attachment 1 has been updated per comments received. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Footnotes have been updated per comments received.</p>		
CenterPoint Energy	No	CenterPoint Energy would agree if the definition for Impact Event was changed as suggested in the response to Question 2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.”. Attachment 1 has been updated per comments received. The DSR SDT believes that the reporting of events supports the reliability of the BES.</p>		
Duke Energy	No	Sabotage is still identified on the flowchart. Timeframes for reporting on Attachment 1 should be made consistent with DOE OE-417 reporting. Also on Attachment 1, the Threshold for Reporting on a Forced Intrusion Event should be Affecting BES reliability instead of At a BES facility.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has updated the flowchart. The DOE Form OE-417 is reviewed biennially by the DOE and can be updated or changed without NERC’s involvement. The DSR SDT has taken into consideration the possible use of Form OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2’s reporting requirements. The DSR SDT has removed sabotage from the flowchart and has replaced it with: “Criminal act under federal jurisdiction.”</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 3 Comment
Indeck Energy Services	No	The SDT hasn't defined sabotage. Attachment 1 does not do justice to the concept of sabotage. Sabotage should be defined as any intentional damage to BES facilities the causes a Reportable Disturbance, reportable event under DOE OE-417 or involves a bomb or bomb threat.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The DOE Form OE-417 is reviewed biennially by the DOE and can be updated or changed without NERC's involvement. The DSR SDT has taken into consideration the possible use of Form OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2's reporting requirements.</p>		
Exelon	Yes	Exelon agrees with the DSR SDT in that the currently proposed solution effectively addresses the intent of FERC Order 693 directive to both clarify the triggering event for an entity to take action and by deleting all references to "sabotage" in effect removes the very term that had no clear definition.
<p><b>Response:</b> Thank you for your comment.</p>		
Georgia Transmission Corporation & Oglethorpe Power Corporation	Yes	We agree with the approach taken by the SDT.
Northeast Power Coordinating Council	Yes	It is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
Midwest Reliability Organization	Yes	Sabotage is usually associated with a malicious attack. Entities have always lacked the clinical expertise to determine if an event was malicious or not. The Impact Event bright line criteria clearly states what the minimum reporting requirements are.
Manitoba Hydro	Yes	"Impact event", The DSR SDT reasoning for this. 'A sabotage event can only be typically determined by law enforcement after the fact' is very creative and concise!
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 3 Comment
Independent Electricity System Operator	Yes	We agree since it is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
<b>Response:</b> The DSR SDT thanks you for your comment.		
ISO New England, Inc	Yes	We agree since it is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
Ingleside Cogeneration LP	Yes	Sabotage cannot be confirmed until after the fact, so we support this initiative.
Bonneville Power Administration	Yes	
Western Electricity Coordinating Council	Yes	
PPL Supply	Yes	
PSEG Companies	Yes	
Dominion	Yes	
SPP Standards Review Group	Yes	
FirstEnergy	Yes	
SERC OC Standards Review Group	Yes	
PJM Interconnection LLC	Yes	
Southern Company	Yes	
SRP	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 3 Comment
We Energies	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
American Municipal Power	Yes	Well done.
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
American Electric Power	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
ExxonMobil Research and Engineering	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 3 Comment
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Constellation Power Generation	Yes	
Georgia System Operations Corporation	Yes	None.
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Brazos Electric Power Cooperative	Yes	
<p><b>Response:</b> The DSR SDT thanks you for your response. Several commenters proposed revisions to the definition, and after deliberation the SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event”. Attachment 1 has been updated per comments received. The DSR SDT believes that the reporting of events supports the reliability of the BES.</p>		

**4. Do you agree with the proposed applicability of EOP-004-2 shown in Section 4 and Attachment 1 of the standard? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. The SDT believes that the industry will gain valuable information from having different perspectives of a single event. Differing viewpoints on the same event will provide for better clarity to all parties on the actual impact to the bulk electric system. The SDT would like to point out that reporting of events is from the time of identification not the time of the event. In response to the comments received, the SDT has made numerous enhancements to Attachment 1. **These revisions include:**

- **Added new column “Submit Attachment 2 or DOE OE-417 Report to:” which references Part 1.3 and provide the time required to submit the report.**
- **Combined Parts A and B into one table and reorganized it so that the events are listed in order of reporting times (either one hour or 24 hours)**
- **Removed references to “Impact Event” and replaced with the specific language for the event type in the “Entity with Reporting Responsibility”. For example, replaced “Impact Event” with “automatic load shedding”.**

**The ERO and the RE were added as applicable entities to reflect CIP-002 applicability to this standard.**

Organization	Yes or No	Question 4 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	<p>We do not believe that GO, TO, TSP, DP, or LSE should be included in the applicability of this standard. It is our opinion that the reporting requirements lie primarily with the applicable operator and should be limited as such. We recommend modifications as discussed in our response to question 6 to clearly define what types of events each Responsible Entity needs to prepare for. Currently, it seems that multiple entities are being required to report the same event for some events where only one entity should have a reporting responsibility. However, NERC should not decide which one entity should report a given event.</p> <p>The entities should have the flexibility to create a process which allows for coordination and communication at a local level and to work out with neighboring entities who might ultimately report events to the applicable</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		organizations.
<p><b>Response:</b> Thank you for your comments. The SDT disagrees that the operators are the only entities with obligations to report; owners and users may have very credible and valuable information relating to events. Such information may be extremely beneficial in developing lessons learned and analyzing events. Your suggestion to allow for local coordination and communication is a practical suggestion and the standard allows for it.</p>		
Northeast Power Coordinating Council	No	<p>Disagree with the following inclusion/exclusion of several entities:</p> <p>a. The applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. NERC should be included in the Applicability Section as it is an applicable entity identified in CIP-002-3.</p> <p>b. If the above approach was not strictly followed, then suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard. The SDT has reviewed the CIP-002-3 standard and has included the ERO and the RE in this standard.</p>		
Pacific Northwest Small Public Power Utility Comment Group	No	We believe that facilities used in the local distribution of electric energy should be excluded from these requirements due the language of 16 U.S.C. ? 824o(a)(1) and 16 U.S.C. ? 824o(i)(1).
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT constructed Attachment 1 based upon the existing requirements in the various reliability standards and established reporting obligations. The information about events and the analysis of those events will be useful to all owners, operators, and users of the bulk power system. The SDT has clarified the reporting requirement such that only those affected by the event are required to submit a report.</p>		
PSEG Companies	No	The PSEG Companies believe the defining language, roles and responsibilities outlined in Attachment 1 are unclear and inconsistent. For example fuel supply emergency reporting footnote 2 “Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability” attempts to clarify the condition for reporting but does not. Whose “emergency actions” are being referred to in the footnote? It is not clear if those actions would be related to the specific station or the overall Bulk Electric



Organization	Yes or No	Question 4 Comment
		<p>System (BES). Can this be interpreted to imply a gas supply issue to one generating station as the result of pipeline maintenance, or local pressure issues would also requiring reporting? The PSEG Companies believe the definition of a fuel supply emergency needs to be more specific and less open to broad interpretation.</p> <p>In addition, the “Time to Submit Report” section of attachment 1 has a significant number of changes from the previous version. Accelerating the twenty four (24) hour to one (1) hour requirement for submitting the reports for several of the events takes resources away from managing the actual event. For the above comments failure to submit a report within 1 hour is a high or severe VSL for a fuel supply emergency. This approach seems inconsistent with ensuring the operation and reliability of the BES. One (1) hour reporting, in most cases, is not adequate time to compile the needed information, prepare report, ensure the accuracy, submit, and simultaneously manage the actual event. We recommend 24 hour reporting for: Damage or destruction to BES, Fuel Supply Emergency, Forced Intrusion, and Risk to BES equipment sections of Attachment 1.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT appreciates the observation on Fuel Supply Emergency and has adjusted Attachment 1 to address it. Reporting under the standard requires that the Registered Entity provide what information it has at the time of the report. The report may not provide the entire record or identification of the event. If the Registered Entity desires to submit an updated report, it may choose to do so; but there is no obligation to do so.</p> <p>The DSR SDT has significantly revised Attachment 1. We have removed the timing column and replaced it with more specific information regarding which form to submit and to whom the report is to be submitted. All events are now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events, Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident. These events are to be reported within 1 hour. Notification of law enforcement (per Requirement R1, Part 1.3.2) is only required for these events. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <p>o “The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
Dominion	No	<p>1) Several of the events require filing a written Impact Event report within one hour. System Separation, for example, is going to require an “all hands on deck” response to the actual event. We note that the paragraph above Attachment 1, Part A indicates that a verbal report would be allowed in certain circumstances, but this</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
		<p>is the same issue with the formal report in that the system operators are concerned with managing the event and not the reporting requirements. Another example would be the Loss of Off-site power to a nuclear generating plant. Suggest reconsideration of one hour reporting requirement for events requiring extensive operator actions to mitigate;</p> <p>2) Several events seem to have the “Threshold for Reporting” contained in footnotes rather than in the table. For example, Damage or destruction of BES equipment - Footnote 1, Fuel supply emergency - Footnote 2, etc.) Suggest moving the actual threshold into the table;</p> <p>3) If one hour reporting remains as indicated in Attachment 1; align/rename events similar to that of the ‘criteria for filing’ events listed in DOE OE-417 for consistency.</p>
<p><b>Response:</b> Thank you for your comment. Reporting under the standard requires that the Registered Entity provide what information it has at the time of the report. The report may not provide the entire record or identification of the event. If the Registered Entity desires to submit an updated report, it may choose to do so; but there is no obligation to do so. Based upon comments received, the SDT has updated the time reporting requirements in Attachment 1. Most events are to be reported within 24 hours. The DSR SDT has retained a one-hour reporting requirement for those events the DSR SDT believes are the types of event that would be typically reported to law enforcement and are of a more urgent nature.</p>		
SPP Standards Review Group	No	<p>While the SDT has recognized the issue of applicability to GO/TO in its background information with the Unofficial Comment Form, we still do not feel comfortable with the GO/TO being listed as a responsible entity when in fact it may be days before they become aware of an event worthy of reporting. If the GOP/TOP makes the report, are the GO/TO still responsible for filing a report? If the GOP/TOP do not file the report, would the GO/TO then be non-compliant? This issue appears to put additional risk on the GO/TO over which they have no control. We need some mechanism to eliminate unnecessary risk while at the same time ensuring that we have coverage for the BES. Perhaps this could be done through delegation agreements between the entities involved or through allowances within the standard itself. For example, could the phrase “appropriate parties in the Interconnection” as currently contained in CIP-001-1, R2 be incorporated into the standard to basically replace GO/TO?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from different entities for the same event may provide a more complete understanding of the event.</p>		
FirstEnergy	No	<p>1. Attachment 1, Part A - Energy Emergency requiring Public appeal for load reduction - In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity." We can't see where the GO/GOP would ever make this determination. Needs to be clarified.</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		<ol style="list-style-type: none"> <li>2. Attachment 1, Part A - Energy Emergency requiring system-wide voltage reduction - In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity." We can't see where the GO/GOP would ever make this determination. Needs to be clarified.</li> <li>3. Attachment 1, Part A - Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 continuous minutes, this should be a TOP RC function only.</li> <li>4. Attachment 1, Part A - Loss of offsite power (LOOP) classification should not apply to nuclear generators. The impact of a LOOP is dependent on the design of the specific nuclear unit and may not necessarily result in a unit trip. If a LOOP did result in a unit trip, the NRC requires notification by the nuclear GO/GOP via the Emergency Notification System (ENS), and time allowed for that notification (1 hour, 4 hours, 8 hour, or none at all) is, as mentioned above, dependent on the design of the plant. We believe it would be beneficial if consideration were given to coordinating reporting requirements for nuclear units with existing required notifications to the NRC to avoid duplication of effort.</li> <li>5. Attachment 1 should align NERC Standard NUC-001 concerning the importance of ensuring nuclear plant safe operation and shutdown. If a transmission entity experiences an event that causes a loss of off-site power as defined in the nuclear generator's Nuclear Plant Interface Requirements, then the responsible transmission entity should report the event within 24 hours after occurrence. Also, for clarity "grid supply" should be replaced with "source" to ensure that notification occurs on a loss of one or multiple sources to a nuclear power plant.</li> <li>6. Attachment 1, Part A - Damage or destruction of BES equipment. See Nuclear comments on question 17 below.</li> <li>7. Attachment 1, Part B - Forced intrusion at a BES facility. See Nuclear comments on question 17 below.</li> <li>8. Attachment 1, Part B - Risk to BES equipment from a non-environmental physical threat. What constitutes a "risk" to the reporting entity is still somewhat ambiguous, and although the DSR SDT has provided some examples, without more specific criteria for this event the affected entity will have difficulty in determining within 1 hour if a report is necessary. Also, see Nuclear comments on question 17 below.</li> </ol>
<p><b>Response:</b> The DSR SDT thanks you for your comment. As a general note, the Applicability section of the standard includes each entity that will be responsible for reporting an event. Attachment 1 has a column "Entity with Reporting Responsibility" to indicate the appropriate entity that is required to report under this standard. For items 1-3 above, the GO or GOP will not be the likely deficient or initiating entity. This will most likely be the BA, TOP or the RC. For item 4, the LOOP event is to be reported by the TO and TOP, not the nuclear plant. For item 5, the TO and TOP are to report within 24 hours. The DSR discussed using "source", however this indicates a single source whereas "supply" encompasses all sources. For items 6, 7 and 8, please see response to Question 17 comments.</p>		
SERC OC Standards Review Group	No	We agree that all of the entities listed should be responsible for reporting an event, provided they own BES assets, but guidance should be given for which entity in Attachment 1 actually files the report to avoid duplication for a single event.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities may provide valuable information on understanding the event.</p>		
PJM Interconnection LLC	Yes	<p>1. We agree that the entities listed should be responsible for ensuring events are reported, provided they own BES assets, but more guidance should be provided on which entity in Attachment 1 should actually file the report to avoid multiple entities reporting a single event. Current Attachment 1 results in significant duplicate reporting.</p> <p>2. Although the applicable entities listed in Section 4 capture all entities that are assigned a reporting responsibility in Attachment 1, some events in Attachment 1 refer to entities applicable under a different standard (e.g CIP-002) as the responsible entities for reporting. This results in IA, TSP, and LSE (none of which, generally own Critical Assets and hence not likely own CCAs) as being responsible for reporting an event. We urge the SDT review the need to include IA, TSP, and LSE in applicable entities. Also, why is NERC an applicable entity in CIP-002-3 but not in this standard?</p>
<p><b>Response:</b> Thank you for your comments. 1. The "Entity with Reporting Responsibility" column of Attachment 1 indicates who is responsible for submitting reports for each event type. It is expected that multiple reports will be received for the same event. Each entity experiencing the event may see something different. This reporting will allow for a more robust analysis process after the fact. 2. The IA, TSP and LSE are included as applicable entities for EOP-004 only because they are applicable under CIP-002. The only events that these entities are required to report are related to cyber assets. The ERO and the RE were added as applicable entities for consistency with CIP-002.</p>		
SRP	No	<p>The threshold for Reporting is broad, vague and repetitive. "Three or more BES Transmission Elements" is vague and could be interpreted as 3 breakers in a large system.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Based upon comments received, the SDT has modified Attachment 1 accordingly.</p>		
We Energies	No	<p>Attachment 1: From the NERC Glossary, an Energy Emergency: A condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements. The first four events listed can only apply to an LSE.</p> <p>Loss of Firm Load for &gt;15 Minutes: By the NERC Glossary definitions of DP and LSE, the LSE would seem to be more appropriate than the DP.</p> <p>With the proposed one-hour reporting requirement, the industry would be undertaking significant regulatory risk with respect to timely reporting. The requirement to report the crime-based events in the field within one</p>

Organization	Yes or No	Question 4 Comment
		<p>hour, as shown in Attachment 1 Part A or Part B will be difficult. We could even discover a theft in progress with the suspect trapped inside the substation fence and the police attempting to make a safe arrest. We need more reporting time, especially when they have not even resulted in an outage.</p> <p>The industry is keenly interested in understanding the benefit of taking on the risk. What analysis, insight, warnings or recommendations would the ES-ISAC provide to the reporting entity, the industry or to law enforcement agencies in the hours after such an incident is reported? Note too that DOE requires reporting of a physical attack within one hour only when it “causes a major interruption or major negative impact on critical infrastructure facilities or to operations.” In lesser cases, the entity gets up to six hours if it “impacts electric power system reliability.” DOE has said that it is not interested in copper theft unless it causes one of these events. If the SDT is working to ensure consistency of reporting requirements, please consider DOE requirements too. Meeting the reporting deadline will mean that available resources in the control center will be devoted to ensuring the report is filed on time instead of making the site safe and arranging for prompt repair. It may even mean that law enforcement won’t be contacted until the forms are filed with the ES-ISAC. The exception contained in footnote #1 of Attachment 1 with respect to copper theft is not an exception at all. The majority of copper theft from substations is, in fact, such grounding connectors which may or may not render the protective relaying inoperative. You could end up receiving reports from all over the USA, Canada and Mexico, mostly on Monday mornings as weekend copper thefts are discovered. Attachment 1 Part A table also contains redundancies. One of the cells reads, “Damage or Destruction of Critical Asset.” One cannot destroy something without damaging it first. Consequently, it is sufficient to simply say, “Damage to a Critical Asset.” Apply to all cells with the same phrase.</p>
<p><b>Response:</b> Thank you for your comments. Only Registered Entities affected by the event have to submit a report. Entities that were not affected by the event are under no obligation to submit a report. Registered Entities are to report what information they have at the submission timeline. The SDT recognizes that a final report may not be possible at the submission time. The reporting requirements are consistent with the current reporting requirements of the various authorities. The one hour reporting times are listed as “one hour within recognition of an event”. This should be sufficient to allow the reporting entity time to submit the report after the event has been recognized. Based upon comments received from many stakeholders, the SDT has modified Attachment 1. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <p>o “The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		

Organization	Yes or No	Question 4 Comment
Exelon	No	<p>Remove LSE. As has been determined in previous filings, FERC has ruled that asset owning DP's must be registered as LSE's. The standard as proposed is applicable to DP's. This addresses any concern with a "reliability gap" for reporting events that could have an adverse material impact to the BES. See FERC Docket RC-07-4-003, -6-003, -7-003 paragraphs 24 and 25. "The Commission approves ... revisions to the Registry Criteria to have registered distribution providers also register as the LSE for all load directly connected to their distribution facilities... The registration of the distribution provider as the LSE for all load directly connected to its distribution facilities is for the purpose of compliance with the Reliability Standards. As NERC explains, distribution providers have both the infrastructure and access to information to enable them to comply with the Reliability Standards that apply to LSEs... The Commission finds that, based on these facts, NERC acted reasonably in determining that the distribution provider is the most appropriate entity to register as the LSE for the load directly connected to its distribution facilities."</p> <p>Attachment 1, Part A – Energy Emergency requiring Public appeal for load reduction – In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency." Suggest revising back to specific entities that would be likely responsible for this action (e.g., RC, BA, TOP). Attachment 1, Part A – Energy Emergency requiring system-wide voltage reduction – In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency" related to system-wide voltage reduction. Suggest revising back to specific entities that would be likely responsible for this action. Attachment 1, Part A – Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 continuous minutes, this should be a TOP RC function only. Attachment 1,</p> <p>Part A – Loss of off-site power (grid supply) affecting a nuclear generating station – this event applicability should be removed in its entirety for a Nuclear Plant Generator Operator. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design, if it is a partial loss of off-site power (per the plant specific NPIRs) and may not result in a loss of generation (i.e., unit trip). If a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a Nuclear Plant Generator Operator during a potential transient on the unit. In addition, if the loss of off-site power were to result in a unit trip, if the impact to the BES were ≥2,000 MW, then required notifications would be made in accordance with the threshold for reporting for Attachment 1, Part A – Generation Loss. However, to align with the importance of ensuring nuclear plant safe operation and shutdown as implemented in NERC Standard NUC-001, if a transmission entity experiences an event that causes an unplanned loss of off-site power (source) as defined in the applicable Nuclear Plant Interface Requirements, then the responsible</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		<p>transmission entity should report the event within 24 hours after occurrence. In addition, replace the words "grid supply" to "source" to ensure that notification occurs on an unplanned loss of one or multiple sources to a nuclear power plant. Suggest rewording as follows (including replacing the words "grid supply" to "source" and adding in the word "unplanned" to eliminate unnecessary reporting of planned maintenance activities in the table below): Event Entity with Reporting Responsibility Threshold for Reporting Time to Submit Report Unplanned loss of off-site power to a Nuclear generating plant (source) as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) Each transmission entity responsible for providing services related to NPIRs (e.g., RC, BA, TO, TOP, TO, GO, GOP) that experiences the event causing an unplanned loss of off-site power (source) Unplanned loss of off-site power (source) to a Nuclear Power Plant as defined in the applicable NPIRs. Within 24 hours after occurrence</p>
<p><b>Response:</b> Thank you for your comments. The SDT constructed Attachment 1 based upon the existing requirements in the various reliability standards and established reporting obligations. The LSE is an applicable entity under CIP-002 and CIP-008. The types of events that you list are not applicable to a GO/GOP. The Applicability section of the standard lists each entity that is applicable for some portion of the standard. The information in Attachment 1 specifies which entity must report for which type of event. The loss of off-site power is only applicable to the TO and TOP and not the nuclear plant operator.</p>		
SDG&E	No	<p>SDG&amp;E recommends that "Load Serving Entity," "Transmission Service Provider," and "Interchange Authority" be removed from the proposed applicability shown in Section 4. These entities do not own assets that could have an impact on the Bulk Electric System. Additionally, none of these entities is listed as an "Entity with Reporting Responsibility" in Attachment 1. Finally, "Transmission Service Provider" is covered by either "Transmission Owner" or "Balancing Authority," which are entities also listed in the proposed Applicability section, and "Load Service Entity" and "Interchange Authority" are covered by "Balancing Authority."</p>
<p><b>Response:</b> Thank you for your comments. The SDT constructed Attachment 1 based upon the existing requirements in the various reliability standards and established reporting obligations. The LSE, TSP and IC are applicable entities under CIP-002 and CIP-008.</p>		
United Illuminating Co	No	<p>Will an entity be required to develop an Operating Process for every Impact Event in Attachment 1, or only those events that apply to its Registration. For example, does a DP require evidence of an Operating Process/Procedure for Voltage Deviations on a BES Facility? Some items in Attachment 1 state "Each RC, BA, TOP, DP that experiences the Impact Event" (such as Loss of Firm Load). DP's may have arranged with TOP and RC to communicate the event to TOP who then will file the NERC report and OE-417. The requirements in the Standard would allow for this as long as the Operating Plan documents it. Attachment 1 though can be interpreted that this arrangement would not be allowed and each entity shall file its own and separate report. UI suggests that Attachment 1 be modified to allow for an Entities Operating Plan to rely on another Entity making the final communication to NERC. "Each RC, BA, TOP, DP that experiences the Impact Event, either individually or combined on a single filing"</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it is not necessary to develop a separate Operating Process for each event, unless the company requires it. The SDT feels that any Registered Entity affected by an event needs to submit a report. The SDT believes that the Registered Entity can utilize any resource it has available to complete the reporting obligations and does not believe that Attachment 1 inhibits any options from being used. Based upon comments received, the SDT has decided to remove the definition of Impact Event from the standard and leave as identified through Attachment 1.</p>		
American Municipal Power	No	No, I do not agree. The DP and LSE functions should be removed.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT constructed Attachment based upon the existing requirements in the various reliability standards and established reporting obligations. This information will be useful to all owners, operators, and users of the bulk power system. The DP and LSE are applicable entities under CIP-002 and CIP-008.</p>		
Sweeny Cogeneration LP	No	In Attachment 1, Generator Operators who experience a ± 10% sustained voltage deviation for ≥ 15 continuous must issue a report For externally driven events, the GOP will have little if any knowledge of the cause or remedies taken to address it. We believe the language presently in EOP-004-1 is satisfactory that any “action taken by a Generator Operator” that results in a voltage deviation has to be reported by the GOP.
<p><b>Response:</b> Thank you for your comment. Reporting of events is an obligation of affected Registered Entities. Registered Entities who do not experience an event do not have any reporting obligations.</p>		
Independent Electricity System Operator	No	<p>We disagree with the following inclusion/exclusion of several entities:</p> <p>a. We assess that the applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. If our reasoning is correct, we question why NERC was dropped from the Applicability Section as it is an applicable entity identified in CIP-002-3.</p> <p>b. If the above approach was not strictly followed, then we’d suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, they will be subject to reporting. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard. The SDT has reviewed the CIP-002-3</p>		



Organization	Yes or No	Question 4 Comment
		<p>standard and have added the ERO and the RE as applicable entities. If an IA, TSP or LSE does not own Critical Assets nor Critical Cyber Assets, then they will have nothing to report under this standard.</p>
Ameren	No	<p>The 1 hour reporting requirement, as reference in Attachment 1 is inappropriate. In the event an "Impact Event" were to be discovered the Responsible Entity should focus on public and personnel safety. The reporting requirement should read "Within 1 hour or as soon as conditions are deemed to be safe." This statement would be applicable to "Damage or destruction of Critical Asset" The SDT should not put personnel in the position of choosing to either comply with NERC or address public or co-worker safety. The Time to Submit Report states "within 1 hour after occurrence is identified" This gives an auditor a wide area to question. If personnel report the occurrence 1 hour after identified, but 24 hours after it occurred, we are subject to the personal beliefs of the auditor that the event was not identified 24 hours ago, and reported 24 hours late. This will also be difficult to measure as the operator will have to document in the plant log the time the event was identified, while possibly dealing with Emergency Conditions. In the Note above the Actual Reliability Impact Table, the SDT identifies that under certain conditions, NERC / RRO staff may not be available for continuous 24 hour reporting. The SDT should consider the same stipulations apply to operating personnel and they should not be held to a higher standard than NERC / RRO.</p>
<p><b>Response:</b> Thank you for your comment. The reporting timelines for most events have been changed from 1 hour to 24 hours. The events that retain the one hour requirement are those that are more closely related to sabotage type events. The DSR SDT chose the wording "upon identification of an event" to allow for cases where an event may not be recognized for some time due to an asset being in a remote location for example. It is expected that an auditor will follow what is written in the standard rather than their personal preference. In the note above Attachment 1, it does not state that the ERO may not be available. This note is related to R3.3 of EOP_004-1 and provides for delayed reporting by an entity during storms or other such instances.</p>		
ISO New England, Inc	No	<p>We disagree with the following inclusion/exclusion of several entities:</p> <ul style="list-style-type: none"> <li>a. We acknowledge that the applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. If our reasoning is correct, we question why NERC was dropped from the Applicability Section as it is an applicable entity identified in CIP-002-3.</li> <li>b. If the above approach was not strictly followed, then we'd suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.</li> <li>c. There is still significant duplicate reporting included. For instance, why do both the RC and TOP to report</li> </ul>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
		voltage deviations? As written, a voltage deviation on the BES would require both to report. The same would hold true for IROLs. Perhaps IROLs should only be reported by the RC to be consistent with the recently FERC approved Interconnection Reliability Operating Limit standards.
<p><b>Response:</b> The DSR SDT thanks you for your comment. (a) The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard. The SDT has reviewed the CIP-002-3 standard and have added the ERO and the RE as applicable entities. (b) The IA, TSP and LSE are included in the Applicability only as it relates to CIP-002 events listed in the table. (c) The DSR SDT has removed the RC from "Voltage Deviations" and the TOP from the IROL to address the comment.</p>		
Calpine Corp	No	Expanding the current applicability of CIP-001-1 and EOP-004-1 to the GO function is unnecessary and will result in numerous duplicate reports, self-certifications, spot checks, and audits reviews, with no benefit to the reliability of the Bulk Electric System. The GOP is the appropriate applicable entity for generation facilities.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities may provide valuable information on understanding the event. The SDT would like to point out that reporting of events is from the time of identification not the time of the event.</p>		
Occidental Power Marketing	No	Load Serving Entities that do not own or operate BES assets (or assets that support the BES) should not be included in the Applicability. The SDT includes LSEs based on CIP-002; however, if the LSE does not have any BES assets (or assets that support the BES), CIP-002 should also not be applicable because the LSE could not have any Critical Assets or Critical Cyber Assets. It is understood that the SDT is trying to comply with FERC Order 693, Sections 460 and 461; however, Section 461 also states: "Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns." A qualifier in the Applicability of EOP-004-2 that would include only LSEs that own, operate or control BES assets (or assets that support the BES) would seem appropriate and acceptable to FERC.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. The LSE is an applicable entity under CIP-002 and CIP-008. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard.</p>		

Organization	Yes or No	Question 4 Comment
American Transmission Company	No	<p>First, under Part A, the reporting requirement for three or more BES Transmission Elements will create confusion. The NERC definition for an Element is: “Any electrical device with terminals that may be connected to other electrical devices such as a generator, transformer, circuit breaker, bus section, or transmission line. An element may be comprised of one or more components.” This could be interpreted to be three potential transformers on a bus section; therefore, any bus section would require a report. It is suggested that this be reworded to indicate three or more BES transmission lines, bus sections, or transformers.</p> <p>Second, under Part A, the reporting requirement for “Damage or destruction of BES equipment” is too broad and needs to be modified. For example, an output contact on a relay could be damaged unintentionally during routine testing resulting in a reportable event. It is suggested that the list of BES equipment and full intent of this be further defined in the footnote. The intent needs to be clarified, such as “events that have an immediate and significant impact to the stability or reliability of the BES.”</p> <p>Third, under Part A, the reporting requirement for “Damage or destruction of a Critical Cyber Asset” is too broad and needs to be modified. For example, an output contact on a relay could be damaged unintentionally during routine testing resulting in a reportable event.</p>
<p><b>Response:</b> Thank you for your comments. (1) The event “Transmission Loss” has been modified to remove the word Element. This now refers to Facilities. 2. If damage to a contact on a relay poses a reliability threat, then it should be reported. There is a footnote for this the type of event that helps clarify what is expected to be reported. It states:</p> <p>1 BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service. Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).</p> <p>3. This relates only to Critical Cyber Assets identified under CIP-002. If a relay contact is identified under CIP-002 as a Critical Cyber Asset, then its damage or destruction should be reported.</p>		
Ingleside Cogeneration LP	No	<p>Owners and operators of facilities whose total removal from the BES would not meet any reportable threshold under Attachment 1 should not have to create and maintain Operating documents. The same would be true of any LSE, TSP, or IA that does not oversee any Critical Cyber Assets as identified under CIP-002. A statement to that effect could be made in Section 4 of EOP-004-2.</p>
<p><b>Response:</b> Thank you for your comments. Requirements under Standards can only be enforced against Registered Entities, not whether or not they own or operate certain types of assets. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. If those standards are modified to remove the applicability to these</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
functional registrations, then the appropriate SDT can modify the applicability of this standard.		
Duke Energy	No	Section 4 is fine, but on Attachment 1, Entity with Reporting Responsibility should just identify “Initiating entity” for every Event, as was done with the first three Events. That way you avoid errors in leaving an entity off, or including an entity incorrectly (as was done with the GOP on Voltage Deviations).
<b>Response:</b> Thank you for comment. The SDT considered your comment in the development of Attachment 1 decided against including the Initiating Entity designation as it was not appropriate in those cases. Based upon comments received, the SDT has modified Attachment 1 accordingly.		
Constellation Power Generation	No	As stated in comments to earlier versions of EOP-004-2, CPG disagrees with the inclusion of Generator Owners. Since one of the goals in revising this standard is to streamline impact event reporting obligations, Generator Operators are the appropriate entity to manage event reporting as the entity most aware of events should they arise. At times, the information required to complete a report may warrant input from entities connected to generation, but the generator operator remains the best entity to fulfill the reporting obligation.
<b>Response:</b> Thank you for your comment. The SDT has chosen not to distinguish between Registered Entities as far as reporting. Instead the SDT has included Registered Entities which are involved or potentially involved in the types of events. Registered Entities need to recognize that only entities that are affected by the event have the reporting obligation.		
Georgia System Operations Corporation	No	We do not agree that this standard assigns clear responsibility for reporting. It seems that multiple entities are being required to report the same event for some events. Only one entity should report. See comments later regarding Attachment 1. NERC should not decide which ONE entity should report. The entities should be allowed to decide this (and include it in the Impact Event Operating Plan) and to let NERC or the region know who will report (or give them a copy of the plan).
<b>Response:</b> Thank you for your comment. The SDT has chosen not to distinguish between Registered Entities as far as reporting. Instead the SDT has included Registered Entities which are involved or potentially involved in the types of events. Registered Entities need to recognize that only entities that are affected by the event have the reporting obligation.		
Indeck Energy Services	No	Voltage Deviations should not be reportable by GOP. That's why we have TOP's.  Damage or destruction of BES equipment should be reportable only if it causes or could cause a Reportable Disturbance, reportable DOE OE-417 event or sabotage (as defined above). Otherwise, an auditor could require reporting of a relay failure caused by human error even though the relay was in test mode and no BES impact was experienced. This category could be dropped in favor of the next one, damage to Critical Asset.  Fuel Supply Emergency needs a definition. For natural gas, various conditions could be referred to as

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		<p>emergencies, but unless they actually affect generation, they should not need to be reported. Fuel Supply Emergencies that cause a Reportable Disturbance or reportable DOE OE-417 event should be reported.</p> <p>It is unclear why Forced Intrusion should be reportable under EOP-004. If it causes a problem, it will be reportable as another category and is one more unpreventable event. Forced Intrusion isn't, in many cases, as the exceptions try to define, an impact event at all, but could be a cause, which would be reported as the cause of an impact event.</p> <p>Risk to BES Equipment is not well defined. It should be expanded to Risk to BES Equipment from a non-environmental physical threat within a reasonable distance of the Equipment. A train derailment on the line past the plant would likely be known, whereas one that was 1/2 mile or more away with flammable materials might not be known about unless a public warning was made.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Voltage Deviation reporting no longer applies to the GOP. There is a footnote on Damage or Destruction to BES equipment that addresses your comment. It states:</p> <p><sup>1</sup>BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service. Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).</p> <p>Fuel Supply Emergency has been removed from Attachment 1. Forced Intrusion is an event could be related to sabotage. Identification and reporting of such events may help identify trends. The footnote associated with Risk TO BES Equipment addresses your comment:</p> <p>Examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment.</p>		
Brazos Electric Power Cooperative	No	Inclusion of LSE and DP is questionable.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. The LSE and DP are applicable entities under CIP-002 and CIP-008. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities may provide valuable information on understanding the event. The SDT would like to point out that reporting of events is from the time of identification not the time of the event.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
Manitoba Hydro	Yes	All registered entities are included. This means all field and office personal involved will create a 360 degree view of the BES, and fulfill “Situational awareness of the industry.” In Attachment 1, the “Entity with Reporting Responsibility” entities vary. It might be clearer to leave all impact levels “Entity with Reporting Responsibility” as the RC, BA and TOP, as these are likely the only parties that will report as required. All other entities must report to the RC, BA and TOP.
<p><b>Response:</b> Thank you for your comment. The SDT had previously considered a hierarchal approach to report; however, this concept was rejected by the industry.</p>		
American Electric Power	Yes	AEP agrees, but it further supports the notion that this standard should not apply to the IA, TSP, and LSE functions.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT constructed Attachment based upon the existing requirements in the various reliability standards and established reporting obligations. The LSE, TSP and IC are applicable entities under CIP-002 and CIP-008. The information about an event will be useful to all owners, operators, and users of the bulk power system.</p>		
Southern Company	Yes	<p>This will cause the duplication of reporting for some events.</p> <p>Reference EOP-004 Attachment 1: Impact Events Table; Event - Loss of Firm Load for ≥ 15 minutes (page 15 of standard)</p> <p>This requires the RC, BA, TOP, and DP to report. So if a storm front goes through our system and takes out 400MW of load in Alabama and Georgia the PCC would have to report as the RC, BA, and TOP. Alabama Power and Georgia Power would also have to report as DPs. The way it is now the PCC reports for any of these events.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities for the same event may provide a more complete understanding of the event.</p>		
Pepco Holdings Inc and Affiliates	Yes	More guidance is needed for which entity in Attachment 1 actually files the report to avoid duplicate filing.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
from different entities for the same event may provide a more complete understanding of the event.		
Midwest ISO Standards Collaborators	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
Western Electricity Coordinating Council	Yes	
PPL Supply	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 4 Comment
ExxonMobil Research and Engineering	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Progress Energy	Yes	
<p><b>Response:</b> The DSR SDT thanks you for your comment. Several commenters provided suggestions that led to modifications of Attachment 1.</p>		



5. Stakeholders suggested removing original Requirements 1, 7 and 8 from the standard and addressing the reliability concepts in the NERC Rules of Procedure. Do you agree with the removal of original requirements 1, 7 and 8 (which were assigned to the ERO) and the proposed language for the Rules of Procedure (Paragraph 812)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

**Summary Consideration:** Most commenters agreed with the removal of R1, R7 and R8. The SDT has provided suggested language to NERC for inclusion into the Rules of Procedure.

Organization	Yes or No	Question 5 Comment
Midwest ISO Standards Collaborators	No	We see no issue with imposing requirements on NERC. However, we are not opposed to making these changes in the Rules of Procedure either.
<b>Response:</b> Thank you for your comments. We are pursuing changes to the Rules of Procedure.		
SERC OC Standards Review Group	No	We agree that the ERO should not have requirements applicable to them, but disagree with changing or revising the Rules of Procedure (ROP) giving this reporting responsibility solely to NERC. This responsibility may be performed by NERC but other learning organizations should also be considered for performing this responsibility. In addition, the proposed wording of the revision to the ROP appears to place the responsibility of notifying the appropriate law enforcement with NERC rather than with the local responsible entity.
<b>Response:</b> Thank you for your comments. The responsibility for notifying law enforcement remains with the entity and has been clarified in Attachment 1.		
PJM Interconnection LLC	No	We agree that the standard should not have requirements applicable to the ERO, but disagree with revising the NERC Rules of Procedure (RoP) to include suggested Section 812. The reporting responsibility should not be solely given to NERC. Other learning organizations must also be considered for performing this responsibility. Additionally, the proposed wording of Section 812 appears to imply that NERC will notify the appropriate law enforcement agencies as opposed to the local responsible entity.
<b>Response:</b> Thank you for your comments. The responsibility for notifying law enforcement remains with the entity and has been clarified in Attachment 1.		
SDG&E	No	SDG&E agrees with removing original Requirements 1, 7, 8 from the standard. In addition, SDG&E recommends that the standard reference Section 812 of the Rules of Procedure.

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 5 Comment
<b>Response:</b> Thank you for your comments.		
Duke Energy	No	Proposed language for Section 812 is very confusing. Is the NERC “system” really going to perform all notifications: “applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, and regulatory agencies as necessary?” Is it intended that the NERC “system” will relieve registered entities of the obligation to make these other reports? Is there an implementation plan to achieve that objective? It appears that this current version of EOP-004-2 has the potential for significantly creating redundant reporting. Will the NERC reports be protected from FOIA disclosure? How will FERC Order 630 be followed (CEII disclosure)?
<b>Response:</b> Thank you for your comments. The SDT expects any system would facilitate the reporting to organizations specified in the submitted report. Until such time that the system can be established, the Registered Entity will be obligated to make the notifications as specified in its Operating Plan(s). The SDT has proposed an amendment to the NERC Rules of Procedure to assist in the development of a single reporting process for all three obligations.		
ExxonMobil Research and Engineering	No	Abstain from commenting on this question.
Brazos Electric Power Cooperative	No	
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration agrees that the NERC Rules of Procedure are the appropriate location for ERO assigned activities. However, we would like to get a solid commitment from NERC that the Events Analysis Process and the Reliability Assessment and Performance Analysis Group (RAPA) data analysis requirements for Protection System Misoperations is coordinated through a single process. Their unique data needs are understandable, but should not require the downstream entity to evaluate what is required by each sub-committee - and which reporting template to use.
<b>Response:</b> Thank you for your comments. Your comment addresses a concern that is beyond the scope of this project and cannot be addressed here. The SDT has communicated with the NERC Events Analysis Working Group and DOE in efforts to develop a single reporting process. The SDT will continue to work with those organizations to complete this task.		
Northeast Power Coordinating Council	Yes	Agree with the proposed removal, but have not assessed the proposed language for RoP para. 812 because unable to access it (not on the RoP page).
<b>Response:</b> Thank you for your comments.		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 5 Comment
Bonneville Power Administration	Yes	Ensure distribution of trends.
<b>Response:</b> Thank you for your comments.		
Midwest Reliability Organization	Yes	The ERO is not a user, owner or operator of the BES and the best place to contain their responsibilities, is in the Rules of Procedure.
<b>Response:</b> Thank you for your comments.		
Pepco Holdings Inc and Affiliates	Yes	Agree that NERC should not have requirements applicable to them.
<b>Response:</b> Thank you for your comments.		
American Municipal Power	Yes	A software solution may provide an easy expansion for reporting EOP-004, CIP-001, and additional standards.
<b>Response:</b> Thank you for your comments.		
Manitoba Hydro	Yes	Agree with R1, a central system for receiving and distributing reports. There is limited time and resources for control operators to follow up and ensure ALL required entities have received all information required in a timely manner. Agree with R7 and R8.
<b>Response:</b> Thank you for your comments.		
Sweeny Cogeneration LP	Yes	We agree that these requirements appropriately belong in the NERC Rules of Procedure. However, we are concerned with the multiple reporting requirements being driven by EOP-004-2, CIP-008-3, the ERO Events Analysis Team, the Reliability Assessment and Performance Analysis Group (RAPA). It is imperative that these efforts be consolidated into a single procedure using a single reporting template.
<b>Response:</b> Thank you for your comments. The DSR SDT agrees with the concept of the single reporting template and is working with other agencies to see if the single form would be achievable.		
Western Electricity Coordinating Council	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 5 Comment
PPL Supply	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Dominion	Yes	
SPP Standards Review Group	Yes	
FirstEnergy	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	
Compliance & Responsibility Organization	Yes	
Exelon	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
Liberty Electric Power LLC	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 5 Comment
Arkansas Electric Cooperative Corporation	Yes	
American Electric Power	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
ISO New England, Inc	Yes	
Platte River Power Authority	Yes	
Calpine Corp	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 5 Comment
Constellation Power Generation	Yes	
Georgia System Operations Corporation	Yes	None.
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Indeck Energy Services	Yes	
Progress Energy	Yes	

**6. Do you agree with the proposed revisions to Requirement 2 (now R1) including the use of defined terms Operating Plan, Operating Process and Operating Procedure? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Stakeholders were fairly evenly divided on this question. Overall, there appears to be a misconception on what is and isn't included in the Operating Plan(s). The SDT believes that current Sabotage Reporting substantially meets the requirements outlined in the standard, albeit there may be some needed alterations to accommodate the new standard. The updated subrequirement is a result of a FERC directive in Order No. 693. The DSR SDT removed references to Operating Process and Operating Procedure and revised the Requirement to:

R1. Each Responsible Entity shall have an Operating Plan that includes: [Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]

1.1. A process for identifying events listed in Attachment 1.

1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.

1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate:

- Internal company personnel
- The Responsible Entity's Regional Entity
- Law enforcement
- Governmental or provincial agencies

1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to R3.

1.5. A Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.

Organization	Yes or No	Question 6 Comment
Georgia Transmission Corporation & Oglethorpe Power	No	The terms "Operating Procedure, Operating Plan, and Operating Process," while included in the NERC glossary, are not consistently used throughout the body of NERC standards as they are used in R1 of EOP-

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
Corporation		<p>004-2. As such, we do not see a reliability benefit in using the defined terms over the more commonly used terms of simply "plans, processes, and procedures." In part 1.1 of R1, we think that the requirement should clearly indicate that a particular Responsible Entity's Impact Event Plan should only be required to include those particular Impact Events for which the Responsible Entity has the reporting obligation. Therefore, we suggest the following modification to R1:</p> <p>"1.1 An Operating Process for identifying Impact Events listed in Attachment 1 for those Impact Events where the Responsible Entity is identified as having the reporting responsibility."</p> <p>Additionally, in part 1.3 of R1, we believe the language to be vague and will introduce the need for further clarification either through an interpretation or the CAN process in part because the verb tenses of the sub-sub-requirements do not agree and it appears to require notification to all listed parties for every Impact Event instead of only those that make sense for a particular event.</p> <p>As such, we suggest adding a column to the tables in Attachment 1 that identifies precisely which organizations should be notified in the case of a particular Impact Event and modifying part 1.3.2 to read:</p> <p>"1.3.2 External organizations to notify as specified in Attachment 1."</p> <p>Currently, as written, the standard could be interpreted to require notification to law enforcement for an IROL violation, for instance. Furthermore, we are concerned that as written, the standard may require that the same event must be reported by multiple responsible entities. Our current process uses notification between Responsible Entities (i.e. from a TO to a TOP and then from the TOP to NERC) to allow for a centralized and coordinated notification to law enforcement, NERC, etc. We are concerned that the requirement as written does not appear to allow this flexibility and may require both the TO and TOP to report the same event in order to prove compliance with the Standard.</p>
<p><b>Response:</b> Thank you for your comments. The SDT believes that in order for a term to become consistent with the body of the reliability standards, each SDT will have to incorporate the terms as the opportunity to revise each standard arises. The SDT envisions that each Registered Entity will develop Operating Plan(s) appropriate to meet its obligations as outlined in the standard. Part 1.3 has been revised to indicate that each report must be sent to the ERO and the Registered Entity's Reliability Coordinator and the remaining entities as appropriate. Law Enforcement would certainly not be interested in an IROL violation, but they would be interested in Forced Intrusion.</p>		
Bonneville Power Administration	No	Not sure that a 90-day update is needed to be sent to CEF.
<p><b>Response:</b> Thank you for your comments. That is not required in the standard. The SDT believes that it is unnecessary to forward any update to any organization outside of the Registered Entity. Updates should be used to inform internal personnel of any Operating Plan changes.</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Pacific Northwest Small Public Power Utility Comment Group	No	1.4 makes no sense. The operating plan update and the change to its content occur simultaneously. Perhaps the SDT meant to say “Provision(s) for updating the Impact Event Operating Plan within 90 days of identification of a needed change to its content. This would be consistent with the “lessons learned” language of the prior version.
<p><b>Response:</b> Thank you for your comment. The DSR SDT added additional detail to Part 1.4 to address the broader term “content.”</p>		
PSEG Companies	No	The PSEG Companies believe that sections 1.3 and 1.3.2 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. This is appropriate for some events if there has been destruction to BES equipment, for example, but not in certain operational events. It should not be necessary to notify law enforcement that a non sabotage event like an IROL violation, generation loss or voltage deviation has occurred.
<p><b>Response:</b> Thank you for your comments. The DSR SDT feels that the Registered Entity will establish Operating Plan(s) appropriate for its needs including the specification of how and when law enforcement agencies are contacted. Part 1.3 has been revised to indicate that each report must be sent to the ERO and the Registered Entity's Reliability Coordinator and the remaining entities as appropriate. Law Enforcement would certainly not be interested in an IROL violation, but they would be interested in Forced Intrusion. Attachment 1 language has been updated to say “The parties identified...” which should be included in the entity's Operating Plan(s).</p>		
Dominion	No	<p>The requirement for Responsible Entities to establish an Impact Event Operating Plan, Operating Process, and Operating Procedure seems overly cumbersome and prescriptive. The use of these NERC defined terms create additional compliance burden for little, if any, improvement to reliability. Suggest simplification by requiring the Responsible Entities to have a procedure to report Impact Events, to the appropriate parties, pursuant to EOP-004.</p> <p>In addition, we request clarification of R1.4. It seems circular to us in that it requires the plan to be updated within 90 days of when it changes. Is the intent that any necessary changes identified in the annual review required by R4 be incorporated in a revision to the plan within 90 days of the review? If so, R1.4 belongs under R4. If not, we do not understand the requirement.</p> <p>What starts the 90 day count down?</p>
<p><b>Response:</b> Thank you for your comment. The language in Requirement R1, Part 1.4 was inserted in response to a directive in FERC Order 693. The SDT feels that the directive requires Registered Entities to update their Operating Plan(s) within 90 days of the time the entity identified the need for the change, such as a new telephone number, personnel staff name/title, or addition/deletion of person or organization. The DSR SDT has made changes to better clarify “content.”</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Pepco Holdings Inc and Affiliates	No	An Operating Plan, Operating Process or Operating Procedure implies something different than an after the fact reporting activity.
<p><b>Response:</b> Thank you for your comment. An Operating Plan is more than an after the fact reporting activity. The Operating Plan(s) incorporates the tasks or steps involved in the identification of events, establishing which internal personnel are to be involved in the communications and or reporting, and establishing the list of outside organizations to be contacted when an event happens.</p>		
SPP Standards Review Group	No	<p>We would suggest rewording Part 1.3.2 to read “External organizations to notify may include but are not limited to the Responsible Entity’s Reliability Coordinator, NERC, Responsible Entity’s Regional Entity, Law Enforcement and Governmental or Provincial Agencies.”</p> <p>We would also suggest the following for Part 1.4: “Provision(s) for updating the Impact Event Operating Plan within 90 days of any known changes to its content.”</p> <p>Would also suggest adding “as requested” at the end of M1.</p>
<p><b>Response:</b> Thank you for your comments. (1) Requirement R1, Part 1.3 has been updated to “as appropriate” to address the parties to communicate event to. (2) The SDT agrees with your suggestions and has made similar word changes. 3) Agreed.</p>		
Midwest ISO Standards Collaborators	No	<p>We do not believe that the use of the Operating Process, Operating Procedure, and Operating Plan for a reporting requirement is consistent with their definitions and certainly not with the intent of the definitions. For instance, an Operating Process is intended to meet an operating goal. What operating goal does this requirement meet?</p> <p>An Operating Procedure includes tasks that must be completed by “specific operating positions.” This reporting requirement could be met by back office personnel. We also believe that parts 1.3 and 1.3.2 under Requirement 1 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. While some should require notification to law enforcement such as when firm load is shed, others certainly would not. For instance, law enforcement does not need to know that an IROL violation, generation loss or voltage deviation occurred.</p>
<p><b>Response:</b> Thank you for your comments. The Glossary Definition of Operating Plan is:</p> <p>A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.</p> <p>The definition uses “goal” rather than “operating goal”. The goal of the Operating Plan is to ensure that entities know how to identify the events listed in</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
<p>Attachment 1 and report them to the appropriate parties. The SDT disagrees with your views on Operating Process, Operating Procedure, and Operating Plan. The SDT appropriately describes the task at hand. The SDT feels that the Operating Plan can identify when law enforcement agencies need to be notified without specification from the SDT. The Background section of the standard contains a heading for “Law Enforcement” and provides clarification regarding the types of events that should be reported to law enforcement.</p>		
FirstEnergy	No	<ol style="list-style-type: none"> <li>1. We believe that the use of stringent definitions for an entity’s process requires too much of the “how” instead of the “what.” As long as the entity has a process, procedure (or whatever they want to call it) that includes the necessary information detailed in sub-parts 1.1 through 1.4 then that should suffice.</li> <li>2. In sub-part 1.3, we suggest adding the phrase “as applicable” to clarify that not every event will require a notification to, for example, law enforcement.</li> <li>3. In sub-part 1.4, we suggest adding clarification that the 90-day framework is only required for substantive changes and that all other minor editorial changes can be updated within a year.</li> </ol>
<p><b>Response:</b> Thank you for your comments. (1) The SDT agrees with your suggestion that the entity can best determine what is included in its Operating Plan. The SDT does not envision instructing an entity on what or how of the Operating Plan(s). (2) The SDT feels that the Operating Plan can identify when law enforcement agencies need to be notified without specification from the SDT. (3) The update requirement comes from a FERC directive in Order No. 693. The SDT has validated the intent of the directive and has included that intent in the requirement. The SDT feels that the directive requires Registered Entities to update their Operating Plan(s) within 90 days of the time the entity identified the need for the change, such as a new telephone number, personnel staff name/title, or addition/deletion of person or organization. The DSR SDT has made changes to better clarify “content.”</p>		
SERC OC Standards Review Group	No	<p>This is a reporting requirement and should not be confused with Operating Plans that have specific operating actions and goals. Each entity should prepare its own event reporting guideline that address impact events, identification, information gathering, and communication without specifying a specific format such as Operating Plans, Operating Process and Operating Procedures.</p>
<p><b>Response:</b> Thank you for your comment. The SDT agrees with your viewpoint and believes that your statement is consistent with the intent of the requirement.</p>		
PJM Interconnection LLC	No	<ol style="list-style-type: none"> <li>1. This is an “after-the-fact” reporting requirement and should not be confused with Operating Plans that have specific operating actions and goals. Each entity should prepare its own impact event operating guideline that addresses impact events, identification of impact events, information gathering, and communication without specifying a specific format such as Operating Plans, Operating Process, and Operating Procedures. In fact, all three documents mentioned can all be a single document.</li> <li>2. 1.3.2 requires notification of law enforcement agencies for all events listed in Attachment 1. This is essentially not true. For example, firm load is shed requires notification to law enforcement but an IROL</li> </ol>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
		violation, generation loss, or voltage deviation do not.
<p><b>Response:</b> Thank you for your comment. (1) The SDT disagrees with your viewpoint that this requirement specifies after-the-fact reporting. The reporting requirement is later in the standard. The SDT agrees with your viewpoint on the operating guideline you provide and believes that your statement is consistent with the intent of the requirement. (2) The SDT believes that the Registered Entity’s Operating Plan(s) can establish when and how law enforcement agencies are notified.</p>		
We Energies	No	<p>R1.2: By its NERC Glossary definition, an Operating Procedure is too prescriptive for data collection. An Operating Procedure requires specific steps to be taken by specific people in a specific order. We would have to predict every event that could happen to have every step in proper order to collect the data. It will be impossible to comply with this requirement.</p> <p>R1.3: Change “Impact Event” to “Impact Event listed in Attachment 1.”</p>
<p><b>Response:</b> Thank you for your comment. The SDT has changed R1 to simply “Operating Plan. The term “Impact Event” has been removed from the standard and R1 and its Parts refer to Attachment 1 as appropriate.</p>		
Compliance & Responsibility Organization	No	<p>See comments to 2. Also, although NextEra agrees that a documented procedure is appropriate, NextEra does not favor the current approach of pre-defined layers of processes and documentation that seem to overly complicate, and, possibly contradict, already established internal methods by which a company implements policies, procedures and processes. Thus, NextEra’s options suggest using a more generic approach that allows entities more flexibility to establish documents and processes, and demonstrate compliance. Such a generic approach was used in NextEra’s proposed options set forth in response to number 2.</p>
<p><b>Response:</b> Thank you for your comments. The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2.</p>		
Exelon	No	<p>R.1 Does an entity need to develop a standalone Operating Plan if there is an existing process to address identification, assessing and reporting certain events?</p> <p>Suggest rewording to state "Each Responsible Entity shall have an Impact Event Operating Plan or equivalent implementing process that includes:"</p> <p>Disagree these new terms are required. Commonly accepted descriptions of programs, processes and procedures exist in registrar entities that would suffice. For example, R1 could use “Impact Event evaluation</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
		and reporting process” as a generic term to describe what is required. This would allow an entity to utilize any existing protocols or management guidelines and naming conventions in effect in their organization.
<p><b>Response:</b> Thank you for your comments. The SDT The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2. The Registered Entity will need to examine its current processes to ensure that all aspects of the new requirements are addressed. Thank you for the suggested re-wording. The SDT revised “Impact Event Operating Plan” to just “Operating Plan”, thus allowing the entity to implement the requirements as needed.</p>		
Tenaska	No	<p>We already have adequate procedures in place to address sabotage and other significant events, pursuant to the existing CIP-001-1 and EOP-004-1 Standards. The requirement to develop a new Impact Event Operating Plan would increase the administrative burden on Registered Entities to comply with the proposed Standard, without providing a foreseeable improvement in system reliability.</p> <p>The “laundry list” of required Impact Event Operating Plan components is too specific and would make it more difficult to prove compliance with EOP-004-2 during an audit.</p> <p>A revised version of the proposed R5 is the only Requirement that is necessary to achieve the stated purpose of Project 2009-01.</p>
<p><b>Response:</b> Thank you for your comments. The SDT The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2 and these should mostly meet the intent of EOP-004. The Registered Entity will need to examine its current processes to ensure that all aspects of the new requirements are addressed. The Parts of R1 are not prescriptive and only provide the minimum information that is required to be in the Operating Plan. The SDT has removed R2 and revised R5 (now R2) to eliminate any duplication.</p>		
United Illuminating Co	No	Does R1.1 require an Operating Process for each Impact Event in attachment 1 or an Operating Process that in general applies to all Impact Events?
<p><b>Response:</b> Thank you for question. The SDT feels that the Registered Entity can have an Operating Plan that in general applies to all events.</p>		
American Municipal Power	No	No, remove R1. R1 is not an acceptable requirement nor should this be an operation. Focusing on a plan and procedure is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> Thank you for your comment. The SDT agrees that the Registered Entity can decide on the how to implement the reporting; however, this requirement mandates that the Registered Entity document its process.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Arkansas Electric Cooperative Corporation	No	<p>We appreciate the effort the team has taken in improving the requirements since the last posting. For 1.3, it appears to suggest the communication must always include communicating to internal personnel and ALL external organizations. We suggest removing the reference to 1.3.1 and 1.3.2 and move 1.3.1 and 1.3.2 to 1.4 and 1.5 respectively. For 1.3.2, modify to state "Internal company personnel notification(s) deemed necessary by the Responsible Entity." For 1.4, we feel the term "content" is too broad as used here. For example, if the FBI changes the contact info for the JTTF, the Responsible Entity may not find out until an incident or annual exercise. Or if the contact person for the state agency changes position without notifying us, it would require us to then change the plan within 90 days. We suggest an annual review of the plan is sufficient for the objective of this requirement.</p>
<p><b>Response:</b> Thank you for your comments. The SDT has added language "as appropriate" to allow the entity to make its own determination who to contact. The term "content" has been removed and replaced with more detail. The requirement for updates requires changes within 90-days. The SDT believes that the timeline for updating can only be based upon the notification to the Registered Entity. The SDT believes that 90-days from the date the Registered Entity is notified or made aware of the change is a suitable time period to update the document.</p>		
Manitoba Hydro	No	<p>Plan, Process and Procedure are all too interchangeable with each other and have no value being used in "one paragraph" as they do not differentiate from one or other.</p> <p>The terms "identify", "gather" and "communicate" better describe "Process, plan or procedure" so simplify to: 1.4. Identification of Impact Events as listed in Attachment 1.1.5. Gathering information for inclusion into Attachment 2 regarding observed Impact Events listed in Attachment 1.1.6. Communicate recognized Impact Events to the following:</p>
<p><b>Response:</b> Thank you for your comments. The SDT has revised R1 to only include an Operating Plan. Part 1.2 has been revised to "A process for gathering information..."</p>		
American Electric Power	No	<p>Even best developed plans, processes and procedures do not always lend themselves to address the issues at hand. There needs to be flexibility to allow entities to first address the reliability concern and second report correspondingly. Currently, this requirement is overly prescriptive and places unnecessary emphasis on the means to an end and not the outcome. The outcome for this requirement is to report Impact Events.</p>
<p><b>Response:</b> Thank you for your comments. While the SDT appreciates your views, it disagrees with your assessment. The outcome of this requirement is not to report events; the outcome is to ensure that the Registered Entity has Operating Plan(s) for the identification of events, establishing which internal personnel are involved, identification of outside agencies to be notified, and having a provision for updating the plan(s). Reporting of events is a requirement later in the standard.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Consumers Energy	No	Requirement R1, "Have a plan..." with all of the listed criteria, seems to present a serious compliance risk to applicable entities without a direct reliability benefit, as long as entities still identify and report relevant events. Ad-hoc procedures, as discussed within the R1 "Rationale" have been acknowledged within the rationale to be working effectively, and should remain sufficient without having a documented and by inference, signed, approved, dated document with revision history (as is being demanded today by compliance auditors wherever a "documented plan" is specified within the requirements).
<p><b>Response:</b> Thank you for your comments. While the SDT appreciates your views, it disagrees with your assessment. The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2. The measure calls for a current, dated, in force Operating Plan to be provided.</p>		
ISO New England, Inc	No	<p>We do not believe that the use of the Operating Process, Operating Procedure, and Operating Plan for a reporting requirement is consistent with their definitions nor with the intent of the definitions. For instance, an Operating Process is intended to meet an operating goal. What operating goal does this requirement meet? An Operating Procedure includes tasks that must be completed by "specific operating positions." This reporting requirement could be met by back office personnel. We suggest that R1.3.2 delete the list of entities to notify. The terms used to identify who to notify are not defined terms and can lead to subjective interpretations. As written, the requirement does not aid the Applicable entity or the Compliance enforcers in clearly including or excluding who to notify.</p> <p>We also believe that parts 1.3 and 1.3.2 under Requirement 1 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. While some should require notification to law enforcement such as when there has been destruction to BES equipment, others certainly would not. For instance, law enforcement does not need to know that an IROL violation, generation loss or voltage deviation occurred.</p> <p>We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will be particularly difficult when support personnel are not present such as during nights, holidays and weekends.</p> <p>We further suggest that as explicit statement that "reliable operations must ALWAYS take precedence to reporting times" be included in the standard.</p>
<p><b>Response:</b> Thank you for your comments. While the SDT appreciates your views, it disagrees with your assessment.</p> <p>(P1) The outcome of this requirement is not to report events; the outcome is to ensure that the Registered Entity has Operating Plan(s) for the identification of events, establishing which internal personnel are involved, identification of outside agencies to be notified, and having a provision for updating the plan(s). The</p>		

Organization	Yes or No	Question 6 Comment
<p>SDT feels that current Sabotage Reporting guides already provides much of the information needed in the new R1.</p> <p>(P2) We have revised Requirement R1, Part 1.3 to “A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:” This should address your concern regarding law enforcement notification.</p> <p>(P3) We have revised most reporting times to 24 hours. Events of a “sabotage” type nature remain at one hour.</p> <p>(P4) While the DSR SDT sees the point you are trying to make, we do not believe that reporting the events in Attachment 1, under the times listed, is burdensome. At the least, this can be accomplished by back office personnel who are not involved in restoration or other reliability efforts.</p>		
Calpine Corp	No	<p>In the “Rationale for R1”, the draft states:</p> <p>“Every industry participant that owns or operates elements or devices on the grid has formal or informal process, procedure, or steps it takes to gather information regarding what happened and why it happened when Impact Events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized.”</p> <p>Absent substantial evidence that the proposed requirement addresses an actual systemic problem with the “formal or informal process, procedure, or steps it takes” for internal and external evaluation and notification of items listed in Attachment 1, there is no obvious need for this additional paperwork burden, which in most cases will result in a written procedure that documents another existing written procedure or procedures, that will be maintained for the sole purpose of demonstrating compliance with the requirement. Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Adding a requirement to implement an “Impact Event Operating Plan”, “Operating Procedure”, and “Operating Process” is unnecessary.</p> <p>However, if the requirement is maintained, the related Measure M1 should state in plain language exactly what elements are required for compliance. Statements such as “The Impact Event Operating Plan may include, but not be limited to, the following?” begs the question regarding what other elements are required to demonstrate compliance. As written, M1 requires that entities provide an “Impact Event Operating Plan”, but does specify the required elements of the plan.</p> <p>In the absence of much more detailed instruction on exactly what elements must be included in the various documents, the proposed requirement will create confusion with both compliance and enforcement of the requirement. An example of each of the various required documents would be helpful. Any difficulty in developing such an example would be instructive of the probable compliance issues that would ensue from the necessarily varying approaches taken by disparate entities attempting to meet the requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Requirement R1 comes from existing CIP-001, R1. The SDT believes it has addressed these concerns by removing the terms “Operating Procedure” and “Operating Process” and has generically referred to them in the elements of the Operating Plan outlined in</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

---

Organization	Yes or No	Question 6 Comment
<a href="#">Parts 1.1-1.5 of the requirement.</a>		
BGE	No	This seems overly restrictive in its use. Requirement is now telling entities how to resolve situations, not giving them a requirement to resolve the situation.
<b>Response:</b> Thank you for your comments. The requirement is written so that an entity has an Operating Plan that contains certain items. The SDT does not specify in the standard how the entity meets these obligations nor does it specify the form nor format of these items.		

Organization	Yes or No	Question 6 Comment
ExxonMobil Research and Engineering	No	<p>The requirement to notify State Law Enforcement deviates from existing government security requirements that Petrochemical Facilities (Cogenerators) are required to follow. Per the Maritime Transportation Security Act of 2002 (MTSA) and the Chemical Facility Anti-Terrorism Standard (CFATS), Petrochemical Facilities are required to report the security incidents identified in EOP-004 Revision 2 to the National Response Center which is staffed by the United States Coast Guard. The National Response Center coordinates incident reporting to both the Department of Homeland Security and Federal Bureau of Investigation. Requiring Petrochemical Facilities to report security incidences to State Law Enforcement agencies duplicates their reporting of incidences to the appropriate law enforcement agencies. EOP-004 Revision 2 should be modified to synergize with existing federal security regulations so that those facilities that are required to comply with the MTSA and CFATS are, by default, compliant with EOP-004 Revision 2 when they comply with these existing federal security regulations.</p> <p>It is unclear, from the documentation provided in this revision of EOP-004, which entities a Responsible Entity is required to notify when certain types of Impact Events occur. Previously, CIP-001 included a similarly vague instruction that required notifications to the 'appropriate parties in the interconnection' and the FBI/RCMP. The Standard Drafting Team should identify which NERC Functional Entities should be notified when each of the Impact Events identified in Attachment 1 occurs.</p> <p>Current revisions of CIP-001 Revision 1 or EOP-004 Revision 1 do not include corresponding requirements to update procedures within a certain time frame. It's difficult to foresee a situation where an Entity would initiate a change to its response plan without being required to update the formal response plan documentation per their management of change process. Additionally, failure to update the procedure would result in the entity deviating from the procedure any time an impact event occurred, which would automatically force a violation of EOP-004-2 R2 for failure to properly implement their Operating Process. Furthermore, the only changes occurring between review cycles should be revisions to the contact information for third parties. It is beyond an entity's power to require third parties to notify the entity when the third party changes their contact information, and, as such, this requirement burdens registered facilities with responsibility for compliance for items that are beyond their realm of control.</p>
<p><b>Response:</b> Thank you for your comments. (P1) The SDT believes that the requirement does not mandate contact to State Law Enforcement agencies; but merely to include them if appropriate. While we have tried to coordinate with the US DOE, Federal security regulations are outside the scope of this project. (P2) We have revised Requirement R1, Part 1.3 to “A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:” Each type of event should be assessed by the entity to determine whether or not law enforcement needs to be notified,</p> <p>(P3)The subrequirement for updating comes from a FERC directive in Order No. 693. If the Registered Entity’s Operating Plan(s) have a provision for updating, then the entity only needs to verify that the updating does not exceed 90 days from the date of being aware.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
Farmington Electric Utility System	No	consider rewording 1.4; the wording implies a change to content already occurred, so it would be updated concurrently ? consider, updating the plan within 90 days of discovery of content requiring a change?
<p><b>Response:</b> Thank you for your comment. The SDT agrees with your suggestion and has revised Requirement R1, Part 1.4 to: Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to R3.</p>		
Constellation Power Generation	No	<p>Per NERC’s glossary of terms, an Operating Plan can include Operating Process documents and Operating Procedures. An Operating Process identifies general tasks while an Operating Procedure identifies specific tasks.</p> <p>CPG is unclear as to why R1.1 and R1.3 require the use of an Operating Process while R1.2 requires an Operating Procedure.</p> <p>CPG believes that R1.2 should be changed to require the use of an Operating Process instead of Operating Procedure. R1.2 is merely requiring an entity to fill out the necessary forms should an event occur, so requiring a clear and concise step by step procedure for filling out a form only adds a compliance burden to an entity instead of improving the reliability of the BES.</p> <p>CPG does agree with the DSR SDT that an entity should have a process in place mandating that the proper paperwork be completed in a timely manner should an event occur.</p>
<p><b>Response:</b> Thank you for your comments. The SDT has modified Requirement R1, Part 1.1 and Part 1.3 to a “process” as part of the elements of the referenced “Operating Plan” in R1. The SDT has also changed “Operating Procedure” to a “process” in R1.2. This sub-requirement provides for establishing the list of internal personnel to be notified in the case of an event, not the reporting of the event.</p>		
Georgia System Operations Corporation	No	<p>-R1.3.2: “Law Enforcement”, “Governmental Agencies”, and “Provincial Agencies” are not proper nouns/names and are not defined in the NERC Glossary. They should not be capitalized.</p> <p>-R1.4: Keeping documents current and in force should be a matter of an entit</p>
<p><b>Response:</b> Thank you for your comments. The SDT agrees with your suggestions on capitalization and has made the corrections. The update provision comes from a FERC directive in Order No. 693.</p>		
Indeck Energy Services	No	The terms are not important and many plans or procedures already exist and restructuring them to match the

Organization	Yes or No	Question 6 Comment
		<p>terms is wasteful. R1 is too prescriptive.</p> <p>R1 should state that a written document should show how the entity will comply with EOP-004.</p> <p>R1.2 is superfluous and should be deleted. The data must be gathered and the process will vary with the event. Trying to define the multitude of possibilities for the collection process is not productive and leaves open the possibility of missing something for an auditor to nit pick.</p> <p>R1.3 should just be a written communications plan/process/procedure for external notifications.</p> <p>R1.4 is redundant because it can't be changed within 90 days until the content has already been changed. R1.4 should be deleted. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.</p>
<p><b>Response:</b> The SDT disagrees with your viewpoints associated with R1 because the requirement only specifies the elements required, now how to implement them. The SDT believes that many Registered Entities will be able to use their current Sabotage Reporting processes, with some slight modification to address the new sub-requirements. Requirement R1, Part 1.2: The requirement is written so that it is not prescriptive and allows the entity to identify the steps it will take to gather information for filing the report. The DSR SDT does not envision this as being a tome that contains specific data gathering protocol for each event type. Requirement R1, Part 1.3: Has been revised to: "1.3. A process for communicating recognized impact events listed in EOP-004 - Attachment 1 that includes to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and , but is not limited to the following as appropriate :” For Requirement R1, Part 1.4, the update provision comes from a FERC directive in Order No. 693. In addition, the SDT believes that the update is required within 90 days from the date of being notified of the change or update. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Midwest Reliability Organization	Yes	This is a NERC defined term and will assist entities in maintaining compliance with this (proposed) Standard.
<p><b>Response:</b> Thank you for your comment.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
Western Electricity Coordinating Council	Yes	<p>Are "Law Enforcement" considered a "Governmental Agency" (they are listed separately and both required) If not, is there any qualifiers on whether Law Enforcement or Governmental Agency refers to municipal, county, state or federal or any combination"</p> <p>Since the term "Provincial" is associated with "Governmental" it tends to indicate State level. As it is written now an auditor would require documentation of "some" Law Enforcement (other than company security) and an additional communication to at least "some" Agency which could be considered Governmental. Municipal or higher.</p> <p>Contact with City police or Sheriff and either city or county government rep would satisfy.</p> <p>Additional clarity would help from a compliance enforcement perspective.</p>
<p><b>Response:</b> Thank you for your comments. The SDT expects that Registered Entities will identify the proper outside organizations needed for their organization. The SDT feels that law enforcement agencies include federal, state, provincial, or local law agencies and these are not the same as governmental or regulatory agencies. Please refer to the Background section of the standard for further clarification on law enforcement notifications.</p>		
Alliant Energy	Yes	<p>This is a NERC defined term and will assist entities in maintaining compliance with this (proposed) Standard. We believe the reference to Attachment 2 in R1.2 should be revised to the DOE Form and utilize only one reporting form, if at all possible.</p>
<p><b>Response:</b> Thank you for your comments. The DSR SDT continues to work with the DOE to develop a single reporting form that is acceptable to both.</p>		
Occidental Power Marketing	Yes	<p>However, only LSEs with BES assets (or assets that support the BES) should be included in the Applicability section of the standard.</p>
<p><b>Response:</b> Thank you for your comment. LSE applicability is related to their applicability under CIP-002 and CIP-008.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	<p>However, there needs to be some clarity on which government agencies (if not the FBI) are responsible for reporting these type of events.</p>
<p><b>Response:</b> Thank you for your comments. Each Registered Entity should be aware of any reporting obligations it may have to various government agencies (federal, state/provincial, local). To the extent they exist, the notification needs to be included in the entity's Operating Plan(s).</p>		
Northeast Power Coordinating	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 6 Comment
Council		
PPL Supply	Yes	
Southern Company	Yes	
SRP	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
Liberty Electric Power LLC	Yes	
APX Power Markets	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
Platte River Power Authority	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 6 Comment
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	
Progress Energy	Yes	

**7. Do you agree with the proposed revisions to Requirement 3 (now R2)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The slight majority of commenters agreed with the language of Requirement R2. A significant minority opinion exists where commenters suggest revisiting R2 and R5 to eliminate potential redundancy and confusion. Similar comments were received pertaining to Requirement 5 (question 10 below). The DSR SDT has revised Attachment 1 to indicate that entities must submit Attachment 2 or the DOE OE-417 form. This information was contained in Requirement R5. The intent of the two requirements is to have entities make appropriate notifications and report impact events contained in Attachment 1. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements while eliminating potential confusion and redundancy. The revised requirements are shown below:

~~R2. Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B). [Violation Risk: Factor Medium] [Time Horizon: Real-time Operations and Same-day Operations]~~

Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].

Organization	Yes or No	Question 7 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	<p>We are concerned with having a separate requirement to implement the Plan.</p> <p>Is this requirement necessary on its own? Should R1 instead require a Responsible Entity to "document and implement" an Impact Event Operating Plan? More specifically, if an Entity does not have an Impact Event, are they in violation of this requirement?</p> <p>If merging this requirement with R1 is not acceptable we suggest moving the language from the measure to the requirement as such: "To the extent that a Responsible Entity has an Impact Event on its Facilities, Each Responsible Entity shall implement?"</p> <p>Additionally, R1 uses the phrase "recognized Impact Event" where as R2 simply uses the term "Impact Event." The phrase "recognized Impact Event" should be used consistently in R2 as well.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted requirement 2 and revised requirements 1 and 5 to address your concern. The DSR SDT believes that the requirement should remain separate to eliminate the possibility of double jeopardy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
Bonneville Power Administration	No	Minimize the number of requirements. Not sure what the new R2 intends that is different than having a valid plan (signed?). Why can't R1 have develop and implement? R5 is the reporting. Implement should be with R1 or R5 depending on the interpretation.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT has deleted requirement 2 and revised requirements 1 and 5 to address your concern. The DSR SDT believes that the requirement should remain separate to eliminate the possibility of double jeopardy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
PSEG Companies	No	Fuel supply emergency, as discussed in response to question 4 above, is not a defined condition. This event should be removed.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Fuel Supply Emergency from Attachment 1. This item was removed in coordination with the NERC Events Analysis Working Group and the proposed Events Analysis Program.</p>		
SERC OC Standards Review Group	No	We agree with the concept, but disagree with the use of the term “Operating Plan” as a defined term in line with our comments in question 6 above.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see response to comments in Question 6 The DSR SDT has revised R1 to eliminate the use of Operating Process and Operating Procedure and have used more generic terms.</p>		
PJM Interconnection LLC	No	We agree with the concept but disagree with the use of the term “Operating Plan” as a defined term in line with our comments in Question 6 above.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
<p><a href="#">Response: The DSR SDT thanks you for your comment. Please see response to comments in Question 6</a></p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p><a href="#">Response: The DSR SDT thanks you for your comment. Please see response to question 2.</a></p>		
Exelon	No	<p>Agree that each Responsible Entity shall implement the [Impact] Events listed in Attachment 1 (Parts A and B); however, disagree with certain events, reporting responsibilities, threshold for reporting and time to submit reports as currently outlined in Attachment 1 (Parts A and B).</p> <p>Also suggest that R.2 be reworded to state for applicable [Impact] Events listed in Attachment 1 (Parts A and B). This requirement should only be applied to those events applicable to the registered entity. R2 is redundant to R1. No entity could claim to have met R1 if their plan / process was not operational and approved in the manner consistent with any other approved program, process, guideline etc. within their company.</p>
<p><a href="#">Response: The DSR SDT thanks you for your comment.</a></p> <p>The DSR SDT has significantly revised Attachment 1. We have removed the timing column and replaced it with more specific information regarding which form to submit and to whom to submit the report. All events are now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events, Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident. These events are to be reported within 1 hour. Notification of law enforcement per Part 1.3.2 is also required for these events only.</p> <p>The DSR SDT has also eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. The DSR SDT believes that the requirement should remain separate to eliminate the possibility of double jeopardy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
Tenaska	No	The proposed Impact Event Operating Plan should not be required.
<p><a href="#">Response: The DSR SDT thanks you for your comment.</a></p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
		<p>The DSR SDT has revised R1 to only include development of an Operating Plan that includes the Parts of R1. This Operating Plan is required so that the entity's personnel will know what to do in the event of an event, how to report the event and to whom the report should be sent.</p>
American Municipal Power	No	<p>No, remove R2. R2 is not an acceptable requirement nor should this be an operation. Focusing on a plan is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
American Electric Power	No	<p>Requirement 5 and Requirement 2 are redundant. We recommend Requirement 2 be replaced with the language in Requirement 5. "Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417."</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. The old Requirement R5 has been revised as the new Requirement R2, which reads: Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
ISO New England, Inc	No	<p>Fuel Supply Emergency is not a defined condition. We suggest that the SDT poll the ballot body regarding the reporting of Fuel Supply Emergencies. Fuel Supply is an economic consideration and the concept of Fuel Supply Emergency is subjective. A resource that uses coal or oil may vary its supplies based on economic considerations (the price of the fuel). For a conservative BA a fuel-on-demand supply line can be viewed as a fuel supply emergency whereas the resource owner sees the matter as good business. Moreover, the release of such reports to the public can have unintended consequences. Fuel disruptions caused by contract negotiations when reported to the public can result in non-union transportation employees being physically</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 7 Comment
		<p>harmd by fuel supply organizers thus resulting in the loss of non-contract fuel. Further, this information may aggravate the situation by causing the cost of fuel to be inflated by suppliers when demand is great.</p> <p>If this event is not deleted, then we would suggest that the definition be constrained to “declared” fuel supply emergencies. Suggest the deletion of category: Risk to BES equipment. Because of the broad definition of BES, the risk to BES equipment is overly broad and can be applied to any risk to any “part of” any BES asset. The footnote helps identify what the SDT was intending, however, the words themselves can result in overly broad findings by compliance enforcement people.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Fuel Supply Emergency from Attachment 1. This item was removed in coordination with the NERC Events Analysis Working Group and the proposed Events Analysis Program.</p>		
Calpine Corp	No	<p>Requirement R2 is unnecessary for the same reasons listed above in answer to question 6 regarding Requirement R1. A new Reliability Standard requirement is not needed to verify that internal notifications are made within Registered Entities or to ensure that Registered Entities notify local law enforcement of suspicious activity, sabotage, theft, or vandalism. Such notifications are made by any company, and this requirement does not clearly enhance the reliability of the Bulk Electric System. Requirement R5 provides sanction in the event that events listed in Attachment 1 are not made appropriately. However, if the requirement is maintained, the related Measure M2 should state in plain language exactly what elements are required for compliance. In the absence of much more detailed instruction on exactly what elements must be included in the various documents, the proposed requirement will create confusion with both compliance and enforcement of the requirement. A detailed example of example documentation would be helpful. Any difficulty in developing such an example would be instructive of the probable compliance issues that would ensure from the necessarily varying approaches that would be taken by disparate entities attempting to meet the requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
CenterPoint Energy	No	<p>CenterPoint Energy recommends deleting the current R2 as it is an inherent part of the current R5. For an entity to “report Impact Events in accordance with the Impact Event Operating Plan pursuant to R1” (see R5), the entity must “implement its Impact Operating Plan documented in Requirement 1?” (see R2). Including</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
		both requirements is unnecessary and duplicative. Likewise, M2 should be deleted.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
ExxonMobil Research and Engineering	No	<p>The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notifications windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of of the situation and determine the extent of the problem. The existing standard's requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
<p>The DSR SDT has significantly revised Attachment 1. We have removed the timing column and replaced it with more specific information regarding which form to submit and to whom to submit the report. All events are now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events in Part A and Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident in Part B. These events are to be reported within 1 hour. Notification of law enforcement per Part 1.3.2 is also required for</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 7 Comment
these events only.		
American Transmission Company	No	ATC does not agree with the proposed language in Requirement 3. ATC is concerned that, in order to demonstrate compliance, an entity will have to show that each step in the plan was followed which will likely leave entities facing the choice of choosing between different compliance violations. If the plan is not followed, but the report is made within the time given, then an entity is in violations of their plan. If the plan is followed, but the report does not get filed within the time allotted, then they face a possible violation of the time to report. ATC believes that the team should enforce the position that the report being filed in the time allotted is key, not that they necessarily follow and document that their plan was followed. Depending on the situation, the internal reporting will vary; however, based on the purpose of the Standard, the key is to get a report to NERC.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
Georgia System Operations Corporation	No	-We suggest moving the language from the measure to the requirement as such:"To the extent that a Responsible Entity has an Impact Event on its Facilities, each Responsible Entity shall implement?"Additionally, R1 uses the phrase "recognized Impact Event"
<p><b>Response:</b> The DSR SDT thanks you for your comment. Requirement 2 has been deleted along with its associated Measure M2. R1 no longer references "recognized" events.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	There are generally several events during the year. If the process is well documented, a drill or exercise is excessive. It should be sufficient to say "provide training."
<p><b>Response:</b> The DSR SDT thanks you for your comment. This appears to be related to R3 in question 8. If an event occurs during the year, additional testing is not required.</p>		
Indeck Energy Services	No	R2 is direct and to the point. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Midwest Reliability Organization	Yes	This clearly states that an entity’s Operating Plan is to be used for reporting of Impact Events.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
Dominion	Yes	Dominion agrees subject to the comments provided in Question #6. In addition, Requirement R2 appears duplicative of Requirement R5. Suggest R2 be clarified relative to the intent.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see responses to comments in Question 6. R2 was deleted and R5 was revised. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment]. The DSR SDT has revised R1 to eliminate the use of Operating Process and Operating Procedure and have used more generic terms.</p>		
Manitoba Hydro	Yes	Removing “assess the initial probable cause” from the statement removes the ambiguity in the same way as replacing sabotage with impact level. Let the staff trained in this field determine probable cause after the fact.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
Occidental Power Marketing	Yes	However, only LSEs with BES assets (or assets that directly support the BES) should be included in the Applicability section of the standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Attachment 1 specifies which types of events are required to be reported by each entity.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
Constellation Power Generation	Yes	Although CPG agrees with the wording of Requirement 2, CPG has several comments and suggested changes regarding the Attachments, to which this requirement points. Please see those comments below.
<b>Response:</b> The DSR SDT thanks you for your comment. Please see responses below.		
Northeast Power Coordinating Council	Yes	
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
Pepco Holdings Inc and Affiliates	Yes	
SPP Standards Review Group	Yes	
Midwest ISO Standards Collaborators	Yes	
FirstEnergy	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 7 Comment
APX Power Markets	Yes	
United Illuminating Co	Yes	
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 7 Comment
Brazos Electric Power Cooperative	Yes	
Progress Energy	Yes	
<p><b>Response:</b> The DSR SDT thanks you for your comment. Based on stakeholder comments, Requirement R2 was deleted and R5 was revised. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		

**8. Do you agree with the proposed revisions to Requirement 4 (now R3)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** There were several issues that commenters raised regarding removing the requirement. Below is a summary:

- 1) Review annual component CAN0010 states: Regardless of the registered entity’s documented definition of annual, it will not supersede any requirement stated in the standard. The DSR SDT is defining “annual” within this Standard (and only for this Standard).
- 2) Remove R3-requirement – Several stakeholders believed the testing to be onerous. The language of the requirement was revised to indicate that only the communications portion of the Operating Plan is required to be tested. Each Responsible Entity shall conduct a test of the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between tests.
- 3) Unclear if actual events would qualify for a test in the requirement – The language in the measure was revised to add “Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement. “
- 4) VRF is too high on R3 – With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.

Organization	Yes or No	Question 8 Comment
--------------	-----------	--------------------

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between tests" is necessary. If instead the team believes that, in order to support the reliability of the BES, tests should be performed at least every 15 months, then the requirement should be to perform a test at least every 15 calendar months and remove the annual component.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. Per the CAN, "Regardless of the registered entity's documented definition of annual, it will not supersede any requirement stated in the standard." The team believes the requirement is specifying what the team believes to be appropriate.</p>		
Northeast Power Coordinating Council	No	The annual testing requirement is too frequent for a reporting, and not an operational process. The testing interval should be extended to five years.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. We feel that five years is too long of an interval between tests as contact information contained in the plan may change more often. A one year test is more likely to catch problems with the Operating Plan. If an entity has an event, then they do not need to test the plan during the annual cycle.</p>		
Bonneville Power Administration	No	Too burdensome to go through EACH and ALL individual Impacts and report each one on a drill basis with outside entities. One or two scenarios may be OK.
<p><b>Response:</b> The DSR SDT thanks you for your comment. It is not intended to perform a test for each type of event listed in Attachment 1. The entity is free to choose any single event to test its operating plan. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The test under R3 Operating Plan is to test the communication aspect of your Operating Plan.</p>		
Dominion	No	: The need to conduct a test of its Operating Process has not been established and is overly restrictive given that the purpose of the standard is to report Impact Events.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
<p>respond appropriately in the case of an actual event. The SDT thinks it is critical to test the Operating Plan to verify that employees know the appropriate actions to take and that there are no issues with the reporting procedures. Not testing the Operating Plan could result in employees being unprepared to communicate and report for an actual event.</p>		
SPP Standards Review Group	No	<p>The SDT included a formal review process in the discussion of R4 in the Background Information in the Unofficial Comment Form as one of three options for demonstrating compliance with the testing requirements of R4, yet M3 only contains two of those options ? a mock Impact Event exercise and a real-time implementation of its Operating Process. The third option, a formal review process, is missing from M3 and needs to be added. We would suggest the following for M3: ?In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 or conducted a formal review of its Operating Process. The time period between tests, actual Impact Events or formal reviews shall be no more than 15 calendar months. Evidence may include, but is not limited to, operator logs, voice recordings or documentation.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. The team feels that a formal review will not be able to identify any of these errors unless the communications process is tested.</p>		
Midwest ISO Standards Collaborators	No	<p>We appreciate the drafting team recognizes that actual implementation of the plan for a real event should qualify as a ?test?. However, we are concerned that review of this requirement in isolation of the background material and information provided by the drafting team may cause a compliance auditor to believe that a test cannot be met by actual implementation. Furthermore, we do not believe testing a reporting procedure is necessary. Periodic reminders to personnel responsible for implementing the procedure make sense but testing it does not add to reliability. If they don?t report an event, it will become obvious with all the tools (SAFNR project) the regulators have to observe system operations.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have added the following to the measure: “Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement.”</p>		
FirstEnergy	No	<p>We believe that a separate requirement for testing the reporting process is unnecessary. The FERC directive that required periodic testing was directed at sabotage events per CIP-001. Since the proposed standard</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
		<p>moves the responsibility for classifying an event as sabotage from the entity to the applicable law enforcement authority, the need for a periodic drill is no longer necessary. We believe that Requirement R4 should suffice in ensuring that the individuals involved in the process are aware of their responsibilities.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified.</p>		
SERC OC Standards Review Group	No	<p>Annual testing of an "after-the-fact" reporting procedure does not add to the reliability of the BES!</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p>		
PJM Interconnection LLC	No	<p>1. This is an "after-the-fact" reporting requirement (administrative in nature). Annual testing of such a requirement does not add to the reliability of the BES.</p> <p>2. R3 attempts to define "Annual" for the Registered Entity to test its Operating Process. We believe R3 should follow the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) ? CAN-0010 ? Definition of Annual as opposed to creating a new definition of Annual ? or ? refer to an entity?s defined use of the term annual.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. Per the CAN, "Regardless of the registered entity's documented definition of annual, it will not supersede any</p>		

Organization	Yes or No	Question 8 Comment
<p>requirement stated in the standard.” The team believes the requirement is specifying what the team believes to be appropriate.</p>		
<p>We Energies</p>	<p>No</p>	<p>A test of the Operating Process for communication would be placing telephone calls. This requirement would have virtually every entity in North America calling NERC, Regional Entities, FERC/Provincial Agency, Public Service Commission, FBI/RCMP, local Police, etc. annually. Every entity will probably be asking for a confirmation letter from each telephone call for proof of compliance. This is an unnecessary requirement. Delete it.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p>		
<p>Compliance &amp; Responsibility Organization</p>	<p>No</p>	<p>See comments set forth in number 2.</p> <p>Also, while NextEra understands the need to have a testing requirement for sabotage (Order 693 at P 446), it does not find it necessary to have a testing requirement for the other events. At this time in the process, additional requirements for the sake of having a requirement are likely to detract from reliability. Thus, NextEra requests that the testing requirement be limited to sabotage related events.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see responses to Question 2 above. Each entity may choose an event type for which to perform the communications process test. It need not be performed for each and every event type listed in Attachment 1. The test must include all aspects of the communications process, including NERC and the RE. The measure for R3 was revised to make it explicit that evidence for compliance for R3 includes an actual event.</p> <p>M3. The Responsible Entity shall provide evidence that it conducted a test of the communication process as documented in its Operating Plan impact events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual impact event may be used as evidence to meet this requirement. The time period between an actual impact event or test shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a test. (R3)</p>		
<p>Exelon</p>	<p>No</p>	<p>- Each entity should be able to determine if they need a drill for a particular event. Is this document implying that the annual drill covering all applicable [Impact] Events?</p>

Organization	Yes or No	Question 8 Comment
		<p>- A provision should be added to be able to take credit for an existing drill/exercise that could incorporate the required communications to meet the intent of R.3 to alleviate the burden on conducting a standalone annual drill. The DSR SDT needs to provide more guidance on the objectives and format of the drill expected (e.g., table top, simulator, mock drill).</p> <p>- A provision should be added to R.3 to allow for an actual event to be used as credit for the annual requirement. It would seem that the intent is as such based on the wording in M.3; however, it needs to be explicit in the Requirement.</p> <p>- Must a test include communicating to NERC or the Region?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each entity may choose an event type for which to perform the communications process test. It need not be performed for each and every event type listed in Attachment 1. The test must include all aspects of the communications process, including NERC and the RE. The measure for R3 was revised to make it explicit that evidence for compliance for R3 includes an actual event.</p> <p>M3. The Responsible Entity shall provide evidence that it conducted a test of the communication process as documented in its Operating Plan impact events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual impact event may be used as evidence to meet this requirement. The time period between an actual impact event or test shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a test. (R3)</p>		
City of Tallahassee (TAL)	No	<p>Comments: The verbiage “at least annually, with no more than 15 months between such tests” is an attempt to define annually. If you want every 15 months say “at least every 15 months.” Otherwise just say annual and let the entities decide what that is, as is being done with other “annual” requirements.</p> <p>Additionally, while the Measure (M3) implies that an actual event would suffice it is not stated in the requirement, and the entire plan should be tested, not just a component. Proposed: Each Responsible Entity shall conduct a test of its Impact Event Operating Plan at least annually. A test of the Impact Event Operating Plan can range from a paper drill, to the response to an actual event.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The language now reads: “annually (once per calendar year), with no more than 15 calendar months between tests”. This comports with the intent and with the recent CAN from NERC on the use of “Annual”. The intent of the requirement is to verify that an entity’s personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test. R3 reads:</p> <p>“Each Responsible Entity shall conduct a test of the communication process as documented in its Operating Plan, created pursuant to Requirement 1, Part 1.3, impact events at least annually, (once per calendar year), with no more than 15 calendar months between tests.”</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 8 Comment
Tenaska	No	The proposed Impact Event Operating Plan should not be required, therefore any tests of the Operating Process should not be required.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Stakeholder consensus indicates that the majority of stakeholders agree with the Operating Plan requirement.</p>		
American Municipal Power	No	No, remove R3. R3 is not an acceptable requirement nor should this be an operation. Focusing on a test is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test. This should not be a costly nor burdensome requirement.</p>		
Liberty Electric Power LLC	No	It is not the proper role of the standards to dictate how an entity conducts training. Large utilities with backup control rooms and enough personnel can conduct routine drills without disturbing operations, but this is not always the case for small entities. Further, classroom training where emergency responses are discussed can be a better tool at times for assuring compliance with operating procedures. I would suggest R3 read "Each entity shall assure that personnel are aware of the requirements of EOP-004 and capable of responding as required."
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT agrees and has removed the training Requirement, R4.</p>		
Sweeny Cogeneration LP	No	We do not see a reliability benefit in the planning and execution of tests or drills to ensure that regulatory reporting is performed in a timely fashion. It is sufficient that penalties can be assessed against entities that do not properly respond in accordance with EOP-004-2, leaving it to us to determine how to avoid them.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
American Electric Power	No	It is unclear if actual events would qualify for a test in the requirement; however, the associated measure and rationale appear to support this. We suggest the requirement be restated to allow for actual events to count for this requirement.

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 8 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
New Harquahala Generating Co.	No	<p>M3. In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or documentation. (R3). The measure for R3 needs to make it clear that “exercise/drill/actual employment” can be a classroom exercise, utilizing scenarios for discussion. It should not be necessary to fully test the plan by making actual phone calls, notifications etc.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process including making actual phone calls, etc. The measure was revised to clarify that an actual event can be used in lieu of a test. The purpose of the requirement is to ensure that the communications process works.</p>		
ISO New England, Inc	No	<p>We appreciate and agree with the drafting team recognizes that actual implementation of the plan for a real event should qualify as a “test.” However, we are concerned that review of this requirement in isolation and without the benefit of the background material and information provided by the drafting team may cause a compliance auditor to believe that a test cannot be met by actual implementation. Furthermore, we do not believe testing a reporting procedure is necessary. Periodic reminders to personnel responsible for implementing the procedure make sense but testing it does not add to reliability. If they don't report an event, it will become obvious to compliance auditors. Recommend using language similar to CIP-009. “Each Responsible Entity shall conduct a an exercise of its operating process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 calendar months between exercises.” An exercise can range from a paper drill, to a full operational exercise, to reporting of actual incident Also, we question the need to conduct a test annually. Since this is only a reporting Standard and, as such, has no direct impact on reliability, we suggest modifying the testing requirement to once every three years.</p> <p><b>CIP-009-3</b></p> <p><b>R.2 Exercises</b> —The recovery plan(s) shall be exercised at least annually. An exercise of the recovery plan(s) can range from a paper drill, to a full operational exercise, to recovery from an actual incident.</p> <p><b>M2.</b> The Responsible Entity shall make available its records documenting required exercises as specified in</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 8 Comment
		<b>Requirement R2.</b>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
Calpine Corp	No	<p>Absent substantial evidence that the proposed requirement addresses an actual systemic problem with actual submittal of reports of electrical disturbances, Requirement R4 should be removed. Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Entities are capable of implementing procedures appropriate to ensure compliance with the actual reporting requirements without the addition of this "test."</p> <p>Alternately, if this requirement for annual tests is retained, it should be supplemented with a detailed example of an acceptable test and acceptable documentation of the test to avoid future compliance and enforcement issues. Stating "evidence may include, but is not limited to..." provides broad and unnecessary opportunity for future compliance and enforcement issues. Any difficulty the committee might encounter in developing such a detailed example would be instructive of the probable compliance and issues that would ensure from implementation of the requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
BGE	No	<p>Requirement 3 (formerly R4) should be removed altogether because it is covered by the new R4. The topic of Disturbance Reporting is covered several times each year during operator training classes and the operators are tested on the material. Actual issued Disturbance Reports throughout the year are also covered during training class.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. R4 was a training requirement which has been revised and incorporated into Requirement R1, Part 1.5. This now calls for an annual review of the Operating Plan rather than training. The intent of the review is to ensure that the plan is up to date.</p>		
Georgia System Operations Corporation	No	<p>-With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between tests" is necessary. Although we understand the additional qualification</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The CAN language defers to the standard drafting team for any qualifications on “annual.” The DSR SDT prefers the existing language.</p>		
Indeck Energy Services	No	<p>For smaller entities, for which few of the Attachment 1 events apply (eg a 75 MW wind farm), a drill is overkill. Reviewing the procedure during training should be sufficient. The solution is to require a drill for any entity for which any of the Attachment 1 events would cause a Reportable Disturbance or reportable DOE OE-417 event and training review for any other entities. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. Any drill or exercise that meets the intent of the requirement is acceptable.</p> <p><b>VRF:</b> With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
ExxonMobil Research and Engineering	No	<p>The annual (15 month) time window for conducting annual performance tests appears to be reasonable. However, the required scope of the test is vague. The Standard Drafting Team should modify the testing requirement to include boundary criteria such as whether notifications to third parties and law enforcement are required or if the test is limited to internal notifications and response processes. Furthermore, the current measure associated with this requirement, EOP-004 Revision 2 Measure 3, implies, that if an Impact Event occurs, the registered entity can count the activation of its Impact Event Operating Plan as a test and extend the test window 15 months from the date of activation. The Standard Drafting Team should revise the requirement to clarify that the test window resets when a site initiates its Impact Event Operating Plan in response to a real Impact Event as requirement criteria should not be included in a measure.</p>

Organization	Yes or No	Question 8 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
Occidental Power Marketing	No	We understand that this requirement is meant to comply with FERC Order 693, Section 466; however, there needs to be more specificity concerning what sort of "test" would be accepted for auditing purposes. Also, only LSEs with BES assets should be included in the Applicability section of the standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
Lincoln Electric System	No	As currently drafted, requirement R3 states one must "conduct a test" whereas the associated Measure requests evidence that one "conducted a mock Impact Event." The Rationale box lends to further confusion by referencing a "drill or exercise" as a process to verify one's Operating Process. To avoid potential confusion between R3 and M3, as well as to maintain consistency with the Rationale box, recommend the drafting team replace the word "test" with "drill or exercise" within R3 and the associated Measure.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. It is not a common practice to include explanatory text in a requirement. The Results-based standards format allows the Rationale boxes to serve this role. The Rationale box includes language that indicates that an actual implementation of the plan counts as a test.</p>		
Farmington Electric Utility System	No	The measure for R3 indicates an actual Impact Event would count as a test, consider aligning the requirement with the measure to clarify an Impact Event could be considered a test.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. It is not a common practice to include explanatory text in a requirement. The Results-based standards format allows the Rationale boxes to serve this role. The Rationale box includes language that indicates that an actual implementation of the plan counts as a test.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
Ingleside Cogeneration LP	No	Since the reporting of event data to regulatory agencies does not support a front-line operations capability to mitigate or restore a BES impairment, regular simulations are not needed. Those notification items which test coordination between operating entities can be addressed in emergency operations exercises.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We concur with your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event.</p>		
Constellation Power Generation	No	As CPG stated in comments to earlier versions of EOP-004-2, this requirement adds a substantial compliance burden with little to no reliability improvement to the BES. Numerous entities in the NERC footprint have created fleet wide compliance programs for their facilities, instead of overseeing multiple stand alone compliance programs. This was done not just for the ease of administration, but it also greatly improves the reliability of the BES by ensuring consistency across multiple facilities. By requiring each responsible entity to test the Operating Process, those under a fleet wide compliance program will end up testing the same Operating Process numerous times. This would be inefficient, ineffective and unnecessarily costly. If the testing requirement remains, then the Responsible Entity should be able to take credit for testing of the Operating Process regardless of which entity in the fleet tested it. Alternatively, the drafting team should consider removing Requirement 3 (formerly R4) because in practice it is covered by the new R4. As discussed below R4 needs refinement, but the topic of Disturbance Reporting is covered during annual training.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. If the intent of this requirement is fulfilled by another exercise or drill conducted by the responsible entity, then that will meet the requirement.</p>		
Duke Energy	Yes	We understand that the objective of this requirement is to test the Operating Process for communicating Impact Events; and that such test could be an actual exercise, a formal review, or a real-time implementation. But given that R1.4 requires updating the Operating Plan within 90 days of any changes, we believe the VRF for R3 should be LOW instead of MEDIUM.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
<p>responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Progress Energy	Yes	<p>Do all individuals who are assigned roles and responsibilities in the Impact Event Operating Plan have to be involved with the test each time? Since there are multiple different types of Impact Events, it seems likely that only a subset of those Impact Events would be tested during an annual test, and therefore only a subset of individuals with responsibilities in the Impact Event Operating Plan would participate. For example, one test may exercise the Operating Process for properly reporting damage to a power plant that is a Critical Asset, and personnel from the Distribution Provider would not be involved in that test. Would such a scenario meet the requirement for the annual test? If so, it seems that some aspects of the Plan may never actually be required to be tested. This is ok, since R4 requires an annual review with personnel with responsibilities in the Impact Event Operating Plan. It must be made clear what is required in the annual test.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
Manitoba Hydro	Yes	<p>This requirement appears to be written so as to leave how each entity tests this procedure is up to them and not how. The testing of this procedure could vary vastly from entity to entity, meaning there is no set protocol on this procedure. As long as this requirement remains open, it is fair.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
United Illuminating Co	Yes	<p>: FERC did state in Order 693 that the reporting procedure requires testing. UI is concerned that the scope of the requirement is unspecified. Does the exercise require only one type of Impact Event to be exercised per period, or is an entity required to simulate each Impact Event and notification</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. If your communications process differs by event type, then all communications should be tested.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
Southern Company	Yes	This will cause all of the entities listed in R1.3.2 to receive test communications from all of the applicable entities annually.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p>		
SRP	Yes	
SDG&E	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Platte River Power Authority	Yes	
Alliant Energy	Yes	
CenterPoint Energy	Yes	
USACE	Yes	
Independent Electricity System Operator	Yes	
PPL Electric Utilities	Yes	
American Transmission Company	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 8 Comment
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Brazos Electric Power Cooperative	Yes	
Midwest Reliability Organization	Yes	
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	

**9. Do you agree with the proposed revisions to Requirement 5 (now R4)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** A significant number of commenters indicated that there was confusion surrounding the use of the term “review” in Requirements R3 and R4. Similar comments suggested that the measure for Requirement R4 has a training connotation, which is inconsistent with the language in the requirement, which uses the term “review.” The DSR SDT has eliminated Requirement R4 and added a part to Requirement 1, Part 1.5, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. Eliminating R4 and adding Part 1.5 maintains the intent while eliminating potential confusion and redundancy.

Other commenters suggested revisions to the use of the term annual. The DSR SDT reviewed the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) CAN-0010, which provides drafting teams latitude to define the term within a requirement as they intend it to be used.

Organization	Yes or No	Question 9 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	We do not believe that the requirement should specify that the plan must be reviewed with those personnel who have responsibilities identified in that plan as there is no requirement in R1 that the plan must identify any specific personnel responsibilities. Additionally, we seek clarification on whether review in this instance means train as indicated in the measure.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated requirement R4 and added a Part under Requirement R1, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. By adding this Part to Requirement R1, the SDT has eliminated confusion and redundancy around the use of the term “review” and the training connotation in the Measure.</p>		
Dominion	No	The need to periodically review its Impact Event Operating Plan has not been established and is overly restrictive (annually) given that the purpose of the standard is to report Impact Events. Suggest removing this requirement
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated requirement R4 and added a Part under Requirement R1, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. The DSR SDT</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
		<p>'s intent is to ensure that there is no gap in the review of the Operating Plan even though the plan has provision(s) for updating the event Operating Plan within 90 days of any change to its content. By adding this Part to Requirement R1, the SDT has eliminated confusion and redundancy around the use of the term "review" and the training connotation in the Measure.</p>
SPP Standards Review Group	No	<p>There is confusion surrounding the use of the term review in R3 and R4. In R3 and the suggested revision to M3 in Question 8, review is an analysis of the plan by a specific group tasked to determine if the plan requires updating or modifying to remain viable. Review in R4 has training connotations for all personnel who have responsibilities identified in the plan. Although we understand the use of review in R4 is new to this version of EOP-004-2, we believe it may be more appropriate to use training rather than review in R4. And further, we feel the training should be focused on those specific portions of the plan that apply to specific job functions.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated Requirement R4 and added a Part under Requirement R1, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. By adding this Part to Requirement R1, the SDT has eliminated confusion and redundancy around the use of the term "review" and the training connotation in the Measure.</p>		
FirstEnergy	No	<p>We believe that Requirement 4 does not warrant a Medium risk factor. For example, a simple review of the process does not have the same impact on the Bulk Electric System as the implementation of the Operating Plan per R2. Therefore, we believe R4 is at best a Low risk to the BES.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated Requirement R4 and has re-evaluated the Violation Risk Factors for each requirement. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
We Energies	No	<p>Include that this is for internal personnel as stated in the associated measure.</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated Requirement R4 and the associated Measure.</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2
<p><b>Response:</b> Thank you for your comments and suggestions. Please see responses to question 2.</p>		
Exelon	No	<p>Need more guidance on what personnel are expected to participate in the annual review.</p> <p>Training for all participants in a plan should not be required. Many organizations have dozens if not hundreds of procedures that a particular individual must use in the performance of various tasks and roles. Checking a box that states someone read a procedure does not add any value. This is an administrative burden with no contribution to reliability. If the intention is that internal personnel who have responsibilities related to the Operating Plan cannot assume the responsibilities unless they have completed training. This requirement places an unnecessary burden on the registered entities to track and maintain a database of all personnel trained and should not be a requirement for job function. A current procedure and/or operating plan that addresses each threshold for reporting should provide adequate assurance that the notifications will be made per an individual's core job responsibilities.</p>
<p><b>Response:</b> Thank you for your comments. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
City of Tallahassee (TAL)	No	The verbiage at least annually, with no more than 15 months between review sessions is an attempt to define annually. If you want every 15 months say at least every 15 months. Otherwise just say annual and let the entities decide what that is, as is being done with other annual requirements.
<p><b>Response:</b> Thank you for your comment. The DSR SDT took into consideration the CAN on the definition of 'Annual" and wrote the requirement to meet the intent of the team.</p>		
Tenaska	No	The proposed Impact Event Operating Plan should not be required.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT considers the proposed event Operating Plan a document that identifies the activities to achieve the purpose to improve industry awareness and the reliability of the Bulk Electric System. The DSR SDT has revised R1 to only include development of an Operating Plan that includes the sub-requirements of R1.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
American Municipal Power	No	No, remove R4. R4 is not an acceptable requirement nor should this be an operation. Focusing on a plan and personnel tracking is overly prescriptive. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has taken into consideration your comment, eliminated Requirement R4, and added Requirement R1, Part 1.5. The SDT agrees that the Registered Entity can decide on the how to implement the reporting; however, this requirement mandates that the Registered Entity document its process.</p>		
Liberty Electric Power LLC	No	Again, the entity should determine the need for review of any procedure. Changing circumstances may dictate a shorter cycle, but no changes could dictate a longer review. I will note that spill prevention plans are required to be reviewed every five years, so I question the need for an 18-month review of the EOP plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The review provisions are designed to ensure that contact information for internal and external organizations are correct and up to date.</p>		
Arkansas Electric Cooperative Corporation	No	We appreciate the effort the team has taken in improving the requirements since the last posting. We request the team clarify if this also includes personnel observing and reporting the requirements or only those specifically listed in the plan. The measure seems to indicate it only includes those listed in the plan, but this is not clear in the requirement. If it includes those personnel involved in observing and notifying management, then this might include a significant portion of the organization. In either case, we feel the requirement should be modified as "review applicable portions of its Impact Event Operating Plan...."
<p><b>Response:</b> The DSR SDT thanks you for your comment. The training provisions of the standard have been removed. The DSR SDT intent is to ensure that the Registered Entity has Operating Plan(s) for the identification of events, establishing which internal personnel are involved, identification of outside agencies to be notified, and having a provision for updating the plan(s). The SDT feels that current Sabotage Reporting guidelines already provide much of the information needed in the new R1.</p>		
Calpine Corp	No	Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Entities are capable of implementing procedures appropriate to ensure compliance with the actual reporting requirements without the addition a formal requirement to annually review their internal procedures with personnel. In the unlikely event that an entity cannot attain this level of operating competence without implementation of a new requirement, such Entities would be subject to enforcement under Requirement R5. Absent substantial evidence of systemic problems by Entities in contacting local law enforcement properly or failures to complete event reports to appropriate agencies when provided with clear guidance on the events to be reported, this requirement is unnecessary.

Organization	Yes or No	Question 9 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R2 and revised Requirements R1 and R5 to address your concern. Requirement R5 (now R2) reads:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
ExxonMobil Research and Engineering	No	<p>Its unclear whether R4 is a training requirement to train all individuals who may be required to implement its Impact Event Operating Plan on an annual basis or a requirement for an Entity to review the Impact Event Operating Plan with at least one person from each position that has a role in the Impact Event Operating Plan in order to complete a quality review of the Impact Event Operating Plan. The SDT should clarify the intent of the requirement. If the intent is that both of the aforementioned interpretations is expected to occur, the SDT should break R4 into two requirements so that an entity is not violation of Requirement R4 when the entity fails to comply with one of the two imbedded requirements (e.g. if the quality review is not performed but all individuals were trained).</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Constellation Power Generation	No	<p>The purpose of this requirement as currently worded is unclear. It seems to insinuate that a formal review of the Operating Plan takes place annually, and that any and all personnel identified in the plant are part of the review. If that is correct, than CPG believes this requirement is echoing Requirement 3. These two requirements can be incorporated into one. Furthermore, the Measure for R4 is too prescriptive, going so far as to specifically describe how this formal review should take place. It even states that the Responsible Entity needs to present documentation showing that the personnel in the plan were trained, yet there is no requirement for training. CPG would like the DSR SDT to revisit the purpose and intent of this requirement, alone and in concert with R3. If there are indeed similar then consolidate them into one requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Georgia System Operations Corporation	No	<p>With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between reviews" is necessary. Remove "with no more that 15 calendar months between reviews.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT has revised the term annual to align with the definition in the NERC Compliance Application</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
Notice (CAN) CAN-0010.		
SERC OC Standards Review Group	Yes	We agree with the concept, but disagree with the use of the term Operating Plan as a defined term in line with our comments in question 6 above.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the use of a defined term “Operating Plan” to describe the procedure to identify and report the occurrence of a disturbance is appropriate and has revised Requirement R1 to remove the terms Operating Process and Operating Procedure to eliminate confusion.</p>		
PJM Interconnection LLC	Yes	<p>1. We agree with the concept but disagree with the use of the term Operating Plan as a defined term in line with our comments to Question 6 above.</p> <p>2. R4 attempts to define Annual for the Registered Entity to review its Impact Operating Plan. We believe R4 should follow the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) CAN-0010 Definition of Annual as opposed to creating a new definition of Annual or refer to an entities defined use of the term annual.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see responses to question 6 above. The DSR SDT reviewed the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) CAN-0010. The NERC CAN provides drafting teams latitude to define annual within a Requirement as they believe is appropriate in the context of a particular standard.</p>		
United Illuminating Co	Yes	As written it is a training burden. Certain persons will have only one step in one operating procedure to perform. There is no necessity to review the entire Operating Plan with them. For example, Field Personnel need to know that if they see something not right to report it immediately. In this instance there is no benefit to review the Operating Procedure/Process for firm load shedding with them.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The training requirement has been removed. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The DSR SDT has removed R4 to eliminate potential confusion and redundancy around the training connotation.</p>		
Manitoba Hydro	Yes	Removing the extreme details within 30 days of revision and train before given responsibility and giving leeway to when this training is necessary, will allow training to be integrated into other existing training schedules. Inclusion of 5.3 and 5.4 would require unique set of time lines and additional resources to monitor and implement.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The training provisions of the standard have been removed.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 9 Comment
Occidental Power Marketing	Yes	However, only LSEs with BES assets (or assets that directly support the BES) should be included in the Applicability section of the standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Attachment 1 specifies which types of events are required to be reported by each entity. LSE is included here due to CIP-002-3 applicability.</p>		
Farmington Electric Utility System	Yes	A review of the Impact Event Operating Plan can be interrupted as an informal examination of the plan. The measure for R4 indicates evidence of a review, parties conducting the review AND when internal training occurred. It should be clarified in R4 training is expected as part of the review for personnel with responsibilities. This is an improvement from the previous 5.3 and 5.4, however, the team should consider adding back, and review/training shall be conducted prior to assuming the responsibility in the plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Ingleside Cogeneration LP	Yes	Yearly refresher training on the reporting process is appropriate. Ingleside Cogeneration also agrees that a review with those individuals with assigned responsibilities under the Operating Plan is a better way to frame the requirement.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Indeck Energy Services		R4 is redundant with R3 and should be deleted. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and revised R3. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
<p>approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	
Midwest ISO Standards Collaborators	Yes	
Southern Company	Yes	
SRP	Yes	
SDG&E	Yes	
New Harquahala Generating Co.	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
APX Power Markets	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
ISO New England, Inc	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
American Transmission Company	Yes	
Duke Energy	Yes	
City of Tacoma, Department	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

<b>Organization</b>	<b>Yes or No</b>	<b>Question 9 Comment</b>
of Public Utilities, Light Division, dba Tacoma Power		
Brazos Electric Power Cooperative	Yes	
Progress Energy	Yes	

10. Do you agree with the proposed revisions to Requirement 6 (now R5) and the use of either Attachment 2 or the DOE-OE-417 form for reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

**Summary Consideration:** The slight majority of commenters suggested revisiting R2 and R5 to eliminate potential redundancy and confusion. The intent of the two requirements is to have entities utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, it does not have to transcribe the same information onto Attachment 2 but may be required to submit the form to the DOE and NERC. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements.

R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

Organization	Yes or No	Question 10 Comment
Northeast Power Coordinating Council	No	R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the how part, not the what. The vehicle for reporting can easily be included in <b>R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event</b> . Suggest combining R2 with R5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Dominion	No	Dominion does not agree because the Requirement is too restrictive giving the Responsible Entity the choice on reporting forms as either Attachment 2 or DOE OE-417. The use of Attachment 2 or DOE OE-417 may be appropriate when reporting to NERC, however, Requirement R 1.3.2 requires the Responsible Entities Impact Event Operating Plan to address notifications to non-NERC entities such as Law Enforcement or Governmental Agencies. It is likely that these organizations have specific reporting requirements or forms that will not line up the options prescribed in Requirement R5. Suggest revising Requirement R5 to not require the use of these two forms as the only options. If these 2 forms are used, suggest aligning the Event names in Attachment 1 to be similar to the criteria for filing event names in the DOE OE-417 to allow for consistency.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
		Also suggest aligning the time to submit for similar event names in each form.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has revised Attachment 1 to indicate that entities must submit Attachment 2 or the DOE OE-417 form. This information was contained in Requirement 5. The intent of the two requirements is to have entities make appropriate notifications and report events contained in Attachment 1. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements while eliminating potential confusion and redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p> <p>The DSR SDT has enhanced Attachment 1 and clarified the intent of each event, threshold and reporting time limits. The DSR SDT removed the column, Time to Submit Report and replaced it with Submit Attachment 2 or DOE OE-417 Report.</p>		
SPP Standards Review Group	No	We feel there is redundancy between R2 and R5. To eliminate this redundancy, we propose to take the phrase using the form in Attachment 2 or the DOE OE-417 reporting form and adding it at the end of R2. Then what is left of R5 could be deleted. The new R2 would read Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B) using the form in Attachment 2 or the DOE OE-417 reporting form.?
<p><b>Response:</b> The DSR SDT has revised Attachment 1 to indicate that entities must submit Attachment 2 or the DOE OE-417 form. This information was contained in Requirement 5. The intent of the two requirements is to have entities make appropriate notifications and report events contained in Attachment 1. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements while eliminating potential confusion and redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Midwest ISO Standards Collaborators	No	Requirement 2 and Requirement 5 appear to be very similar. Requirement 2 requires implementation of the Operating Plan, Operating Process and/or Operating Procedure in Requirement 1. The Operating Procedure requires gathering and reporting of information for the form in Attachment 2. What does Requirement 5 add that is not already covered in Requirement 2 except the ability to use the DOE OE-417 reporting form which
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the two requirements is to have entities utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
FirstEnergy	No	We believe that Requirement 5 does not warrant a Medium risk factor. Not using a particular form is strictly

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
		administrative in nature and the VRF should be Low.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
PJM Interconnection LLC	No	R5 seems redundant as R2 already requires an entity to report any Impact Events by executing/implementing its Impact Event Operating Plan. R5 merely stipulates the use of Attachment 2 or DOE-417, which an entity automatically would use for reporting purposes while implementing its Impact Event Operating Plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the two requirements is to have entities utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Exelon	No	Agree that each Responsible Entity should be able to use either Attachment 2 or the DOE OE-417 form for reporting; however, a GO/GOP will not have the ability to respond to Attachment 2 Task numbers 8, 9, 10, 11, and 12. Suggest that the DSR SDT either evaluate a shortened form version, provide a note or provision for "N/A" based on registration, or revise form to be submitted by the most knowledgeable functional entity (e.g., TOP or RC).Need clear guidance as to which form is to be used for which Impact Event, we feel that one and only one form should be used to eliminate confusion. Attachment 2 has an asterisk on #s 7, 8, 9, 10 and 11 there is not reference corresponding to it.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has updated Attachment 2 to per comments received.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
Tenaska	No	R5 should be changed to Each Responsible Entity shall report Impact Events listed in Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form. This revised version of the proposed R5 is the only Requirement that is necessary to achieve the stated purpose of Project 2009-01. The proposed R1 through R4 should be deleted and R5 should be changed to R1.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT agrees the reporting is a fundamental aspect, but the operation plans are integral piece of the BES. The DSR SDT believes that the revisions created will provide clarity for the requirements. Please see the revised standard.</p>		
American Municipal Power	No	R5 is not an acceptable requirement, but it can be improved. Each Responsible Entity shall report "Impact Events" to _____ (address specified in attachment 1, website, entity, email address, or fax, etc.) Focusing on a plan and procedure is overly prescriptive. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy. The SDT agrees that the Registered Entity can decide on the how to implement the reporting; however, this requirement mandates that the Registered Entity document its process.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Arkansas Electric Cooperative Corporation	No	We appreciate the effort the team has taken in improving the requirements since the last posting. For R5, we suggest including the reporting form as part of the plan in R1. Otherwise, a violation of R5 would also indicate a violation of R2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
American Electric Power	No	This should be one-step covered by the implementation in requirement 2. We like the ability to use one form (i.e. NERC Attachment 2 or the DOE-417); however, we would prefer to have this information only be reported once.
<p><b>Response:</b> The DSR SDT thanks you for your comment. EOP-004-2 allows entities to utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
Consumers Energy	No	We understand that DOE is migrating to an on-line reporting facility rather than the email-submitted OE-417. If they do so, Form OE-417 will not be available for providing to NERC, and the reporting specified by EOP-004 will be duplicative of that for DOE. We recommend that NERC, RFC and the DOE work cooperatively to enable a single reporting system in which on-line reports are made available to all appropriate parties.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT agrees with the concept of the single reporting template and is working with other agencies to see if the single form would be achievable.</p>		
Independent Electricity System Operator	No	R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the how part, not the what. The vehicle for reporting can easily be included in R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event. We suggest the SDT combine R2 with R5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Ameren	No	The "Responsible Entity" should be limited to those functions with the most oversight such as the BA, RC, or TOP. Otherwise there will be multiple DOE OE-417 reports sent by multiple entities.
<p><b>Response:</b> Thank you for your comments. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
ISO New England, Inc	No	R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the how part, not the what. The vehicle for reporting can easily be included in R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event. We suggest the SDT combine R2 with R5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p>		
Calpine Corp	No	The use of DOE OE-417 is acceptable, but the language of Requirement R5 should be modified. The disturbance event form must be filled out correctly, irrespective of the requirements of an Entities Impact Event Operating Plan. Reference to that Plan does not add clarity to the requirement to report events. The



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 10 Comment
		<p>requirement should delete the reference to the Impact Event Operating Plan? and simply state: Each Responsible Entity shall report events listed in Attachment 1 using the provided form, or where also required to complete the current version of DOE OE-417, that form. Although one of the primary stated purposes of the original SAR was to simplify the reporting process by creating a single form, the fact that some entities are already required to report substantially identical information to DOE argues for retention of the use of the DOE form.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. DSR SDT has deleted requirement 2 and revised requirements R1 and R5 (now R2) to address your concern. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
BGE	No	<p>Language needs to be more specific on when to use Attachment 2 or DOE-OE-417.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Attachment 2 should be the normal reporting vehicle unless the entity is required to submit an OE-417 to the DOE. This keeps the entity from having to file two distinctly different reports for the same event.</p>		
Alliant Energy	No	<p>We believe Attachment 2 should be deleted, and NERC should work with the DOE to have one form for all events, if possible. It makes the reporting procedure much simpler, only having to use one form.</p>
<p><b>Response</b> The DSR SDT thanks you for your comment. EOP-004-2 allows entities to utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC. The DSR SDT is currently working with the DOE to make revisions to Form OE-417 that would achieve the objective of your comment. We will continue to pursue this.</p>		
ExxonMobil Research and Engineering	No	<p>The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notification windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 10 Comment
		<p>purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of the situation and determine the extent of the problem. The existing standards requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT envisions that each Registered Entity will develop Operating Plan(s) appropriate to meet its obligations as outlined in the standard. The SDT doesn't feel it necessary to prescribe to the Registered Entity any particular interpretation on how to achieve compliance, including who the information should be reported to. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
American Transmission Company	No	<p>Attachment 2, Task #14 in the report should be modified to read, Identify any known protection system misoperation(s). If this report is filed quickly, there is not enough time to assess all operations to determine any misoperation. As a case in point, it typically takes at least 24 hrs. to receive final lightning data; therefore, not all data is available to make a proper determination of a misoperation</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The entire Attachment 1 has been updated to reflect your comment.</p>		
Constellation Power Generation	No	<p>The requirements for filling out the DOE-OE-417 form are not necessarily the same as the requirements prescribed in Attachment 1. CPG suggests that the drafting team create a new requirement, spelling out when an entity is required to complete the DOE-OE-417 form.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Any entity that is obligated to submit Form OE-417 may submit that completed form to NERC in lieu of Attachment 2.</p>		
Georgia System Operations Corporation	No	<p>R5: This standard should not require all Responsible Entities to report the same event. Entities should be allowed to report in a hierarchical manner. They should be allowed to coordinate impact event plans and include in their plans the entity that has the responsibility for reporting various events. Flexibility should be allowed to provide different reporting entities depending on the type of event. In R5, does each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan? Allow this hierarchical reporting and flexibility? An entity should be allowed to report to another operating entity by whatever reporting form or mechanism works and then the other entity reports to NERC using the required NERC or DOE form. Add "To the extent that a Responsible Entity had an Impact Event," at the beginning of R5 and</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
		M5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each entity is required to report their portion of the event, however they can coordinate. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, will be able to provide the ERO and others with a different views of what has happened. The DSR SDT understands that there may be multiple reports (for certain events) that are required by different government agencies. NERC will continue to streamline the reporting process as we move into the future. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p>		
Indeck Energy Services	No	The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Bonneville Power Administration	Yes	Reporting form OK. Note that the Frequency Maximum/Minimum Section should be clarified. A Gen Loss doesn't usually experience a high (maximum) frequency, just the low immediately following the event.
<p><b>Response:</b> The DSR SDT thanks you for your comment</p>		
Midwest Reliability Organization	Yes	This will reduce any double reporting to the ERO and FERC.
PPL Supply	Yes	Reporting consistency and timelines may need to be reviewed for example: Fuel Supply Emergency - OE-417 requires reporting within 6 hours / Attachment 1 Part B requires reporting within 1 hour.
<p><b>Response:</b> The DSR SDT thanks you for your comment The DSR SDT has significantly revised Attachment 1 and deleted Fuel Supply Emergency from Attachment 1. This item was removed in coordination with the NERC Events Analysis Working Group and the proposed Events Analysis Program. All events are</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events in Part A and Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident in Part B.		
SERC OC Standards Review Group	Yes	We agree with the concept, but disagree with the use of the term Operating Plan as a defined term in line with our comments in question 6 above.
<b>Response:</b> The DSR SDT thanks you for your comment. The SDT agrees with your viewpoint and believes that your statement is consistent with the intent of the requirement. (refer to question 6)		
United Illuminating Co	Yes	Put it's before Impact Event Operating Plan.
<b>Response:</b> The DSR SDT thanks you for your comment. Please see the revised standard.		
Manitoba Hydro	Yes	The DOE-OE-417 appears more intuitive and descriptive (and on line ability), but having the either or option is fine. DOE-OE-417 Form is mentioned several time in this Standard, but no link to this document.
<b>Response:</b> The DSR SDT thanks you for your comment. Please see the revised standard.		
CenterPoint Energy	Yes	CenterPoint Energy agrees with the idea of streamlining the reporting process through the use of existing report forms. However, as noted in the response to Question 11, the Company has concerns about the DOE OE-417 Form, specifically the timeframes in which to submit reports. CenterPoint Energy will be making the same recommendation to extend reporting timeframes during the DOE OE-417 report revision process when the current form expires on 12/31/11. Any future changes to the DOE Form could also impact reporting for this requirement.
<b>Response:</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. The DOE Form OE-417 is under review by the U.S. Department of Energy (DOE) and can be updated or changed without NERC's involvement. The DSR SDT has taken into consideration the use of OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2's reporting requirements.		
PPL Electric Utilities	Yes	We would like to suggest the language be changed such that submission via a NERC system would be acceptable in addition to the use of the Attachment 2 Form or the DOE OE-417 form. The standard would then accommodate the proposed revision to NERC Rules of Procedure 812. NERC will establish a system to collect impact events reports??

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT expects any system would facilitate the reporting to organizations specified in the submitted report. Until such time that the system can be established, the Registered Entity will be obligated to make the notifications as specified in its Operating Plan(s). The DSR SDT is currently working with the U.S. Department of Energy (DOE) to make revisions to Form OE-417 that would achieve the objective of your comment, and will continue to pursue this.</p>		
Ingleside Cogeneration LP	Yes	Although our preference would be to have a single form, Ingleside Cogeneration realizes that is not likely in the near term. We would like to see that remain as a goal of the project team or the ERO.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT is currently working with the DOE to make revisions to Form Form OE-417 that would achieve the objective of your comment, and will continue to pursue this.</p>		
Duke Energy	Yes	There is so much overlap between Attachment 2 and the DOE OE-417 that we believe the DOE OE-417 should be revised to include the additional items that must be reported to NERC, so that there is only one form to submit to NERC and DOE.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT is currently working with the DOE to make revisions to Form OE-417 that would achieve the objective of your comment, and will continue to pursue this.</p>		
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
Compliance & Responsibility Organization	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Liberty Electric Power LLC	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Brazos Electric Power Cooperative	Yes	

**11. Do you agree with the proposed revisions to Attachment 1? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Most commenters expressed concerns with the reporting times listed in Attachment 1. Upon review of comments received concerning Attachment 1, the DSR SDT did a thorough review and updated the entire document, along with all Footnotes. The DSR SDT removed the column, Time to Submit Report and replaced it with Submit Attachment 2 or DOE OE-417 Report. There were many noted comments that a one hour reporting time frame does not coincide with an after the fact reporting Standard. The DSR SDT reviewed each time frame to report and has extended most of the time frames to 24 hours. There are a few events that have a one hour reporting requirement that was not changed because these are events that would generally be reported to law enforcement authorities and prompt reporting is in the interest of BES reliability. Duplicate reporting of events was minimized where possible. There are several events that will require reporting by multiple entities to achieve a complete enough picture to facilitate industry awareness.

Organization	Yes or No	Question 11 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	As stated above in response to question 6, we believe that a column should be added to the tables to explicitly indicate what external organizations should receive the communications of a particular Impact Event type. Additionally we have concerns with the following table items: Threshold for reporting Transmission Loss: As stated, this will require the reporting of almost all transmission outages. This is particularly true taking into consideration the current work of the drafting team to define the Bulk Electric System. The loss of a single 115kV network line could meet the threshold for reporting as the definition of Element includes both the line itself and the circuit breakers. Instead, we recommend the following threshold "Three or more BES Transmission lines." This threshold has consistency with CIP-002-4 and draft PRC-002-2. This threshold also needs additional clarification as to the timeframe involved. Is the intent the reporting of the loss of 3 or more BES Transmission Elements anytime within a 24 hour period or must they be lost simultaneously? Also, we recommend that these three losses be the result of a related event to require reporting. Entity with Reporting Responsibility for Loss of Off-site power to a nuclear generating plant (grid supply): The reporting responsibility should clarify that this is only entities included in the Nuclear Plan Interface Requirements.
<p><b>Response:</b> The DSR DT thanks you for your comment. Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received.</p>		
Northeast Power Coordinating	No	As indicated under Question 4, we question the need to include IA, TSP and LSE in the responsible entities

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
Council		for reporting.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has established that CIP-002 and CIP-008 are applicable to an IA, TSP, and LSE. These entities will report a Cyber Security Incident per Attachment 2 (or OE-417) as the vehicle to inform the ERO, their Regional Entity and their Reliability Coordinator.</p>		
Bonneville Power Administration	No	Generally OK, but there are too many events to report. The loss of 3 BES elements for a large geographic entity for a (5 county?) windstorm that has little impact to the system is not needed. 3 elements within the same minute could be acceptable and 6? elements still out within an hour ... or something to that affect could work.
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received.</p>		
Midwest Reliability Organization	No	<p>1) Section 9 of the Impact Reporting Form states: "List transmission facilities (lines, transformers, busses, etc.) tripped and locked out." But Part A of Attachment 1 states: "Three or more BES Transmission Elements." a. Should section 9 state: "List transmission facilities (lines, transformers, busses, etc.) tripped or locked out"? b. Should section 9 state: "List transmission elements (lines, transformers, busses, etc.) tripped or locked out"? This will align the reporting criteria with the actual reporting form.2) Section 13 of the Impact Reporting Form states: "Identify the initial probable cause or known root cause of the actual or potential Impact Event if know at the time of submittal of Part I of this report:." Recommend that "of Part I" be removed since there is no Part 2.3) Every Threshold in attachment 1 gives a clear measurable bright line, except: ?Transmission Loss?. As presently written ?Three or more BES Transmission Elements? could imply that a Report will be required to be submitted if a BES transmission substation is removed from service to perform maintenance. Or there could be three separate elements within a large substation that are out of service (and don?t effect each other) that will require a Report. Upon review of the TPL standards, there are normally planned items that our industry plans for. It is recommended that the Threshold for Reporting of Transmission Loss be enhanced to read: ?Two or more BES Transmission Elements that exceed TPL Category D operating criteria or its successor?. This threshold now is based on a actively enforced NERC Standard, and each RC and TOP are aware of what this bright line is.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received. Attachment 2 has been updated to reflect the changes noted in your comments and changes per the received comments.</p>		
PPL Supply	No	Recommendation: Add a column in Attachment 1 to acknowledge the events that require a OE-417 Report



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		and list the number under Schedule 1 that required Form OE-417Report. This would add accuracy and consistency among reporting entities.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DOE Form OE-417 is under review by the DOE and can be updated or changed without NERC’s involvement. The DSR SDT has taken into consideration the use of OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2’s reporting requirements.</p>		
Pacific Northwest Small Public Power Utility Comment Group	No	<p>The comment group is composed of smaller entities that do not all maintain 24/7 administrative support. While many of the 1 hour reporting thresholds do not affect us, some do. Others may come into play as standards are revised, such as the CIPs. We ask the SDT to consider the identification or verification that starts the clock on these may come at inopportune times for meeting a one hour deadline for these entities. Restoration may be delayed in an attempt to meet these time limits. Safety should always be the number one priority, and restoration and continuity of service second. We see reporting of these events much further down the list. We note that FERC order 693, paragraph 471 does not dictate a specific reporting time period and therefore we suggest timing requirements that promote situational awareness but allow smaller entities needed flexibility. FERC order 693, paragraph 470 directed the ERO to consider ?APPA?s concerns regarding events at unstaffed or remote facilities, and triggering events occurring outside staffed hours at small entities.? Our comment group does not believe the SDT has adequately responded to APPA?s concerns but rather took the 1 hour Homeland security requirement referenced in paragraph 470 verbatim. While a report within an hour might be ideal, it is not always practicable. We suggest: 1) as soon as possible after service has been restored to critical services within the service territory, or 2) By the COB the first business day after discovery. Our comment group realizes the difficulty in wording standards/requirements that lump small entities in with larger ones and we believe our suggestion achieves some balance. Expecting smaller entities to achieve timing requirements that can only be normally met under ideal conditions at large entities is not feasible or fair.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity’s notification. The Threshold for Reporting has been updated to reflect comments that have been received. EOP-004-2 requires an entity to “push” information to certain parties for industry awareness. Since this Standard is an after the fact reporting Standard, reporting times for a majority of event types reporting times for a majority of event types have been extended to allow the impacted entity to recover from the event and then report. The starting time to report is upon an entity’s recognized the event, per Submit Report column of Attachment 1.</p>		
PSEG Companies	No	For the reasons cited in response to question 4 above the language roles and responsibilities remain inconsistent and unclear. The Time to Report changes are unreasonable and there is significant duplicate reporting required.

Organization	Yes or No	Question 11 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received. EOP-004-2 requires an entity to "push" information to certain parties for industry awareness. Since this Standard is an after the fact reporting Standard, reporting times for a majority of event types have been extended to allow the impacted entity to recover from the event and then report.</p>		
Dominion	No	<p>1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would appear to overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the functional entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The DSR SDT understands that there may be multiple reports (for certain events) that are required by different governing agencies. NERC will continue to streamline the reporting process in the future.</p>		
Pepco Holdings Inc and Affiliates	No	<p>The entity responsible for reporting is not clear. Is the initiating entity the same as requesting entity or implementing entity? In the paper it indicates the DT intent is for the entity that performs the action or is directly affected will report. It seems that the proposal would result in a significant amount of duplicate reporting.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT believes it is clear that the reporting entity is the entity that experiences an event or initiates the event (per Threshold for Reporting in Attachment 1). The DSR SDT will ensure that the supporting guideline clearly states this. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view to what has happened.</p>		
SPP Standards Review Group	No	<p>Threshold for Reporting ? Some of the thresholds used to trigger event reporting seem arbitrary. For example, why were three BES Transmission Elements selected for the transmission loss trigger? What's significant with three? There may be situations where one element can impact reliability more than other situations where three or more lines may be lost. The defining line should be impact to reliability, not a simple count of elements. Also, timing of the loss of these elements is important. If the three elements are lost over a 3-day span, does this trigger an event report? We would think not and would like to see that clarification in the</p>

Organization	Yes or No	Question 11 Comment
		<p>standard.Public appeals ? Some entities may utilize load reduction (Demand Response, interruptible loads, etc) in the normal course of daily operation in lieu of committing additional generation resources. Because this is not an Energy Emergency as defined in the NERC Glossary, would such an event trigger the filing of an Impact Event report under EOP-004-2? We would like clarification on this issue.Multiple entity reporting responsibility ? Several of the triggering events in Attachment 1 list multiple entity reporting responsibility. The SDT needs to clarify precisely who has the actual reporting responsibility for those events. For example, if a DP loses ? 300 MW (or ? 200 MW depending on size) of load who files the report? Is it the DP, TOP, BA or RC? Attachment 1 would lead us to believe all four are required to file reports. This redundancy is unnecessary and creates unneeded paperwork. Surely this redundancy is not the intent of the SDT.Reporting timeframe ? The timeframes for reporting these after-the-fact reports need to be thoroughly reviewed and, we believe, realigned. Which is more important to the reliability of the BES, operating and controlling the BES following an Impact Event or filing a report describing that event? Most operating desks are staffed by a single operator at nights and on weekends. Their focus should be on operating the system, not filing a report with NERC or DOE within one hour.There appears to be inconsistency in the reporting times among the triggering events. There doesn't appear to be any logic regarding how the times were selected. Shouldn't impact to the reliability of the BES be that basis? Why is a BA with 50 MW of load who makes a public appeal to customers for load reduction required to report within 1 hour while an IROL violation doesn't need to be reported for 24 hours? Clearly the IROL violation has a greater impact on the reliability of the BES. Therefore, shouldn't these types of reports be filed sooner than those events with less impact on BES reliability?Risk to BES equipment ? The Threshold for Reporting this event indicates that only those events associated with a non-environmental physical threat should be reported. The train derailment example in the footnote then conversely describes just such an environmental threat with flammable or toxic cargo. Which should it be? Additionally, how does one determine the applicability of a potential threat? Is this time dependent, is it threat dependent, how do we factor all this in?</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT believes it is clear that the reporting entity is the entity that experiences an event or initiates the event (per Threshold for Reporting in Attachment 1). The DSR SDT will ensure that the supporting guideline clearly states this. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view to what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
FirstEnergy	No	Nuclear facilities should be explicitly excluded from the events which have CIP standards as the threshold for reporting since they are exempt from the CIP standards.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT understands that nuclear facilities are exempt from CIP Standards but the Loss of Off Site Power to a nuclear generating plant is a Transmission Owner's and Transmission Operator's responsibility and needs to be reported to the ERO and their</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
Regional Entity for the follow up as described by the Event Analysis Program.		
SERC OC Standards Review Group	No	While we agree with the changes made, we do not believe the goal of eliminating duplicate reporting has been accomplished. In addition, the threshold for transmission loss does not adequately translate to previous ?loss of major system components? which had a threshold of ?significantly affects the integrity of interconnected system operations?.
<b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.		
PJM Interconnection LLC	No	There is still a significant amount of duplicate reporting involved in Attachment 1, which needs to be cleared. See comments to Question 4.
<b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.		
We Energies	No	It appears that the footnotes only apply one place in the table. Place the footnote in the table where it applies.Voltage Deviations on BES Facilities: 10% compared to what? Rated?Forced Intrusion: ?At a BES facility? facility or Facility?
<b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. The Footnotes have been reviewed and updated per comments received.		
LG&E and KU Energy LLC	No	In Attachment 1, the existing EOP-004-1 Attachment 1, point 6 includes an ?Or? for the entities (RC, TOP, GOP) for a, b and c. The way the SDT has pulled this apart, they have included the GOP as having an impact on the Voltage Deviations on BES Facilities. The TOP monitors the transmission system and directs GOPs when they need to change in order to protect the system reliability. This is not something the GOP is responsible for monitoring. The GOP is required to be at the TOP assigned voltage schedule and that actually falls under VAR-002 already. Please remove the GOP from the line of ?Voltage Deviations on BES Equipment.? The way EOP-004-1 Attachment 1 point 6 is currently written, the GOP is an ?or? and does fall into parts b or c, where part 6b is similar to the proposed line ?Damage or destruction of BES equipment? identified in the proposed EOP-004-2 Attachment 1. However, currently the GO/GOP reports ?Loss of Major System Components? on EOP-004-1 within 24 hours of determining damage to the equipment. The proposed ?One hour? is too tight of a window as the GO/GOP often do not know the extent of damage that

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		soon. Typically the OEM is called upon to come and do a thorough inspection and assess the extent of damage, of if there even is any damage; once the ?loss of major system components? is determined, then the 24 hour clock begins today.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2
Exelon	No	<p>Attachment 1, Part A ? Energy Emergency requiring Public appeal for load reduction ? In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency." Suggest revising back to specific entities that would be likely responsible for this action (e.g., RC, BA, TOP). Attachment 1, Part A ? Energy Emergency requiring system-wide voltage reduction ? In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency" related to system-wide voltage reduction. Suggest revising back to specific entities that would be likely responsible for this action.</p> <p>Attachment 1, Part A ? Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ? 15 continuous minutes, this should be a TOP RC function only. Attachment 1, Part A ? Generation Loss of ? 2, 000 MW for a GOP does not provide a time threshold. If the 2, 000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? Suggest that a time threshold be added for clarity.</p> <p>Attachment 1, Part A ? Loss of off-site power (grid supply) affecting a nuclear generating station ? this event applicability should be removed in its entirety for a Nuclear Plant Generator Operator. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design, if it is a partial loss of off-site power (per the plant specific NPIRs) and may not result in a loss of generation (i.e., unit trip). If a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a Nuclear Plant Generator Operator during a potential transient on the unit. In addition, if the loss of off-site power were to result in a unit trip, if the impact to the BES were ?2,000 MW, then required notifications would be made in accordance with the threshold for reporting for Attachment 1, Part A ? Generation Loss. However, to align with the importance of ensuring nuclear plant safe operation and shutdown as implemented in NERC Standard NUC-001, if a transmission entity experiences an event</p>

Organization	Yes or No	Question 11 Comment
		<p>that causes an unplanned loss of off-site power (source) as defined in the applicable Nuclear Plant Interface Requirements, then the responsible transmission entity should report the event within 24 hours after occurrence. In addition, replace the words "grid supply" to "source" to ensure that notification occurs on an unplanned loss of one or multiple sources to a nuclear power plant. Suggest rewording as follows (including replacing the words "grid supply" to "source" and adding in the word "unplanned" to eliminate unnecessary reporting of planned maintenance activities in the table below):</p> <p>Event Entity with Reporting Responsibility Threshold for Reporting Time to Submit Report            Unplanned loss of off-site power to a Nuclear generating plant (source) as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) Each transmission entity responsible for providing services related to NPIRs (e.g., RC, BA, TO, TOP, TO, GO, GOP) that experiences the event causing an unplanned loss of off-site power (source) Unplanned loss of off-site power (source) to a Nuclear Power Plant as defined in the applicable NPIRs. Within 24 hours after occurrence</p> <p>Attachment 1, Part A ? Damage or destruction of BES equipment ? The event criteria is still ambiguous and does not provide clear guidance; specifically, the determination of the aggregate impact of damage may not be immediately understood ? it does not seem reasonable to expect that the 1 hour report time clock starts on identification of an occurrence. Suggest that the 1 hour report time clock begins following confirmation of event. ? The initiating event needs to explicitly state that it is a physical and not cyber. ? If the damage or destruction is related to a deliberate act, consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event (see additional comments in response to item 17 below).</p> <p>Attachment 1, Part A ? Damage or destruction of Critical Cyber Asset The events that are associated with Critical Cyber Assets should be removed from this Standard. Critical Cyber Asset related events are better addressed in the reporting of Cyber Security Incidents which is already included in Attachment 1, Part B and the CIP standards currently require details about Critical Cyber Assets to be protected with access to that information restricted to only specifically authorized personnel.</p> <p>Attachment 1, Part A ? Damage or destruction of Critical Asset The events that are associated with Critical Assets should be removed from this Standard. Critical Assets are typically whole control centers, substations or generation plants and the damage or destruction of individual pieces of equipment at one of these locations will usually not have much impact to the BES. Any important impacts located at these sites are already addressed in the other existing [Impact] Event types or would be addressed in the Cyber Security Incident event which is already included in Attachment 1, Part B. The CIP standards also currently require that details about Critical Assets and Critical Cyber Assets must be protected with access to that information restricted to only specifically authorized personnel. The identification of Critical Asset is also only an interim step used to identify the Critical Cyber Assets that need to have cyber security protections and the NERC Project 2008-06 CSO706 Standards Drafting Team is currently expecting to eliminate the requirement to identify Critical Assets in the draft revisions they are currently working on.</p> <p>Attachment 1, Part B ? Forced intrusion at a BES facility ? Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>potential security event (see additional comments in response to item 17 below).Attachment 1, Part B ? Risk to BES equipment from a non-environmental physical threat ? this event leaves the interpretation of what constitutes a "risk" with the reporting entity. Although the DSR SDT has provided some examples, there needs to be more specific criteria for this event as this threshold still remains ambiguous and will lead to difficulty in determining within 1 hour if a report is necessary. Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event (see additional comments in response to item 17 below).Attachment 1, Part B ? Detection of a reportable Cyber Security IncidentAlthough the DSR SDT agreed that there may be confusion between reporting requirements in this draft and the current CIP-008, "Cyber Security ? Incident Reporting and Response Planning", Part B now requires a 1 hour report after occurrence. The DSR SDT should verify the timing and reporting required for these Cyber Security Incident events is coordinated with the NERC Project 2008-06 CSO706 Standards Drafting Team.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received. The DSR SDT has worked closely with NERC Staff, the Event Analysis Working Group, Project 2008-06 and the U.S. Department of Energy to ensure that EOP-004-2 captures what FERC has directed and will improve the reliability of the BES.</p>		
SDG&E	No	<p>For ?Detection of a reportable Cyber Security Incident,? Attachment 1 identifies the threshold for reporting as: ?that meets the criteria in CIP-008 (or its successor)?; however, CIP-008 has no specified criteria, so this is an unusable threshold. Additionally, SDG&amp;E recommends that the timing of any follow-up and/or final reports required by the standard be listed in the Attachment 1 table.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> CIP-008 states that an entity will report a Cyber Security Incident to the ES-ISAC. EOP-004-2, Attachment 2 is the vehicle to report a Cyber Security Incident. It is also required to be sent to their RC which will give them the industry awareness of a single event or is it a multiple event within their area.</p>		
City of Tallahassee (TAL)	No	<p>One hour should be expanded. While I realize the importance of getting information to NERC/ESISAC/whoever, most of the 1-hour requirements are tied to events that may not be resolved within one hour. This will result in stopping restoration efforts or monitoring to submit paperwork. Calling in additional assistance, while certainly a possibility, may not be feasible to accomplish in sufficient time to meet the one-hour deadline. If any of these events were to truly have a detrimental effect on the BES, the effects would have already been felt.Recommend all 1-hour reports be extended to 4-hours. This should also be placed on the list to modify Form OE-417report time lines.</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received. The DOE Form OE-417 is not governed by NERC but the DSR SDT is proposing to allow an entity to use it to report an event in lieu of Attachment 2.</p>		
Lakeland Electric	No	<p>Event ? Transmission lossThreshold for Reporting ? Revise to ?Loss of three or more BES Transmission elements within a 15 minute period?. This change would capture a sequence of transmission element losses and remove the question if timing that will arise if other transmission elements trip, cascade, due to loss of the first element. There may also be a need for a footnote to clarify that a transmission element that is removed from service by a transmission operator to prevent uncontrolled cascading would be classified as a loss (something for the SDT to consider). Event ? Energy Emergency requiring Public appeal for load reductionThreshold for Reporting ? Add a footnote: Repeated public appeals for the same initiating Impact Event shall be reported as one Public Appeal Event. The initiation and release to the media of the Public appeal(s) should be the reportable event. Question: would an internal request to large industrial customers for voluntary load reductions be reportable under this Event?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received. Demand responsive load is not covered within this proposed Standard unless it fulfills a Threshold of Reporting within Attachment 1. Footnotes have been update to reflect comments received.</p>		
Arkansas Electric Cooperative Corporation	No	<p>We appreciate the effort the team has taken in improving the requirements since the last posting. Event Forced Intrusion: The timeframe is very small given the possibly minimal risk to the BES. It often takes much longer than 1 hour after verification of intrusion to determine the intrusion was only for copper theft. We suggest a 24 hour time frame or tie the timeframe to the "verification of forced intrusion."</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Manitoba Hydro	No	<p>Reporting for CCA's should be limited to damage associated with a detected cyber security incident.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Damage or destruction of Critical Cyber Assets s is per CIP-002 and may not fall into the category of Cyber Security Response as outlined by an entity.</p>		
Sweeny Cogeneration LP	No	<p>In Attachment 1, Part A, Generator Operators who experience a ? 10% sustained voltage deviation for ? 15</p>



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		continuous must issue a report For externally driven events, the GOP will have little if any knowledge of the cause or remedies taken to address it. We believe the language presently in EOP-004-1 is satisfactory that any ?action taken by a Generator Operator? that results in a voltage deviation has to be reported by the GOP.
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
American Electric Power	No	<p>The time to submit a report for the inclusion of the damage or destruction of BES equipment, critical asset, or critical cyber asset is too aggressive. The critical cyber asset reporting is redundant with CIP-008. Furthermore, reporting equipment failures within an hour for Critical Assets is going to overwhelm operators that need to focus on the restoration efforts. Self-evident equipment failures at a Critical Asset (such as a tube leak at a generator which is a Critical Asset) should not be required to be reported. Maybe the wording should be stated as an ?abnormal occurrence? rather than ?equipment failure.?It would be helpful if there was a defining or a footnote that defines the nature and/or duration for loss of some equipment. For example, is a transmission loss for sustain or momentary outages?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The Implementation Plan for this project now includes a provision to retire the requirement in CIP-008 for reporting (Requirement 1, Part 1.3). The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
USACE	No	The "Potential Reliability Impact" table should be taken out. Referred to previous comment on our position on potential impacts.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT believes that potential events are required to be reported to provide industry awareness.</p>		
Consumers Energy	No	<p>1. In reference to the Impact Event addressing ?Loss of Firm load for greater than or equal to 15 minutes?, this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to ?Within 1 hour after detection of exceeding 15-minute threshold?. Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES.2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting ?Within 1 hour after occurrence is identified? possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the ?time to submit?3. Referring to the</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>?Transmission Loss? Impact Event, please provide more specificity. Is this intended to address :- anytime that three or more BES Transmission Elements are out of service, - only when three or more BES Transmission Elements are concurrently out-of-service due to unscheduled events, - only when three or more BES Transmission Elements are simultaneously automatically forced out-of-service, or- only when three or more BES Transmission Elements are forced from service in some proximity to each other? It is not unusual, for a large transmission system, that this many elements may be concurrently forced out-of-service at widely-separated locations for independent reasons.4. Referring to the ?Fuel Supply Emergency? Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.5. For that matter, the SDT should carefully compare the Impact Event Table with OE-417. Where similar Impact Events are listed, consistent terminology should be used, and identical reporting periods specified. Where the Impact Event Table contains additional events, they should be clarified as being distinct from OE-417 to assist entities in implementation. Further, since OE-417 must be reviewed and updated every three years, EOP-004 should defer to the reporting time constraints within OE-417 wherever listed in order to assure that conflicting reporting requirements are not imposed.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed 'Loss of Firm Load' as a reporting event, and believe the reporting requirement currently approved in EOP-004-1 should remain in EOP-004-2. The DSR SDT has removed the 'Fuel Supply Emergencies' event after considering comments the DSR SDT received on this event. The DOE Form OE-417 is reviewed biennially by the DOE and can be updated or changed without NERC's involvement. The DSR SDT has taken into consideration the use of Form O- 417 to report events to NERC and agrees that this will fulfill EOP-004-2's reporting requirements. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Independent Electricity System Operator	No	As indicated under Q4, we question the need to include IA, TSP and LSE in the responsible entities for reporting.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has established that CIP-002-4 and CIP-008-3 are applicable to an IA, TSP, and LSE. These entities will report a Cyber Security Incident per Attachment 2 (or OE-417) as the vehicle to inform the ERO, their Regional Entity and their Reliability Coordinator.</p>		
Ameren	No	See response to question 4.
<p><b>Response: The DSR DT thanks you for your comment.</b> Please see question 4 response.</p>		
ISO New England, Inc	No	As indicated under Q4, we question the need to include IA, TSP and LSE in the responsible entities for reporting. There is still significant duplicate reporting included. For instance, why do both the RC and TOP to report voltage deviations? As written, a voltage deviation on the BES would require both to report. The same

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>would hold true for IROLs. Perhaps IROLs should only be reported by the RC to be consistent with the recently FERC approved Interconnection Reliability Operating Limit standards. Also, the CIP reporting requirements duplicate was is already contained in the CIP Standards, specifically CIP-008. Also, we are required to intentionally destroy Critical Cyber Assets when they are retired, why would we be required to report this?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has established that CIP-002-3 and CIP-008-3 are applicable to an IA, TSP, and LSE. These entities will report a Cyber Security Incident per Attachment 2 (or OE-417) as the vehicle to inform the ERO, their Regional Entity and their Reliability Coordinator. If a Critical Cyber Asset (CCA) was to be retired, the entity would declassify it as a CCA and therefore it would not be required to be reported. The Implementation Plan for this project now includes a provision to retire the requirement in CIP-008 for reporting (Requirement 1, Part 1.3)</p>		
Calpine Corp	No	<p>1. Additional clarity on the nature of reportable ?Fuel Emergencies? is needed. Does loss of interruptible gas transportation require reporting? 2. Additional clarity on the threshold for ?damage or destruction of BES equipment? is needed. Footnote 1 on page 16 states, in part ?Significantly affects the reliability margin of the system (e.g. has the potential to result the need for emergency actions?. For generating facilities, does this statement refer specifically to the parallel requirement to report any loss of generation &gt;= 2,000 in the Eastern or Western Connection or &gt;= 1,000 in the ERCOT or Quebec Interconnection? If not, exactly what level of damage at a generating plant requires reporting? Use of imprecise terms such as ?significantly? sets the stage for future compliance and enforcement confusion.3. Additional clarity is required for ?Detection of reportable Cyber Security Incident.” Is this item intended to apply only to Critical Cyber Assets, or is it an extension of the requirement to all applicable entities irrespective of their Critical Asset status? If it applies only to Critical Cyber Assets, does this reporting requirement create redundant reporting (as reporting is already required under CIP-008-4)? CIP-008-4 requires reporting only of events affecting Critical Cyber Assets. If a more expansive application is intended, what equipment or systems are to be included in the reporting requirement?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The event of Fuel Supply Emergencies has been removed per comments the DSR SDT received. The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. Damage to BES equipment’s foot note has been enhanced to mean that the BES piece of equipment is required to be removed from service. CIP-008 states that an entity will report a Cyber Security Incident to the ES-ISAC. EOP-004-2, Attachment 2 is the vehicle to report a Cyber Security Incident.</p>		
BGE	No	<p>For the following Events (Damage or destruction of BES equipment, Damage of destruction of Critical Asset, and Damage or destruction of a Critical Cyber Asset), submitting a report within 1 hour after occurrence is identified is too short of a time frame. Generally, the initial time period is spent in recovering from the situation and restoring either electric service or restoring computer services to assure proper operations. To</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>distract from the restoration to normal activities to focus on a report would be detrimental to reliability. Notification of an event may perhaps be made by phone call within 1 hour but completing a report should be required no less than 6 or 12 hours. Determining a cause (especially external or intentional) could take longer than 1 hour to determine and complete a report. It is important to consider the imposition created by a compliance obligation and weigh it against the other demands before the operator at that time. A compliance obligation should avoid becoming a distraction from reliability related work. Under impact event type scenarios, in the first hour of the event, the primary concern should be coping with/resolving the event.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. Damage to BES equipment's foot note has been enhanced to mean that the BES piece of equipment is required to be removed from service.</p>		
Alliant Energy	No	<p>The item relating to Loss of Firm Load for &gt; 15 minutes should be revised to 500 MW and 300 MW. For many companies, a storm moving across their system could cause more than 300 MW of firm load to be lost, but there is no impact on the BES, so why does the detailed reporting need to be done? The items relating to ?damage or destruction? need to be revised to not be so wide. As currently written, a plan by a company to raze a facility could be considered a violation and must be reported. We believe it needs to be tightened to malicious intent or human negligence/error.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed Loss of Firm load and believe the reporting requirement presented approved in EOP-004-1 is substantial and should remain within EOP-004-2. If a Critical Cyber Asset (CCA) was to be retired, the entity would declassify it as a CCA and therefore it would not be required to be reported.</p>		
CenterPoint Energy	No	<p>(1) CenterPoint Energy believes that the ?Entity with Reporting Responsibility? for the first three events in Part A should be clarified. There could still be confusion regarding the ?initiating entity? for events where one entity directs another to take action. From the text on page 5 of the Unofficial Comment Form, it appears that the SDT intended for the ?initiating entity? to be the entity that takes action. To make this clear in Attachment 1, CenterPoint Energy recommends replacing ?initiating entity? with ?Each (insert applicable entities) that (insert action). For example, for ?Energy Emergency requiring a Public appeal? the Entity with Reporting Responsibility should be ?Each?that issues a public appeal for load reduction?. (2) Part A: The threshold for reporting ?System Separation? should not be fixed at greater than or equal to 100 MW for all entities, but rather should be scaled to previous year's demand as in ?Loss of Firm load for greater than or equal to 15 minutes?, so that for entities with demand greater than or equal to 3000 MW, the island would be greater than or equal to 300MW. (3) Part A: The one hour reporting requirements are unreasonable and burdensome. The Background text indicates that ?proposed changes do not include any real-time operating notifications?? CenterPoint Energy believes all one hour reporting requirements could potentially divert resources away from</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>responding to the event. In many instances the event may still be developing within one hour. Likewise, the 24 hour reporting requirements are also burdensome. CenterPoint Energy recommends changing all reporting requirements to 48 hours. CenterPoint Energy acknowledges that the DOE OE-417 report requires certain one hour and 6 hour reporting. Those requirements should also be extended, and CenterPoint Energy will be making the same recommendation during the DOE OE-417 report revision process when the current form expires on 12/31/11.(4) Part B: CenterPoint Energy is very concerned with the ?events? listed under Attachment 1 ? Potential Reliability Impact ? Part B and believes Part B should be deleted. These arbitrary ?events? with ?potential reliability impact? and reporting times place unnecessary burden on entities to report ?situations? that would rarely impact the reliability of the BES. Entities should be aware of developing situations; however, this standard should not require reporting of such occurrences.(5) Part B: Of particular concern is the overly broad ?Risk to BES equipment? and the example provided in the footnote. CenterPoint Energy believes the SDT has already identified the events with the greatest risk to impact the BES in Part A. Also including ?potential reliability impact? situations in Part B inappropriately dilutes attention away from the truly important events. The industry, NERC and FERC should not lose sight of the forest for the trees.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. The DOE Form OE-417 is under review by the DOE and can be updated or changed without NERC’s involvement. The DSR SDT has taken into consideration the use of OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2’s reporting requirements.</p>		
ExxonMobil Research and Engineering	No	<p>The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notifications windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of of the situation and determine the extent of the problem. The existing standard’s</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received.</p>		
PPL Electric Utilities	No	<p>We very much appreciate the work performed by SDT and consideration of all the comments received. While we agree with the majority of the Attachment 1 changes, we suggest the SDT add further clarification to Attachment 1, Part A, Event 'Transmission Loss'. Does this mean permanent loss? Do two lines and a pole constitute a loss of three elements? E.g. Consider the loss of a 230 kV line with two tapped transformers. This does not have a significant effect on the BES, yet would it be reportable? We would prefer Attachment 1, Part A, 'Threshold Reporting' be clarified. E.g. 'Three or more "unrelated" pieces of equipment for a single event'.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received.</p>		
Lincoln Electric System	No	<p>While LES supports the bright line criteria listed in Attachment 1 for reporting Impact Events, we have concerns regarding the reporting threshold for 'Transmission loss'. For Transmission loss of three or more Transmission Elements, LES supports the MRO NSRS' suggested wording of 'Two or more BES Transmission Elements that exceed TPL Category D operating criteria or its successor.'</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
American Transmission Company	No	<p>Energy Emergency requiring Public AppealATC believes that the phrase 'initiating entity' is unclear and could be interpreted in multiple ways. 1) the entity has the authority to call for public appeals, 2) the entity has the authority to declare an Energy Emergency, or 3) the entity determines and identifies the need for the Energy EmergencyTypically the BA's call for public appeals, so does every BA that calls for the public appeal have to make a filing?The RC declares the need for an Energy Emergency, so are they the initiating entity? A TOP could also identify the need for public appeals and notify the RC about the request. In this case, is the TOP the initiating entity?Given the above examples, ATC believes that the SDT needs to clarify who is required to make the filing. Voltage Deviations on BES FacilitiesATC believes that this should be clarified because one may assume that a loss of a single bus in which voltage goes to zero for more than 15 minutes</p>

Organization	Yes or No	Question 11 Comment
		<p>is reportable. It is ATC understands that what the SDT means is a voltage dip, not an outage to a BES facility. However, given the brief description, ATC is not 100% sure whether there is a clear understanding of the standard's intent. Energy Emergency resulting in automatic firm load shedding Please provide additional clarify. ATC believes that the SDT should not use the term "Impact Event" when identifying the entity with reporting responsibility. The term "Impact Event" is identified in the standard and points to Attachment 1 but now is being used outside of that context and requires entities to interpret what qualifies as an Impact Event. The above observation also applies to those other events that use the term "Impact Event" to describe Reporting Responsibility. Footnote 1: ATC would like the phrase "as determined by the equipment owner" added to the footnote. This simple phrase will allow entities to be sure that they are responsible for determining if the damage significantly affects the reliability margin of the system. Without this phrase, entities could be subject to non-compliance actions based on differences of opinions to the extent of the damage on the system. The other option the SDT has is to provide additional clarity on what qualifies as a significant affect. Time to Submit Report: ATC strongly disagrees with the 1 hour time to submit a report because it does not fit with the purpose of this standard. The purpose of this standard is to increase awareness, however, requiring a one-hour reporting window following the event provides little to no benefit. ATC believes that these events should have a 24 hour reporting window which allows for a reasonable amount of time to gather information and report the issue. If the SDT disagrees with this observation, ATC believes a complete explanation should be provided on why knowledge of an event within an hour is significantly better than having the knowledge of the event in a 24 hour time period. ATC strongly believes that NERC will gain as much or more knowledge of the event by giving entities time to understand the event and report.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Duke Energy	No	<p>" Attachment 1 contains three reportable events (Damage or destruction of Critical Asset, Damage or destruction of a Critical Cyber Asset, and Detection of a reportable Cyber Security Incident) that overlap with CIP-008-3 Cyber Security Incident Reporting and Response Planning and could result in redundant or conflicting content between the two standards. We propose either of the following options: 1. Remove the requirement for reporting these events from EOP-004-2 and add the timing and reporting requirements into CIP-008-3, R1.3. "Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary." OR 2. Replace the reporting requirement in CIP-008-3, R1.3. with a reference to report as required in EOP-004-2." Also, as noted in our comment to Question #4 above, the Attachment 1 Section "Entity with Reporting Responsibility" should just identify "Initiating entity" for every Event, as was done with the first three Events. That way you avoid errors in leaving an entity off, or including an entity incorrectly (as was done with the GOP on Voltage Deviations). We note that LSE is listed in the standard as an Applicable entity, and should be included in Attachment 1.</p>

Organization	Yes or No	Question 11 Comment
		<p>Our suggestion would handle this oversight. We also note that CIP-001 does not include Distribution Provider in the list of applicable entities, but EOP-004-2 does include the DP.? We reiterate our comment to Question #1 above that the DSR SDT statement that the proposed changes do not include any real-time operating notifications is inconsistent with requiring notification within one hour for thirteen of the twenty listed Events in Attachment 1.? The last six events refer to the entity that experiences the potential Impact Event. We believe that the word ?potential? should be struck, as this creates an impossibly broad reporting requirement.? Footnote 1 should be revised to strike the phrase ?has the potential to? from the parenthetical, as this creates an impossibly broad reporting requirement.? The Impact Event ?Risk to BES equipment? should be revised to ?Risk to BES equipment that results in the need for emergency actions?. The accompanying footnote 4 should be revised to read as follows: Examples could include a train derailment adjacent to BES equipment (e.g. flammable or toxic cargo that would cause the evacuation of a BES facility control center), or a report of a suspicious device near BES equipment.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. CIP-008 states that an entity will report a Cyber Security Incident to the ES-ISAC. EOP-004-2, Attachment 2 is the vehicle to report a Cyber Security Incident. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The DSR SDT understands that there may be multiple reports (for certain events) that are required by different government agencies. NERC will continue to streamline the reporting process as we move into the future.</p>		
Constellation Power Generation	No	<p>CPG has the following concerns regarding Attachment 1: ?Real-Time - On page 5 of the proposed standard, the team noted that ?the proposed changes do not include any real-time operating notifications.? However, several events in Attachment 1 require that documentation be completed and submitted to the ERO within 1 hour. For generation sites that are unmanned, or only have 1 to 2 operators on site at all times, a 1 hour requirement is not only onerous but is essentially ?real time.??Response within 1 hour - It is important to consider the imposition created by a compliance obligation and weigh it against the other demands before the operator at that time. A compliance obligation should avoid becoming a distraction from reliability related work. Under impact event type scenarios, in the first hour of the event, the primary concern should be coping with/resolving the event. Other notification requirements exists based on required agency response relative to the concern at hand (e.g. public evacuations, fire assistance, etc.) Notification within an hour under EOP-004 does not appear to represent a relevant benefit to resolving the situation and the potential cost would be borne by reliability and recovery efforts. Anything performed within the first hour of the event must be to benefit the public or benefit the restoration of power.?Damage or destruction of BES equipment ? the reporting requirement of 1 hour is extremely onerous. A good example is the failure of a major piece of equipment at a remote combustion turbine generation site. Combustion turbine generation sites are not usually manned with many people. If a failure of a major piece of equipment were to occur, the few people on site need to complete communications to affected entities, communications to their management, as well as</p>



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>emergency switching and ensuring that no other pieces of equipment are effected or harmed. There is little time to complete a form in 1 hour. This should be changed to 48 hours. The form is also inadequate for this type of event.     o Using the example above of a failure of a major piece of equipment, CPG is not sure if it's reportable per Attachment 1, which further proves that Attachment 1 is not clear. Per the footnote regarding damage to BES equipment, the failure would not be reportable, as it does not affect IROL, given the information at the plant it does not significantly affect the reliability margin of the system, and was not damaged or destroyed due to intentional or unintentional human action. However, it would be reportable per the table as the table states "equipment failure" and "external cause." Clarification is needed. "Damage or destruction of Critical Asset" This item should be removed or significantly refined. For generation assets, a critical asset is essentially the entire plant, so in many cases the information reported at this level would not be useful if the valuable details reside at the equipment level. If it is not removed, then see the notes above on the 1 hour requirement for the completion of the form. "Fuel supply emergency" 1 hour for reporting the document is unreasonable. See the earlier notes. "Risk to BES equipment" "From a non-environmental physical threat" This item is too vague and subjective. A catch all category to capture a broad list of potential risks is problematic for entities to manage in their compliance programs and to audit. This should be removed.</p>
<p><b>Response: The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</b></p>		
<p>Georgia System Operations Corporation</p>	<p>No</p>	<p>Energy Emergency requiring public appeal for load reduction:-The NERC Glossary defines "Energy Emergency" as a "condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements." Per EOP-002, an Energy Emergency Alert may be initiated by the RC upon RC sole discretion, upon BA request, or upon LSE request.-Question: Is it intended that the LSE reports the event if the LSE requests an alert, the BA reports the event if the BA requests an alert, and the RC reports it if it is a RC sole discretion decision? What if an alert is not initiated? Is it an Energy Emergency? Is it an impact event? Who must initiate the public appeal? Since it must be reported within a certain time after the issuance of the public appeal, is it not an impact event until after the initiation of the public appeal (which should be after the initiation of the alert)? Shouldn't the reporting of the impact event be done by the initiator of the public appeal? The event should probably be the public appeal and not the Energy Emergency.-"Public" should not be capitalized.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained." Energy Emergency requiring system-wide voltage reduction: See Energy Emergency requiring public appeal for load reduction above regarding requesting Energy Emergency Alerts. If this event is to be reported within a certain time after "the event", at what time is the event marked? Or is it within a certain time after the initiation of the voltage reduction and, if so, shouldn't the reporting of the impact event be done by the initiator of the voltage reduction? The event should probably be the system-wide voltage reduction and not the Energy Emergency. The reliability objective</p>

Organization	Yes or No	Question 11 Comment
		<p>of this standard is not achieved by NERC knowing of this within 1 hour and NERC does not need to know this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Energy Emergency requiring manual firm load shedding:-See Energy Emergency requiring public appeal for load reduction above regarding requesting Energy Emergency Alerts. If this event is to be reported within a certain time after the event?, at what time is the event marked? Or is it a certain time after the initiation of the shedding of load, if so, shouldn't the reporting of the impact event be done by the initiator of the shedding of the load? If the RC directs a BA to shed load, then the BA directs a DP to do it, then the DP sheds the load, who is the initiator of the load shedding? The event should probably be the firm load shedding and not the Energy Emergency.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Energy Emergency resulting in automatic firm load shedding:Whenever load is automatically shed both the DP and the TOP experience the event. So does the BA and the LSE. This event includes or between DP and TOP.? Is that intentional? Other events in the table do not include either an and or an or.? The entities are separated only by commas. NERC should not require multiple entities to report the same event. See comment for R5 above. If a DP "experiences" an automatic load shedding doesn't the TOP also experience it? Both should not report the same event.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Voltage deviations on BES Facilities:-Should GOs/GOPs be required instead to report to BAs when this condition exists with the BA then reporting to NERC? The idea of a deviation "on BES Facilities" is not clear. On any one Facility? On all Facilities in an area? How wide of an area? Voltage Deviation is not proper noun/name and is not defined in the NERC Glossary. It should not be capitalized. IROL violation: Multiple entities should not report the same event. Please define IROL Violation or use lowercase. It is assumed that IROL Violation means operation outside the IROL for a time greater than IROL TV. Loss of firm load for 15 minutes:-Multiple entities should not report the same event. The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Firm Demand is defined but not Firm load. System separation (islanding):-Multiple entities should not report the same event. A DP separating from the transmission system should not be a reportable event for a DP in and of itself. If it leads to a sufficient loss of load, it is reportable as above.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. The words separation and islanding should not be capitalized. Generation loss:-Should GOs/GOPs be required instead to report to BAs when their generation is lost with the BA then reporting to NERC when the total is 2,000 MW? A loss of generation should be clarified. Is the discovery of damaged equipment in an offline plant which makes the plant unavailable for an extended period of time a loss of generation?-It should be clarified if this event means the concurrent loss of the generation or losing the generation non-concurrently</p>

Organization	Yes or No	Question 11 Comment
		<p>but they are concurrently unavailable. What is the time window for losing the generation? Lost within seconds of each other? Minutes? Hours? Loss of off-site power to a nuclear generating plant (grid supply):-Multiple entities should not report the same event.-?Off? should be lowercase. Transmission loss:-RCs should not be required to report the loss of transmission elements to NERC. A ?loss? of a BES Transmission Element should be clarified. It should be clarified if this event means the concurrent loss of elements or the non-concurrent loss of the elements but they are concurrently unavailable. What is the time window for losing the elements? When elements are lost, it will be difficult to differentiate if they are BES Transmission Elements or not. Alarms don't immediately identify this. It could lead to gross over-reporting if no distinction is made by a TOP and the TOP reports all losses of 3 elements. It may still be over-reporting (from a reasonableness/practicality basis) even if the differentiation could be easily made and only BES Transmission Elements are reported. Threshold for reporting Transmission Loss: As stated, this will require the reporting of almost all transmission outages. This is particularly true taking into consideration the current work of the drafting team to define the Bulk Electric System. The loss of a single 115kV network line could meet the threshold for reporting as the definition of Element includes both the line itself and the circuit breakers. Instead, we recommend the following threshold "Three or more BES Transmission lines." This threshold has consistency with CIP-002-4 and draft PRC-002-2. This threshold also needs additional clarification as to the timeframe involved. Is the intent the reporting of the loss of 3 or more BES Transmission Elements anytime within a 24 hour period or must they be lost simultaneously? Also, we recommend that the three losses be the result of a related event to require reporting. Damage or destruction of BES equipment that i. affects an IROL; ii. significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); or iii. damaged or destroyed due to intentional or unintentional human action (Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly, e.g., removal of grounding straps rendering protective relaying inoperative.): -What is ?BES equipment?? Would an operator know which equipment is BES equipment and which is not or which BES equipment affects an IROL (if we had one) or which does not? It is a judgment call as to whether the effect was significant or not or if it has the potential or not. Multiple entities should not report the same event. Unplanned control center evacuation:-?Control Center? should be lowercase.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Fuel supply emergency: Multiple entities should not report the same event. Should GOs/GOPs be required instead to report to BAs when they have a fuel supply emergency with the BA then reporting to NERC if the situation is projected to require emergency action at the BA level?-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Loss of all monitoring or voice communication capability (affecting a BES control center for ? 30 minutes):-Does this event mean that ALL capability at both the primary and backup control centers or just one? Forced intrusion at a BES facility (report if you cannot reasonably determine likely motivation, i.e., intrusion to steal copper or spray graffiti is not reportable unless it affects (affects ? not effects) the reliability</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>of the BES):-What is a ?BES facility?? It is not clear for the purposes of complying with this standard what it means to affect the reliability of the BES. Deferred for ECMS review and additional comments.Risk to BES equipment (examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment, e.g., flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center, and report of suspicious device near BES equipment.): -In the footnote, delete ?could have? from ??either could have damaged?? Something that could cause evacuation of a control center does not pose a risk to damaging BES equipment. The threshold is ?from a non-environmental physical threat? but the example (toxic cargo) IS an environmental threat.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received. The DSR SDT reviewed the term 'Energy Emergency' and has removed it from Attachment 1.</p>		
<p>City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power</p>	<p>No</p>	<p>The one hour reporting timeline is unrealistic for this event. In general it looks like other events requiring the 1 hour reporting timeline are for event that are ?initiated? by the system operator. (ie load shedding, public load reduction, EEP?). Loss of BES equipment is in general 24 hour reporting timeline. It should be, ?as soon as possible but within 24 hours."</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
<p>Indeck Energy Services</p>	<p>No</p>	<p>Comments were included in previous comments.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
<p>BC Hydro</p>		<p>For the change from 24hr to 1hr reporting for events, 1 hour goes extremely quickly in these types of events and it will be difficult to report anything meaningful. As the RC is kept informed during the event why is the report required within 1hr?</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received. EOP-004-2 is an after the fact reporting Standard. The entity experiencing an event is required to inform their RC per other NERC Standards.</p>		
<p>Brazos Electric Power Cooperative</p>	<p>No</p>	<p>Question applicability to DP.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the</p>		

Organization	Yes or No	Question 11 Comment
<p>ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
<p>Progress Energy</p>	<p>No</p>	<p>Progress Energy appreciates the effort of the Standard Drafting Team, but we do have some issues with the content of Attachment 1. The loss of three Transmission Elements can occur with a single transmission line outage. Progress is concerned that the possible frequency of this type of reporting could be an extreme burden. Under the column "Entity with Reporting Responsibility," why do all related entities have to report the same event? (i.e. do the RC and the TOP in the RC footprint both have to report an event, or is it either/or? The word "Each" implies separate reports. What is the Reliability-based need for both an RC and the BA/TOP/GO within the footprint to file the same report for the same event?) For vertically integrated companies it should be clear that only one report is required per Impact Event that will cover the reporting requirements for all registered entities within that company. The "damage or destruction of BES equipment" footnote contains the language "Significantly affects the reliability margin?". The word significantly should not be used in a Standard because it is subjective. Reliability margin is also undefined. System Operators must be trained on how to comply with the Standard, and thus objective criteria must be developed for reporting. "1 hour after occurrence" places a burden on System Operators for reporting when response to and information gathering dealing with the Impact Event may still be occurring. There is a note that states that the timing guidelines may not be met "under certain conditions?" but then requires a call to both its Regional Entity and notification to NERC. The focus should be on the event response and this type of reporting should occur "within an hour or as soon as practical." It is unclear what the voltage deviations of +-10% based on (i.e. is that +-10% of nominal voltage? This may require new alarm set-points to be placed in service in Energy Management Systems in order for entities to be able to prove in an audit that they reported all occurrences of voltage exceeding the 10% limit for 15 minutes or more. It has been stated by Regional Entity audit and enforcement personnel that attestations cannot be used to "prove the positive.") The word "potential" should be removed from Attachment 1 and from the definition of Impact Event. An event is either an Impact Event or not. If an entity has to evacuate its control center facility temporarily for a small fire, or any other such minor occurrence, then it activates its EOP-008 compliant backup control center, and there is no impact to reliability, then why does there need to be a report generated? The "Forced Intrusion" category is problematic. The footnote 3 states: "Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects (sic) the reliability of the BES)." "Reasonably determine likely motivation" makes this subjective. If someone breaks into a BES substation fence to steal copper, is interrupted and leaves, then entity personnel determine someone tried to break into the substation, but cannot determine why, then this table requires a report to be filed within an hour. It is unclear what the purpose of such a report would be. Progress agrees that multiple reports in a short time across multiple entities may indicate a larger issue.</p>
<p>Response: The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 11 Comment
have been updated per comments received.		
Liberty Electric Power LLC	Yes	A qualified yes here - please clarify footnote 1 to the table. Are the listed qualifications "and" or "or" statements -IOW, if destruction of BES equipment through human error does not have the potential to result in the need for emergency actions, is it still reportable? If a 18-240 KV step-up transformer suffers minor damage because a conservator tank was valved out, is this reportable under this definition?
<p><b>Response: The DSR DT thanks you for your comment.</b> Footnotes have been update to reflect comments received. This proposed Standard is targeted at BES level Thresholds for Reporting as outlined in Attachment 1.</p>		
Ingleside Cogeneration LP	Yes	We believe that there should be close, if not perfect, synchronization between the ERO?s Event Analysis Process and Attachment 1 since they share the same ultimate goal as EOP-004-2 to improve industry awareness and BES reliability.
<p><b>Response: The DSR DT thanks you for your comment.</b> EOP-004-2 is an after the fact reporting Standard and the reports submitted by entities complying with the standard may be used by the NERC Event Analysis Program to review reported events. The Event Analysis Program may change their categories of events at anytime, but revisions to an approved standard must follow the standards development process embodied in the NERC Standard Processes Manual. Despite the differences in process, the DSR SDT is working closely with the Event Analysis Working Group to ensure alignment between the standard and the program to the maximum extent possible.</p>		
Occidental Power Marketing	Yes	There does not appear to be any reportable events for LSEs that do not own, operate, or control BES assets (or assets that directly support the BES) in Attachment 1. This would support removing such entities from the Applicability.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT understands that every LSE may not own or operate BES assets. If of the LSE does not own or operate BES assets, then EOP-004-2 would not be applicable to that LSE. Since CIP-002 and CIP-008 are applicable to LSEs they will be required to be applicable under EOP-004-2 for cyber incidents.</p>		
Farmington Electric Utility System	Yes	
Platte River Power Authority	Yes	
New Harquahala Generating Co.	Yes	
Western Electricity Coordinating	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 11 Comment
Council		
Midwest ISO Standards Collaborators	Yes	
Southern Company	Yes	
SRP	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
American Municipal Power	Yes	

**12. Do you agree with the proposed measures for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of commenters agree with the proposed measures. Since two requirements were removed, the DSR SDT did a complete review of the Requirements and associated Measure and assured that Measurements did not add to any Requirement. The Measures have been rewritten to reflect strict accuracy to each Requirement and provide a minimum measure required for an entity to be compliant.

Organization	Yes or No	Question 12 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	Several of the measures appear to introduce items that are not required by the standard. For instance, R3 requires that a test of the communications process be performed, however Measure 3 indicates that a mock impact event be performed. Measure 4 indicates that personnel be listed in the plan and be trained on the plan, however there is no requirement to include people in the plan or to train them.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Northeast Power Coordinating Council	No	Concerns with M5:a. As suggested in the response to Question 10 above, R5 should be combined with R2; b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to support the type of Impact Event experienced?. Also, the date and time of the Impact Event is provided in the reporting form. Why the need to provide additional evidence on the date and time of the Impact Event?
<p><b>Response:</b> The DSR SDT thanks you for your comment. Requirement 2 has been deleted as requested by the industry. Requirement R5 (now R2) was revised along with the measure:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
stamped transmittal records to show that the event was reported.		
Pacific Northwest Small Public Power Utility Comment Group	No	It is unclear when reporting to the Compliance Enforcement Authority is required. Does the registered entity report initially, and then anytime a change to the plan is made, or a drill is performed. Or is the information only provided following a request of the Compliance Enforcement Authority, and if so what is the acceptable time limit to respond?
<b>Response:</b> The DSR SDT thanks you for your comment. The Measure is designed to inform applicable entities of the minimum acceptable evidence needed to prove compliance with a requirement. The reference to Compliance Enforcement Authority has been removed since it does not assist an entity in the minimum level of evidence needed per the requirement.		
Dominion	No	1) M1 is open ended. Suggest adding ?on request? to the end of the sentence as written; 2) M4 requires evidence of ?when internal personnel were trained; however, Requirement R4 does not require training.
<b>Response:</b> The DSR SDT thanks you for your comment. The Measure is designed to inform applicable entities of the minimum acceptable evidence needed to prove compliance with a requirement. The reference to Compliance Enforcement Authority has been removed since it does not assist an entity in the minimum level of evidence needed per the requirement.		
SPP Standards Review Group	No	The measures are written as if they are adding requirements to the standards. Using wording such as ?shall provide? gives this implication. We would suggest wording such as ?examples of acceptable evidence to demonstrate compliance may be??See Question 6 for comments regarding M1. See Question 8 for comments regarding M3.
<b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.		
Midwest ISO Standards Collaborators	No	We disagree with Measurement 4. It implies that the review must be conducted in person. Why could other means such as a web training or a reminder memo not satisfy the requirement? Because Requirement 1 does not require submittal of the Operating Plan, Operating Process and/or the Operating Procedure, Measurement 1 should only require submittal to the Compliance Enforcement Authority upon its request.
<b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement 4 has been deleted.		
FirstEnergy	No	Measure M4 includes the phrase ?when internal personnel were trained on the responsibilities in the plan? implies the Requirement R4 requires training. R4 is only requiring the review of a document of the necessary

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 12 Comment
		<p>personnel and that the rest of the measure covers the needed evidence for R4. This phrase in the measure should be removed. We suggest the following for M4:M4. Responsible Entities shall provide the materials presented to verify content and the association between the people listed in the plan and those who participated in the review, documentation showing who was present.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement 4 has been deleted.</p>		
SERC OC Standards Review Group	No	<p>The measures should be revised to match the general nature of the comments we have made on each requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
PJM Interconnection LLC	No	<p>1. We disagree with M4 as it seems to indicate that all training needs to be in person and precludes any form of Computer Based Training (CBT). 2. As indicated in 10, R5 is redundant as R2 already required an entity to report any Impact Events by executing/implementing its Impact Event Operating plan. If R5 is to remain as is, then M5 goes beyond the requirement by requiring the entity to produce evidence of compliance for the type of Impact Event experienced. It is not clear as to what additional evidence is needed to support the type of Impact Event experienced?.</p>
<p>The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
We Energies	No	<p>M1 contains a redundancy: It currently reads, "Each Responsible Entity shall provide the current in force Impact Event Operating Plan to the Compliance Enforcement Authority." ("In force" is the same as "current".)M2: Change "Impact Event" to "Impact Event listed in Attachment 1".M3: This is an additional requirement. R3 does not require a mock Impact Event. R3 requires a test of the communicating Operating Process. As stated above, R3 and M3 should be deleted.M4: This is written assuming classroom training. R4 does not require formal training much less classroom training. R4 requires that those (internal) personnel who have responsibilities in the plan review the Impact Event Operating Plan.M5: When we report, how do we show to an auditor that we reported "using the plan"? Delete the reference to "the plan".</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
Compliance & Responsibility Organization	No	See comments set forth in number 2.
Exelon	No	? M1 - Suggest rewording to state "Each Responsible Entity shall provide the current revision of the Impact Event Operating Plan or equivalent implementing process"? M3 ? Need to provide more guidance on evidence of compliance to meet R.3 The DSR SDT needs to provide more guidance on the objectives and format of the drill expected (e.g., table top, simulator, mock drill) and what evidence will be required to illustrate compliance.? M5 - Suggest that the DSR SDT provide a note or provision to allow for the DOE OE-417 reporting form be submitted by the most knowledgeable functional entity (e.g., the TOP or RC) experiencing the event.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
City of Tallahassee (TAL)	No	M3 & M4 should be modified if comments above (#8 and #9) are incorporated.M4 - Providing the ?materials presented? is beyond the scope of compliance. This constitutes a review of the training program which is beyond the scope of the standard. Review of attendance sheets should be sufficient. The personnel will be listed in the Plan/Process/Procedure. Modify M4: Responsible Entities shall provide evidence of those who participated in the review, showing who was present and when internal personnel were trained on their responsibilities in the plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Tenaska	No	The proposed R1 through R4 should be deleted and a revised version of R5 should become R1. The proposed measures for the new R1 should be revised accordingly.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
American Municipal Power	No	M1-M4 should be eliminated and M5 should be revised to incorporate a simplified R5. M5 - Date and time of submitted report
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 12 Comment
Liberty Electric Power LLC	No	Due to disagreement with R3 and R4.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Arkansas Electric Cooperative Corporation	No	We applaud the drafting team's effort in crafting more meaningful measures. However, we have concerns with the measures reading like requirements in stating Responsible Entities "shall" do something. We suggest crafting the measures to provide acceptable, but not all exclusive, forms of evidence by stating something similar to "Acceptable forms of evidence may include??"
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
New Harquahala Generating Co.	No	See R3 comments
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see R3 responses.</p>		
Consumers Energy	No	We understand that DOE is migrating to an on-line reporting facility rather than the email-submitted OE-417. If they do so, Form OE-417 will not be available for providing to NERC, and the reporting specified by EOP-004 will be duplicative of that for DOE. We recommend that NERC, RFC and the DOE work cooperatively to enable a single reporting system in which on-line reports are made available to all appropriate parties.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has been working with the U.S. Department of Energy (DOE) to streamline the reporting process. The DOE Form OE-417 will be accepted at NERC if you are reporting an event to the DOE.</p>		
Independent Electricity System Operator	No	We do not have any issues with Measures M1, M2 and M4, but have a concern with M3 and a couple of concerns with M5:M3: This Measure contains a requirement for the Responsible Entities to conduct a mock Impact Event. We disagree to have this included in the Measure. R3 requires the Responsible Entity to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The Measure should adhere to this condition only. We suggest to change the wording to: The Responsible Entity shall provide evidence that it conducted a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, documentation or a report on an actual Impact Event. M5: a. As

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 12 Comment
		<p>suggested above, R5 should be combined with R2;b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to ?support the type of Impact Event experienced?. Also, the date and time of the Impact Event is provided in the reporting from. Why do we need to provide additional evidence on the date and time of the Impact Event?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement R5 (now R2) was revised along with the measure:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported.</p>		
ISO New England, Inc	No	<p>We do not have any issues with Measures M1, M2 and M4, but have a comment on M3 and a couple of concerns with M5:M3: This Measure contains a requirement for the Responsible Entities to conduct a mock Impact Event. We disagree to have this included in the Measure. R3 requires the Responsible Entity to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The Measure should adhere to this condition only. We suggest to change the wording to:The Responsible Entity shall provide evidence that it conducted a test of it its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, documentation or a report on an actual Impact Event.M5:a. As suggested above, R5 should be combined with R2;b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to ?support the type of Impact Event experienced?. Also, the date and time of the Impact Event is provided in the reporting from. Why do we need to provide additional evidence on the date and time of the Impact Event?c. We disagree with Measurement 4. It implies that the review must be conducted in person. Why couldn't other means such as web training or a reminder memo not satisfy the requirement?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement R5 (now R2) was revised along with the measure:</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
		<p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported.</p>
Calpine Corp	No	<p>Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. The measure for Requirement R5 should focus on the need to report accurately and promptly, not on a Responsible Entity's Operating Plan?. If the Requirements are retained, the measures should state in much greater detail what actions and documentation are required for compliance.</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement R5 (now R2) was revised along with the measure:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported.</p>
CenterPoint Energy	No	<p>M1: CenterPoint Energy recommends that the phrase "current in force" be updated to "current" or "currently effective". Additionally, CenterPoint Energy suggests clarifying M1 by adding "within 30 days upon request", which would be consistent with language found in measures in other standards. The revised measure would read, "Each Responsible Entity shall provide the currently effective Impact Event Operating Plan to the Compliance Enforcement Authority within 30 days upon request." M2: If R2 is deleted (as recommended in response to Question 7), then M2 should be deleted.</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. R2 was deleted along with the measure M2.</p>
ExxonMobil Research and Engineering	No	<p>Measure M3 introduces a pseudo-requirement by implying you are able to reset the testing clock if you implement our Impact Event Operating Plan in response to an Impact Event. This should be covered in Requirement R3. Measure M4 should refer to positions and evidence that people occupying those positions participated in the annual review of the Impact Event Operating Plan. Given the number of individuals involved in operations and the cycle of promotions and reassignments, it's unreasonable to expect an entity</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 12 Comment
		to identify specific individuals in their Impact Event Operating Plan. As the one hour time window is not long enough for entities to report all types of events when responding to the impact the Impact Event had on its facility, Measure M5 should be modified to include voice recordings and log book entries to capture verbal information reported to required parties.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Constellation Power Generation	No	See CPG's earlier comments regarding the Requirements and Measures.
<p><b>Response:</b> The DSR SDT thanks you for your comment. See response to comments on Requirements and Measures.</p>		
Georgia System Operations Corporation	No	There are a lot of inconsistencies between the requirements and the measures. The measures add requirements that are not stated in the requirements. The measures need to be made consistent with the requirements and to not add to them. Also see comments on requirements earlier for language to move from the measures into the requirements. M2: Remove "on its Facilities." The word "its" leads to a lot of confusion regarding who reports what. Attachment 1 should make clear "what" needs to be reported. The entities' operating plan should make it clear as to who should report each "what." Furthermore, not all Impact Events are "on Facilities." M3: Replace "that it conducted a mock Impact Event" with "that it conducted a test of its Operating Process." Delete "The time period between actual and or mock Impact Events shall be no more than 15 months." M4: The measure says that documentation showing when personnel were trained is required. R4 does not require training. The requirement and the measure should be made clear and consistent.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	M3 -The testing of the Plan by drill or mock impact event is unnecessary and burdensome.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The Measure M3 has been revised as follows:  M3. The Responsible Entity shall provide evidence that it conducted a test of the communication process in its Operating Plan events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement. The time period between an actual event or test shall be no more than 15 months. Evidence may include, but is not limited to, operator logs,</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
<p>voice recordings, or dated documentation of a test. (R3)</p> <p>The intent of R3 is to ensure that the communications process of the Operating Plan works when needed. The annual test is not burdensome and an actual event will take the place of the test.</p>		
Farmington Electric Utility System	No	See comments in requirements for R3 and R4
<p><b>Response:</b> The DSR SDT thanks you for your comment. See response to comments on R3 and R4.</p>		
Indeck Energy Services	No	<p>M1 is OK. M2 should be about implementation, not about any particular events--M5 is about events. Implementation would include distribution and training. M3 should be modified to reflect a training review by entities that cannot cause a Reportable Disturbance or reportable DOE OE-417 event and for the others documentation of an actual event (which is not included in the present M3) or a drill or mock event. M4 is OK. M5 should only include the reports submitted and the date of submission. Further evidence of the event is redundant.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Brazos Electric Power Cooperative	No	M2 and M5 appear to duplicate each other.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. R2/M2 have been deleted and R5/M5 is now R2/M2.</p>		
Progress Energy	No	<p>M3 states that ?In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event?? Does this mean that, if an entity experiences an Impact Event that is reportable, then the entity does not have to perform its annual test? If so, this should be made clear in the Requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. That is the intent of the requirement. The Rationale box has been revised to express this intent. The measure now reads:</p> <p>The Responsible Entity shall provide evidence that it conducted a test of the communication process in its Operating Plan for events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement. The time period between an actual event or test shall be no more than 15 months. Evidence may include, but is</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
not limited to, operator logs, voice recordings, or dated documentation of a test. (R3)		
Occidental Power Marketing	Yes	In general, the measures are okay. However, as mentioned above for R3, there needs to be more specificity as to what is acceptable as a "mock Impact Event" for auditing purposes--especially for small entities such as LSEs that do not own, operate, or control BES assets.
<b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.		
SDG&E	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	
Southern Company	Yes	
SRP	Yes	
APX Power Markets	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 12 Comment
USACE	Yes	
Ameren	Yes	
BGE		No position or comments.
Platte River Power Authority	Yes	
Alliant Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

**13. Do you agree with the proposed Violation Risk Factors for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Many stakeholders suggested that the reporting of events after the fact only justified a VRF of Lower for each requirement. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.

Organization	Yes or No	Question 13 Comment
Northeast Power Coordinating Council	No	If R5 is to remain as is, then the VRF should be a Lower, not a Medium. R5 stipulates the form to be used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form does not lead to unreliability.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
Bonneville Power Administration	No	R2, R3 and R4 should be lower VRFs than R5 and R1.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
PSEG Companies	No	If Requirements 1-5 remain intact the Violation Risk Factor should be reduced to a Lower not a Medium since this is an administrative requirement and does not impact the reliability of the BES.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Dominion	No	All the VRFs are "Medium." Since the requirements deal with after-the-fact reporting and the administration of reporting plans, procedures, and processes; all VRFs should be "Lower."
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		<p>the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
Pepco Holdings Inc and Affiliates	No	<p>This standard involves after the fact reporting of events. Other standards deal with the real time notifications. How do the risk factors between the two line up? A VRF of Low would seem appropriate, since a violation would not affect the reliability of the BES.</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
SPP Standards Review Group	No	<p>These are reporting requirements and therefore do not deserve the "medium" VRF. We suggest making the VRFs for all requirements for EOP-004-2 "low."</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		<p>communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
Midwest ISO Standards Collaborators	No	<p>All violation risk factors should be Lower. All requirements are administrative in nature. While they are necessary because a certain amount of regulatory reporting will always be required, a violation will not in any direct or indirect way lead to reliability problem on the Bulk Electric System</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
FirstEnergy	No	<ol style="list-style-type: none"> <li>1. We believe that Requirement 5 does not warrant a “Medium” risk factor. Not using a particular form is strictly administrative in nature and the VRF should be “Low.”</li> <li>2. We believe that Requirement 4 does not warrant a “Medium” risk factor. For example, a simple review of the process does not have the same impact on the Bulk Electric System as the implementation of the Operating Plan per R2. Therefore, we believe R4 is at best a “Low” risk to the BES.</li> </ol>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		<p>events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
SERC OC Standards Review Group	No	How can an after-the-fact report require a VRF greater than low?
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
PJM Interconnection LLC	No	All VRFs should be lower as Requirements 1-5 are all administrative in nature. A violation of any of these requirements does not directly or indirectly affect the reliability of the BES.
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
We Energies	No	All VRFs should be Lower. They are all administrative and will not affect BES Reliability.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
LG&E and KU Energy LLC		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. See response to comments on Question 2.</p>		
Exelon	No	R.4 should be a low risk factor, this is an administrative requirement with no contribution to reliability.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
City of Tallahassee (TAL)	No	R1 is administrative in nature (must have a document) and should be Lower.



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT concurs and has assigned a “lower” VRF for Requirement R1.</p>		
United Illuminating Co	No	R3 should be Low. It is a test of the communication Plan which is use of telephone and email.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
American Municipal Power	No	No, this is not acceptable. Eliminate R1-R4. Change R5 to Lower.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Liberty Electric Power LLC	No	See Q 12.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see response to Question 12.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
Manitoba Hydro	No	Reduce the Long Term Planning items to Lower VRF. The planning items will not have the same impact on the reliability of the system as real time operations.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each Requirement is in the Operations Assessment or Operations Planning time horizon. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Independent Electricity System Operator	No	If R5 were to remain as is, then the VRF should be a Lower, not a Medium since R5 stipulates the form to be used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form does not give rise to unreliability.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
ISO New England, Inc	No	If R5 is to remain as is, then the VRF should be a Lower, not a Medium since R5 stipulates the form to be

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		<p>used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form has no impact on reliability.</p> <p>All violation risk factors should be Lower. All requirements are administrative in nature. While they are necessary because a certain amount of regulatory reporting will always be required, a violation will not in any direct or indirect affect reliability.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Calpine Corp	No	<p>Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. If retained, the violation risk factors should be low for those Requirements, as they all simply support the requirement to actually report correctly stated in Requirement R5.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
ExxonMobil Research and	No	<p>VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
Engineering		appropriate for this requirements of this standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Georgia System Operations Corporation	No	<p>Failing to report to NERC any of many of the listed events does not present a reliability risk. The exception to this would be those threat events where the ES-ISAC needs to be notified. The object of the standard is to prevent or reduce the risk of Cascading. Reporting system situations to appropriate operating entities who can take some mitigating action (e.g., a LSE reporting to its BA or a BA reporting to its RC) and reporting threats to law enforcement officials could prevent or reduce the risk of Cascading but reporting to NERC (except for events where the ES-ISAC needs to know) is unlikely to do that. Reporting of most of the listed events to NERC does not meet the objective of this standard and should be removed from this standard. Such events should be reported to NERC through some other (than a Reliability Standard) requirement for reporting to NERC so that NERC can accomplish its mission of analyzing events. Analyzing events may lead to an understanding that could reduce the future risk of Cascading but analyzing events cannot be performed in time to reduce any impending risks.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.		
Indeck Energy Services	No	If there are any, they should all be Low because this is reporting of historical events. There is no direct effect on BES reliability. Some effect could occur if someone reacts to the reports, but many are concerning unpreventable events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	
Progress Energy	No	
BGE	Yes	No comments.
Platte River Power Authority	Yes	
Alliant Energy	Yes	
Midwest Reliability Organization	Yes	
Southern Company	Yes	
SRP	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 13 Comment
SDG&E	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

**14. Do you agree with the proposed Violation Severity Levels for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Most commenters agreed with the VSLs. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements. The ‘Severe’ rating for excessively long reporting times has been retained as the DSR SDT believes that fairly reflects the definition of ‘Severe’ i.e., The performance or product measured does not substantively meet the intent of the requirement.

Organization	Yes or No	Question 14 Comment
Northeast Power Coordinating Council	No	No major issues with the proposed VSLs. However, because of the preceding comments, want to see the next revision of the draft.
<i>Response:</i> The DSR SDT thanks you for your comment.		
Bonneville Power Administration	No	For R5 VSL's: suggest moving the 1-2 hours down one level to Moderate and move the >2 hours down to High with a range of 2-8 hours. Leave the "Failed to Submit" in the Severe category.
<i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has increased most reporting timeframes to 24 hours. Those that still require 1 hour reporting have been adjusted to better align with the 24 hour VSLs. Namely, taking twice as long to report is a ‘Medium’ VSL. The ‘Severe’ rating for excessively long reporting times has been retained as the DSR SDT believes that fairly reflects the definition of ‘Severe’ i.e., The performance or product measured does not substantively meet the intent of the requirement.		
Western Electricity Coordinating Council		Regarding the proposed VSLs for R3, since communication testing involves multiple parties it would be more appropriate to base severity level on the number of applicable parties which were not tested rather than how long after 15 months it took to do the test. The standard already builds in a 3 month leeway, In reality the way it is written almost guarantees a lower severity level.
<i>Response:</i> The DSR SDT thanks you for your comment. VSLs reflect the degree to which the requirements are met. The DSR SDT envisions that communication testing will include all parties referenced in the entity's operating plan. Failure to test any part of that communication process is a failure of that Part of the requirement.		
Pepco Holdings Inc and Affiliates	No	This standard involves after the fact reporting of events. Other standards deal with the real time notifications. How do the severity level between the two line up? See above VRF comments.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 14 Comment
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the VSLs appropriately align with the NERC Guidelines.</p>		
SPP Standards Review Group	No	<p>Requirement 4: We would suggest the following:Low ? The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 15 calendar months but less than 18 calendar months since the last review.Moderate - The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 18 calendar months but less than 21 calendar months since the last review.High - The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 21 calendar months but less than 24 calendar months since the last review.Severe - The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan within 24 calendar months since the last review.Requirement 5: With our suggested deletion of Requirement 5, we further suggest deleting the VSLs associated with Requirement 5.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2.</p>		
SERC OC Standards Review Group	No	The VSLs should reflect the comments on the requirements above.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements.</p>		
PJM Interconnection LLC	No	VSLs should reflect the comments on the VRFs above.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the VSLs appropriately align with the NERC Guidelines.</p>		
We Energies	No	Change the VRFs as indicated above and the Time Horizons as indicated below.
<p>Response: The DSR SDT thanks you for your comment. Please see responses to those comments.</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p>Response: The DSR SDT thanks you for your comment. Please see responses Question 2.</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 14 Comment
Exelon	No	Suggest rewording the 1 hour reporting for High and Severe to state "communicate or submit" a report within ? depending on the severity of the event, an actual report may not be feasible. Similar to an NRC event report, a provision should be made for verbal notifications in lieu of an actual submitted report. An entity should not be penalized for failing to submit a written report within 1 hour if the communications were completed within the 1 hour time period meeting the intent of the Standard.
<p>Response: The DSR SDT thanks you for your comment. Attachment 1 allows you to provide a verbal report under the conditions you contemplate.</p>		
SDG&E	No	This Reliability Standard provides a list of reporting requirements that are applicable to registered entities, thus it is a paperwork exercise; therefore, SDG&E recommends that none of the requirements should exceed a ?Moderate? Violation Severity Level. Failure on the part of an applicable Registered Entity to provide an event report will have no immediate impact on the Bulk Electric System.
<p>Response: The DSR SDT thanks you for your comment. VSLs describe how fully an entity meets the requirements and are not a measure of severity or impact. These items are captured in the VRFs.</p>		
American Municipal Power		No, this is not acceptable. Eliminate R1-R4 and change R5. Severe: n/aHigh VSL: n/aMedium VSL: No report for a reportable eventLow VSL: Late report for a reportable event
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements.</p>		
Liberty Electric Power LLC	No	See Q 12.
<p>Response: The DSR SDT thanks you for your comment. Please see responses to Question 12.</p>		
Consumers Energy	No	<p>1. In reference to the Impact Event addressing ?Loss of Firm load for greater than or equal to 15 minutes?, this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to ?Within 1 hour after detection of exceeding 15-minute threshold?. Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES.2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting ?Within 1 hour after occurrence</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 14 Comment
		<p>is identified? possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the ?time to submit?.3. Referring to the ?Fuel Supply Emergency? Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has increased almost all reporting timeframe to 24 hours. Also, the fuel supply emergency has been removed from Attachment 1. Reporting period was chosen to meet NERC needs, you may have more restrictive periods for OE-417, but that is outside the jurisdiction of the DSR SDT.</p>		
Calpine Corp	No	<p>Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. If retained, the violation risk factors should be low for those requirements, as they all simply support the requirement to actually report correctly stated in Requirement R5.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements.</p>		
CenterPoint Energy	No	<p>CenterPoint Energy believes that the Severe VSL for R5 (Reporting) in the current draft incorrectly equates 2X reporting with failure to submit a report. CenterPoint Energy believes the VSLs for R5 should all reflect a factor increase in time. For example, the lower VSL should be 1.5X the reporting time frame. The Moderate VSL should be 2x the reporting time frame. The High VSL should be 3x the reporting time frame. The Severe VSL should be failure to report.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements. The 'Severe' rating for excessively long reporting times has been retained as the DSR SDT believes that fairly reflects the definition of 'Severe' i.e., The performance or product measured does not substantively meet the intent of the requirement.</p>		
ExxonMobil Research and Engineering	No	<p>VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more appropriate for the requirements of this standard.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the VSLs and time horizons appropriately align with the requirements and NERC Guidelines. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2)</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 14 Comment
<p>and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Indeck Energy Services	No	<p>There should be only Lower VSL's. This is reporting of historical events and there is no direct effect on BES reliability. How does missing 3 parts of R1 compare to tripping a 4,000 MW generating station because vegetation was not properly managed? Just because there are 4 levels, doesn't mean that all Standards need to use them all. If you step back, and think about causes of cascading outages, reporting events 1 hour or 24 hours later has no significance. There is no direct preventative causation either.</p>
<p>Response: The DSR SDT thanks you for your comment. VSLs describe how fully an entity meets the requirements and are not a measure of severity or impact to the BES. These items are captured in the VRFs.</p>		
Progress Energy	No	<p>Progress disagrees with the High and Severe VSLs listed for R5. If an entity experiences an Impact Event and fails to submit a report within an hour as required, it may be that there are multiple mitigating circumstances. It is not reasonable to require reporting within an hour since identifying a reportable event often takes longer than this time period.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has increased almost all reporting timeframe to 24 hours. Also, VSLs describe how fully an entity meets the requirements and are not a measure of severity or impact to the BES. These items are captured in the VRFs.</p>		
Georgia System Operations Corporation	No	None.
Independent Electricity System Operator		<p>We do not have any major issues with the proposed VSLs. However, in view of our comments on some of the Questions, above, we reserve our comments upon seeing a revised draft.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
ISO New England, Inc		<p>We do not have any major issues with the proposed VSLs. However, in view of our comments on some of the Questions, above, we reserve our comments upon seeing a revised draft.</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 14 Comment
<a href="#">Response: The DSR SDT thanks you for your comment.</a>		
Midwest Reliability Organization	Yes	
Midwest ISO Standards Collaborators	Yes	
Southern Company	Yes	
SRP	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 14 Comment
BGE	Yes	No comments.
Alliant Energy	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	

**15. Do you agree with the proposed Time Horizons for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Many stakeholders suggested that the Time Horizons for this standard should be **Operations Assessment or Operations Planning rather than Long Term Planning. The DSR SDT agrees.** The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Assessment, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 has been changed to Operations Planning.

Organization	Yes or No	Question 15 Comment
Northeast Power Coordinating Council	No	For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. Consistent with other plans such as system restoration plans which need to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. Suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Assessment, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 has been changed to Operations Planning.</p>		
Bonneville Power Administration	No	Depends on the answer to #7. If implementation means a signed and valid Plan, then it should be with Long Term. If reporting the events, then it should be Real-Time/Same Day Operations.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted the separate requirement to 'implement the plan'. The reporting obligation is now R2 with a time horizon of Operations Assessment, which is defined as 'follow-up evaluations and reporting of real time operations'.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

SPP Standards Review Group	No	Based on our previous comments in response to Question 11, we feel that the Time Horizon for R2 should be lengthened. Assigning it a Real-time Operations and Same ?day Operations timeframe has too much of an impact on real-time operations. Pushing it back will allow support personnel to do the after-the-fact reporting and keep this burden off of the operators.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The reporting obligation is now R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'.</p>		
Midwest ISO Standards Collaborators	No	R2 and R5 should be Operations Assessment since it deals with after the fact reporting. R3 should included Operations Assessment since an actual event could be used as the test.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
SERC OC Standards Review Group	No	R2 and R5 should be in the Operations Assessment time horizon.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
PJM Interconnection LLC	No	R2 and R5 should be in Operations Assessment Time Horizon as they deal with ?after-the-fact? reporting.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
We Energies	No	R2 and R5 should be Operations Assessment.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Consumers Energy	No	<p>1. In reference to the Impact Event addressing 'Loss of Firm load for greater than or equal to 15 minutes?', this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to 'Within 1 hour after detection of exceeding 15-minute threshold?'. Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES.2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting 'Within 1 hour after occurrence is identified?' possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the 'time to submit?'.3. Referring to the 'Fuel Supply Emergency? Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has increased almost all reporting timeframe to 24 hours. Also, the fuel supply emergency has been removed from Attachment 1. Reporting period was chosen to meet NERC needs, you may have more restrictive periods for OE-417, but that is outside the jurisdiction of the DSR SDT.</p>		
Independent Electricity System Operator	No	<p>For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. And consistent with other plans such as system restoration plan which needs to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. We suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

ISO New England, Inc	No	For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. And consistent with other plans such as system restoration plan which needs to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. We suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning. The Time Horizon for R2 and R5 should be changed to Operations Assessment since they both deal with after the fact reporting.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
ExxonMobil Research and Engineering	No	VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more appropriate for this requirements of this standard.
<p><i>Response:</i> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p> <p>The DSR SDT believe the VSLs and revised time horizons appropriately align.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	Why shorten the normal process?
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has revised most of the reporting timelines 24 hours.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Indeck Energy Services	No	These requirements have no time horizon. There about history and not about the future.
<p><i>Response:</i> The DSR SDT thanks you for your comment. All NERC standards must have a time horizon associated with each requirement. Time horizons are used as a factor in determining size of a sanction.</p>		
American Municipal Power	No	
USACE	No	
Pepco Holdings Inc and Affiliates	Yes	However, do they line up with the corresponding real time reporting procedures as mentioned above, #13 and #14?
<p><i>Response:</i> The DSR DT thanks you for your comment. Please see responses to comments #13 and #14. Since the time for reporting impact events is no more than 24 hours, the time horizon has been revised to Operations Planning.</p>		
Midwest Reliability Organization	Yes	
PPL Supply	Yes	
Dominion	Yes	
FirstEnergy	Yes	
Southern Company	Yes	
SRP	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
BGE		No position or comments.
Alliant Energy	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

Georgia System Operations Corporation	Yes	None.
---------------------------------------	-----	-------

**16. Do you agree with the proposed Implementation Plan for EOP-004-2? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of commenters agreed with the Implementation Plan. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with. Consequently the effective date remains as first calendar day of the third calendar quarter following the regulatory approval/BOT adoption as applicable.

Organization	Yes or No	Question 16 Comment
Pepco Holdings Inc and Affiliates	No	The proposed time line is too short. It is easy to revise procedures. However developing training and integrating the training into the schedule takes time. Shorter time frame takes away adequate time to integrate into the training plan and disrupts operator schedules. Since notifications already exist and after the fact reporting does not impact BES reliability, why the need to expedite? There are many other training activities that must be coordinated with this.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
FirstEnergy	No	We believe the previous proposal for a 12 month implementation was more appropriate and suggest the team revert back to that timeframe.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Southern Company	No	The implementation time should be 12 months after approval regardless of the elapsed time taken to get the standard approved.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Exelon	No	The DSR SDT reduced the implementation from one year to between six and nine months based on the revised standard requirements. Exelon disagrees with the proposed shortened implementation timeframe. The current revision to EOP-004 still requires an entity to generate, implement and provide any necessary training for the "Impact Event Operating Plan" by a registered entity. Commenters previously supported a one year minimum; but the requirements for implementation have not changed measurably - six to nine months is not adequate to implement as written.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
SDG&E	No	SDG&E recommends a 9 month minimum timeframe for implementation.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
United Illuminating Co	No	The SDT should be specific that on the effective date an Entity will have the Operating documented and approved. The SDT should be specific that the first simulation is required to occur 15 months following the effective date. The SDT should be specific that the first annual review shall occur within 15 months after the effective date.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
American Electric Power	No	With the scope of applicable functions expanding, more time will be required to develop broader processes and training. This will need to be extended for 18 months to get the process implemented and everyone trained.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
CenterPoint Energy	No	CenterPoint Energy prefers the previously accepted timeline of 1 year.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Georgia System Operations Corporation	No	There is nothing about the revisions that were made to the requirements that shortens the time needed by the industry to get prepared for this revision. The removal of requirements for NERC does not shorten the requirements for the industry. Eighteen months (or 12 months minimum) should be allotted to prepare for this revision.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Brazos Electric Power Cooperative	No	A one year implementation is needed to develop and implement formal documents to meet requirements.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	The implementation Plan was to move up the timeline and we do not see why this needs to be pushed forward on a shortened timeline. It should remain at the one year implementation schedule especially if annual exercises are not removed from the standard requirements as this take some time to prepare.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
ExxonMobil Research and Engineering		Recommend 4th calendar quarter instead of 3rd.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Consumers Energy	No	
Dominion	Yes	Dominion agrees with the Implementation Plan; however, notes that the title for EOP-004-2 is inconsistent with the actual proposed standard.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.

Farmington Electric Utility System	Yes	Nine months would be preferred
------------------------------------	-----	--------------------------------

Response: The DSR SDT thanks you for your comment. The majority of stakeholders agree with the proposed implementation plan and it will remain unchanged.

Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
PPL Supply	Yes	
SPP Standards Review Group	Yes	
Midwest ISO Standards Collaborators	Yes	
SERC OC Standards Review Group	Yes	
PJM Interconnection LLC	Yes	
SRP	Yes	
We Energies	Yes	
Compliance & Responsibility Organization	Yes	
City of Tallahassee (TAL)	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
American Municipal Power	Yes	
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
ISO New England, Inc	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
PPL Electric Utilities	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	
Indeck Energy Services	Yes	

17. If you have any other comments you have not already provided in response to the questions above, please provide them here.

**Summary Consideration:** The majority of comments received relate to Attachment 1 and the Flowchart in the background section. The DSR SDT has made conforming revisions to each based on the comments received. The Flowchart was updated to remove references to sabotage and replaced with “Criminal act invoking federal jurisdiction”. In response to the comments received, the SDT has made numerous enhancements to Attachment 1. These revisions include:

- Added new column “Submit Attachment 2 or DOE OE-417 Report to:” which references Part 1.3 and provide the time required to submit the report.
- Combined Parts A and B into one table and reorganized it so that the events are listed in order of reporting times (either one hour or 24 hours)
- Removed references to “Impact Event” and replaced with the specific language for the event type in the “Entity with Reporting Responsibility”. For example, replaced “Impact Event” with “automatic load shedding”.

The ERO and the RE were added as applicable entities to reflect CIP-002 applicability to this standard.

Organization	Yes or No	Question 17 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation		In the discussion and related flowchart described as "A Reporting Process Solution - EOP-004," the discussion suggests that Industry should notify the state law enforcement agency and then allow the state agency to coordinate with local law enforcement. It has been our experience that we receive very good response from local law enforcement and they have existing processes to notify state or federal agencies as necessary. It appears the recommendation is to bypass the local law enforcement, but it is not clear that representatives from state or local law enforcement were included in this discussion (see proposal discussed with "FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair"). It would be helpful to see some additional clarification to understand why the state agency was chosen over local or federal agencies. Finally, we would like to express our gratitude to the DSR SDT for their hard work in making improvements to the NERC standards for event reporting.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 17 Comment
<p><b>Response:</b> The DSR DT thanks you for your comment. The Flowchart has been updated. The DSR SDT has reviewed all comments and believes it is the responsibility of the Reporting Entity to contact the appropriate law enforcement officials.</p>		
Bonneville Power Administration		<p>Work needed on Part A Damage or Destruction of BES equipment. The Note 1 is OK, but the Threshold doesn't match well. If a PCB is damaged by lightning or an earthquake, Note 1 (human action) doesn't require Reporting (proper interpretation), but the Threshold still requires "equipment damage."</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 has been updated concerning Destruction of BES equipment and the associated footnote has been revised.</p>		
Midwest Reliability Organization		<p>On the Impact Reporting Form, number 7,8,9,10, and 11 have an astrict (*) but nothing describes what the astrict means. Recommend a foot note be added to state: * If applicable to the reported Impact Event.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1, Part B has been updated to reflect these noted changes.</p>		
Western Electricity Coordinating Council		<p>Actual Reliability Impact Table comments: Note that per the NERC glossary "Energy Emergency" only is defined for an LSE. Energy Emergency is the precursor term in the first three lines. Thus logically an LSE is the only entity which would be initiating the event and responsible for reporting for first three items. We don't believe that is the intent. We suggest you consider just eliminating ?Energy Emergency? and going with: ? Public appeal for load reduction? system-wide voltage reduction? manual firm load shedding For Loss of Off site power at Nuc Station is reporting really expected of each of the entities listed? (lots of reports) We suggest you consider just the Nuclear GOP and perhaps the associated TOP. Perhaps you could use the CIP approach as in the next two rows and say Applicable GOP and Transmission Entities under NUC-001-2 Potential Reliability Impact Table Comments: For Fuel Supply Emergency, Forced Intrusion, Risk to BES Equipment, Cyber Security Incident where owner/operator are both listed (GO/GOP or TO/TOP) could consider perhaps reporting to be assigned to only one rather than both.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has removed the use of "Energy Emergency" and has updated Loss of offsite power to a nuclear generating plant within Attachment 1. Fuel Supply emergency has been removed from Attachment 1 per comments received. The entire Attachment 1 has been updated per comments received.</p>		
Pacific Northwest Small Public Power Utility Comment Group		<p>All five requirements refer to Attachment 1 Part A either directly, or indirectly by referring to R1 plans. Attachment 1 Part A, though, only provides the thresholds required for reporting (R5). No thresholds are provided for planning (R1) or the requirements referencing the plan (R2-R4). Strictly interpreted, an entity would be required to plan for any amount of firm load loss exceeding 15 minutes (for example), implement the</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
		<p>plan for any amount and then report only those events that exceeded the applicable 200 or 300 MW level. An entity that had a peak load of less than 200 MW would still need to meet R1-R4 regarding load loss. We believe the SDT intended to use common thresholds for all the requirements. Suggest relabeling the Attachment 1 Part A column header from "Threshold for Reporting" to "Threshold." We also fail to see how an entity's size in MWh affects the threshold for reporting firm load loss.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has revised each Requirement and Attachment 1. There are other events within Attachment 1 that a responsible entity will be required to report.</p>		
Dominion		<p>The following comments are provided on the Reporting Hierarchy for Impact Events EOP-004-2: 1) A reference to sabotage still exists in a "decision block"; 2) The "entry block" only specifies "actual Impact Events" and does not address "potential"; 3) Hierarchy is misspelled in the title. Attachment 2: Impact Event Reporting Form; in questions 7, 8, 9, 10, 11 what is the purpose of the *(asterisk) behind each Task that is named?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The Flowchart has been updated based on comments received. Attachment 2 has been updated to reflect comments received.</p>		
Pepco Holdings Inc and Affiliates		<p>IRO-000-1, Sec D1.5 and TOP-007, Sec D1.1 there are "after the fact" reporting requirements for IROL violations. Since IROL violations are included in this standard, should those standards be modified? Should the standard include a specific statement that this standard deals only with after the fact and other standards deal with real time reporting? Since this standard deals with after the fact reporting, consideration should be given to extending the time to report as defined in Attachment 1. One hour does not seem to be reasonable.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed TOP-007 and note that the 72 hour issue is not defined within a Requirement. This issue has been forwarded to the "NERC Issues Data base." Attachment 1 has been updated to reflect this event to 24 hours per comments received.</p>		
SPP Standards Review Group		<p>In Attachment 2 just before the table, the statement is made that "NERC will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report." But the last sentence in the Guideline and Technical Basis white paper, it is stated that "For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report." These are in conflict with each other. Which is correct? We prefer the former over the latter. In Attachment 2 in Tasks 7-11 an asterisk appears in those tasks. To what does this asterisk refer?</p>

Organization	Yes or No	Question 17 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT's White Paper was the initial road map for the SDT to follow. The DSR SDT has proposed allowing entities to use the DOE Form OE-417 to report events listed within Attachment 1.</p>		
Midwest ISO Standards Collaborators		<p>We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing with the event. This will be particularly difficult when support personnel are not present such as during nights, holidays, and weekends.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 has been updated per comments received.</p>		
FirstEnergy		<p>FE offers the following additional comments and suggestions:</p> <ol style="list-style-type: none"> <li>1. In the Background section of EOP-004-2, on page 6 under Stakeholders in the Reporting Process, we suggest adding "Regional Entity?" and "Nuclear Regulatory Commission?".</li> <li>2. The DSR SDT makes reference to comments that Exelon provided that suggested adopting the NRC definition of "sabotage." We feel the comment made by Exelon in their previous submittal was to ensure that the DSR SDT included the Nuclear Regulatory Commission (NRC) as a key Stakeholder in the Reporting Process and FE agrees with this suggestion. Nuclear generator operators already have specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(s)(xi). We ask that the DSR SDT contact the NRC about this project to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. We believe this is a similar situation as what was recently resolved between NERC and the NRC concerning the applicability of CIPs 002 &amp; 009 for nuclear plants. Each nuclear generating site licensee must have an NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan (E-Plan). We ask that the proposed "Reporting Hierarchy for Impact Event EOP-004-2," flow chart be coordinated with the NRC to ensure it does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans.</li> </ol>
<p><b>Response: The DSR DT thanks you for your comment.</b> 1. We have added these as requested. 2. The NRC was added to the list on page 6 as requested. The events in Attachment 1 that are applicable to nuclear plants are: Generation loss (&gt;1,000 MW WECC, &gt;2,000 MW Elsewhere); Destruction of BES Equipment; Damage or destruction of Critical Asset per CIP-002; Damage or destruction of a Critical Cyber Asset per CIP-002; Forced Intrusion; Risk to BES Equipment; and Detection of a Reportable Cyber Security incident. Two of these events are addressed in the situation that you mention above (CIP-002). The other events should be reported to both the NRC and ERO if they occur. These are considered to be sabotage type events.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
SERC OC Standards Review Group		In Attachment 1, the reporting timeline should be no less than the end of the next business day for after-the-fact reporting of events. If reporting in a time frame less than this is required for reliability, the groups or organizations receiving the reports should be included in the functional model. The emphasis should be on giving the operators the time to respond to events and not to reporting requirements. The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers.
<p><b>Response:</b> The DSR DT thanks you for your comment. Attachment 1 has been updated to reflect comments received. Many of the reporting time frames have been revised to 24 hours.</p>		
PJM Interconnection LLC		In the Compliance Enforcement Authority Section on Page 11, the second bullet says ?If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement?. We are not sure what this exactly implies or means. Additional clarification is required.
<p><b>Response:</b> The DSR DT thanks you for your comment. The statement that PJM is referring to applies to Regional Entities that also have a functional model obligation.</p>		
Southern Company		Need guidance for incorporating disturbance reporting that is in CIP-008.
<p><b>Response:</b> The DSR DT thanks you for your comment. EOP-004-2 is the reporting vehicle for CIP-008. CIP-008-4, Requirement 1, Part 1,3 will be retired upon approval of EOP-004-2.</p>		
We Energies		Attachment 2: What do the asterisks refer to? I didn't see a comment or description related to them.#7 & #10: What is ?tripped?? Automatic or manual or both.#13: This report has no Part 1.Flowchart: By the flowchart, the only time an OE-417 is filed is when I do not need to contact Law Enforcement. The Reporting Hierarchy flow chart should be modified. In the lower right corner it indicates that if sabotage is not confirmed, the state law enforcement agency investigates. Law enforcement agencies will not investigate an incident that is not a crime. Note too that state law enforcement agencies do not even investigate these kinds of events unless and until requested by local law enforcement. The local law enforcement agency always has initial jurisdiction until surrendered or seized by a superior agency's authority. Evidence Retention is incomplete. From the NERC Standards Process Manual: ?Evidence Retention: Identification, for each requirement in the standard, of the entity that is responsible for retaining evidence to demonstrate compliance, and the duration for retention of that evidence.?

Organization	Yes or No	Question 17 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 and Attachment 2 have been updated per comments received. The Flowchart has been updated per your comment.</p>		
<p>Compliance &amp; Responsibility Organization</p>		<p>Nuclear power plants (a need for a revised approach)With respect to sabotage, damage or destruction of BES equipment, damage or destruction of a Critical Asset, damage or destruction of a Critical Cyber Asset, forced intrusion, etc., nuclear plants already have a responsibility to report the events to the FBI and the Nuclear Regulatory Commission (NRC). Performing another report to NERC, with potentially different requirements, within 60 minutes of an event does not seem necessary or practical. It would also be difficult, during an event, to report to external organizations, including but not limited to the Responsible Entities? Reliability Coordinator, NERC, Responsible Entities? Regional Entity, Law Enforcement, and Governmental or Provincial Agencies when operations personnel are pre-occupied with an abnormal or emergency situation. Further, nuclear plants already have an obligation to report the loss of off site power to NRC. Similarly, now that cyber assets will be regulated by the NRC, these reporting requirements should not be applicable to a nuclear power plant. Thus, there is a need to exempt nuclear power plants from these requirements or provide more flexibility to such plants, given its pre-existing NRC reporting requirements.Attachment 1. There is no explanation for why a report must be submitted within one hour of an event. As stated with respect to nuclear, an entity should not be prioritizing between stabilizing the system and reporting. One approach that would help balance conflicting priorities is to start the time frame after ?all is clear.? Another approach could involve the use of target times, with an allowance for exceptions during emergencies or situations in which it is impracticable. Another alternative is to have two times: an earlier ?target reporting time? and second later ?mandatory reporting time.? Further, the current wording suggests that a generator owner or generator operator will be able to determine the impact or potential impact on the BES. This is not realistic, given that impacts to the BES are generally only understood at a transmission operator or reliability coordinator level. Thus, the concept of relying on generators to determine impacts on the BES needs to be eliminated.Also, as written, for a generator, Attachment 1 appears to require a report when a lightning arrestor fails at a Critical Asset. NextEra cannot see any justification for reporting such an event, and this is another reason why Attachment 1 needs more review and revision prior to the next draft of EOP-004-2. This one reason why NextEra has suggested a materiality test for reporting in a definition of Attempted or Actual Sabotage.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 has been updated per comments received. Any NRC requirements or comments fall outside the scope of this project.</p>		
<p>Exelon</p>		<p>The DSR SDT makes reference to comments that were previously provided that suggested adopting the NRC definition of "sabotage." Respectfully, this commenter believes the DSR SDT did not understand the intent of the original comment. The comment made by Exelon in the October 15, 2009 submittal was to ensure that the DSR SDT made an effort to include the Nuclear Regulatory Commission (NRC) as a key Stakeholder in</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
		<p>the Reporting Process and to consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator. Depending on the event, a nuclear generator operator (NRC licensee) also has specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72, "Immediate notification requirements for operating nuclear power reactors," paragraph (b)(2)(xi). The one hour notification requirement for an intrusion event would also meet an emergency event classification at a nuclear power plant. If an operations crew is responsible for the one hour notification and if separate notifications must be completed within the Emergency Plan event response, then an evaluation in accordance with 10 CFR 50.54, "Conditions of licensees," paragraph (q), would need to be performed to ensure that this notification requirement would not impact the ability to implement the Emergency Plan. At a minimum the DSR SDT should communicate this project to the NRC to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. Note that existing reporting/communication requirements are already established with the FBI, DHS, NORAD, FAA, State Police, LLEA and the NRC depending on the event. There are existing nuclear plant specific memorandums of understanding between the NRC and the FBI and each nuclear generating site licensee must have a NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan. The proposed "Reporting Hierarchy for Impact Event EOP-004-2," needs to be communicated and coordinated with the NRC to ensure that the flow chart does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans. Propose allowing for verbal reporting via telephone, for 1 hr. reporting with a follow up using the forms. With the revised standard EOP-004-2 it eliminates the #8; loss of electric service &gt;= 50K, however, that requirement is still required for the DOE-OE-417 form. The question is do we still have to send it to NERC / Region if NERC/ Region does not specifically still have that as a requirement? Also, with that requirement on the current EOP-004-1 it says that schedule 1 has to be filled out within 1 hour? This does not coincide with DOE-OE-417 form. The bottom line, it looks like there is inconsistency as to what is reportable per EOP-004-2 and DOE-OE-417 form, some of the items are redundant, some are not, but better guidance is needed as to which form to use when. The SDT should have a Webinar with the industry to create an understanding as to who is responsible to report what and at what time.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The NRC issues falls outside the scope of this project</p>		
City of Tallahassee (TAL)		Attachment 2 (Impact Event Reporting Form) items 8, 9, 10, and 11 have an asterisk but no identification as to what the asterisks refer to.
<p><b>Response:</b> The DSR DT thanks you for your comment. The asterisk was addressed at the bottom of the second page of the form. Attachment 2 has been</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
updated to align with the types of events that are to be reported.		
APX Power Markets		The reporting of Impact Events needs to be clear spelled out and if moving some of that to State Agencies it needs to be consistent in all States at the same time and which State it should be reported to. We have a 24-hour Desk in one state that handles facilities in many other States. If there is an Impact Event that needs to be reported, where is that report sent to. The State the facility resides in or the State where our 24-hour Desk resides in.
<b>Response:</b> The DSR DT thanks you for your comment. Attachment 1 has been updated per comments received and a new column has been added to reflect who the impacted entity is required to report to.		
Arkansas Electric Cooperative Corporation		We appreciate the added context through the use of extended background information, rationale statements, and corresponding guideline and hope this context will remain in line with the Standards through the ballot and approval process. We have a few suggestions and questions related to this context. Our comments for this question relate to the contextual information. First of all, in the diagram on page 8, we suggest the appropriate question to ask is "Is event associated with potential criminal activity?" rather than "Report to Law Enforcement?? Also, it would be helpful to make clear the communication flow associated with the State Agency is the responsibility of the State Agency and not the Responsible Entity. This could be shown with a different colored background that calls this process out separately. In the rationale box for R3, it states "The DSR SDT intends?? We propose this should read similar to "The objective of this requirement is?? Overall, we suggest the SDT review the guidance document to make sure any changes made to the requirements are consistent with the guidance.
<b>Response:</b> The DSR DT thanks you for your comment. The flowchart has been updated per comments received. The Rationale box will be removed upon this Standard being Filled for approval.		
American Electric Power		We still do not agree that LSE, TSP and IA should be included in the applicability of this standard. Having processes to report to local or federal law enforcement agencies is ?legislating the obvious?. The focus on this standard should only be on Impact Event reporting to reliability entities.
<b>Response:</b> The DSR DT thanks you for your comment. Attachment 1 has been reviewed and updated. The LSE, TSP, and IA are required under the CIP Standards and Attachment 1 is based on reporting per the CIP requirements.		
Consumers Energy		1. We appreciate the aggregation of redundant standards on this subject, but have some concerns about the content of the aggregated standard as listed below and in reference to previous questions on this comment form.2. It is not clear whether an event that meets OE-417 reporting criteria but is not defined within EOP-

Organization	Yes or No	Question 17 Comment
		<p>004-2 is an Impact Event; for example, "loss of 50,000 or more customers for 1 hour or more" is required to be reported to DOE as a OE-417 type 11 event but it is not clear whether EOP-004-2 requires that such events be also reported to NERC. The "Reporting Hierarchy" flow chart seems to suggest that any OE-417 must still be filed with NERC/RE. If the flow chart is not consistent with the intent of the Requirements, it must be clarified.3. NERC implies active involvement of law enforcement. This assumes that law enforcement has the resources to be involved in an Impact Event investigation and fulfill the standard reporting requirements. This is an unrealistic expectation as we have experienced first-hand, a lack of response by law enforcement agencies as their resources shrink due to economic issues. Additionally, NERC is asking that we place credence in law enforcement, on our behalf, to make a definitive decision about the reporting of events. Refer to page 6 of EOP-004-2 under "Law Enforcement Reporting": "Entities rely upon law enforcement agencies to respond and investigate those Impact Events which have the potential of wider area affect?" In many cases, the internal security function must work with system operations personnel to thoroughly understand the system and the effects of certain events. It is unrealistic to think law enforcement would be in a position to make BES decisions within the timeframe given without having system operations experience. It is our experience that external agencies do not understand the integration / inter-connectivity, resiliency, or implications of our energy infrastructure.4. Within Michigan, a "Michigan Fusion Center: Michigan Intelligence Operations Center (MIOC)" has been established. - Today, we share information such as substation issues and identity theft (not internal issues) to the MIOC. The MIOC is trending incidents on critical infrastructure assets and sectors around the state. The private sector is encouraged to report to the Fusion Center. If NERC is collecting this type of information for future studies and trending / analysis, they should coordinate with each state's Fusion Center.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has reviewed and updated the Requirements per the comments received. Attachment 1 has been updated and the team has an additional column to reflect where a report should be sent. EOP-004-2 does not define what "law enforcement" is and that will be left up to each entity.</p>		
Ameren		<p>The following is a list of our greatest concerns. (1) We are concerned about the lack of definitions and use of critical non-capitalized terms. As an example, there is a reportable Impact Event if there is a +/- 10% Voltage Deviation for 15 minutes or more on BES Facilities. As a first example, why is the term Voltage Deviation capitalized when it is not in the NERC Glossary and not proposed to be added? Where is the deviation measured - at any BES metering device? What is the deviation to be reported - the nominal voltage? the high-side of the Voltage Schedule? the low-side of the Voltage Schedule? the generator terminals? when a unit is starting up? All of these are possible interpretations, but &lt; 1% of them would ever result in a Cascading outage - which is the reliability objective of this Standard. A second example is a Generation loss. The threshold for reporting is 2,000 MW, or more, for the Eastern or Western Interconnection. Is this simultaneous loss of capacity over the entire Interconnection? Or, cumulative loss within 1 hour? Or, cumulative loss within 24 hours? How many individual GOPs have responsibility for &gt; 2,000 MW? It seems</p>

Organization	Yes or No	Question 17 Comment
		<p>this would more effectively apply only to an RC and/or BA. The likelihood that one GOP would lose that much generation at once is probably remote. A third example would be the damage or destruction of BES equipment event. The term "equipment" was left lower case with a footnote explanation that includes "?due to intentional or unintentional human action?." This is likely to require the determination of intent by the human involved, which will almost certainly impossible to determine within the 1 hour reporting time. Also, what is the definition of the terms "damage" and "destruction"? Once again, if the reliability intent is to ONLY report Events that have a likely chance of leading to Cascading, this will greatly reduce the potentially enormous reporting burden. that could result without this type of clarification. (2) Without a very thorough understanding of the definitions of the terms requiring reporting, the 1 hour reporting constraint on most events will likely require that we frequently overreport events to minimize any chance of non-compliance. A webinar explaining expected reporting requirements would very useful and valuable. It is also unclear why so many Impact Events require such a short reporting time period. There will almost certainly be many times at 2:00 AM on a weekend when experts and the appropriate personnel will be available to quickly analyze an event and decide, within 1 hour, if a report is necessary. (3) Have all the new Impact Event reporting requirements been checked against reporting requirements from other Standards? For example, the Voltage Deviation Event would appear to potentially overlap/conflict with instructions from a TOP for VAR-002 compliance. Since VAR-002-2 is now in draft, has the SDT worked with that Team to determine if the requirements dovetail?</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the Requirements within EOP-004-2 and both Attachments 1 and 2 per comments received. Many of the reporting time frames have been extended to 24 hours per comments received. Voltage deviation is no longer capitalized. All event types are not intended to be new defined terms for the NERC Glossary and have been revised to lower case words. The reporting of voltage deviations is no longer applicable to the GOP which obviates the need to coordinate with the VAR-002 standard drafting team.</p>		
ISO New England, Inc		<p>Under the ?Law Enforcement Reporting? it is stated ?The Standard is intended to reduce the risk of Cascading involving Impact Events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.? We question whether a reporting standard can ?reduce the risk of cascading? and wonder if the reference to the threat ?around them? refers to law enforcement? We would expect that the appropriate operating personnel are the only entities that would be able to mitigate the potential risk to the BES.As it currently stands there is a potential duplication between the reporting requirements under EOP-004-2 (i.e. Attachment 2 Form) and the ERO Event Analysis Process that is undergoing field test (i.e. Event Report Form). This will result in entities (potentially multiple) reporting same event under two separate processes using two very similar forms. Is this the intent or will information requirements be coordinated further prior to adoption in order to meet the declared objective that the impact event reporting under EOP-004 be ?the starting vehicle for any required Event Analysis within the NERC Event Analysis Program?</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
<p><b>Response:</b> The DSR DT thanks you for your comment. The Background section was provided to assist entities in understanding the DSR SDT's process for updating CIP-001 and EOP-004, only.</p>		
Calpine Corp		<p>Focusing on reporting of actual disturbance events as listed in Attachment 1 based on potential or actual impact to the Bulk Electric System will provide maximum benefit to system reliability without adding needless levels of new documentation generated to demonstrate compliance. Absent significant evidence of systemic problems in the industry with past reporting attributable to causes other than a lack of clear guidance on the types events that require reporting, the proposed Standard should focus on the single issue of correct reporting, without attempting to micromanage how Entities internally manage such reporting.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received.</p>		
BGE		<p>Please provide a Mapping Document which shows where the four CIP-001 requirements map to in the new EOP-004-2, and note if any of the CIP-001 requirements have been eliminated. A Mapping Document was provided during the first Comment Period, but not during the second Comment Period. A Mapping Document will be very helpful to companies in aligning standard owners in reviewing this proposal and in transitioning compliance programs when the revised standard is approved.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has a current Mapping Document and it will be updated to reflect the changes that the DSR SDT has made to EOP-004-2. This Mapping document will be posted with the standard when it is posted for comment and ballot.</p>		
CenterPoint Energy		<p>CenterPoint Energy believes the flowchart found on page 8 identifying the reporting hierarchy for EOP-004 is helpful. CenterPoint Energy believes the DOE reporting items should also be included on the right side of the chart. Some of the issues with CIP-001 were a result of law enforcement's preference and procedures for notification. Law enforcement's preferences and procedures should be considered for this draft. (Reference: <a href="http://www.fbi.gov/contact-us/when">http://www.fbi.gov/contact-us/when</a>)</p>
<ul style="list-style-type: none"> <li><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the flowchart and a current Mapping Document and it will be updated to reflect the changes that the DSR SDT has made to EOP-004-2. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading "Law Enforcement Reporting": "These are the types of events that should be reported to law enforcement." The entire paragraph is:  "The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact</li> </ul>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 17 Comment
<p>a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
PPL Electric Utilities		<p>We thank the SDT for addressing so many Industry concerns with the 2010 draft of EOP-004-2. We feel the current draft version of EOP-004-2 is a significant improvement over current EOP-004-1 and CIP-001-1 standard and the previous draft. Thank you for your time.</p>
<p><b>Response:</b> Thank you for your comment.</p>		
Occidental Power Marketing		<p>Occidental Power Marketing appreciates the extensive work accomplished by the SDT and their responsiveness to comments. Also, the presentation of this draft with its extensive explanation of the SDT's considerations during development of the draft were very helpful in preparing our comments.</p>
<p><b>Response:</b> Thank you for your comment.</p>		
Constellation Power Generation		<p>CPG has the following comments regarding Attachment 2: Generally, this attachment is inadequate for all events. The real-life experience with the recent SW cold snap demonstrated that the questions inadequately capture what may be of greatest concern in the situation. Question 4 ? this question is vague. It should be removed. Question 7 ? the role of generation in an event may not always be related to a trip. As experienced with the recent SW cold snap, this question may inadequately capture information relevant to the situation at hand. The drafting team should reassess how best to gather information relevant to the event and useful for evaluation. Question 8 ? generation is not required to monitor frequency during events, so this would not be answered. This question also assumes that frequency had been impacted, which is not always the case (i.e., the plant could not come online). The asterisk on some questions in Attachment 2 is not defined.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received. Attachment 2 has been streamlined to match the types of events that are to be reported. The purpose of this standard is to have events reported. Once reported, the events are included in the NERC Events Analysis Program for possible further investigation. The asterisk has been removed from Attachment 2.</p>		
Georgia System Operations Corporation		<p>Attachment 2: Impact Event Reporting Form-Instructions for filling out this form are needed.-Line 7, Generation tripped off-line: What is the asterisk for after this task and after the many others following? This should only be reported by a BA. Does generation ?tripped off-line? mean the same as generation ?lost??-Line 9, List of transmission facilities (lines, transformers, buses, etc.) tripped and locked-out: Does this means the same as BES Transmission Elements lost?-Line 10: The column headings in white text on lighter blue</p>

Organization	Yes or No	Question 17 Comment
		<p>background at the top do not seem to apply from this line on.-Line 11, Restoration Time: Restoration of what? Initial/Final clock time? Transmission? What about transmission? Generation/Demand?-Line 13, Identify the initial probable cause or known root cause of the actual or potential Impact Event if known at time of submittal of Part I of this report: ?At the time of submittal of Part I of this report??? Where is Part II? Did you mean Part A? Is Part B to be submitted at a different time?Background-Page 5, last sentence which is continued on page 6: This standard does not recognize the various ?versions? of companies in the industry. The standard is made applicable to a long list of registered entity types. In many cases, many of these entities are wrapped into one company. A company may be responsible for ?everything? in a geographic area. It may be almost every registered entity type with no other registered entities within its geographic area. There should be no conflicts or need for coordination with others for this company. Everything would be coordinated internally within that one company before being reported to NERC and no one else would be reporting to NERC.However, sometimes one company is only a LSE. When an LSE-only is having a LSE impact event, the LSE should report to some higher operating entity like its BA and should not report to NERC. Reporting should be done in a hierarchical manner within appropriate operating entities and then reported to NERC at the RC (or BA) level or as agreed among entities in any coordinated impact event reporting plans. The RC, BA, TOP, and LSE should not all be held accountable for reporting the same event.This standard does not deal exclusively with after-the-fact reporting. Some events deal with the condition of the system (risk of possible future events) or condition of an entity?s ability to operate (supplying fuel, covering load, etc.) or with a threat to the BES.-Page 6, Summary of Concepts: A single form may have been an objective but it is obviously not a concept being implemented by the standard. There are two forms.-Page 6, Law Enforcement Reporting: The object of the standard may be to prevent or reduce the risk of Cascading. Reporting system situations to appropriate operating entities who can take some mitigating action (e.g., a LSE reporting to its BA or a BA reporting to its RC) and reporting threats to law enforcement officials could prevent or reduce the risk of Cascading but reporting to NERC is unlikely to a do that. Reporting of most of the listed events to NERC does not meet the objective of this standard and should be removed from this standard. Such events should be reported to NERC through some other (than a Reliability Standard) requirement for reporting to NERC so that NERC can accomplish its mission of analyzing events. Analyzing events may lead to an understanding that could reduce the future risk of Cascading but not any impending risks.-Page 6, Stakeholders: What is ?Homeland Security ? State?? We know what the Department of Homeland Security and the State Department are but this term is not clear. -Page 6, ?State Regulators?, ?Local Law Enforcement?, and State Law Enforcement?: These are not proper nouns/names and are not defined in the NERC Glossary. They should not be capitalized.-Pages 7 &amp; 8, Law enforcement: Is each entity required to determine procedures for reporting to law enforcement and work it out with the state law enforcement agency? Do the state law enforcement agencies know this? Or is there a pre-determine procedure that is already worked out with the state law enforcement agency that entities are to follow?</p>
<ul style="list-style-type: none"> <li>• <b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received.</li> </ul>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 17 Comment
<p>Attachment 2 has been streamlined to match the types of events that are to be reported. The purpose of this standard is to have events reported. Once reported, the events are included in the NERC Events Analysis Program for possible further investigation. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <p>“The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power		We like the option to use the OE_417 as the reporting form for these events.
<p><b>Response:</b> The DSR DT thanks you for your comment. EOP-004-2 allows entities to utilize the DOE Form OE-417 to report events.</p>		
Indeck Energy Services		This revision seriously missed the mark.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received.</p>		
Progress Energy		<p>Progress thanks the Standard Drafting Team for their efforts on this project. The BES definition is still being revised under ?Project 2010-17: Proposed Definition of Bulk Electric System.? ?BES equipment? is mentioned several times in this Standard. A better definition of BES is important to the effectiveness of this Standard and integral to entities ability to comply with the Standard requirements. In Attachment 2, on the Impact Event Reporting form, item 10 is ?Demand Tripped? and the categories include ?FIRM? and ?INTERRUPTIBLE.? It is unclear why interruptible load is included on the reporting form.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The definition of BES will apply to this standard after it is approved by stakeholders, the NERC BOT and FERC. The DSR SDT has updated the requirements, Attachments 1 and 2 per comments received. Attachment 2 has been streamlined to match the types of events that are to be reported. The purpose of this standard is to have events reported. Once reported, the events are included in the NERC Events Analysis Program for possible further investigation. Firm and Interruptible load have been removed from the list of reportable events in Attachment 1.</p>		





## Consideration of Comments

### Disturbance and Sabotage Reporting (Project 2009-01)

The Disturbance and Sabotage Reporting Drafting Team thanks all commenters who submitted comments on the second formal posting for Project 2009-01—Disturbance and Sabotage Reporting. The standard was posted for a 45-day public comment period from October 28, 2011 through December 12, 2011 and included an initial ballot during the last 10 days of the comment period. Stakeholders were asked to provide feedback on the standard and associated documents through a special electronic comment form. There were 76 sets of comments, including comments from approximately 171 different people from approximately 140 companies representing nine of the ten Industry Segments as shown in the table on the following pages.

All comments submitted may be reviewed in their original format on the standard's project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President of Standards and Training, Herb Schrayshuen, at 404-446-2560 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

### Summary Consideration

EOP-004-2 was posted for a 45-day formal comment period and initial ballot from October 28-December 12, 2011. The DSR SDT received comments from stakeholders to improve the readability and clarity of the requirements of the standard. The revisions that were made to the standard are summarized in the following paragraphs.

#### Purpose Statement

The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:

“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”

<sup>1</sup> The appeals process is in the Standard Processes Manual  
[http://www.nerc.com/files/Appendix\\_3A\\_Standard\\_Processes\\_Manual\\_Rev%201\\_20110825.pdf](http://www.nerc.com/files/Appendix_3A_Standard_Processes_Manual_Rev%201_20110825.pdf)

### Operating Plan

Based on stakeholder comments, Requirement R1 was revised for clarity. Part 1.1 was revised to replace the word “identifying” with “recognizing” and Part 1.2 was eliminated. This also aligns the language of the standard with FERC Order 693, Paragraph 471.

“(2) specify baseline requirements regarding what issues should be addressed in the **procedures for recognizing** {emphasis added} sabotage events and making personnel aware of such events;”

Requirement R1, Part 1.3 (now Part 1.2) was revised by eliminating the phrase “as appropriate” and adding language indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:

“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”

The SDT envisions that most entities will only need to slightly modify their existing CIP-001 Sabotage Reporting procedures to comply with the Operating Plan requirement in this proposed standard. As many of the features of both sabotage reporting procedures and the Operating Plan are substantially similar, the SDT feels that some information in the sabotage reporting procedures may need to be updated and verified.

### Operating Plan Review and Communications Testing

Requirement R1, Part 1.4 was removed and Requirement 1, Part, 1.5 was separated out as new Requirement 4. Requirement R4 was revised and is now R3. FERC Order 693, Paragraph 466 includes provisions for periodic review and update of the Operating Plan:

“466. The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”

Requirement R3 requires an annual test of the communication portion of Requirement R1 while Requirement R4 requires an annual review of the Operating Plan.:

“R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.”

“R4. Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1.”

The DSR SDT envisions that the annual test will include verification that communication information contained in the Operating Plan is correct. As an example, the annual update of the Operating Plan could include calling “others as defined in the Responsibility Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator.

#### Operating Plan Implementation

Most stakeholders indicated that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:

“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”

#### Reporting Timelines

The DSR SDT received many comments regarding the various entries of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments; those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is “A reportable Cyber Security Incident” as it is required by CIP-008 and FERC Order 706, Paragraph 673:

“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”

The table was reformatted to separate one hour reporting and 24 hour reporting. The last column of the table was also deleted and the information contained in the table was transferred to the sentence above each table. These sentences are:

“One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event.”

“Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event.”

Note that the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.

### Cyber-Related Events

The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1. Stakeholders pointed out these events are adequately addressed through the CIP-008 and “Damage or Destruction of a Facility” reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:

“Any malicious act or suspicious event that:

- Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,
- Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”

A Critical Asset is defined as:

“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”

Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.

### Damage or Destruction

The event for “Destruction of BES equipment” has been revised to “Damage or destruction of a Facility”. The threshold for reporting information was expanded for clarity:

“Damage or destruction of a Facility that: affects an IROL  
OR  
Results in the need for actions to avoid an Adverse Reliability Impact  
OR  
Results from intentional human action.”

### Facility Definition

The DSR SDT used the defined term “Facility” to add clarity for this event as well as other events in Attachment 1. A Facility is defined as:

“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”

The DSR SDT did not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

### Physical Threats

Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “Any physical threat that could impact the operability of a Facility”.

Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.

The footnote regarding this event type was expanded to provide additional guidance in:

“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also, report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”

#### Use of DOE OE-417

The DSR SDT received many comments requesting consistency with DOE OE-417 thresholds and timelines. These items, as well as, the Events Analysis Working Group’s (EAWG) requirements were considered in creating Attachment 1, but differences remain for the following reasons:

- EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’
- OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America
- NERC has no control over the criteria in OE-417, which can change at any time
- Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary

In an effort to minimize administrative burden, US entities may use the OE-417 form rather than Attachment 2 to report under EOP-004. The SDT was informed by the DOE of its new online process coming later this year. In this process, entities may be able to record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses, thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.

#### Miscellaneous

Other minor edits were made to Attachment 1. Several words were capitalized but not defined terms. The DSR SDT did not intend for these terms to be capitalized (defined terms) and these words were reverted to lower case. The event type “Loss of monitoring or all voice communication capability” was divided into two separate events as “Loss of monitoring capability” and “Loss of all voice communication capability”.

Attachment 2 was updated to reflect the revisions to Attachment 1. The reference to “actual or potential events” was removed. Also, the event type of “other” and “fuel supply emergency” was removed as well.

It was noted that ‘Transmission Facilities’ is not a defined term in the NERC Glossary. Transmission and Facilities are separately defined terms. The combination of these two definitions are what the DSR SDT has based the applicability of “Transmission Facilities” in Attachment 1.

**Index to Questions, Comments, and Responses**

1. The DSR SDT has revised EOP-004-2 to remove the training requirement R4 based on stakeholder comments from the second formal posting. Do you agree this revision? If not, please explain in the comment area below..... 18
2. The DSR SDT includes two requirement regarding implementation of the Operating Plan specified in Requirement R1. The previous version of the standard had a requirement to implement the Operating plan as well as a requirement to report events. The two requirements R2 and R3 were written to delineate implementation of the Parts of R1. Do you agree with these revisions? If not, please explain in the comment area below..... 42
  - R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.
  - R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.
3. The DSR SDT revised reporting times for many events listed in Attachment 1 from one hour to 24 hours. Do you agree with these revisions? If not, please explain in the comment area below..... 79
4. Do you have any other comment, not expressed in the questions above, for the DSR SDT?.....156

**The Industry Segments are:**

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	Gerald Beckerle	SERC OC Standards Review Group	X		X								
Additional Member		Additional Organization	Region	Segment Selection										
1.	Charlie Cook	TVA		5, 6, 1, 3										
2.	Jake Miller	Dynegy	SERC	5										
3.	Joel Wise	TVA	SERC	1, 3, 5, 6										
4.	Tim Hattaway	PowerSouth	SERC	1, 5										
5.	Robert Thomasson	BREC	SERC	1										
6.	Shaun Anders	CWLP	SERC	1, 3										
7.	Jim Case	Entergy	SERC	1, 3, 6										
8.	Tim Lyons	OMU	SERC	3, 5										
9.	Len Sandberg	Dominion Virginia Power	SERC	1, 3, 5, 6										
10.	Brad Young	LGE-KU	SERC	3										



Group/Individual	Commenter	Organization	Registered Ballot Body Segment												
			1	2	3	4	5	6	7	8	9	10			
11. Larry Akens	TVA	SERC	1, 3, 5, 6												
12. Mike Hirst	Cogentrix	SERC	5												
13. Wayne Van Liere	LGE-KU	SERC	3												
14. Scott Brame	NCEMC	SERC	1, 3, 4, 5												
15. Steve Corbin	SERC Reliability Corp.	SERC	10												
16. John Johnson	SERC Reliability Corp.	SERC	10												
17. John Troha	SERC Reliability Corp.	SERC	10												
2.	Group	Guy Zito	Northeast Power Coordinating Council												X
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment</b>	<b>Selection</b>										
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10											
2.	Greg Campoli	New York Independent System Operator	NPCC	2											
3.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1											
4.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1											
5.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10											
6.	Ben Wu	Orange and Rockland Utilities	NPCC	1											
7.	Peter Yost	Consolidated Edison co. of New York, Inc.	NPCC	3											
8.	Kathleen Goodman	ISO - New England	NPCC	2											
9.	Chantel Haswell	FPL Group, Inc.	NPCC	5											
10.	David Kiguel	Hydro One Networks Inc.	NPCC	1											
11.	Michael R. Lombardi	Northeast Utilities	NPCC	1											
12.	Randy Macdonald	New Brunswick Power Transmission	NPCC	9											
13.	Bruce Metruck	New York Power Authority	NPCC	6											
14.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10											
15.	Robert Pellegrini	The United Illuminating Company	NPCC	1											
16.	Si-Truc Phan	Hydro-Quebec TransEnergie	NPCC	1											
17.	David Ramkalawan	Ontario Power Generation, Inc.	NPCC	5											
18.	Saurabh Saksena	National Grid	NPCC	1											
19.	Michael Schiavone	National Grid	NPCC	1											
20.	Wayne Sipperly	New York Power Authority	NPCC	5											
21.	Tina Teng	Independent Electricity System Operator	NPCC	2											
22.	Donald Weaver	New Brunswick System Operator	NPCC	2											

Group/Individual		Commenter	Organization	Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
3.	Group	Steve Alexanderson	Pacific Northwest Small Public Power Utility Comment Group			X	X							X	
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>										
1.	Russell A. Noble	Cowlitz County PUD No. 1	WECC	3, 4, 5											
2.	Ronald Sporseen	Blachly-Lane Electric Cooperative	WECC	3											
3.	Ronald Sporseen	Central Electric Cooperative	WECC	3											
4.	Ronald Sporseen	Consumers Power	WECC	1, 3											
5.	Ronald Sporseen	Clearwater Power Company	WECC	3											
6.	Ronald Sporseen	Douglas Electric Cooperative	WECC	3											
7.	Ronald Sporseen	Fall River Rural Electric Cooperative	WECC	3											
8.	Ronald Sporseen	Northern Lights	WECC	3											
9.	Ronald Sporseen	Lane Electric Cooperative	WECC	3											
10.	Ronald Sporseen	Lincoln Electric Cooperative	WECC	3											
11.	Ronald Sporseen	Raft River Rural Electric Cooperative	WECC	3											
12.	Ronald Sporseen	Lost River Electric Cooperative	WECC	3											
13.	Ronald Sporseen	Salmon River Electric Cooperative	WECC	3											
14.	Ronald Sporseen	Umatilla Electric Cooperative	WECC	3											
15.	Ronald Sporseen	Coos-Curry Electric Cooperative	WECC	3											
16.	Ronald Sporseen	West Oregon Electric Cooperative	WECC	3											
17.	Ronald Sporseen	Pacific Northwest Generating Cooperative	WECC	3, 4, 8											
18.	Ronald Sporseen	Power Resources Cooperative	WECC	5											
4.	Group	Emily Pannel	Southwest Power Pool Regional Entity												X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>										
1.	John Allen	City Utilities of Springfield	SPP	1, 4											
2.	Clem Cassmeyer	Western Farmer's Electric Cooperative	SPP	1, 3, 5											
3.	Michelle Corley	Cleco Power	SPP	1, 3, 5											
4.	Kevin Emery	Carthage Water and Electric Plant	SPP	NA											
5.	Jonathan Hayes	Southwest Power Pool	SPP	2											
6.	Philip Huff	Arkansas Electric Cooperative Corporation	SPP	3, 4, 5, 6											
7.	Ashley Stringer	Oklahoma Municipal Power Authority	SPP	4											
5.	Group	Patricia Robertson	BC Hydro	X	X	X		X							

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Patricia Robertson	BC Hydro	WECC	1									
2.	Rama Vinnakota	BC Hydro	WECC	2									
3.	Pat Harrington	BC Hydro	WECC	3									
4.	Clement Ma	BC Hydro	WECC	5									
5.	Daniel O'Hearn	BC Hydro	WECC	6									
6.	Group	Mary Jo Cooper	ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi			X							X
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Elizabeth Kirkley	City of Lodi	WECC	3									
2.	Colin Murphey	City of Ukiah	WECC	3									
3.	Douglas Draeger	Alameda Municipal Power	WECC	3									
4.	Ken Dizes	Salmen River Electric Coop	WECC	3									
7.	Group	WILL SMITH	MRO NSRF										
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	MAHMOOD SAFI	OPPD	MRO	1, 3, 5, 6									
2.	CHUCK LAWRENCE	ATC	MRO	1									
3.	TOM WEBB	WPS	MRO	3, 4, 5, 6									
4.	JODI JENSON	WAPA	MRO	1, 6									
5.	KEN GOLDSMITH	ALTW	MRO	4									
6.	ALICE IRELAND	NSP (XCEL)	MRO	1, 3, 5, 6									
7.	DAVE RUDOLPH	BEPC	MRO	1, 3, 5, 6									
8.	ERIC RUSKAMP	LES	MRO	1, 3, 5, 6									
9.	JOE DEPOORTER	MGE	MRO	3, 4, 5, 6									
10.	SCOTT NICKELS	RPU	MRO	4									
11.	TERRY HARBOUR	MEC	MRO	1, 3, 5, 6									
12.	MARIE KNOX	MISO	MRO	2									
13.	LEE KITTELSON	OTP	MRO	1, 3, 4, 5									
14.	SCOTT BOS	MPW	MRO	1, 3, 5, 6									
15.	TONY EDDLEMAN	NPPD	MRO	1, 3, 5									

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																																									
			1	2	3	4	5	6	7	8	9	10																																
16. MIKE BRYTOWSKI	GRE	MRO	1, 3, 5, 6																																									
17. RICHARD BURT	MPC	MRO	1, 3, 5, 6																																									
8.	Group	Steve Rueckert	Western Electricity Coordinating Council																																									
No Additional members listed.																																												
9.	Group	Jesus Sammy Alcaraz	Imperial Irrigation District																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Tino Zaragoza</td> <td>IID</td> <td>WECC</td> <td>1</td> </tr> <tr> <td>2. Jesus Sammy Alcaraz</td> <td>IID</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>3. Diana Torres</td> <td>IID</td> <td>WECC</td> <td>4</td> </tr> <tr> <td>4. Marcela Caballero</td> <td>IID</td> <td>WECC</td> <td>5</td> </tr> <tr> <td>5. Cathy Bretz</td> <td>IID</td> <td>WECC</td> <td>6</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Tino Zaragoza	IID	WECC	1	2. Jesus Sammy Alcaraz	IID	WECC	3	3. Diana Torres	IID	WECC	4	4. Marcela Caballero	IID	WECC	5	5. Cathy Bretz	IID	WECC	6								
Additional Member	Additional Organization	Region	Segment Selection																																									
1. Tino Zaragoza	IID	WECC	1																																									
2. Jesus Sammy Alcaraz	IID	WECC	3																																									
3. Diana Torres	IID	WECC	4																																									
4. Marcela Caballero	IID	WECC	5																																									
5. Cathy Bretz	IID	WECC	6																																									
10.	Group	Jean Nitz	ACES Power Marketing Standards Collaborators																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Chris Bradley</td> <td>Big Rivers Electric Corporation</td> <td>SERC</td> <td>1</td> </tr> <tr> <td>2. Erin Woods</td> <td>East Kentucky Power Cooperative</td> <td>SERC</td> <td>1, 3, 5</td> </tr> <tr> <td>3. Susan Sosbe</td> <td>Wabash Valley Power Association</td> <td>RFC</td> <td>3</td> </tr> <tr> <td>4. Scott Brame</td> <td>North Carolina Electric Membership Corporation</td> <td>RFC</td> <td>5, 1, 3, 4</td> </tr> <tr> <td>5. Shari Heino</td> <td>Brazos Electric Power Cooperative, Inc.</td> <td>ERCOT</td> <td>1</td> </tr> <tr> <td>6. Lindsay Shepard</td> <td>Western Farmers Electric Cooperative</td> <td>SPP</td> <td>1, 5</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Chris Bradley	Big Rivers Electric Corporation	SERC	1	2. Erin Woods	East Kentucky Power Cooperative	SERC	1, 3, 5	3. Susan Sosbe	Wabash Valley Power Association	RFC	3	4. Scott Brame	North Carolina Electric Membership Corporation	RFC	5, 1, 3, 4	5. Shari Heino	Brazos Electric Power Cooperative, Inc.	ERCOT	1	6. Lindsay Shepard	Western Farmers Electric Cooperative	SPP	1, 5				
Additional Member	Additional Organization	Region	Segment Selection																																									
1. Chris Bradley	Big Rivers Electric Corporation	SERC	1																																									
2. Erin Woods	East Kentucky Power Cooperative	SERC	1, 3, 5																																									
3. Susan Sosbe	Wabash Valley Power Association	RFC	3																																									
4. Scott Brame	North Carolina Electric Membership Corporation	RFC	5, 1, 3, 4																																									
5. Shari Heino	Brazos Electric Power Cooperative, Inc.	ERCOT	1																																									
6. Lindsay Shepard	Western Farmers Electric Cooperative	SPP	1, 5																																									
11.	Group	Frank Gaffney	Florida Municipal Power Agency																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Timothy Beyrle</td> <td>City of New Smyrna Beach</td> <td>FRCC</td> <td>4</td> </tr> <tr> <td>2. Greg Woessner</td> <td>KissimmeeUtility Authority</td> <td>FRCC</td> <td>3</td> </tr> <tr> <td>3. Jim Howard</td> <td>Lakeland Electric</td> <td>FRCC</td> <td>3</td> </tr> <tr> <td>4. Lynne Mila</td> <td>City of Clewiston</td> <td>FRCC</td> <td>3</td> </tr> <tr> <td>5. Joe Stonecipher</td> <td>Beaches Energy Services</td> <td>FRCC</td> <td>1</td> </tr> <tr> <td>6. Cairo Vanegas</td> <td>Fort Pierce Utility Authority</td> <td>FRCC</td> <td>4</td> </tr> <tr> <td>7. Randy Hahn</td> <td>Ocala Utility Services</td> <td>FRCC</td> <td>3</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Timothy Beyrle	City of New Smyrna Beach	FRCC	4	2. Greg Woessner	KissimmeeUtility Authority	FRCC	3	3. Jim Howard	Lakeland Electric	FRCC	3	4. Lynne Mila	City of Clewiston	FRCC	3	5. Joe Stonecipher	Beaches Energy Services	FRCC	1	6. Cairo Vanegas	Fort Pierce Utility Authority	FRCC	4	7. Randy Hahn	Ocala Utility Services	FRCC	3
Additional Member	Additional Organization	Region	Segment Selection																																									
1. Timothy Beyrle	City of New Smyrna Beach	FRCC	4																																									
2. Greg Woessner	KissimmeeUtility Authority	FRCC	3																																									
3. Jim Howard	Lakeland Electric	FRCC	3																																									
4. Lynne Mila	City of Clewiston	FRCC	3																																									
5. Joe Stonecipher	Beaches Energy Services	FRCC	1																																									
6. Cairo Vanegas	Fort Pierce Utility Authority	FRCC	4																																									
7. Randy Hahn	Ocala Utility Services	FRCC	3																																									
12.	Group	Terry L. Blackwell	Santee Cooper																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection																												
Additional Member	Additional Organization	Region	Segment Selection																																									

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
1. S. T. Abrams	Santee Cooper	SERC 1												
2. Wayne Ahl	Santee Cooper	SERC 1												
3. Rene Free	Santee Cooper	SERC 1												
13. Group	Joe Tarantino	Sacramento Municipal Utility District (SMUD)	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Kevin Smith	BANC	WECC 1												
14. Group	Robert Rhodes	SPP Standards Review Group		X										
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. John Allen	City Utilities of Springfield	SPP 1, 4												
2. Clem Cassmeyer	Western Farmer's Electric Cooperative	SPP 1, 3, 5												
3. Michelle Corley	Cleco Power	SPP 1, 3, 5												
4. Kevin Emery	Carthage Water and Electric Plant	SPP NA												
5. Jonathan Hayes	Southwest Power Pool	SPP 2												
6. Philip Huff	Arkansas Electric Cooperative Corporation	SPP 3, 4, 5, 6												
7. Ashley Stringer	Oklahoma Municipal Power Authority	SPP 4												
15. Group	Connie Lowe	Dominion	X		X		X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Louis Slade		RFC 3, 6												
2. Michael Crowley		SERC 1, 3												
3. Mike Garton		NPCC 5, 6												
4. Michael Gildea		MRO 5, 6												
16. Group	Sam Ciccone	FirstEnergy	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Doug Hohlbaugh	FE	RFC 1, 3, 4, 5, 6												
2. Larry Raczkowski	FE	RFC 1, 3, 4, 5, 6												
3. Jim Eckels	FE	RFC 1												
4. John Reed	FE	RFC 1												
5. Ken Dresner	FE	RFC 5												
6. Bill Duge	FE	RFC 5												
7. Kevin Querry	FE	RFC 5												

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
17.	Group	Annette M. Bannon	PPL Electric Utilities and PPL Supply Organizations'	X				X	X				
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Brenda Truhe	PPL Electric Utilities	RFC 1										
2.	Annette Bannon	PPL Generation	RFC 5										
3.	Annette Bannon	PPL Generation	WECC 5										
4.	Mark Heimbach	PPL EnergyPlus	MRO 6										
5.	Mark Heimbach	PPL EnergyPlus	NPCC 6										
6.	Mark Heimbach	PPL EnergyPlus	RFC 6										
7.	Mark Heimbach	PPL EnergyPlus	SERC 6										
8.	Mark Heimbach	PPL EnergyPlus	SPP 6										
9.	Mark Heimbach	PPL EnergyPlus	WECC 6										
18.	Group	Tom McElhinney	Electric Compliance	X		X		X					
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Ted Hobson		FRCC 1										
2.	John Babik		FRCC 5										
3.	Garry Baker		3										
19.	Group	Michael Gammon	Kansas City Power & Light	X		X		X	X				
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Scott Harris	KCP&L	SPP 1, 3, 5, 6										
2.	Monica Strain	KCP&L	SPP 1, 3, 5, 6										
3.	Brett Holland	KCP&L	SPP 1, 3, 5, 6										
4.	Jennifer Flandermeyer	KCP&L	SPP 1, 3, 5, 6										
20.	Individual	Stewart Rake	Luminant Power					X					
21.	Individual	Sandra Shaffer	PacifiCorp	X		X		X	X				
22.	Individual	Janet Smith, Regulatory Affairs Supervisor	Arizona Public Service Company	X		X		X	X				
23.	Individual	Jim Eckelkamp	Progress Energy	X		X		X	X				
24.	Individual	Silvia Parada Mitchell	Compliance & Responsibility Office	X		X		X	X				
25.	Individual	Antonio Grayson	Southern Company	X		X		X	X				

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
26.	Individual	John Brockhan	CenterPoint Energy	X										
27.	Individual	Brenton Lopez	Salt River Project	X		X		X	X					
28.	Individual	Bo Jones	Westar Energy	X		X		X	X					
29.	Individual	Michael Johnson	APX Power Markets (NCR-11034)						X					
30.	Individual	David Proebstel	Clallam County PUD No.1			X								
31.	Individual	Michael Moltane	ITC	X										
32.	Individual	Tracy Richardson	Springfield Utility Board			X								
33.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X					
34.	Individual	Kevin Conway	Intellibind								X			
35.	Individual	Chris Higgins / Jim Burns / Ted Snodgrass / Jeff Millenor / Russell Funk	Bonneville Power Administration	X		X		X	X					
36.	Individual	Chris de Graffenried	Consolidated Edison Co. of NY, Inc.	X		X		X	X					
37.	Individual	David Burke	Orange and Rockland Utilities, Inc.	X		X								
38.	Individual	Alice Ireland	Xcel Energy	X		X		X	X					
39.	Individual	Greg Rowland	Duke Energy	X		X		X	X					
40.	Individual	Rodney Luck	Los Angeles Department of Water and Power	X		X		X	X					
41.	Individual	Daniel Duff	Liberty Electric Power					X						
42.	Individual	Lisa Rosintoski	Colorado Springs Utilities	X		X		X	X					
43.	Individual	Michael Falvo	Independent Electricity System Operator		X									
44.	Individual	John Bee on Behalf of Exelon	Exelon	X		X		X						
45.	Individual	John D. Martinsen	Public Utility District No. 1 of Snohomish County											
46.	Individual	RoLynda Shumpert	South Carolina Electric and Gas	X		X		X	X					
47.	Individual	Kathleen Goodman	ISO New England		X									

Group/Individual		Commenter	Organization	Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
48.	Individual	Curtis Crews	Texas Reliability Entity												X
49.	Individual	Andrew Z. Pusztai	American Transmission Company, LLC	X											
50.	Individual	Anthony Jablonski	ReliabilityFirst												X
51.	Individual	Don Schmit	Nebraska Public Power District	X		X		X							
52.	Individual	Dennis Sismaet	Seattle City Light	X		X	X	X	X						
53.	Individual	John Seelke	PSEG	X		X		X	X						
54.	Individual	Barry Lawson	NRECA												
55.	Individual	Terry Harbour	MidAmerican Energy	X		X		X							
56.	Individual	Thad Ness	American Electric Power	X		X		X	X						
57.	Individual	Guy Andrews	Georgia System Operations Corporation	X		X	X	X	X						
58.	Individual	Ed Davis	Entergy Services												
59.	Individual	Margaret McNaul	Thompson Coburn LLP on behalf of Miss. Delta Energy Agency												
60.	Individual	Bob Thomas	Illinois Municipal Electric Agency				X								
61.	Individual	Kirit Shah	Ameren	X		X		X	X						
62.	Individual	Linda Jacobson-Quinn	FEUS			X									
63.	Individual	Tom Foreman	Lower Colorado River Authority	X		X		X	X						
64.	Individual	Richard Salgo	NV Energy												
65.	Individual	Nathan Mitchell	American Public Power Association			X									
66.	Individual	Angela Summer	Southwestern Power Administration	X											
67.	Individual	Michelle R D'Antuono	Ingleside Cogeneration LP					X							
68.	Individual	Tim Soles	Occidental Power Services, Inc. (OPSI)			X			X						
69.	Individual	Michael Lombardi	Northeast Utilities	X		X		X							
70.	Individual	Andrew Gallo	City of Austin dba Austin Energy	X		X	X	X	X						
71.	Individual	James Saucedo	Energy Northwest - Columbia					X							
72.	Individual	Scott Berry	Indiana Municipal Power Agency				X								



Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
73.	Individual	Maggy Powell	Constellation Energy on behalf of Baltimore Gas & Electric, Constellation Power Generation, Constellation Energy Commodities Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.	X		X		X	X				
74.	Individual	Michael Brytowski	Great River Energy	X		X		X	X				
75.	Individual	Christine Hasha	Electric Reliability Council of Texas, Inc.		X								
76.	Individual	Darryl Curtis	Oncor Electric Delivery Company LLC	X									

1. The DSR SDT has revised EOP-004-2 to remove the training requirement R4 based on stakeholder comments from the second formal posting. Do you agree this revision? If not, please explain in the comment area below.

**Summary Consideration:** As a result of the industry comments, the SDT has further modified the standard as follows:

- Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom events are communicated.
- Combined relevant parts of Requirement R1, Parts 1.4, 1.5 and Requirement R4 into Requirement 1, Part 1.3.
- Deleted the requirement for drills or exercises
- Clarified that only Registered Entities conduct annual tests of the communication process outlined in Requirement 1, Part 1.2
- Changed the review of the Operating Plan to 'annually'

The DSR SDT envisions the testing under Requirement R1, Part 1.3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsibility Entity’s Operating Plan” (see Part 1.2) to verify their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.

Despite some industry opposition, both the periodic review of the Operating Plan and the testing requirements were maintained to meet the intent of FERC Order 693, Paragraph 466:

“The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”

Organization	Yes or No	Question 1 Comment
Beaches Energy Services, City of	Negative	First, I wish to thank the SDT for their hard work and making significant progress in significant improvements in the standard. I commend the

Organization	Yes or No	Question 1 Comment
Green Cove Springs		<p>direction that the SDT is taking. There are; however, a few unresolved issues that cause me to not support the standard at this time. 1. An issue of possible differences in interpretation between entities and compliance monitoring and enforcement is the phrase in 1.3 that states “the following as appropriate”. Who has the authority to deem what is appropriate? The requirements should be clear that the Responsible Entity is the decision maker of who is appropriate, otherwise there is opportunity for conflict between entities and compliance. <i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan.</i></p> <p>In addition, 1.4 is onerous and burdensome regarding the need to revise the plan within 90 days of “any” change, especially considering the ambiguity of “other circumstances”. “Other circumstances” is open to interpretation and a potential source of conflict.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
New Brunswick Power Transmission Corporation	Negative	<p>It is NBPT’s opinion that because this is a standard associated with reporting events after an occurrence, it is overly burdensome to require drills and exercises for verification purposes as described in R4.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications</i></p>

Organization	Yes or No	Question 1 Comment
		<i>process in Part 1.2.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
United Illuminating Co.	Negative	<p>R4 is not clear what is expected. There is a difference between testing a process that consists of identify an event then select commuication contacts versus needing to test contacts for each event in Attachment 1 and drill each event and document each event drill.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement r3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>In R2 the phrase "as specified" should be replaced or completed, as specified by what.</p> <p><i>The DSR SDT has deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read: “Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004</i></p>

Organization	Yes or No	Question 1 Comment
		<a href="#">Attachment1.</a>
<b>Response: Thank you for your comment. Please see response above.</b>		
City of Farmington	Negative	<p>R4 requires verification through a drill or exercise the communication process created as part of R1.3. Clarification of what a drill or exercise should be considered. In order to show compliance to R4 would the entity have to send a pseudo event report to Internal Personnel, the Regional Entity, NERC ES-ISAC, Law Enforcement, and Governmental or provincial agencies listed in R1.3 to verify the communications plan? It would not be a burden on the entity so much, however, I'm not sure the external parties want to be the recipient of approximately 2000 psuedo event reports annually.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Hydro One Networks, Inc.	Negative	Referring to Requirement R4, the communication process can be verified without having to go through a drill or exercise. Any specific testing or

Organization	Yes or No	Question 1 Comment
		<p>verification of the process is the responsibility of the Responsible Entity.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>Despite some industry opposition, both periodic review of the Operating Plan and the test requirements were maintained to meet the intent of FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ameren Services	Negative	<p>The current language in the parenthesis of R4 suggests that the training requirement was actually not removed, in that "a drill or exercise" constitutes training. As documented in the last sentence of the Summary of Key Concepts section, "The proposed standard deals exclusively with after-the-fact reporting." We feel that training, even if it is called drills or exercises is not necessary for an after-the-fact report.</p> <p><i>Requirement R4 related to an annual test of the communication portion of</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>Despite some industry opposition, both periodic review of the Operating Plan and the test requirements were maintained to meet the intent of FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Liberty Electric Power LLC</p>	<p>Negative</p>	<p>Voting no due to training not being an option to fill the "drill" requirement. The reason for R4 seems to be to assure personnel will respond to an event in accordance with the entity procedure. Entities meet their obligations for other regulatory requirements with training, and should be permitted to do so for R4.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing, Hoosier Energy Rural Electric Cooperative, Inc., Sunflower Electric Power Corporation, Great River Energy</p>	<p>Negative</p>	<p>We appreciate the efforts of the SDT in considering the comments of stakeholders from prior comment periods. We believe this draft is greatly improved over the previous version and we agree with the elimination of the term "sabotage" which is a difficult term to define. The determination of an act of sabotage should be left to the proper law enforcement authorities. However, we also realize that the proper authorities would be hard pressed to make these determinations without reporting from industry when there are threats to BES equipment or facilities. We understand and agree there should be verification of the information required for such reporting (contact information, process flow charts, etc). But we still believe improvements can be made to the draft standard. The use of the words “or through a drill or exercise” in Requirement R4 still implies that training is required if no actual event has occurred. When you conduct a fire “drill” you are training your employees on evacuation routes and who they need to report to. Not only are you verifying your process but you are training your employees as well. It is imperative that the information in the Event</p>



Organization	Yes or No	Question 1 Comment
		<p>Reporting process is correct but we don't agree that performing a drill on the process is necessary. We recommend modifying the requirement to focus on verifying the information needed for appropriate communications on an event. And we agree this should take place at least annually.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>First, we wish to thank the SDT for their hard work and making significant progress in significant improvements in the standard. We commend the direction that the SDT is taking. There are; however, a few unresolved issues that cause us to not support the standard at this time. An issue of possible differences in interpretation between entities and compliance monitoring and enforcement is the phrase in 1.3 that states "the following as appropriate". Who has the authority to deem what is appropriate? The</p>

Organization	Yes or No	Question 1 Comment
		<p>requirements should be clear that the Responsible Entity is the decision maker of who is appropriate, otherwise there is opportunity for conflict between entities and compliance.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan. Part 1.2 now reads: “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>In addition, 1.4 is onerous and burdensome regarding the need to revise the plan within 90 days of “any” change, especially considering the ambiguity of “other circumstances”. “Other circumstances” is open to interpretation and a potential source of conflict.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Illinois Municipal Electric Agency</p>	<p>No</p>	<p>IMEA agrees with the removal of the training requirement, but also believes verification is not a necessary requirement for this standard; therefore, R4 is not necessary and should be removed.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Indiana Municipal Power Agency</p>	<p>No</p>	<p>IMPA does not believe that R4 is necessary. In addition, if a drill or exercise is used to verify the communication process, some of the parties listed in R1.3 may not want to participate in the drill or exercise every 15 months, such as law enforcement and governmental agencies. IMPA would propose a contacting these agencies every 15 months to verify their contact information only and updating their information in the plan as needed, without performing a drill or exercise.</p> <p><i>This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ISO New England</p>	<p>No</p>	<p>Please see further comments; we do not believe R4 is a necessary requirement in the standard and suggest it be deleted.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>

Organization	Yes or No	Question 1 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Northeast Power Coordinating Council</p>	<p>No</p>	<p>Requirement R4 is unnecessary. Whether or not the process, plan, procedure, etc. is “verified” is of no consequence. EOP standards are intended to have entities prepare for likely events (restoration/evacuation), and to provide tools for similar unforeseen events (ice storms, tornadoes, earthquakes, etc.). They should not force a script when results are what matters.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		

Organization	Yes or No	Question 1 Comment
Southern Company	No	<p>Southern agrees with removing the training requirement of R4 from the previous version of the standard. However, Southern suggests that drills and exercises are also training and R4 in this revised standard should be removed in its entirety</p> <p><i>The “drill or exercise” language has been deleted. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ameren	No	<p>The current language in the parenthesis of R4 suggests that the training requirement was actually not removed, in that "a drill or exercise" constitutes training. As documented in the last sentence of the Summary of</p>

Organization	Yes or No	Question 1 Comment
		<p>Key Concepts section, "The proposed standard deals exclusively with after-the-fact reporting." We feel that training, even if it is called drills or exercises is not necessary for an after-the-fact report.</p> <p><i>The "drill or exercise" language has been deleted. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Liberty Electric Power</p>	<p>No</p>	<p>Training should be left in the standard as an option, along with an actual event, drill or exercise, to demonstrate that operating personnel have knowledge of the procedure.</p> <p><i>The "drill or exercise" language has been deleted. Requirement R4 related</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>	<p>No</p>	<p>We agree with removing the training requirement of R4; however we believe that drills and exercises are also training and R4 should be removed in its entirety because drills and exercises on an after the fact process do not enhance reliability.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1 This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include</i></p>



Organization	Yes or No	Question 1 Comment
		<p><i>verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing Standards Collaborators/Great River Energy</p>	<p>No</p>	<p>We understand and agree there should be verification of the information required for such reporting (contact information, process flow charts, etc). But we still believe improvements can be made to the draft standard, in particular to requirement R4. The use of the words “or through a drill or exercise” still implies that training is required if no actual event has occurred. When you conduct a fire “drill” you are training your employees on evacuation routes and who they need to report to. Not only are you verifying your process but you are training your employees as well. It is imperative that the information in the Event Reporting process is correct but we don't agree that performing a drill on the process is necessary. We recommend modifying the requirement to focus on verifying the information needed for appropriate communications on an event. And we agree this should take place at least annually.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Ingleside Cogeneration LP</p>	<p>Yes</p>	<p>: Yes. Ingleside Cogeneration LP agrees that training on an incident reporting operations plan should be at the option of the entity. However, we recommend that a statement be included in the “Guideline and Technical Basis” section that encourages drills and exercises be coincident with those conducted for Emergency Operations. Since front-line operators must send out the initial alert that a reportable condition exists, such exercises may help determine how to manage their reporting obligations during the early stages of the troubleshooting process. This is especially true where a notification must be made within an hour of discovery - a very short time period.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Public Power Association</p>	<p>Yes</p>	<p>APPA agrees that removal of the training requirement was an appropriate revision to limit the burden on small registered entities. However, APPA requests clarification from the SDT on the current draft of R4. If no event occurs during the calendar year, a drill or exercise of the Operating Plan communication process is required. APPA believes that if this drill or exercise is required, then it should be a table top verification of the internal communication process such as verification of phone numbers and stepping through a Registered Entity specific scenario. This should not be a full drill with requirements to contact outside entities such as law enforcement, NERC, the RC or other entities playing out a drill scenario. This full drill would be a major burden for small entities.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
FirstEnergy	Yes	FirstEnergy supports this removal and thanks the drafting team.
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Compliance & Responsibility Office	Yes	See comments in response to Question 4.
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
NV Energy	Yes	Thank you for responding to the stakeholder comments on this issue.
<p><b>Response: Thank you for your comment.</b></p>		
Constellation Energy on behalf of Baltimore Gas & Electric, Constellation Power Generation, Constellation Energy Commodities	Yes	Yes, we support removal of the training requirement.

Organization	Yes or No	Question 1 Comment
Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.		
<b>Response: Thank you for your comment.</b>		
Pacific Northwest Small Public Power Utility Comment Group	Yes	
Southwest Power Pool Regional Entity	Yes	
BC Hydro	Yes	
ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi	Yes	
MRO NSRF	Yes	
Western Electricity Coordinating Council	Yes	
Imperial Irrigation District	Yes	
Santee Cooper	Yes	
Sacramento Municipal Utility District (SMUD)	Yes	

Organization	Yes or No	Question 1 Comment
SPP Standards Review Group	Yes	
Dominion	Yes	
PPL Electric Utilities and PPL Supply Organizations`	Yes	
Electric Compliance	Yes	
Kansas City Power & Light	Yes	
Luminant Power	Yes	
PacifiCorp	Yes	
Arizona Public Service Company	Yes	
CenterPoint Energy	Yes	
Salt River Project	Yes	
Westar Energy	Yes	
APX Power Markets (NCR-11034)	Yes	
Clallam County PUD No.1	Yes	
ITC	Yes	
Springfield Utility Board	Yes	

Organization	Yes or No	Question 1 Comment
Manitoba Hydro	Yes	
Intellibind	Yes	
Bonneville Power Administration	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Orange and Rockland Utilities, Inc.	Yes	
Xcel Energy	Yes	
Duke Energy	Yes	
Colorado Springs Utilities	Yes	
Independent Electricity System Operator	Yes	
Exelon	Yes	
Public Utility District No. 1 of Snohomish County	Yes	
South Carolina Electric and Gas	Yes	
American Transmission Company, LLC	Yes	
Nebraska Public Power District	Yes	

Organization	Yes or No	Question 1 Comment
Seattle City Light	Yes	
PSEG	Yes	
MidAmerican Energy	Yes	
American Electric Power	Yes	
Georgia System Operations Corporation	Yes	
FEUS	Yes	
Lower Colorado River Authority	Yes	
Southwestern Power Administration	Yes	
Occidental Power Services, Inc. (OPSI)	Yes	
Northeast Utilities	Yes	
City of Austin dba Austin Energy	Yes	
Energy Northwest - Columbia	Yes	
Electric Reliability Council of Texas, Inc.	Yes	
Oncor Electric Delivery Company LLC	Yes	



Organization	Yes or No	Question 1 Comment
Progress Energy		
Los Angeles Department of Water and Power		
Texas Reliability Entity		
ReliabilityFirst		
NRECA		
Entergy Services		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		

2. The DSR SDT includes two requirement regarding implementation of the Operating Plan specified in Requirement R1. The previous version of the standard had a requirement to implement the Operating plan as well as a requirement to report events. The two requirements R2 and R3 were written to delineate implementation of the Parts of R1. Do you agree with these revisions? If not, please explain in the comment area below.

R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.

R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

**Summary Consideration:** Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:

**“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”**

Organization	Yes or No	Question 2 Comment
Ameren Services	Negative	<p>(2) The new wording while well intentioned, effectively does not add clarity and leads to confusion. From our perspective, R1, which requires and Operating Plan, which is defined by the NERC glossary as: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan."</p> <p><i>The DSR SDT thanks you for your comment. The SDT has made changes to the</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>requirements highlighted in your comments.</i></p> <p><i>FERC Order 693, Paragraph 466 includes provisions for periodic review and update of the Operating Plan: “466. The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>(3) Is not a proper location for an after-the-fact reporting standard? In fact it could be argued that after-the-fact reports in and of themselves do not affect the reliability of the bulk electric system.</p> <p><i>The DSR SDT does not agree with this comment. Reporting of an event will give the Electric Reliability Organization and your Reliability Coordinator the situational awareness of what has occurred on your part of the BES. Plus as described in your Operating Plan, you would have communicated the event as you saw fit. By broadcasting that an event has occurred you will increase the awareness of your company (as described in your Operating Plan) and increase the awareness of the Electric Reliability Organization and your Reliability Coordinator.</i></p> <p>(4) But considering the proposed standard as written with the Operating Plan in requirement R1, and implementation of the Operating Plan in requirement R2 (except the actual reporting which is in R3) and then R3 which requires implementing the reporting section R1.3, it is not clear how these requirements can be kept separate in either implementation nor by the CEA.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2). The test and review requirement is</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>(5) The second sentence in the second paragraph of “Rationale for R1” states: “The main issue is to make sure an entity can a) identify when an event has occurred and b) be able to gather enough information to complete the report.” This is crucial for a Standard like this that is intended to mandate actions for events that are frequently totally unexpected and beyond normal planning criteria. This language needs to be added to Attachment 1 by the DSR SDT as explained in the rest of our comments.</p> <p><i>The DSR SDT has updated the Rationale for Part 1.2 (previous Part 1.3) to read as: “Part 1.2 could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information.” Whereas Part 1.2 now states:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Old Dominion Electric Coop.</p>	<p>Negative</p>	<p>I disagree with two things in the presently drafted standard. First, I do not feel a separate requirement to implement the plan is necessary (R2),</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>and I do not think that verification of the communications process should require a minimum of a drill or exercise. This is verified now under the current standard CIP-001 through verification contact with the appropriate authorities and this should be enough to verify that the communications for the plan is in place.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing, Hoosier Energy Rural Electric Cooperative, Inc., Sunflower Electric Power Corporation,</p>	<p>Negative</p>	<p>Requirement R2 requires Responsible Entities to implement the various sub-requirements in R1. We believe it is unnecessary to state that an entity must implement their Operating Plan in a separate requirement. Having a separate requirement seems redundant. If the processes in the Operating Plan are not</p>

Organization	Yes or No	Question 2 Comment
<p>Great River Energy/ ACES Power Marketing Standards Collaborators/ Great River Energy</p>		<p>implemented, the entity is non-compliant with the standard.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>There doesn't need to be an extra requirement saying entities need to implement their Operating Plan.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Hydro One Networks, Inc.</p>	<p>Negative</p>	<p>Requirement R2 seems to not be necessary. Who would have a plan and not implement it? This may also introduce double jeopardy issues should some entity not have a plan as required in R1. They would be unable to implement something they did not have so automatically non-compliant with R1 and R2. o Requirements R2 and R3 seem to be redundant. Isn't implementing the Operating Plan the same as reporting events in accordance with its Operating Plan?</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>The standard mentions collecting information for Attachment 2, but the standard does not state what to do with Attachment 2. Is it merely a record for demonstrating compliance with R3?</p> <p><i>The DSR SDT has updated Requirement R2 to read: “Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in Attachment 1.”</i></p> <p><i>The DSR SDT has also added the following statement to Attachment 1 for 1 hour reporting time frame and 24 hour reporting time frame, respectfully:</i></p> <p><i>“One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event”</i></p> <p><i>And</i></p> <p><i>“Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 2 Comment
<p>Beaches Energy Services, City of Green Cove Springs</p>	<p>Negative</p>	<p>Requirements R2 and R3 are to implement the Operating Plan. Hence, R3 should be a bullet under R2 and not a separate requirement. In addition, for R2, the phrase “actual event” is ambiguous and should mean: “actual event that meets the criteria of Attachment 1” I suggest the following wording to R2 (which will result in eliminating R3) “Each Responsible Entity shall implement its Operating Plan: o For actual events meeting the threshold criteria of Attachment 1, in accordance with Requirement R1 parts 1.1, 1.2 and 1.3</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>o For review and updating of the Operating Plan, in accordance with Requirement R1 parts 1.4 and 1.5” Note that I believe that if the SDT decides to not combine R2 and R3, then we disagree with the distinction between the two requirements.</p> <p><i>Requirements R2 and R3 have been combined. Requirement 1, Part 1.4 was removed.</i></p> <p>The division of implementing R1 through R2 and R3 as presented is “implementing” vs. “reporting”. We believe that the correct division should rather be “implementation” of the plan (which includes reporting) vs. revisions to the plan.</p> <p><i>The DSR SDT has updated Requirement R2 to read as: “R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1.”</i></p> <p><i>FERC Order 693 section 617 states “...the Commission directs the ERO to develop a</i></p>



Organization	Yes or No	Question 2 Comment
		<p><i>modification to EOP-004-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the Bulk-Power System to provide data...". In order for entities to provide data they are required to implement their Operating Plan.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Ameren</p>	<p>No</p>	<p>(1) The new wording while well intentioned, effectively does not add clarity and leads to confusion. From our perspective, R1, which requires and Operating Plan, which is defined by the NERC glossary as: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan."</p> <p><i>The DSR SDT has maintained Requirement 1 with the wording of "Operating Plan" which gives entities the flexibility of containing an Operating Process or Operating Procedure, as stated as "An Operating Plan may contain Operating Procedures and Operating Processes. Please note the use of "may contain" in the NERC approved definition.</i></p> <p><i>Requirement 1 now reads as"</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the</i></li> </ul>

Organization	Yes or No	Question 2 Comment
		<p><i>Responsible Entity's Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p>(2) Is not a proper location for an after-the-fact reporting standard? In fact it could be argued that after-the-fact reports in and of themselves do not affect the reliability of the bulk electric system.</p> <p><i>The DSR SDT does not agree with this comment. Reporting of an event will give the Electric Reliability Organization and your Reliability Coordinator the situational awareness of what has occurred on your part of the BES. Plus as described in your Operating Plan, you would have communicated the event as you saw fit. By broadcasting that an event has occurred you will increase the awareness of your company (as described in your Operating Plan) and increase the awareness of the Electric Reliability Organization and your Reliability Coordinator.</i></p> <p>(3) But considering the proposed standard as written with the Operating Plan in requirement R1, and implementation of the Operating Plan in requirement R2 (except the actual reporting which is in R3) and then R3 which requires implementing the reporting section R1.3, it is not clear how these requirements can be kept separate in either implementation nor by the CEA.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2).</i></p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>procedures.”</i></p> <p>(4) The second sentence in the second paragraph of “Rationale for R1” states: “The main issue is to make sure an entity can a) identify when an event has occurred and b) be able to gather enough information to complete the report.” This is crucial for a Standard like this that is intended to mandate actions for events that are frequently totally unexpected and beyond normal planning criteria. This language needs to be added to Attachment 1 by the DSR SDT as explained in the rest of our comments</p> <p><i>The DSR SDT has updated the Rationale for Part 1.2 (previous Part 1.3) to read as: “Part 1.2 could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information.” Whereas Part 1.2 now states:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Electric Power</p>	<p>No</p>	<p>AEP prefers to avoid requirements that are purely administrative in nature. Requirements should be clear in their actions of supporting of the BES. For example, we would prefer requirements which state what is to be expected, and allowing the entities to develop their programs, processes, and procedures accordingly. It has been our understanding that industry, and perhaps NERC as well, seeks to reduce the amount to administrative (i.e. document-based) requirements. We are confident</p>

Organization	Yes or No	Question 2 Comment
		<p>that the appropriate documentation and administrative elements would occur as a natural course of implementing and adhering to action-based requirements. In light of this perspective, we believe that that R1 and R2 is not necessary, and that R3 would be sufficient by itself. Our comments above notwithstanding, AEP strongly encourages the SDT to consider that R2 and R3, if kept, be merged into a single requirement as a violation of R2 would also be a violation of R3. Two violations would then occur for what is essentially only a single incident. Rather than having both R2 and R3, might R3 be sufficient on its own? R2 is simply a means to an end of achieving R3.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2).</i></p> <p>.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>If there is a need to explicitly reference implementation, that could be addressed as part of R1. For example, R1 could state “Each Responsible Entity shall implement an Operating Plan that includes...”R1 seems disjointed, as subparts 1.4 and 1.5 (updating and reviewing the Operating Plan) do not align well with subparts 1.1 through 1.3 which are process related. If 1.4 and 1.5 are indeed needed, we recommend that they be a part of their own requirement(s). Furthermore, the action of these requirements should be changed from emphasizing provision(s) of a process to demonstrating the underlying activity.</p>

Organization	Yes or No	Question 2 Comment
		<p><i>The DSR SDT has maintained Requirement 1 with the wording of “Operating Plan” which gives entities the flexibility of containing an Operating Process or Operating Procedure, as stated as “An Operating Plan may contain Operating Procedures and Operating Processes. Please note the use of “may contain” in the NERC approved definition.</i></p> <p><i>Requirement 1 now reads as “Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p><i>1.4 AEP is concerned by the vagueness of requiring provision(s) for updating the Operating Plan for “changes”, as such changes could occur frequently and unpredictably.</i></p> <p><i>Part 1.4 was removed from the standard.</i></p> <p><i>It is the sole responsibility of the Applicable Entity to determine when an annual review of the Operating Plan is required. The Operating Plan has the minimum requirement for an annual review. You may review your Operating Plan as often as you see appropriate.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Occidental Power Services,	No	Attachment 1 and R3 require event reports to be sent to the ERO and the entity’s RC and to others “as appropriate.” Although this gives the entity some discretion, it

Organization	Yes or No	Question 2 Comment
Inc. (OPSI)		<p>might also create some “Monday morning quarterbacking” situations. This is especially true for the one hour reporting situations as personnel that would be responding to these events are the same ones needed to report the event. OPSI suggests that the SDT reconsider and clarify reporting obligations with the objective of sending initial reports to the minimum number of entities on a need-to-know basis.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan.</i></p> <p><i>The DSR SDT also received many comments regarding the various events of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO and their Reliability Coordinator within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is “A reportable Cyber Security Incident” as it required by CIP-008.</i></p> <p><i>FERC Order 706, paragraph 673 states: “...each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but, in any event within one hour of the event...”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ingleside Cogeneration LP	No	<p>Attachment 1 and requirement R3 are written in a manner which would seem to indicate that internal personnel and law enforcement personnel would have to be copied on the submitted form - either Attachment 2 or OE-417. We believe the intent is to submit such forms to the appropriate recipients only (e.g.; the ERO and</p>

Organization	Yes or No	Question 2 Comment
		<p>the DOE). The requirement should be re-written to clarify that this is the case.</p> <p><i>The DSR SDT thanks you for your comment. Requirement 1 has been updated and now reads as"</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p><i>The Applicable Entity's Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and for communicating to others as defined in the Responsible Entity's Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity's Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your company's needs and wants.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>Both requirements are to implement the Operating Plan. Hence, R3 should be a bullet under R2 and not a separate requirement. In addition, for R2, the phrase "actual event" is ambiguous and should mean: "actual event that meets the criteria of Attachment 1" We suggest the following wording to R2 (which will result in eliminating R3)"Each Responsible Entity shall implement its Operating Plan: o For actual events meeting the threshold criteria of Attachment 1 in accordance with</p>

Organization	Yes or No	Question 2 Comment
		<p>Requirement R1 parts 1.1, 1.2 and 1.3</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>o For review and updating of the Operating Plan in accordance with Requirement R1 parts 1.4 and 1.5”Note that we believe that if the SDT decides to not combine R2 and R3, then we disagree with the distinction between the two requirements.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>The division of implementing R1 through R2 and R3 as presented is “implementing” vs. “reporting”. We believe that the correct division should rather be “implementation” of the plan (which includes reporting) vs. revisions to the plan.</p> <p><i>The DSR SDT has updated Requirement R2 to read as: “R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1.”</i></p> <p><i>FERC Order 693 section 617 states “...the Commission directs the ERO to develop a modification to EOP-001-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the</i></p>



Organization	Yes or No	Question 2 Comment
		<p><i>Bulk-Power System to provide data...". In order for entities to provide data they are required to implement their Operating Plan.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Indiana Municipal Power Agency</p>	<p>No</p>	<p>Both requirements seem to be implementing the Operating Plan which means R3 should be a bullet under R2 and not a separate requirement. IMPA supports making R2 and R3 one requirement and eliminating the current R3 requirement.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>"R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p> <p>In addition, R2 needs to be clarified when addressing an actual event. IMPA recommends saying "an actual event that meets the criteria of Attachment 1."</p> <p><i>The DSR SDT has implemented your suggestion.</i></p> <p><i>Requirement R2now reads as: "Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 2 Comment
CenterPoint Energy	No	<p>CenterPoint Energy believes the current R2 is unnecessary and duplicative. Upon reporting events as required by R3, entities will be implementing the relevant parts of their Operating Plan that address R1.1 and R1.2. This duplication is clear when reading M2 and M3. Acceptable evidence is an event report. R2 should be modified to remove this duplicative requirement.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Orange and Rockland Utilities, Inc./Consolidated Edison Co. Of NY, Inc.	No	<p>Comments:</p> <ul style="list-style-type: none"> <li>o R1.3 should be revised as follows: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as determined by the responsible entity: ["appropriate: - deleted] [otherwise it is not clear who determines what communication level is appropriate]</li> <li>o R1.4 should be revised as follows: Provision(s) for updating the Operating Plan following ["within 90 calendar days of any" - deleted] change in assets or personnel (if the Operating Plan specifies personnel or assets) , ["other circumstances" - deleted] that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3.</li> <li>o R1.5 should be deleted. Responsible Entities can determine the frequency of Operating Plan updates. Requirement 1.4 requires updating the Operating Plan within 90 calendar days for changes in “assets, personnel.... or incorporating lessons</li> </ul>

Organization	Yes or No	Question 2 Comment
		<p>learned”.</p> <p><i>Requirement 1 has been updated and now reads as”</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p>This requirement eliminates the need for Requirement 1.5 requiring a review of the Operating Plan on an annual basis.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
ISO New England	No	<p>In accordance with the results-based standards concept, all that is required, for the “what” is that company X reported on event Y in accordance with the reporting requirements in attachment Z of the draft standard. Therefore, we proposed the only requirement that is necessary is R3, which should be re-written to read...”Each</p>

Organization	Yes or No	Question 2 Comment
		<p>Responsible Entity shall report to address the events listed in Attachment 1."</p> <p><i>Requirement 1 and 2 is the basis of the "what" you have described in your comment. Whereas Attachment 1 contains a minimum list of events that apply to Requirement 1, this is why Requirement R2 was rewritten as: "R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1."</i></p> <p><i>The DSR SDT was directed to incorporate certain items such as; FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>	<p>No</p>	<p>It is confusing why R3 is not considered part of R2, which deals with implementation of the Operating Plan and it appears that R3 could be interpreted as double jeopardy. We suggest deleting R3.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>"R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 2 Comment
Oncor Electric Delivery Company LLC	No	<p>NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC considers ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.</p> <p><i>The Event Analysis Program may use a reported event as a basis to analyze an event. The reporting required in EOP-004-2 provides the input to the Events Analysis Process. The processes of the Event Analysis Program fall outside the scope of this project, but the DSR SDT has collaborated with them of events contained in Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
NV Energy	No	<p>On my read of the Standard, R2 and R3 appear to be duplicative, and I can't really distinguish the difference between the two. The action required appears to be the same for both requirements. Even the Measures for these two sound similar. It is not clear to me what it means to "implement" other than to have evidence of the existence and understanding of roles and responsibilities under the "Operating Plan." I suggest elimination of R2 and inclusion of a line item in Measure 1 calling for evidence of the existence of an "Operating Plan" including all the required elements in R1.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>"R2 Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p>

Organization	Yes or No	Question 2 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Northeast Power Coordinating Council</p>	<p>No</p>	<p>R1.3 should be revised as follows: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as determined by the responsible entity:...Without this change it is not clear who determines what communication level is appropriate.</p> <p><i>Requirement 1, Part 1.3 (now Part 1.2) was updated per comments received.</i></p> <p><i>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p>R1.4 should be revised as follows: Provision(s) for updating the Operating Plan following any change in assets or personnel (if the Operating Plan specifies personnel or assets), that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3. R1.5 should be deleted. Responsible Entities can determine the frequency of Operating Plan updates. Requirement 1.4 requires updating the Operating Plan within 90 calendar days for changes in “assets, personnel.... or incorporating lessons learned”, (or our preceding proposed revision).</p> <p><i>Requirement 1, part 1.4 has been deleted and Requirement R2 has been updated to read as: “R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>This requirement eliminates the need for Requirement 1.5 requiring a review of the Operating Plan on an annual basis.</p>

Organization	Yes or No	Question 2 Comment
		<p>The only true requirement that is results-based, not administrative and is actually required to support the Purpose of the Standard is R3.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i></p> <p><i>“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Illinois Municipal Electric Agency</p>	<p>No</p>	<p>R2 is not necessary, and should be removed. Subrequirement R1.4 is also not necessary and should be removed.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Kansas City Power &amp; Light</p>	<p>No</p>	<p>Requirement R1.1 is confusing regarding the “process for identifying events listed in Attachment 1”. Considering Attachment 1, the Events Table, already identifies the events required for reporting, please clearly describe in the requirement what the “process” referred to in requirement R1.1 represents.</p> <p><i>The DSR SDT has reviewed FERC Order 693 and paragraph 471 states: “...(2) specify</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>baseline requirement regarding what issues should be addressed in the procedures for recognizing sabotage events and making personnel aware of such events...”</i></p> <p><i>The DSR SDT has written Requirement 1, Part 1.1 to read as: “A process for recognizing each of the events listed in EOP-004 Attachment 1”. An Applicable Entity may rely on SCADA alarms as a process for recognizing an event or being made aware of an event through a scheduled Facility check. The DSR SDT has not been overly prescriptive on part 1.1 but has allowed each Applicable Entity to determine their own process for recognizing events listed in Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Luminant Power	No	<p>Requirements R1, R2, and R4 are burdensome administrative requirements and are contradictory to the NERC stated Standards Development goals of reducing administrative requirements by moving to performance requirements.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to indicate that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004</i></p>



Organization	Yes or No	Question 2 Comment
		<p><i>Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>There is only one Requirement needed in this standard: “The Responsible Entity shall report events in accordance with Attachment 1.” Attachment 1 should describe how events should be reported by what Entity to which party within a defined timeframe. If this requirement is met, all the other proposed requirements have no benefit to the reliability of the Bulk Electric System. Per the NERC Standard Development guidelines, only items that provide a reliability benefit should be included in a standard.</p> <p><i>The DSR SDT has updated Attachment 1 to a minimum threshold for Applicable Entities to report contained events. Requirement R2 has been updated to reflect that Applicable Entities shall implement their Operating Plan per Requirement 1 for events listed in Attachment 1. Requirement R2 reads as: “R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Xcel Energy</p>	<p>No</p>	<p>Suggest modifying R3 to indicate this is related to R 1.3.Each Responsible Entity shall report events to entities specified in R1.3 and as identified as appropriate in its Operating Plan.</p> <p><i>Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>(now R2)</i></p> <p><i>R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Colorado Springs Utilities	No	<p>The act of implementing the plan needs to include reporting events per R1, sub-requirement 1.3. R2 should simply state something like, "Each Responsible Entity shall implement the Operating Plan that meets the requirements of R1, as applicable, for an actual event or as specified." Suggest eliminating R3 which, seems to create double jeopardy effect.</p> <p><i>Requirement R2 was updated to reflect comments received to read as: "R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1." R3 was deleted.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Intellibind	No	<p>The language proposed is not clear and will continue to add confusion to entities who are trying to meet these requirements. It is not clear that the drafting team can put itself in the position of how the auditors will interpret and implement compliance against thithe R2 requirement. Requirements should be written to stand alone, not reference other requirements (or parts of the requirments. If the R1 parts 1.1, 1.2, 1.4 and 1.5 are so significant for this requirement, then they should be rewritten in R2.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Southern Company</p>	<p>No</p>	<p>These requirements as drafted in this revised standard potentially create a situation where an entity could be deemed non-compliant for both R2 and R3. For example, if a Responsible Entity included a reporting obligation in its Operating Plan, and failed to report an event, the Responsible Entity could be deemed non-compliant for R2 for not “implementing” its plan and for R3 for not reporting the event to the appropriate entities. A potential solution to address this would be to add Requirement 1, Part 1.3 to Requirement 2 and remove Requirement 3 in its entirety.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p>We also request clarification on Measure M3. Which records should have “dated and time-stamped transmittal records to show that the event was reported”? Some of the communication is handled via face-to-face conversation or through telephone</p>

Organization	Yes or No	Question 2 Comment
		<p>conversation.</p> <p><i>Measurement 3 has been deleted since Requirement 3 has been deleted. The new Measurement 2 allows for "...or other documentation". This may be in any form that the Applicable Entity wishes to maintain that they met Requirement 2. The Electric Reliability Organization does allow "Attestations" along with voice recordings as proof of compliance.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Independent Electricity System Operator</p>	<p>No</p>	<p>We agree with the revision to R2 and R3, but assess that a requirement to enforce implementation of Part 1.3 in Requirement R1 is missing. Part 1.3 in Requirement R1 stipulates that:1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate: o Internal company personnel o The Responsible Entity’s Regional Entity o Law enforcement o Governmental or provincial agenciesThe implementation of Part 1.3 is not enforced by R2 or R3 or any other Requirements in the standard. Suggest to add another requirement or expand Requirement R4 (and M4) to require the implementation of this Part in addition to verifying the process.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p><i>Requirement 1 has been updated and now reads as”</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <p><i>1.1 A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></p> <p><i>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Independent Electricity System Operator</p>	<p>Affirmative</p>	<p>The IESO believes that a requirement to enforce implementation of Part 1.3 in Requirement R1 is missing. Part 1.3 in Requirement R1 stipulates that: 1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:</p> <ul style="list-style-type: none"> <li>o Internal company personnel</li> <li>o The Responsible Entity’s Regional Entity</li> <li>o Law enforcement</li> <li>o Governmental or provincial agencies</li> </ul> <p>The implementation of Part 1.3 is not enforced by R2 or R3 or any other Requirements in the standard. The IESO suggests that another requirement be added or Requirement R4 (and M4) be expanded to require the implementation of this Part in addition to verifying the process.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>timeframe specified in EOP-004 Attachment 1.”</i></p> <p><i>Requirement 1 has been updated and now reads as”</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <p><i>1.1 A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></p> <p><i>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Bonneville Power Administration</p>	<p>Yes</p>	<p>BPA believes the measures for R2 are unclear since they are similar to R3’s reporting measures.</p>
<p><b>Response: Thank you for your comment. The SDT has revised the standard to have a single implementation requirement with a single associated measure.</b></p>		
<p>Compliance &amp; Responsibility Office</p>	<p>Yes</p>	<p>See comments in response to Question 4.</p>
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
<p>Constellation Energy on behalf of Baltimore Gas &amp; Electric, Constellation Power Generation, Constellation Energy Commodities Group,</p>	<p>Yes</p>	<p>While we support the delineation of the different activities associated with implementation and reporting, further clarification would be helpful. R1. 1.3: As currently written, it is somewhat confusing, in particular the use of the qualifier “as appropriate”.</p> <p><i>The DSR SDT has updated Requirement 1, Part 1.2 to read as: “A process for</i></p>

Organization	Yes or No	Question 2 Comment
<p>Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.</p>		<p><i>communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>In addition, the use of the word “communicating” to capture both reporting to reliability authorities and notifying others may leave the requirement open to question. Below is a proposed revision: 1.3 A process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan, such as:</p> <ul style="list-style-type: none"> <li>o Internal company personnel</li> <li>o The Responsible Entity’s Regional Entity</li> <li>o Law Enforcement</li> <li>o Government or provincial agencies</li> </ul> <p>R1, 1.4: the last phrase of the requirements seems to be leftover from an earlier version. The requirement should end after the word “Plan”.R1, 1.5: “Process” should not be capitalized. While we understand the intent of the draft language and appreciate the effort to streamline the requirements, we propose an adjusted delineation below that we feel tracks more cleanly to the structure of a compliance program. Proposed revised language:R2. Each Responsible Entity shall implement its Operating Plan to meet Requirement R1, parts 1.1 and 1.2 for an actual event(s).M2. Responsible Entities shall provide evidence that it implemented it Operating Plan to meet Requirement R1, Parts 1.1 and 1.2 for an actual event.</p> <p><i>The DSR SDT has updated Requirement 1, Part 1.2 to read as: “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator;</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>law enforcement governmental or provincial agencies.”</i></p> <p><i>The Applicable Entity’s Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your company’s needs and wants.</i></p> <p><i>DSR SDT has revised R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.</i></p> <p><i>DSR SDT has revised M2. “Each Responsible Entity will have, for each event experienced, a dated copy of the completed EOP-004 Attachment 2 form or DOE form OE-417 report submitted for that event; and dated and time-stamped transmittal records to show that the event was reported supplemented by operator logs or other operating documentation. Other forms of evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other operating documentation for situations where filing a written report was not possible.</i></p> <p>Evidence may include, but is not limited to, an submitted event report form (Attachment 2) or a submitted OE-417 report, operator logs, or voice recording.R3. Each Responsible Entity shall implement its Operating Plan to meet Requirement R1, parts 1.4 and 1.5.M3. Responsible Entities shall provide evidence that it implemented it Operating Plan to meet Requirement R1, Parts 1.4 and 1.5. Evidence may include, but is not limited to, dated documentation of review and update of the Operating Plan.</p>



Organization	Yes or No	Question 2 Comment
		<p>R4. Each Responsible Entity shall verify (through implementation for an actual event, or through a drill, exercise or table top exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification.</p> <p>M4. The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan for events created pursuant to Requirement R1, Part 1.3. Either implementation of the communication process as documented in its Operating Plan for an actual event or documented evidence of a drill, exercise, or table top exercise may be used as evidence to meet this requirement. The time period between verification shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a verification.</p> <p><i>Requirement 4 (now R3) was revised as:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p><i>M3. Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. (R3)</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Exelon	Yes	Why is the reference to R1.3 missing from EOP-004-2 Requirement R2?

Organization	Yes or No	Question 2 Comment
		<p><i>R1.3 was associated with implementation in R3 which was removed from the standard. DSR SDT has revised R2 to read as: "Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Pacific Northwest Small Public Power Utility Comment Group	Yes	
Southwest Power Pool Regional Entity	Yes	
BC Hydro	Yes	
ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi	Yes	
MRO NSRF	Yes	
Western Electricity Coordinating Council	Yes	
Imperial Irrigation District	Yes	
Santee Cooper	Yes	

Organization	Yes or No	Question 2 Comment
Sacramento Municipal Utility District (SMUD)	Yes	
SPP Standards Review Group	Yes	
Dominion	Yes	
FirstEnergy	Yes	
PPL Electric Utilities and PPL Supply Organizations`	Yes	
Electric Compliance	Yes	
PacifiCorp	Yes	
Arizona Public Service Company	Yes	
Salt River Project	Yes	
Westar Energy	Yes	
APX Power Markets (NCR-11034)	Yes	
Clallam County PUD No.1	Yes	
ITC	Yes	
Springfield Utility Board	Yes	

Organization	Yes or No	Question 2 Comment
Manitoba Hydro	Yes	
Duke Energy	Yes	
Liberty Electric Power	Yes	
Public Utility District No. 1 of Snohomish County	Yes	
South Carolina Electric and Gas	Yes	
American Transmission Company, LLC	Yes	
Nebraska Public Power District	Yes	
Seattle City Light	Yes	
PSEG	Yes	
MidAmerican Energy	Yes	
Georgia System Operations Corporation	Yes	
FEUS	Yes	
Lower Colorado River Authority	Yes	

Organization	Yes or No	Question 2 Comment
American Public Power Association	Yes	
Northeast Utilities	Yes	
City of Austin dba Austin Energy	Yes	
Energy Northwest - Columbia	Yes	
Electric Reliability Council of Texas, Inc.	Yes	
		R2 and R3 appear redundant.
Progress Energy		
Los Angeles Department of Water and Power		
Texas Reliability Entity		
ReliabilityFirst		
NRECA		
Entergy Services		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		

Organization	Yes or No	Question 2 Comment
Southwestern Power Administration		

3. The DSR SDT revised reporting times for many events listed in Attachment 1 from one hour to 24 hours. Do you agree with these revisions? If not, please explain in the comment area below.

**Summary Consideration:** The DSR SDT appreciates the industry comments on the difficulty associated with reporting events that impact reliability. However, the SDT desires to point out that it is not the objective of this standard to provide an analysis of the event; but to provide the known facts of the events at the reporting threshold of onehour or 24hours depending upon the type of event. The SDT worked with the DOE and the NERC EAWG to develop reporting timelines consistent between the parties in an effort to promote consistency and uniformity.

The SDT has not established any requirement for a final or follow up report. The obligation is to report the facts known at the time. Once the report has been provided to the parties identified in the Operating Plan, no further action is required. All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:

“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”

For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report, and is consistent with current in-force standard EOP-004-1.

Organization	Yes or No	Question 3 Comment
Ameren Services	Negative	(6)By our count there are still six of the nineteen events listed with a one hour reporting requirement and the rest are all within 24 hour after the occurrence (or recognition of the event). This in our opinion, is reporting in real-time, which is against one of the key concepts listed in the background section:"The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of

Organization	Yes or No	Question 3 Comment
		<p>standards). The proposed standard deals exclusively with after-the-fact reporting." <i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(7)We believe the earliest preliminary report required in this standard should at the close of the next business day. Operating Entities, such as the RC, BA, TOP, GOP, DP, and LSE should not be burdened with unnecessary after-the-fact reporting while they are addressing real-time operating conditions. Entities should have the ability to allow their support staff to perform this function during the next business day as needed. We acknowledge it would not be an undue burden to cc: NERC on other required governmental reports with shorter reporting timeframes, but NERC should not expand on this practice.</p> <p><i>No preliminary report is required within the revised standard. Also, timelines have been revised (Please see response to item (6) above).</i></p> <p>(8)We agree with the extension in reporting times for events that now have 24 hours of reporting time. As a GO there are still too many potential events that still require a 1 hour reporting time that is impractical, unrealistic and could lead to inappropriate escalation of normal failures. For example, the sudden loss of several control room display screens for a BES generator at 2 AM in the morning, with only 1 hour to report something, might be mistakenly interpreted as a cyber-attack. The reality is</p>



Organization	Yes or No	Question 3 Comment
		<p>most likely something far more mundane such as the unexpected failure of an instrument transformer, critical circuit board, etc.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(9) The "EOP-004 Attachment 1: Events Table" is quite lengthy and written in a manner that can be quite subjective in interpretation when determining if an event is reportable. We believe this table should be clear and unambiguous for consistent and repeatable application by both reliability entities and a CEA. The table should be divided into sections such as: 9a) Events that affect the BES that are either clearly sabotage or suspected sabotage after review by an entity's security department and local/state/federal law enforcement.(b) Events that pose a risk to the BES and that clearly reach a defined threshold, such as load loss, generation loss, public appeal, EEAs, etc. that entities are required to report by the end of the next business day.(c) Other events that may prove valuable for lessons learned, but are less definitive than required reporting events. These events should be reported voluntarily and not be subject to a CEA for non-reporting.(d)Events identified through other means outside of entity reporting, but due to their nature, could benefit the industry by an event report with lessons learned. Requests to report and perform analysis on these type of events should be vetted through a ERO/Functional Entity process to ensure resources provided to this effort have an effective reliability benefit.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li>• <i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li>• <i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></li> </ul> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>(10)Any event reporting shall not in any manner replace or inhibit an Entity's responsibility to coordinate with other Reliability Entities (such as the RC, TOP, BA, GOP as appropriate) as required by other Standards, and good utility practice to operate the electric system in a safe and reliable manner.</p> <p><i>The DSR SDT agrees and believes the revised reporting timelines support that concept.</i></p> <p>(11) The 1 hour reporting maximum time limit for all GO events in Attachment 1 should be lengthened to something reasonable - at least 24 hours. Operators in our energy centers are well-trained and if they have good reason to suspect an event</p>

Organization	Yes or No	Question 3 Comment
		<p>that might have serious impact on the BES will contact the TOP quickly. However, constantly reporting events that turn out to have no serious BES impact and were only reported for fear of a violation or self-report will quickly result in a cry wolf syndrome and a great waste of resources and risk to the GO and the BES. The risk to the GO will be potential fines, and the risk to the BES will be ignoring events that truly have an impact of the BES.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(12)The 2nd and 3rd Events on Attachment 1 should be reworded so they do not use terms that may have been deleted from the NERC Glossary by the time FERC approves this Standard.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>(13) The terms "destruction" and "damage" are key to identifying reportable events. Neither has been defined in the Standard. The term destruction is usually defined as 100% unusable. However, the term damage can be anywhere from 1% to 99%</p>

Organization	Yes or No	Question 3 Comment
		<p>unusable and take anywhere from 5 minutes to 5 months to repair. How will we know what the SDT intended, or an auditor will expect, without additional information?</p> <p><i>The 'Damage or Destruction' event category has been revised to say '...to a Facility', (a defined term) and thresholds have be modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term "Facility" to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p> <p style="padding-left: 40px;"><i>"A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)"</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>(14)We also do not understand why "destruction of BES equipment" (first item Attachment 1, first page) must be reported &lt; 1 hour, but "system separation (islanding) &gt; 100 MW" (Attachment 1, page 3) does not need to be reported for 24 hours.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(15)The first 2 Events in Attachment 1 list criteria Threshold for Reporting as “...operational error, equipment failure, external cause, or intentional or unintentional human action.” The term “intentional or unintentional human action” appears to cover “operational error” so these terms appear redundant and create risk of misreporting. Can this be clarified?</p> <p><i>The second event has been deleted and the language has been clarified in the ‘Threshold for Reporting’ column in the ‘Damage or Destruction’ event category. The updated Threshold for Reporting now reads as:</i></p> <p><i>“Damage or destruction of a Facility that:</i></p> <ul style="list-style-type: none"> <li><i>• Affects an IROL (per FAC-014)</i></li> <li><i>OR</i></li> <li><i>• Results in the need for actions to avoid an Adverse Reliability Impact</i></li> <li><i>OR</i></li> <li><i>• Results from intentional human action.”</i></li> </ul> <p>(16)The footnote of the first page of Attachment 1 includes the explanation “...ii) Significantly affects the reliability margin of the system...” However, the GO is prevented from seeing the system and has no idea what BES equipment can affect the reliability margin of the system. Can this be clarified by the SDT?</p> <p><i>The footnote has been deleted and relevant information moved to the ‘Threshold for Reporting column in the ‘Damage or Destruction’ event category.</i></p> <p>(17) The use of the term “BES equipment” is problematic for a GO. NERC Team 2010-</p>

Organization	Yes or No	Question 3 Comment
		<p>17 (BES Definition) has told the industry its next work phase will include identify</p> <p><i>The term “BES equipment” is no longer used. The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have been modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p> <p style="text-align: center;"><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Beaches Energy Services, City of Green Cove Springs</p>	<p>Negative</p>	<p>3. Att. 1, going from 1 to 24 hrs: The times don’t seem aggressive enough for some of the Events related to generation capacity shortages, e.g., we would think public appeal, system wide voltage reduction and manual firm load shedding ought to be within an hour. These are indicators that the BES is “on the edge” and to help BES reliability, communication of this status is important to Interconnection-wide reliability.</p> <p><i>This standard concerns after-the-fact reporting. It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. This standard does not preclude a Responsible Entity from reporting more quickly than required by Attachment 1.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>4. The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., “Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements”) so that changes to the RoP do not necessitate changes to the standard.</p> <p><i>The DSR SDT believes that although the evidence retention language is the same as the current RoP, it is not specifically linked, so changes to the RoP will not necessitate changes to the standard.</i></p> <p>In R4, it might be worth clarifying that, in this case, implementation of the plan for an event that does not meet the criteria of Attachment 1 and going beyond the requirements R2 and R3 could be used as evidence. Consider adding a phrase as such to M4, or a descriptive footnote that in this case, “actual event” may not be limited to those in Attachment 1.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1. ”</i></p> <p>Comments to Attachment 1 table: On “Damage or destruction of Critical Asset” and “... Critical Cyber Asset”, Version 5 of the CIP standards is moving away from the</p>

Organization	Yes or No	Question 3 Comment
		<p>binary critical/non-critical paradigm to a high/medium/low risk paradigm. Suggest adding description that if version 5 is approved by FERC, that “critical” would be replaced with “high or medium risk”, or include changing this standard to the scope of the CIP SDT, or consider posting multiple versions of this standard depending on the outcome of CIP v5 in a similar fashion to how FAC-003 was posted as part of the GO/TO effort of Project 2010-07.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>On “forced intrusion”, the phrase “at BES facility” is open to interpretation as “BES Facility” (e.g., controversy surrounding CAN-0016) which would exclude control centers and other critical/high/medium cyber system Physical Security Perimeters (PSPs). We suggest changing this to “BES Facility or the PSP or Defined Physical Boundary of critical/high/medium cyber assets”. This change would cause a change to the applicability of this reportable event to coincide with CIP standard applicability. On “Risk to BES equipment”, that phrase is open to too wide a range of interpretation; we suggest adding the word “imminent” in front of it, i.e., “Imminent risk to BES equipment”. For instance, heavy thermal loading puts equipment at risk, but not imminent risk. Also, “non-environmental” used as the threshold criteria is ambiguous. For instance, the example in the footnote, if the BES equipment is near railroad tracks, then trains getting derailed can be interpreted as part of that BES equipment’s “environment”, defined in Webster’s as “the circumstances, objects, or conditions by which one is surrounded”. It seems that the SDT really means “non-weather related”, or “Not risks due to Acts of Nature”.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen</i></p>



Organization	Yes or No	Question 3 Comment
		<p><i>because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p>On “public appeal”, in the threshold, the descriptor “each” should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event?</p> <p><i>To clarify your point, the threshold has been changed to ‘Public appeal or load reduction event’.</i></p> <p>Should LSE be an applicable entity to “loss of firm load”? As proposed, the DP is but the LSE is not. In an RTO market, will a DP know what is firm and what is non-firm load? Suggest eliminating DP from the applicability of “system separation”. The system separation we care about is separation of one part of the BES from another which would not involve a DP.</p> <p><i>The DSR SDT believes the current applicability is correct and the threshold provides sufficient discrimination to drive the proper Applicable Entities to report.</i></p> <p>On “Unplanned Control Center Evacuation”, CIP v5 might add GOP to the applicability, another reason to add revision of EOP-004-2 to the scope of the CIP v5 drafting team, or in other ways coordinate this SDT with that SDT. Consider posting a couple of versions of the standard depending on the outcome of CIP v5 in a similar fashion to the multiple versions of FAC-003 posted with the GO/TO effort of Project 2010-07.</p> <p><i>The DSR SDT believes the current applicability is correct. The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. Note that EOP-008-0 is only Applicable to Balancing Authorities, Transmission Operators and Reliability Coordinators, this is the basis for the “Entity with reporting Responsibilities” and reads as” “Each RC, BA, TOP that experiences the event”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Arkansas Electric Cooperative Corporation</p>	<p>Negative</p>	<p>AECC appreciates the efforts of the SDT to address our comments from the previous posting and feels the Standards have shown great improvement in the current posting. Our negative vote stems from concerns around the 1 hour reporting requirements for events having no size thresholds and ambiguity for external entity reporting in R1.3. Please refer to the comments submitted by the SPP Standards Review Group.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 3 Comment
PowerSouth Energy Cooperative	Negative	<p>Attachment 1 needs to be eliminated. It is confusing to operators and doesn't enhance the reliability of the BES.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Clark Public Utilities	Negative	<p>Attachment 1 provides confusion not clarification. Just use the OE-417 reporting form for any and all events identified in that form for any one-hour or six-hour reporting. Utilities are required by law to provide the DOE notification and the SDT has just confused the situation by attempting (as it appears) to rename the one-hour reporting events. In some instances, Attachment 1 contradicts the DOE reporting. Public appeals for load reduction are required within 24 hours (according to the Events Table) but OE-417 requires such public appeals to be reported within one</p>

Organization	Yes or No	Question 3 Comment
		<p>hour.</p> <p>Clark recommends the Events Table show first the one hour reporting of OE-417, then the six hour reporting of OE-417, and finally any additional reporting that is desired but not reportable to DOE. This will help in not confusing seemingly related events. The table should indicate which form is to be used and should mandate Form OE-417 for all DOE reportable events and the Attachment 2: Event Reporting Form for all reportable events not subject to the DOE reporting requirements.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>Clark questions whether the event labeled Forced Intrusion really needs to be reported in one hour. It can take several hours to determine if a forced entry actually occurred. Clark is also unsure if reporting forced intrusions at these facilities (if no other disturbance occurs) will provide any information useful in preventing system disturbances but believes this event should be changed to a 24 hour notification.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>The event labeled Detection of a reportable Cyber Security Incident should have the Entity with Reporting Responsibility changed to the following: “Applicable Entities under CIP-008.” The Threshold for Reporting on this event is based on the criteria in CIP-008. If an entity is not an applicable entity under CIP-008, it should not have a reporting requirement based on CIP-008 that appears in EOP-004.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
City of Farmington	Negative	<p>Attachment 1: BES equipment is too vague - consider changing to BES facility and including that reduces the reliability of the BES in the footnote. Is the footnote an and or an or?</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>Attachment 1: Version 5 of CIP Requirements the use of the terms Critical Asset and Critical Cyber Asset. The drafting team should consider revising the table to be flexible so it will not require modification when new versions of CIP become effective. Clarify if Damage or Destruction is physical damage (aka - cyber incidents would be part of CIP-008 covered separately in Attachment 1.)</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Attachment 1: Unplanned Control Center evacuation - remove “potential” from the reporting responsibility Attachment 1:</p> <p><i>The ‘potential’ language has been removed. The threshold for Reporting now reads as: “Each RC, BA, TOP that experiences the event”.</i></p> <p>SOL Tv - is not defined.</p> <p><i>The SOL Violation (WECC only) event has been revised to remove Tv and replace it with “30 minutes” to be consistent with TOP-007-WECC requirements. The event has</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>also been revised to indicate an SOL associated with a Major WECC transfer path.</i></p> <p>Attachment 2 - 3: change to, “Did the event originate in your system?” The requirement only requires reporting for Events - not potential events. This implies if there is potential for an event to occur, the entity should report (potential of a public appeal or potential to shed firm load)</p> <p><i>The ‘actual or potential’ language has been removed.</i></p> <p>Attachment 2 4: “Damage or Destruction to BES equipment” should be “Destruction of BES Equipment” like it is in Attachment 1 and “forced intrusion risk to BES equipment” remove “risk”</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘...to a Facility’, (a defined term) and thresholds have be modified to provide clarity. Also, the reporting timeline is now 24 hours.</i></p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>The OE-417 requires several of the events listed in Attachment 1 be reported within 1 hour. FEUS recommends the drafting team review the events and the OE-417 form and align the reporting window requirements. For example, public appeals, load shedding, and system separation have a 1 hour requirement in OE-417.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Wisconsin Public Service Corp.	Negative	<p>EOP-004 Attachment 1 states: That any Damage or destruction of a Critical Cyber Asset per CIP-002 Applicable Entities under CIP-002 Through intentional or unintentional human action. Requires reporting in 1 hour of recognition of event. This is too low of a threshold for reporting. Unintentional damage could be caused by an individual spilling coffee on a laptop. Hardly the item for a report.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		



Organization	Yes or No	Question 3 Comment
<p>ACES Power Marketing, Hoosier Energy Rural Electric Cooperative, Inc., Sunflower Electric Power Corporation, Great River Energy</p>	<p>Negative</p>	<p>For many of the events listed in Attachment 1, there would be duplicate reporting the way it is written right now. For example, in the case of a fire in a substation (Destruction of BES equipment), the RC, BA, TO, TOP and perhaps the GO and GOP could all experience the event and each would have to report on it. This seems quite excessive and redundant. We recommend eliminating this duplicate reporting.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Consumers Energy</p>	<p>Negative</p>	<p>Forced intrusion needs to be specifically defined. A 1-hour report requirement is not necessary but for critical events that would have wide-ranging impact.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>Requirements 2 and 3 should be combined into a single requirement.</p> <p><i>The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>MidAmerican Energy Co.</p>	<p>Negative</p>	<p>MidAmerican Energy believes Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. Based on our understanding of Attachment 1, the category of “damage or destruction of a critical cyber asset” will likely result in hundreds or thousands of small equipment failures being reported to NERC and DOE, with no improvement to security. For example, hard drive failures, server failures, PLC failures and relay failures could all meet the criteria of “damage or destruction of a critical cyber asset.” which would be required reporting in 1 hour.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>EOP-004-2 needs to clearly state that initial reports can be made by a phone call, email or another method, in accordance with paragraph 674 of FERC Order 706. MidAmerican recommends replacing Attachment 1 and Attachment 2 with the categories and timeframes that are listed in OE-417. This eliminates confusion between government requirements in OE-417 and NERC standards.</p> <p><i>Attachment 1 provides the flexibility to make a verbal report. The header of Attachment 1 states:</i></p> <p><i>“NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p><i>Attachment 2 provides the flexibility to make a verbal report. The header of Attachment 2 states:</i></p> <p><i>“This form is to be used to report events. The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports to the ERO should be submitted via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, voice: 609-452-1422.”</i></p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>EOP-004 requirements were designed to meet NERC and the industry’s needs;</i></li> </ul>

Organization	Yes or No	Question 3 Comment
		<p><i>accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></p> <ul style="list-style-type: none"> <li><i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>MidAmerican Energy Co.</p>	<p>Negative</p>	<p>MidAmerican Energy believes Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. EOP-004-2 needs to clearly state that initial reports can be made by a phone call, email or another method, in accordance with paragraph 674 of FERC Order 706. MidAmerican recommends replacing Attachment 1 and Attachment 2 with the categories and timeframes that are listed in OE-417. This eliminates confusion between government requirements in OE-417 and NERC standards.</p> <p><i>Attachment 1 provides the flexibility to make a verbal report. The header of Attachment 1 states:</i></p> <p><i>“NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p><i>Attachment 2 provides the flexibility to make a verbal report. The header of Attachment 2 states:</i></p> <p><i>“This form is to be used to report events. The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports to the ERO should be submitted via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, voice: 609-452-1422.”</i></p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Seattle City Light</p>	<p>Negative</p>	<p>Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes, as well as the CIP standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist. As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>Related to "Reportable Events" of Attachment 1: 1. A reportable event is stated as, "Risk to the BES", the threshold for reporting is, "From a non-environmental physical threat". This appears to be a catch-all event, and basically every other event in Attachment 1 should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>a threat, not when it may have first occurred.</i></p> <p>2. A reportable event is stated as, “Damage or destruction of Critical Asset per CIP-002”. The term “Damage” would have to be defined in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. One could argue that normal “Damage” can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard. Reporting Thresholds 1.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing. An example is the “BES Emergency requiring manual firm load shedding of greater than or equal to 100 MW or the Loss of Firm load for = 15 Minutes that is greater than or equal to 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases these low thresholds represent reporting of minor wind events or other seasonal system issues on Local Network used to provide distribution service.</p> <p><i>These thresholds reflect those used in the current in-force EOP-004-1, and haven’t congested the reporting process to date.</i></p> <p>Firm Demand 1. The use of Firm Demand in the context of the draft Standards could be used to describe commercial arrangements with a customer rather than a</p>

Organization	Yes or No	Question 3 Comment
		<p>reliability issue. Clarification of Firm Demand would be helpful</p> <p><i>The DSR SDT did not use the words 'Firm Demand' anywhere in the proposed standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Constellation Energy; Constellation Energy Commodities Group; Constellation Power Source Generation, Inc.</p>	<p>Negative</p>	<p>Please see the comments offered in the concurrent comment form. While Constellation is voting negative on this ballot, we recognize the progress made by the drafting team and find the proposal very close to acceptable. It should be noted that our negative vote is due to remaining concerns with the Attachment 1: Event Table categories language. In the comment form Constellation proposes revisions to both the requirement language and to the Event Table language; however, the Event Table language is the greater hurdle</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>



Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Salt River Project</p>	<p>Negative</p>	<p>Related to “Reportable Events” of Attachment 1: 1. A reportable event is stated as, “Risk to the BES”, the threshold for reporting is, “From a non-environmental physical threat”. This as appears to be a catch-all event, and basically every other event should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. A reportable event is stated as, “Damage or destruction of Critical Asset per CIP-002”. The term “Damage” would have to be defined in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. One could argue that normal “Damage” can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Southern California Edison Co.</p>	<p>Negative</p>	<p>SCE and WECC are in agreement on one key point (removing the requirement to</p>

Organization	Yes or No	Question 3 Comment
		<p>determine if an act was "sabotage"), however, I continue to believe SCE will find the one-hour reporting requirement difficult to manage.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
City of Redding	Negative	<p>The following comments are directed toward Attachment 1: We commend the SDT for properly addressing the sabotage issue. However, additional confusion is caused by introducing term "damage". As "damage" is not a defined term it would be beneficial for the drafting team to provide clarification for what is meant by "damage".</p> <p><i>The 'Damage or Destruction' event category has been revised to say '...to a Facility', (a defined term) and thresholds have be modified to provide clarity. Also, the reporting timeline is now 24 hours.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>The threshold for reporting “Each public Appeal for load reduction” should clearly state the triggering is for the BES Emergency as routine “public appeal” for conservation could be considered a threshold for the report triggering..</p> <p><i>The DSR SDT believes the current language of the event category ‘BES Emergency...’ clearly excludes routine conservation requests. The Threshold for Reporting has been updated to read as: “Public appeal for load reduction event”.</i></p> <p>Regarding the SOL violations in Attachment 1 the SOL violations should only be those that affect the WECC Paths.</p> <p><i>The SOL Violation (WECC only) event has been revised to remove Tv and replace it with “30 minutes” to be consistent with TOP-007-WECC requirements. The event is now “SOL for Major WECC Transfer Paths (WECC only)”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Avista Corp.	Negative	<p>The VSLs associated with not reporting in an hour for some of the events (Destruction of BES Equipment) is too severe. Operators need to be able to deal with events and not worry about reporting until the system is secure. Back office personnel are only available 40-50 hours per week, so the reporting burden falls on the Operator.</p> <p><i>The DSR SDT believes the VSL is appropriate for the only remaining 1 hour event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Avista Corp.	Negative	<p>There is definitely a need to communicate and report out system events to NERC, RCs, and adjacent utilities. However, this new standard has gone too far with regards to reporting of certain events within a 1 hour timeframe and the associated VSLs for going beyond the hour time period. Operators need to be able to deal with the system events and not worry about reporting out for the “Destruction of BES</p>

Organization	Yes or No	Question 3 Comment
		<p>equipment” (first row in Attachment 1 -Reportable Events). Operators only have 40-50 hours out of 168 hours in a week where supporting personnel are also on shift, so this reporting burden will usually fall on the Operators not back office support. Again this is another example of the documentation requirements of a standard being more important than actually operating the system.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>The “Destruction of BES equipment” event is too ambiguous and will lead to interpretations by auditors to determine violations. The ambiguity will also lead to the reporting of all BES equipment outages to avoid potential violations of the standard. It usually takes more than an hour to determine the cause and extent of an outage.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘...to a Facility’, (a defined term) and thresholds have been modified to provide clarity. Also, the reporting timeline is now 24 hours.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>National Association of Regulatory Utility Commissioners</p>	<p>Negative</p>	<p>Therequirement that any event with the potential to impact reliability be reported is overly broad and requires more focus.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ (which this footnote referenced) have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Alameda Municipal Power, Salmon River Electric Cooperative</p>	<p>Negative</p>	<p>We feel that the drafting team has done an excellent job of providing clarify and reasonable reporting requirements to the right functional entity. We support the modifications but would like to have two additional minor modification in order to provide additional clarification to the Attachment I Event Table. We suggest the following clarifications: For the Event: BES Emergency resulting in automatic firm load shedding Modify the Entity with Reporting Responsibility to: Each DP or TOP that experiences the automatic load shedding within their respective distribution serving or Transmission Operating area.</p> <p><i>The DSR SDT believes the current language is sufficient and cannot envision how a BA, TOP, or DP could ‘experience the automatic load shedding’ if it didn’t take place in its balancing, transmission operating, or distribution serving area.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>For the Event: Loss of Firm load for = 15 Minutes Modify the Entity with Reporting Responsibility to: Each BA, TOP, DP that experiences the loss of firm load within their respective balancing, Transmission operating, or distribution serving area. With these modifications or similar modifications we fully support the proposed Standard.</p> <p><i>The DSR SDT believes the current language is sufficient and cannot envision how a BA, TOP, or DP could 'experience the loss of firm load' if it didn't take place in its balancing, transmission operating, or distribution serving area.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Orange and Rockland Utilities, Inc.</p>	<p>No</p>	<p>o Generally speaking the SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language. o EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded. o If the list of reportable events is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and in the EAP Categories 1 through 5.</p> <p><i>OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may</i></li> </ul>

Organization	Yes or No	Question 3 Comment
		<p><i>trigger further information requests from EAWG as necessary</i></p> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>o It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>o Event: “Risk to BES equipment” should be deleted. This is too vague and subjective. Will result in many “prove the negative” situations.’</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>o Event: “Destruction of BES equipment” is again too vague. The footnote refers to equipment being “damaged or destroyed”. There is a major difference between</p>

Organization	Yes or No	Question 3 Comment
		<p>destruction and damage.</p> <p><i>The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have been modified to provide clarity.</i></p> <p>o Event: "Damage or Destruction of a Critical Asset or Critical Cyber Asset" should be deleted. Disclosure policies regarding sensitive information could limit an entity's ability to report. Unintentional damage to a CCA does not warrant a report.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>o Event: "BES Emergency requiring public appeal for load reduction" should be modified to note that this does not apply to routine requests for customer conservation during high load periods</p> <p><i>The DSR SDT believes the current language of the event category 'BES Emergency...' clearly excludes routine conservation requests.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ameren	No	<p>(1)By our count there are still six of the nineteen events listed with a one hour reporting requirement and the rest are all within 24 hour after the occurrence (or recognition of the event). This in our opinion, is reporting in real-time, which is against one of the key concepts listed in the background section:"The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of</p>



Organization	Yes or No	Question 3 Comment
		<p>standards). The proposed standard deals exclusively with after-the-fact reporting."</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>(2)We believe the earliest preliminary report required in this standard should at the close of the next business day. Operating Entities, such as the RC, BA, TOP, GOP, DP, and LSE should not be burdened with unnecessary after-the-fact reporting while they are addressing real-time operating conditions. Entities should have the ability to allow their support staff to perform this function during the next business day as needed. We acknowledge it would not be an undue burden to cc: NERC on other required governmental reports with shorter reporting timeframes, but NERC should not expand on this practice.</p> <p><i>No preliminary report is required within the revised standard.</i></p> <p>(3)We agree with the extension in reporting times for events that now have 24 hours of reporting time. As a GO there are still too many potential events that still require</p>

Organization	Yes or No	Question 3 Comment
		<p>a 1 hour reporting time that is impractical, unrealistic and could lead to inappropriate escalation of normal failures. For example, the sudden loss of several control room display screens for a BES generator at 2 AM in the morning, with only 1 hour to report something, might be mistakenly interpreted as a cyber-attack. The reality is most likely something far more mundane such as the unexpected failure of an instrument transformer, critical circuit board, etc.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Duke Energy	No	<p>All events in Attachment 1 should have reporting times of no less than 24 hours. As stated on page 6 of the current draft of the standard: "The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting."We maintain</p>

Organization	Yes or No	Question 3 Comment
		<p>that a report which is required to be made within one hour after an event is, in fact, a real time report. In the first hour or even several hours after an event the operator may appropriately still be totally committed to restoring service or returning to a stable bulk power system state, and should not stop that recovery activity in order to make this “after-the-fact” report.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Public Power Association</p>	<p>No</p>	<p>APPA echoes the comments made by Central Lincoln: We do not believe the SDT has adequately addressed the FERC Order to “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely “recognition” starts the clock and reporting will become a higher</p>

Organization	Yes or No	Question 3 Comment
		<p>priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition. APPA recommends the SDT evaluate a less burdensome requirement for smaller entities with reporting requirements in Attachment 1. This exception needs to address the fact that not all entities have 24 hour 7 day a week operating personnel.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p> <p>However, APPA cautions the SDT that changes to this standard may expose entities to reporting violations on DOE-OE-417 which imposes civil and criminal penalties on reporting events to the Department of Energy. APPA recommends that the SDT reach out to DOE for clarification of reporting requirements for DOE-OE-417 for small entities, asking DOE to change their reporting requirement to match EOP-004-2. If</p>

Organization	Yes or No	Question 3 Comment
		<p>DOE cannot change their reporting requirement the SDT should provide an explanation in the guidance section of Reliability Standard EOP-004-2 that addresses these competing FERC/DOE directives.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
BC Hydro	No	<p>As an event would be verbally reported to the RC, all the one hour requirements to submit a written report should be moved from one hour to 24 hours.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Bonneville Power Administration</p>	<p>No</p>	<p>BPA believes that the first three elements in Attachment 1 are too generic and should be with only the intentional human criterion. The suspicious device needs to be determined as a threat (and not left behind tools) before requiring a report.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. These thresholds include intentional human action as well as impact-based for those cases when cause isn’t known. The determination of a threat as you suggest is now part of the revised event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>CenterPoint Energy</p>	<p>No</p>	<p>CenterPoint Energy agrees with the revision that allows more time for reporting some events; however, some 1 hour requirements remain. The Company does not agree with this timeframe for any event.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p>Response: Thank you for your comment Please see response above.</p>		
<p>Consolidated Edison Co. of NY, Inc.</p>	<p>No</p>	<p>Comments: We have a number of comments on Attachment 1 and will make them here:</p> <ul style="list-style-type: none"> <li>o Generally speaking the SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language.</li> <li>o EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded.</li> <li>o If the list of reportable events</li> </ul>

Organization	Yes or No	Question 3 Comment
		<p>is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and in the EAP Categories 1 through 5.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>o It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘Any physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>o Event: “Risk to BES equipment” should be deleted. This is too vague and subjective. Will result in many “prove the negative” situations.’</p>



Organization	Yes or No	Question 3 Comment
		<p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>o Event: “Destruction of BES equipment” is again too vague. The footnote refers to equipment being “damaged or destroyed”. There is a major difference between destruction and damage.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity.</i></p> <p>o Event: “Damage or Destruction of a Critical Asset or Critical Cyber Asset” should be deleted. Disclosure policies regarding sensitive information could limit an entity’s ability to report. Unintentional damage to a CCA does not warrant a report.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>o Event: “BES Emergency requiring public appeal for load reduction” should be modified to note that this does not apply to routine requests for customer conservation during high load periods.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>The DSR SDT believes the current language 'BES Emergency...' clearly excludes routine conservation requests.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Electric Reliability Council of Texas, Inc.</p>	<p>No</p>	<p>Destruction of BES equipment: 1. Request that the term “destruction” be clarified.</p> <p><i>The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity.</i></p> <p>Damage or destruction of Critical Asset per CIP-002: 1. Request that the terms “damage” and “destruction” be clarified. 2. Is the expectation that an entity report each individual device or system equipment failure or each mistake made by someone administering a system?</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>3. Request that “initial indication of the event” be changed to “confirmation of the event”. Event monitoring and management systems may receive many events that are determined to be harmless and put the entity at no risk. This can only be determined after analysis of the associated events is performed.</p> <p><i>The 'initial indication of the event' is no longer part of the threshold for 'Damage or Destruction of a Facility'</i></p> <p>Risk to BES equipment: Request that the terms “risk” be clarified.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'.</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Exelon</p>	<p>No</p>	<p>Due to the size of the service territories in ComEd and PECO it's difficult to get to some of the stations within in an hour to analyze an event which causes concern with the 1 hour criteria. It is conceivable that the evaluation of an event could take longer then one hour to determine if it is reportable. Exelon cannot support this version of the standard until the 1 hour reporting criteria is clarified so that the reporting requirements are reasonable and obtainable. Exelon has concerns about the existing 1 hour reporting requirements and feels that additional guidance and verbiage is required for clarification. We would like a better understanding when the 1 hour clock starts please consider using the following clarifying statement, in the statements that read, "recognition of events" please consider replacing the word "recognition" with the word "confirmation" as in a "confirmed event"</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Energy Northwest - Columbia</p>	<p>No</p>	<p>Energy Northwest - Columbia (ENWC) has concerns about the existing 1 hour reporting requirements and feels that additional guidance and verbiage is required for clarification. ENWC would like the word "recognition" in the statement that reads, "recognition of events," be replaced by "confirmation" as in "confirmed event."Also, we would like clarification as to when the 1 hour clock starts. Please consider changing recognition in "within 1 hour of recognition of event" and incorporating in "confirmation."</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 3 Comment
Indiana Municipal Power Agency	No	<p>IMPA believes that some of the times may not be aggressive enough that are related to generation capacity shortages.</p> <p><i>This standard concerns after-the-fact reporting. It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. This standard does not preclude a Responsible Entity from reporting more quickly than required by Attachment 1.</i></p> <p>In addition, IMPA believes clarity needs to be added when saying within 1 hour of recognition of event. For example, A fence cutting may not be discovered for days at a remote substation and then a determination has to be made if it was “forced intrusion” - Does that one hour apply once the determination is made that is was “forced intrusion” or from the time the discovery was made? Some of the 1 hour time limits can be expanded to allow for more time, such as forced intrusion, destruction of BES equipment, Risk to BES equipment, etc.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘Any physical threat that could impact the operability of a Facility’. Timelines start at the moment the Responsible Entity determines the event represents a threat, not when it first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Luminant Power	No	<p>Luminant agrees with the changes the SDT made, however, the timeline should be modified to put higher priority activities before reporting requirements. The SDT should consider allowing entities the ability to put the safety of personnel, safety of the equipment, and possibly the stabilization of BES equipment efforts prior to initiating the one hour reporting timeline. Reporting requirements should not be prioritized above these important activities. The requirement to report one hour after the recognition of such an event may not be sufficient in all instances. Entities</p>

Organization	Yes or No	Question 3 Comment
		<p>should not have a potential violation as a result of putting these priority issues first and not meeting the one hour reporting timeline.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>Actions taken to maintain the reliability of the BES in real-time always take precedence over reporting. The revised thresholds should ensure there is no perverse driver to act differently.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
MidAmerican Energy	No	<p>MidAmerican Energy agrees with the direction of consolidating CIP-001, EOP-004 and portions of CIP-008. However, we have concerns with some of the events included in Attachment 1 and reporting timelines. EOP-004-2 needs to clearly state that initial reports can be made by a phone call, email or another method, in accordance with paragraph 674 of FERC Order 706.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>MidAmerican Energy believes draft Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. Based on our understanding of Attachment 1, the category of “damage or destruction of a critical cyber asset” will result in hundreds or thousands of small equipment failures being reported to NERC and DOE, with no improvement to security. For example, hard drive failures, server failures, PLC failures and relay failures could all meet the criteria of “damage or destruction of a critical cyber asset.”</p> <p><i>The DSR SDT agrees and the ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>We recommend replacing Attachment 1 and Attachment 2 with the categories and timeframes that are listed in OE-417. This eliminates confusion between government requirements in OE-417 and NERC standards.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may</i></li> </ul>

Organization	Yes or No	Question 3 Comment
		<p><i>trigger further information requests from EAWG as necessary</i></p> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>Reporting timelines and reporting form FERC Order 706, paragraph 676, directed NERC to require a responsible entity to “at a minimum, notify the ESISAC and appropriate government authorities of a cyber security incident as soon as possible, but, in any event, within one hour of the event, even if it is a preliminary report.” In paragraph 674, FERC stated that the Commission agrees that, in the “aftermath of a cyber attack, restoring the system is the utmost priority.” They clarified: “the responsible entity does not need to initially send a full report of the incident...To report to appropriate government authorities and industry participants within one hour, it would be sufficient to simply communicate a preliminary report, including the time and nature of the incident and whatever useful preliminary information is available at the time. This could be accomplished by a phone call or another method.” While FERC did not order completion of a full report within one hour in Order 706, the draft EOP-004 Attachment 1 appears to require submittal of formal reports within one hour for six of the categories, unless there have been “certain adverse conditions” (in which case, as much information as is available must be submitted at the time of notification).</p> <p><i>It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. As stated above, all one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673. For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions, which would certainly include the aftermath of a cyber attack that had</i></p>



Organization	Yes or No	Question 3 Comment
		<p><i>major impact on the BES.</i></p> <p>The Violation Severity Levels are extreme for late submittal of a report. For example, it would be a severe violation to submit a report more than three hours following an event for an event requiring reporting in one hour.</p> <p><i>The DSR SDT believes the VSL is appropriate now that it only applies to the remaining 1 hour reportable event, which is the Reportable Cyber Event under CIP-008.</i></p> <p>MidAmerican Energy suggests incorporating the language from FERC Order 706, paragraph 674, into the EOP-004 reporting requirement to allow preliminary reporting within one hour to be done through a phone call or another method to allow the responsible entity to focus on recovery and/or restoration, if needed. MidAmerican Energy agrees with the use of DOE OE-417 for submittal of the full report of incidents under EOP-004 and CIP-008. We would note there are two parts to this form -- Schedule 1-Alert Notice, and Schedule 2-Narrative Description. Since OE-417 already requires submittal of a final report that includes Schedule 2 within 48 hours of the event, MidAmerican Energy believes it is not necessary to include a timeline for completion of the final report within the EOP-004 standard. We would note that Schedule 2 has an estimated public reporting burden time of two hours so it is not realistic to expect Schedule 2 to be completed within one hour. Events included in Attachment 1: MidAmerican Energy believes draft Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. The categories listed in Attachment 1 with one-hour reporting timelines cause the greatest concern. None of these categories are listed in OE-417, and all but the last row would not be considered a Cyber Security Incident under CIP-008, unless there was malicious or suspicious intent.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>	<p>No</p>	<p>No event should have a reporting time less than at the close of the next business day. Any reporting of an event that requires a less reporting time should only be to entities that can help mitigate an event such as an RC or other Reliability Entity.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 3 Comment
Southwestern Power Administration	No	<p>One hour is not enough time to make these assessments for all of the six items in attachment 1. All timing requirements should be made the same in order to simplify the reporting process.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
ITC	No	See comments to Question #4
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
Southern Company	No	<p>Southern request clarification on one of the entries in Attachment 1. The concern is with the last row on page 21 of Draft 3. What is the basis for "Voltage deviations"? The Threshold is <math>\hat{\pm}10\%</math> sustained for <math>\hat{\approx} 15</math> minutes. Is the voltage deviation based on the Voltage Schedule for that particular timeframe, or is it something else (pre-contingency voltage level, nominal voltage, etc.)?</p> <p><i>A sustained voltage deviation of <math>\pm 10\%</math> on the BES is significant deviation and is indicative of a shortfall of reactive resources either pre- or post-contingency. The DSR SDT is indifferent to which of nominal, pre-contingency, or scheduled voltage, is used</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>as the baseline, but for simplicity and to promote a common understanding suggest using nominal voltage.</i></p> <p>In addition, the second row of Attachment 1 lists “Damage or destruction of a Critical Cyber Asset per CIP-002” as a reportable event. The threshold includes “...intentional or unintentional human action” and gives us 1 hour to report. The term “damage” may be overly broad and, without definition, is not limited in any way. If a person mistypes a command and accidentally deletes a file, or renames something, or in any way changes anything on the CCA in error, then this could be considered “damage” and becomes a reportable event. The SDT should consider more thoroughly defining what is meant by “damage”. Should it incorporate the idea that the essential functions that the CCA is performing must be adversely impacted?</p> <p><i>The DSR SDT agrees and the ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Lastly, no event should have a reporting time shorter than at the close of the next business day. Any reporting of an event that requires a shorter reporting time should only be to entities that can help mitigate an event such as an RC or other Reliability Entity.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
FEUS	No	<p>The OE-417 requires several of the events listed in Attachment 1 be reported within 1 hour. FEUS recommends the drafting team review the events and the OE-417 form and align the reporting window requirements. For example, public appeals, load shedding, and system separation have a 1 hour requirement in OE-417.</p> <p><i>OE-417 thresholds and reporting timelines were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America. Non-US Responsible Entities cannot be obligated to report in shorter timelines simply to make the two forms line up. The current in-force EOP-004 requires 24 hour reporting on the items you have identified and so does the latest version of EOP-004-2</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>SPP Standards Review Group</p>	<p>No</p>	<p>The purpose of the reporting requirement should be clear either in the text of the requirements or through an explanation that is embodied in the language of the approved set of standards. This would be consistent with a “Results-based” architecture. What is lacking in the proposed language of this standard is recognition that registered entities differ in size and relevance of their impact on the Bulk Electric System. Also, events that are reportable differ in their impact on the registered entity. A “one-size fits all” approach to this standard may cause smaller entities with low impact on the grid to take extraordinary measures to meet the reporting/timing requirements and yet be too “loose” for larger more sophisticated and impacting entities to meet the same requirements. Therefore, we believe language of the standard must clearly state the intent that entities must provide reports in a manner consistent with their capabilities from a size/reliability impact perspective and from a communications availability perspective. Timing requirements should allow for differences and consider these variables. Also, we would suggest including language to specifically exclude situations where communications facilities may not be available for reporting. For example, in situations where communications facilities have been lost, initial reports would be due within 6 hours of the restoration of those communication facilities.</p> <p><i>The DSR SDT has reviewed Attachment 1 and made revisions to Event types, used the NERC approved term ‘Facility’, and revised some of the language under ‘Entity with Reporting Responsibility’ to ensure that these reportable events correctly represent the relative impact to the BES. Also, all one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p> <p>We would also suggest that Attachment 1 be broken into two distinct parts such that those events which must be reported within 1 hour stand out from those events that have to be reported within 24 hours.</p> <p><i>The DSR SDT agrees and has implemented your suggestion.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Kansas City Power &amp; Light</p>	<p>No</p>	<p>The reportable events listed in Attachment 1 can be categorized as events that have had a reliability impact and those events that could have a reliability impact. The listed events that could have a reliability impact should have a 24 hour reporting requirement and the events that have had a reliability impact are appropriate at a 1 hour reporting. The following events with a 1 hour report requirement are recommended to change to 24 hour: Forced Intrusion and Risk to BES Equipment.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>In addition, the Attachment 1 Events Table is incomplete as many of the listed events are incomplete regarding reporting time requirements and event descriptions.</p> <p><i>Attachment 1 has been revised to more clearly indicate reporting timelines and some of the event descriptions were changed to add clarity.</i></p> <p>Also recommend removing (ii) from note 5 with event “Destruction of BES equipment” as this part of the note is already described in the event description and insinuates reporting of equipment losses that do not have a reliability impact.</p> <p><i>This footnote has been deleted</i></p> <p>The events, “Damage or destruction of Critical Asset per CIP-002” and “Damage or destruction of a Critical Cyber Asset per CIP-002”, does not have sufficient clarity regarding what that represents. A note similar in nature to Note 5 for BES equipment is recommended.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Los Angeles Department of Water and Power</p>	<p>No</p>	<p>The reporting time of within 1 hour of recognition for a "Forced Intrusion" (last event category on page 20 of Draft 3, dated October 25, 2011) when considered with the associated footnote “Report if you cannot reasonably determine likely motivation” is overly burdensome and unrealistic. What is “reasonably determine likely motivation” is too general and requires further clarity. For example, LADWP has numerous facilities with extensive perimeter fencing. There is a significant</p>



Organization	Yes or No	Question 3 Comment
		<p>difference between a forced intrusion like a hole or cut in a property line fence of a facility versus a forced intrusion at a control house. Often cuts in fences, after further investigation, are determined to be cases of minor vandalism. An investigation of this nature will take much more than the allotted hour. The NERC Design Team needs to develop difference levels for the term “Force Intrusion” that fit the magnitude of the event and provide for adequate time to determine if the event was only a case of minor vandalism or petty thief. The requirement, as currently written, would unnecessarily burden an entity in reporting events that after given more time to investigate would more than likely not have been a reportable event.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Northeast Power Coordinating Council</p>	<p>No</p>	<p>The SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language. EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded. If the list of reportable events is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and</p>

Organization	Yes or No	Question 3 Comment
		<p>in the EAP Categories 1 through 5.</p> <p><i>OE-417 thresholds and reporting timelines were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America. Non-US Responsible Entities cannot be obligated to report in shorter timelines simply to make the two forms line up. The current in-force EOP-004 requires 24 hour reporting on the items you have identified and so does the latest version of EOP-004-2</i></li> <li><i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>Event: Risk to BES equipment should be deleted. This is too vague and subjective. This will result in many “prove the negative” situations.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>Event: Damage or Destruction of a Critical Asset or Critical Cyber Asset should be deleted. Disclosure policies regarding sensitive information could limit an entity’s ability to report. Unintentional damage to a CCA does not warrant a report.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Event: BES Emergency requiring public appeal for load reduction should be modified to note that this does not apply to routine requests for customer conservation during high load periods.</p> <p><i>The DSR SDT believes the current language of the event category ‘BES Emergency...’ clearly excludes routine conservation requests.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>The times don’t seem aggressive enough for some of the Events related to generation capacity shortages, e.g., we would think public appeal, system wide voltage reduction and manual firm load shedding ought to be within an hour. These are indicators that the BES is “on the edge” and to help BES reliability,</p>

Organization	Yes or No	Question 3 Comment
		<p>communication of this status is important to Interconnection-wide reliability.</p> <p><i>This standard concerns after-the-fact reporting. It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. This standard does not preclude a Responsible Entity from reporting more quickly than required by Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>NorthWestern Energy</p>	<p>Affirmative</p>	<p>In Attachment 1 NorthWestern Energy does not agree with the Transmission loss event, the threshold for reporting is “Unintentional loss of Three or more Transmission Facilities (excluding successful automatic reclosing).” There are lots of instances where this can happen and not have any major impacts to the BES. This reporting requirement is stemming from the Event Analysis Reporting Requirements and in many instances does not constitute an emergency.</p> <p><i>You are correct. This event is used as a trigger to the Events Analysis Process.</i></p> <p>Also, in Attachment 1 it is not clear when the DOE OE-417 form MUST be submitted. It give an option to use this form or another form but does not state when it must be used - confusing.</p> <p><i>For the purposes of EOP-004, Responsible Entities may use either Attachment 2 or OE-417. Submission of OE-417 to the DOE is mandatory for US entities and outside the scope of NERC. Giving you the option to submit OE-417 to NERC and your RC to satisfy EOP-004 is permitted as a matter of convenience so you don’t have to submit two different forms for the same event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Rutherford EMC</p>	<p>Affirmative</p>	<p>The SDT should consider adding a clause in the standard exempting small DP/LSEs</p>

Organization	Yes or No	Question 3 Comment
		<p>from the standard if the DP/LSE annually reviews and approves that it owns no facilities or equipment creating an event as described in Attachment 1.</p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Fort Pierce Utilities Authority	Affirmative	<p>The triggering event “Detection of a reportable Cyber Security Incident” listed in Attachment 1 assigns essentially all utilities reporting responsibility. This is not in line its reporting threshold, which is an event meeting the criteria in CIP-008. Shouldn’t the responsibility fall on only those responsible for compliance with CIP-008, version 3 or 4, as determined by CIP-002? The SDT should also give additional consideration to necessary provisions to make it align with the proposed CIP-008-5.</p> <p><i>The ‘Entity with Reporting Responsibility’ has been changed to reflect your comment to ‘Each Responsible Entity applicable under CIP-008 that experiences the Cyber Security Incident.’</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Nebraska Public Power District	Yes	<p>Although 24 hours is a vast improvement, one business day would make more sense for after the fact reporting.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
FirstEnergy	Yes	<p>Although we agree with the timeframes for reporting, we have other concerns as listed in our response to Question 4.</p>
<p><b>Response: Thank you for your comment. Please see response to question 4.</b></p>		
Intellibind	Yes	<p>Does this reporting conflict with reporting for DOE, and Regions? If so, what reporting requirements will the entity be held accountable to? Managing multiple reporting requirements for the multiple agencies is very problematic for entities and this standard should resolve those reporting requirements, as well as reduce the reporting down to one form and one submission. Reporting to ESISAC should take care of all reporting by the company. NERC should route all reports to the DOE, and regions through this mechanism.</p> <p><i>OE-417 thresholds and reporting timelines were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America. Non-US Responsible Entities cannot be obligated to report in shorter timelines simply to make the two forms line up. NERC has no control over the criteria in OE-417, which can change at any time</i></li> </ul>

Organization	Yes or No	Question 3 Comment
		<p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. NERC cannot take on the statutory obligation of US entities to report to the DOE.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Dominion</p>	<p>Yes</p>	<p>Dominion appreciates the changes that have been made to increase the 1 hr reporting time to 24 hours.</p>
<p><b>Response: Thank you for your comment.</b></p>		
<p>APX Power Markets (NCR-11034)</p>	<p>Yes</p>	<p>In my opinion the remaining items with 1 hour reporting requirements will in most cases require the input of in-complete information, since you maybe aware of the outage/disturbance, but not aware of any reason for it. If that is acceptable just to get the intial report that there was an outage/disturbance then we are OK. I believe it would help to have that clarified in the EOP, or maybe a CAN can be created for that.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>

Organization	Yes or No	Question 3 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Compliance &amp; Responsibility Office</p>	<p>Yes</p>	<p>See comments in response to Question 4.</p>
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
<p>Lower Colorado River Authority</p>	<p>Yes</p>	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>City of Austin dba Austin Energy</p>	<p>Yes</p>	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may</i></p>



Organization	Yes or No	Question 3 Comment
		<i>trigger further information requests from EAWG as necessary.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Public Utility District No. 1 of Snohomish County	Yes	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. The EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify if both forms will still be required to be submitted. We also need to ensure that there won’t be a duplication of efforts between the two reports. This is fairly minor, but the clarification need should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Seattle City Light	Yes	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. The EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify if both forms will still be required to be submitted. We also need to ensure that there won’t be a duplication of efforts between the two reports. This is fairly minor, but the clarification need should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		

Organization	Yes or No	Question 3 Comment
Salt River Project	Yes	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the NERC Event Analysis process, but there is some duplication of efforts. EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Constellation Energy on behalf of Baltimore Gas &amp; Electric, Constellation Power Generation, Constellation Energy Commodities Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.</p>	Yes	<p>We agree with the change to the reporting times in Attachment 1. While this is an improvement, other concerns with the language in the events table language remain. Please see additional details below: General items:</p> <ul style="list-style-type: none"> <li>o All submission instructions (column 4 in Events Table) should qualify the recognition of the event as “of recognition of event as a reportable event.”</li> </ul> <p><i>Column 4 has been deleted. The table headings now state that Responsible Entities must submit the report within X hours of recognition of event.</i></p> <ul style="list-style-type: none"> <li>o Is the ES-ISAC the appropriate contact for the ERO given that these two entities are separate even though they are currently managed by NERC?</li> </ul> <p><i>Yes. This is the current reporting contact and this is the advice that the DSR SDT team received from NERC.</i></p> <p>In addition, are the phone numbers in the Attachment 1 NOTE accurate? Is it possible they will change in a different cycle than the standard?</p>

Organization	Yes or No	Question 3 Comment
		<p><i>Yes. The standard will require updating should the phone number change.</i></p> <p>Specific Event Language: o Destruction of BES Equipment, footnote: Footnote 1, item iii confuses the clarification added in items i. and ii. Footnote 1 should be modified to state BES equipment that (i) an entity knows will affect an IROL or has been notified the loss affects an IROL; (ii) significantly affects the reserve margin of a Balancing Authority or Reserve Sharing Group. Item iii should be dropped.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say “to a Facility’, (a defined term) and thresholds have be modified to provide clarity. Footnotes for this event have been deleted.</i></p> <p>o Damage or destruction of Critical Asset per CIP-002: Within the currently developing revisions to CIP-002 (version 5), Critical Asset will be retired as a glossary term. As well as addressing the durability of this event category, additional delineation is needed regarding which asset disruptions are to be reported. A CA as currently defined incorporates assets in a broad perspective, for instance a generating plant may be a Critical Asset. As currently written in Attachment 1, reporting may be required for unintended events, such as a boiler leak that takes a plant offline for a minor repair. Event #1 - Destruction of BES Equipment - captures incidents at the relevant equipment regardless of whether they are a Critical Asset or not. We recommend dropping this event. However, if reference to CIP-002 assets remains, it will be important to capture reporting of the events relevant to reliability and not just more events. o Damage or destruction of a Critical Cyber Asset per CIP-002: Because CCAs are defined at the component level, including this trigger is appropriate; however, as with CAs, the CCA term is scheduled to be retired under CIP-002 version 5.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>o Forced Intrusion: The footnote confuses the goal of including this event category. In addition, "forced" doesn't need to define the incident. Constellation proposes the following to better define the event: Intrusion that affects or attempts to affect the reliable operation of the BES (1)(1) Examples of "affecting reliable operation of the BES are": (i) device operations, (ii) protective equipment degradation, (iii) communications systems degradation including telemetered values and device status. o Risk to BES equipment: This category is too vague to be effective and the footnote further complicates the expectations around this event. The catch all concept of reporting potential risks to BES equipment is problematic. It's not clear what the reliability goal of this category is. Risk is not an event, it is an analysis. How are entities to comply with this "event", never mind within an hour? It appears that the information contemplated within this scenario would be better captured within the greater efforts underway by NERC to assess risks to the BES. This event should be removed from the Attachment 1 list in EOP-004.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' (which this footnote referenced) have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>o BES Emergency requiring system-wide voltage reduction: the Entity with Reporting Responsibility should be limited to RC and TOP.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>Entity with Reporting Responsibility states 'Initiating entity is responsible for reporting', which the DSR SDT feels is adequate direction in conjunction with the event: BES Emergency requiring system-wide voltage reduction.</i></p> <p>o Voltage deviations on BES Facilities: The Threshold for Reporting language needs more detail to explain +/- 10% of what? Proposed revision: <math>\hat{\pm}</math> 10% outside the voltage schedule band sustained for <math>\hat{\%}\%¥</math> 15 continuous minutes</p> <p>o IROL Violation (all Interconnections) or SOL Violation (WECC only): Should "Interconnections" be capitalized?</p> <p>o Transmission loss: The reporting threshold should provide more specifics around what constitutes Transmission Facilities. One minor item, under the Threshold for Reporting, "Three" does not need to be capitalized.</p> <p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Pacific Northwest Small Public Power Utility Comment Group</p>	<p>Yes</p>	<p>While we agree with the revisions as far as they went, we do not believe the SDT has adequately addressed the FERC Order to "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely "recognition" starts the clock and reporting will become a higher priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Clallam County PUD No.1</p>	<p>Yes</p>	<p>While we agree with the revisions as far as they went, we do not believe the SDT has adequately addressed the FERC Order to "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely "recognition" starts the clock and reporting will become a higher priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Illinois Municipal Electric Agency</p>	<p>Yes</p>	<p>With the understanding this is within 24 hrs., and good professional judgment determines the amount of time to report the event to appropriate parties.</p>
<p><b>Response: Thank you for your comment.</b></p>		
<p>Ingleside Cogeneration LP</p>	<p>Yes</p>	<p>Yes. Any reporting that is mandated during the first hour of an event must be subject to close scrutiny. Many of the same resources that are needed to troubleshoot and stabilize the local system will be engaged in the reporting - which will impair reliability if not carefully applied. We believe that the ERO should reassess the need for any immediate reporting requirements on a regular basis to confirm that it provides some value to the restoration process.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706,</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Southwest Power Pool Regional Entity	Yes	
ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi	Yes	
MRO NSRF	Yes	
Western Electricity Coordinating Council	Yes	
Imperial Irrigation District	Yes	



Organization	Yes or No	Question 3 Comment
ACES Power Marketing Standards Collaborators	Yes	
Santee Cooper	Yes	
Sacramento Municipal Utility District (SMUD)	Yes	
Electric Compliance	Yes	
PacifiCorp	Yes	
Arizona Public Service Company	Yes	
Westar Energy	Yes	
Springfield Utility Board	Yes	
Manitoba Hydro	Yes	
Xcel Energy	Yes	
Liberty Electric Power	Yes	
Colorado Springs Utilities	Yes	
Independent Electricity System Operator	Yes	
South Carolina Electric and	Yes	

Organization	Yes or No	Question 3 Comment
Gas		
ISO New England	Yes	
American Transmission Company, LLC	Yes	
PSEG	Yes	
American Electric Power	Yes	
Georgia System Operations Corporation	Yes	
NV Energy	Yes	
Occidental Power Services, Inc. (OPSI)	Yes	
Northeast Utilities	Yes	
Great River Energy	Yes	
Oncor Electric Delivery Company LLC	Yes	
PPL Electric Utilities and PPL Supply Organizations`		
Progress Energy		

Organization	Yes or No	Question 3 Comment
Texas Reliability Entity		
ReliabilityFirst		
NRECA		
Entergy Services		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		

4. Do you have any other comment, not expressed in questions above, for the DSR SDT?

**Summary Consideration:** The issues addressed in this question resulted in the DSR SDT reviewing and updating each requirement, Attachment 1 and Attachment 2. The DSR SDT has removed ambiguous language such as “risk” and “potential” based on comments received. All of the time frames in Attachment 1 have been moved to 24 hours upon recognition with the exception to reporting of CIP-008 events that remains one hour per FERC Order 706. Attachment 2 has been rewritten to mirror Attachment 1 events for entities who wish to use Attachment 2 in lieu of the DOE Form OE 417. VSLs have been reviewed to match the updated requirements.

Organization	Yes or No	Question 4 Comment
Cleco Corporation, Cleco Power, Cleco Power LLC	Abstain	Cleco does not use the VSL or VRF.
<b>Response: Thank you for your comment</b>		
Oklahoma Gas and Electric Co.	Abstain	Please see comments on SPP ballot
<b>Response: Thank you for your comment. See response to those comments.</b>		
Alberta Electric System Operator	Abstain	The Alberta Electric System Operator will need to modify parts of this standard to fit the provincial model when it develops the Alberta Reliability Standard.
<b>Response: Thank you for your comment.</b>		
Gainesville Regional Utilities	Affirmative	Looking forward to the added clarity.
<b>Response: Thank you for your comment.</b>		

Organization	Yes or No	Question 4 Comment
Manitoba Hydro	Affirmative	<p>Manitoba Hydro is voting affirmative but would like to point out the following issues:                      -Attachment 1: The term ‘Transmission Facilities’ used in Attachment 1 is capitalized, but it is not a defined term in the NERC glossary. The drafting team should clarify what is meant by ‘Transmission Facilities’ and remove the capitalization. –</p> <p><i>The DSR SDT has reviewed the NERC Glossary of Terms and notes that Transmission and Facilities are both defined. The combination of these two definitions are what the DSR SDT has based the applicability of “Transmission Facilities” in Attachment 1.</i></p> <p>Attachment 2: The inclusion of ‘fuel supply emergency’ in Attachment 2 creates confusion as it infers that reporting a ‘fuel supply emergency’ may be required by the standard even though it is not listed as a reportable event in Attachment 1. On a similar note, it is not clear what the drafting team is hoping to capture by including a checkbox for ‘other’ in Attachment 2.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Oncor Electric Delivery	Affirmative	<p>NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC consider ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.</p> <p><i>The reporting of events as required in EOP-004 is the input to the Events Analysis Program. Events are reported to the ERO and the EAP will follow up as per the EAP processes and procedures.</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>City Utilities of Springfield, Missouri</p>	<p>Affirmative</p>	<p>SPRM supports the comments from SPP.</p>
<p><b>Response: Thank you for your comment. Please see response to comments from SPP.</b></p>		
<p>Kootenai Electric Cooperative</p>	<p>Affirmative</p>	<p>The changes are an improvement over the existing standards.</p>
<p><b>Response: Thank you for your comment.</b></p>		
<p>Empire District Electric Co.</p>	<p>Affirmative</p>	<p>We agree with the comments provided by SPP</p>
<p><b>Response: Thank you for your comment. Please see response to SPP comments.</b></p>		
<p>Lakeland Electric</p>	<p>Negative</p>	<p>1. Further clarity is needed. For example the standard stipulates in R1.3 ".as appropriate." Who deems what is appropriate? Also in R1.4 ".other circumstances" is open to interpretation.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase "as appropriate" and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity's Operating Plan.</i></p> <p><i>Requirement R1, Part 1.4 was removed from the standard</i></p> <p>2. Remove paragraph 1 of the data retention section as it parrots the Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2. Possibly place a pointer to the CMEP in the data retention section.</p> <p><i>The item in question is standard boilerplate language that is being placed in all NERC standards.</i></p>

Organization	Yes or No	Question 4 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>CPS Energy</p>	<p>Negative</p>	<p>oR1.4: CPS Energy believes that “updating the Operating Plan within 90 calendar days of any change...” is a very burdensome compliance documentation requirement.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p> <p>oAttachment 1: Events Table: In DOE OE-417 local electrical systems with less than 300MW are excluded from reporting certain events since they are not significant to the BES. CPS Energy believes that the benefit of reporting certain events on systems below this value would outweigh the compliance burden placed on these small systems.</p> <p><i>Upon review of the DOE OE 417, it states “Local Utilities in Alaska, Hawaii, Puerto Rico, the U.S. Virgin Islands, and the U.S. Territories - If the local electrical system is less than 300 MW, then only file if criteria 1, 2, 3 or 4 are met”. Please be advised this exception applies to entities outside the continental USA.</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Lakeland Electric</p>	<p>Negative</p>	<p>An issue of possible differences in interpretation between entities and compliance monitoring and enforcement is the phrase in 1.3 that states “the following as appropriate”. Who has the authority to deem what is appropriate?</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Dynegy Inc.; Southern Illinois Power Coop.; Louisville Gas and Electric Co.</p>	<p>Negative</p>	<p>Comments submitted as part of the SERC OC; I agree with the comments of the SERC OC Standards Review group that have been provided to NERC.; We are a signatory to the SERC OC RRG comments filed last week.</p>
<p><b>Response: Thank you for your comment. Please see response to the SERC OC RRG comments.</b></p>		
<p>Hydro One Networks, Inc.</p>	<p>Negative</p>	<p>First and foremost we are not supportive of continuance of standards that are not "results based". Standards written to gather data, make reports etc. should not be written. There should be other processes for reporting in place that will not be subject to ERO oversight and further compliance burdens.</p> <p><i>The DSR SDT has been following the guidance set by NERC to write a "results based" standard. As with any process there may be many different ways to achieve the same outcome. The NERC Quality Process has not indicated any request to update this Standard, concerning the Results Based Standard format.</i></p> <p>o We are disappointed that the standard does not appear to reduce reporting requirements nor does it promote more efficient reporting. We encourage the SDT to take a results based approach and coordinate and reduce reporting through efficiencies between the various agencies and NERC.</p> <p><i>The DSR SDT is staying within scope of the approved SAR and will be forwarding your concern of efficiencies between various agencies and NERC</i></p> <p>o The Purpose statement is very broad, and "...by requiring the reporting of events with the potential to impact reliability and their causes..." on the Bulk Electric System it can be said that every event occurring on the Bulk Electric System would have to be reported. There is already an event analysis process in place. Could this reporting</p>



Organization	Yes or No	Question 4 Comment
		<p>be effectively performed in that effort?</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i></p> <p style="padding-left: 40px;"><i>“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”</i></p> <p>o The standard prescribes different sets of criteria, and forms.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>o There should be one recipient of event information. That recipient should be a</p>

Organization	Yes or No	Question 4 Comment
		<p>“clearinghouse” to ensure the proper dissemination of information.</p> <p><i>The DSR SDT is proposing revisions to the NERC Rules of Procedure that address your comment:</i></p> <p><i>812. NERC Reporting Clearinghouse</i>  <i>NERC will establish a system to collect report forms as established for this section or standard, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations.</i></p> <p>o Why is this standard applicable to the ERO?</p> <p><i>The ERO is applicable to CIP-008 and therefore is applicable to this proposed Standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>FirstEnergy Corp., FirstEnergy Energy Delivery, FirstEnergy Solutions, Ohio Edison Company</p>	<p>Negative</p>	<p>FirstEnergy appreciates the hard work of the drafting team and believes it has made great improvements to the standards. However, we must vote negative at this time until a few issues are clarified per our comments submitted through the formal comment period.</p>
<p><b>Response: Thank you for your comment. Please see response to your other comments.</b></p>		
<p>Lakeland Electric</p>	<p>Negative</p>	<p>In general; here has not been sufficient prudence review for the standard, especially R1, to justify a performance based standard around a Frequency Response Measure</p> <p><i>Based on your short comment, Requirement 1 has been modified as requested by stakeholders. The DSR SDT cannot answer the issue of Frequency Response Measures</i></p>

Organization	Yes or No	Question 4 Comment
		<i>since it is not within the scope of the SAR.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Northeast Power Coordinating Council	Negative	NPCC believes that further revision of the standard is necessary so is not able to support the VSLs at this time. Comments to the standard will be made in the formal comment period.
<b>Response: Thank you for your comment. Please see responses to your other comments.</b>		
Central Lincoln PUD; Blachly-Lane Electric Co-op; Central Electric Cooperative, Inc. (Redmond, Oregon); Clearwater Power Co.; Consumers Power Inc.; Coos-Curry Electric Cooperative, Inc; Fall River Rural Electric Cooperative; Lane Electric Cooperative, Inc.; Northern Lights Inc.; Pacific Northwest Generating Cooperative; Raft River Rural Electric Cooperative; Umatilla Electric Cooperative; West Oregon Electric Cooperative, Inc.; Cowlitz County PUD	Negative	Please see comments submitted by the Pacific Northwest Small Public Power Utility Comment Group.
<b>Response: Thank you for your comment. Please see responses to comments of the Pacific Northwest Small Public Power Utility</b>		

Organization	Yes or No	Question 4 Comment
<b>Comment Group.</b>		
Rochester Gas and Electric Corp.	Negative	RG&E supports comments to be submitted to NPCC.
New Brunswick System Operator	Negative	See comments submitted by the NPCC Reliability Standards Committee and the IRC Standards Review Committee.
Florida Municipal Power Pool	Negative	See FMPPA's comments
<b>Response: Thank you for your comment. See responses to those comments.</b>		
Commonwealth of Massachusetts Department of Public Utilities	Negative	<p>Standards written to gather data, make reports etc. should not be written. There should be other processes for reporting in place that will not be subject to ERO oversight and further compliance burdens.</p> <p><i>FERC Order 693 section 617 states "...the Commission directs the ERO to develop a modification to EOP-004-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the Bulk-Power System to provide data...". In order for entities to provide data they are required to implement their Operating Plan. EOP-004-2 will satisfy this FERC directive.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Hydro One Networks, Inc.	Negative	<p>Suggested key concepts for the SDT consideration in this standard: ? Develop a single form to report disturbances and events that threaten the reliability of the bulk electric system ? Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements ? Establish clear criteria for reporting ?</p> <p><i>The DSR SDT has only provided one form within this proposed Standard, please see</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 2. Based on stakeholder feedback, the DSR SDT has allowed stakeholders to use the DOE Form OE 417. Please note that not every Stakeholder in NERC wishes to use the DOE Form OE 417.</i></p> <p>Establish consistent reporting timelines ?</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>Provide clarity around who will receive the information and how it will be used ? Explore other opportunities beside a standard to effectively achieve the same outcome. Standards should be strictly results based, whose purpose is to achieve an adequate level of reliability on the BES.</p> <p><i>The DSR SDT has clearly stated who will receive the information: Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p><i>The information received will be mainly used for situational awareness and other processes.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Orlando Utilities Commission	Negative	<p>The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes, as well as the CIP standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist. As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
James A Maenner	Negative	<p>The information in section “5 Background” should be moved from the standard to a supporting document.</p> <p><i>The DSR SDT will refer to guidance within the Standards Development process on the proper place to maintain Background information.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>The reporting exemption language for weather in the Note on Attachment 1 - Events Table should be included in R3, not just a note.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p>The “Guideline and Technical Basis”, last 3 pages, should be moved from the standard to a supporting document.</p> <p><i>The Guideline and Technical Basis section is a part of the Results-Based Standard format and the information contained in it is in the correct place.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Kansas City Power &amp; Light Co.</p>	<p>Negative</p>	<p>The proposed Standard is in need of additional work to complete the Attachment 1, complete the VSL's, and clarify language and content within the proposed standard.</p> <p><i>The DSR SDT has reviewed and revamped all Requirements and both Attachments based on stakeholders feedback. This will provide clarity for entities to follow.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 4 Comment
SERC Reliability Corporation	Negative	<p>The purpose of the standard "To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities" has not been achieved as written. There is the potential for the information and data contemplated by this standard to be useful in achieving the stated purpose through follow-on activities of the industry, the regions, and NERC. However, as drafted, Attachment 1 will inform the ERO of the existence of only a portion of the "events with the potential to impact reliability and their causes, if known".</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></p> <p>Events listed in Appendix E to the ERO Event Analysis Process document should be incorporated into the standard instead of hardwiring inconsistency by requiring a different set of events. Alternatively, the SDT should explore deleting Attachment 1 and instead referencing the ERO Event Analysis process (which as a learning organization will have systematic changes to the reporting thresholds over time). At first this may seem contrary to the SDT objective of eliminating fill-in-the-blank aspects of the existing standard but the SDT should explore the Commission's willingness to accept a reference document for reporting thresholds. Additionally, it is unclear how NERC's role as the ES-ISAC is supported through the requirements of this reliability standard. It appears to undermine the ability of NERC (ES-ISAC) to be made timely aware of threats to the critical infrastructure--at odds with its purpose. Thus, this draft does not achieve the elimination of redundant reporting envisioned in the SAR, nor does it achieve the objective of supporting NERC in the analysis of disturbances or blackouts.</p> <p><i>The DSR SDT is following NERC's ANSI approved process for standards development.</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>The ERO Events Analysis process does not have the frame work as required by the ANSI development process. Within this proposed Standard, when an Attachment 1 event is recognized, the ERO (which is the ES-ISAC) will be one of the first to be notified, as will the entities Reliability Coordinator. This will enhance situational awareness as per the entity’s Operation Plan and this Standard.</i></p> <p><i>FERC Order 693 section 617 states “...the Commission directs the ERO to develop a modification to EOP-004-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the Bulk-Power System to provide data...”. In order for entities to provide data they are required to implement their Operating Plan. EOP-004-2 will satisfy this FERC directive.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Tucson Electric Power Co.	Negative	<p>The tie between an Operating Plan and reportable disturbance events is not clear. Being the exception, I feel that a reportable disturbance methodology should be part of an Emergency Operating Plan.</p> <p><i>EOP-004-2 provides Applicable Entities with the minimum report requirements for events contained in Attachment 1. NERC has defined Operating Plan in part as: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes." An entity may include a reportable disturbance methodology within their Operating Plan since this Standard does not preclude it.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
United Illuminating Co.	Negative	The VSL table is mistyped. R2 lists 1.1 and 1.5. R4 VRF should be lower.

Organization	Yes or No	Question 4 Comment
		<i>Requirement R4 (now R3) calls for conducting an annual test of the communications process in Requirement 1, Part 1.2. It is not strictly administrative in nature and therefore does not meet the VRF guideline for a Lower VRF. .</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
PSEG Energy Resources & Trade LLC, PSEG Fossil LLC, Public Service Electric and Gas Co.	Negative	There are several items that need clarification. See PSEG's separately provided comments.
<b>Response: Thank you for your comment. Please see response to your other comments.</b>		
Kansas City Power & Light Co.	Negative	There is no VSL for R4.  <i>The VSL for Requirement R4 was inadvertently redlined in the redline version of the standard, but it was present in the clean version.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Ameren Services	Negative	We believe that these [VRFs and VSLs] will change as we expect some changes in the draft standard.
<b>Response: Thank you for your comment.</b>		
New York State Department of Public Service	Negative	While the proposed standard consolidates many reporting requirements, the requirement that any event with the "potential to impact reliability" be reported is overly broad and will prove to be burdensome and distracting to system operations.  <i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i>

Organization	Yes or No	Question 4 Comment
		<p><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Springfield Utility Board		<p>o The Draft 3 Version History still lists the term "Impact Event" instead of "Event". <i>This has been corrected.</i></p> <p>o Draft 3 of EOP-004-2 - Event Reporting does not provide a definition for the term "Event" nor does the NERC Glossary of Terms Used in Reliability Standards. SUB recommends that "Event" be listed and defined in "Definitions and Terms Used in the Standard" as well as the NERC Glossary, providing a framework and giving guidance to entities for how to determine what should be considered an "Event" (ex: sabotage, unusual occurrence, metal theft, etc.).</p> <p><i>The DSR SDT has reviewed this issue and has changed "Event" to "event". Attachment 1 contains each reportable 'event'.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Northeast Utilities		<p>- Incorporate NERC Event Analysis Reporting into this standard. Make the requirements more specific to functional registrations as opposed to having requirements applicable to "Responsible Entities".- The description of a Transmission Loss Event in A</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1. The DSR SDT has reviewed and reworded "Entities with Reporting Responsibilities" to require the minimum amount of entities who will be required to report each event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 4 Comment
Progress Energy		<p>(1) Attachment 1 lists “Destruction of BES Equipment” as a reportable event but then lists “equipment failure” as one of several thresholds for reporting, with a one hour time limit for reporting. It is simply not common sense to think of the simple failure of a single piece of equipment as “destruction of BES equipment”. Does the standard really expect that every BES equipment failure must be reported within one hour, regardless of cause or impact to BES reliability? What is the purpose of such extensive reporting?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> </ul> <p>(2) The same comment as (1) above is applicable to the “Damage or destruction of Critical Asset” because one threshold is simple “equipment failure” as well.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>(3) Footnote 2 (page 20) says copper theft is not reportable “unless it effects the reliability of the BES”, but footnote 1 on the same page says copper theft is reportable if “it degrades the ability of equipment to operate properly”. In this instance, the proposed standard provides two different criteria for reporting one of the most common events on the same page.</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “A physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>(4) Forced Intrusion must be reported if “you cannot determine the likely motivation”, and not based on a conclusion that the intent was to commit sabotage or intentional damage. This would require reporting many theft related instances of cut fences and forced doors (including aborted theft attempts where nothing is stolen) which would consume a great deal of time and resources and accomplish nothing. This criteria is exactly the opposite of the existing philosophy of only reporting events if there is an indication of an intent to commit sabotage or cause damage.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p>(5) “Risk to BES equipment...from a non-environmental physical threat” is reportable, but this is an example of a vague, open ended reporting requirement that will either</p>

Organization	Yes or No	Question 4 Comment
		<p>generate a high volume of unproductive reports or will expose reporting entities to audit risk for not reporting potential threats that could have been reported. The standard helpfully lists train derailments and suspicious devices as examples of reportable events.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p>The existing CAN for CIP-001 (CAN-0016) is already asking for a list of events that were analyzed so the auditors can determine if a violation was committed due to failure to report. I can envision the CAN for this new standard requiring a list of all “non-environmental physical threats” that were analyzed during the audit period to determine if applicable events were reported. This could generate a great deal of work simply to provide audit documentation even if no events actually occur that are reportable. It would also be easy for an audit team to second guess a decision that was made by an entity not to report an event (what is risk?...how much risk was present due to the event?...). Also, the reporting for this vague criteria must be done within one hour. Any event with a one hour reporting requirement should be crystal clear and unambiguous.</p> <p><i>The DSR SDT has reworded and updated Attachment 1 per comments received and believes that the language used obviates the need for CAN-016. CAN-0016 has been</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>remanded.</i></p> <p>(6) Transmission Loss...of three or more Transmission Facilities” is reportable. “Facility” is a defined term in the NERC Glossary, but “Transmission Facility” is not a defined term, which will lead to confusion when this criteria is applied. This requirement raises many confusing questions. What if three or more elements are lost due to two separate or loosely related events - is this reportable or not? What processes will need to be put in place to count elements that are lost for each event and determine if reporting is required? Why must events be reported that fit an arbitrary numerical criteria without regard to any material impact on BES reliability?</p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p> <p style="text-align: center;"><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
MRO NSRF		<p>: The MRO NSRF wishes to thank the SDT for incorporating changes that the industry had with reporting time periods and aligning this with the Events Analysis Working Group and Department of Energy’s OE 417 reporting form.</p>

Organization	Yes or No	Question 4 Comment
<p>Response: Thank you for your comment.</p>		
<p>FirstEnergy</p>		<p>1. Attachment 1 - Regarding the 1st event listed in the table, “Destruction of BES Equipment” and its accompanying Footnote 1, we believe that this event should be broken into two separate events that incorporate the specifics in the footnote as follows: a. “Destruction of BES equipment that associated with an IROL per FAC-014-2.” Regarding the 1st event we have proposed - We have proposed this be made specific to IROL as stated in Footnote 1 part i. Also, we believe that only the RC and TOP would have the ability to quickly determine and report within 1 hour if the destruction is associated with an IROL. The other entities listed would not necessarily know if the event affects and IROL. Therefore, we also propose that the Entities with Reporting Responsibilities (column 2) be revised to only include the RC and TOP.</p> <p><i>The DSR SDT agrees with your comment and made the following changes:</i></p> <p><i>‘Threshold for Reporting’ column in the ‘Damage or Destruction’ event category. The updated Threshold for Reporting now reads as:</i></p> <p><i>“Damage or destruction of a Facility that:</i></p> <ul style="list-style-type: none"> <li><i>• Affects an IROL (per FAC-014)</i></li> <li><i>OR</i></li> <li><i>• Results in the need for actions to avoid an Adverse Reliability Impact</i></li> <li><i>OR</i></li> <li><i>• Results from intentional human action.”</i></li> </ul> <p>b. "Destruction of BES equipment that removes the equipment from service." Regarding the 3rd event we have proposed - We have proposed this be made specific to destruction of BES equipment that removes the equipment from service as stated in Footnote 1 part iii. Also, the other part of footnote 1 part iii which states “Damaged or destroyed due to intentional or unintentional human action” is not</p>



Organization	Yes or No	Question 4 Comment
		<p>required since it is covered in the threshold for reporting. Also the term “Damaged” in this part iii is not appropriate since these events are limited to equipment that has been destroyed. We also propose that the Entities with Reporting Responsibilities (column 2) for this event would remain the same as it states now since any of those entities may observe out of service BES equipment. Regarding part ii of footnote 1, we do not believe that this event needs to be separated. Regarding the phrase “significantly affects the reliability margin of the system be clarified so that it is not left up to the entity to interpret a “significant” affect. Lastly, since we have incorporated parts i and iii into the two separate events and removed part ii as proposed above, the only statement that needs to be left in the Footnote 1 is: “Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).”</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “Any physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>2. Attachment 1 - We ask that the team add an “Event #” column to the table so that each of the events listed can be referred to by #, such as Event 1, Event 2, etc.</p> <p><i>The DSR SDT believes that the minimum reporting attributes are contained in Attachment 1.</i></p> <p>3. Attachment 1 - Event titled “Damage or destruction of a Critical Cyber Asset per</p>

Organization	Yes or No	Question 4 Comment
		<p>CIP-002”, the proposed threshold for reporting seems incomplete. We suggest the threshold for this event match the threshold for the Critical Asset event which states: “Initial indication the event was due to operational error, equipment failure, external cause, or intentional or unintentional human action.”4. Attachment 1 - Events titled “Damage or destruction of a Critical Assets per CIP-002” and “Damage or destruction of a Critical Cyber Asset per CIP-002” seem ambiguous due to the term “damage”. We suggest removal of “damage” or clarity as to what is considered a damaged asset.5. VSL Table - Instead of listing every entity, it may be more efficient to simply say “The Responsible Entity” in the VSL for each requirement.6. Guideline and Technical Basis section - This section does not provide guidance on each of the requirements of the standard. We suggest the team consider adding guidance for the requirements.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Southwest Power Pool Regional Entity</p>		<p>1. EOP-004-2 R1.4 states entities must update their Operating Plans within 90 calendar days of incorporating lessons learned pursuant to R3. However, neither R3 nor Attachment 1 include a timeline for incorporating lessons learned. It is unclear when the “clock starts” on incorporating improvements or lessons learned. Within 90 days of what? 90 days of the event? 90 days from when management approved the lesson learned? Auditors need to know the trigger for the 90-day clock.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p> <p>2. The Event Analysis classification includes Category 1C “failure or misoperation of</p>

Organization	Yes or No	Question 4 Comment
		<p>the BPS SPS/RAS". This category is not included in EOP-004-2's Attachment 1. This event, "failure or misoperation of the BPS SPS/RAS", needs to either be added to Attachment 1 or removed from the Event Analysis classification. It is important that EOP-004-2 Attachment 1 and the Event Analysis categories match up. Thank you for your work on this standard.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Independent Electricity System Operator</p>		<p>1. Measures M1, M2 and M3: Suggest to achieve consistent wording among them by saying the leading part to "Each Responsible Entity shall provide...."</p> <p><i>The DSR SDT is following the guidance within the Standards Development process on</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>the wording pertaining to items outside the realm of a requirement.</i></p> <p>2. In our comments on the previous version, we suggested the SDT to review the need to include IA, TSP and LSE for some of the reporting requirements in Attachment 1. The SDT’s responded that it had to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, they will be subject to reporting. We accept this rationale. However, the revised Attachment 1 appears to be still somewhat discriminative on who needs to report an event. For example, the event of “Detection of a reportable Cyber Security Incident” (6th row in the table) requires reporting by a list of responsible entities based on the underlying requirements in CIP-008, but the list does not include the IA, TSP and LSE. We again suggest the SDT to review the need for listing the specific entities versus leaving it general by saying: “Applicable Entities under CIP-008” for this particular item, and review and establish a consistent approach throughout Attachment 1.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008.</i></p> <p>3. VSLs: a. Suggest to not list all the specific entities, but replace them with “Each Responsible Entity” to simplify the write-up which will allow readers to get to the violation condition much more quickly. b. For R1, it is not clear whether the conditions listed under the four columns are “OR” or “AND”. We believe it means “OR”, but this needs to be clarified in the VSL table.4. The proposed implementation plan conflicts with Ontario regulatory practice respecting the effective date of the standard. It is suggested that this conflict be removed by appending to the implementation plan wording, after “applicable regulatory approval” in the Effective Dates Section on P. 2 of the draft standard and P. 1 of the draft implementation plan, to the following effect: “, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.”</p> <p><i>The DSR SDT is following the guidance within the Standards Development process on</i></p>

Organization	Yes or No	Question 4 Comment
		<i>the wording pertaining to items outside the realm of a requirement.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
NRECA		<p>1. Please ensure that the work of the SDT is done in close coordination with Events Analysis Process (EAP) work being undertaken by the PC/OC and BOT, and with any NERC ROP additions or modifications. NRECA is concerned that the EAP work being done by these groups is not closely coordinated even though their respective work products are closely linked -- especially since the EAP references information in EOP-004.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>2. The SDT needs to be consistent in its use of "BES" and "BPS" - boths acronyms are used throughout the SDT documents. NRECA strongly prefers the use of "BES" since that is what NERC standards are written for.</p> <p><i>The DSR SDT has used BES within EOP-004-2. All references to BPS have been removed.</i></p> <p>3. Under "Purpose" section of standard, 3rd line, add "BES" between "impact" and "reliability." Without making this change the "Purpose" section could be misconstrued to refer to reliability beyond the BES.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><b><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></b></p> <p>4. In the Background section there is reference to the Events Analysis Program. Is that the same thing as the Events Analysis Process? Is it something different? Is it referring to a specific department at NERC? Please clarify in order to reduce confusion. Also in the Background section there is reference to the Events Analysis Program personnel. Who is this referring to -- NERC staff in a specific department? Please clarify.</p> <p><i>The DSR SDT was explaining that the DSR SDT and has been coordinating with the "Events Analysis Working Group.</i></p> <p>5. In M1 please be specific regarding what "dated" means.</p> <p><i>This is a common term used with many NERC Standards and simply means that your evidence is dated and time stamped.</i></p> <p>6. In M3 please make it clear that if there wasn't an event, this measure is not applicable</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has not implied that Applicable Entities need to prove that something did not happen.</i></p> <p>7. In R4 it is not clear what “verify” means. Please clarify.</p> <p><i>R4 (now R3) was revised to remove “verify”</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p>8. In Attachment 1 there are references to Critical Asset and Critical Cyber Asset. These terms will likely be eliminated from the NERC Glossary of Terms when CIP V5 moves forward and is ultimately approved by FERC. This could create future problems with EOP-004 if CIP V5 is made effective as currently drafted.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008.</i></p> <p>9. In Attachment 1 the one hour timeframe for submitting data for the first 7 items listed is very tight. Other than being required by the EOE )E-417 form, NRECA requests that the SDT provide further support for this timeframe. If there are not distinct reasons why 1 hour is the right timeframe for this, then other timeframes should be explored with DOE.</p> <p><i>The DSR SDT also received many comments regarding the various events of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO and their Reliability Coordinator within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is “A reportable Cyber</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Security Incident” as it required by CIP-008.</i></p> <p><i>FERC Order 706, paragraph 673 states: “...each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but, in any event within one hour of the event...”</i></p> <p><i>Note that members of NRECA may be required to submit the DOE Form OE 417, and this agency’s reporting requirements are not within scope of the project.</i></p> <p>10. While including Footnote 1 is appreciated, NRECA is concerned that this footnote will create confusion in the compliance and audit areas and request the SDT to provide more definitive guidance to help explain what these "Events" refer to. NRECA has the same comment on Footnote 2 and 3. Specifically in Footnote 3, how do you clearly determine and audit from a factual standpoint something that “could have damaged” or “has the potential to damage the equipment?”</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “A physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>11. In the Guideline and Technical Basis section, in the 1st bullet, how do you determine, demonstrate and audit for something that “may impact” BES reliability?</p> <p><i>This statement has been removed per comments received.</i></p> <p>12. On p. 28, first line, this sentence seems to state that NERC, law enforcement and other entities - not the responsible entity - will be doing event analysis. My understanding of the current and future Event Analysis Process is that the</p>



Organization	Yes or No	Question 4 Comment
		<p>responsible entity does the event analysis. Please confirm and clarify.</p> <p><i>EOP-004-2 requires Applicable Entities to “report “ and “communicate” as stated in Requirement 1, Part 1.2: “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p><i>The Event Analysis Program may use a reported event as a basis to analyze an event. The processes of the Event Analysis Program fall outside the scope of this project, but the DSR SDT has collaborated with them of events contained in Attachment 1.</i></p> <p><i>The Standard does not require the Applicable Entity to analyze a reported event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Exelon</p>		<p>1. Please replace the text “Operating Plan” with procedure(s). Many companies have procedure(s) for the reporting and recognition of sabotage events. These procedures extend beyond operating groups and provide guidance to the entire company.</p> <p><i>Thank you for your comment. The DSR SDT intends on keeping “Operating Plan” within EOP-004-2 since NERC has it defined as:</i></p> <p><i>“A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan”. As stated, the Operating Plan may contain Operating procedures or Operating Processes. This will give Applicable Entities the greatest flexibility in achieving compliance with this Standard.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>2. The Loss of Off-site power event criteria is much improved from the last draft of EOP 004-2; however, some clarification is needed to more accurately align with NERC Standard NUC-001 in both nomenclature and intent. Specifically, as Exelon has previously commented, there are many different configurations supplying offsite power to a nuclear power plant and it is essential that all configurations be accounted for. As identified in the applicability section of NUC-001 the applicable transmission entities may include one or more of the following (TO, TOP, TP, TSP, BA, RC, PC, DP, LSE, and other non-nuclear GO/GOPs). Based on the response to previous comments submitted for Draft 2, Exelon understands that the DSR SDT evaluated the use of the word “source” but dismissed the use in favor of “supply” with the justification “[that] ‘supply’ encompasses all sources”. Exelon again suggests that the word “source” is used as the event criteria in EOP-004-2 as this nomenclature is commonly used in the licensing basis of a nuclear power plant. By revising the threshold criteria to “one or more” Exelon believes the concern the DSR SDT noted is addressed and ensures all sources are addressed. In addition, by revising the threshold for reporting to a loss of “one or more” will ensure that all potential events (regardless of configuration of off-site power supplies) will be reported by any applicable transmission entity specifically identified in the nuclear plant site specific NPIRs. As previously suggested, Exelon again proposes that the loss of an off-site power source be revised to an “unplanned” loss to account for planned maintenance that is coordinated in advance in accordance with the site specific NPIRs and associated Agreements. This will also eliminate unnecessary reporting for planned maintenance. Although the loss of one off-site power source may not result in a nuclear generating unit trip, Exelon agrees that an unplanned loss of an off-site power source regardless of impact should be reported within the 24 hour time limit as proposed. Suggest that the Loss of Offsite power to a nuclear generating plant event be revised as follows: Event: Unplanned loss of any off-site power source to a Nuclear Power Plant Entity with Reporting Responsibility: The applicable Transmission Entity that owns and/or operates the off-site power source to a</p>

Organization	Yes or No	Question 4 Comment
		<p>Nuclear Power Plant as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) and associated Agreements. Threshold for Reporting: Unplanned loss of one or more off-site power sources to a Nuclear Power Plant per the applicable NPIRs.</p> <p><i>Based on comments received, this event has been updated within Attachment 1 to read as:</i></p> <p><i>“Complete loss of off-site power to a nuclear generating plant (grid supply)”.</i></p> <p>3. Attachment 1 Generation loss event criteria Generation lossThe ≥ 2000 MW/≥ 1000 MW generation loss criteria do not provide a time threshold or location criteria. If the 2000 MW/1000 MW is intended to be from a combination of units in a single location, what is the time threshold for the combined unit loss? For example, if a large two unit facility in the Eastern Interconnection with an aggregate full power output of 2200 MW (1100 MW per unit) trips one unit (1100 MW) [T=0 loss of 1100 MW] and is ramping back the other unit from 100% power and 2 hours later the other unit trips at 50% power [550 MW at time of trip]. The total loss is 2200 MW; however, the loss was sustained over a 2 hour period. Would this scenario require reporting in accordance with Attachment 1? What if it happened in 15 minutes? 1 hour? 24 hours? Exelon suggests the criteria revised to include a time threshold for the total loss at a single location to provide this additional guidance to the GOP (e.g., within 15 minutes to align with other similar threshold conditions). Threshold for Reporting ≥ 2,000 MW unplanned total loss at a single location within 15 minutes for entities in the Eastern or Western Interconnection ≥ 1000 MW unplanned total loss at a single location within 15 minutes for entities in the ERCOT or Quebec Interconnection</p> <p><i>The DSR SDT has not modified this event since it is being maintained as it is presently enforceable within EOP-004-1.</i></p> <p>4. Exelon appreciates that the DSR SDT has added the NRC to the list of Stakeholders in the Reporting Process, but does not agree with the SDT response to FirstEnergy’s</p>

Organization	Yes or No	Question 4 Comment
		<p>comment to Question 17 [page 206] that stated “NRC requirements or comments fall outside the scope of this project.” Quite the contrary, this project should be communicated and coordinated with the NRC to eliminate confusion and duplicative reporting requirements. There are unique and specific reporting criteria and coordination that is currently in place with the NRC, the FBI and the JTTF for all nuclear power plants. If an event is in progress at a nuclear facility, consideration should be given to coordinating such reporting as to not duplicate effort, introduce conflicting reporting thresholds, or add unnecessary burden on the part of a nuclear GO/GOP who’s primary focus is to protect the health and safety of the public during a potential radiological sabotage event (as defined by the NRC) in conjunction with potential impact to the reliability of the BES.</p> <p><i>The DSR SDT has established a minimum amount of reporting for events listed in Attachment 1. The NRC does not fall under the jurisdiction of NERC and so therefore it is not within scope of this project.</i></p> <p>5. Attachment 1 Detection of a reportable Cyber Security Incident event criteria. The threshold for reporting is “that meets the criteria in CIP-008”. If an entity is exempt from CIP-008, does that mean that this reportable event is therefore also not applicable in accordance with EOP-004-2 Attachment 1?</p> <p><i>If an entity is exempt from CIP-008, then they do not have to report this type of event. Entities can report any situation at anytime to whomever they wish. If an entity is responsible for items that fall under a Cyber Security Incident, then they would report per this standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Duke Energy</p>		<p>1. Reporting under EOP-004-2 should be more closely aligned with Events Analysis Reporting.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>2. Attachment 1 - Under the column titled “Entity with Reporting Responsibility”, several Events list multiple entities, using the phrase “Each RC, BA, TO, TOP, GO, GOP, DP that experiences...” or a similar phrase requiring that multiple entities report the same event. We believe these entries should be changed so that multiple reports aren’t required for the same event.</p> <p><i>The DSR SDT agrees that there may be some dual reporting for the same event. The minimum Applicable Entities have been review and updated where updates could be made. The DSR SDT believes that a dual report will provide a clearer picture of the breadth and depth of an event the Electric Reliability Organization and the Applicable Entities Reliability Coordinator.</i></p> <p>3. Attachment 1 - The phrase “BES equipment” is used several times in the Events Table and footnotes to the table. “Equipment” is not a defined term and lacks clarity. “Element” and “Facility” are defined terms. Replace “BES equipment” with</p>

Organization	Yes or No	Question 4 Comment
		<p>“BES Element” or “BES Facility”.</p> <p><i>The DST SDT has removed the term “equipment” from Attachment 1 per comments received.</i></p> <p>4. Attachment 1 - The Event “Risk to BES equipment” is unclear, since some amount of risk is always present. Reword as follows: “Event that creates additional risk to a BES Element or Facility.”</p> <p><i>The DSR SDT has removed this event from Attachment 1. Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p>5. Attachment 1 - The Threshold for Reporting Voltage deviations on BES Facilities is identified as “+ 10% sustained for &gt; 15 continuous minutes.” Need to clarify + 10% of what voltage? We think it should be nominal voltage.</p> <p><i>A sustained voltage deviation of ± 10% on the BES is significant deviation and is indicative of a shortfall of reactive resources either pre- or post-contingency. The DSR SDT is indifferent to which of nominal, pre-contingency, or scheduled voltage, is used as the baseline, but for simplicity and to promote a common understanding suggest using nominal voltage.</i></p> <p>6. Attachment 1 - Footnote 1 contains the phrase “has the potential to”. This phrase should be struck because it creates an impossibly broad compliance responsibility. Similarly, Footnote 3 contains the same phrase, as well as the word “could” several times, which should be changed so that entities can reasonably comply.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: "A physical threat that could impact the operability of a Facility". This event has the following footnote, which states: "Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility."</i></p> <p>7. Attachment 1 - The "Unplanned Control Center evacuation" Event has the word "potential" in the column under "Entity with Reporting Responsibility". The word "potential" should be struck.8. Attachment 2 - Includes "fuel supply emergency", which is not listed on Attachment 1.</p> <p><i>The DSR SDT has removed the word "potential" from this event. It now reads as: "Each RC, BA, TOP that experiences the event"</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Energy Northwest - Columbia</p>		<p>1. The Loss of Off-site power event criteria is much improved from the last draft of EOP 004-2; however, some clarification is needed to more accurately align with NERC Standard NUC-001 in both nomenclature and intent. Specifically, there are many different configurations supplying offsite power to a nuclear power plant and it is essential that all configurations be accounted for. As identified in the applicability section of NUC-001 the applicable transmission entities may include one or more of the following (TO, TOP, TP, TSP, BA, RC, PC, DP, LSE, and other non-nuclear GO/GOPs). Based on the response to previous comments submitted for Draft 2, Energy Northwest understands that the DSR SDT evaluated the use of the word "source" but dismissed the use in favor of "supply" with the justification "[that] 'supply' encompasses all sources". Energy Northwest suggests that the word</p>

Organization	Yes or No	Question 4 Comment
		<p>“source” is used as the event criteria in EOP-004-2 as this nomenclature is commonly used in the licensing basis of a nuclear power plant. By revising the threshold criteria to “one or more” Energy Northwest believes the concern the DSR SDT noted is addressed and ensures all sources are addressed. In addition, by revising the threshold for reporting to a loss of “one or more” will ensure that all potential events (regardless of configuration of off-site power supplies) will be reported by any applicable transmission entity specifically identified in the nuclear plant site specific NPIRs. Energy Northwest proposes that the loss of an off-site power source be revised to an “unplanned” loss to account for planned maintenance that is coordinated in advance in accordance with the site specific NPIRs and associated Agreements. This will also eliminate unnecessary reporting for planned maintenance. Although the loss of one off-site power source may not result in a nuclear generating unit trip, Energy Northwest agrees that an unplanned loss of an off-site power source regardless of impact should be reported within the 24 hour time limit as proposed. Suggest that the Loss of Offsite power to a nuclear generating plant event be revised as follows: Event: Unplanned loss of any off-site power source to a Nuclear Power Plant Entity with Reporting Responsibility: The applicable Transmission Entity that owns and/or operates the off-site power source to a Nuclear Power Plant as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) and associated Agreements. Threshold for Reporting: Unplanned loss of one or more off-site power sources to a Nuclear Power Plant per the applicable NPIRs.</p> <p><i>Based on comments received, this event has been updated within Attachment 1 to read as:</i></p> <p><i>“Complete loss of off-site power to a nuclear generating plant (grid supply)”.</i></p> <p>2. Please consider changing "Operating Plan" with "Procedure(s)". Procedures extend beyond operating groups and provide guidance to the entire company.</p>



Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT intends on keeping “Operating Plan” within EOP-004-2 since NERC has it defined as:</i></p> <p><i>“A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan”. As stated, the Operating Plan may contain Operating procedures or Operating Processes. This will give Applicable Entities the greatest flexibility in achieving compliance with this Standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Colorado Springs Utilities		<p>Agree with concept to combine CIP-001 into EOP-004. Agree with elimination of “sabotage” concept. Appreciate the attempt to combine reporting requirements, but it seems that in practice will still have separate reporting to DOE and NERC/Regional Entities. EOP-004-2 A.5. “Summary of Key Concepts” refers to Att. 1 Part A and Att. 1 Part B. I believe these have now been combined. EOP-004-2 A.5. “Summary of Key Concepts” refers to development of an electronic reporting form and inclusion of regional reporting requirements. It is unfortunate no progress was made on this front.</p>
<p><b>Response: Thank you for your comment. The DSR SDT is providing a proposed revision to the NERC Rules of Procedure to address the electronic reporting concept. These proposed revisions will be posted with the standard.</b></p>		
American Transmission Company, LLC		<p>ATC appreciates the work of the SDT in incorporating changes that the industry had with reporting time periods and aligning this with the Events Analysis Working Group and Department of Energy’s OE 417 reporting form.</p>
<p><b>Response: Thank you for your comment.</b></p>		

Organization	Yes or No	Question 4 Comment
Manitoba Hydro		<p>Attachment 1 - The term 'Transmission Facilities' used in Attachment 1 is capitalized, but it is not a defined term in the NERC glossary. The drafting team should clarify this issue.</p> <p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p> <p>Attachment 2 - The inclusion of 'Fuel supply emergency' in Attachment 2 creates confusion as it infers that reporting a 'fuel supply emergency' may be required by the standard even though 'fuel supply emergency' is not listed in Attachment 1. On a similar note, it is not clear what the drafting team is hoping to capture by including a checkbox for 'other' in Attachment 2.</p> <p><i>The DSR SDT has removed both "fuel supply emergency" and "other" from Attachment 2.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
NV Energy		<p>Attachment 1 includes an item "Detection of a reportable cyber security incident." The reporting requirement is a report via Attachment 2 or the OE417 report form submittal. However, under CIP-008, to which this requirement is linked, the reporting is accomplished via NERC's secure CIPIS reporting tool. This appears to be a conflict in that the entity is directed to file reporting under CIP-008 that differs from this subject standard.</p> <p><i>CIP-008-4, Requirement 1, Part 1.3 states that an entity must have:</i></p> <p><i>1.3 Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary.</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>EOP-004-2 also allows for submittal of the report to the ESISAC.</i></p> <p>Attachment 1 also includes a provision for reporting the "loss of firm load greater than or equal to 15 minutes in an amount of 200MW (or 300MW for peaks greater than 3000MW). This appears to be a rather low threshold, particularly in comparison with the companion loss of generation reporting threshold elsewhere in the attachment. The volume of reports triggered by this low threshold will likely lead to an inordinate number of filed reports, sapping NERC staff time and deflecting resources from more severe events that require attention. I suggest either an increase in the threshold, or the addition of the qualifier "caused by interruption/loss of BES facilities" in this reporting item. This qualifier would therefore exclude distribution-only outages that are not indicative of a BES reliability issue.</p> <p><i>The DSR SDT has not modified this event since it is being maintained as it is presently enforceable within EOP-004-1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
BC Hydro		<p>Attachment 1: Reportable Events: BC Hydro recommends further defining “BES equipment” for the events Destruction of BES equipment and Risk to BES equipment.</p> <p>Attachment 1: Reportable Events: BC Hydro recommends defining the Forced intrusion event as the wording is very broad and open to each entities interpretation. What would be a forced intrusion ie entry or only if equipment damage occurs?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity.</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>The footnote was deleted</i></p> <ul style="list-style-type: none"> <li><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></li> </ul> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ISO New England</p>		<p>Attachment 1 should be revisited. “Equipment Damage” is overly vague and will also potentially result in reporting on equipment failures which may simply be related to the age and/or vintage of equipment.</p> <p><i>The DSR SDT has revised this event based on comments received. The new event is “Damage or destruction of a Facility” which has a threshold of “Damage or destruction of a Facility that:</i></p> <p><i>Affects an IROL (per FAC-014)</i></p> <p><i>OR</i></p> <p><i>Results in the need for actions to avoid an Adverse Reliability Impact</i></p> <p><i>OR</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Results from intentional human action."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Constellation Energy on behalf of Baltimore Gas &amp; Electric, Constellation Power Generation, Constellation Energy Commodities Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.</p>		<p>Background Section: The background section in this revision of EOP-004 reads more like guidance than a background of the development of the event reporting standard. Because of the background remains as part of the standard, the language raises questions as to role it plays relative to the standard language. For instance, the Law Enforcement Reporting section states: "Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES." It's not clear how "potential to impact to a wider area of the BES" is defined and where it fits into the standard. As well, and perhaps more problematic, is the Reporting Hierarchy for Reportable Events flow chart. While the flow chart concept is quite useful as a guidance tool, the flow chart currently in the Background raises questions. For instance, the Procedure to Report to Law Enforcement sequence does not map to language in the requirements. Further, Entities would not know about the interaction between law enforcement agencies.</p> <p><i>The DSR SDT included the flow chart as an example of how an entity might report and communicate an event. For clarity, we have added the phrase "Example of Reporting Process Including Law Enforcement" to the top of the page.</i></p> <p>Please see additional recommended revisions to the requirement language and to the Events Table in the Q2 and Q3 responses.</p> <p><i>The DSR SDT has removed the wording of "potential" based on comments received.</i></p> <p>Attachment 2: Event Reporting Form: The review of the form is one of the many aspects to compare with the developments within the Events Analysis Process (EAP) developments. We support the effort to create one form for submissions. The</p>

Organization	Yes or No	Question 4 Comment
		<p>recent draft EAP posted as part of Planning Committee and Operating Committee agendas includes a form requiring a few bits of additional relevant information when compared to the EOP-004 form. This may be a valuable approach to avoid follow up inquiries that may result if the form is too limited. We suggest that consideration be given to the proposed EAP form. One specific note on the Proposed EOP-004 Attachment 2: The “Potential event” box in item 3 should be eliminated to track with the removal of the “Risk to the BES” category.</p> <p><i>The DSR SDT has updated Attachment 2 to remove potential event and “Risk to the BES” category based on comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Bonneville Power Administration</p>		<p>BPA believes that Attachment 1 has too many added reportable items because unintentional, equipment failure &amp; operational errors are included in the first three items.</p> <p>A. Change to only “intentional human action”. Otherwise, the first item “destruction of BES equipment” is too burdensome, along with its short time reporting time: i. - If a single transformer fails that shouldn’t require a report. ii.- Emergency actions have to be taken for any failure of equipment, e.g. a loss of line reduces a path SOL and requires curtailments to reduce risk to the system.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> </ul> <p>B. The item for “risk to BES” is not necessary until the suspicious object has been identified as a threat. If what turns out to be air impact wrench left next to BES</p>

Organization	Yes or No	Question 4 Comment
		<p>equipment, that should not be a reportable incident as this current table implies. <i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>C. The nuclear “LOOP” should be only reported if total loss of offsite source (i.e. 2 of 2 or 3 of 3) when supplying the plants load. If lightning or insulator fails causing one of the line sources to trip that’s not a system disturbance especially if it is just used as a backup. It should only be a NRC process if they want to monitor that.</p> <p><i>The DSR SDT has updated this event per your comment, it now reads as: “Complete loss of off-site power to a nuclear generating plant (grid supply)”</i></p> <p>The VRF/VSL: BPA believes that the VRF for R2 &amp; R4 should be “Lower”. <i>The DSR SDT has reviewed and updated the two new requirements and believe the VRF’s follow the NERC Standard development process.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
CenterPoint Energy		<p>CenterPoint Energy appreciates the SDT’s consideration of comments and removal of the term, Impact Event. However, the Company still suggests removing the phrase “with the potential to impact” from the purpose as it is vast and vague. An</p>

Organization	Yes or No	Question 4 Comment
		<p>alternative purpose would be "To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events that impact reliability and their causes if known". The focus should remain on those events that truly impact the reliability of the BES.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><b><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></b></p> <p>CenterPoint Energy remains very concerned about the types of events that the SDT has retained in Attachment 1 as indicated in the following comments: Destruction of BES Equipment - The loss of BES equipment should not be reportable unless the reliability of the BES is impacted.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> </ul> <p>Footnote 5, iii should be modified to tie the removal of a piece of equipment from service back to reliability of the BES. Risk to BES equipment: This Event is too vague to be meaningful and should be deleted. The Event should be modified to "Detection of an imminent physical threat to BES equipment".</p> <p><i>The SDR SDT discussed this event as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "A physical threat that could impact the operability of a Facility".</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>Any reporting time frame of 1 hour is unreasonable; Entities will still be responding to the Event and gathering information. A 24 hour reporting time frame would be more reasonable and would still provide timely information.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>System Separation: The 100 MW threshold is too low for a reliability impact. A more appropriate threshold is 500 MW.</p> <p><i>The DSR SDT has reviewed your request and have determined the event as written "Each separation resulting in an island of generation and load ≥ 100 MW" does impact the reliability of the BES.</i></p> <p>Loss of Monitoring or all voice communication capability: The two elements of this Event should be separated for clarity as follows: "Loss of monitoring of Real-Time conditions" and "Loss of all voice communication capability."</p> <p><i>The DSR SDT has broken this event down into two distinct events: "Loss of all voice communication capability" and "Complete or partial loss of monitoring capability", per comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Orange and Rockland Utilities, Inc./Consolidated Edison Co. of NY, Inc.</p>		<p>Comments:</p> <ul style="list-style-type: none"> <li>o Requirement 4 does not specifically state details necessary for an entity to achieve compliance. Requirement 4 should provide more guidance as to what is required in a drill. Audit / enforcement of any requirement language that is too broad will potentially lead to Regional interpretation, inconsistency, and additional CANS.</li> <li>o R4 should be revised to delete the 15 month requirement. CAN-0010 recognizes that entities may determine the definition of annual.</li> </ul> <p><i>Requirement R4 has been revised as you suggested.</i></p> <ul style="list-style-type: none"> <li>o The Purpose of the Standard should be revised because some of the events being reported on have no impact on the BES. Revise Purpose as follows: To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of [add] "major system events." [delete - "with the potential to impact</li> </ul>

Organization	Yes or No	Question 4 Comment
		<p>reliability and their causes, if known, by the Responsible Entities.”]</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i></p> <p><b><i>“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”</i></b></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Entergy Services		<p>Entergy agrees with and supports comments submitted by the SERC OC Standards Review group.</p>
<p><b>Response: Thank you for your comment.</b></p>		
ITC		<p>Footnote 1 and the corresponding Threshold For Reporting associated with the first Event in Attachment 1 are not consistent and thus confusing. Qualifying the term BES equipment through a footnote is inappropriate as it leads to this confusion. For instance, does iii under Footnote 1 apply only to BES equipment that meet i and ii or is it applicable to all BES equipment?</p> <p><i>The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>The inclusion of equipment failure, operational error and unintentional human action within the threshold of reporting for “destruction” required in the first 3 Events listed in Attachment 1 is also not appropriate. It is clear through operational history that the intent of the equipment applied to the system, the operating practices and personnel training developed/delivered to operate the BES is to result in reliable operation of the BES which has been accomplished exceedingly well given past history. This is vastly different than for intentional actions and should be excluded from the first 3 events listed in Attachment. To the extent these issues are present in another event type they will be captured accordingly.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>Footnote 1 should be removed and the Threshold for Reporting associated with the first three events in Attachment 1 should be updated only to include intentional human action. This will also result in including all BES equipment that was intentionally damaged in the reporting requirement and not just the small subset qualified by the existing footnote 1. This provides a much better data sample for law enforcement to make assessments from than the smaller subset qualified by what we believe the intent of footnote 1 is.</p> <p><i>The SDR SDT discussed this event as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "A physical threat that could impact the operability of a Facility".</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>APX Power Markets (NCR-11034)</p>		<p>For Attachment 1 and the events titled "Unplanned Control Center evacuation" and "Loss of monitoring or all voice communication capability". RC, BA, and TOP are the only listed entity types listed for reporting responsibility. We are a GOP that offers a SCADA service in several regions and those type of events could result in a loss of situational awareness for the regions we provide services. I believe the requirement for reporting should not be limited to Entity Type, but on their impact for situational awareness to the BES based on the amount of generation they control (specific to our case), or other criteria that would be critical to the BES (i.e. voltage, frequency).</p> <p><i>Note that EOP-008-0 is only applicable to Balancing Authorities, Transmission Operators and Reliability Coordinators, this is the basis for the “Entity with reporting Responsibilities” and reads as “Each RC, BA, TOP that experiences the event”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing Standards Collaborators/ Great River Energy</p>		<p>For many of the events listed in Attachment 1, there would be duplicate reporting the way it is written right now. For example, in the case of a fire in a substation (Destruction of BES equipment), the RC, BA, TO, TOP and perhaps the GO and GOP could all experience the event and each would have to report on it. This seems quite excessive and redundant. We recommend eliminating this duplicate reporting.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Intellibind</p>		<p>I do not see that the rewrite of this standard is meeting the goal of clear reliability standards, and in fact the documents are looking more like legal documents. Though the original EOP-004 and CIP-001 was problematic at times, this rewrite, and the need to have such extensive guidance, attachments, and references for EOP-004-2 will create an even more difficult standard to properly meet to ensure compliance during an audit. Though CIP-001 and EOP-004 were related, combining them in a single standard is not resolving the issues, and is in fact complicating the tasks. Requirements in this standard should deal with only one specific issue, not deal with multiple tasks. I am not sure how an auditor will consistently audit against R2, and how a violation will be categorized when an entity implements all portions of their Operating Plan, however fails to fully address all the requirements in R1, thereby not fully implementing R2, in strict interpretation.</p> <p><i>The DSR SDT does not agree that the proposed EOP-004-2 “will create an even more difficult standard to properly meet to ensure compliance during an audit”. The DSR SDT main concern is the reporting of events per Attachment 1 is in-line with the Purpose of this Standard that states: “To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.” The NERC Reliability Standards are designed to support the reliability of the BES. Requirement R2 has been updated to read as: ““R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.” Based on comments received.</i></p> <p>The drafting team should not set up a situation where an entity is in double jeopardy for missing an element of a requirement. I also suggest that EOP-004-2 be given a</p>

Organization	Yes or No	Question 4 Comment
		<p>new EOP designation rather than calling it a revision. This way implementation can be better controlled, since most companies have written specific CIP-001 and EOP-004 document that will not simple transfer over to the new version. This standard is a drastic departure from the original versions. I appreciate the level of work that is going into EOP-004-2, it appears that significant time and effort has been going into the supporting documentation. It is my opinion that if this much material has to be created to state what the standard really requires, then the standard is flawed. When there are 21 pages of explanation for five requirements, especially when we have previously had 16 pages that originally covered 2 separate reliability standards, we need to reevaluate what we are really doing.</p> <p><i>The DSR SDT has revised EOP-004 and CIP-001 using the results based standard development process. This process calls for the drafting team to develop documentation regarding its thoughts during the development process. This allows for a more robust standard which contains background material for an entity to have sufficient guidance to show compliance with the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Imperial Irrigation District		<p>IID strongly believes the reporting flowchart should not be part of a standard. The suggestion is to replace it with a more clear, right to the point requirement.</p> <p><i>The DSR SDT has discussed this issue and believes it would be too prescriptive to have a flow chart as a requirement. If desired, an entity can have a flow chart as part of the Operating Plan as stated in Requirement 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Illinois Municipal Electric Agency		<p>IMEA appreciates this opportunity to comment. IMEA appreciates the SDT's efforts to simplify reporting requirements by combining CIP-001 with EOP-004. [IMEA encourages NERC to continue working towards a one-stop-shop to simplify reporting on ES-ISAC.] IMEA supports, and encourages SDT consideration of, comments</p>



Organization	Yes or No	Question 4 Comment
		submitted by APPA and Florida Municipal Power Agency.
<p><b>Response: Thank you for your comment. Please see the responses to the other comments that you mention.</b></p>		
Westar Energy		<p>In Requirement 1.3, the statement “and the following as appropriate” is vague and subject to interpretation. Who determines what is appropriate? We feel it would be better if the SDT would specify for each event, which party should be notified.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
South Carolina Electric and Gas		<p>In terms of receiving reports, is it the drafting teams expectation that separate reports be developed by both the RC and the TOP, GO, BA, etc. for an event that occurs on a company's system that is within the RC's footprint? One by the RC and one by the TOP, GO, BA, etc. In terms of meeting reporting thresholds, is it the drafting teams expectation that the RC aggregate events within its RC Area to determine whether a reporting threshold has been met within its area for the quantitative thresholds?</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>that could affect just one of the entities with reporting responsibility isn't missed.</i></p> <p><i>It is possible for the Applicable Entities within the Reliability Coordinator's area to be part of a JRO/CFR but this is outside the scope of this Project.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Occidental Power Services, Inc. (OPSI)</p>		<p>Load Serving Entities that do not own or operate BES assets should not be included in the Applicability. In current posting, the SDT states that it includes LSEs based on CIP-002; however, if the LSE does not have any BES assets, CIP-002 should also not be applicable, because the LSE could not have any Critical Assets or Critical Cyber Assets. It is understood that the SDT is trying to comply with FERC Order 693, Section 460 and 461; however, Section 461 also states "Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns." A qualifier in the Applicability of EOP-004-2 that would include only LSEs that own or operate BES assets would seem appropriate. The proposed CIP-002 Version V has such a qualifier in that it applies to a "Load-Serving Entity that owns Facilities that are part of any of the following systems or programs designed, installed, and operated for the protection or restoration of the BES: o A UFLS program required by a NERC or Regional Reliability Standard o A UVLS program required by a NERC or Regional Reliability Standard" The SDT should consider the same wording in the Applicability section of EOP-004-2 on order to be consistent with what will become the standing version of CIP-002 (Version 5).</p> <p><i>The DSR SDT has "considered" section 460 and 461 of FERC Order 693 and has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p> <p><i>The DSR SDT wishes to draw your attention to section 459 of FERC Order 693 which states: "... an adversary may target a small user, owner or operator because it may</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>have similar equipment or protections as a larger facility, that is, the adversary may use an attack against a smaller facility as a training ‘exercise’.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Electric Power</p>		<p>M4: Recommend removing the text “for events” so that it instead reads “The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan created pursuant to Requirement R1, Part 1.3.”R4: It is not clear to what extent the verification needs to be applied if the process used is complex and includes a variety of paths and/or tasks. The draft team may wish to consider changing the wording to simply state “each Responsible Entity shall test each of the communication paths in the operating plan”. We also recommend dropping “once per calendar year” as it is inconstant with the measure itself which allows for 15 months.</p> <p><i>The DSR SDT has revised R4 (now R3 and the associated measure M3:</i></p> <p><i>M3. Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. (R3)</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Indiana Municipal Power Agency</p>		<p>Many of the items listed in Attachment 1 are onerous and burdensome when it comes to making judgments or determinations. What one may consider “Risk to BES equipment” another person may not make the same determination. Clarity needs to</p>

Organization	Yes or No	Question 4 Comment
		<p>be added to make the events easier to determine and that will result in less issues when it comes to compliance audits.</p> <p>IMPA does not understand the usage of the terms Critical Asset and Critical Cyber Asset as they will be retired with CIP version 5. IMPA believes the data retention requirements are way too complicated and need to be simplified. It seems like it would be less complicated if one data retention period applied to all data associated with this standard.</p> <p><i>The DSR has revised many of the events listed in Attachment 1 to provide clarity. We have also removed the references to Critical Asset and Critical Cyber Asset.</i></p> <p>On “public appeal”, in the threshold, the descriptor “each” should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event?</p> <p><i>The DSR SDT has updated the Public Appeal event to read as: “Public appeal for load reduction event” based on comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
MidAmerican Energy		<p>MidAmerican proposes eliminating the phrase “with no more than 15 months between reviews” from R1.5. While we agree this is best practice, it creates the need to track two conditions for the review, eliminates flexibility for the responsible entity and does not improve security to the Bulk Electric System. There has not been a directive from FERC to specify the definition of annual within the standard itself. In conjunction with this comment, the Violation Severity Levels for R4 should be revised to remove the references to months.</p> <p><i>The DSR SDT has removed this phrase from the requirement (now R3).</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Oncor Electric Delivery Company LLC</p>		<p>NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC considers ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.</p> <p><i>The DSR SDT has reviewed the Event Analysis Programs criteria. The DSR SDT has determined that Attachment 1 covers the minimum reporting requirements.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Compliance &amp; Responsibility Office</p>		<p>NextEra Energy, Inc. (NextEra) appreciates the DSR SDT revising proposed EOP-004-2, based on the previous comments of NextEra and the stakeholders. NextEra, however, believes that EOP-004-2 needs additional refinement prior to approval. R1.3In R1.3, NextEra is concerned that the term “internal company personnel” is unclear and may be misinterpreted. For example, NextEra does not believe this term should include all company or corporate personnel, or even all personnel in the Responsible Entity’s company or business unit. Instead, the definition of personnel should be limited to those who could be directly impacted by the event or are working on the event. Thus, NextEra suggests that the language in R1.3 be revised to read: “Internal Responsible Entity personnel whose tasks require them to take specific actions to mitigate, stop the spread and/or normalize the event, or personnel who are directly impacted by the event.” NextEra is concerned that R1.3, as written, will be interpreted differently from company to company, region to region, auditor to auditor, and, therefore, may result in considerable confusion during actual events as well as during the audits/stop checks of EOP-004-2 compliance.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has written Requirement R1, Part 1.2 in a way to allow the entity to determine who should receive the communication within your company as stated in your Operating Plan.</i></p> <p>Also, in R1.3, NextEra is concerned that many of the events listed in Attachment A already must be reported to NERC under its trial (soon to be final) Event Analysis Reporting requirements (Event Analysis). NextEra believes duplicative and different reporting requirements in EOP-004-2 and the Event Analysis rules will cause confusion and inefficiencies during an actual event, which will likely be counterproductive to promoting reliability of the bulk power system. Thus, NextEra believes that any event already covered by NERC’s Event Analysis should be deleted from Attachment 1. Events already covered include, for example, loss of monitoring or all voice, loss of firm load and loss of generation. If this approach is not acceptable, NextEra proposes, in the alternative, that the reporting requirements between EOP-004-2 and Event Analysis be identical. For instance, in EOP-004-2, there is a requirement to report any loss of firm load lasting for more than 15 minutes, while the Event Analysis only requires reporting the of loss of firm load above 300 megawatts and lasting more than 15 minutes. Similarly, EOP-004-2 requires the reporting of any unplanned control center evacuation, while the Event Analysis only requires reporting after the evacuation of the control center that lasted 30 minutes or more. Thus, NextEra requests that either EOP-004-2 not address events that are already set forth in NERC’s Event Analysis, or, in the alternative, for those duplicative events to be reconciled and made identical, so the thresholds set forth in the Event Analysis are also used in EOP-004-2.</p> <p><i>The DSR SDT has worked with the EAWG to develop Attachment 1. At one point they matched. The event for loss of load matches and we revised the “unplanned control center evacuation” event to be for 30 minutes or more.</i></p> <p>In addition, NextEra believes that a reconciliation between the language “of recognition” in Attachment 1 and “process to identify” in R1.1 is necessary. NextEra prefers that the language in Attachment 1 be revised to read “. . . of the</p>

Organization	Yes or No	Question 4 Comment
		<p>identification of the event under the Responsible Entity’s R1.1 process.” For instance, the first event under the “Submit Attachment 2 . . . .” column should read: “The parties identified pursuant to R1.3 within 1 hour of the identification of an event under the Responsible Entity’s R1.1 process.” This change will help eliminate confusion, and will also likely address (and possibly make moot) many of the footnotes and qualifications in Attachment 1, because a Responsible Entity’s process will likely require that possible events are properly vetted with subject matter experts and law enforcement, as appropriate, prior to identifying them as “events”. Thus, only after any such vetting and a formal identification of an event would the one hour or twenty-four hour reporting clock start to run. R1.4, R1.5, R3 and R4NextEra is concerned with the wording and purpose of R1.4, R1.5, R3 and R4.</p> <p><i>The language was revised in Requirement 1, Part 1.1 to “recognize” based on other comments received.</i></p> <p>For example, R1.4 requires an update to the Operating Plan for “. . . any change in assets, personnel, other circumstances . . . .” This language is much too broad to understand what is required or its purpose. Further, R1.4 states that the Operating Plan shall be updated for lessons learned pursuant to R3, but R3 does not address lessons learned. Although there may be lessons learned during a post event assessment, there is no requirement to conduct such an assessment. Stepping back, it appears that the proposed EOP-004-2 has a mix of updates, reviews and verifications, and the implication that there will be lessons learned. Given that EOP-004-2 is a reporting Standard, and not an operational Standard, NextEra is not inclined to agree that it needs the same testing and updating requirements like EOP-005 (restoration) or EOP-008 (control centers). Thus, it is NextEra’s preference that R1.4, R1.5 and R4 be deleted, and replaced with a new R1.4 as follows:R1.4 A process for ensuring that the Responsibly Entity reviews, and updates, as appropriate its Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.If the DSR SDT does not agree with this approach, NextEra, in the alternative, proposes a second approach that consolidates R1.4, R1.5 and R4 in a new R1.4 as follows:R1.4 A process for ensuring that the Responsibly Entity tests</p>

Organization	Yes or No	Question 4 Comment
		<p>and reviews its Operating Plan at least annually (once each calendar year) with no more than 15 months between a test and review. Based on the test and review, the Operating Plan shall be updated, as appropriate, within 90 calendar days. If an actual event occurs, the Responsible Entity shall conduct a post event assessment to identify any lessons learned within 90 calendar days of the event. If the Responsible Entity identifies any lessons learned in post event assessment, the lessons learned shall be incorporated in the Operating Plan within 90 calendar days of the date of the final post event assessment. NextEra purposely did not add language regarding “any change in assets, personnel etc,” because that language is not sufficiently clear or understandable for purposes of a mandatory requirement. Although it may be argued that it is a best practice to update an Operating Plan for certain changes, unless the DST SDT can articulate specific, concrete and understandable issues that require an updated Operating Plan prior to an annual review, NextEra recommends that the concept be dropped.</p> <p><i>Requirement 1, Part 1.4 was merged with Part 1.5 as well as R4. The resulting requirement is now Requirement 3:</i></p> <p><i>“Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p>Nuclear Specific ConcernsEOP-004-2 identifies the Nuclear Regulatory Commission (NRC) as a stakeholder in the Reporting Process, but does not address the status of reporting to the NRC in the Event Reporting flow diagram on page 9. Is the NRC considered Law Enforcement as is presented in the diagram? Since nuclear stations are under a federal license, some of the events that would trigger local/state law enforcement at non-nuclear facilities would be under federal jurisdiction at a nuclear site.</p> <p><i>The process flowchart is an example of how an entity might operate. If an event requires notification of the NRC, this would be an example of notification of a regulatory authority. It is anticipated that the reporting entity would also notify law</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>enforcement if appropriate.</i></p> <p>There are some events listed in Attachment 1 that seem redundant or out of place. For example, a forced intrusion is a one hour report to NERC. However, if there is an ongoing forced intrusion at a nuclear power plant, there are many actions taking place, with the NRC Operations Center as the primary contact which will mobilize the local law enforcement agency, etc.</p> <p><i>The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "Any physical threat that could impact the operability of a Facility".</i></p> <p>It is unclear that reporting to NERC in one hour promotes reliability or the resolution of an emergency in progress.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>Also, is there an ability to have the NRC in an emergency notify NERC? The same concerns related to cyber security events.Procedures versus PlanNextEra also suggests replacing "Operating Plan" with "procedures". Given that EOP-004-2 is a reporting Standard and not an operational Standard, it is typical for procedures that address this standard to reside in other departments, such as Information Management and Security. In other words, the procedures needed to address the requirements of EOP-004-2 are likely broader than the NERC-defined Operating Plan.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Within your Operating Plan you are required to “report” events to the ERO and your RC and communicate this information (to others) as you define it within your company’s Operating Plan. This will allow you to customize any events as you see fit.</i></p> <p>Clean-Up Items In Attachment 1, Control Centers should be capitalized in all columns so as not to be confused with control rooms.</p> <p><i>Since “control center” is not a defined term, it has been revised to lower case.</i></p> <p>Also, the final product should clearly state that the process flow chart that is set forth before the Standard is for illustrative purposes, so there is no implication that a Registered Entity must implement multiple procedures versus one comprehensive procedure to address different reporting requirements.</p> <p><i>The introduction of the flow chart is clearly marked “Example of Reporting Process including Law Enforcement”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
PacifiCorp		No comment.
Arizona Public Service Company		No comments
PPL Electric Utilities and PPL Supply Organizations`		<p>Our comments center around the footnotes and events 'Destruction of BES equipment' and 'Loss of Off-site power to a nuclear generating plant'. We request the SDT consider adding a statement to the standard that acknowledges that not all registered entities have visibility to the information in the footnotes. E.G. Destruction of BES equipment. A GO/GOP does not necessarily know if loss of specific BES equipment would affect any IROL and therefore would not be able to consider this criteria in its reporting decision. Loss of BES equipment would be reported to the BA/RC and the BA/RC would know of an IROL impact and the BA/RC</p>

Organization	Yes or No	Question 4 Comment
		<p>is the appropriate entity to report. We request the SDT consider the information in the footnotes for inclusion in the table directly. Consider Event 'Destruction of BES equipment'. Is footnote 1 a scoping statement? Is it part of the threshold? Is it the impact? Is it defining Destruction? If the BES equipment was destroyed by weather and does not affect an IROL, then is no report is needed? Alternatively, do you still apply the threshold and say it was external cause and therefore report?</p> <p><i>Several event categories were removed or combined to improve Attachment 1. The footnotes that you mention were removed and included in the threshold for reporting column. If an entity does not experience an event, then they should not report on it. As you suggest, most GO /GOPs do not see the transmission system. It is anticipated that they will report for events on their Facilities.</i></p> <p>We suggest including a flowchart on how to use Attachment 1 with an example. The flowchart would explain the order in which to consider the event and the threshold, and footnotes if they remain. Regarding Attachment 1 Footnote 1 'do not report copper theft...unless it degrades the ability of equipment to operate correctly.', is this defining destruction as not operating correctly ? or is the entirety of footnote 1 a definition of destruction? Regarding Attachment 1 Footnote 1, iii, we request this be changed for consistency with the Event and suggest removing damage from the footnote. i.e. The event is 'destruction' whereas the footnote says 'damaged or destroyed'. The standard does not provide guidance on damage vs destruction which could lead to differing reporting conclusions. Is the reporting line out of service, beyond repair, or is it timeframe based? Regarding Attachment 1 Footnote 2 ' to steal copper... unless it affects the reliability of the BES', is affecting the reliability of the BES a consideration in all the events? PPL believes this is the case and request this statement be made. This could be included in the flowchart as a decision point. Regarding Event 'Loss of Off-site power to a nuclear generating plant', the threshold for reporting does not designate if the off-site loss is planned and/or unplanned - or if the reporting threshold includes the loss of one source of off-site power or is the reporting limited to when all off-site sources are unavailable. PPL recommends the event be 'Total unplanned loss of offsite power to a nuclear generating plant (grid</p>

Organization	Yes or No	Question 4 Comment
		<p>supply)'Thank you for considering our comments.</p> <p><i>The SDR SDT discussed "Forced Intrusion" as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "A physical threat that could impact the operability of a Facility".</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>"Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility."</i></p> <p><i>The DSR SDT has updated the Requirements based on comments received along with updating Attachment 1 and 2. Please review the updated standard for all your concerns.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>City of Austin dba Austin</p>		<p>Overarching Concern related to EOP-004-2 draft:The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes</p>

Organization	Yes or No	Question 4 Comment
Energy		<p>and CIP Standards Version 5 could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definition of a BES element could change significantly and the concepts of “Critical Assets” and “Critical Cyber Assets” no longer exist in Version 5 of the CIP Standards.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Additionally, it is debatable whether the destruction of, for example, one relay would be a reportable incident given the proposed language. Related to “Reportable Events” of Attachment 1:1. The “Purpose” section of the Standard indicates it is designed to require the reporting of events “with the potential to impact reliability” of the BES. Footnote 1 and the “Threshold for Reporting” associated with the Event described as “Destruction of BES equipment” expand the reporting scope beyond that intent. For example, a fan on a generation unit can be destroyed because a plant employee drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be “unintentional human action” that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. Item iii) in Footnote 1 seems redundant with the Threshold for Reporting.3. The word “Significantly” in item ii) of footnote 1 introduces an element of subjectivity. What is “significant” to one person may not be significant to someone else.4. The word “unintentional” in Item iii) of footnote 1 may introduce nuisance reporting. The SDT should consider: (1) changing the Event description to “Damage or destruction of BES equipment” (2) removing the footnote and (3) replacing the existing “Threshold for Reporting” with the following language:”Initial indication the event: (i) was due to intentional human action, (ii) affects an IROL or (iii) in the opinion of the Responsible Entity, jeopardizes the reliability margin of the system (e.g., results in the need for emergency actions)”</p> <p><i>The SDR SDT revised this event to “Damage or destruction of a Facility” and removed the footnote. The threshold for reporting now reads:</i></p> <p><i>Damage or destruction of a Facility that:</i>  <i>Affects an IROL (per FAC-014)</i>  <i>OR</i>  <i>Results in the need for actions to avoid an Adverse Reliability Impact</i>  <i>OR</i>  <i>Results from intentional human action.</i></p> <p>5. One reportable event is “Risk to the BES” and the threshold for reporting is, “From a non-environmental physical threat.” This appears to be intended as a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>6. One reportable event is “Damage or destruction of Critical Asset per CIP-002.” The SDT should define the term “Damage” in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. Normal “damage” can occur on a CA that should not be reportable (e.g. the screwdriver example, above).</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>7. For the event called “BES Emergency requiring public appeal for load reduction,” the SDT should make it clear who should report such an event. For example, in the ERCOT Region, there is a requirement that ERCOT issue public appeals for load reduction (See ERCOT Protocols Section 6.5.9.4). As the draft of EOP-004-2 is currently written, every Registered Entity in the ERCOT Region would have to file a report when ERCOT issues such an appeal. Such a requirement is overly burdensome and does not enhance the reliability of the BES. The Standard should require that the Reliability Coordinator file a report when it issues a public appeal to reduce load.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p> <p>Reporting Thresholds<sup>1</sup>. See Paragraph 1 in the “Related to 'Reportable Events' of Attachment 1” section, above. 2. We believe damage or destruction of Critical</p>

Organization	Yes or No	Question 4 Comment
		<p>Assets or CCAs resulting from operational error, equipment failure or unintentional human action should not be reportable under this Standard. We recommend changing the thresholds for “Damage or destruction of Critical Asset...” and “Damage or destruction of a [CCA]” to “Initial Indication the event was due to external cause or intentional human action.” 3. We support the SDT’s attempted to limit nuisance reporting related to copper thefts. However, a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could clog the reporting process with nuisance reporting and reviewing. An example is the “BES Emergency requiring manual firm load shedding” of “¥ 100 MW or “Loss of Firm load for ¥ 15 Minutes” that is ¥ 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases, those low thresholds would require reporting minor wind events or other seasonal system issues on a local network used to provide distribution service. Firm Load1. The use of the term “Firm load” in the context of the draft Standard seems inappropriate. “Firm load” is not defined in the NERC Glossary (although “Firm Demand” is defined). If the SDT intended to use “Firm Demand,” they should revise the draft Standard to use that language. If the SDT wishes to use the term “Firm load” they should define it. [For example, we understand that some load agrees to be dropped in an emergency. In fact, in the ERCOT Region, we have a paid service referred to as “Emergency Interruptible Load Service” (EILS). If the SDT intends that “Firm load” means load other than load which has agreed to be dropped, it should make that fact clear.]</p> <p><i>The thresholds and events listed in Attachment 1 are currently required under DOE OE-417 and NERC reporting requirements.</i></p> <p>Comments to Attachment 21. The checkbox for “fuel supply emergency” should be deleted because it is not listed as an Event on Attachment 1.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p>



Organization	Yes or No	Question 4 Comment
		<p>2. There should be separation between “forced intrusion” and “Risk to BES equipment.” They are separate Events on Attachment 1.</p> <p><i>Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p>Comments to Guideline and Technical Basis The last paragraph appears to state NERC will accept an OE-417 form as long as it contains all of the information required by the NERC form and goes on to state the DOE form “may be included or attached to the NERC report.” If the intent is for NERC to accept the OE-417 in lieu of the NERC report, this paragraph should be clarified.</p> <p><i>The DSR SDT received many comments requesting consistency with DOE OE-417 thresholds and timelines. These items as well as the Events Analysis Working Group’s (EAWG) requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>North America</i></p> <ul style="list-style-type: none"> <li><i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use the OE-417 form rather than Attachment 2 to report under EOP-004. The SDT was informed by the DOE of its new online process coming later this year. In this process, entities may be able to record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses, thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Salt River Project/ Lower Colorado River Authority</p>		<p>Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes and CIP Standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definition of a BES element could change significantly and the concepts of "Critical Assets" and "Critical Cyber Assets" no longer exist in Version 5 of the CIP Standards.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>Additionally, it is debatable whether the destruction of, for example, one relay would</p>

Organization	Yes or No	Question 4 Comment
		<p>be a reportable incident given the proposed language. Related to “Reportable Events” of Attachment 1:1. The “Purpose” section of the Standard indicates it is designed to require the reporting of events “with the potential to impact reliability” of the BES. Footnote 1 and the “Threshold for Reporting” associated with the Event described as “Destruction of BES equipment” expand the reporting scope beyond that intent. For example, a fan on a generation unit can be destroyed because a plant employee drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be “unintentional human action” that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. Item iii) in Footnote 1 seems redundant with the Threshold for Reporting.3. The word “Significantly” in item ii) of footnote 1 introduces an element of subjectivity. What is “significant” to one person may not be significant to someone else.4. The word “unintentional” in Item iii) of footnote 1 may introduce nuisance reporting. The SDT should consider: (1) changing the Event description to “Damage or destruction of BES equipment” (2) removing the footnote and (3) replacing the</p>

Organization	Yes or No	Question 4 Comment
		<p>existing “Threshold for Reporting” with the following language: “Initial indication the event: (i) was due to intentional human action, (ii) affects an IROL or (iii) in the opinion of the Responsible Entity, jeopardizes the reliability margin of the system (e.g., results in the need for emergency actions)”</p> <p><i>The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>5. One reportable event is, “Risk to the BES” and the threshold for reporting is, “From a non-environmental physical threat.” This appears to be intended as a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>6. One reportable event is, "Damage or destruction of Critical Asset per CIP-002." The SDT should define the term "Damage" in order for an entity to determine a threshold for what qualifies as "Damage" to a CA. Normal "damage" can occur on a CA that should not be reportable (e.g. the screwdriver example, above). Reporting Thresholds<sup>1</sup>. We believe damage or destruction of Critical Assets or CCAs resulting from operational error, equipment failure or unintentional human action should not be reportable under this Standard. We recommend changing the thresholds for "Damage or destruction to Critical Assets ..." and "Damage or destruction of a [CCA]" to "Initial Indication the event was due to external cause or intentional human action."</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>2. We support the SDT's attempted to limit nuisance reporting related to copper thefts. However, a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could clog the reporting process with nuisance reporting and reviewing. An example is the "BES Emergency requiring manual firm load shedding" of â%¥ 100 MW or "Loss of Firm load for â%¥ 15 Minutes" that is â%¥ 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases, those low thresholds would require reporting minor wind events or other seasonal system issues on a local network used to provide distribution service. Firm Demand<sup>1</sup>. The use of the term "Firm load" in the context of the draft Standard seems inappropriate.</p>

Organization	Yes or No	Question 4 Comment
		<p>“Firm load” is not defined in the NERC Glossary (although “Firm Demand” is defined). If the SDT intended to use “Firm Demand,” they should revised the draft Standard. If the SDT wishes to use the term “Firm load” they should define it. [For example, we understand that some load agrees to be dropped in an emergency. In fact, in the ERCOT Region, we have a paid service referred to as “Emergency Interruptible Load Service” (EILS). If the SDT intends that “Firm load” means load other than load which has agreed to be dropped, it should make that fact clear.]</p> <p><i>The thresholds and event types in Attachment 1 are from current DOE OE-417 and NERC reporting requirements.</i></p> <p>Comments to Attachment 21. The checkbox for “fuel supply emergency” should be deleted because it is not listed as an Event on Attachment 1.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p> <p>2. There should be separation between “forced intrusion” and “Risk to BES equipment.” They are separate Events on Attachment 1.</p> <p><i>Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>meaningful to industry awareness are reported.</i></p> <p>Comments to Guideline and Technical Basis                      The last paragraph appears to state NERC will accept an OE-417 form as long as it contains all of the information required by the NERC form and goes on to state the DOE form “may be included or attached to the NERC report.” If the intent is for NERC to accept the OE-417 in lieu of the NERC report, this paragraph should be clarified.</p> <p><i>The DSR SDT received many comments requesting consistency with DOE OE-417 thresholds and timelines. These items as well as the Events Analysis Working Group’s (EAWG) requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use the OE-417 form rather than Attachment 2 to report under EOP-004. The SDT was informed by the DOE of its new online process coming later this year. In this process, entities may be able to record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses, thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Public Utility District No. 1 of Snohomish County/Seattle City Light</p>		<p>Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes, as well as the CIP standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts. Related to "Reportable Events" of Attachment 1:1. A reportable event is stated as, "Risk to the BES", the threshold for reporting is, "From a non-environmental physical threat". This appears to be a catch-all event, and basically every other event in Attachment 1 should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. A reportable event is stated as, “Damage or destruction of Critical Asset per CIP-002”. The term “Damage” would have to be defined in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. One could argue that normal “Damage” can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Reporting Thresholds1. The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing. An example is the “BES Emergency requiring manual firm load shedding of greater than or equal to 100 MW or the Loss of Firm load for 15 Minutes that is greater than or equal to 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases these low thresholds represent reporting of minor wind events or other seasonal system issues on Local Network used to provide distribution service. Firm Demand1. The use of Firm Demand in the context of the draft Standards could be used to describe commercial arrangements with a customer rather than a reliability issue. Clarification of Firm Demand would be helpful</p> <p><i>The DSR SDT has updated the requirements based on comments received along with updating Attachment 1 and 2. Please review the updated standard for all your</i></p>

Organization	Yes or No	Question 4 Comment
		<i>concerns.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Pacific Northwest Small Public Power Utility Comment Group		<p>Project 2008-06 proposes to withdraw the terms “Critical Asset” and “Critical Cyber Asset” from the NERC Glossary. In order to avoid a reliability gap when this occurs, we propose including High and Medium Impact BES Cyber Systems and Assets.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>The revised wording to add, “as appropriate” to R1.3 is a concern. We understand the SDT’s intent to not require all the bulleted parties to be notified for every event type. But will a good faith effort on the part of the registered entity to deem appropriateness be subject to second guessing and possible sanctions by the Compliance Enforcement Authority if they disagree? We note that CIP-001 required an interpretation to address this issue, but cannot assume that interpretation will carry over. We suggest spelling out exactly who shall deem appropriateness.</p> <p><i>The phrase “as appropriate” was removed and Requirement 1, Part 1.2 was revised to:</i></p> <p><i>A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p>R4 continues to be an onerous requirement for smaller entities. Verification was not</p>

Organization	Yes or No	Question 4 Comment
		<p>part of the SAR and we are not convinced it is needed for reliability. We are unsure how a DP with no generation, no BES assets, no Critical Cyber Assets, and less than 100 MW of load; would meet R4. Shall they drill for impossible events? We ask that R4 be removed. At a minimum it should exclude entities that cannot experience the events of Attachment 1. Entities that cannot experience the events of Attachment 1 should likewise be exempt from R1.2, 1.3, R2, and R3.</p> <p><i>Requirement R4 (now R3) was revised to :</i></p> <p><i>Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>Requirement R1, Part 1.1 specifies that an entity must have a process for recognizing “applicable events”. An entity is only required to have the Operating Plan as it relates to events applicable to that entity. The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event. The DSR SDT has updated the Requirements based on comments received along with updating Attachment 1 and 2. Please review the updated Standard for all your concerns.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Clallam County PUD No.1		Project 2008-06 proposes to withdraw the terms “Critical Asset” and “Critical Cyber Asset” from the NERC Glossary. In order to avoid a reliability gap when this occurs,

Organization	Yes or No	Question 4 Comment
		<p>we propose including High and Medium Impact BES Cyber Systems and Assets.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>The revised wording to add, “as appropriate” to R1.3 is a concern. We understand the SDT’s intent to not require all the bulleted parties to be notified for every event type. But will a good faith effort on the part of the registered entity to deem appropriateness be subject to second guessing and possible sanctions by the Compliance Enforcement Authority if they disagree? We note that CIP-001 required an interpretation to address this issue, but cannot assume that interpretation will carry over. We suggest spelling out exactly who shall deem appropriateness.</p> <p>Part 1.3 (now Part 1.2 was revised to:</p> <p>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</p> <p>R4 continues to be an onerous requirement for smaller entities. Verification was not part of the SAR and we are not convinced it is needed for reliability. We are unsure how a DP with no generation, no BES assets, no Critical Cyber Assets, and less than 100 MW of load; would meet R4. Shall they drill for impossible events? We ask that R4 be removed. At a minimum it should exclude entities that cannot experience the events of Attachment 1. Entities that cannot experience the events of Attachment 1 should likewise be exempt from R1.2, 1.3, R2, and R3.</p> <p><i>Part 1.1 has been revised to include “applicable events listed in EOP-004, Attachment</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>1.” If an entity cannot experience an event, then it would not be an applicable event.</i></p> <p><i>Requirement R4 (now R3) has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p><i>The DSR SDT envisions that the testing under R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
FEUS		<p>R4 requires verification through a drill or exercise the communication process created as part of R1.3. Clarification of what a drill or exercise should be considered. In order to show compliance to R4 would the entity have to send a pseudo event report to Internal Personnel, the Regional Entity, NERC ES-ISAC, Law Enforcement, and Governmental or provincial agencies listed in R1.3 to verify the communications plan? It would not be a burden on the entity so much, however, I’m not sure the external parties want to be the recipient of approximately 2000 psuedo event reports annually.</p> <p><i>Requirement R4 (now R3) related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R1, R3 now reads: “Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.”The DSR SDT envisions that the testing under Requirement 3 will include</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event.</i></p> <p>Attachment 1: BES equipment is too vague - consider changing to BES facility and including that reduces the reliability of the BES in the footnote. Is the footnote an and or an or? Attachment 1: Version 5 of CIP Requirements remove the terms Critical Asset and Critical Cyber Asset. The drafting team should consider revising the table to include BES Cyber Systems. Clarify if Damage or Destruction is physical damage (aka - cyber incidents would be part of CIP-008.)</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Attachment 1: Unplanned Control Center evacuation - remove “potential” from the reporting responsibility</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p> <p>Attachment 2 - 3: change to, “Did the event originate in your system?” The requirement only requires reporting for Events - not potential events.</p> <p><i>The DSR SDT has streamlined Attachment 2, per comments received.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>Attachment 2 4: “Damage or Destruction to BES equipment” should be “Destruction of BES Equipment” like it is in Attachment 1 and “forced intrusion risk to BES equipment” remove “risk”</p> <p><i>The DSR SDT has streamlined Attachment 2 to reflect the events of Attachment 1, per comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ReliabilityFirst</p>		<p>ReliabilityFirst thanks the SDT for their effort on this project. ReliabilityFirst has a number of concerns/questions related to the draft EOP-004-2 standard which include the following:</p> <p>1. General Comment - The SDT should consider any possible impacts that could arise related to the applicability of Generator Owners that may or may not own transmission facilities. This will help alleviate any potential or unforeseen impacts on these Generator Owners</p> <p><i>The DSR SDT cannot apply items such as GO/TO issues when NERC and the Regions are not in agreement to what the issue and solution is.</i></p> <p>2. General Comment - Though the rationale boxes contain useful editorial information for each requirement, they should rather contain the technical rationale or answer the question “why is this needed” for each requirement. The rationale boxes currently seem to contain suggestions on how to meet the requirements. ReliabilityFirst suggests possibly moving some of the statements in the “Guideline and Technical Basis” into the rationale boxes, as some of the rationale seems to be contained in that section.</p> <p><i>The DSR SDT will continue to update rationale boxes per comments received.</i></p> <p>3. General comment - The end of Measure M4 is incorrectly pointing to R3. This should refer to R4.</p> <p><i>Measurement 4 has been corrected.</i></p> <p>4. General Comment - ReliabilityFirst recommends the “Reporting Hierarchy for</p>

Organization	Yes or No	Question 4 Comment
		<p>Reportable Events” flowchart should be removed from the “Background” section and put into an appendix. ReliabilityFirst believes the flowchart is not really background information, but an outline of the proposed process found in the new standard.</p> <p><i>The DSR SDT provided a flow chart for stakeholders to use if desired. EOP-004-2 sets a minimum level of reporting per the events described in Attachment 1. The DSR SDT has received negative feedback in past drafts, the DSR SDT was too prescriptive.</i></p> <p>5. Applicability Comment - ReliabilityFirst questions the newly added applicability for both the Regional Entity (RE) and ERO. Standards, as outlined in many, if not all, the FERC Orders, should have applicability to users, owners and operators of the BES and not to the compliance monitoring entities (e.g. RE and ERO). Any requirements regarding event reporting for the RE and ERO should be dealt with in the NERC Rules of Procedure and/or Regional Delegation Agreements. It is also unclear who would enforce compliance on the ERO if the ERO remains an applicable entity.</p> <p><i>The ERO is an Applicable Entity under the current version of CIP-008 and therefore they are held to EOP-004-2. Note, this proposed Standard has been through two Quality Reviews and there has been no rejection from NERC .</i></p> <p>6. Requirement Comment - ReliabilityFirst believes the process for communicating events in Requirement R1, Part 1.3 should be all inclusive and therefore include the bullet points. Bullet points are considered to be “OR” statements and thus ReliabilityFirst believes they should be characterized as sub-parts. Listed below is an example:1.3. A process for communicating events listed in Attachment 1 to the following:1.3.1 Electric Reliability Organization, 1.3.2 Responsible Entity’s Reliability Coordinator 1.3.3 Internal company personnel 1.3.4 The Responsible Entity’s Regional Entity 1.3.5 Law enforcement 1.3.6 Governmental or provincial agencies</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: “Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>Part 1.2. ". The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>7. Requirement Comment - ReliabilityFirst questions why Requirement R1, Part 1.1 and Part 1.2 are not required to be verified when performing a drill or exercise in Requirement R4? ReliabilityFirst believes that performing a drill or exercise utilizing the process for identifying events (Part 1.1) and the process for gathering information (Part 1.2) are needed along with the verification of the process for communicating events as listed in Part 1.3.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: "Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. ". The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>8. Compliance Section Comment - Section 1.1 states "If the Responsible Entity works for the Regional Entity..." and ReliabilityFirst questions the intent of this language. ReliabilityFirst is unaware of any Responsible Entities who work for a Regional Entity. Also, if the Regional Entity and ERO remain as applicable entities, in Section 1.1 of</p>

Organization	Yes or No	Question 4 Comment
		<p>the standard, it is unclear who will act as the Compliance Enforcement Authority (CEA).</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from NERC guideline documents</i></p> <p>9. Compliance Section Comment - ReliabilityFirst recommends removing the second, third and fourth paragraphs from Section 1.2 since ReliabilityFirst believes entities should retain evidence for the entire time period since their last audit.</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from NERC guideline documents</i></p> <p>10. Compliance Section Comment - ReliabilityFirst recommends modifying the fifth paragraph from Section 1.2 as follows: “If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or until a data hold release is issued by the CEA.” ReliabilityFirst believes, as currently stated, the CEA would be required to retain information for an indefinite period of time.</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from NERC guideline documents.</i></p> <p>11. Compliance Section Comment - ReliabilityFirst recommends removing the sixth paragraph from Section 1.2 since the requirement for the CEA to keep the last audit records and all requested and submitted subsequent audit records is already covered in the NERC ROP.</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>NERC guideline documents</i></p> <p>12. Attachment 1 Comment - It is unclear what the term/acronym “Tv” is referring to. It may be beneficial to include a footnote clarifying what the term “Tv” stands for.</p> <p><i>Tv is based on FAC-010 and the DSR SDT believes that this is clear to affected stakeholders.</i></p> <p>13. VSL General Comment - although ReliabilityFirst believes that the applicability is not appropriate, as the REs and ERO are not users, owners, or operators of the Bulk Electric System, the Regional Entity and ERO are missing from all four sets of VSLs, if the applicability as currently written stays as is. If the Regional Entity and ERO are subject to compliance for all four requirements, they need to be included in the VSLs as well. Furthermore, for consistency with other standards, each VSL should begin with the phrase “The Responsible Entity...”</p> <p><i>The DSR SDT will follow the guidance in the Standards Development process to assure that “template” information is correct.</i></p> <p>14. VSL 4 Comment - The second “OR” statement under the “Lower” VSL should be removed. By not verifying the communication process in its Operating Plan within the calendar year, the responsible entity completely missed the intent of the requirement and is already covered under the “Severe” VSL category.</p> <p><i>The DSR SDT will follow the guidance in the Standards Development process to assure that “template” information is correct.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Northeast Power Coordinating</p>		<p>Requirement 4 does not specifically state the details necessary for an entity to</p>

Organization	Yes or No	Question 4 Comment
Council		<p>achieve compliance. Requirement 4 should provide more guidance as to what is required in a drill. Audit/enforcement of any requirement language that is too broad will potentially lead to Regional interpretation, inconsistency, and additional CANs.R4 should be revised to delete the 15 month requirement. CAN-0010 recognizes that entities may determine the definition of annual.The standard is too specific, and drills down into entity practices, when the results are all that should be looked for.The standard is requiring multiple reports.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: "Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. ". The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>The Purpose of the Standard is very broad and should be revised because some of the events being reported on have no impact on the BES. Revise Purpose wording as follows: To improve industry awareness and the reliability of the Bulk Electric System "by requiring the reporting of major system events with the potential to impact reliability and their causes..." on the Bulk Electric System it can be said that every event occurring on the Bulk Electric System would have to be reported.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></p>

Organization	Yes or No	Question 4 Comment
		<p>Referring to Requirement R4, the testing of the communication process is the responsibility of the Responsible Entity. There is an event analysis process already in place. The standard prescribes different sets of criteria, and forms. There should be one recipient of event information. That recipient should be a “clearinghouse” to ensure the proper dissemination of information.</p> <p><i>EOP-004 is a standard that requires reporting of events to the ERO. The events analysis program receives these reports and determines whether further analysis is appropriate.</i></p> <p>Why is this standard applicable to the ERO?</p> <p><i>NERC as the ERO is currently a Responsible Entity under CIP-008, and therefore the proposed EOP-004-2 has the ERO as a Responsible Entity.</i></p> <p>Requirement R2 is not necessary. It states the obvious. Requirements R2 and R3 are redundant. The standard mentions collecting information for Attachment 2, but nowhere does it state what to do with Attachment 2.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“Requirement R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p>

Organization	Yes or No	Question 4 Comment
		<p>None of the key concepts identified on page 5 of the standard are clearly stated or described in the requirements:</p> <ul style="list-style-type: none"> <li>o Develop a single form to report disturbances and events that threaten the reliability of the bulk electric system.</li> </ul> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <ul style="list-style-type: none"> <li>o Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements.</li> <li>o Establish clear criteria for reporting.</li> <li>o Establish consistent reporting timelines.</li> </ul> <p><i>The DSR SDT does allow entities to use the DOE Form OE 417 in lieu of Attachment 2 to report an event. Attachment 1 has been updated to provide consistent criteria for reporting as well as reporting timelines. All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>o Provide clarity for who will receive the information and how it will be used. The standard’s requirements should be reviewed with an eye for deleting those that are redundant, or do not address the Purpose or intent of the standard.</p> <p><i>Requirement R1 has been updated and now reads as”</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p><i>The Applicable Entity’s Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your</i></p>

Organization	Yes or No	Question 4 Comment
		<i>company's needs and wants.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
American Public Power Association		<p>Requirement R1:1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate: o Internal company personnel o The Responsible Entity's Regional Entity o Law enforcement o Governmental or provincial agencies APPA believes that including the list of other entities needing to be included in a process for communicating events under 1.3 may open this requirement up for interpretation. APPA requests that the SDT remove from the requirement the listing of; "Internal company personnel, The Responsible Entity's Regional Entity, Law enforcement &amp; Governmental or provincial agencies" and include these references in a guidance document. The registered entities need to communicate with the ERO and the RC if applicable for compliance with this standard and to maintain the reliability of the BES. Communication with other entities such as internal company personnel, law enforcement and the Regional Entity are expected, but do not impact the reliability of the BES. This will simplify the reporting structure and will not be burdensome to registered entities when documenting compliance. If this is not an acceptable solution, APPA suggests revising 1.3 to remove the wording "the following as appropriate" and add "other entities as determined by the Responsible Entity. Examples of other entities may include, but are not limited to:" Then it is clear that the list is examples and should not be enforced by the auditor.</p> <p><i>Requirement R1 has been updated and now reads as</i></p> <p><i>"Each Responsible Entity shall have an Operating Plan that includes:</i></p> <p><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></p> <p><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p><i>The Applicable Entity’s Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your company’s needs and wants.</i></p> <p>1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3. APPA understands that the SDT is following the FERC order requiring a 90 day limit on updates to any changes to the plan. However, APPA believes that “updating the Operating Plan within 90 calendar days of any change...” is a very burdensome compliance documentation requirement. APPA reminds the SDT that including DPs in this combined standard has increased the number of small Responsible Entities that will be required to document compliance. APPA requests that the SDT combine requirement 1.4 and 1.5 so the Operating Plan will be reviewed and updated with any changes on a yearly basis. If this is not an acceptable solution, APPA suggests that the “Lower VSL” exclude a violation to 1.4. The thought being, a violation of 1.4 by itself is a documentation error and should not be levied a penalty.</p> <p><i>Requirement 1, Part 1.4 has been removed from the standard.</i></p> <p>Attachment 1: Events Table APPA believes that the intent of the SDT was to mirror the DOE OE-417 criteria in reporting requirements. With the inclusion of DP in the</p>

Organization	Yes or No	Question 4 Comment
		<p>Applicability, however, APPA believes the SDT created an unintended excessive reporting requirement for DPs during insignificant events.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>APPA recommends that a qualifier be added to the events table. In DOE OE-417 local electrical systems with less than 300MW are excluded from reporting certain events since they are not significant to the BES.</p> <p>APPA believes that the benefit of reporting certain events on systems below this value would not outweigh the compliance burden placed on these small systems. Therefore, APPA requests that the standard drafting team add the following qualifier to the Events Table of Attachment 1: “For systems with greater than 300MW peak load.” This statement should be placed in the Threshold for Reporting column for the following Events: BES Emergency requiring appeal for load reduction, BES</p>

Organization	Yes or No	Question 4 Comment
		<p>Emergency requiring system-wide voltage reduction, BES Emergency requiring manual firm load shedding, BES Emergency resulting in automatic firm load shedding. This will match the DOE OE-417 reporting criteria and relieve the burden on small entities.</p> <p><i>Upon review of the DOE OE 417, it states “Local Utilities in Alaska, Hawaii, Puerto Rico, the U.S. Virgin Islands, and the U.S. Territories - If the local electrical system is less than 300 MW, then only file if criteria 1, 2, 3 or 4 are met”. Please be advised this exception applies to entities outside the continental USA.</i></p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn’t missed.</i></p> <p>Definition of “Risk to BES equipment”:The SDT attempted to give examples of the Event category “Risk to BES equipment” in a footnote. This footnote gives the Responsible Entity and the Auditor a lot of room for interpretation. APPA suggests that the SDT either define this term or give a triggering mechanism that the industry would understand. One suggestion would be “Risk to BES equipment: An event that forces a Facility Owner to initiate an unplanned, non-standard or conservative operating procedure.” Then list; “Examples include train derailment adjacent to BES Facilities that either could have damaged the equipment directly or has the potential to damage the equipment...” This will allow the entity to have an operating procedure linked to the event. If this suggestion is taken by the SDT then the Reporting column of Attachment 1 needs to be changed to: “The parties identified pursuant to R1.3 within 1 hour of initiating conservative operating procedures.”</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Western Electricity Coordinating Council</p>		<p>Results-based standards should include, within each requirement, the purpose or reason for the requirement. The requirements of this standard, while we support the requirements, do not include the goal or proupose of meeting each stated requirement. The Measures all include language stating “the responsible entity shall provide...”. During a quality review of a WECC Regional Reliability Standard we were told that the “shall provide” language is essentially another requirement to provide something. If it is truly necessary to provide this it should be in the requirements. It was suggested to us that we drop the “shall provide” language and just start each Measure with the “Evidence may include but is not limited to...”.</p> <p><i>The DSR SDT changed each instance of “shall” to “will” within the measures. We will defer to NERC Quality Review comments for any additional revisions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Sacramento Municipal Utility District (SMUD)</p>		<p>SMUD and BANC agree with the revised language in EOP-004-1 requirements, but we have identified the following issues in A-1:We commend the SDT for properly addressing the sabotage issue. However, additional confusion is caused by introducing term "damage". As "damage" is not a defined term it would be beneficial for the drafting team to provide clarification for what is meant by "damage".</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></li> </ul> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p><i>As discussed in prior comment forms, the DSR SDT has elected not to define “sabotage”. As defined in an Entity’s operating Plan, the requirement is to report and communicate an event as listed in Attachment 1. EOP-004-2 does not require analysis of any event listed in Attachment 1.</i></p> <p>The threshold for reporting "Each public Appeal for load reduction" should clearly state the triggering is for the BES Emergency as routine "public appeal" for conservation could be considered a threshold for the report triggering.</p> <p><i>To clarify your point, the threshold has been changed to ‘Public appeal or load reduction event’.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>Regarding the SOL Violations in Attachment 1 the SOL Violations should only be those that affect the WECC paths.</p> <p><i>The DSR SDT has included the following language for WECC’s SOL violation in Attachment 1:</i></p> <p><i>“IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)”</i></p> <p>The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing.</p> <p><i>The DSR SDT made reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Southern Company		<p>Southern has the following comments:(1) In Requirement R1.4, we request the SDT to clarify what is meant by the term “assets”?</p> <p><i>The DSR SDT has deleted Requirement R1, Part 1.4, thus “assets” is not contained in EOP-004-2 based on comments received.</i></p> <p>2) If requirement 4 is not deleted, should we have to test every possible event described in our Operating Plan or each event listed in Attachment 1 to verify communications?</p> <p><i>The DSR SDT has deleted Requirement R4 based on comments received.</i></p> <p>(3) In the last paragraph of the “Summary of Key Concepts” section on page 6 of</p>

Organization	Yes or No	Question 4 Comment
		<p>Draft 3, there is a statement that “Real-time reporting is achieved through the RCIS...” The only reporting required on RCIS by the Standards is for EEAs and TLRs. Please review and modify this language as needed.</p> <p><i>The DSR SDT believes “The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting” is correct.</i></p> <p>(4) Evidence Retention (page 12 of Draft 3): The 3 calendar year reference has no bearing on a Standard that may be audited on a cycle greater than 3 years.</p> <p><i>The DSR SDT has updated the Evidence Retention section with standard language provided by NERC staff.</i></p> <p>(5) In the NOTE for Attachment 1 (page 20 of Draft 3), what is meant by “periodic verbal updates” and to whom should the updates be made?</p> <p><i>The DSR SDT has updated the note in question to remove the language of “periodic verbal updates”, it now reads as:</i></p> <p><i>“NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p>(6) There are Prerequisite Approvals listed in the Implementation Plan. Is it appropriate to ask industry to vote on this Standard Revision that has a prerequisite approval of changes in the Rules of Procedure that have not been approved?</p> <p><i>The proposed revisions to the Rules of Procedure should have been posted with the</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>standard. This posting will occur with the successive ballot of EOP-004-2.</i></p> <p>(7) We believe the reporting of the events in Attachment 1 has no reliability benefit to the Bulk Electric System. We suggest that Attachment 1 should be removed.</p> <p><i>The DSR SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Texas Reliability Entity</p>		<p>Substantive comments:1.ERO and Regional Entities should not be included in the Applicability of this standard. Just because they may be subject to some CIP requirements does not mean they also have to be included here. The ERO and Regional Entities do not operate equipment or systems that are integral to the operation of the BES. Also, none of the VSLs apply to the ERO or to Regional Entities.</p> <p><i>The DSR SDT is following guidance that NERC has provided to the DSR SDT. The ERO and the RE are applicable entities under CIP-008. Reporting of Cyber Security Incidents is the responsibility of the ERO and the RE.</i></p> <p>2.The first entry in the Events Table should say “Damage or destruction of BES equipment.” Equipment may be rendered inoperable without being “destroyed,” and entities should not have to determine within one hour whether damage is sufficient to cause the equipment to be considered “destroyed.” Footnote 1 refers to equipment that is “damaged or destroyed.”</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 1. A Facility is defined as:</i></p> <p><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>3.In the Events Table, consider whether the item for “Voltage deviations on BES facilities” should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator and power system stabilizer) could have a similar impact on the BES as other reportable items.</p> <p><i>The DSR SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p> <p>4.In the Events Table, under Transmission Loss, does this item require that at least three Facilities owned by one entity must be lost to trigger the reporting requirement, or is the reporting requirement also to be triggered by loss of three Facilities during one event or occurrence that are owned by two or three different entities?</p> <p><i>The DSR SDT has stated in Attachment 1 that “Each TOP that experiences the transmission loss”. This would mean per individual TOP.</i></p> <p>5.In the Events Table, under Transmission Loss, it is unclear how Facilities are to be counted to determine when “three or more” Facilities are lost. In the NERC Glossary, Facility is ambiguously defined as “a set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)” In many cases, a “set of electrical equipment” can be selected and counted in different ways, which makes this item ambiguous.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p> <p>6.In the Events Table, under Transmission Loss, it appears that a substation bus failure would only count as a loss of one Facility, even though it might interrupt flow between several transmission lines. We believe this type of event should be reported under this standard, and appropriate revisions should be made to this entry.</p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for this event as well as other events in Attachment 1. A Facility is defined as:</i></p> <p style="padding-left: 40px;"><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>7.In the Events Table, under Transmission Loss, consider including generators that are lost as a result of transmission loss events when counting Facilities. For example, if a transmission line and a transformer fail, resulting in a generator going off-line, that should count as a loss of “three or more” facilities and be reportable under this standard.</p> <p><i>Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p> <p>8.In the Events Table, under “Unplanned Control Center evacuation” and “Loss of monitoring or all voice communication capability,” GOPs should be included. GOPs also operate control centers that would be subject to these kinds of occurrences.</p> <p><i>Attachment 1 is the minimum set of events that will be required to report and</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>communicate per your Operating Plan will be aware of system conditions.</i></p> <p>9.In the Events Table, under “Loss of monitoring or all voice communication capability,” we suggest adding that if there is a failure at one control center, that event is not reportable if there is a successful failover to a backup system or control center.</p> <p><i>The DSR SDT has split this event into two separate events based on comments received, it now reads as: “Loss of all voice communication capability” and “Complete or partial loss of monitoring capability”.</i></p> <p>10.”Fuel supply emergency” is included in the Event Reporting Form, but not in Attachment 1, so there is no reporting threshold or deadline provided for this type of event.</p> <p><i>Attachment 2 was updated to reflect the revisions to Attachment 1. The reference to “actual or potential events” was removed. Also, the event type of “other” and “fuel supply emergency” was removed as well.</i></p> <p>Clean-up items:1.In R1.5, capitalize “Responsible Entity” and lower-case “process”.</p> <p><i>The DSR SDT has deleted Requirement 1, part 1.5.</i></p> <p>2.In footnote 1, add “or” before “iii)” to clarify that this event type applies to equipment that satisfies any one of these three conditions.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>3.In the Event Reporting Form, “forced intrusion” and “Risk to BES equipment” are run together and should be separated.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>VSLs:1.We support the substance of the VSLs, but the repeated long list of entities makes the VSLs extremely difficult to read and decipher. The repeated list of entities should be replaced by “Responsible Entities.” 2.If the ERO and Regional Entities are to be subject to requirements in this standard (which we oppose), they need to be added to the VSLs.</p> <p><i>The DSR SDT has revised the VSLs to eliminate the list of entities and lead with “Responsible Entity”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
		<p>Suggest removing 1.4 since 1.5 ensures a annual review. . The implementation of the plan should also include the necessary reporting.</p> <p><i>Requirement R1, Part 1.4 has been removed.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Electric Compliance</p>		<p>The concepts of “Critical Assets” and “Critical Cyber Assets” no longer exist in Version 5 of the CIP Standards and so this may cause confusion. Recommend modifying to be in accordance with Version 5. Additionally, it is debatable whether the</p>

Organization	Yes or No	Question 4 Comment
		<p>destruction of, for example, one relay would be a reportable incident given the proposed language. We recommend modifying the language to insure nuisance reporting is minimized. One reportable event is, “Risk to the BES” and the threshold for reporting is, “From a non-environmental physical threat.” This appears to be a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”</i> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>Footnote 1 and the “Threshold for Reporting” associated with the Event described as “Destruction of BES equipment” expand the reporting scope. For example, a fan on a</p> </li></ul>

Organization	Yes or No	Question 4 Comment
		<p>transformer can be destroyed because a technician drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be “unintentional human action” that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear. Proposed Footnote: BES equipment that become damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service that i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii). Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>The word “Significantly” in item ii) of footnote 1 and “as appropriate” in section 1.3 introduces elements of subjectivity. What is “significant” or “appropriate” to one person may not be to someone else.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>In section 1.4, we believe that revising the plan within 90 days of “any” change should be changed to 180 days or else classes of events should be made so that only</p>

Organization	Yes or No	Question 4 Comment
		<p>substantial changes are required to made within the 90 day timeframe.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Georgia System Operations Corporation</p>		<p>The ERO and the Regional Entity should not be listed as Responsible Entities. The ERO and the Regional Entity should not have to meet the requirements of this standard, especially reporting to itself.</p> <p><i>The ERO and the RE are applicable under the CIP-008 standard and are therefore applicable under EOP-004.</i></p> <p>Attachment 1 (all page numbers are from the clean draft):Page 20, destruction of BES equipment: part iii) of the footnote adds damage as an event but the heading is for destruction. Is it just for destruction? Or is it for damage or destruction?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The ‘Destruction’ event category has been revised to include damage or destruction of a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></p> <p>Page 21, Risk to BES equipment: Footnote 3 gives an example where there is flammable or toxic cargo. These are environmental threats. However, the threshold for reporting is for non-environmental threats. Which is it?</p> <p><i>For this event, environmental threats are considered to be severe weather, earthquakes, etc. rather than an external threat.</i></p> <p>Page 21, BES emergency requiring public appeal for load reduction: A small deficient</p>

Organization	Yes or No	Question 4 Comment
		<p>entity within a BA may not initiate public appeals. The BA is typically the entity which initiates public appeals when the entire BA is deficient. The initiating entity should be the responsible entity not the deficient entity.</p> <p><i>The DSR SDT revised this event to indicate the “initiating” entity is responsible for reporting.</i></p> <p>Page 21, BES emergency requiring manual firm load shedding: If a RC directs a DP to shed load and the DP initiates manually shedding its load as directed, is the RC the initiating entity? Or is it the DP?</p> <p><i>The DSR SDT believes the wording of “initiating entity” provides enough clarity for each applicable entity to understand. In this case, the RC made the call to shed load and therefore should report.</i></p> <p>Page 22, system separation (islanding): a DP does not have a view of the system to see that the system separated or how much generation and load are in the island. Remove DP.</p> <p><i>The DSR SDT disagrees with your comment. DP’s may be the first to recognize that they are islanded or separated from the system.</i></p> <p>Attachment 2 (all page numbers are from the clean draft):Page 25: fuel supply emergencies will no longer be reportable under the current draft.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2 based on comments received.</i></p> <p>Miscellaneous typos and quality issues (all page numbers are from the clean draft):Page 5, the last paragraph: There are two cases where Parts A or B are referred to. Attachment 1 no longer has two parts (A &amp; B).Page 27, Discussion of Event Reporting: the second paragraph has a typo at the beginning of the sentence.</p>



Organization	Yes or No	Question 4 Comment
		<i>The DSR SDT has corrected these typos.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		<p>The first three incident categories designated on Attachment 1 as reportable events should be modified. As the Standard is current drafted, each incident category (i.e., destruction of BES equipment, damage or destruction of Critical Assets, and damage or destruction of Critical Cyber Assets) requires reporting if the event was due to unintentional human action. For example, under the reporting criteria as drafted, inadvertently dropping and damaging a piece of computer equipment designated as a Critical Cyber Asset while moving or installing it would appear to require an event report within an hour of the incident.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”</i> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> </li></ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>MDEA requests that the Drafting Team consider modifying footnote 1 and each of the first three event categories to reflect that reportable events include only those that (i) affect an IROL; (ii) significantly affect the reliability margin of the system; or (iii) involve equipment damage or destruction due to intentional human action that results in the removal of the BES equipment, Critical Assets, and/or Critical Cyber Assets, as applicable, from service.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>Footnote 2 (which now pertains only to the fourth incident category - forced intrusions) should also apply to the first three event categories. Specifically, responsible entities should report intentional damage or destruction of BES equipment, damage or destruction of Critical Assets, and damage or destruction of Critical Cyber Assets if either the damage/destruction was clearly intentional or if motivation for the damage or destruction cannot reasonably be determined and the damage or destruction affects the reliability of the BES.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>Attachment 1 is also unclear to the extent that the incident category involving reports for the detection of reportable Cyber Security Incidents includes a reference to CIP-008 as the reporting threshold. While entities in various functional categories</p>

Organization	Yes or No	Question 4 Comment
		<p>(i.e., RCs, BAs, TOPs/TOs, GOPs/GOs, and DPs) are listed as being responsible for the reporting of such events, some entities in these functional categories may not currently be subject to CIP-008. If it is the Drafting Team’s intent to limit event reports for Cyber Security Incidents to include only registered entities subject to CIP-008, that clarification should be incorporated into the listing of entities with reporting responsibility for this incident category in Attachment 1.</p> <p><i>The “Entity with reporting responsibility” for the event “A reportable Cyber Security Incident” has been revised to “Each Responsible Entity applicable under CIP-008-4 or its successor that experiences the Cyber Security Incident”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Luminant Power		<p>The following comments all apply to Attachment 1:</p> <ul style="list-style-type: none"> <li>o As a general comment, SDT should specifically list the entities the reportable event applies to in the table for clarity. Do not use general language referencing another standard or statements such as “Deficient entity is responsible for reporting”, “Initiating entity is responsible for reporting”, or other similar statements used currently in the table. This leaves this open and subject to interpretation.</li> </ul> <p><i>The DSR SDT disagrees with your comment. This language provides the most flexibility for applicable entities and maintains a minimum level of who is required to report or communicate events based an entity’s Operating Plan, as described in Requirement 1.</i></p> <p>Also, there are a number of events that do not apply to all entities.</p> <ul style="list-style-type: none"> <li>o Destruction of BES equipment should be Intentional Damage or Destruction of BES equipment. Unintentional actions occur and should not be a requirement for reporting under disturbance reporting.</li> </ul> <p><i>The event for “Destruction of BES equipment” has been revised to “Damage or destruction of a Facility”. The threshold for reporting information was expanded for</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>clarity:</i></p> <p><i>“Damage or destruction of a Facility that: affects an IROL OR Results in the need for actions to avoid an Adverse Reliability Impact OR Results from intentional human action.”</i></p> <p>o Actions or situations affecting equipment or generation unit availability due to human error, equipment failure, unintentional human action, external cause, etc. are reported in real time to the BA and other entities as required by other NERC Standards. Disturbance reporting should avoid the type of events that, for instance, would cause the total or partial loss of a generating unit under normal operational circumstances. There are a number of issues with the table in this regard.</p> <p><i>The DSR SDT has removed such language based on comments received.</i></p> <p>o For clarity, consider changing the table to identify for each event type “who” should be notified. This appears to be missing from the table overall.</p> <p><i>The DSR SDT has updated Requirement R1, Part 1.2 to read as: ““1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>o Reportable Events, the meaning for the Event labeled “Destruction of BES equipment” is not clear. Footnote 1 adds the language “iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment</p>

Organization	Yes or No	Question 4 Comment
		<p>from service.” This language can be interpreted to mean that any damage to any BES equipment caused by human action, regardless of intention, must be reported within 1 hour of recognition of the event. This requirement will be overly burdensome. If this is not the intent of the definition of “Destruction of BES equipment”, the footnote should be re-worded. As such, it is subjective and left open to interpretation. It should focus only on intentional actions to damage or interrupt BES functionality. It should not be worded as such that every item that trips a unit or every item that is damaged on a unit requires a report. That is where the language right now is not clear. There are and will continue to be unintentional human error that results in taking equipment out of service. This standard was meant to replace sabotage reporting.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>o Damage or destruction of Critical Asset per CIP-002 and Damage or destruction of a Critical Cyber Asset per CIP-002 should be removed from the table as Intentional Damage or Destruction of BES equipment would cover this as well.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Asset.”</i></p> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>o Risk to BES equipment should be removed from the table as it is very subjective and broad. At a minimum, the 1 hour reporting timeline should begin after recognition and assessment of the incident. As an example, a fire close to BES equipment may not truly be a threat to the equipment and will not be known until an assessment can be made to determine the risk.</p> <p><i>The DSR SDT has removed this event based on comments received.</i></p> <p>o Detection of a Reportable Cyber Security incident should be removed from the table as this is covered by CIP-008 requirements. Having this in two separate standards is double jeopardy and confusing to entities.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p>

Organization	Yes or No	Question 4 Comment
		<ul style="list-style-type: none"> <li>• <i>Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li>• <i>Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”</i></li> </ul> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>o Generation Loss event reporting should only apply to the BA. These authorities have the ability and right to contact generation resources to supply necessary information needed for reporting. This would also eliminate redundant reporting by multiple entities for the same event.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn’t missed.</i></p> <p>o Suggest that Generation Loss MW loss would match up with the 1500 MW level identified in CIP Version 4 or Version 5 for consistency between future CIP standards and this disturbance reporting standard. This would then cover CIP and significant MW losses that should be reported.</p> <p><i>The DSR SDT disagrees as this threshold is based on the current EOP-004-1.</i></p> <p>o The Generation Loss MW loss amount needs to have a time boundary. Luminant</p>

Organization	Yes or No	Question 4 Comment
		<p>would suggest a loss of 1500 MW within 15 minutes.</p> <p><i>The DSR SDT disagrees as this threshold is based on the current EOP-004-1.</i></p> <p>o Unplanned Control Center evacuation should not apply to entities that have backup Control Centers where normal operations can continue without impact to the BES.</p> <p><i>The DSR SDT disagrees with your comment. By reporting and communicating per an entity's Operating Plan, you will provide situational awareness to entities per your Operating Plan.</i></p> <p>o Loss of monitoring or all voice communication capability should be separated. Also the 24 hour reporting requirement may not be feasible if communications is down for longer than 24 hours.</p> <p><i>The DSR SDT has split this event into two separate events based on comments received, it now reads as: "Loss of all voice communication capability" and "Complete or partial loss of monitoring capability".</i></p> <p>Luminant would suggest removal of the communication reporting event as there are a number of things that could cause this to occur for longer than the reporting requirement allows, thus putting entities at jeopardy of a potential violation that is out of their control. How does an entity report if all systems and communications are down for more than 24 hours? What about in instances of a partial or total blackout? These events could last much longer than 24 hours. All computer communication would likely also be down thus rendering electronic reporting unavailable.</p> <p><i>EOP-004-2 only requires an entity to report and communicate per their Operating Plan within the time frames set in Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		



Organization	Yes or No	Question 4 Comment
Kansas City Power & Light		<p>The implementation plan indicates that much of CIP-008 is retained. The reporting requirements in CIP-008 and the required reportable events outlined in Attachment 1 are an overlap with CIP-008-3 R1.1 which says “Procedures to characterize and classify events as reportable Cyber Security Incidents” and CIP-008-3 R1.3 which requires processes to address reporting to the ES-ISAC. There is also a NERC document titled, Security Guideline for the Electricity Sector: Threat and Incident Reporting, which is a guideline to “assist entities to identify and classify incidents for reporting to the ES-ISAC”. The SDT should consider the content of the Security Guideline for the Electricity Sector: Threat and Incident Reporting when considering the reporting requirements proposed EOP-004. The efforts to incorporate CIP-008 into EOP-004 are insufficient and will result in serious confusion between proposed EOP-004 and CIP-008 and reporting expectations. Considering the complexity CIP incident reporting and the interests of ES-ISAC, it may be beneficial to leave CIP-008 out of the proposed EOP-004 and limit EOP-004 to the reporting interests of NERC.</p> <p><i>Attachment 2 (or the DOE Form OE 417) is the reporting form to be used for reporting a “Cyber Security Incident”.</i></p> <p>The flowchart states, “Notification Protocol to State Agency Law Enforcement”. Please correct this to, “Notification to State, Provincial, or Local Law Enforcement”, to be consistent with the language in the background section part, “A Reporting Process Solution - EOP-004”.</p> <p><i>The DSR SDT has updated the “Example of reporting _Process including Law Enforcement”, and please note that this is only an “example”.</i></p> <p>Measure 4 is not clear enough regarding the extent to which drills should be performed. Does the measure mean that all events in the events list need to be drilled or is drilling a subset of the events list sufficient? Please clearly indicate the extent of drilling that is required or clearly indicate in the requirement the extent of the drills to be performed is the responsibility of the Responsible Entity to identify in their “processes”.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Requirement R4 (now R3) has been revised and the measure now reads:</i></p> <p><i>Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. (R3)</i></p> <p>Evidence Retention - it is not clear what the phrase “prior 3 calendar years” represents in the third paragraph of this section regarding data retention for requirements and measures for R2, R3, R4 and M2, M3, M4 respectively. Please clarify what this means. Is that different than the meaning of “since the last audit for 3 calendar years” for R1 and M1?</p> <p><i>This has been revised for clarity and to be consistent with NERC Guidance documents. The new evidence retention reads:</i></p> <p><i>Each Responsible Entity shall retain the current, in force document plus the ‘date change page’ from each version issued since the last audit or the current and previous version for Requirements R1, R4 and Measures M1, M4.</i></p> <p><i>Each Responsible Entity shall retain evidence from prior 3 calendar years for Requirements R2, R3 and Measures M2, M3.</i></p> <p>VSL for R2 under Severe regarding R1.1 may require revision considering the comment regarding R1.1 in item 2 previously stated. In addition, the VRF for R2 is MEDIUM. R2 is administrative regarding the implementation of the requirements specified in R1. Documentation and maintenance should be considered LOWER. There is no VSL for R4 and a VSL for R4 needs to be proposed.</p> <p><i>The DSR SDT reviewed and updated both VSL’s for the new requirements.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 4 Comment
SPP Standards Review Group		<p>The inclusion of optional entities to which to report events in R1.3 introduces ambiguity into the standard that we feel needs to be eliminated. We propose the following replacement language for R1.3:A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the Responsible Entity’s Regional Entity.We would also propose to incorporate the law enforcement and governmental or provincial agencies mentioned in R1.3 in Attachment 1 by adding them to the existing language for each of the event cells. For example, the first cell in that column would read:The parties identified pursuant to R1.3 and applicable law enforcement and governmental or provincial agencies within 1 hour of recognition of event.Similarly, the phrase ‘...and applicable law enforcement and governmental or provincial agencies...’ should be inserted in all the remaining cells in the 4th column.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Requirement R1,Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Santee Cooper		<p>The on-going development of the definition of the BES could have significant impacts on reporting requirements associated with this standard.The event titled “Risk to the</p>

Organization	Yes or No	Question 4 Comment
		<p>BES” appears to be a catch-all event and more guidance needs to be provided on this category.</p> <p><i>Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p>The event titled “Damage or Destruction of a Critical Asset or Critical Cyber Asset per CIP-002” is ambiguous and further guidance is recommended. Ambiguity in a standard leaves it open to interpretation for all involved.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<ul style="list-style-type: none"> <li>• <i>Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.</i></li> </ul> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>		<p>The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., “Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements”) so that changes to the RoP do not necessitate changes to the standard.</p> <p><i>The language incorporated in this section of the standard is boilerplate language provided by NERC staff for inclusion in each standard.</i></p> <p>In R4, it might be worth clarifying that, in this case, implementation of the plan for an event that does not meet the criteria of Attachment 1 and going beyond the requirements R2 and R3 could be used as evidence. Consider adding a phrase as such to M4, or a descriptive footnote that in this case, “actual event” may not be limited to those in Attachment 1.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“Requirement R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p>Comments to Attachment 1 table: On “Damage or destruction of Critical Asset” and “... Critical Cyber Asset”, Version 5 of the CIP standards is moving away from the binary critical/non-critical paradigm to a high/medium/low risk paradigm. Suggest adding description that if version 5 is approved by FERC, that “critical” would be replaced with “high or medium risk”, or include changing this standard to the scope of the CIP SDT, or consider posting multiple versions of this standard depending on the outcome of CIP v5 in a similar fashion to how FAC-003 was posted as part of the GO/TO effort of Project 2010-07.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Asset.”</i></p> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>On “forced intrusion”, the phrase “at BES facility” is open to interpretation as “BES Facility” (e.g., controversy surrounding CAN-0016) which would exclude control centers and other critical/high/medium cyber system Physical Security Perimeters (PSPs). We suggest changing this to “BES Facility or the PSP or Defined Physical Boundary of critical/high/medium cyber assets”. This change would cause a change to the applicability of this reportable event to coincide with CIP standard applicability.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>On "Risk to BES equipment", that phrase is open to too wide a range of interpretation; we suggest adding the word "imminent" in front of it, i.e., "Imminent risk to BES equipment". For instance, heavy thermal loading puts equipment at risk, but not imminent risk. Also, "non-environmental" used as the threshold criteria is ambiguous. For instance, the example in the footnote, if the BES equipment is near railroad tracks, then trains getting derailed can be interpreted as part of that BES equipment's "environment", defined in Webster's as "the circumstances, objects, or conditions by which one is surrounded". It seems that the SDT really means "non-weather related", or "Not risks due to Acts of Nature".</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• 'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its</i></li> </ul>



Organization	Yes or No	Question 4 Comment
		<p><i>Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>On "public appeal", in the threshold, the descriptor "each" should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event?</p> <p><i>The DSR SDT has updated the event concerning "public appeals" based on comments received and now reads as: "Public appeal for load reduction event".</i></p> <p>Should LSE be an applicable entity to "loss of firm load"? As proposed, the DP is but the LSE is not. In an RTO market, will a DP know what is firm and what is non-firm load? Suggest eliminating DP from the applicability of "system separation". The system separation we care about is separation of one part of the BES from another which would not involve a DP.</p> <p><i>The DSR SDT believes the "Entity with Reporting Responsibility" maintains the minimum number and type of entities that will be required to report such an event.</i></p> <p>On "Unplanned Control Center Evacuation", CIP v5 might add GOP to the applicability, another reason to add revision of EOP-004-2 to the scope of the CIP v5 drafting team, or in other ways coordinate this SDT with that SDT. Consider posting a couple of versions of the standard depending on the outcome of CIP v5 in a similar fashion to the multiple versions of FAC-003 posted with the Go/TO effort of Project 2010-07.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT can only provide information on approved standards, not yet to be defined standards.</i></p>
<p><b>Response: Thank you for your comment.</b> Please see response above.</p>		
<p>Dominion</p>		<p>There is still inconsistency in Attachment 1 vs. the DOE OE-417 form; in future changes, Dominion suggests align/rename events similar to that of the ‘criteria for filing’ events listed in the DOE OE-417, by working in coordination with the DOE.</p> <p><i>Thank you for your comment. Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p><i>Please note that not all entities in North America are required to submit the DOE Form OE 417.</i></p> <p>Minor comment; in the Background section, the drafting team refers to bulk power</p>

Organization	Yes or No	Question 4 Comment
		<p>system (redline page 5; 1st paragraph and page 7; 2nd paragraph) rather than bulk electric system.</p> <p><i>This has been revised to Bulk Electric System.</i></p> <p>The note in Attachment 1 states in part that “the affected Responsible Entity shall notify parties per R1 and ...” Dominion believes the correct reference to be R3. In addition, capitalized terms “Event” and “Event Report” are used in this note. Dominion believes the terms should be non-capitalized as they are not NERC defined terms.</p> <p><i>The DSR SDT has updated this note based on comments received and now reads as: “NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written event report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p>Attachment 1 - “Detection of a reportable Cyber Security Incident - That meets the criteria in CIP-008”. This essentially equates the criteria to be defined by the entity in its procedures as required by CIP-008 R1.1., additional clarification should be added in Attachment 1 to make this clear.</p> <p><i>The DSR SDT believes that this event language provides enough clarity by providing the minimum events to be reported.</i></p> <p>The last sentence in Attachment 2 instructions should clarify that the email, facsimile and voice communication methods are for ERO notification only.</p> <p><i>The DSR SDT agrees and has revised the sentence to include “to the ERO”.</i></p> <p>Dominion continues to believe that the drill or exercise specified in R4 is</p>

Organization	Yes or No	Question 4 Comment
		<p>unnecessary. Dominion suggests deleting this activity in the requirement.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: "Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. "</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Ingleside Cogeneration LP</p>		<p>We are encouraged that the 2009-01 project team has eliminated duplicate reporting requirements from multiple organizations and governmental agencies. Ingleside Cogeneration LP believes that there are further improvements that can be made in this area - as the remaining overlap seem to be a result of legalities and preferences, not technical issues. We would like to see an ongoing commitment by NERC for a single process that will consolidate and automate data entry, submission, and distribution.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>opportunity not a 'must-have'</i></p> <ul style="list-style-type: none"> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p><i>Please note that not all entities in North America are required to submit the DOE Form OE 417.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>		<p>We believe that reporting of the events in Attachment 1 has no reliability benefit to the bulk electric system. In addition, Attachment 1, in its current form, is likely to be impossible to implement consistently across North America. A requirement, to be considered a reliability requirement, must be implementable. We suggest that Attachment 1 should be removed.</p> <p><i>The DSR SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p> <p>We have a question about what looks like a gap in this standard: Assuming one of the drivers for the standard is to protect against a coordinated physical or cyber attack on the grid, what happens if the attack occurs in 3-4 geographically diverse areas? State or provisional law enforcement officials are not accountable under the standard, so we have no way of knowing if they report the attack to the FBI or the</p>

Organization	Yes or No	Question 4 Comment
		<p>RCMP. Even if one or two of them did, might not the FBI, in different parts of the country, interpret it as vandalism, subject to local jurisdiction? It seems that NERC is the focal point that would have all the reports and, ideally, some knowledge how the pieces fit together. It looks like NERC's role is to solely pass information on "applicable" events to the FERC. Unless the FERC has a 24x7 role not shown in the standard, should not NERC have some type of assessment responsibility to makes inquiries at the FBI/RCMP on whether they are aware of the potential issue and are working on it?" The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers."</p> <p><i>Requirement R1, Part 1.2 was updated and now reads as: "A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement governmental or provincial agencies."</i></p> <p><i>By reporting to the ERO all events, this will allow the ERO to coordinate with other agencies as they see fit.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi</p>		<p>We feel that the drafting team has done an excellent job of providing clarification and reasonable reporting requirements to the right functional entity. However we feel additional clarification should be made in the Attachment I Event Table. We suggest the following modifications: For the Event: BES Emergency resulting in automatic firm load shedding Modify the Entity with Reporting Responsibility to: Each DP or TOP that experiences the automatic load shedding within their respective distribution serving or Transmission Operating area.</p> <p><i>The DSR SDT believes the "Entity with Reporting Responsibility" contains the minimum</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>entities that will be required to report and reads as: "Each DP or TOP that experiences the automatic load shedding"</i></p> <p>For the Event: Loss of Firm load for 15 Minutes Modify the Entity with Reporting Responsibility to: Each BA, TOP, DP that experiences the loss of firm load within their respective balancing, Transmission operating, or distribution serving area.</p> <p><i>The DSR SDT believes the "Entity with Reporting Responsibility" contains the minimum entities that will be required to report and reads as: "Each BA, TOP, DP that experiences the loss of firm load"</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
PSEG		<p>We have several comments:1. The "Law Enforcement Reporting" section on p. 6 is unclearly written. The first three sentences are excerpted here: "The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement."The outages described prior to the last sentence are "vandalism and terrorism." The next sentence states "Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES." If the SDT intended to only have events reported to law enforcement that could to Cascading, it should state so clearly and succinctly. But other language implies otherwise.</p> <p><i>The DSR SDT has updated the "Example of reporting _Process including Law Enforcement", and please note that this is only an "example".</i></p> <p>a. The footnote 1 on Attachment 1 (p. 20) states: "Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g.,</p>

Organization	Yes or No	Question 4 Comment
		<p>removal of grounding straps rendering protective relaying inoperative).” Rendering a relay inoperative may or may not lead to Cascading.</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “A physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>b. With regard to “forced intrusion,” footnote 2 on Attachment 1 states: “Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects (sic) the reliability of the BES.” The criterion, or criteria, for reporting an event to law enforcement needs to be unambiguous. The SDT needs to revise this “Law Enforcement Section” so that is achieved. The “law enforcement reporting” criterion, or criteria, should also be added to the flow chart on p. 9. We suggest the following as a starting point for the team to discuss: there should be two criteria for reporting an event to law enforcement: (1) BES equipment appears to have been deliberately damaged, destroyed, or stolen, whether by physical or cyber means, or (2) someone has gained, or attempted to gain, unauthorized access by forced or unauthorized entry (e.g., via a stolen employee keycard badge) into BES facilities, including by physical or cyber means.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows: The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>deleted</i></p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>2. The use of the terms “communicating events” in R1.3, and the use of the term “communication process” are confusing because in other places such as R3 the term “reporting” is used. If the SDT intends “communicating” to mean “reporting” as that later term is used in R3, it should use the same “reporting” term in lieu of “communicating” or “communication” elsewhere. Inconsistent terminology causes confusion. PSEG prefers the word “reporting” because it is better understood.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Requirement R1, Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>The SDT envisions that most entities will only need to slightly modify their existing CIP-001 Sabotage Reporting procedures in order to comply with the Operating Plan requirement in this proposed standard. As many of the features of both are substantially similar, the SDT feels that some information may need to updated and verified.</i></p> <p>3. Attachment 1 needs to more clearly define what is meant by “recognition of an event.”a. When equipment or a facility is involved, it would better state within “X” time (e.g., 1 hour) of “of confirmation of an event by the entity that either owns or operates the Element or Facility.”</p> <p><i>Based on stakeholder comments, Requirement R1 was revised for clarity. Requirement R1, Part 1.1 was revised to replace the word “identifying” with “recognizing” and Part 1.2 was eliminated. This also aligns the language of the standard with FERC Order 693, Paragraph 471.</i></p> <p><i>“(2) specify baseline requirements regarding what issues should be addressed in the procedures for recognizing {emphasis added} sabotage events and making personnel aware of such events;”</i></p> <p>b. Other reports should have a different specification of the starting time of the reporting deadline clock. For example, in the requirement for reporting a “BES Emergency requiring public appeal for load reduction,” it is unclear what event is required to be reported - the “BES Emergency requiring public appeal” or “public appeal for load reduction.” If the later is intended, then the event should be reported within “24 hours after a public appeal for load reduction is first issued.” These statements need to be reviewed and customized for each event by the SDT so they are unambiguous.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>In summary, the starting time for the reporting clock to start running should be made clear for each event. This will require that the SDT review each event and customize the starting time appropriately. The phrase "recognition of an event" should not be used because it is too vague.</p> <p><i>Based on stakeholder comments, Requirement R1 was revised for clarity. Part 1.1 was revised to replace the word "identifying" with "recognizing" and Part 1.2 was eliminated. This also aligns the language of the standard with FERC Order 693, Paragraph 471.</i></p> <p><i>"(2) specify baseline requirements regarding what issues should be addressed in the procedures for recognizing {emphasis added} sabotage events and making personnel aware of such events;"</i></p> <p>4. When EOP-004-2 refers to other standards, it frequently omits the version of the standard. Example: see the second and third row of Attachment 1 that refers to "CIP-002." Include the version on all standards referenced.</p> <p><i>References to CIP-002 have been removed from the standard. The intent of referencing those standards is to prevent rewriting the standard within EOP-004-2. The threshold for reporting CIP-008 events is written as "That meets the criteria in CIP-008-4 or its successor."</i></p>

Organization	Yes or No	Question 4 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Ameren</p>		<p>Yes. We have the other comments as follow:(1) The "EOP-004 Attachment 1: Events Table" is quite lengthy and written in a manner that can be quite subjective in interpretation when determining if an event is reportable. We believe this table should be clear and unambiguous for consistent and repeatable application by both reliability entities and a CEA.</p> <p><i>The DSR SDT has reviewed and further revised Attachment 1 based on comments received. We believe that it is both concise and easily interpreted.</i></p> <p>The table should be divided into sections such as: 9a) Events that affect the BES that are either clearly sabotage or suspected sabotage after review by an entity's security department and local/state/federal law enforcement.(b) Events that pose a risk to the BES and that clearly reach a defined threshold, such as load loss, generation loss, public appeal, EEAs, etc. that entities are required to report by the end of the next business day.(c) Other events that may prove valuable for lessons learned, but are less definitive than required reporting events. These events should be reported voluntarily and not be subject to a CEA for non-reporting.</p> <p><i>The DSR SDT received many comments regarding the various entries of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is "A reportable Cyber Security Incident" as it required by CIP-008 and FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>The table was reformatted to separate one hour reporting and 24 hour reporting. The last column of the table was also deleted and the information contained in it was transferred to the sentence above each table. These sentences are:</i></p> <p><i>"One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event."</i></p> <p><i>"Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event."</i></p> <p>(d)Events identified through other means outside of entity reporting, but due to their nature, could benefit the industry by an event report with lessons learned. Requests to report and perform analysis on these type of events should be vetted through a ERO/Functional Entity process to ensure resources provided to this effort have an effective reliability benefit.</p> <p><i>The DSR SDT has deleted the "lessons learned" language. Requirement R4 now only requires an annual review of the Operating Plan - the '90 days' and ' other circumstances' elements have been removed.</i></p> <p>(2)Any event reporting shall not in any manner replace or inhibit an Entity's responsibility to coordinate with other Reliability Entities (such as the RC, TOP, BA, GOP as appropriate) as required by other Standards, and good utility practice to operate the electric system in a safe and reliable manner.</p> <p><i>The DSR SDT concurs with your comment.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>(3) The 1 hour reporting maximum time limit for all GO events in Attachment 1 should be lengthened to something reasonable - at least 24 hours. Operators in our energy centers are well-trained and if they have good reason to suspect an event that might have serious impact on the BES will contact the TOP quickly. However, constantly reporting events that turn out to have no serious BES impact and were only reported for fear of a violation or self-report will quickly result in a cry wolf syndrome and a great waste of resources and risk to the GO and the BES. The risk to the GO will be potential fines, and the risk to the BES will be ignoring events that truly have an impact of the BES.</p> <p><i>The DSR SDT received many comments regarding the various entries of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is "A reportable Cyber Security Incident" as it required by CIP-008 and FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>The table was reformatted to separate one hour reporting and 24 hour reporting. The last column of the table was also deleted and the information contained in it was transferred to the sentence above each table. These sentences are:</i></p> <p><i>"One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>event.”</i></p> <p><i>“Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event.”</i></p> <p>(4)The 2nd and 3rd Events on Attachment 1 should be reworded so they do not use terms that may have been deleted from the NERC Glossary by the time FERC approves this Standard.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>(5) The terms “destruction” and “damage” are key to identifying reportable events. Neither has been defined in the Standard. The term destruction is usually defined as 100% unusable. However, the term damage can be anywhere from 1% to 99% unusable and take anywhere from 5 minutes to 5 months to repair. How will we know what the SDT intended, or an auditor will expect, without additional information?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p><i>(6)We also do not understand why "destruction of BES equipment" (first item Attachment 1, first page) must be reported &lt; 1 hour, but "system separation (islanding) &gt; 100 MW" (Attachment 1, page 3) does not need to be reported for 24 hours.</i></p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <p><i>The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>(7)The first 2 Events in Attachment 1 list criteria Threshold for Reporting as "...operational error, equipment failure, external cause, or intentional or unintentional human action." The term "intentional or unintentional human action" appears to cover "operational error" so these terms appear redundant and create risk of misreporting. Can this be clarified?</p> <p><i>The DSR SDT has updated this language based on comments received and now reads as: " Damage or destruction of a Facility that:</i></p> <p><i>Affects an IROL (per FAC-014)</i></p> <p><i>OR</i></p> <p><i>Results in the need for actions to avoid an Adverse Reliability Impact</i></p> <p><i>OR</i></p> <p><i>Results from intentional human action."</i></p> <p>(8)The footnote of the first page of Attachment 1 includes the explanation "...ii) Significantly affects the reliability margin of the system..." However, the GO is prevented from seeing the system and has no idea what BES equipment can affect the reliability margin of the system. Can this be clarified by the SDT?</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: "A physical threat that could impact the operability of a Facility". This event has the following footnote, which states: "Examples include a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>(9) The use of the term “BES equipment” is problematic for a GO. NERC Team 2010-17 (BES Definition) has told the industry its next work phase will include identifying the interface between the generator and the transmission system. The 2010-17 current effort at defining the BES still fails to clearly define whether or not generator tie-lines are part of the BES. In addition, NERC Team 2010-07 may also be assigned the task of defining the generator/transmission interface and possibly whether or not these are BES facilities. Can the SDT clarify the use of this term? For example, does it include the entire generator lead-line from the GSU high-side to the point of interconnection? Does it include any station service transformer supplied from the interconnected BES?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘ to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Performance Analysis Subcommittee</p>		<p>There continues to be some confusion regarding whether the loss of firm load was consistent with the planned operation of the system or was an unintended consequence. As such it might be helpful if instead of a single check box for loss of firm load there were two check boxes 1) loss of firm load – consequential and 2) loss of firm load non-consequential.</p> <p><i>Thank you for your comment. The DSR SDT believes that Attachment 2 contains the minimum amount of information under this standard. Any entity reporting an event can add as much information as they see fit.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p><b>Southwestern Power Administration's</b></p>		<p>"Attachment 1 contains elements that do not need to be included, and redundant elements such as:</p> <p>Forced intrusion at BES Facility - A facility break-in does not necessarily mean that the facility has been impacted or has undergone damage or destruction.</p> <p><i>The DSR SDT discussed this event as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>revised to “Any physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>Detection of a reportable Cyber Security Incident per CIP-008 - If entities are addressing this requirement in CIP-008, why do so again in EOP-004 (Attachment 2- EOP-004, Reporting Requirement number 5)?</p> <p><i>The reporting aspects of CIP-008 have been removed from CIP-008 and are included in EOP-004. Please see the Implementation Plan with regards to the retirement of CIP-008, R1.3</i></p> <p>Transmission Loss: Each TOP that experiences transmission loss of three or more facilities - This element should be removed or rewritten so that it only applies when the loss includes a contingent element of an IROL facility."</p> <p><i>The DSR SDT disagrees with limiting this type of event to only “a contingent element</i></p>

Organization	Yes or No	Question 4 Comment
		<i>of an IROL facility.” It is important for situational awareness and trending analysis to have these types of events reported.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
The Performance Analysis Subcommittee		<p>There continues to be some confusion regarding whether the loss of firm load was consistent with the planned operation of the system or was an unintended consequence. As such it might be helpful if instead of a single check box for loss of firm load there were two check boxes 1) loss of firm load – consequential and 2) loss of firm load non-consequential.</p> <p><i>The DSR SDT believes that this information should be obtained in follow up through the Events Analysis Program. The reporting entity may have concerns or difficulties in determining if load is consequential or non-consequential in its initial analysis for the report. Further investigation outside of the reporting time of 24 hours may be needed to make this determination.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Xcel Energy		
Los Angeles Department of Water and Power		
Liberty Electric Power		
Nebraska Public Power District		
Southwestern Power Administration		

Organization	Yes or No	Question 4 Comment
Electric Reliability Council of Texas, Inc.		

**END OF REPORT**

## Consideration of Comments

### Disturbance and Sabotage Reporting – Project 2009-01

The Disturbance and Sabotage Reporting Drafting Team thanks all commenters who submitted comments on the draft standard EOP-004-2. This standard was posted for a 30-day public comment period from April 25, 2012 through May 24, 2012. Stakeholders were asked to provide feedback on the standards and associated documents through a special electronic comment form. There were 87 sets of comments, including comments from approximately 210 different people from approximately 135 companies representing 9 of the 10 Industry Segments as shown in the table on the following pages.

All comments submitted may be reviewed in their original format on the standard's project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President of Standards and Training, Herb Schrayshuen, at 404-446-2560 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

---

<sup>1</sup> The appeals process is in the Standard Processes Manual:

[http://www.nerc.com/files/Appendix\\_3A\\_Standard\\_Processes\\_Manual\\_Rev%201\\_20110825.pdf](http://www.nerc.com/files/Appendix_3A_Standard_Processes_Manual_Rev%201_20110825.pdf)

**Summary Consideration:** The DSR SDT received several suggestions for improvement to the standard. As a result of these revisions, the DSR SDT is posting the standard for a second successive ballot period.

The DSR SDT has removed reporting of Cyber Security Incidents from EOP-004 and have asked the team developing CIP-008-5 to retain this reporting. With this revision, the Interchange Coordinator, Transmission Service Providers, Load-Serving Entity, Electric Reliability Organization and Regional Entity were removed as Responsible Entities.

Most of the language contained in the “Background” Section was moved to the “Guidelines and Technical Basis” Section. Minor language changes were made to the measures and the data retention section. Attachment 2 was revised to list events in the same order in which they appear in Attachment 1.

Requirement R1 was revised to include the Parts in the main body of the Requirement. The Measure and VSLs were updated accordingly.

Following review of the industry’s comments, the SDT has re-examined the FERC Directive in Order 693 and has dropped both R3 and R4, as they were written and established a new Requirement R3 to have the Registered Entity “validate” the contact information in the contact list(s) they may have for the events applicable to them. This validation needs to be performed each calendar year to ensure that the list(s) have current and up-to-date contact data.

- R3. Each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*

The SDT reviewed, discussed and updated Attachment 1 based on comments received for commenters, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Under the Event Column, the SDT starts to classify each type of an event by assigning an “Event” title. The DSRSDT then updated the “Entity with Reporting Responsibilities” column to simply state which entity has the responsibility to report if they experience an event. The last column, “Threshold for Reporting” is a bright line that, if reached, the entity needs to report that they experienced the applicable event per Requirement 1.

The DSR SDT proposed a revision to the NERC Rules of Procedure (Section 812). The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.



**Index to Questions, Comments, and Responses**

1. The DSR SDT has revised EOP-004-2 by removing Requirement 1, Part 1.4 and separating Parts 1.3 and 1.5 into new Requirements R3 and R4. Requirement R3 calls for an annual test of the communications portion of the Operating Plan and Requirement R4 requires an annual review of the Operating Plan. Do you agree with this revision? If not, please explain in the comment area below. .... 19
2. The DSR SDT made clarifying revisions to Attachment 1 based on stakeholder feedback. Do you agree with these revisions? If not, please explain in the comment area below. .... 46
3. The DSR SDT has proposed a new Section 812 to be incorporated into the NERC Rules of Procedure. Do you agree with the proposed addition? If not, please explain in the comment area below. .... 169
4. Do you have any other comment, not expressed in the questions above, for the DSR SDT? .... 183

**The Industry Segments are:**

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
1.	Group	Guy Zito	Northeast Power Coordinating Council												X
Additional Member	Additional Organization	Region	Segment Selection												
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10											

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
2.	Greg Campoli	NewYork Independent System Operator	NPCC	2																
3.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1																
4.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1																
5.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10																
6.	Mike Garton	Dominion Resources Services, Inc.	NPCC	5																
7.	Kathleen Goodman	ISO - New England	NPCC	2																
8.	Michael Jones	National Grid	NPCC	1																
9.	David Kiguel	Hydro One Networks Inc.	NPCC	1																
10.	Michael Lombardi	Northeast Utilities	NPCC	1																
11.	Randy MacDonald	New Brunswick Power Transmission	NPCC	9																
12.	Bruce Metruck	New York Power Authority	NPCC	6																
13.	Silvia Parada Mitchell	NextEra Energy, LLC	NPCC	5																
14.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10																
15.	Robert Pellegrini	The United Illuminating Company	NPCC	1																
16.	Si Truc Phan	Hydro-Quebec TransEnergie	NPCC	1																
17.	David Ramkalawan	Ontario Power Generation, Inc.	NPCC	5																

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
18.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC	3																
19.	Michael Schiavone	National Grid	NPCC	1																
20.	Wayne Sipperly	New York Power Authority	NPCC	5																
21.	Tina Teng	Independent Electricity System Operator	NPCC	2																
22.	Donald Weaver	New Brunswick System Operator	NPCC	2																
23.	Ben Wu	Orange and Rockland Utilities	NPCC	1																
2.	Group	Kent Kujala	DECo			X	X	X												
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Barbara Holland		RFC	3, 4, 5																
2.	Alexander Eizans		RFC	3, 4, 5																
3.	Group	Greg Rowland	Duke Energy		X		X		X	X										
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Doug Hils	Duke Energy	RFC	1																
2.	Ed Ernst	Duke Energy	SERC	3																
3.	Dale Goodwine	Duke Energy	SERC	5																
4.	Greg Cecil	Duke Energy	RFC	6																
4.	Group	Brenda Hampton	Luminant							X										

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Mike Laney	Luminant Generation Company, LLC	5												
5. Group	Patricia Robertson	BC Hydro	X	X	X		X							
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Venkatarmakrishnan Vinnakota	BC Hydro	WECC 2												
2. Pat G. Harrington	BC Hydro	WECC 3												
3. Clement Ma	BC Hydro	WECC 5												
6. Group	Chris Higgins	Bonneville Power Administration	X		X		X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. James	Burns	WECC 1												
2. John	Wylder	WECC 1												
3. Kristy	Humphrey	WECC 1												
7. Group	Jesus Sammy Alcaraz	Imperial Irrigation District (IID)	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Joel Fugett	IID	WECC 1, 3, 4, 5, 6												
2. Cathy Bretz	IID	WECC 1, 3, 4, 5, 6												
8. Group	Connie Lowe	Dominion	X		X		X	X						

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																																																	
			1	2	3	4	5	6	7	8	9	10																																								
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Michael Crowley</td> <td>SERC</td> <td></td> <td>1, 3, 5, 6</td> </tr> <tr> <td>2. Mike Garton</td> <td>NPCC</td> <td></td> <td>5, 6</td> </tr> <tr> <td>3. Randi Heise</td> <td>MRO</td> <td></td> <td>5</td> </tr> <tr> <td>4. Louis Slade</td> <td>RFC</td> <td></td> <td>5</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Michael Crowley	SERC		1, 3, 5, 6	2. Mike Garton	NPCC		5, 6	3. Randi Heise	MRO		5	4. Louis Slade	RFC		5																				
Additional Member	Additional Organization	Region	Segment Selection																																																	
1. Michael Crowley	SERC		1, 3, 5, 6																																																	
2. Mike Garton	NPCC		5, 6																																																	
3. Randi Heise	MRO		5																																																	
4. Louis Slade	RFC		5																																																	
9.	Group	Robert Rhodes	SPP Standards Review Group		X																																															
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Matt Bordelon</td> <td>CLECO Power</td> <td>SPP</td> <td>1, 3, 5</td> </tr> <tr> <td>2. Michelle Corley</td> <td>CLECO Power</td> <td>SPP</td> <td>1, 3, 5</td> </tr> <tr> <td>3. Gary Cox</td> <td>Southwestern Power Administration</td> <td>SPP</td> <td>1, 5</td> </tr> <tr> <td>4. Dan Lusk</td> <td>Xcel Energy</td> <td>SPP</td> <td>1, 3, 5, 6</td> </tr> <tr> <td>5. Stephen McGie</td> <td>City of Coffeyville</td> <td>SPP</td> <td>NA</td> </tr> <tr> <td>6. John Payne</td> <td>KEPCO</td> <td>SPP</td> <td>4</td> </tr> <tr> <td>7. Terri Pyle</td> <td>Oklahoma Gas &amp; Electric</td> <td>SPP</td> <td>1, 3, 5</td> </tr> <tr> <td>8. Sean Simpson</td> <td>Board of Public Utilities, City of McPherson, KS</td> <td>SPP</td> <td>NA</td> </tr> <tr> <td>9. Ashley Stringer</td> <td>Oklahoma Municipal Power Authority</td> <td>SPP</td> <td>4</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Matt Bordelon	CLECO Power	SPP	1, 3, 5	2. Michelle Corley	CLECO Power	SPP	1, 3, 5	3. Gary Cox	Southwestern Power Administration	SPP	1, 5	4. Dan Lusk	Xcel Energy	SPP	1, 3, 5, 6	5. Stephen McGie	City of Coffeyville	SPP	NA	6. John Payne	KEPCO	SPP	4	7. Terri Pyle	Oklahoma Gas & Electric	SPP	1, 3, 5	8. Sean Simpson	Board of Public Utilities, City of McPherson, KS	SPP	NA	9. Ashley Stringer	Oklahoma Municipal Power Authority	SPP	4
Additional Member	Additional Organization	Region	Segment Selection																																																	
1. Matt Bordelon	CLECO Power	SPP	1, 3, 5																																																	
2. Michelle Corley	CLECO Power	SPP	1, 3, 5																																																	
3. Gary Cox	Southwestern Power Administration	SPP	1, 5																																																	
4. Dan Lusk	Xcel Energy	SPP	1, 3, 5, 6																																																	
5. Stephen McGie	City of Coffeyville	SPP	NA																																																	
6. John Payne	KEPCO	SPP	4																																																	
7. Terri Pyle	Oklahoma Gas & Electric	SPP	1, 3, 5																																																	
8. Sean Simpson	Board of Public Utilities, City of McPherson, KS	SPP	NA																																																	
9. Ashley Stringer	Oklahoma Municipal Power Authority	SPP	4																																																	

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
10. Mike Swearingen	Tri-County Electric Cooperative	SPP 4												
11. Michael Veillon	CLECO Power	SPP 1, 3, 5												
12. Mark Wurm	Board of Public Utilities, City of McPherson, KS	SPP NA												
13. Jonathan Hayes	Southwest Power Pool	SPP 2												
14. Julie Lux	Westar Energy	SPP 1, 3, 5, 6												
15. Greg McAuley	Oklahoma Gas & Electric	SPP 1, 3, 5												
10. Group	Frank Gaffney	Florida Municipal Power Agency	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Timothy Beyrle	City of New Smyrna Beach	FRCC 4												
2. Jim Howard	Lakeland Electric	FRCC 3												
3. Greg Woessner	Kissimmee Utility Authority	FRCC 3												
4. Lynne Mila	City of Clewiston	FRCC 3												
5. Joe Stonecipher	Beaches Energy Services	FRCC 1												
6. Cairo Vanegas	Fort Pierce Utility Authority	FRCC 4												
7. Randy Hahn	Ocala Utility Services	FRCC 3												
11. Group	Brent Ingebrigtsen	LG&E and KU Services	X		X		X	X						
No additional members listed.														

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
12.	Group	WILL SMITH	MRO NSRF	X	X	X	X	X	X					X
<b>Additional Member</b>				<b>Additional Organization Region Segment Selection</b>										
1.	MAHMOOD SAFI	OPPD	MRO	1, 3, 5, 6										
2.	CHUCK LAWRENCE	ATC	MRO	1										
3.	TOM WEBB	WPS	MRO	3, 4, 5, 6										
4.	JODI JENSON	WAPA	MRO	1, 6										
5.	KEN GOLDSMITH	ALTW	MRO	4										
6.	ALICE IRELAND	XCEL	MRO	1, 3, 5, 6										
7.	DAVE RUDOLPH	BEPC	MRO	1, 3, 5, 6										
8.	ERIC RUSKAMP	LES	MRO	1, 3, 5, 6										
9.	JOE DEPOORTER	MGE	MRO	3, 4, 5, 6										
10.	SCOTT NICKELS	RPU	MRO	4										
11.	TERRY HARBOUR	MEC	MRO	3, 5, 6, 1										
12.	MARIE KNOX	MISO	MRO	2										
13.	LEE KITTELSON	OTP	MRO	1, 3, 4, 5										
14.	SCOTT BOS	MPW	MRO	1, 3, 5, 6										



Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
15. TONY EDDLEMAN	NPPD	MRO	1, 3, 5											
16. MIKE BRYTOWSKI	GRE	MRO	1, 3, 5, 6											
17. THERESA ALLARD	MPC	MRO	1, 3, 5, 6											
13. Group	Stephen J. Berger	PPL Corporation NERC Registered Affiliates						X	X					
Additional Member	Additional Organization	Region	Segment Selection											
1.	Annette Bannon	PPL Generation, LLC on Behalf of its NERC Registered Entities	RFC	5										
2.			WECC	5										
3.	Mark Heimbach	PPL EnergyPlus, LLC	MRO	6										
4.			NPCC	6										
5.			SERC	6										
6.			SPP	6										
7.			RFC	6										
8.			WECC	6										
14. Group	Joe Tarantino	SMUD & BANC		X		X	X	X	X					
Additional Member	Additional Organization	Region	Segment Selection											

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
1. Kevin Smith	BANC	WECC	1																	
15. Group	Albert DiCaprio	ISO/RTO Standards Review Committee		X																
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1. Terry Bilke	MISO	RFC	2																	
2. Greg Campoli	NY ISO	NPCC	2																	
3. Gary DeShazo	CAISO	WECC	2																	
4. Matt Goldberg	ISO NE	NPCC	2																	
5. Kathleen Goodman	ISO NE	NPCC	2																	
6. Stephanie Monzon	PJM	RFC	2																	
7. Steve Myers	ERCOT	ERCOT	2																	
8. Bill Phillips	MSO	RFC	2																	
9. Don Weaver	NBSO	NPCC	2																	
10. Charles Yeung	SPP	SPP	2																	
16. Group	Sam Ciccone	FirstEnergy		X		X	X	X	X											
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1. Bill Duge	FE	RFC																		

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																		
			1	2	3	4	5	6	7	8	9	10									
2. Doug Hohlbaugh	FE	RFC																			
17.	Group	Jason Marshall	ACES Power Marketing Standards Collaborators																		
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																	
1.	Bill Hutchison	Southern Illinois Power Cooperative	SERC	1																	
2.	Robert A. Thomasson	Big Rivers Electric Corporation	SERC	1																	
3.	Shari Heino	Brazos Electric Power Cooperative	ERCOT	1																	
4.	John Shaver	Arizona Electric Power Cooperative	WECC	4, 5																	
5.	John Shaver	Southwest Transmission Cooperative	WECC	1																	
6.	Michael Brytowski	Great River Energy	MRO	1, 3, 5, 6																	
7.	Scott Brame	North Carolina Electric Membership Corporation	SERC	1, 3, 4, 5																	
18.	Group	Pawel Krupa	Seattle City Light										X		X	X					
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																	
1.	Pawel Krupa	Seattle City Light	WECC	1																	
2.	Dana Wheelock	Seattle City Light	WECC	3																	
3.	Hao Li	Seattle City Light	WECC	4																	
19.	Group	Scott Kinney	Avista										X		X		X				

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																																																									
			1	2	3	4	5	6	7	8	9	10																																																
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Ed Groce</td> <td>Avista Corp</td> <td>WECC</td> <td>5</td> </tr> <tr> <td>2. Bob Lafferty</td> <td>Avista Corp</td> <td>WECC</td> <td>3</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Ed Groce	Avista Corp	WECC	5	2. Bob Lafferty	Avista Corp	WECC	3																																				
Additional Member	Additional Organization	Region	Segment Selection																																																									
1. Ed Groce	Avista Corp	WECC	5																																																									
2. Bob Lafferty	Avista Corp	WECC	3																																																									
20.	Group	Ron Sporseen	PNGC Comment Group																																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Joe Jarvis</td> <td>Blachly-Lane Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>2. Dave Markham</td> <td>Central Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>3. Dave Hagen</td> <td>Clearwater Power Company</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>4. Roman Gillen</td> <td>Consumers Power Inc.</td> <td>WECC</td> <td>1, 3</td> </tr> <tr> <td>5. Roger Meader</td> <td>Coos-Curry Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>6. Bryan Case</td> <td>Fall River Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>7. Rick Crinklaw</td> <td>Lane Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>8. Annie Terracciano</td> <td>Northern Lights Inc.</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>9. Aleka Scott</td> <td>PNGC Power</td> <td>WECC</td> <td>4</td> </tr> <tr> <td>10. Heber Carpenter</td> <td>Raft River Rural Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>11. Steve Eldrige</td> <td>Umatilla Electric Cooperative</td> <td>WECC</td> <td>1, 3</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Joe Jarvis	Blachly-Lane Electric Cooperative	WECC	3	2. Dave Markham	Central Electric Cooperative	WECC	3	3. Dave Hagen	Clearwater Power Company	WECC	3	4. Roman Gillen	Consumers Power Inc.	WECC	1, 3	5. Roger Meader	Coos-Curry Electric Cooperative	WECC	3	6. Bryan Case	Fall River Electric Cooperative	WECC	3	7. Rick Crinklaw	Lane Electric Cooperative	WECC	3	8. Annie Terracciano	Northern Lights Inc.	WECC	3	9. Aleka Scott	PNGC Power	WECC	4	10. Heber Carpenter	Raft River Rural Electric Cooperative	WECC	3	11. Steve Eldrige	Umatilla Electric Cooperative	WECC	1, 3
Additional Member	Additional Organization	Region	Segment Selection																																																									
1. Joe Jarvis	Blachly-Lane Electric Cooperative	WECC	3																																																									
2. Dave Markham	Central Electric Cooperative	WECC	3																																																									
3. Dave Hagen	Clearwater Power Company	WECC	3																																																									
4. Roman Gillen	Consumers Power Inc.	WECC	1, 3																																																									
5. Roger Meader	Coos-Curry Electric Cooperative	WECC	3																																																									
6. Bryan Case	Fall River Electric Cooperative	WECC	3																																																									
7. Rick Crinklaw	Lane Electric Cooperative	WECC	3																																																									
8. Annie Terracciano	Northern Lights Inc.	WECC	3																																																									
9. Aleka Scott	PNGC Power	WECC	4																																																									
10. Heber Carpenter	Raft River Rural Electric Cooperative	WECC	3																																																									
11. Steve Eldrige	Umatilla Electric Cooperative	WECC	1, 3																																																									
			X		X	X				X																																																		

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
12. Marc Farmer	West Oregon Electric Cooperative	WECC 4												
13. Margaret Ryan	PNGC Power	WECC 8												
14. Stuart Sloan	Consumers Power Inc.	WECC 1												
21. Group	Jennifer Eckels	Colorado Springs Utilities	X		X		X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Lisa Rosintoski		WECC 6												
2. Charlie Morgan		WECC 3												
3. Paul Morland		WECC 1												
22. Individual	Janet Smith, Regulatory Affairs Supervisor	Arizona Public Service Company	X		X		X	X						
23. Individual	Antonio Grayson	Southern Company Services	X		X		X	X						
24. Individual	Jim Eckelkamp	Progress Energy	X		X		X	X						
25. Individual	Sasa Maljukan	Hydro One	X											
26. Individual	John Brockhan	CenterPoint Energy	X											
27. Individual	Philip Huff	Arkansas Electric Cooperative Corporation			X	X		X						
28. Individual	Barry Lawson	National Rural Electric Cooperative Association (NRECA)			X	X								
29. Individual	Brian Evans-Mongeon	Utility Services										X		
30. Individual	E Hahn	MWDSC	X											
31. Individual	Scott McGough	Georgia System Operations Corporation			X	X								
32. Individual	Don Jones	Texas Reliability Entity												X

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
33.	Individual	Jonathan Appelbaum	United Illuminating Company	X									
34.	Individual	Dan Roethemeyer	Dynegy Inc.					X					
35.	Individual	Anthony Jablonski	ReliabilityFirst										X
36.	Individual	Joe Petaski	Manitoba Hydro	X		X		X	X				
37.	Individual	Michelle R. D'Antuono	Ingleside Cogeneration LP					X					
38.	Individual	Tim Soles	Occidental Power Services, Inc.			X			X				
39.	Individual	Alice Ireland	Xcel Energy	X		X		X	X				
40.	Individual	Andrew Gallo	City of Austin dba Austin Energy	X		X	X	X	X				
41.	Individual	Thad Ness	American Electric Power	X		X		X	X				
42.	Individual	Ed Davis	Entergy	X		X		X	X				
43.	Individual	Jack Stamper	Clark Public Utilities	X									
44.	Individual	Tracy Richardson	Springfield Utility Board			X							
45.	Individual	Wayne Sipperly	New York Power Authority	X		X		X	X				
46.	Individual	David Thorne	Pepco Holdings Inc	X		X							
47.	Individual	Chris de Graffenried	Consolidated Edison Co. of NY, Inc.	X		X		X	X				
48.	Individual	David Burke	Orange and Rockland Utilities, Inc.	X		X							
49.	Individual	Larry Raczkowski	FirstEnergy Corp	X		X	X	X	X				
50.	Individual	Linda Jacobson-Quinn	Farmington Electric Utility System			X							
51.	Individual	Michael Falvo	Independent Electricity System Operator		X								
52.	Individual	John Seelke	Public Service Enterprise Group	X		X		X	X				
53.	Individual	Terry Harbour	MidAmerican Energy	X		X		X	X				
54.	Individual	Brenda Lyn Truhe	PPL Electric Utilities	X									
55.	Individual	John Martinsen	Public Utility District No. 1 of Snohomish County	X		X	X	X	X				

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
56.	Individual	Russell A. Noble	Cowlitz County PUD			X	X	X						
57.	Individual	Thomas Washburn	FMPP						X					
58.	Individual	Bob Thomas	Illinois Municipal Electric Agency				X							
59.	Individual	Andrew Z. Puztai	Americian Transmission Company, LLC	X										
60.	Individual	Brenda Frazer	Edison Mission Marketing & Trading, Inc.	X				X						
61.	Individual	Kenneth A Goldsmith	Alliant Energy				X							
62.	Individual	Eric Salsbury	Consumers Energy			X	X	X						
63.	Individual	Kirit Shah	Ameren	X		X		X	X					
64.	Individual	Howard Rulf	We Energies			X	X	X						
65.	Individual	Brian J Murphy	NextEra Energy Inc	X		X		X	X					
66.	Individual	Kathleen Goodman	ISO New England Inc		X									
67.	Individual	Mark B Thompson	Alberta Electric System Operator		X									
68.	Individual	Maggy Powell	Exelon Corporation and its affiliates	X		X		X	X					
69.	Individual	Keith Morisette	Tacoma Power	X		X	X	X	X					
70.	Individual	Dennis Sismaet	Seattle City Light						X					
71.	Individual	Scott Miller	MEAG Power	X		X		X						
72.	Individual	Patrick Brown	Essential Power, LLC					X						
73.	Individual	Gregory Campoli	New York Independent System Operator		X									
74.	Individual	Don Schmit	Nebraska Public Power District	X		X		X						
75.	Individual	David Revill	GTC	X										
76.	Individual	Scott Berry	Indiana Municipal Power Agency				X							
77.	Individual	Christine Hasha	ERCOT		X									
78.	Individual	Molly Devine	Idaho Power Co.	X										
79.	Individual	Rebecca Moore Darrah	MISO		X									

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
80.	Individual	Nathan Mitchell	American Public Power Association			X							
81.	Individual	Tony Kroskey	Brazos Electric Power Cooperative	X									
82.	Individual	Darryl Curtis	Oncor Electric Delivery	X									
83.	Individual	Denise Lietz	Puget Sound Energy, Inc.	X		X		X					
84.	Individual	Steve Alexanderson	Central Lincoln			X	X					X	
85.	Individual	Mauricio Guardado	Los Angeles Department of Water and Power	X		X		X	X				
86.	Individual	James Tucker	Deseret Power	X									
87.	Individual	Michael Gammon	Kansas City Power & Light	X		X		X	X				



1. The SDT has revised EOP-004-2 by removing Requirement 1, Part 1.4 and separating Parts 1.3 and 1.5 into new Requirements R3 and R4. Requirement R3 calls for an annual test of the communications portion of the Operating Plan and Requirement R4 requires an annual review of the Operating Plan. Do you agree with this revision? If not, please explain in the comment area below.

**Summary Consideration:** Following review of the industry’s comments, the SDT has re-examined the FERC Directive in Order 693 and has dropped both R3 and R4, as they were written and established a new Requirement R3 to have the Registered Entity “validate” the contact information in the contact list(s) they may have for the applicable events to their functional registration(s). This validation needs to be performed on a calendar year period to ensure that the list(s) have current and up-to-date contact data.

Organization	Yes or No	Question 1 Comment
Northeast Power Coordinating Council	No	<p>Regarding Requirement R3, add the following wording from Measure M3 to the end of R3 after the wording “in Part 1.2.”: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable.</p> <p>Regarding Requirement R4, replace the words “an annual review” with the words “a periodic review. “Add the following to R4: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years. This does not preclude an annual review in an Entity’s operating plan. The Entity will then be audited to its plan. If the industry approves a five (5) year periodic review ‘cap’, and FERC disagrees, then FERC will have to issue a directive, state its reasons and provide justification for an annual review that is not arbitrary or capricious. Adding the one year “test” requirement adds to the administrative tracking burden and adds no reliability value.</p>

Organization	Yes or No	Question 1 Comment
<p><b>Response: The SDT thanks you for your comment. The SDT has removed R4 and revised R3 that calls for the responsible entity to validate contact information contain in the Operating Plan each calendar year as described in Requirement R1. The “Annual review” is used to ensure that the event reporting Operating Plan is up to date. If an entity experiences an event, communication evidence from the event may be used to show compliance.</b></p>		
DECo	No	Should only have annual "review" requirement rather than test.
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		
Duke Energy	No	Under R3, we agree with testing communications internally. Just as the ERO is excluded under R3, other external entities should also be excluded. External communications should be verified under R4.
<p><b>Response: The SDT thanks you for your comment. Due to industry opposition, the SDT revised Requirement R3 to remove test to “validate” contact information contained in the Operating Plan. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.</b></p>		
Dominion	No	While Dominion believes these are positive changes, we are concerned that placing actual calls to each of the “other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies” may be seen by one or more of those called as a ‘nuisance call’. Given the intent is to insure validity of the contact information (phone number, email, etc), we suggest revising the standard language to support various forms of validation to include, documented send/receipt of email, documented verification of phone number (use of phone book, directory assistance, etc).
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b></p>		

Organization	Yes or No	Question 1 Comment
SPP Standards Review Group	No	There needs to be a more granular definition of which entities should be included in the annual testing requirement in R3. To clarify what must be tested we propose the following language to replace the last sentence in M3. The annual test requirement is considered to be met if the responsible entity implements any communications process in the Operating Plan during an actual event. If no actual event was reported during the year, at least one of the communication processes in the Operating Plan must be tested to satisfy the requirement. We do not believe the time-stamping requirement in M3 and M4 contribute to the reliability of the BES. A dated review should be sufficient.
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comments. The Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event. Time-stamping has been removed.</b></p>		
Florida Municipal Power Agency	No	First, FMPA believes the standard is much improved from the last posting and we thank the SDT or their hard work. Having said that, there are still a number of issues, mostly due to ambiguity in terms, which cause us to vote Negative. R3 and R4 should be combined into a single requirement with two subparts, one for annual testing, and another to incorporate lessons learned from the annual testing into the plan (as opposed to an annual review).The word “test” is ambiguous as used in R3, e.g., does a table top drill count as a “test”? Is the intent to “test” the plan, or “test” the phone numbers, or what?
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b></p>		
MRO NSRF	No	R3 states: Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. R1.2 states: A process for communicating each of the

Organization	Yes or No	Question 1 Comment
		<p>applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies. With the use of “i.e.” the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that “e.g.” should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity. R3 requires and annual test that would include notification of:”other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.”Since NERC see no value in receiving these test notification we are doubtful other entities identified in R1.2 would find them of value. The real purpose of this requirement appears to be to assure operators are trained in the use of the procedure, process, or plan that assures proper notification. PER-005 already requires a systematic approach to training. It is hard to comprehend an organization not identifying this as a Critical Task, and if they failed to identify it as a Critical Task that this would not be a violation. Therefore this requirement is not required. Furthermore organizations test their response to events in accordance with CIP-008 R1.6. Therefore this requirement is covered by other standards and is not needed. The SDT may need to address this within M3, by stating “... that the annual test of the communication process of 1.2 (e.g. communication via e-mail, fax, phone, etc) was conducted”.</p> <p>R4 states: Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1. We question the value of requiring an annual review. If the Standard does not change, there seems little value in requiring an annual review. This appears to be an administrative requirement with little reliability value. It would likely be identified as a requirement that that should be eliminated as part of the</p>

Organization	Yes or No	Question 1 Comment
		request by FERC to identify strictly administrative requirements in FERC's recent order on FFTR. We suggest it be eliminated.
<p><b>Response: The SDT thanks you for your comment. Requirement R3 called for test of all contact information contain. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p> <p><b>The annual review requirement was maintained to meet the intent of NERC Order 693, Paragraph 466. The Commission does not specify a review period, as suggested; rather, believes that the appropriate period should be determined through the ERO's Reliability Standards.</b></p> <p><b>"The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</b></p>		
ISO/RTO Standards Review Committee	No	<p>The SRC offers comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see the latter part of the SRC's response to Question 4 below for an SRC proposed alternative approach: Regarding the proposed posted requirements, without indicating support of those requirements, the SRC concurs with the changes as they provide better streamlining of the four key requirements, with enhanced clarity. However, we are unclear on the intent of Requirement R3, in particular the phrase "not including notification to the Electric Reliability Organization" which begs the question on whether or not the test requires notifying all the other entities as if it were a real event. This may create confusion in ensuring compliance and during audits. Suggest the SDT to review and modify this requirement as appropriate. Regarding part 1.2, the SRC requests that the text be terminated after the word "type" and before "i.e." As written, the requirement does not allow for the entity to add/remove others as necessary. Please consider combining R3 and R4.</p>

Organization	Yes or No	Question 1 Comment
		<p>These can be accomplished at the same time. The process should be evaluated to determine effectiveness when an exercise or test is conducted. The SDT is asked to review the proposal and to address the issue of requirements vs. bullets vs. sub-requirements. It is suggested that each requirement be listed independently, and that each sub-step be bulleted.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b></p>		
<p>ACES Power Marketing Standards Collaborators</p>	<p>No</p>	<p>(1) We agree with removing Part 1.4 and we agree with a requirement to periodically review the event reporting Operating Plan. However we are not convinced the review of the Operating Plan needs to be conducted annually. The event reporting Operating Plan likely will not change frequently so a biannual review seems more appropriate.</p> <p>(2) We also do not believe that Requirement R3 is needed at all. Requirement R3 compels the responsible entity to test their Operating Plan annually. We do not see how testing an Operating Plan that is largely administrative in nature contributes to reliability. Given that the drafting team is obligated to address the FERC directive regarding periodic testing, we suggest the Operating Plan should be tested biannually. This would still meet the FERC directive requiring periodic testing.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
<p>Southern Company Services</p>	<p>No</p>	<p>There are approximately 17 event types for which Responsible Entities must have a process for communicating such events to the appropriate entities and R3 states that “The Responsible Entity shall conduct an annual test of the communications process”. It is likely that the same communications process will be used to report multiple event types, so Southern suggest that</p>

Organization	Yes or No	Question 1 Comment
		<p>the Responsible Entities conduct an annual test for each unique communications process. Southern suggest that this requirement be revised to state “Each Responsible Entity shall conduct an annual test of each unique communications process addressed in R1.2”.</p> <ul style="list-style-type: none"> <li>o In Attachment 1, for Event: “Damage or destruction of a Facility”, SDT should consider removing “Results from actual or suspected intentional human action” from the “Threshold for Reporting” column. The basis for this suggestion is as follows: <ul style="list-style-type: none"> <li>o The actual threshold should be measurable, similar to the thresholds specified for other events in Attachment 1. [Note: The first two thresholds identified (i.e., “Affects and IROL” and “Results in the need for actions to avoid an Adverse Reliability Impact”) are measurable and sufficiently qualify which types of Facility damage should be reported.]</li> <li>o The determination of human intent is too subjective. Including this as a threshold will cause many events to be reported that otherwise may not need to be reported. (e.g., Vandalism and copper theft, while addressed under physical threats, is more appropriately classified as damage. These are generally intentional human acts and would qualify for reporting under the current guidance in Attachment 1. They may be excluded from reporting by the threshold criteria regarding IROLs and Adverse Reliability Impact, if the human intent threshold is removed.)</li> <li>o It may be more appropriate to address human intent in the event description as follows: “Damage or destruction of a Facility, whether from natural or human causes”. Let the thresholds related to BES impact dictate the reporting requirement.</li> <li>o In Attachment 1, for Event: “Complete or partial loss of monitoring capability”, SDT should consider changing the threshold criteria to state: “Affecting a BES control center for 30 continuous minutes such that analysis capability (State Estimator, Contingency Analysis) is rendered</li> </ul> </li> </ul>

Organization	Yes or No	Question 1 Comment
		<p>inoperable.” There may be instances where the tools themselves are out of commission, but the control center personnel have sufficiently accurate models and alternate methods of performing the required analyses.</p>
<p><b>Response:</b> The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your initial comment.</p> <p>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Under the Event Column, the SDT starts to classify each type of an event by assigning an “Event” title. The DSR SDT then updated the “Entity with Reporting Responsibilities” column to simply state what entity has the responsibility to report if they experience an event. The last column, “Threshold for Reporting” is a bright line that, if reached, the entity needs to report that they experienced the applicable event per Requirement 1.</p> <p><b>Damage or destruction of a Facility:</b></p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state;</p> <p><b>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</b></p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p>		



Organization	Yes or No	Question 1 Comment
Progress Energy	No	<p>It should be clear that the Operating Plan can be multiple procedures. It is an unnecessary burden to have entities create a new document outlining the Operating Plan. Having to create a new Operating Plan would not improve reliability and would further burden limited resources. The annual testing required by R3 should be clarified. Do all communication paths need to be annually tested or just one path? An actual event may only utilize one communication 'leg' or 'path' and leave others untested and utilized. Entities may have a corporate level procedure that 'hand-shakes' with more localized procedures that make up the entire Operating Plan. Must all communications processes be tested to fulfill the requirement? If an entity has 'an actual event' it is not necessarily true that their Operating Plan has been exercised completely, yet this one 'actual event' would satisfy M3 as written.</p>
<p><b>Response: The SDT thanks you for your comment. Regarding your initial comment on the need to create a new document, the SDT believes that a Registered Entity with a procedure under CIP-001 will be able to utilize that document as the starting point for the Operating Plan here. The SDT feels that many of the necessary components will already exist in that document and the Registered Entity should only need to edit it accordingly for the types of Events applicable to them. The SDT has made changes to the standard highlighted in your comment.</b></p>		
Hydro One	No	<p>In the Requirement R3, we suggest adding the following wording from Measure M3 to the end of R3 after the wording “in Part 1.2.”: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable.</p> <p>Statement “... not including notification to the ERO...” as it stands now is confusing. We suggest that this statement is either reworded (and explained in the Rational for this requirement) or outright removed for clarity purposes In the requirement R4, we suggest replacing the words “an annual</p>

Organization	Yes or No	Question 1 Comment
		<p>review” with the words “a periodic review.” Add the following to R4: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years. This does not preclude an annual review in an Entity’s operating plan. The Entity will then be audited to its plan. If the industry approves a five (5) year periodic review ‘cap,’ and FERC disagrees, then FERC will have to issue a directive, state it reasons and provide justification for an annual review that is not arbitrary or capricious. Adding the one year “test” requirement adds to the administrative tracking burden and adds no reliability value.</p> <p>The table in the standard is clear regarding what events need to be reported. An auditor may want to see a test for "each" of the applicable events listed in EOP-004 Attachment 1.If the requirement for "an" annual test remains in the standard in R3, then it should be made clear that a test is not required for "each" of the applicable events listed in Attachment 1 (reference to R1.2.)</p>
<p><b>Response: The SDT thanks you for your comment. Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004 Attachment 1. The SDT removed the Operating Plan Process from Requirement 1 and revised the measure to meet the communications of Requirement R1, “to implement an operating plan within the time frames specified in Attachment 1.” Requirement R3 called for test of all contact information contained. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
CenterPoint Energy	No	CenterPoint Energy recommends that “and implement” be added after “Each Responsible Entity shall have” in Requirement R1. After such revision, Requirement R2 will not be needed as noted in previous comments submitted by the Company.

Organization	Yes or No	Question 1 Comment
		CenterPoint Energy also believes that Requirement R3 is not needed as an annual review encompassing the elements of the test described in the draft is sufficient.
<p><b>Response: The SDT thanks you for your comment. The SDT considered the consolidation of the first and second requirements. However, since the requirements have the Registered Entity perform two distinct steps, a single requirement cannot be written to achieve multiple tasks. Each task must stand on its own and be judged singly.</b></p> <p><b>The annual review helps ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Arkansas Electric Cooperative Corporation	No	AECC supports the comments submitted by ACES Power Marketing.
<p><b>Response: The SDT thanks you for your comment. Please review the response directed to them.</b></p>		
MWDSC	No	Transmission Owners (TO) should not be included as a "Responsible Entity" for this or other requirements because the Operating Plan is usually prepared by the Transmission Operator (TOP). For TOs who are not also TOPs, there are usually delegation agreements. CIP-001 never directly applied to TOs.
<p><b>Response: The SDT thanks you for your comment. The SDT disagrees with your assessment, as the TOs are physical owners of the equipment that would be affected by this standard. As Owners of the equipment, they need to be reporting on what is happening to their equipment.</b></p>		
Manitoba Hydro	No	(R1.1 and 1.2) It is unclear whether or not R1.1 and R1.2 require a separate recognition and communication process for each of the event types listed in Attachment 1 or if event types can be grouped as determined appropriate by the responsible entity given that identical processes will apply for multiple types of events. Manitoba Hydro suggests that wording is revised so

Organization	Yes or No	Question 1 Comment
		<p>that multiple event types can be addressed by a single process as deemed appropriate by the Responsible Entity.</p> <p>(R3) It is unclear whether or not R3 requires the testing of the communications process for each separate event type identified in Attachment 1. If so, this would be extremely onerous. Manitoba Hydro suggests that only unique communication processes (as identified by the Responsible Entity in R1.2) require an annual test and that testing should not be required for each type of event listed in Attachment 1. As well, Manitoba Hydro believes that testing the communications process alone is not as effective as also providing training to applicable personnel on the communications process. Manitoba Hydro suggests that R3 be revised to require annual training to applicable personnel on the communications process and that only 1 test per unique communications process be required annually.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comments. Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004 Attachment 1. The SDT has attempted to clarify that it is the choice of the Registered Entity on whether one, or more than one, contact list(s) is needed for the differing types applicable to them. Depending upon your needs of who you have an obligation to report, you can elect to have one or multiple lists.</b></p> <p><b>Requirement R3 called for test of all contact information contained. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Occidental Power Services, Inc.	No	<p>There should be an exception for LSEs with no BES assets from having an Operating Plan and, therefore, from testing and review of such plan. These LSEs have no reporting responsibilities under Attachment 1 and, if they have nothing ever to report, why would they have to have an Operating Plan and have to test and review it? This places an undue burden on small entities</p>

Organization	Yes or No	Question 1 Comment
		that cannot impact the BES.
<p><b>Response: The SDT thanks you for your comment. LSEs, as being applicable under the Cyber Security standards, were included in the applicability of this standard. Since the SDT is proposing to keep the Cyber Security reporting requirements in CIP-008, LSEs have been removed from the applicability of this standard. This action will not negate the LSE responsibilities under that standard and your comments will need to be addressed there.</b></p>		
Xcel Energy	No	<p>1) In R1.2, We understand what the drafting team had intended here. However, we are concerned that the way this requirement is drafted, using i.e., it could easily be interpreted to mean that you must notify all of those entities listed. Instead, we are suggesting that the requirement be rewritten to require entities to define in their Operating Plan the minimum organizations/entities that would need to be notified for applicable events. We believe this would remove any ambiguity and make it clear for both the registered entity and regional staff. We recommend the requirement read something like this: 1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to applicable internal and external organizations needed for the event type, as defined in the Responsible Entity's Operating Plan.</p> <p>2) We also suggest that R3 be clarified as to whether communications to all organizations must be tested or just those applicable to the test event type/scenario.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comments.</b></p>		
American Electric Power	No	R3: How many different scenarios need to be tested? For example, reporting sabotage-related events might well be different than reporting reliability-related events such as those regarding loss of Transmission. While these

Organization	Yes or No	Question 1 Comment
		<p>examples might vary a great deal, other such scenarios may be very similar in nature in terms of communication procedures. Perhaps solely testing the most complex procedure would be sufficient. AEP agrees with the changes with R3 calling for an annual test provided the requirement R2 is modified to include the measure language “The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event.”</p> <p>M3: While we agree that “the annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event”, we believe it would be preferable to include this text in R3 in addition to M3. Measures included in earlier standards (some of which are still enforced today) had little correlation to the requirement itself, and as a result, those measures were seldom referenced.</p> <p>M3: It would be unfair to assume that every piece of evidence required to prove compliance would be dated and time-stamped, so we recommend removing the text “dated and time-stamped” from the first sentence so that it reads “Each Responsible Entity will have records to show that the annual test of Part 1.2 was conducted.” The language regarding dating and time stamps in regards to “voice recordings and operating logs or other communication” is sufficient.</p>
<p><b>Response: The SDT thanks you for your comment. Based on stakeholder comments the SDT revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization. The SDT agrees with the point raised on time-stamping and has removed it from the standard.</b></p>		
Entergy	No	The requirement for a “time stamped record” of annual review is unreasonable and unnecessary. A dated document showing that a review was performed should be sufficient.

Organization	Yes or No	Question 1 Comment
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment. The SDT has removed time-stamping from the standard.</b></p>		
New York Power Authority	No	Please see comments submitted by NPCC Regional Standards Committee (RSC).
<p><b>Response: The SDT thanks you for your comment. Please review the response to the commenter.</b></p>		
Consolidated Edison Co. of NY, Inc.	No	<p>Requirement R3: Following the sentence ending “in Part 1.2” add the following wording from the Measure to R3: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Requirement R4: Replace the words “an annual review” with the words “a periodic review.” Following the first sentence in R4 add: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years.</p>
Orange and Rockland Utilities, Inc.	No	<p>Requirement R3: Following the sentence ending “in Part 1.2” add the following wording from the Measure to R3: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Requirement R4: Replace the words “an annual review” with the words “a periodic review.” Following the first sentence in R4 add: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years.</p>
<p><b>Response: The SDT thanks you for your comment. Based on stakeholder comments the SDT revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively</b></p>		

Organization	Yes or No	Question 1 Comment
<p>report events to assure situational awareness to the Electric Reliability Organization. The SDT considered various time frames for the action needed and felt that a calendar year was necessary due to the FERC Directive in Order 693 and to ensure that contact information remained useful in a timely manner.</p>		
MidAmerican Energy	No	<p>See the NSRF comments. The real purpose of this requirement appears to be to assure operators are trained in the use of the procedure, process, or plan that assures proper notification. PER-005 already requires a systematic approach to training. Reporting to other affected entities is a PER-005 system operator task. Therefore this requirement already covered by PER-005 and is not required. Organizations are also required to test their response to events in accordance with CIP-008 R1.6. Therefore this requirement is covered by other standards and is not needed. Inclusion of this standard would place entities in a double or possible triple jeopardy. The SDT may need to expand M3 reporting options, by stating "... that the annual test of the communication process of 1.2 (e.g. communication via e-mail, fax, phone, ect) was conducted".</p> <p>R4 is an administrative requirement with little reliability value and should be deleted. It would likely be identified as a requirement that that should be eliminated as part of the request by FERC to identify strictly administrative requirements in FERC's recent order on FFTR.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT asks you to review the response to that commenter. The SDT disagrees with your understanding of the real purpose. Reporting of events listed in Attachment 1 is necessary for personnel beyond the operators.</b></p> <p><b>The SDT deleted Requirement R4 based on stakeholder comments and revised Requirement R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Illinois Municipal Electric Agency	No	IMEA reluctantly (in recognition of the SDT's efforts and accomplishments to date) cast a Negative vote for this project primarily based on R3 because it is



Organization	Yes or No	Question 1 Comment
		<p>attempting to fix a problem that does not exist and impacts small entity resources in particular. IMEA is not aware of seeing any information regarding a trend, or even a single occurrence for that matter, in a failure to report an event due to failure in reporting procedures. A small entity is less likely to experience a reportable event, and therefore is less likely to be able to take advantage of the provision in M3 to satisfy the annual testing through implementation of an actual event. If there is a problem that needs to be fixed, it would make much more sense to replace the language in R3 with a simple requirement for the RC, BA, IC, TSP, TOP, etc. to inform the TO, DP, LSE if there is a change in contact information for reporting an event. It is hard to believe that an RC, BA, IC, TSP, TOP, etc. is going to want to be annually handling numerous inquiries from entities regarding the accuracy of contact information. The impact of unnecessary requirements on entity resources, particularly small entities', is finally starting to get some meaningful attention at NERC and FERC. It would be a mistake to adopt another unnecessary requirement as currently specified in R3.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised Requirement R3 to help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
<p>American Transmission Company, LLC</p>	<p>No</p>	<p>ATC recommends eliminating R4 altogether. If R3, the annual test, is conducted as part of the Operating Plan, R4 is merely administrative, and does not add value to reliability.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT deleted Requirement R4 based on stakeholder comments and revised Requirement R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
<p>NextEra Energy Inc</p>	<p>No</p>	<p>NextEra Energy, Inc. (NextEra) does not agree that annual reviews and</p>

Organization	Yes or No	Question 1 Comment
		<p>annual tests should be mandated via Reliability Standards; instead, NextEra believes it is more appropriate to require that the Operating Plan be up-to-date and reviewed/tested as the Responsible Entity deems necessary. These enhancements provide for a robust Operating Plan, without arbitrary deadlines for a review and testing. It also provides Responsible Entities of different sizes and configurations the flexibility to efficiently and effectively integrate compliance with operations.</p> <p>Thus, NextEra requests that R1 be revised to read: “Each Responsible Entity shall have an up-to-date event reporting Operating Plan that is tested and reviewed as the Responsible Entity deems necessary and includes: ...”. Consistent with these changes NextEra also requests that R3 and R4 be deleted.</p>
<p><b>Response: The SDT thanks you for your comment. While the SDT recognizes the simplicity that your comment would bring, it cannot be implemented in that manner. For auditability reasons, each task must be separate and distinct in order for the performance to be assessed. Alternatively, the SDT has re-constructed three distinct requirements that can be judged and evaluated on their own with compromising the others.</b></p>		
ISO New England Inc	No	Due to the FERC mandate to assign VRFs/VSLs, we do not support using subrequirements and, instead, favor the use of bullets when the subrequirements are not standalone but rely on the partent requirement.
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the language and removed all subrequirements.</b></p>		
Exelon Corporation and its affiliates	No	It’s not clear that R3 and R4 need to be separated. Consider revising R3 to read: “Through use or testing, verify the operability of the plan on an annual basis” and dropping R4.
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		

Organization	Yes or No	Question 1 Comment
Indiana Municipal Power Agency	No	<p>IMPA does not believe that both R3 and R4 are necessary and they are redundant to a degree. Generally, when performing an annual review of a process or procedure, the call numbers for agencies or entities are verified to be up to date. Also, in R3, what does “test” mean. It could mean have different meanings to registered entities and to auditors which does not promote consistency among the industry. IMPA recommends going with an annual review of the process and having the telephone numbers verified that are in the event reporting Operating Plan. IMPA also believes that the local and federal law enforcement agencies would rather go with a verification of contact information over being besieged by "test" reports. The way R3 is written gives the appearance that the SDT did not want to overwhelm the ERO with all of the "test" reports from the registered entities (by excluding them from the test notification).</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		
ERCOT	No	<p>ERCOT has joined the IRC comments on this project and offers these additional comments. ERCOT requests that the measure be updated to say “acceptable evidence may include”. As written, the measure reads that there is only one way to comply with the requirement. The Standards should note "what" an entity is required to do and not prescribe the "how".</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the standard highlighted in your comment.</b></p>		
Brazos Electric Power Cooperative	No	<p>Please see the comments submitted by ACES Power Marketing.</p>
<p><b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b></p>		
Central Lincoln	No	<p>The new language of R3 and R4 provide nothing to clarify the word “annual.” We note that while a Compliance Application Notice was written on this,</p>

Organization	Yes or No	Question 1 Comment
		<p>Central Lincoln believes that standards should be written so they do not rely on the continually changing CANs. CAN-0010 itself implies that “annual” should be defined within the standards themselves. We suggest: R3 Each Responsible Entity shall conduct a test of the communications process in R1 Part 1.2, not including notification to the Electric Reliability Organization, at least once per calendar year with no more than 15 calendar months between tests.R4 Each Responsible Entity shall conduct a review of the event reporting Operating Plan in Requirement R1. at least at least once per calendar year with no more than 15 calendar months between reviews.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		
Kansas City Power & Light	No	<p>Requirement 3 requires a test of the communications in the operating plan. A test implies a simulation of the communications part of the operating plan by actual communications being conducted pursuant to the plan. It is not appropriate to burden agencies with testing of communications under a test environment. Recommend the drafting team consider a confirmation of the contact information with various agencies as the operations plan dictates.</p>
<p><b>Response: The SDT thanks you for your comment. SDT has made changes to the requirements highlighted in your comment.</b></p>		
Bonneville Power Administration	Yes	<p>BPA believes that the annual testing and review as described in R3 is too cumbersome and unnecessary for entities with large footprints to inundate federal and local enforcement bodies such as the FBI for “only” testing and the documenting for auditing purposes. BPA suggests that testing be performed on a bi-annual or longer basis.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment; however, the SDT has decided that the period will be shorter than your suggestion based upon comments received from all parties.</b></p>		

Organization	Yes or No	Question 1 Comment
Seattle City Light	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Utility Services	Yes	While agreeing with the change, confusion may exist with the CAN that exists for the term "Annual". Utility Services suggests that the language be changed to "Every calendar year" or something equivalent. Given everything that transpired in the discussion on the term annual, using a different phrase may be advantageous.
<b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b>		
United Illuminating Company	Yes	R3 should be clear that the annual test of the plan does not mean each communication path for each applicable event on an annual basis.
<b>Response: The SDT thanks you for your comment. Requirement R3 has been rewritten to address comments like yours and other industry members. While testing is no longer a part of the requirement, validating the contact information associated with each contact list for each applicable event type is.</b>		
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration LP agrees that it is appropriate to test reporting communications on an annual basis, primarily to validate that phone numbers, email ids, and contact information is current. We appreciate the project team's elimination of the terms "exercise" and "drill", which we believe connotes a formalized planning and assessment process. An annual review of the Operating Plan implies a confirmation that linkages to sub-processes remain intact and that new learnings are captured. We also agree that it is appropriate only to require an updated Revision Level Control chart entry as evidence of compliance - it is very likely that no updates are required after the review is complete. In our view, both of these requirements are sufficient to assure an effective assessment of all facets of

Organization	Yes or No	Question 1 Comment
		the Operating Plan. As such, we fully agree with the project team’s decision to delete the requirement to update the plan within 90 days of a change. In most cases, our internal processes will address the updates much sooner, but there is no compelling reason to include it as an enforceable requirement.
<b>Response: The SDT thanks you for your comment.</b>		
City of Austin dba Austin Energy	Yes	Austin Energy (AE) supports the requirements for (1) an annual test of the communications portion of the Operating Plan (R3) and (2) an annual review of the Operating Plan (R4); however, we offer a slight modification to the measures associated with those requirements. AE does not believe that records evidencing such test and reviews need to be time-stamped to adequately demonstrate compliance with the requirements. In each case, we recommend that the first sentence of M3 and M4 start with “Each Responsible Entity will have dated records to show that the annual ...”
<b>Response: The SDT thanks you for your comment. The SDT has removed the time-stamping provision in the standard.</b>		
Springfield Utility Board	Yes	<ul style="list-style-type: none"> <li>o SUB supports the removal of Requirement 1, Part 1.4, as well the separation of Parts 1.3 and 1.5, agreeing that they are their own separate actions.</li> <li>o The Draft 4 Version History still lists the term “Impact Event” rather than “Event”.</li> </ul>
<b>Response: The SDT thanks you for your comment. The SDT has made changes highlighted in your comment.</b>		
FirstEnergy Corp	Yes	<p>FE agrees with the revision but has the following comments and suggestions:</p> <ol style="list-style-type: none"> <li>1. We request clarity and guidance on R3 (See our comments in Question 4 for further consideration). Also, we suggest a change in the phrase “shall conduct an annual test” to “shall conduct a test each calendar year, not to exceed 15 calendar months between tests”. This wording is consistent with other</li> </ol>

Organization	Yes or No	Question 1 Comment
		<p>standards in development such as CIP Version 5.2.</p> <p>2. In R4 we suggest a change in the phrase “shall conduct an annual review” to “shall conduct a review each calendar year, not to exceed 15 calendar months between reviews”. This wording is consistent with other standards in development such as CIP Version 5.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT deleted Requirement R4 based on stakeholder comments and revised Requirement R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Independent Electricity System Operator	Yes	<p>We concur with the changes as they provide better streamlining of the four key requirements, with enhanced clarity. However, we are unclear on the intent of Requirement R3, in particular the phrase “not including notification to the Electric Reliability Organization” which begs the question on whether or not the test requires notifying all the other entities as if it were a real event. This may create confusion in ensuring compliance and during audits. Suggest the SDT to review and modify this requirement as appropriate.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the standard’s language to address this concern.</b></p>		
Public Utility District No. 1 of Snohomish County	Yes	<p>This is an excellent improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.</p>
Seattle City Light	Yes	<p>This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.</p>
MEAG Power	Yes	<p>This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.</p>
<p><b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b></p>		

Organization	Yes or No	Question 1 Comment
Tacoma Power	Yes	Tacoma Power agrees with the requirement but would suggest removing all instances the word “Operating” from the Standard. The requirements should read, “ Each Responsible Entity shall have an “Event Reporting Plan...”.The term Operating in this context is confusing as there are many other “Operating Plans” for other defined emergencies. This standard is about “Reporting” and should be confined to that.
<p><b>Response: The SDT thanks you for your comment. The SDT has chosen to include “Operating” due to the definition in the NERC Glossary. The SDT believes Operating Plan clearly defines what is needed in this standard.</b></p>		
Idaho Power Co.	Yes	But this is going to require that we create a new Operating Plan with test procedures and revision history.
<p><b>Response: The SDT thanks you for your comment. The SDT believes that an existing procedure, that meets the requirements of CIP-001-2a, may well be the starting point for the Operating Plan in this standard, or could go a long way towards achieving the requirements in this standard. The SDT revised Requirement R3 to remove test to “validate” contact information contained in the Operating Plan. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.</b></p>		
American Public Power Association	Yes	APPA appreciates the SDT making these requirements clearer as requested in our comments on the previous draft standard.
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Puget Sound Energy, Inc.	Yes	This draft is a considerable improvement on the previous draft in terms of clarity and will be much easier for Responsible Entities to implement. Puget Sound Energy appreciates the drafting team’s responsiveness to stakeholder’s concerns and the opportunity to comment on the current draft. The drafting team should revise Requirement R2 to state that the “activation” of the Operating Plan is required only when an event occurs, instead of using the term “implement”. “Implementation” could also refer



Organization	Yes or No	Question 1 Comment
		<p>to the activities such as distributing the plan to operating personnel and training operating personnel on the use of the plan. These activities are not triggered by any event and, since it is clear from the measure that this requirement is intended to apply only when there has been a reportable event, the requirement should be revised to state that as well.</p> <p>The drafting team should revise measure M2 to require reports to be “supplemented by operator logs or other reporting documentation” only “as necessary”. In many cases, the report itself and time-stamped record of transmittal will be the only documents necessary to demonstrate compliance with requirement R2. Under Requirement R3, using an actual event as sufficient for meeting the requirement for conducting an annual test would likely fall short of demonstrating compliance with the entire scope of the Operating Plan. R1.2 requires "a process for communicating EACH of the applicable events listed....". If the actual event is only one of many "applicable" events, is it sufficient to only exercise one process flow? If there is no actual event during the annual time-frame, do all the process flows then have to be exercised?</p>
<p><b>Response: The SDT thanks you for your comment. The SDT appreciates the suggestion; however, to be consistent with other reliability standards, the SDT has elected to continue to use the word “Implement.” Your suggestion could end up creating confusion and misunderstandings since the context is not used elsewhere.</b></p> <p><b>The SDT has revised the language the requirements and measures as a result of your and other commenter’s remarks.</b></p>		
FMPP		See FMPP's comments
<p><b>Response: The SDT thanks you for your comment. Please review the response to the FMPP comments.</b></p>		

Organization	Yes or No	Question 1 Comment
Luminant	Yes	
BC Hydro	Yes	
Imperial Irrigation District (IID)	Yes	
LG&E and KU Services	Yes	
PPL Corporation NERC Registered Affiliates	Yes	
Avista	Yes	
PNGC Comment Group	Yes	
Colorado Springs Utilities	Yes	
Arizona Public Service Company	Yes	
Georgia System Operations Corporation	Yes	
Texas Reliability Entity	Yes	
Dynergy Inc.	Yes	
Clark Public Utilities	Yes	
Pepco Holdings Inc	Yes	
Farmington Electric Utility System	Yes	

Organization	Yes or No	Question 1 Comment
Public Service Enterprise Group	Yes	
PPL Electric Utilities	Yes	
Cowlitz County PUD	Yes	
Edison Mission Marketing & Trading, Inc.	Yes	
Ameren	Yes	
We Energies	Yes	
GTC	Yes	
MISO	Yes	
Oncor Electric Delivery	Yes	
Los Angeles Department of Water and Power	Yes	
Deseret Power	Yes	

2. The SDT made clarifying revisions to Attachment 1 based on stakeholder feedback. Do you agree with these revisions? If not, please explain in the comment area below.

**Summary Consideration:**

The SDT reviewed, discussed and updated Attachment 1 based on comments received for commenters, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Under the Event Column, the SDT starts to classify each type of an event by assigning an “Event” title. The DSR SDT then updated the “Entity with Reporting Responsibilities” column to simply state which entity has the responsibility to report if they experience an event. The last column, “Threshold for Reporting” is a bright line that, if reached, the entity needs to report that they experienced the applicable event per Requirement 1.

Organization	Yes or No	Question 2 Comment
Northeast Power Coordinating Council	No	<p>Regarding Attachment 1, language identical to event descriptions in the NERC Event Analysis Process and FERC OE-417 should be used. Creating a third set of event descriptions is not helpful to system operators. Recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>The following pertains to Attachment 1: Replace the Attachment 1 “NOTE” with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to</p>

Organization	Yes or No	Question 2 Comment
		<p>the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required.</p> <p><b>The SDT thanks you with your comment. First, the SDT believes that you intended the comment to address the “Note” on Attachment 2, not Attachment 1. The SDT does not believe that a hardcopy report is necessary if the organization has made voice contact.</b></p> <p>The proposed “events” are subjective and will lead to confusion and questions as to what has to be reported.</p> <p><b>The SDT disagrees and has established “events” to be reported based on bright line criteria. The events are consistent with previous versions of the CIP-001 and EOP-004 standards, as well as incidences being reporting to the DOE and EAP.</b></p> <p>Event: A reportable Cyber Security Incident. All reportable Cyber Security Incidents may not require “One Hour Reporting.” A “one-size fits all” approach may not be appropriate for the reporting of all Cyber Security Incidents. The NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document provides time-frames for Cyber Security Incident Reporting. For example, a Cyber Security Compromise is recommended to be reported within one hour of detection, however, Information Theft or Loss is recommended to be reported within 48 hours. Recommend listing the Event as “A confirmed reportable Cyber Security Incident. The existing NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document uses reporting time-frames based on “detection” and “discovery.” Recommend using the word confirmed because of the investigation time that may be required from the point of initial “detection” or “discovery” to the point of confirmation, when the compliance “time-clock” would start for the reporting requirement in EOP-004-2.</p> <p><b>The SDT is revising the standard to not contain reporting for Cyber Security incidents. Under the revisions, CIP-008-3 and successive versions will retain the</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>reporting requirements.</b></p> <p>Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read: Results from actual or suspected intentional human action, excluding unintentional human errors.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” now states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p>Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore</p>

Organization	Yes or No	Question 2 Comment
		<p>unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whomever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Event: BES Emergency requiring public appeal for load reduction. Replace wording in the Event column with language from #8 on the OE-417 Reporting Form to eliminate reporting confusion. Following this sentence add, “This shall exclude other public</p>

Organization	Yes or No	Question 2 Comment
		<p>appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.”</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is required to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>Event: Complete or partial loss of monitoring capability Event wording: Delete the words “or partial” to conform the wording to the NERC Event Analysis Process.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to “Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p> <p>Event: Transmission Loss Revise to BES Transmission Loss</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b>  <b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>Event: Generation Loss Revise to BES Generation Loss</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT</b></p>



Organization	Yes or No	Question 2 Comment
		<p>removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:  “Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection  OR  <math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”  The SDT believes that if an entity reaches this threshold, it needs to be reported and most likely this will be BES connected generation assets.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
DECo	No	<p>On pg 17 in the Rationale Box for EOP-004 Attachment 1: The set of terms is specific then includes the word ETC. Then further lists areas to exclude. Then on Pg 23 of document it includes train derailment near a transmission right of way and forced entry attempt into a substation facility as reportable. These conflict. Also see conflict when in pg 21 states the DOE OE417 would be excepted in lieu of the NERC form, but on the last pg it states the DOE OE417 should be attached to the NERC report indicating the NERC report is still required.</p>
<p><b>Response: The SDT thanks you for your comment. While the SDT would like to point out the “etc.” is the last word in the definition of Facility; the SDT has removed footnote 1 and the forced intrusion statement has been removed. The SDT has updated to remove the conflict of “attached to the NERC report...” The SDT agrees with your comments and have revised the standard to address these discrepancies.</b></p>		
Duke Energy	No	<p>(1)We disagree with reporting CIP-008 incidents under this standard. We agree with the one-hour notification timeframe, but believe it should be in CIP-008 to avoid double jeopardy.   <b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one-hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b>   (2)Damage or destruction of a Facility - Need clarity on how a vertically integrated</p>

Organization	Yes or No	Question 2 Comment
		<p>entity must report. For example a GOP probably won't know if an IROL will be affected. Also, there shouldn't be multiple reports from different functional entities for the same event. Suggest splitting this table so that GO, GOP, DP only reports "Results from actual or suspected intentional human action".</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of its Facility that results from actual or suspected intentional human action.</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the Facility was 'damaged or destroyed' intentionally by a human."</b></p> <p><b>This event was written to cover the increase of "Entity with Reporting Responsibility," and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being "suspected intentional human action." This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>(3)Generation Loss - Need more clarity on the threshold for reporting. For example if</p>

Organization	Yes or No	Question 2 Comment
		<p>we lose one 1000 MW generator at 6:00 am and another 1000 MW generator at 4:00 pm, is that a reportable event?</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b>≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Luminant	No	<p>Luminant appreciates the work of the SDT to modify Attachment 1 to address the concerns of the stakeholders. However, we are concerned that the threshold for reporting a Generation Loss in the ERCOT interconnection established by this revision is set at 1,000MW, which is not consistent with the level of single generation contingency used in ERCOT planning and operating studies. That level of contingency is currently set at the size of the largest generating unit in ERCOT, which is 1,375MW. For this reason, Luminant believes that the minimum threshold for reporting of a disturbance should be &gt; 1,375MW for the ERCOT Interconnection.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b>≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p><b>The SDT discussed this issue and believes that ERCOT could change contingency level in the future, and this event is also applicable to the Quebec Interconnection.</b></p>		

Organization	Yes or No	Question 2 Comment
BC Hydro	No	BC Hydro supports the revisions to EOP-004 and would vote Affirmative with the following change. Attachment 1 has a One Hour Reporting requirement. BC Hydro proposes a One Hour Notification with the Report submitted within a specified timeframe afterward.
<p><b>Response: The SDT thanks you for your comment. The SDT has removed all incidences involving one-hour reporting threshold; therefore, the SDT does not see the need to make this change.</b></p>		
Bonneville Power Administration	No	<p>BPA believes that clarifying language should be added to transmission loss event. (Page 19) [a report should not be required if the number of elements is forced because of pre-designed or planned configuration. System studies have to take such a configuration into account possible wording could be. Unintentional loss of three or more Transmission Facilities (excluding successful automatic reclosing or planned operating configuration)]</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>In addition, under the “Event” of Complete or partial loss of monitoring capability, BPA believes that “partial loss” is not sufficiently specific for BPA to write compliance operating procedures and suggest defining partial loss or removing it from the standard. Should the drafting team add clarifying language to remove “or partial loss” and address BPA’s concerns on over emphasis on software tool to the operation of the system. BPA would change its negative position to affirmative.</p> <p><b>The SDT has revised the language on this point in Attachment 1.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		

Organization	Yes or No	Question 2 Comment
SPP Standards Review Group	No	<p>To obtain an understanding of the drivers behind the events in Attachment 1, we would like to see where these events come from. If the events are required in standards, refer to them. If they are in the existing event reporting list, indicate so. If they are coming from the EAP, let us know. We have a concern that, as it currently exists, Attachment 1 can increase our reporting requirements considerably.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Reportable events should be similar, but not identical to the events reported to DOE or EAP.</b></p> <p>We also have concerns about what appears to be a lack of coordination between EAP reporting requirements and those contained in Attachment 1. For example, the EAP reporting requirement is for the complete loss of monitoring capability whereas Attachment 1 adds the requirement for reporting a partial loss of monitoring capability. It appears that some of the EAP reporting requirements are contained in Attachment 1. We have concerns that this is beyond the scope of the SAR and should not be incorporated in this standard.</p> <p><b>The SDT has revised the language on this point in Attachment 1. It should be noted that the EAP can use reports submitted under EOP-004-2 as the initial notification of an event that could be further addressed in the EAP.</b></p> <p>We have concern with several of the specific event descriptions as contained in Attachment 1:</p> <p>Damage or destruction of a Facility - We are comfortable with the proposed definition of Adverse Reliability Impact but have concerns with the existing definition of ARI.</p> <p>Any physical threat that could impact the operability of a Facility<sup>1</sup> - We take exception to this event in that it goes beyond what is currently required in EOP-004-1, including DOE reporting requirements, and the EAP reporting requirements. We do not understand the need for this event type and object to the potential for excessive</p>

Organization	Yes or No	Question 2 Comment
		<p>reporting required by such an event type. Additionally, we are concerned about the potential for multiple reporting of a single event. This same concern applies to several other events including Damage or destruction of a Facility, Loss of firm load for 15 minutes, System separation, etc. When multiple entities are listed as the Entity with Reporting Responsibility, Attachment 1 appears to require each entity in the hierarchy to submit a report. There should only be one report and it should be filed by the entity owning the event. The SDT addressed this issue in its last posting but the issue still remains and should be reviewed again.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>depth and breathe of system conditions based on the given event.</b></p> <p>BES Emergency resulting in automatic firm load shedding - For some reason, not stipulated in the Consideration of Comments, the action word in the Entity with Reporting Responsibility was changed from 'experiences' to 'implements'. We recommend changing it back to 'experiences'. Automatic load shedding is not implemented. It does not require human intervention. It's automatic. Voltage deviation on a Facility - Similar to the comment on automatic load shedding above, the action word was changed from 'experiences' to 'observes'. We again recommend that it be changed back to 'experiences'. Using observes obligates a TOP, who is able to see a portion of a neighboring TOP's area, to submit a report if that TOP observed a voltage deviation in the neighboring TOP's area. The only reporting entity in this event should be the TOP within whose area the voltage deviation occurred.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Automatic firm load shedding ≥ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)."</b></p> <p><b>This language clearly states that an entity reports if the threshold is reached.</b></p> <p>Complete or partial loss of monitoring capability - Clarification on partial loss of monitoring capability and inoperable are needed. Also, the way the Threshold is written, it implies that a State Estimator and Contingency Analysis are required. To tone this down, insert the qualifier 'such as' in front of State Estimator.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to "Complete loss of monitoring capabilities" for a RC, BA, or TOP when there is a complete loss of monitoring</b></p>

Organization	Yes or No	Question 2 Comment
		<p>capabilities for 30 continuous minutes where their State Estimator or Contingency Analysis is inoperable. This will only apply to an RC, BA, or TOP who have this capability to start with.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>The bullet on “any physical threat” is un-measurable. What constitutes a “threat”? FMPA likes the language used in the comment form discussing this item concerning the judgment of the Responsible Entity, but, the way it is worded in Attachment 1 will mean the judgment of the Compliance Enforcement Authority, not the Responsible Entity. Presumably, the Responsible Entity will need to develop methods to identify physical threats in accordance with R1; hence, FMPA suggests rewording to: “Any physical threat recognized by the Responsible Entity through processes established in R1 bullet 1.1”. We understand this introduces circular logic, but, it also introduces the “judgment of the Responsible Entity” into the bullet.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b>  <b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or</b></p>



Organization	Yes or No	Question 2 Comment
		<p>activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event, unless it degrades the normal operation of a Facility.</p> <p>On the row of the table on voltage deviation, replace the word “observes” with “experiences”. It is possible for one TOP to “observe” a voltage deviation on another TOP’s system. It should be the responsibility of the TOP experiencing the voltage deviation on its system to report, not the one who “observes”. On the row on islanding, it does not make sense to report islanding for a system with load less than the loss of load metrics and we suggest using the same 300 MW threshold for a reporting threshold. On the row on generation loss, some clarification on what type of generation loss (especially in the time domain) would help it be more measurable, e.g., concurrent forced outages. On the row on transmission loss, the same clarity is important, e.g., three or more concurrent forced outages.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Automatic firm load shedding ≥ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS).”</b></p> <p><b>This language clearly states that an entity reports if the threshold is reached.</b></p> <p>On the row on loss of monitoring, while FMPA likes the threshold for “partial loss of monitoring capability” for those systems that have State Estimators, small BAs and TOPs will not need or have State Estimators and the reporting threshold becomes ambiguous. We suggest adding something like loss of monitoring for 25% of monitored points for those BAs and TOPs that do not have State Estimators.</p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to “Complete loss of monitoring capabilities” for a RC, BA, or TOP when there is a complete loss of monitoring capabilities for 30 continuous minutes where their State Estimator or Contingency Analysis is inoperable. This will only apply to an RC, BA, or TOP who have this capability to start with.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>LG&amp;E and KU Services</p>	<p>No</p>	<p>The SDT should consider more clearly defining the Threshold for Reporting for the Event: “Any physical threat that could impact the operability of a Facility” to only address those events that have an Adverse Reliability Impact. Some proposed language might be: “Threat to a Facility excluding weather related threats that could result in an Adverse Reliability Impact.” For those events specifically defined in the ERO Events Analysis Process, the SDT should consider revising the language to be more consistent with the language included in the ERO Events Analysis Process. Here is some recommended language:</p> <ol style="list-style-type: none"> <li>1. EVENT: Transmission loss THRESHOLD FOR REPORTING: “Unintentional loss, contrary to design, of three or more BES Transmission Facilities (excluding successful automatic reclosing) caused by a common disturbance.</li> </ol> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b>  <b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <ol style="list-style-type: none"> <li>2. EVENT: “Complete or partial loss of monitoring capability” - could be revised to read “Complete loss of SCADA control or monitoring functionality” THRESHOLD FOR REPORTING: “Affecting a BES control center for 30 continuous minutes such that analysis tools (e.g. State Estimator, Contingency Analysis) are rendered inoperable”.</li> </ol> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments</b></p>

Organization	Yes or No	Question 2 Comment
		<p>received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:  <b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
MRO NSRF	No	<p>R1.2 states: A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies. This implies not only does NERC need to be notified within the specified time period but that: “other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.” are also required to be notified within in the time periods specified. We suggest a forth column be added to the table to clearly identify who must be notified within the specified time period or that R1.2 be revised to clearly state that only NERC must be notified to comply with the standard. With the use of “i.e.” the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that “e.g.” should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity.</p> <p><b>The SDT has made the required change concerning replacing “i.e.” with “e.g.”</b></p> <p>Also with regards to Attachment 1, the following comments are provided:</p> <ol style="list-style-type: none"> <li>1. Instead of referring to CIP-008 (in the 1 hour reporting section), quote the words from CIP-008, this will require coordination of future revisions but will assure clarity in reporting requirements.</li> </ol> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>have remanded the one-hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>2. Under “Damage or destruction of a Facility” a. The wording “affects an IROL (per FAC-014),” is too vague. Many facilities could affect an IROL, not as many if lost would cause an IROL. b. Adverse Reliability Impact is defined as: “The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection.” There are an infinite number of routine events that result in the loss of generation plants due to inadvertent actions that somehow also damaged equipment. Any maintenance activity that damaged a piece of equipment that causes a unit to trip or results in a unit being taken off line in a controlled manner would now be reportable. This seems to be an excessive reporting requirement. Recommend that Adverse Reliability Impact be deleted and be replaced with actual EEA 2 or EEA 3 level events. c. The phrase “Results from actual or suspected intentional human action.” This line item used the term “suspected” which relates to “sabotage”. Recommend the following: Results from actual or malicious human action intended to damage the BES.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any</b></p>

Organization	Yes or No	Question 2 Comment
		<p>abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>3. “Any physical threat that could impact the operability of a Facility1”The example provided by the drafting team of a train derailment exemplifies why this requirement should be deleted. A train derailment of a load of banana’s more than likely would not threaten a nearby BES Facility. However a train carrying propane that derails carrying propane could even if it were 10 miles away. Whose calculation will be used to determine if an event could have impacted the asset? As worded there is too much ambiguity left to the auditor. We suggest the drafting team clarify by saying “Any event that requires the a BES site be evacuated for safety reasons”</p> <p>Furthermore if weather events are excluded, we are hard pressed to understand why this information is important enough to report to NERC. So barring an explanation of the purpose of this requirement, including why weather events would be excluded, we suggest the requirement be deleted. Please note that if you align this with “Physical attack” with #1 of the OE-417. This clearly states what the SDT is looking for.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:</p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>4. The phrase “or partial loss of monitoring capability” is too vague. Further definitions of “inoperable” are required to assure consistent application of this requirement. Recommend that “Complete loss of SCADA affecting a BES control center for 30 continuous minutes such that analysis tools of State Estimator and/or Contingency Analysis are rendered inoperable. Or, Complete loss of the ability to perform a State Estimator or Contingency Analysis function, the threshold of 30 mins is too short. A 60 min threshold will align with EOP-008-1, R1.8. Since this is the time to implement the contingency back up control center plan.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p> <p>5. Event: Voltage deviation on a Facility. ATC believes that the term “observes” for Entity with Reporting Responsibility be changed back to “experiences” as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. Also, for Threshold for Reporting, ATC believes the language should be expanded to - plus or minus 10% “of target voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>6. Event: Transmission loss. ATC recommends that Threshold for Reporting be changed to read “Unintentional loss of four, or more Transmission Facilities, excluding successful automatic reclosing, within 30 seconds of the first loss experienced and for 30 continuous minutes. Technical justification or Discussion for this recommended change: In the instance of a transformer-line-transformer, scenario commonly found close-in to Generating stations, consisting of 3 defined “facilities”, 1 lightning strike can cause automatic unintentional loss by design. Increase the number of facilities to 4. In a normal shoulder season day, an entity may experience the unintentional loss of a 138kv line from storm activity, at point A in the morning, a loss of a 115kv line from a different storm 300 miles from point A in the afternoon, and a loss of 161kv line in the evening 500 miles from point A due to a</p>

Organization	Yes or No	Question 2 Comment
		<p>failed component, if it is an entity of significant size. Propose some type of time constraint. Add time constraint as proposed, 30 seconds, other than automatic reclosing. In the event of dense lightning occurrence, the loss of multiple transmission facilities may occur over several minutes to several hours with no significant detrimental effect to the BES, as load will most certainly be affected (lost due to breaker activity on the much more exposed Distribution system) as well. Any additional loss after 30 seconds must take into account supplemental devices with intentional relay time delays, such as shunt capacitors, reactors, or load tap changers on transformers activating as designed, arresting system decay. In addition, Generator response after this time has significant impact. Please clarify or completely delete why this is included within this version when no basis has been give and it is not contained within the current enforceable version.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>7. Modify the threshold of “BES emergency requiring a public appeal...” to include, “Public appear for a load reduction event resulting for a RC or BA implementing its emergency operators plans documented in EOP-001.” The reason is that normal public appeals for conservation should be clearly excluded.</p> <p><b>The SDT disagrees since it is clearly stated that a report is required for “Public appeal for load reduction event.” The SDT has not discussed a reporting mechanism for “conservation.”</b></p> <p>8. Add a time threshold to complete loss of off-site power to a nuclear plant. Nuclear plants are to have backup diesel generation that last for a minimum amount of time. A threshold recognizing this 4 hour or longer window needs to be added</p>



Organization	Yes or No	Question 2 Comment
		<p>such as complete loss of off-site power to a nuclear plant for more than 4 hours.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.” As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</b></p> <p>9. Delete “Transmission loss”. The loss of a specific number of elements has no direct bearing on the risk of a system cascade. Faults and storms can easily result in “unintentional” the loss of multiple elements. This is a flawed concept and needs to be deleted</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p>
<b>Response: The SDT thanks you for your comment.</b>		
PPL Corporation NERC Registered Affiliates	No	<p>1.) PPL Generation thanks the SDT for the changes made in this latest proposal. We feel our previous comments were addressed. PPL Generation offers the following additional comments. Regarding the event ‘Transmission Loss’: For your consideration, please consider adding a footnote to the event ‘Transmission Loss’ such that weather events do not need to be reported. Also please consider including operation contrary to design in the language and not just in the example. E.g. consistent with the NERC Event Analysis table, the threshold would be, ‘Unintentional loss, contrary to design, of three or more</p>

Organization	Yes or No	Question 2 Comment
		<p>BES Transmission Facilities.’</p> <p>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</p> <p>The SDT has taken your comment into consideration and this threshold for reporting now states:  “Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).” The SDT has removed all footnotes within Attachment 1.</p> <p>2.) PPL Generation proposes the following changes in Attachment 1 to the first entry in the “Threshold for Reporting” column to make it clear that independent GO/GOPs are required to act only within their sphere of operation and based on the information that is available to the GO/GOPs: Damage or destruction of a Facility that: Affects an IROL (per FAC-014, not applicable to GOs and GOPs) OR Results in the need for actions to avoid an Adverse Reliability Impact (not applicable to GOs and GOPs) OR Results from actual or suspected intentional human action (applicable to all).</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any</p>

Organization	Yes or No	Question 2 Comment
		<p>abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within</p>

Organization	Yes or No	Question 2 Comment
		<p><b>their Operating Plan.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>ISO/RTO Standards Review Committee</p>	<p>No</p>	<p>The SRC response to this question does not indicate support of the proposed requirement. Please see the latter part of the SRC’s response to Question 4 below for an SRC proposed alternative approach:</p>
<p><b>Response: The SDT thanks you for your comment. Please review response to Question 4 comment.</b></p>		
<p>ACES Power Marketing Standards Collaborators</p>	<p>No</p>	<p>The drafting team made a number of positive changes to Attachment 1. However, there are a few changes that have introduced new issues and there are a number of existing issues that have yet to be fully addressed. One of the existing issues is that the reporting requirements will result in duplicate reporting. Considering that one of the stated purposes is to eliminate redundancy, we do not see how the scope of the SAR can be considered to be met until all duplicate reporting is eliminated.</p> <p><b>The SDT acknowledges that reporting of the same event will come from multiple parties. However, as the industry has learned from recent events, NERC needs to have perspectives from a variety of entities instead of just one party’s viewpoint. Reliability can be improved from learning how the differing parties see or experience the event. Sometimes, the differing perspectives have provided valuable insight on the true nature of the event. Therefore, the SDT believes that having multiple reports will aid reliability as we can learn from everyone’s experiences.</b></p>

Organization	Yes or No	Question 2 Comment
		<p>More specifics on our concerns are provided in the following discussion.</p> <p>(1) In the “Damage or destruction of a Facility” event, the statement “Affects an IROL (per FAC-014)” in the “Threshold for Reporting” is ambiguous. What does it mean? If the loss of a Facility will have a 1 MW flow change on the Facilities to which the IROL applies, is this considered to have affected the IROL? We suggest a more direct statement that damage or destruction occurred on a Facility to which the IROL applies or to one of the Facilities that comprise an IROL contingency as identified in FAC-014-2 R5.1.3. Otherwise, there will continue to be ambiguity over what constitutes “affects”.</p> <p>(2) In the “Damage or destruction of a Facility” event, the threshold regarding “intentional human action” is ambiguous and suffers from the same difficulties as defining sabotage. What constitutes intentional? How do we know something was intentional without a law enforcement investigation? This is the same issue that prevented the drafting team from defining sabotage.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to</b></p>

Organization	Yes or No	Question 2 Comment
		<p>prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within</p>

Organization	Yes or No	Question 2 Comment
		<p><b>their Operating Plan.</b></p> <p>(3) In the “Damage or destruction of a Facility” and “Any physical threat that could impact the operability of a Facility” events, Distribution Provider should be removed. Per the Function Model, the Distribution Provider does not have any Facilities (line, generator, shunt compensator, transformer). The only Distribution Provider equipment that even resembles a Facility would be capacitors (i.e. shunt compensator) but they do not qualify because they are not Bulk Electric System Elements.</p> <p><b>The SDT agrees that if a DP does not own or operate a Facility then this event would not be applicable to them. However, if a DP does experience an event such as those listed, then it is a reportable incident under this standard.</b></p> <p>(4) The “Any physical threat that could impact the operability of a Facility” event requires duplicate reporting. For example, if a large generating plant experiences such a threat, who should report the event? What if loss of the plant could cause capacity and energy shortages as well as transmission limits? The end result is that the RC, BA, TOP, GO and GOP could all end up submitting a report for the same event. For a given operating area, only one report should be required from one registered entity for each event.</p> <p><b>The SDT acknowledges that multiple reports could result from an event. If an entity experiences an applicable event type, then they required to report it. As previously stated, the industry can benefit from having such differing perspectives when events occur.</b></p> <p>(5) The “Any physical threat that could impact the operability of a Facility” event should not apply to a single Facility but rather multiple Facilities which if lost would impact BES reliability. As written now, a train derailment near a single 138 kV transmission line or small generator with minimal reliability impact would require reporting.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>(6) The “BES Emergency resulting in automatic firm load shedding” should not apply to the DP. In the existing EOP-004 standard, Distribution Provider is not included and the load shed information still gets reported.</p> <p>The SDT believes that the DP should be required to report “automatic firm load shedding...” to the ERO (and whoever else the entity wishes to inform per Requirement R1).</p> <p>(7) The “Voltage deviation on a Facility” event needs to be clarified that the TOP only reports voltage deviations in its Transmission Operator Area. Because TOPs may view</p>



Organization	Yes or No	Question 2 Comment
		<p>into other Transmission Operator Areas, it could technically be required to report another TOP's voltage deviation because one of its System Operators observed the neighboring TOP's voltage deviation.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Observed voltage deviation of <math>\pm</math> 10% of nominal voltage sustained for <math>\geq</math> 15 continuous minutes."</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(8) For the "Loss of firm load greater than 15 minutes" event, the potential for duplicate reporting needs to be eliminated. Every time a DP experiences this event, the DP, TOP and BA all appear to be required to report since the DP is within both the Balancing Authority Area and Transmission Operator Area. Only one report is necessary and should be sent. Given that the existing EOP-004 standard does not include the DP, we suggest eliminating the DP to eliminate one level of duplicate reporting.</p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(9) For the "System separation (islanding)" event, please remove DP. As long as any island remains viable, the Distribution Provider will not even be aware that an island occurred. It is not responsible for monitoring frequency or having a wide area view.</p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified.</p> <p><b>This event is now only applicable to RC, BA, and TOP.</b></p> <p>(10) For the “System separation (islanding)” event, please remove BA. Because islanding and system separation, involve Transmission Facilities automatically being removed from service, this is largely a Transmission Operator issue. This position is further supported by the approval of system restoration standard (EOP-005-2) that gives the responsibility to restore the system to the TOP. (11) For the “System separation (islanding)” event, please eliminate duplicate reporting by clarifying that the RC should submit the report when more than one TOP is involved. If only one TOP is involved, then the single TOP can submit the report or the RC could agree to do it on their behalf. Only one report is necessary.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified.</b></p> <p><b>This event is now only applicable to RC, BA, and TOP. The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(12) For the “Generation loss” event, duplicate reporting should be eliminated. It is not necessary for both the BA and GOP to submit two separate reports with nearly identical information. Only one entity should be responsible for reporting.</p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(13) For the “Complete loss of off-site power to a nuclear generating plant”, the</p>

Organization	Yes or No	Question 2 Comment
		<p>associated GO or GOP should be required to report rather than the TO or TOP. Maintaining power to cooling systems is ultimately the responsibility of the nuclear plant operator. At the very least, TO should be removed because it is not an operating entity and loss of off-site power is an operational issue. If the TOP remains in the reporting responsibility, it should be clarified that it is only a TOP with an agreement pursuant to NUC-001. All of this is further complicated because NUC-001 was written for a non-specific transmission entity because there was no one functional entity from which the nuclear plant operator gets it off-site power.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.” As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</b></p> <p>(14) For the “Complete or partial loss of monitoring capability”, partial loss needs to be further clarified. Is loss of a single RTU a partial loss of monitoring capability? For a large RC is loss of ICCP to a single small TOP, considered a partial loss? We suggest as long as the entity has the ability to monitor their system through other means that the event should not be reported. For the loss of a single RTU, if the entity has a solving state estimator that provides estimates for the area impacted, the partial threshold loss would not be considered. If the entity has another entity (i.e. perhaps the RC is still receiving data for its TOP area, the RC can monitor for the TOP) that can monitor their system as a backup, the partial loss has not been met.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30</b></p>

Organization	Yes or No	Question 2 Comment
		<p>continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>Southern Company Services</p>	<p>No</p>	<p>It appears that the SDT has incorporated the reporting requirements for CIP-008 “reportable Cyber Security Incidents”; however, the “recognition” requirements remain in CIP-008 Reliability Standard. Southern understands the desire to consolidate reporting requirements into a single standard, but it would be clearer for Cyber Security Incidents if both the recognition and reporting requirements were in one reliability standard and not spread across multiple standards.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>As it relates to the event type “Loss of Firm Load for &gt; 15 minutes”, Southern suggests that the SDT clarify if weather related loss of firm load is excluded from the reporting requirement.</p> <p><b>The SDT believes that it is important to report this event based on the threshold regardless of the cause. This will give the ERO (and whoever else the entity wishes to inform per Requirement R1) a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>As it relates to the event type “Loss of all voice communication capability”, Southern suggest that the SDT clarify if this means both primary and backup voice communication systems or just primary voice communication systems.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</b></p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:  <b>“Complete loss of voice communications capabilities affecting a BES control center for 30 continuous minutes or more.”</b> The SDT intends “complete” to mean all capabilities, including back up capabilities.</p> <p>Referring to “CIP-008-3 or its successor” in Requirement R1.1 is problematic. This arrangement results in a variable requirement for EOP-004-2 R1. The requirements in a particular version of a standard should be fixed and not variable. If exceptions to applicable events change, a revision should be made to EOP-004 to reflect the modified requirement.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Hydro One	No	<p>In the Attachment 1, language identical to event descriptions in the NERC Event Analysis Process and FERC OE-417 should be used. Creating a third set of event descriptions is not helpful to system operators. Recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>The proposed “events” are subjective and will lead to confusion and questions as to what has to be reported. - Event: A reportable Cyber Security Incident. All reportable Cyber Security Incidents may not require “One Hour Reporting.” A “one-size fits all” approach may not be appropriate for the reporting of all Cyber Security</p>

Organization	Yes or No	Question 2 Comment
		<p>Incidents. The NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document provides time-frames for Cyber Security Incident Reporting. For example, a Cyber Security Compromise is recommended to be reported within one hour of detection, however, Information Theft or Loss is recommended to be reported within 48 hours. Recommend listing the Event as “A confirmed reportable Cyber Security Incident. The existing NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document uses reporting time-frames based on “detection” and “discovery.” Recommend using the word confirmed because of the investigation time that may be required from the point of initial “detection” or “discovery” to the point of confirmation, when the compliance “time-clock” would start for the reporting requirement in EOP-004-2.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement. Note that the existing NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document is a “guideline” to assist entities. It should not be confused with a mandatory and enforceable Reliability Standard.</b></p> <p>- Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read: “Results from actual or suspected intentional human action, excluding unintentional human errors”.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” not states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any</b></p>

Organization	Yes or No	Question 2 Comment
		<p>abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>- Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p>

Organization	Yes or No	Question 2 Comment
		<p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>- Event: BES Emergency requiring public appeal for load reduction. Replace wording in the Event column with language from #8 on the OE-417 Reporting Form to eliminate reporting confusion. Following this sentence add, “This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.”</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is require to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>- Event: Complete or partial loss of monitoring capability Event wording: Delete the words “or partial” to conform the wording to the NERC Event Analysis Process.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:</b>  <b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>



Organization	Yes or No	Question 2 Comment
		<p>Event: Transmission Loss Revise to BES Transmission Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:  “Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</p> <p>Event: Generation Loss Revise to BES Generation Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:  “Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection  OR  ≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”  The SDT believes that if an entity reaches this threshold, it needs to be reported.</p>
<b>Response: The SDT thanks you for your comment.</b>		
CenterPoint Energy	No	CenterPoint Energy appreciates the revisions made to Attachment 1 based on stakeholder feedback; however, the Company continues to have concerns regarding certain events and thresholds for reporting and offers the following recommendations. (1) CenterPoint Energy recommends the deletion of "per Requirement R1" in the “Note” under Attachment 1 as it contains a circular reference back to R1 which includes timeframes.

Organization	Yes or No	Question 2 Comment
		<p>The SDT has updated Requirement R1 due to industry comments to read:  <b>“R1. Each Responsible Entity shall have an event reporting Operating Plan that includes communication protocol(s) for applicable events listed in, and within the time frames specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations based on the event type (e.g. the Regional Entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, governmental or provincial agencies).”</b></p> <p>(2) CenterPoint Energy maintains that a required 1 hour threshold for reporting of any event is unreasonable. CenterPoint Energy is confident that given dire circumstances Responsible Entities will act quickly on responding to and communication of any impending threat to the reliability of the Bulk Electric System.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>(3) For the event of “Damage or destruction of a Facility”, CenterPoint Energy is concerned that the use of the term “suspected” is too broad and proposes that the SDT delete "suspected" and add "that causes an Adverse Reliability Impact..." to the threshold for reporting regarding human action.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility</p>

Organization	Yes or No	Question 2 Comment
		<p><b>was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>(4) CenterPoint Energy believes that the event, “Any physical threat that could impact the operability of a Facility” is too broad and should be deleted. Alternatively, CenterPoint Energy recommends that the SDT delete “could” or change the event description to “A physical incident that causes an Adverse Reliability Impact”. Additionally, in footnote 1, the example of a train derailment uses the phrase “could have damaged”. CenterPoint Energy is concerned that as beauty is the eye of the beholder, this phrase is open to interpretation and therefore recommends that the phrase, “causes an Adverse Reliability Impact” be incorporated into the description.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event and footnote 1. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>(5) The Company proposes that the threshold for reporting the event, “BES Emergency requiring manual firm load shedding” is too low. It appears the SDT was attempting to align this threshold with the DOE reporting requirement. However, as the SDT stated above, there are several valid reasons why this should not be done; therefore, CenterPoint Energy recommends the threshold be revised to “Manual firm load shedding â%¥ 300 MW”.</p> <p><b>The SDT disagrees as this is currently enforceable within EOP-004-1.</b></p> <p>(6) CenterPoint Energy also recommends a similar revision to the threshold for reporting associated with the “BES Emergency resulting in automatic firm load shedding” event. (“Firm load shedding â%¥ 300 MW (via automatic under voltage or under frequency load shedding schemes, or SPS/RAS”)</p> <p><b>The SDT disagrees as we have aligned this with “manual firm load shedding.” As written a report will be required for load shedding of 100MW for automatic or manual actions.</b></p> <p>(7) CenterPoint Energy is uncertain of the event, “Loss of firm load for â%¥ 15 minutes” and its fit with BES Emergency requiring manual firm load shedding or BES Emergency resulting in automatic firm load shedding. The Company believes that this event is already covered with manual firm load shedding and automatic firm load shedding and should therefore be deleted.</p> <p><b>The SDT disagrees, as “Loss of firm load” is due to an action other than loss of load due to “automatic” or “manual” actions by the BA, TOP, or DP. The intent is to capture that load was loss by some other action. Note that this is a currently enforceable item within EOP-004-1.</b></p>

Organization	Yes or No	Question 2 Comment
		<p>(8) For the event of “System separation (islanding)”, CenterPoint Energy believes that 100 MW is inconsequential and proposes 300 MW instead.</p> <p><b>The SDT disagrees, as this has been vetted through the industry with very little negative feedback.</b></p> <p>(9) For “Generation loss”, CenterPoint Energy suggests that the SDT add "only if multiple units" to the criteria of “1,000 MW for entities in the ERCOT or Quebec Interconnection”.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b><math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p>(10) Finally, CenterPoint Energy recommends that the SDT delete the term “partial” under the “Entity with Reporting Responsibility” for “Complete or partial loss of monitoring capability”. The Company proposes revising the event description to "Loss of monitoring capability for &gt; 30 minutes that causes system analysis tools to be inoperable”.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or</b></p>

Organization	Yes or No	Question 2 Comment
		TOP who have this capability to start with.
<b>Response: The SDT thanks you for your comment.</b>		
Arkansas Electric Cooperative Corporation	No	AECC supports the comments submitted by ACES Power Marketing.
<b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b>		
MWDSC	No	See comment for question 1
<b>Response: The SDT thanks you for your comment. Please review the response to Question 1.</b>		
Georgia System Operations Corporation	No	See comments under no. 4 below.
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Texas Reliability Entity	No	<p>(1) In the Events Table, consider whether the item for “Voltage deviation on Facility” should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator or power system stabilizer) could have a similar impact on the BES as other reportable items. Note: We made this comment last time, and the SDT’s posted response was non-responsive to this concern.</p> <p><b>The SDT reviewed TRE’s comment and believe that our consideration of comments during that last posting clearly stated the SDT view correctly. We stated “The SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.” Further, we note that such events do not rise to the level of notification to the ERO. When events like the ones you mention occur, then entity has obligations to notify other parties according to reliability standards relating to that equipment. The NERC Standards Process Manual does allow TRE to apply for a variance if they have special concerns that GOPs should submit a report to the ERO.</b></p> <p>(2) In the Events Table, under Transmission Loss, the SDT indicated that reporting is triggered only if three or more Transmission Facilities operated by a single TOP are lost. What if four Facilities are lost, with two Facilities operated by each of two TOPs?</p>

Organization	Yes or No	Question 2 Comment
		<p>That is a larger event than three Facilities lost by one TOP, but there is no reporting requirement? Determining event status by facility ownership is not an appropriate measure. The reporting requirements should be based on the magnitude, duration, or impact of the event, and not on what entities own or operate the facilities.</p> <p>(3) In the Events Table, under Transmission Loss, the criteria “loss of three or more Transmission Facilities” is very indefinite and ambiguous. For example, how will bus outages be considered? Many entities consider a bus as a single “Facility,” but loss of a single bus may impact as many as six 345kV transmission lines and cause a major event. It is not clear if this type of event would be reportable under the listed event threshold? Is the single-end opening of a transmission line considered as a loss of a Facility under the reporting criteria?</p> <p>(4) Combinations of events should be reportable. For example, a single event resulting in the loss of two Transmission Facilities (line and transformer) and a 950 MW generator would not be reportable under this standard. But loss of two lines and a transformer, or a 1000 MW generator, would be reportable. It is important to capture all events that have significant impacts.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p><b>The SDT has reviewed Attachment 1 as a minimum level of reporting thresholds. There may be times where an entity may wish to report when a threshold has not been reached because of their experience with their system. EOP-004-2 does not prevent any entity from reporting any type of situation (event) at anytime. Note that the SDT has received industry feedback and it is not within scope of a results</b></p>



Organization	Yes or No	Question 2 Comment
		<p><b>based Standards concept to be very prescriptive in nature.</b></p> <p>(5) In the Events Table, under “Unplanned control center evacuation,” “Loss of all voice communication capability” and “Complete or partial loss of monitoring capability,” GOPs should be included. GOPs also operate control centers that are subject to these kinds of occurrences, with potentially major impacts to the BES. Note that large GOP control centers are classified as “High Impact” facilities in the CIP Version 5 standards, and a single facility can control more than 10,000 MW of generation.</p> <p><b>The SDT appreciates your suggestion; however, as we understand the point, it doesn’t apply continent-wide. The SDT has applied these events to RCs, BAs, and TOPs.</b></p> <p>(6) The “BES Emergency resulting in automatic firm load shedding” event row within Attachment 1 should include the BA as a responsible entity for reporting. Note that EOP-003-1 requires the BA to shed load in emergency situations (R1, R5 as examples), and any such occurrence should be reported.</p> <p><b>The SDT has reviewed your comment and would like to note that manual load shedding is only reportable if 100 MW or more is activated. Automatic load shedding is intended to be when a “relay” performs a breaker action that sheds load without human interaction and achieves a level of 100 MW or more.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Occidental Power Services, Inc.	No	There are no requirements in Attachment 1 for LSEs without BES assets so these entities should not be in the Applicability section.
<p><b>Response: The SDT thanks you for your comment. The LSE obligation in this standard was tied to applicability in CIP-008 for cyber incident reporting. Reporting under CIP-008 is no longer proposed to be a part of EOP-004-2 so this applicability has been removed. Please note that LSEs will be obligated to report under CIP-008 until that standard has been changed.</b></p>		
Xcel Energy	No	1) The event Damage or destruction of a Facility appears to need ‘qualifying’. Is this intended for only malicious intent? Otherwise, weather related or other operational events will often meet this criteria. For example adjustment in generation or changes

Organization	Yes or No	Question 2 Comment
		<p>in line limits to “avoid an Adverse Reliability Impact” could occur during a weather related outage. We suggest adjusting this event and criteria to clearly exclude certain items or identify what is included.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</b></p>

Organization	Yes or No	Question 2 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>2) Also recommend placing the information in footnote 1 into the associated Threshold for Reporting column, and removing the footnote.</p> <p><b>The SDT has removed the footnote per industry comments and concerns.</b></p>
<b>Response: The SDT thanks you for your comment.</b>		
American Electric Power	No	<p>If CIP-008 is now out of scope within the requirements of this standard, any references to it should also be removed from Attachment 1.</p> <p><b>The SDT has removed the one-hour reporting requirement as requested within</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>comments received.</b></p> <p>The Threshold for Reporting column on page 26 includes “Results from actual or suspected intentional human action.” This wording is too vague as many actions by their very nature are intentional. In addition, it should actually be used as a qualifying event rather than a threshold. We recommend removing it entirely from the Threshold column, and placing it in the Events column and also replacing the first row as follows: “Actual or suspected intentional human action with the goal of damage to, or destruction of, the Facility.”</p> <p>On page 27, the event “Any physical threat that could impact the operability of a Facility” is too vague and broad. Using the phrases “any physical threat” and “could impact” sets too high a bar on what would need to be reported. On page 28, for the event “Complete loss of off-site power to a nuclear generating plant (grid supply)”, TO and TOP should be removed and replaced by GOP.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Clark Public Utilities	No	<p>I agree with all but one. The event is "Damage or destruction of a Facility" and the threshold for reporting is "Results from actual or suspected intentional human action." I understand and agree that destruction of a facility due to actual or suspected intentional human action should always be reported. However, I do not know what level of damage should be reported. Obviously the term "damage" is meant to signify an event that is less than destruction. As a result, damage could be extensive, minimal, or hardly noticeable. There needs to be some measure of what the damage entails if the standard is to contain a broad requirement for the reporting of damage intentionally caused by human action. Whether that measure is based on the actual impacts to the BES from the damage or whether the measure is based on the ability of the damaged equipment to continue to function at 100%, 50% or some capability would be acceptable but currently it is too open ended.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p>		

Organization	Yes or No	Question 2 Comment
<p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).  The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>		
New York Power Authority	No	Please see comments submitted by NPCC Regional Standards Committee (RSC).
<p><b>Response: Thank you for your comment. Please see response to the comments.</b></p>		
Consolidated Edison Co. of NY, Inc.	No	<p>General comment regarding Attachment 1:SDT should strive to use identical language to event descriptions in the NERC Event Analysis Process and FERC OE-417. Creating a third set of event descriptions is not helpful to system operators. We recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>Replace the Attachment 1 “NOTE” with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required.</p>

Organization	Yes or No	Question 2 Comment
		<p><b>The SDT thanks you with your comment. First, the SDT believes that you intended the comment to address the “Note” on Attachment 2, not Attachment 1. The SDT does not believe that a hardcopy report is necessary if the organization has made voice contact.</b></p> <p>Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read, Results from actual or suspected intentional human action, excluding unintentional human errors.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” not states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>operations of each interconnection.</b></p> <p>Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or please provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement</b></p>



Organization	Yes or No	Question 2 Comment
		<p><b>R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Event: BES Emergency requiring public appeal for load reduction. Replace Event wording with language from #8 on OE-417 reporting form to eliminate reporting confusion. Following this sentence add, "This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is require to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>"Event: Complete or partial loss of monitoring capability Event wording: Delete the words "or partial" to conform the wording to NERC Event Analysis Process. Event: Transmission Loss Modify to BES Transmission Loss Event Generation Loss Modify to BES Generation Loss</p>
Orange and Rockland Utilities, Inc.	No	<p>General comment regarding Attachment 1: SDT should strive to use identical language to event descriptions in the NERC Event Analysis Process and FERC OE-417. Creating a third set of event descriptions is not helpful to system operators. We recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>Replace the Attachment 1 “NOTE” with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required.</p> <p><b>The SDT thanks you for your comment. First, the SDT believes that you intended the comment to address the “Note” on Attachment 2, not Attachment 1. The SDT does not believe that a hardcopy report is necessary if the organization has made voice contact.</b></p> <p>Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read, Results from actual or suspected intentional human action, excluding unintentional human errors.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” not states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could</b></p>

Organization	Yes or No	Question 2 Comment
		<p>adversely affect the reliability of the Bulk Electric System).</p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p>Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or please provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Event: BES Emergency requiring public appeal for load reduction. Replace Event wording with language from #8 on OE-417 reporting form to eliminate reporting confusion. Following this sentence add, “This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.”</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is require to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>Event: Complete or partial loss of monitoring capability Event wording: Delete the words “or partial” to conform the wording to NERC Event Analysis Process.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or</b></p>

Organization	Yes or No	Question 2 Comment
		<p>TOP who have this capability to start with.</p> <p>Event: Transmission Loss Modify to BES Transmission Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</p> <p>Event Generation Loss Modify to BES Generation Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</p> <p>OR</p> <p><math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
FirstEnergy Corp	No	<p>FE requests the following changes be made to Attachment 1:1. Pg. 19 / Event: “Voltage deviation on a Facility”. The term “observes” for Entity with Reporting Responsibility be changed to “experiences”. The burden should rest with the</p>

Organization	Yes or No	Question 2 Comment
		<p>initiating entity in consistency with other Reporting Responsibilities.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p>2. In “Threshold for Reporting”, the language should be expanded to - plus or minus 10% “of nominal voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>3. Pg.20 /Event: “Complete or partial loss of monitoring capability”. The term “partial” should be deleted from the event description to read as follows: Complete loss of monitoring capability and the reporting responsibility requirements to read “Each RC, BA, and TOP that experiences the complete loss of monitoring capability.”</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004</b></p>

Organization	Yes or No	Question 2 Comment
		<p>into EOP-004-2. This event is now written to state:</p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Farmington Electric Utility System	No	<p>The reporting threshold for “Complete or partial loss of monitoring capability” should be modified to include the loss of additional equipment and not be limited to State Estimator and Contingency Analysis. Some options have been included: Affecting a BES control center for 30 continuous minutes such that Real-Time monitoring tools are rendered inoperable. Affecting a BES control center for 30 continuous minutes to the extent a Constrained Facility would not be identified or an Adverse Reliability Impact event could occur due to lack of monitoring capability. Affecting a BES control center for 30 continuous minutes such that an Emergency would not be identified or ma</p>
<p><b>Response: The SDT thanks you for your comment. The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>		
Public Service Enterprise Group	No	<p>We agreed with most of the revisions. However, for the 24-hour reporting time frame portion of the EOP-004 Attachment 1: Reportable Event that starts on p. 18, we have these concerns: a. Why was “RC” left out in the first row? RC is in the second row that also addresses a “Facility.” We believe that “RC” was inadvertently</p>

Organization	Yes or No	Question 2 Comment
		<p>left out.</p> <p>b. In the first row, entities such as a BA, TO, GO, GOP, or DP would not know whether damage or destruction of one of its Facilities either “Affects an IROL (per FAC-014)” or “Results in the need for actions to avoid an Adverse Reliability Impact.” FAC-014-2, R5.1.1 requires Reliability Coordinators provide information for each IROL on the “Identification and status of the associated Facility (or group of Facilities) that is (are) critical to the derivation of the IROL” to entities that do NOT include the entities listed above. And frankly, those entities would not need to know. The reporting requirements associated with “Damage or destruction of a Facility” need to be changed so that the criteria for reporting by an entity whose Facilities experience damage or destruction does not rely upon information that the entity does not possess. c. A possible route to achieve the results in b. above is described below: i. All Facilities that are damaged or destroyed that “Results from actual or suspected intentional human action” would be reported to the ERO by the entity experiencing the damage or destruction. ii. All Facilities that are damaged or destroyed OTHER THAN THAT due to an “actual or suspected intentional human action” would be reported to the RC by the entity experiencing the damage or destruction. Based upon those reports, the RC would be required to report whether the reported damage or destruction of a Facility “Affects an IROL (per FAC-010)” or “Results in the need for actions to Avoid an Adverse Reliability Consequence.” (The RC may need to modify its data specifications in IRO-010-1a - Reliability Coordinator Data Specification and Collection - to specify outages due to “damage or destruction of a Facility.” We also note that “DP” is not included in IRO-010-1a, but “LSE” is included. DPs are required to also register as LSEs if they meet certain criteria. See the “Statement of Compliance Registry Criteria, Rev. 5.0”, p.7. For this reason, we suggest that DP be replaced with LSE in EOP-004-2.) d. To implement the changes in c. above, we suggest that the first row be divided into two rows: i. FIRST ROW: This would be like the existing first row on page 18, except “RC” would be added to the column for “Entity with Reporting Responsibility” and the only reporting threshold would be ““Results from actual or suspected intentional human action.” ii. SECOND ROW: The Event would be “Damage or destruction of a Facility of a BA, TO, TOP, GO,</p>



Organization	Yes or No	Question 2 Comment
		<p>GOP, or LSE,” the Entity, the Reporting Responsibility would be “The RC that has the BA, TOP, GO, GOP, or LSE experiencing the damage or destruction in its area,” and the Threshold for Reporting would be “Affects an IROL (per FAC-010)” or “Results in the need for actions to avoid an Adverse Reliability Consequence.”</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p><b>The SDT also developed another to read:</b></p>		

Organization	Yes or No	Question 2 Comment
		<p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p>
MidAmerican Energy	No	<p>Several modifications need to be made to Table 1 to enhance clarity and delete unnecessary or duplicate items. The stated reliability objective of EOP-004 and the drafting team is to reduce and prevent outages which could lead to cascading through reporting. It is understood that the EOP-004 Attachment 1 is to cover similar items to the DOE OE-417 form. Last, remember that FERC recently asked the question of what standards did not provide system reliability benefits. Those reports that cannot show a direct threat to a potential cascade need to be eliminated. Table 1 should always align with the cascade risk objectives and OE-417 where possible. Therefore Table 1 should be modified as follows:</p> <ol style="list-style-type: none"> <li>1. Completely divorce CIP-008 from EOP-004. Constant changes, the introduction of new players such as DOE and DHS, and repeated congressional bills, make coordination with CIP-008 nearly impossible. Cyber security and operational performance under EOP-004 remain separate and different despite best efforts to combine the two concepts.</li> </ol> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we</b></p>

Organization	Yes or No	Question 2 Comment
		<p>have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</p> <p>2. Modify R1.2 to state that ERO notification only is required for Table 1. This is similar to the DOE OE-417 notification. Notification of other entities is a best practice, not a mandatory NERC standard. If entities want to notify neighboring entities, they may do so as a best practice guideline.</p> <p><b>The SDT has updated R1 based on comments received to read as:</b></p> <p><b>“R1. Each Responsible Entity shall have an event reporting Operating Plan that includes communication protocol(s) for applicable events listed in, and within the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations based on the event type (e.g. the Regional Entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, governmental or provincial agencies).”</b></p> <p>3. Better clarity for communicating each of the applicable events listed in the EOP-004 Attachment 1 in accordance with the timeframes specified are needed. MidAmerican suggests a forth column be added to the table to clearly identify who must be notified within the specified time period or at a minimum, that R1.2 be revised to clearly state that only the ERO must be notified to comply with the standard.</p> <p><b>The SDT disagrees but believes that per your Operating Plan contained in Requirement R1, an entity could take Attachment 1 and insert another column to assist whoever is designated to report an event within your company. The SDT does not want to be too prescriptive within Attachment 1.</b></p> <p>4. Consolidate OE-417 concepts on physical attack and cyber events by consolidating OE-417 items 1, 2, 9 and 10 to: Verifiable, credible, and malicious physical damage (excluding natural weather events) to a BES generator, line, transformer, or bus that when reported requires an appropriate Reliability Coordinator or Balancing Authority to issue an Energy Emergency Alert Level 2 or higher. The whole attempt to discuss a</p>

Organization	Yes or No	Question 2 Comment
		<p>NERC Facility and avoid adverse reliability impacts overreaches the fundamental principal or reporting for an emergency that could result in a cascade.</p> <p><b>The SDT disagrees since the OE-417 (and EAP) does not follow the ANSI process as NERC does in the Standards Development Process.</b></p> <p>5. The wording “affects an IROL (per FAC-014),” is too vague and not measurable. Many facilities could affect an IROL, but fewer facilities if lost would cause an IROL. Change “affects” to “results in”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed”</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>6. Recommend that Adverse Reliability Impact be deleted and be replaced with actual EEA 2 or EEA 3 level events.</p> <p>The SDT has removed Adverse Reliability Impact based on industry feedback and rewrote the event:</p> <p>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are</p>

Organization	Yes or No	Question 2 Comment
		<p>required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>7. The phrase “results from actual or suspected intentional human action” is vague</p>

Organization	Yes or No	Question 2 Comment
		<p>and not measurable. This line item used the term “suspected” which relates to “sabotage”. MidAmerican recommends that “Results from actual or suspected intentional human action” be deleted. If not deleted the phrase should be replaced with “Results from verifiable, credible, and malicious human action intended to damage the BES.”</p> <p>8. Delete “Any physical threat...” as vague, and difficult to measure in a “perfect” zero defect audit environment, and as already covered by item 1 above. If not deleted, at a minimum replace “Any physical threat”, with “physical attack” as being measurable and consistent with DOE OE-417.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>9. With the use of “i.e.” the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that “e.g.” should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity.</p> <p><b>The SDT has made the required change concerning replacing “i.e.” with “e.g.”</b></p> <p>10. The phrase “or partial loss of monitoring capability” is too vague and should be deleted. In addition, the 30 minute window is too short for EMS and IT staff to effectively be notified and troubleshoot systems before being subjected to a federal law requiring reporting and potential violations. The time frame should be consistent with the EOP-008 standard. If not deleted, replace with “Complete loss of SCADA affecting a BES control center for 60 continuous minutes such that analysis tools of State Estimator and/or Contingency Analysis are rendered inoperable.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p> <p>11. Transmission loss should be deleted. The number of transmission elements out does not directly correlate to BES stability and cascading. For that reason alone, this</p>



Organization	Yes or No	Question 2 Comment
		<p>item should be deleted or it would have already been included in the past EOP-004 standard. In addition, large footprints can have multiple storms or weather events resulting in normal system outages. This should not be a reportable event that deals with potential cascading.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>12. Modify the threshold of “BES emergency requiring a public appeal...” to include, “Public appeal for a load reduction event resulting from a RC or BA implementing its emergency energy and capacity plans documented in EOP-001.” Public appeals for conservation that aren't used to avoid capacity and energy emergencies should be clearly excluded.</p> <p><b>The SDT disagrees as your request makes the event very prescriptive. The threshold is written to state: “Public appeal for load reduction event.” The SDT understands that there may be several reports of a single event and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>13. Add a time threshold to complete loss of off-site power to a nuclear plant. Nuclear plants are to have backup diesel generation that last for a minimum amount of time. A threshold recognizing this 4 hour or longer window needs to be added such as complete loss of off-site power to a nuclear plant for more than 4 hours.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT</b></p>

Organization	Yes or No	Question 2 Comment
		<p>removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.”</p> <p>As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</p> <p>Also see the NSRF comments.</p> <p>Please review the responses to that commenter.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Illinois Municipal Electric Agency	No	Illinois Municipal Electric Agency supports comments submitted by Florida Municipal Power Agency.
<p><b>Response: The SDT thanks you for your comment. Please review the responses to that commenter.</b></p>		
Americican Transmission Company, LLC	No	<p>ATC is proposing changes to the following Events in Attachment 1: (Reference Clean Copy of the Standard)</p> <p>1) Pg. 18/ Event: Any Physical threat that could impact the operability of a Facility. ATC is proposing a language change to the Threshold- “Meets Registered Entities criteria stated in its Event Reporting Operating Plan, in addition to excluding weather.”</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:</p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>2) Pg. 19 / Event: Voltage deviation on a Facility. ATC believes that the term “observes” for Entity with Reporting Responsibility be changed back to “experiences” as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. Also, for Threshold for Reporting, ATC believes the language should be expanded to - plus or minus 10% “of target voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</b></p>

Organization	Yes or No	Question 2 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Observed voltage deviation of <math>\pm 10\%</math> of nominal voltage sustained for <math>\geq 15</math> continuous minutes.”</p> <p>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</p> <p>3) Pg. 19/ Event: Transmission loss. ATC recommends that Threshold for Reporting be changed to read “Unintentional loss of four, or more Transmission Facilities, excluding successful automatic reclosing, within 30 seconds of the first loss experienced and for 30 continuous minutes. Technical justification or Discussion for this recommended change: In the instance of a transformer-line-transformer, scenario commonly found close-in to Generating stations, consisting of 3 defined “facilities”, 1 lightning strike can cause automatic unintentional loss by design. Increase the number of facilities to 4. In a normal shoulder season day, an entity may experience the unintentional loss of a 138kv line from storm activity, at point A in the morning, a loss of a 115kv line from a different storm 300 miles from point A in the afternoon, and a loss of 161kv line in the evening 500 miles from point A due to a failed component, if it is an entity of significant size. Propose some type of time constraint. Add time constraint as proposed, 30 seconds, other than automatic reclosing. In the event of dense lightning occurrence, the loss of multiple transmission facilities may occur over several minutes to several hours with no significant detrimental effect to the BES, as load will most certainly be affected (lost due to breaker activity on the much more exposed Distribution system) as well. Any additional loss after 30 seconds must take into account supplemental devices with intentional relay time delays, such as shunt capacitors, reactors, or load tap changers on transformers activating as designed, arresting system decay. In addition, Generator response after this time has significant impact.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with</p>

Organization	Yes or No	Question 2 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>4) Pg.20 /Event: Complete or partial loss of monitoring capability. ATC recommends that the term “partial” be deleted from the event description.ATC recommends that the term “partial” be deleted for the Entity with Reporting Responsibility and changed to read: Each RC, BA, and TOP that experiences the complete loss of monitoring capability.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Alliant Energy	No	<p>In the first Event for twenty four hour reporting, the last item in “Threshold for Reporting” should be revised to “Results from actual or suspected intentional malicious human action.” An employee may be performing maintenance and make a mistake, which could impact the BES. In the second Event for twenty four hour reporting the event should be revised to “Any physical attack that could impact the operability of a Facility.” Alliant Energy believes this is clearer and easier to measure.</p>

Organization	Yes or No	Question 2 Comment
<p>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the</p>		

Organization	Yes or No	Question 2 Comment
<p>situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>		
Consumers Energy	No	<p>The term "Facility" seems to be much more broad and even more vague than the use of BES equipment. We recommend reverting back to use of BES equipment.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT disagrees since BES is used within the definition of Facility. NERC defines Facility as: "A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)."</b></p>		
Ameren	No	<p>We appreciate the efforts of the SDT and believe this latest Draft is greatly improved over the previous version. However, we propose the following suggestions: (1) The first Event category in Attachment 1 under 24 Hour Reporting is Applicable to GO and GOP entities. Yet the first 2 of 3 Thresholds for Reporting require data that is unobtainable for GO and GOP entities. Specifically, Events that "Affects an IROL (per FAC-014)" and "Results in the need for actions to avoid an Adverse Reliability Impact". We believe these thresholds, and the use of the NERC Glossary term Adverse Reliability Impact, clearly show the SDT's intent to limit reporting only to Events that have a major and significant reliability impact on the BES. GO or GOP does not have access to the wide-area view of the transmission system, making them to make this determination is impossible. As a result, we do not believe GO and GOP entities should have Reporting Responsibility for these types of Events.</p> <p>(2) For GO and GOP entities, the third Threshold is confusing as to which facilities in the plant it would be applicable to; because the definition of "Facility" does not provide a clear guidance in that respect. For example, would a damage to ID fan qualify as a reportable event?</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</b></p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:</p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24</p>



Organization	Yes or No	Question 2 Comment
		<p>hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>(3) The second Event category in Attachment 1 under 24 Hour Reporting, "Any physical threat that could impact the operability of a Facility" is wide open to interpretation and thus impracticable to comply with. For example, a simple car accident that threatens any transmission circuit, whether it impacts the BES (as listed in the Threshold for the previous event in the table or any other measure) or not, is reportable. This list could become endless without the events having any substantial impact on the system. To continue this point, the Footnote 1 can also include, among many other examples, the following:(a) A wild fire near a generating plant, (b) Low river levels that might shut down a generating plant, (c) A crane that has partially collapsed near a generator switchyard, (d) Damage to a rail line into a coal plant, and/or (v) low gas pressure that might limit or stop operation of a natural gas generating plant.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT</b></p>

Organization	Yes or No	Question 2 Comment
		<p>removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p><b>"Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility."</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility's normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>(4) The category, "Transmission Loss" is a concern also. If the meaning of Transmission Facility is included in the meaning of Facility as described in the event list, it may be acceptable; but, we still have a question how would a loss of a bus and the multiple radial element that may be connected to that bus would be treated? Also, how would a breaker failure affect this type of an event? The loss of a circuit is</p>

Organization	Yes or No	Question 2 Comment
		<p>“intentional” (as opposed to Unintentional as listed in the threshold) for the failure of breaker, how will it be treated in counting three or more? We suggest a clarification for such types of scenarios.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>(5) Requirement R1.: 1.1 includes an exception from compliance with this Standard if there is a Cyber Security Incident according to CIP-008-3. However, note that the CIP-008-3 may not apply to all GO and GOP facilities. While the exception is warranted to eliminate duplicative event reporting plans, the language of this requirement is confusing as it does not clearly provides that message.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have proposed remanding the one hour event back to CIP-008.</b></p> <p>(6) The second paragraph in Section C.1.1.2. Includes the phrases “...shall retain the current, document...” and “...the “date change page” from each version...” Is the “document” intended to be the Operating Plan? We do not see a defining reference in the text around this phrase; also, is a “date change page” mandatory for compliance with this Standard? We request additional clarification of wording in the Evidence Retention section of the Standard.</p> <p>(7) Page 19 / Event: Voltage deviation on a Facility: We believe that the term “observes” for Entity with Reporting Responsibility be changed back to “experiences” as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. In addition, for Threshold for Reporting, We</p>

Organization	Yes or No	Question 2 Comment
		<p>believe the language should be expanded to - plus or minus 10%”of nominal voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>(8) Page 20 /Event: Complete or partial loss of monitoring capability. We suggest to the SDT that the term “partial” be deleted from the event description.</p> <p>(9) We suggest to the SDT that the term “partial” be deleted for the Entity with Reporting Responsibility and changed to read: Each RC, BA, and TOP that experiences the complete loss of monitoring capability.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
We Energies	No	Submitting reports to the ERO: NERC and all of the Regional Entities are the ERO. If I

Organization	Yes or No	Question 2 Comment
		<p>send a report to any Regional Entity (and not NERC), I have sent it to the ERO.</p> <p><b>The SDT would like to point out the FERC has approved NERC to be the ERO. And the NERC has a delegation agreement with each Regional Entities. This Requirement R1 requires you send a report to the ERO (and whoever else the entity wishes to inform per Requirement R1 including the applicable regions if you are so obligated or its' your desire).</b></p> <p>Damage or Destruction of a Facility: A DP may not have a Facility by the NERC Glossary definition. All distribution is not a Facility. Did you mean to exclude all distribution?</p> <p><b>The SDT agrees that if a DP does not own or operate a Facility then this event would not be applicable to them.</b></p> <p>Any Physical threat that could impact the operability of a Facility: An RC does not have Facilities by the NERC Glossary definition. An RC will not have to report this. BES Emergency... Reporting Responsibility: If meeting the Reporting Threshold was due to a directive from the RC, who is the Initiating entity?</p> <p><b>The SDT agrees concerning the RC does not own a Facility and has removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>Voltage deviation on a Facility Threshold for Reporting: 10% of what voltage? Nominal, rated, scheduled, design, actual at an instant?</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</p> <p>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
NextEra Energy Inc	No	As stated in NextEra’s past comments, we continue to be concerned that EOP-004-2 does not appropriately address actual sabotage that threatens the Bulk Electric

Organization	Yes or No	Question 2 Comment
		<p>System (BES) versus random acts that are isolated and pose no risk to the BES. Therefore, NextEra repeats a portion of its past comments below in the hope that the next revision of EOP-004-2 will more adequately address NextEra’s concerns. Specifically, NextEra’s requests that its definition of sabotage set forth below replace Attachment 1’s “Damage and Destruction of Equipment” and “Any physical threat that could impact the operability of a Facility.” In Order No. 693, FERC stated its interest in NERC revising CIP-001 to better define sabotage and requiring notification to the certain appropriate federal authorities, such as the Department of Homeland Security. FERC Order No. 693 at PP 461, 462, 467, 468, 471. NextEra has provided an approach that accomplishes FERC’s objectives and remains within the framework of the drafting team, but also focuses the process of determining and reporting on only those sabotage acts that could affect other BES systems. Today, there are too many events that are being reported as sabotage to all parties in the Interconnection, when in reality these acts have no material affect or potential impact to other BES systems other than the one that experienced it. For example, while the drafting team notes the issue of copper theft is a localized act, there are other localized acts of sabotage that are committed by an individual, and these acts pose little, if any, impact or threat to other BES systems. Reporting sabotage that does not need to be sent to everyone does not add to the security or reliability of the BES. Relatedly, there is a need to clarify some of the current industry confusion on who should (and has the capabilities to) be reporting to a broader audience of entities. Hence, the NextEra approach provides a clear definition of sabotage, as well as the process for determining and reporting sabotage. New Definition for Sabotage. Attempted or Actual Sabotage: an intentional act that attempts to or does destroy or damage BES equipment for the purpose of disrupting the operations of BES equipment, or the BES, and has a potential to materially threaten or impact the reliability of one or more BES systems (i.e., one act of sabotage on BES equipment is only reportable if it is determined to be part of a larger conspiracy to threaten the reliability of the Interconnection or more than one BES system).</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has stated in our “Consideration of Issues and Directives – March 15,</b></p>		

Organization	Yes or No	Question 2 Comment
<p>2012” that was posted with the last posting stated:</p> <p>The SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of “event”. The SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p> <p>The SDT has discussed this with FERC Staff and we agree that sabotage could be a state of mind; and, therefore, the real issue: Was there an event or not?</p>		
ISO New England Inc	No	
<p><b>Response: The SDT thanks you for your participation.</b></p>		
Nebraska Public Power District	No	<p>1. The following comments are in regard to Attachment 1:A. The row [Event] titled “Damage or destruction of Facility”: 1. In column 3 [Threshold for Reporting], the word “Affect” is vague note the following concerns: i. Does “Affect” include a broken crossarm damaged without the Facility relaying out of service. This could be considered to have an “Affect” on the IROL. ii. Would the answer be different if the line relayed out of service and auto-reclosed (short interruption) for the same damaged crossarm? We need clarity from the SDT in order to know when a report is due.</p> <p>2. For clarification: Who initiates the report when the IROL interfaces spans between multiple entities? We know of an IROL that has no less that four entities that operate Facilities within the interface. Who initiates the report of the IROL is affected? All?</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</b></p>



Organization	Yes or No	Question 2 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p>

Organization	Yes or No	Question 2 Comment
		<p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>B. The row [Event] titled “Any physical threat that could impact the operability of a Facility”:1. In Column 1 [Event] change the word “threat” to “attack”, this aligns with the OE-417 report.2. In Column 3 [Threshold for Reporting], align the threshold with the OE-417 form.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p>

Organization	Yes or No	Question 2 Comment
		<p>Or</p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>C. The row [Event] titled “Transmission loss”, in column 3 [Threshold for Reporting], the defined term “Transmission Facilities” is too vague. There needs to be a more description such that an entity clearly understands when an event is reportable and for what equipment. We would recommend the definition used in the Event Reporting Field Trial: An unexpected outage, contrary to design, of three or more BES elements caused by a common disturbance. Excluding successful automatic reclosing. For example: a. The loss of a combination of NERC-defined Facilities. b. The loss of an entire generation station of three or more generators (aggregate generation of 500 MW to 1,999 MW); combined cycle units are represented as one unit.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>D. The row [Event] titled “Complete or partial loss of monitoring”: 1. In column 1 [Event], delete the words “or partial”. This is subjective without definition, delete. 2. Also in column 1 [Event], delete the word “monitoring” and replace with Supervisory Control and Data Acquisition (SCADA). SCADA is defined term that explicitly calls out in the definition “monitoring and control” and is understood by the industry as such. 3. In column 2 [Entity with Reporting Responsibility], delete the words “or partial”; also delete the word “monitoring” and replace with SCADA. 4. In column 3 [Threshold for Reporting], reword to state “Complete loss of SCADA affecting a BES control center for <math>\geq</math> 30 continuous minutes”.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
GTC	No	<p>Page 17 &amp; 18, One Hour Reporting and Twenty-four Hour Reporting: append the introductory statements with the following: “meeting the threshold for reporting” after recognition of the event. Example: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hours of recognition of the event meeting the threshold for reporting. Page 19, system separation (islanding); Clarify the intent of this threshold for reporting: Load <math>\geq</math> 100 MW and any generation; or Load <math>\geq</math> 100 MW and Generation</p>

Organization	Yes or No	Question 2 Comment
		>= 100 MW, or some combination of load and generation totaling 100 MW.
<p><b>Response: The SDT thanks you for your comment. The SDT has chosen not add the requested language as we believe the intent is understood that the time frames means from “meeting the threshold for reporting.” The SDT has revised the language regarding islanding and we believe it addresses your concern.</b></p>		
Indiana Municipal Power Agency	No	<p>The event "any physical threat that could impact the operability of a Facility" is not measurable and can be interpreted many ways by entities or auditors. IMPA recommend incorporating language that let's this be the judgment of the registered entity only.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or</b></p>

Organization	Yes or No	Question 2 Comment
		<p>activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>On the "voltage deviation on a Facility", IMPA recommends that only the TOP the experiences a voltage deviation be the one responsible for reporting.</p> <p><b>The SDT has made this change per comments received from the industry.</b></p> <p>For generation loss and transmission loss, IMPA believes that the amount of loss needs to be associated with a time period or event (concurrent forced outages).</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Idaho Power Co.	No	<p>I think that the category "Damage or destruction of a Facility" is too ambiguous, and the Threshold for Reporting criteria does not help to clarify the question. Any loss of a facility may result in the need for actions to get to the new operating point, would this be a reportable disturbance?</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency."</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
MISO	No	
American Public Power Association	No	<p>APPA in our comments on the previous draft of EOP-004-2 requested relief for small entities from this reporting/documentation standard. APPA suggested setting a 300 MW threshold for some of the criteria in Attachment 1. This suggestion was not accepted by the SDT. However, the SDT is still directed by FERC to “consider whether separate, less burdensome requirements for smaller entities may be appropriate. Therefore, APPA requests that the SDT provide relief to small entities by providing separate requirements for small entities by requiring reporting only when one of the four criteria in DOE-OE-417 are met: 1. Actual physical attack, 2. Actual cyber attack, 3. Complete operational failure, or 4. Electrical System Separation. APPA recommends this information should be reported to the small entity’s BA as allowed in the DOE-OE-417 joint filing process.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has taken your concerns into consideration (as directed by FERC) and believes that “small entities” will most likely not meet the thresholds for reporting since items are predicated on “Facilities” or they don’t meet the Threshold for reporting.</b></p>		
Brazos Electric Power Cooperative	No	Please see the comments submitted by ACES Power Marketing.



Organization	Yes or No	Question 2 Comment
<p><b>Response: The SDT thanks you for your comment. Please review the response to those comments.</b></p>		
<p>Puget Sound Energy, Inc.</p>	<p>No</p>	<p>The Note at the beginning of Attachment 1 references notifying parties per Requirement R1; however, notification occurs in conjunction with Requirement R2. The term “Adverse Reliability Impact” is used in the threshold section of the event “Damage or destruction of a Facility”. At this time, there are two definitions for that term in the NERC Glossary. The FERC-approved definition for this term is “The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection.” If the drafting team instead means to use the definition that NERC approved on 8/4/2011 (as seems likely, since that definition more closely aligns with the severity level indicated by the other two threshold statements) then the definition should be included in the Implementation Plan as a prerequisite approval.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p>In addition, would the threshold of “Results from actual or suspected intentional human action” include results from actual intentional human action which produced an accidental result, meaning, someone was intentionally doing some authorized action but unintentionally made a mistake, leading to damage of a facility? The event “Any physical threat that could impact the operability of a Facility” will require reporting for many events that have little or no significance to reliable operation of the Bulk Electric System. For example, a balloon lodged in a 115 kV transmission line is a “physical threat” that could definitely “impact the operability” of that Facility and, yet, will probably have little reliability impact. So, too, could a car-pole accident that causes a pole to lean, a leaning tree, or an unfortunately-located bird’s nest. The drafting team should develop appropriate threshold language so that reporting is required only for events that do threaten the reliability of the Bulk Electric System.</p> <p><b>The SDT also developed another to read:</b></p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>With respect to the event “Unplanned control center evacuation”, the standard drafting team should include the term “complete” in the description and/or threshold statement to avoid having partial evacuations trigger the need to report.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Unplanned evacuation from BES control center facility for 30 continuous minutes or more.” The SDT does not believe the word “complete” needs to be added.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Central Lincoln	No	1) We appreciate the changes made to reduce the short time reporting requirements.

Organization	Yes or No	Question 2 Comment
		<p><b>The SDT has removed the one-hour reporting time frame, and all events are to be reported within 24 hours of recognition of the event.</b></p> <p>2) We would like to point out that the 24 hour reporting threshold for “Damage or destruction of a Facility” resulting from intentional human action will still be non-proportional BES risk for certain events. The discovery of a gunshot 115 kV insulator will start the 24 hour clock running, no matter how busy the discoverer is performing restoration or other duties that are more important. The damage may have been done a year earlier, but upon discovery the report suddenly becomes the priority task. To hit the insulator, the shooter likely had to take aim and pull the trigger, so intent is at least suspected if not actual. And the voltage level ensures the insulator is part of a Facility.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could</p>

Organization	Yes or No	Question 2 Comment
		<p>further define what a suspected intentional human action is within their Operating Plan.</p> <p>3) We also note that the theft of in service copper is not a physical threat, it is actual damage. The reference to Footnote 1 should be relocated or copied to the cell above the one it resides in now.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>4) We support the APPA comments regarding small entities.</p> <p>The SDT has taken your concerns into consideration (as directed by FERC) and believes that “small entities” will most likely not meet the thresholds for reporting</p>

Organization	Yes or No	Question 2 Comment
		since items are predicated on “Facilities.”
<b>Response: The SDT thanks you for your comment.</b>		
Los Angeles Department of Water and Power	No	<p>LADWP has the following comments:#1 - “Any physical threat that could impact the operability of a Facility” is still vague and “operability” is too low a threshold. There needs to be a potential impact to BES reliability.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed”</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>#2 - “Voltage Deviation on a Facility” I think the threshold definition needs to be more specific: Is it 10% from nominal? 10% from normal min/max operating</p>



Organization	Yes or No	Question 2 Comment
		<p>tables/schedules? Another entities 10% might be different than mine.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>#3 - “Transmission Loss” The threshold of three facilities is still too vague. A generator and a transformer and a gen-tie are likely to have overlapping zones of protection that could routinely take out all three. The prospect of penalties would likely cause unneeded reporting.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Deseret Power	No	The threshold for reporting is way too low. A gun shot insulator is not an act of

Organization	Yes or No	Question 2 Comment
		terrorism... vandalism yes... and a car hit pole would be reportable on a 138 kv line. these seem to be too aggressive in reporting.
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p>		
Kansas City Power & Light	No	For the event, “Damage or destruction of a Facility”, the “Threshold for reporting” includes “Results from actual or suspected intentional human action”. This is too broad and could include events such as damage to equipment resulting from stealing cooper or wire which has no intentional motivation to disrupt the reliability of the bulk electric system. Reports of this type to law enforcement and governmental agencies will quickly appear as noise and begin to be treated as noise. This may result in overlooking a report that deserves attention. Recommend the drafting team consider making this threshold conditional on the judgment by the entity on the

Organization	Yes or No	Question 2 Comment
		<p>human action intended to be a potential threat to the reliability of the bulk electric system. For the event, “Any physical threat that could impact the operability of a Facility”, the same comment as above applies. The footnote states to include copper theft if the Facility operation is impacted. Again, it is recommended to make a report of this nature conditional on the judgment of the entity on the intent to be a potential threat to the reliability of the bulk electric system.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each</b></p>		

Organization	Yes or No	Question 2 Comment
		<p>interconnection.</p> <p>The SDT also developed another to read:</p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
Dominion	Yes	<p>Comments: While Dominion agrees that the revisions are a much appreciated improvement, we are concerned that Attachment 1 does not explicitly contain the ‘entities which must be, at a minimum, notified.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified.</b></p> <p>Attachment 2 appears to indicate that only the ERO and the Reliability Coordinator for the Entity with Reporting Responsibility need be informed. However, the background section indicates that the Entity with Reporting Responsibility is also</p>

Organization	Yes or No	Question 2 Comment
		<p>expected to contact local law enforcement. We therefore suggest that Attachment 2 be modified to include local law enforcement.</p> <p><b>The SDT has adapted the language in Attachment 2 along the lines of your concern.</b></p> <p>Page 26 redline; Attachment 1; Event - Damage or destruction of a Facility; Threshold for Reporting - Results from actual or suspected intentional human action; Dominion is concerned with the ambiguity that this could be interpreted as applying to distribution. Page 27 redline; Attachment 1; Event - Any physical threat that could impact the operability of a Facility; Dominion is concerned the word “could” is hypothetical and therefore unverifiable and un-auditable.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within</p>

Organization	Yes or No	Question 2 Comment
		<p>their Operating Plan.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>The SDT could provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p>

Organization	Yes or No	Question 2 Comment
		The SDT cannot provide a list of hypothetical events, but will remind the entity that the Operating Plan that is required per Requirement R1 could contain a basis to report concerning your unique system equipment or configuration of your system.
<b>Response: The SDT thanks you for your comment.</b>		
Seattle City Light	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Avista	Yes	In general the SDT has made significant improvements to Attachment 1. Avista does have a suggestion to further improve Attachment 1. In Attachment 1 under the 24 hour Reporting Matrix, the second event states "Any physical threat that could impact the operability of a Facility" and the Threshold for Reporting states "Threat to a Facility excluding weather related threats". This is extremely open ended. We suggest adding the following language to the Threshold for Reporting for Any Physical Threat: Threat to a facility that: Could affect an IROL (per FAC-014) OR Could result in the need for actions to avoid and Adverse Reliability Impact This new language would be consistent with the reporting threshold for a Damage event.
<p><b>Response: The SDT thanks you for your comment. The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator</b></p>		



Organization	Yes or No	Question 2 Comment
		<p>Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT</p>

Organization	Yes or No	Question 2 Comment
<b>envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b>		
PNGC Comment Group	Yes	<p>We agree with reservations. Our comments are below and we are seeking clarification of the Applicability section of the standard. We are voting "no" but if slight changes are made to the applicability section we will change our votes to "yes". NERC and FERC have expressed a willingness to address the compliance burden on smaller entities that pose minimal risk to the Bulk Electric System. The PNGC Comment Group understands the SDT's intent to categorize reportable events and achieve an Adequate Level of Reliability while also understanding the costs associated. Given the changes made by the SDT to Attachment 1, we believe you have gone a long way in alleviating the potential for needless reporting from small entities that does not support reliability.</p> <p><b>The SDT has taken your concerns into consideration (as directed by FERC) and believes that "small entities" will most likely not meet the thresholds for reporting since items are predicated on "Facilities."</b></p> <p>One remaining concern we have are potential reporting requirements in the Event types; "Damage or destruction of a Facility" and "Any physical threat that could impact the operability of a Facility". These two event types have the following threshold language; "Results from actual or suspected intentional human action" and "Threat to a Facility excluding weather related threats" respectively. We believe these two thresholds could lead to very small entities filing reports for events that really are not a threat to the BES or Reliability.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p>

Organization	Yes or No	Question 2 Comment
		<p data-bbox="772 269 1885 378">“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p data-bbox="772 456 1885 643">This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p data-bbox="772 721 1885 984">This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p data-bbox="772 1062 1318 1094">The SDT also developed another to read:</p> <p data-bbox="772 1172 1766 1240">“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p data-bbox="772 1268 1871 1414">This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or</p>

Organization	Yes or No	Question 2 Comment
		<p><b>destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>Note: For vandalism, sabotage or suspected terrorism, even the smallest entities will file a police report and at that point local law enforcement will follow their terrorism reporting procedures if necessary, as you’ve rightly indicated in your “Law Enforcement Reporting” section. We believe extraneous reporting could be alleviated with a small tweak to the Applicability section for 4.1.9 to exclude the smallest Distribution Providers. As stated before, even if these very small entities are excluded from filing reports under EOP-004-2, threats to Facilities that they may have will still be reported to local law enforcement while not cluttering up the NERC/DOE reporting process for real threats to the BES. Our suggested change:4.1.9. Distribution Provider: with peak load &gt;= 200 MWs. The PNGC Comment Group arrived at the 200 MWs threshold after reviewing Attachment 1, Event “Loss of firm load for &gt;= 15 Minutes”. We agree with the SDT’s intent to exclude these small firm load losses from reporting through EOP-004-2. Another approach we could support is that taken by the Project 2008-06 SDT with respect to Distribution Provider Facilities:4.2.2 Distribution Provider: One or more of the Systems or programs designed, installed, and operated for the protection or restoration of the BES:</p>

Organization	Yes or No	Question 2 Comment
		<p><b>The SDT has discussed this very issue and would like to point out that the Threshold for Reporting limits are the same as in the enforceable Reliability Standard, EOP-004-1. The SDT believes that small entities (200mw or less) would not be applicable to this event. The SDT has attempted to place these types of limits to reduce small entities from having these applicable reporting requirements.</b></p> <ul style="list-style-type: none"> <li>o A UFLS or UVLS System that is part of a Load shedding program required by a NERC or Regional Reliability Standard and that performs automatic Load shedding under a common control system, without human operator initiation, of 300 MW or more</li> <li>o A Special Protection System or Remedial Action Scheme where the Special Protection System or Remedial Action Scheme is required by a NERC or Regional Reliability Standard</li> <li>o A Protection System that applies to Transmission where the Protection System is required by a NERC or Regional Reliability Standard</li> <li>o Each Cranking Path and group of Elements meeting the initial switching requirements from a Blackstart Resource up to and including the first interconnection point of the starting station service of the next generation unit(s) to be started. We're not advocating this exact language but rather the approach that narrows the focus to what is truly impactful to reliability while minimizing costs and needless compliance burden. One last issue we have is with the language in Attachment 1, Event "BES Emergency resulting in automatic firm load shedding." Under "Entity with Reporting Responsibility", you state that the DP or TOP that "implements" automatic load shedding of &gt;= 100 MWs must report (Also please review the CIP threshold of 300 MWs as this may be a more appropriate threshold). We believe rather than specifying a DP or TOP report, it would be appropriate for the UFLS Program Owner to file the report per EOP-004-2. In our situation we have DPs that own UFLS relays that are part of the TOP's program and this could lead to confusing reporting requirements. Also we don't believe that an entity can "Implement" "Automatic" load shedding but this is purely a semantic issue.</li> </ul> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds: The SDT removed all language under "Entity with Reporting Responsibility" with</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected</p>

Organization	Yes or No	Question 2 Comment
		<p>intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
United Illuminating Company	Yes	<p>The phrasing of the event labeled as Event Damage or Destruction of a Facility may be improved in the Threshold for Reporting Column. Suggest the introduction sentence for this event should be phrased as Where the Damage or Destruction of a Facility: etc. The rationale for the change is that as written it is unclear if the list that follows is meant to modify the word Facilities or the overall introductory sentence. The confusion being caused by the word That. What is important to be reported is if a Facility is damaged and then an IROL is affected it should be reported, not that if a Facility is comprising an IROL Facility is damaged but there is no impact on the IROL.</p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p>



Organization	Yes or No	Question 2 Comment
		<p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p><b>Second, the top of each table is the phrase Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event. This creates the requirement that the actual form is required to be transmitted to parties other than NERC/DOE. The suggested revision is Submit EOP-004 Attachment 2 or DOE-OE-417 report to NERC and/or DOE, and complete notification to other organizations identified pursuant to Requirement R1 Part 1.2 within one hour etc..</b></p> <p><b>The SDT has revised Attachment 2 heading to read “Use this form to report events. The Electric Reliability Organization will accept the DOE OE-417 form in lieu of this</b></p>

Organization	Yes or No	Question 2 Comment
		<p>form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> voice: 404-446-9780.” Based on industry comments.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Ingleside Cogeneration LP	Yes	<p>Ingleside Cogeneration LP agrees with the removal of nearly all one hour reporting requirements. In our view there must be a valid contribution expected of the recipients of any reporting that takes place this early in the process. Any non-essential communications will impede the progress of the front-line personnel attempting to resolve the issue at hand - which has to be the priority. Secondly, there is a risk that early reporting may include some speculation of the cause, which may be found to be incorrect as more information becomes available. Recipients must temper their reactions to account for this uncertainty. In fact, Ingleside Cogeneration LP recommends that the single remaining one-hour reporting scenario be eliminated. It essentially defers the reporting of a cyber security incident to CIP-008 anyways, and may even lead to a multiple violation of both Standards if exceeded.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT agrees and has removed the one-hour reporting requirement based on comments received.</b></p>		
Springfield Utility Board	Yes	<p>o Spell out Requirement 1, rather than “parties per R1” in NOTE. o On page 44, “Examples of such events include” should say, “include, but are not limited to”. o SUB appreciates clarification regarding events, particularly the discussion regarding “sabotage”, and recommends listing and defining “Event” in Definitions and Terms Used in NERC Standards.</p> <p><b>The SDT has stated in our “Consideration of Issues and Directives – March 15, 2012” that was posted with the last posting stated:</b></p> <p><b>The SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the definition. Attachment 1 is the de facto definition of “event.” The SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p> <p><b>The SDT has discussed this with FERC Staff and we agree that sabotage could be a state of mind and therefore the real issue was there an event or not.</b></p> <p>o The Guideline and Technical Basis provides clarity, and SUB agrees with the removal of “NERC Guideline: Threat and Incident Reporting”.</p> <p>o In the flow chart on page 9 there are parallel paths going from “Refer to Ops Plan for Reporting” to the ‘Report Event to ERO, Reliability Coordinator’ via both the Yes and No response. It seems like the yes/no decision should follow after “Refer to Ops Plan” for communication to law enforcement.</p> <p><b>The SDT has offered the flowchart as an example of how an entity could handle the notification to law enforcement agencies. There is no requirement to follow the flowchart. Entities are free to develop their own procedures based upon their needs to report.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
PPL Electric Utilities	Yes	<p>PPL EU thanks the SDT for the changes made in this latest proposal. We feel our prior comments were addressed. Regarding the event 'Transmission Loss': For your consideration, please consider adding a footnote to the event ‘Transmission Loss’ such that weather events do not need to be reported. Also please consider including 'operation contrary to design' in the threshold language. E.g. consistent with the</p>

Organization	Yes or No	Question 2 Comment
		NERC Event Analysis table, the threshold would be, 'Unintentional loss, contrary to design, of three or more BES Transmission Facilities.'
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing)."</b></p>		
Tacoma Power	Yes	Tacoma Power supports the revisions. It appears that all agencies and entities are willing to support the use of the DOE Form OE-417 as the initial notification form (although EOP-004 does include their own reporting form as an attachment to the Standard). Tacoma is already using the OE-417 and distributing it to all applicable Entities and Agencies.
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Seattle City Light	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<p><b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b></p>		
MEAG Power	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<p><b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b></p>		
Public Utility District No. 1 of Snohomish County		This is an excellent improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.

Organization	Yes or No	Question 2 Comment
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Imperial Irrigation District (IID)	Yes	
Colorado Springs Utilities	Yes	
Arizona Public Service Company	Yes	
Utility Services	Yes	
Dynergy Inc.	Yes	
Manitoba Hydro	Yes	
City of Austin dba Austin Energy	Yes	
Entergy	Yes	
Pepco Holdings Inc	Yes	
Independent Electricity System Operator	Yes	
Cowlitz County PUD	Yes	
Edison Mission Marketing & Trading, Inc.	Yes	
Exelon Corporation and its affiliates	Yes	

Organization	Yes or No	Question 2 Comment
ERCOT	Yes	
Oncor Electric Delivery	Yes	

3. The SDT has proposed a new Section 812 to be incorporated into the NERC Rules of Procedure. Do you agree with the proposed addition? If not, please explain in the comment area below.

**Summary Consideration:** The DSR SDT proposed a revision to the NERC Rules of Procedure (Section 812). The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.

Organization	Yes or No	Question 3 Comment
Northeast Power Coordinating Council	No	The proposed new section does not contain specifics of the proposed system nor the interfacing outside of the system to support the report collecting.
<p><b>Response:</b> The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</p>		
SPP Standards Review Group	No	We have two concerns about the proposed change to the RoP. One, we have concerns that our information and data will be circulated to an as yet undetermined audience which appears to be solely under NERC’s control. Secondly, there isn’t sufficient detail in the clearinghouse concept to support comments at this time.
<p><b>Response:</b> The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</p>		
ISO/RTO Standards Review Committee	No	The SRC offers comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see the latter part of the SRC’s response to Question 4 below for an SRC proposed alternative approach: The SRC is unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the

Organization	Yes or No	Question 3 Comment
		proposal when the proposed addition is posted.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
ACES Power Marketing Standards Collaborators	No	<p>(1) It is not clear to us what is the driving the need for the Rules of Procedure proposal. NERC is already collecting event and disturbance reports without memorializing the change in the Rules of Procedure. (2) The language potentially conflicts with other subsections in Section 800. For instance, the proposal says that the system will apply to collect report forms “for this section”. This section would refer to Section 800. Section 800 covers NERC alerts and GADS. Electronic GADS (eGADS) already has been established to collect GADS data? Will this section cause NERC to have to incorporate eGADS into this report collection system? Incorporating NERC Alerts is also problematic because when reports are required as a result of a NERC alert, the report must be submitted through the NERC Alert system.(3) The statement that “a system to collect report forms as established for this section or standard” causes additional confusion regarding to which standards it applies. Does it only apply to this new EOP-004-2 or to all standards? If it applies to all standards, does this create a potential issue for CIP-008-3 R1.3 which requires reporting to the ES-ISAC and not this clearinghouse?</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Seattle City Light	No	Seattle City Light follows MEAG and believes this type of activity and process is better suited to NAESBE than it is to NERC Compliance.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Hydro One	No	The proposed new section does not contain specifics of the proposed system nor the



Organization	Yes or No	Question 3 Comment
		interfacing outside of the system to support the report collecting.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
CenterPoint Energy	No	<p>CenterPoint Energy does not agree with the SDT’s proposed section 812. The proposal for NERC to establish a system that will “...forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations.” is redundant with the draft Standard. Responsible entities are already required to report applicable events to NERC, applicable regional entities, registered entities, and appropriate governmental, law enforcement, and regulatory agencies. CenterPoint Energy believes if the SDT’s intent is to require NERC to distribute these system event reports, then EOP-004-2 should be revised to require responsible entities to only report the event to NERC. As far as distribution to appropriate NERC departments, CenterPoint Energy believes that is an internal NERC matter and does not need to be included in the Rules of Procedure.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Arkansas Electric Cooperative Corporation	No	AECC supports the comments submitted by ACES Power Marketing.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
National Rural Electric Cooperative Association (NRECA)	No	<p>NRECA is concerned with the drafting team's proposal to add a new Section 812 to the NERC ROP. NRECA does not see the need for the drafting team to make such a proposal as it relates to the new EOP-004 that the drafting team is working on. The</p>

Organization	Yes or No	Question 3 Comment
		<p>requirements in the draft standard clearly require what is necessary for this Event Reporting standard. NRECA requests that the drafting team withdraw its proposed ROP Section 812 from consideration. The proposed language is unclear to the point of not being able to understand who is being required to do what. Further, the language is styled in more of a proposal, and not in the style of what would appropriately be included in the NERC ROP. Finally, the SDT has not adequately supported the need for such a modification to the NERC ROP. Without that support, NRECA is not able to agree with the need for this addition to the ROP. Again, NRECA requests that the drafting team withdraw its proposed ROP Section 812 from consideration.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Occidental Power Services, Inc.	No	<p>This section should reference the confidentiality requirements in the ROP and should have a statement about the system for collection and dissemination of disturbance reports being “subject to the confidentiality requirements of the NERC ROP.”</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Pepco Holdings Inc	No	<p>This could create confusion. This new ROP section states that “... the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary.” Standard Section R1.2 states “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.” If NERC is going to be the “clearinghouse” forwarding reports to the RE and DOE, does that mean that</p>

Organization	Yes or No	Question 3 Comment
		<p>the reporting entity only needs to make a single submission to NERC for distribution? If the reporting entity is required to make all notifications, per R1.2, what is the purpose of NERC's duplication of sending out reports? It would be very helpful to the reporting entities if R1.2 was revised to state that NERC would forward the event form to the RE and DOE and the reporting entity would only be responsible for providing notice verbally to its associated BA, TOP, RC, etc. as appropriate and for notifying appropriate law enforcement as required.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Independent Electricity System Operator	No	<p>We are unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the proposal when the proposed addition is posted.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
MidAmerican Energy	No	<p>See the NSRF comments. The NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC's crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Public Utility District No. 1 of Snohomish County	No	<p>This type of activity and process is better suited to NAESBE than it is to NERC Compliance.</p>

Organization	Yes or No	Question 3 Comment
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Illinois Municipal Electric Agency	No	Illinois Municipal Electric Agency supports comments submitted by ATC.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Americian Transmission Company, LLC	No	ATC believes that the NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC’s crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Ameren	No	If the SDT keeps new Section 812 we suggest to the SDT a wording change for the second sentence, underlined: “Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC department for review. After review, the report will be forwarded to the applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary.”
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
We Energies	No	Section 812 refers to the section as a standard and as a Procedure. That is not correct. Section 812 reads to me as if NERC (the system) will be forwarding everything

Organization	Yes or No	Question 3 Comment
		specified anywhere in RoP 800.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Exelon Corporation and its affiliates	No	<p>While we don't have any immediate objection to revising the Rules of Procedures (ROP) to allow for report collecting under Section 800 relative to the EOP-004 standard, the proposed language is unclear and confusing. Please consider the following revision:"812. NERC Reporting Clearinghouse NERC will establish a system to collect reporting forms as required for Section 800 or per FERC approved standards from any Registered Entities. NERC shall distribute the reports to the appropriate governmental, law enforcement, regulatory agencies as required per Section 800 or the applicable standard."Further, NERC should post ROP revisions along with a discussion justifying the revision for industry comment specific to the ROP. There may be significant implications to this revision beyond the efforts relative to EOP-004.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Tacoma Power	No	<p>Tacoma Power disagrees with the requirement to perform annual testing of each communication plan. We do not see any added value in performing annual testing of each communication plan. There are already other Standard requirements to performing routine testing of communications equipment and emergency communications with other agencies.The "proof of compliance" to the Standard should be in the documentation of the reports filed for any qualifying event, within the specified timelines and logs or phone records that it was communicated per each specified communication plan.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		

Organization	Yes or No	Question 3 Comment
Seattle City Light	No	Seattle City Light follows MEAG and believes this type of activity and process is better suited to NAESBE than it is to NERC Compliance.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
MEAG Power	No	This type of activity and process is better suited to NAESBE than it is to NERC Compliance.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
ERCOT	No	ERCOT has joined the IRC comments on this project.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Idaho Power Co.	No	No opinion
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
MISO	No	MISO agrees with and adopts the Comments of the IRC on this issue.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Brazos Electric Power Cooperative	No	Please see the comments submitted by ACES Power Marketing.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports</b>		

Organization	Yes or No	Question 3 Comment
<b>to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Kansas City Power & Light	No	Rules stipulating the extent of how reported information will be treated by NERC is an important consideration, however, the proposed section 812 proposes to provide reports to other governmental agencies and regulatory bodies beyond that of NERC and FERC. NERC should be treating the event information reported to NERC as confidential and should not take it upon itself to distribute such information beyond the boundaries of the national interest at NERC and FERC.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Dominion	Yes	While Dominion supports this addition, we suggest adding to the sentence “NERC will establish a system to collect report forms as established for this section or reliability standard.....”
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
MRO NSRF	Yes	ATC believes that the NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC’s crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration is encouraged by NERC’s willingness to act as central data gathering point for event information. However, we see this only as a starting point.

Organization	Yes or No	Question 3 Comment
		There are still multiple internal and external reporting demands that are similar to those captured in EOP-004-2 - examples include the DOE, RAPA (misoperations), EAWG (events analysis), and ES-ISAC (cyber security). Although we appreciate the difference in reporting needs expressed by each of these organizations, there are very powerful reporting applications available which capture a basic set of data and publish them in multiple desirable formats. We ask that NERC spearhead this initiative - as it is a natural part of the ERO function.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
American Electric Power	Yes	While we have no objections at this point, we would like specific details on what our obligations would be as a result of these changes. For example, would the clearinghouse tool provide verifications that the report(s) had been received as well as forwarded? In addition, if DOE OE-417 is the form being submitted, would the NERC Reporting Clearinghouse forward that report to the DOE?
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Springfield Utility Board	Yes	o SUB supports the new Section 812 being incorporated into the NERC ROP. This addition provides clarity for what is required by whom and takes away any possible ambiguity.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
FirstEnergy Corp	Yes	FE agrees but asks that the defined term “registered entities” in the second sentence be capitalized.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports</b>		



Organization	Yes or No	Question 3 Comment
<b>to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
GTC	Yes	With the exception of the RC and company personnel, it appears this proposed section captures the same reporting obligations and to the same entities via R1.2. Recommend adjustments to R1.2 such that reportable events are submitted to NERC, RC, and company personnel.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Central Lincoln	Yes	Thank you for minimizing the number of necessary reports.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Xcel Energy		We believe such a tool would be useful, however we are indifferent as to if it is required to be established by the Rules of Procedure.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
ISO New England Inc		We unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the proposal when the proposed addition is posted.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Indiana Municipal Power Agency		no comment

Organization	Yes or No	Question 3 Comment
Los Angeles Department of Water and Power		LADWP does not have a comment on this question at this time
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
DECo	Yes	
Duke Energy	Yes	
Luminant	Yes	
Bonneville Power Administration	Yes	
Imperial Irrigation District (IID)	Yes	
Florida Municipal Power Agency	Yes	
LG&E and KU Services	Yes	
PPL Corporation NERC Registered Affiliates	Yes	
PNGC Comment Group	Yes	
Colorado Springs Utilities	Yes	
Arizona Public Service Company	Yes	

Organization	Yes or No	Question 3 Comment
Southern Company Services	Yes	
Utility Services	Yes	
Georgia System Operations Corporation	Yes	
Manitoba Hydro	Yes	
Clark Public Utilities	Yes	
New York Power Authority	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Orange and Rockland Utilities, Inc.	Yes	
Farmington Electric Utility System	Yes	
Public Service Enterprise Group	Yes	
PPL Electric Utilities	Yes	
Cowlitz County PUD	Yes	
Edison Mission Marketing & Trading, Inc.	Yes	

Organization	Yes or No	Question 3 Comment
American Public Power Association	Yes	
Oncor Electric Delivery	Yes	
Deseret Power	Yes	

4. Do you have any other comment, not expressed in the questions above, for the SDT?

**Summary Consideration:** The DSR SDT received several suggestions for improvement to the standard. The DSR SDT has removed reporting of Cyber Security Incidents from EOP-004 and have asked the team developing CIP-008-5 to retain this reporting. Most of the language contained in the “Background” Section was moved to the “Guidelines and Technical Basis” Section. Minor language changes were made to the measures and the data retention section. Attachment 2 was revised to list events in the same order in which they appear in Attachment 1.

Organization	Yes or No	Question 4 Comment
Texas Reliability Entity		<p>(1) The ERO and Regional Entities should not be included in the Applicability of this standard. The only justification given for including them was they are required to comply with CIP-008. CIP-008 contains its own reporting requirements, and no additional reliability benefit is provided by including ERO and Regional Entities in EOP-004. Furthermore, stated NERC policy is to avoid writing requirements that apply to the ERO and Regional Entities, and we do not believe there is any sufficient reason to deviate from that policy in this standard.</p> <p><b>The SDT is revising the standard to not contain reporting for Cyber Security Incidences. Under the revisions, CIP-008-3 and successive versions will retain the reporting requirements. The Applicability section has been revised to address this situation.</b></p> <p>(2) Under Compliance, in section 1.1, all the words in “Compliance Enforcement Authority” should be capitalized.</p> <p><b>The SDT agrees and has adopted this suggestion.</b></p> <p>(3) Under Evidence Retention, it is not sufficient to retain only the “date change page” from prior versions of the Plan. It is not unduly burdensome for the entity to retain all prior versions of its “event reporting Operating Plan” since the last audit, and it should be required to do so. (What purpose is supposed to be served by</p>

Organization	Yes or No	Question 4 Comment
		<p>retaining only the “date change pages”?)</p> <p><b>The SDT has revised the standard to require the retention of previous versions, not just the date change page.</b></p> <p>(4) The title of part F, “Interpretations,” is incorrect on page 23. Should perhaps be “Associated Documents.”</p> <p><b>The SDT has revised Part F and it now contains the Guidelines and Technical Basis.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>ACES Power Marketing Standards Collaborators</p>		<p>(1) IC, TSP, TO, GO, and DP should be all removed from the applicability of the standard. Previous versions of the standard did not apply to them and we see no reason to expand applicability to them. IC and TSP are not even mentioned in any of the “Entity with Reporting Responsibility” sections. For the sections that do not mention specific entities, IC and TSP would have no responsibility for any of the events. The TO and GO are not operating entities so the reporting should not apply to them. DP was not included in any previous versions of CIP-001 or EOP-004. Any information (such as load) that was necessary regarding DPs was always gathered by the BA or TOP and included in their reports. There is no indication that this process was not working and, therefore, it should not be changed. Furthermore, including the DP potentially expands the standard outside of the Bulk Electric System which is contrary to recent statements that NERC Legal has made at the April 11 and 12, 2012 SC meeting. Their comments indicated the standards are written for the Bulk Electric System. What information does a DP have to report except load loss which can easily be reported by the BA or TOP?</p> <p><b>The SDT disagrees with some of your suggestions. As the standard is to report events associated with physical assets, it is incumbent for the asset owners to file the reports associated with any events. Thus DP, TO, and GO were added to the Applicability of this standard. Their perspectives on events can be useful in evaluating situational awareness and providing NERC with information on lessons learned. Further, this standard limits reporting to BES Elements except where</b></p>

Organization	Yes or No	Question 4 Comment
		<p>noted. This is consistent with NERC and SC Standard Process design. Where this standard had included other functional registrations associated with the inclusion of CIP-008; those registrations have been removed from the standard.</p> <p>(2) Measure M2 needs to clarify an attestation is an acceptable form of evidence if there are no events.</p> <p><b>Registered Entities must determine how to best demonstrate they have met the performance obligation of a requirement. The use of an attestation statement is already permitted and recognized with the NERC Compliance Program if that is the best means of demonstrating your performance under the requirement. Auditors will then assess whether or not an attestation meets the requirement in one's audit. Attestations cannot be specifically permitted for use.</b></p> <p>(3) The rationale box for R3 and R4 should be modified. It in essence states that updating the event reporting Operating Plan and testing it will assure that the BES remains secure. While these requirements might contribute to reliability, these two requirements collectively will not assure BES security and stability.</p> <p><b>The SDT has revised the rationale box language based upon the changes it has made to the requirements. It should be noted that upon acceptance of the standard, the language in the rationale boxes are removed from the standard.</b></p> <p>(4) We disagree with the VSLs for Requirement R2. While the VSLs associated with late reporting for a 24-hour reporting requirement include four VSLs, the one-hour reporting requirement only includes three VSLs. There seems to be no justification for this inconsistency. Four VSLs should be written for the one-hour reporting requirement.</p> <p><b>As the standard has been revised to remove the one-hour reporting provision, your suggestion is moot.</b></p> <p>(5) Reporting of reportable Cyber Security Incidents does not appear to be fully coordinated with version 5 of the CIP standards. For instance, EOP-004-2 R1, Part 1.2 requires a process for reporting events to external entities and CIP-008-5 Part 1.5</p>

Organization	Yes or No	Question 4 Comment
		<p>requires identifying external groups to which to communicate Reportable Cyber Security Incidents. Thus, it appears the Cyber Security Incident response plan in CIP-008-5 R1 and the event reporting Operating Plan in EOP-004-2 R1 will compel duplication of external reporting at least in the document of the Operating Plain and Reportable Cyber Security Incident response plan. This needs to be resolved.</p> <p><b>While the SDT had worked this through with the other standard team to resolve this concern; it is now irrelevant, as reporting of Cyber Security Incidences are no longer part of EOP-004-2.</b></p> <p>(6) In the effective date section of the implementation plan, the statement that the prior version of the standard remains in effect until the new version is accepted by all applicable regulatory authorities is not correct. In areas where regulatory approval is required, it will only remain in effect in the areas where the regulator has not approved it.</p> <p><b>The SDT finds that the two statements are making the same point; that the new standard does not become enforceable until all regulatory authorities have approved it.</b></p> <p>(7) On page 6 in the background section, the statement attributing RCIS reporting to the TOP standards is not accurate. There is no requirement in the TOP standards to report events across RCIS. In fact, the only mention of RCIS in the standards occurs in EOP-002-3 and COM-001-1.1.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p> <p>(8) On page 6 in the background section, the first sentence of the third paragraph is not completely aligned with the purpose statement of the standard. The statement in the background section indicates that the reliability objective “is to prevent outages which could lead to Cascading by effectively reporting events”. However, the purpose states that the goal is to improve reliability. We think it would make more sense for the reliability objective to match the purpose statement more closely.</p> <p><b>The SDT has revised the Background section to match the standard’s purpose</b></p>



Organization	Yes or No	Question 4 Comment
		<p><b>statement.</b></p> <p>(9) On page 7 in the first paragraph, “industry facility” should be changed to “Facility”.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Seattle City Light		<p>1) Seattle City Light follows MEAG and questions if these administrative activities better should be sent over to NAESB? R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB’s domain? R2, R3 &amp; R4: These are not appropriate for a Standard. If you don’t annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn’t need to pile on. Mike Moon and Jim Merlo have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.</p> <p><b>The SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need. While it may be appropriate to have NAESB to adopt this obligation at some in the future, the SDT was charged with addressing deficiencies at this time. The SDT has removed all references to filing reports to DOE from the earlier versions. Today’s only reference provides for NERC’s acceptance of the use of their form when it is appropriate.</b></p> <p>2) Seattle City Light finds that even though efforts were made to differentiate between sabotage vs. criminal damage, the difference still appears to be confusing. Sabotage clearly requires FBI notification, but criminal damage (i.e. copper theft, trespassing, equipment theft) is best handled by local law agencies. A key point on how to determine the difference is to always go with the evidence. If you have a hole in the fence and cut grounding wires, this would only require local law enforcement</p>

Organization	Yes or No	Question 4 Comment
		<p>notification. If there is a deliberate attack on a utility’s BES infrastructure for intent of sabotage and or terrorism--this is a FBI notification event. One area where a potential for confusion arises is with the term “intentional human action” in defining damage. Shooting insulators on a rural transmission tower is not generally sabotage, but removing bolts from the tower may well be. Seattle understands the difficulty in differentiating these two cases, for example, and supports the proposed Standard, but would encourage additional clarification in this one area.</p> <p><b>The SDT appreciates the concern you raise. The SDT decided early that trying to set a definition for sabotage across the continent would be impossible as there are many differing viewpoints; particularly within the law enforcement agencies. There was consensus that even if we were able to set a definition, it may be consistent or recognized by other agencies. Therefore, the SDT decided to set event types that warranted reporting. Entities best know who they have to report to and under what considerations those reports need to be submitted. This is basis for this standard. The SDT wanted to provide entities with the result that was necessary but not prescribe how to do it. This concept has been embraced throughout this project. We believe that entities can create a single or multiple contact lists that have the right people being notified when an event type occurs. The SDT has revised the language on “intentional human action” in Attachment 1 in an attempt to provide you the clarification you requested.</b></p>
<p><b>Response: Thank you for your comment.</b></p>		
Essential Power, LLC		<p>1. As this Standard does not deal with real-time reporting or analysis, and is simply considered an after the fact reporting process, I question the need for the Standard at all. This is a process that could be handled through a change to the Rules of Procedure rather than through a Standard. Developing this process as a Reliability Standard is, in my opinion, contrary to the shift toward Reliability-Based Standards Development.2. I do not believe that establishing a reporting requirement improves the reliability of the BES, as stated in the purpose statement. The reporting requirement, however, would improve situational awareness. I recommend the</p>

Organization	Yes or No	Question 4 Comment
		purpose statement be changed to reflect this, and included with the process in the NERC Rules of Procedure.
<p><b>Response: The SDT thanks you for your comment. The SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need. The vast majority of commenters support the Purpose statement as written.</b></p>		
Georgia System Operations Corporation		<p>a) Reporting most of these items ...  o Does not "provide for reliable operation of the BES"  o Does not include "requirements for the operation of existing BES facilities"  o Is not necessary to "provide for reliable operation of the BES"... and is therefore not in accordance with the statutory and regulatory definitions of a Reliability Standard. They should not be in a Reliability Standard. Most of this is an administrative activity to provide information for NERC to perform some mandated analysis.</p> <p><b>The SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need.</b></p> <p>b) A reportable Cyber Security Incident: Delete this item from the table. It is covered in another standard and does not need to be duplicated in another standard.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>c) Damage or destruction of a Facility: Entities MAY only need to slightly modify their existing CIP-001 Sabotage Reporting procedures from a compliance perspective of HAVING an Operating Plan but not from a perspective of complying with the Plan. A change from an entity reporting "sabotage" on "its" facilities (especially when the common understanding of CIP-001 is to report sabotage on facilities as "one might consider facilities in everyday discussions") to reporting "damage on its Facilities" (as defined in the Glossary) is a significant change. An operator does not know off the top of his head the definition of Facility or Element. He will not know for any particular electrical device whether or not reporting is required. Although the term is</p>

Organization	Yes or No	Question 4 Comment
		<p>useful for legal and regulatory needs, it is problematic for practical operational needs. This creates the need for a big change in guidance, training, and tools for an operator to know which pieces of equipment this applies to. There is the need to translate from NERC-ese to Operator-ese. Much more time is needed to implement. The third threshold ("Results from actual or suspected intentional human action") perpetuates the problem of knowing the human's intention. Also, what if the action was intended but the result was not intended? The third threshold is ambiguous and subject to interpretation. The original intent of this project was to get away from the problem of the term sabotage due to its ambiguity and subjectivity. This latest change reverses all of the work so far toward that original goal. Instead of the drafted language, change this item to reporting "Damage or destruction of a Facility and any involved human action" and use only the first two threshold criteria.</p> <p><b>The SDT has stated in our "Consideration of Issues and Directives – March 15, 2012" that was posted with the last posting stated:</b></p> <p><b>The SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of "event." The SDT considered the FERC directive to "further define sabotage" and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term "sabotage" is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</b></p> <p><b>The SDT has discussed this with FERC Staff and we agree that sabotage could be a</b></p>

Organization	Yes or No	Question 4 Comment
		<p>state of mind and therefore the real issue was there an event or not.</p> <p>The SDT also uses the NERC defined term of “Facility: A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</p> <p>d) Any physical threat that could impact the operability of a Facility: See comment above about the term "Facility" and the need for a much longer implementation time.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to</p>

Organization	Yes or No	Question 4 Comment
		<p><b>operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>e) Transmission loss: This item is very unclear. What is meant by "loss?" Above, it says to report damage or destruction of a Facility. This says to report the loss of 3 Facilities. Is the intent here to report when there are 3 or more Facilities that are unintentionally and concurrently out of service for longer than a certain threshold of time? The intent should not be to include equipment failure? Three is very arbitrary. An entity with a very large footprint with a very large number of electrical devices is highly likely to have 3 out of service at one time. An entity with very few electrical devices is less likely to have 3. Delete the word Transmission. It is somewhat redundant. A Facility is BES Element. I believe all BES Elements are Transmission Facilities. A Facility operates as a single "electrical device." What if more than 3 downstream electrical devices are all concurrently out of service due to the failure of one upstream device? Would that meet the criteria? A situation meeting the criteria will be difficult to detect. Need better operator tools, specific procedures for this, training, and more implementation time.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state"</b></p> <p><b>"Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing)."</b></p> <p>f) The implementation plan says current version stays in effect until accepted by ALL regulatory authorities but it also says that the new version takes effect 12 months after the BOT or the APPLICABLE authorities accept it. It is possible that ONE regulatory authority will not accept it for 13 months and both versions will be in</p>

Organization	Yes or No	Question 4 Comment
		<p>effect. It is also possible for ALL regulatory authorities to accept it at the same time, the current version to no longer be in effect, but the new version will not be in effect for 12 months.</p> <p><b>The SDT intends for this standard to not become enforceable until all regulatory authorities have approved it. The SDT will work with NERC and others to ensure a timely enforcement period without overlap.</b></p>
<p><b>Response: Thank you for your comment.</b></p>		
We Energies		<p>Applicability: Change Electric Reliability Organization to NERC or delete Regional Entity. The ERO is NERC and all the Regional Entities.R1.2: The ERO is NERC and all the REs. If I report to any one on the REs (only and not to NERC), I have reported to the ERO. Change ERO to NERC. M1 refers to R1.1 and R1.2 as Parts. It would be clearer to refer to them as requirements or sub-requirements.</p> <p><b>The SDT is limited to listing functional registrations in the Applicability section. The applicable entities are the ERO and Regional Entity, not NERC. The SDT notes that the Applicability section has nothing to do with the reporting obligations. The Applicability section denotes who has obligations within the standard to report. The Applicability section has been revised in accordance with comments received on who needs to report on event types.</b></p> <p>M2: Add a comma after "that the event was reported" and "supplemented by operator logs". It will be easier to read.</p> <p><b>The SDT has revised the requirement and associated language.</b></p> <p>R3: This should be clarified to state that no reporting will be done for the annual test, not just exclude the ERO.</p> <p><b>The SDT has revised the requirement.</b></p> <p>M4: An annual review will not be time stamped.</p> <p><b>The SDT has removed the time-stamp provision.</b></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>City of Austin dba Austin Energy</p>		<p>Austin Energy makes the following comments:</p> <p>(1) Comment on the Background section titled “A Reporting Process Solution - EOP-004”: This section includes the sentence, “Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state OR PROVINCIAL OR LOCAL level law enforcement agency.” (emphasis added) The corresponding flowchart includes a step, “Notification Protocol to State Agency Law Enforcement.” Austin Energy requests that the SDT update the flowchart to match the language of the associated paragraph and include “state or provincial or local” agencies.</p> <p><b>The SDT wishes to point out that the flowchart is an example only – it was not meant to show every permutation. The entity can choose to use the flowchart or develop one for their own use.</b></p> <p>(2) Comments on VSLs: Austin Energy recommends that the SDT amend the VSLs for R2 to include the "recognition of" events throughout. That is, update the R2 VSLs to state “... X hours after "recognizing" an event ...” in all locations where the phrase occurs.</p> <p><b>The DSR SDT believes the current language is sufficient as Table 1 clearly states that the reporting ‘clock’ starts after recognition of the event.</b></p> <p>(3) Austin Energy has a concern with the inclusion of the word "damage" to the phrase "damage or destruction of a Facility." We agree that any "destruction" of a facility that meets any of the three criteria be a reportable event. However, if the Standard is going to include "damage," some objective definition for "damage" (that sets a floor) ought to be included. Much like the copper theft issue, we do not see the benefit of reporting to NERC vandalism that does not rise to a certain threshold (e.g. someone who takes a pot shot at an insulator) unless the damage has some tangible impact on the reliability of the BES or is an act of an orchestrated sabotage (e.g.</p>



Organization	Yes or No	Question 4 Comment
		<p>removal of a bolt in a transmission structure).</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with</p>

Organization	Yes or No	Question 4 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>(4) Austin Energy voted to approve the revised Standard because it is an improvement over the existing Standard. In light of FERC's comments in Paragraph 81 of the Order approving the Find, Fix, Track and Report initiative, however, Austin Energy would propose that this Standard is the type of Standard that does not truly</p>

Organization	Yes or No	Question 4 Comment
		<p>enhance reliability of the BES and is, instead, an administrative activity. As such, we recommend that NERC consider whether EOP-004-2 ought to be retired.</p> <p><b>The SDT appreciates the suggestion; however, we note that a standard cannot be retired prior to its effective and enforcement dates. Further, the SDT has been charged with addressing deficiencies that are present in current standards which the industry has determined to be needed through approval of the SAR. If the P81 process should ultimately decide to retire this standard, then the process will have made that decision. The SDT cannot presume that the P81 effort will become effective.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Bonneville Power Administration		<p>BPA believes that the VSL should allow for amending the form after a NERC specified time period without penalty and suggests that a window of 48 hours be given to amend the form to make adjustments without needing to file a self report. Should the standard be revised to allow a time period for amending the form without having to file a self report, BPA would change its negative position to affirmative.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT would like to point that a window is not needed as the standard requires a report at a 24-hour time frame which provides information on what is known at the time. The standard does not require any follow up or update report. If the entity wishes to file a follow up report, it can do so on its own. A self report should only be needed if the 24-hour report was not filed.</b></p>		
CenterPoint Energy		<p>CenterPoint Energy proposes that the purpose be enhanced to reflect risk and response. For example, the purpose could read “To sustain and improve reliability of the Bulk Electric System by identifying common risks reported by Responsible Entities as a source of lessons learned.” In the Background section under Law Enforcement Reporting, “the” should be added in front of “Bulk Electric System”. Also under the Background section - “Present expectations of the industry under CIP-001-1a”, CenterPoint Energy is not aware of any current annual requirements for CIP-001 and suggests that this section be revised to reflect that fact. CenterPoint Energy strongly</p>

Organization	Yes or No	Question 4 Comment
		<p>believes that the Violation Severity Levels (VSL) should not be high or severe unless an Adverse Reliability Impact occurred. CenterPoint Energy is requesting that Requirement R2 be deleted and the phrase, "as a result of not implementing the plan/insufficient or untimely report, an Adverse Reliability Impact occurred" be added to the Requirement R1 VSL. Regarding the VSL for Requirement R4, the Violation Risk Factor should be "Lower" and read "the entity did not perform the annual test of the operating plan" as annual is to be defined by the entity or according to the CAN-0010.</p>
<p><b>Response: The SDT thanks you for your comment. The vast majority of commenters support the Purpose statement as written. The missing 'the' has been added to the background section under 'Law Enforcement Reporting.' 'Annual' has been changed to 'These'. VSLs refer to how closely the entity met the requirements of the standard; it is the VRF that measures impact to reliability. The DSR SDT believes use of the high and severe VSLs is appropriate. R4 has been deleted along with its VRF/VSLs.</b></p>		
Cowlitz County PUD		<p>Cowlitz is pleased with changes made to account for the difficulties small entities have in regard to reporting time frames. Although Cowlitz is confident that the current draft is manageable for small entities, we propose that the resulting reports this Standard will generate will contain many insignificant events from the event types "Damage or destruction of a Facility," and "Any physical threat that could impact the operability of a Facility." In particular, examples would be limited target practice on insulators, car-pole accidents, and accidental contact from tree trimming or construction activities.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of a Facility within its Reliability Coordinator Area,</b></p>

Organization	Yes or No	Question 4 Comment
		<p>Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human</p>

Organization	Yes or No	Question 4 Comment
		<p>action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>Cowlitz suggests that at least a <math>\geq 100</math> MW (200 MW would be better) and/or <math>\geq</math> N-2 impact threshold be established for these event types. Also, Cowlitz suggests the statement “results from actual or suspected intentional human action” be changed to “results from actual or suspected intentional human action to damage or destroy a Facility.” A human action may be intentional which can result in damage to a facility, but the intent may have been of good standing, and not directed at the Facility. For example, the intent may have been to legally harvest a tree, or move equipment under a line. Cowlitz believes the above proposed changes would benefit the ERO, both in reduction of nuisance reports and possible violations over minimal to no impact BES events.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</p>

Organization	Yes or No	Question 4 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Colorado Springs Utilities		<p>CSU is concerned with the word ‘damage’. We support any ‘destruction’ of a facility that meets any of the three criteria be a reportable issue, but ‘damage’, if it’s going to be included should have some objective definition that sets a baseline.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,”</b></p>		

Organization	Yes or No	Question 4 Comment
		<p>with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1)</p>



Organization	Yes or No	Question 4 Comment
		<p>the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
<p>Dominion</p>		<p>Dominion believes that the reporting of “Any physical threat that could impact the operability of a Facility4” may overwhelm the Reliability Coordinator staff with little to no value since the event may have already passed. This specific event uses the phrase “operability of a Facility” yet “operability” is not defined and is therefore ambiguous. We do support the reporting to law enforcement and the ERO but do not generally support reporting events that have passed to the Reliability Coordinator.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p>

Organization	Yes or No	Question 4 Comment
		<p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Attachment 2; section 4 Event Identification and Description: The type of events listed should match the events as they are exactly written in Attachment 1. As it is currently written, it leaves room for ambiguity.</p> <p><b>The SDT agrees and has adopted your suggestion.</b></p> <p>M3 - Dominion objects to having to provide additional supplemental evidence (i.e. operator logs), and the SDT maybe want to include a requirement for NERC to provide a confirmation that the report has been received.</p> <p><b>The SDT believes that you are referring to M2. We have added “which may be” prior to “supplemented by operator logs,” indicating that this is optional. The SDT has opted not to develop a requirement for the ERO to provide receipt confirmation of a report.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Entergy		<p>Entergy does not agree with the Time Horizon for R2. The rationale for R2 contains phrases related to situational awareness and keeping people/agencies aware of the “current situation.” However, this standard is related to after the fact event reporting, not real-time reporting via RCIS, as discussed on page 6 of the red-lined standard. Therefore the time horizon for R2 should indicate that this is an after the</p>

Organization	Yes or No	Question 4 Comment
		<p>fact requirement expected to be performed either in 1 hour or 24 hours after an event occurs, not in the operations assessment time frame. This change should also be made on page 15 of the redline in the Table of compliance elements for R2. Page 18 of the redline document contains a VSL for R2 which states that it will be considered a violation if the Responsible Entity submitted a report in the appropriate timeframe but failed to provide all of the required information. It has long been the practice to submit an initial report and provide additional information as it becomes available. On page 24 of the redlined document, this is included in the following “...and provide as much information as is available at the time of the notification to the ERO...” But the compliance elements table now imposes that if the entity fails to provide ALL required information at the time the initial report is required, the entity will be non compliant with the standard. This imposes an unreasonable burden to the Reliability Entity. This language should be removed. The compliance element table for R3 and R4 make it a high or severe violation to be late on either the annual test or the annual review of the Operating plan for communication. While Entergy supports that periodically verifying the information in the plan and having a test of the operating plan have value, it does not necessarily impose additional risk to the BES to have a plan that exceeds its testing or review period by two to three months. This is an administrative requirement and the failure to test or review should be a lower or moderate VSL, which would be consistent with the actual risk imposed by a late test or review. On page 24 of the redlined draft, there is a statement that says “In such cases, the affected Responsible Entity shall notify parties per Requirement R1 and provide as much information as if available at the time of the notification...” Since R1 is the requirement to have a plan, and R2 is the requirement to implement the plan for applicable events, it seems that the reference in this section should be to Requirement R2, not Requirement R1.</p>
<p><b>Response: The SDT thanks you for your comment. There is no longer a requirement for this ‘two-step’ reporting. The initial report is the only report an entity must make. The note at the top of Attachment 1 is to give entities the flexibility to make a quick ‘something big just happened, but I don’t know the extent’ phone call, but realistically the reporting time frame is 24 hours which should give ample time to make one written report using OE-417 or Attachment 2. You will also notice that the amount of</b></p>		

Organization	Yes or No	Question 4 Comment
<p>information you must provide is minimal – the idea is that this is a trigger for NERC or the Event Analysis process and they will contact you if further details are required.</p> <p>VSLs refer to how closely the entity met the requirements of the standard; it is the VRF that measures impact to reliability. The DSRSDT believes use of the high and severe VSLs is appropriate. Also, R4 has been deleted along with its VRF/VSLs.</p>		
ERCOT		<p>ERCOT has joined the IRC comments on this project and offers these additional comments. ERCOT supports the alternative approach submitted by the IRC. ERCOT requests that time horizons be added for each of the requirements as have been with other recent Reliability Standards projects. With regards to Attachment 1, ERCOT requests the following changes:</p> <ul style="list-style-type: none"> <li>o Modify “Generation loss” from “≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection” to “≥ 1,100 MW for entities in the ERCOT Interconnection” and “≥ 1,000 MW for entities in the Quebec Interconnection”. This is consistent with the DCS threshold and eliminates possible operator confusion since DCSs event are reported in the ERCOT interconnection at 80% of single largest contingency which equates to 1100 MW.</li> </ul> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b>≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p><b>The NERC SPM does allow TRE to apply for a variance if they have special concerns that GOPs should submit a report to the ERO.</b></p>

Organization	Yes or No	Question 4 Comment
		<p>o Modify “Transmission loss” from “Unintentional loss of three or more Transmission Facilities (excluding successful automatic reclosing)” to “Inconsequential loss of three or more Transmission Facilities not part of a single rated transmission path (excluding successful automatic reclosing).” If a single line is comprised of 3 or more sections, this should not be part of what is reported here as it is intended to be when you have a single event trip of 3 or more transmission facilities that is not part of its intended design.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p><b>The NERC SPM does allow TRE to apply for a variance if they have special concerns that GOPs should submit a report to the ERO.</b></p> <p>o ERCOT requests review of footnote 1. The footnote does not seem appropriate in including an example of a control center as the definition of a BES facility does not include control centers.</p> <p><b>The SDT removed all foot notes within Attachment based on comments received.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
FirstEnergy Corp		<p>FE supports the standard and has the following additional comments and suggestions:1. Guideline/Technical Basis Section - FE requests the SDT add specific guidance for each requirement. Much of the information in this section is either included, or should be included in the Background section of the standard. One example of guidance that would help is for Requirement R3 on how an entity could</p>

Organization	Yes or No	Question 4 Comment
		<p>perform the annual test. The comment form for this posting has the following paragraph on pg. 2 which could be used as guidance for R3: “the annual test will include verification that communication information contained in the Operating Plan is correct. As an example, the annual update of the Operating Plan could include calling “others as defined in the Responsibility Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator.”<sup>2</sup>. With regard to the statement in the comment form (pg 2 paragraph 7)“Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator.”, requirement R3 only includes the ERO as an entity and should also include the Reliability Coordinator.</p> <p>3. The measure M3 says that an entity can use an actual event as a test to meet R3. Does this mean just 1 actual event will meet R3, or is the intent that all possible events per 1.2 are tested? Would like some clarity on this measure.</p>
<p><b>Response: The SDT thanks you for your comment. The requirements have been revised and these revisions along with the ‘Rationale’ boxes should provide the clarity you seek.</b></p>		
<p>Indiana Municipal Power Agency</p>		<p>For 1.2 under R1, is the SDT leaving it up to the registered entities do decide which organizations will be contacted for each event listed in attachment 1 or do all of those organization need to be contacted for each event listed in attachment 1? The requirement needs to clearly communicate this clarification and be independent of the rationale language. Auditors will go by the requirement and not the rationale for the requirement. For 1.1 under R1, does each event need its own process of recognition or can one process be used to cover all the applicable events? The requirement needs to clearly communicate this clarification and be independent of the rationale language. Auditors will go by the requirement and not the rationale for the requirement. For 1.2 under R1, company personnel is used as an example but in the rationale for R1, the third line uses operating personnel. IMPA recommends</p>

Organization	Yes or No	Question 4 Comment
		changing the example in 1.2 to operating personnel which is used in the current version of CIP-001.
<p><b>Response: The SDT thanks you for your comment. The SDT does not believe that it has the ability (or desire) to programmatically prescribe whether entities have a single or multiple contact lists. Entities themselves know best who and under what conditions do reports need to be provided. Further, the industry in past comment periods, clearly indicated that they did not wish to have the SDT provide the “how.”</b></p>		
GTC		For R2, please clarify how an entity can demonstrate that no reportable events were experienced. GTC recommends an allowance for a letter of attestation within M2.
<p><b>Response: Thank you for your comment. Registered Entities must determine how to best demonstrate they have met the performance obligation of a requirement. The use of an attestation statement is already permitted and recognized with the NERC Compliance Program if that is the best means of demonstrating your performance under the requirement. Auditors will then assess whether or not an attestation meets the requirement in one's audit. Attestations cannot be specifically permitted for use.</b></p>		
Orange and Rockland Utilities, Inc.		Form EOP-004, Attachment 2: Event Reporting Form: Delete the Task words “or partial.” Delete the Task words “physical threat that could impact the operability of a Facility.” Make any changes to the VSL’s necessary to align them with the reviewed wording provided above.
Consolidated Edison Co. of NY, Inc.		Form EOP-004, Attachment 2: Event Reporting Form: Delete the Task words “or partial.” Delete the Task words “physical threat that could impact the operability of a Facility.” Make any changes to the VSL’s necessary to align them with the reviewed wording provided above.
<p><b>Response: The SDT thanks you for your comment. The SDT has updated Attachment 2 to reflect the events listed in Attachment 1.</b></p>		
NextEra Energy Inc		Given that Responsible Entities are already required by other Reliability Standards to communicate threats to reliability to their Reliability Coordinator (RC), NextEra does not believe that EOP-004-2 is a Reliability Standard that promotes the reliability of the bulk power system, as envisioned by Section 215 of the Federal Power Act.

Organization	Yes or No	Question 4 Comment
		<p>Because an RC reporting requirement is already covered in other Standards, EOP-004-2 essentially is a reporting out requirement to the Regional Reliability Organization (RRO). NextEra does not agree that the reporting of events to the RROs should be subject to fines under the Reliability Standard regulatory framework. The reporting to RROs, as required by EOP-004-2, while informative and helpful for lessons learned, etc., is not necessary to address an immediate threat to reliability. In addition, NextEra does not believe it would be constructive to fine Responsible Entities for failure to report to a RRO within a mandated deadline during times when these entities are attempting to address potential sabotage on their system. NextEra would, therefore, prefer that the EOP-004-2 Standards Drafting Team be disbanded, and instead that EOP-004-2's reporting requirements be folded in to the event analysis reporting requirements. Therefore, NextEra requests that the new Section 812 be revised to include EOP-004-2 as a data request for lessons learn or for informational purposes only, and, also, for EOP-004-2 project to be disbanded.</p>
<p><b>Response: The SDT thanks you for your comment. While the SDT appreciates your viewpoint, the SDT has been charged with addressing deficiencies identified in current standards. The SDT believes that the standard will provide NERC with the situational awareness it needs as well as providing the industry valuable information through lessons learned.</b></p>		
Illinois Municipal Electric Agency		Illinois Municipal Electric Agency supports comments submitted by Florida Municipal Power Agency.
<p><b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b></p>		
Florida Municipal Power Agency		<p>In R1, bullet, it is a bit ambiguous whether the list of organizations to be communicated with is an exhaustive list (i.e.) or a list of examples (e.g.). The list is preceded by an "i.e." which indicates the former, but includes an "or" which indicates the latter. We are interpreting this as meaning the list is exhaustive as separated by semi-colons, but that the last phrase separated by commas is a list of examples. Is this the correct interpretation?</p> <p><b>The SDT has made the required change concerning replacing "i.e." with "e.g."</b></p>



Organization	Yes or No	Question 4 Comment
		<p>The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., “Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements”) so that changes to the RoP do not necessitate changes to the standard.</p> <p><b>The language that you mention is part of the standard boilerplate and is included in all standards. The SDT has chosen to keep the language as is at this time.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Ingleside Cogeneration LP		<p>Ingleside Cogeneration LP strongly believes that LSEs that do not own BES assets should be excluded from the Applicability section of this standard.</p>
<p><b>Response: The SDT thanks you for your comment. The LSE obligation in this standard was tied to applicability in CIP-008 for cyber incident reporting. Reporting under CIP-008 is no longer part of EOP-004-2 so this applicability has been removed.</b></p>		
Los Angeles Department of Water and Power		<p>LADWP does not have any other comments at this time</p>
<p><b>Response: The SDT thanks you for your participation.</b></p>		
Manitoba Hydro		<p>Manitoba Hydro is voting negative on EOP-004-2 for the reasons identified in our response to Question 1. In addition, Manitoba Hydro has the following comments:(Background section) - The section has inconsistent references to EOP-004 (eg. EOP-004 and EOP-004-2 are used). Wording should be made consistent. (Background section) - The section references entities, and responsible entities. Suggest wording is made consistent and changed to Responsible Entities. (General comment) - References in the standard to ‘Part 1.2’ should be changed to R1.2 as it is unclear if Part 1.2 refers to, for example, R1.2 or part 1.2 ‘Evidence Retention’.</p>

Organization	Yes or No	Question 4 Comment
		(M4) -Please clarify what is meant by 'date change page'.
<p><b>Response: The SDT thanks you for your comment. The SDT appreciates the points you raise and we continually review the document to make sure the language is consistent and unambiguous.</b></p>		
Southern Company Services		<p>Move the Background Section (pages 4-9) to the Guideline and Technical Basis section. They are not needed in the main body of the standard.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p> <p>Each “Entity with Reporting Responsibility” in the one-hour reporting table (p. 17) should be explicitly listed in the table, not pointed to another variable location. The criterion for “Threshold for Reporting” in the one-hour reporting table (p. 17) should be explicitly listed in the table, not pointed to another variable location.</p> <p>Please specify the voltage base against which the +/- 10% voltage deviation on a Facility is to be measured in the twenty-four hour reporting table (p. 19).</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes .”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Oncor Electric Delivery		Oncor takes the position that the proposed objectives as prescribed in Project 2009-01 - Disturbance and Sabotage Reporting, is a “good” step forward. Currently, NERC

Organization	Yes or No	Question 4 Comment
		<p>reporting obligations related to disturbances occurs over multiple standards including CIP-001, EOP-004-1, TOP-007-0, CIP-008-3 and Event Analysis (EA). Oncor is especially pleased that the Event Analysis Working Group (EAWG) is actively working to find ways of streamlining the disturbance reporting process especially to agencies outside of NERC such as FERC, and state agencies. Oncor is in agreement that an addition to the NERC Rules of Procedure in section 800 to develop a Reporting Clearinghouse for disturbance events by the establishment of a system to collect report and then forward completed forms to various requesting agencies, is also a very positive step."</p>
<p><b>Response: The SDT thanks you for your comment. The SDT would like to point out that the EAP is a voluntary program where the entity analyzes an issue or system condition. EOP-004-2 is a Reporting Standard where an entity informs the ERO (and whoever else per Requirement R1) of a current event. This will give other the situational awareness that their system may be degraded. Please refer to the Southwest Outage Report for more situational awareness issues that failed.</b></p>		
Occidental Power Services, Inc.		<p>OPSI continues to believe that LSEs that do not own BES assets should be excluded from the Applicability section of this standard.</p> <p>It is disingenuous of both the SDT and FERC to promote an argument to support this inclusion such as that stated in Section 459 of Order 693 (and referred to by the SDT in their Consideration of Comments in the last posting). The fact is that no reportable disturbance can be caused by an "attack" on an LSE that does not own BES assets. The SDT has yet to point out such an event.</p>
<p><b>Response: The SDT thanks you for your comment. The LSE obligation in this standard was tied to applicability in CIP-008 for cyber incident reporting. Reporting under CIP-008 is no longer part of EOP-004-2 so this applicability has been removed. The SDT notes that LSEs will still be subject to reporting under CIP-008 until such time they are removed from that standard.</b></p>		
New York Power Authority		Please see comments submitted by NPCC Regional Standards Committee (RSC).
<p><b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b></p>		
MRO NSRF		R1 states: "Each Responsible Entity shall have an event reporting Operating Plan that

Organization	Yes or No	Question 4 Comment
		<p>includes:”The definition of Operating Plan is:”A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.” This appears to us to be too prescriptive and could be interpreted to require a series of documents to for reporting issues to NERC. We suggest the following wording: R1. Each Responsible Entity shall have document methodology(ies) or process(es) for: 1.1. Recognizing each of the applicable events listed in EOP-004 Attachment 1.1.2. Reporting each of the applicable events listed in EOP-004 Attachment 1 in accordance with the time framess specified in EOP-004 Attachment 1 to the Electric Reliability Organization. LES Comment: [R1] We are concerned by the significant amount of detail an entity would be required to contain within the Operating Plan as part of Requirement R1. Rather than specifying an entity must have a documented process for recognizing each of the events listed in EOP-004-2 Attachment 1, at a minimum, consider removing the term “process” in R1.1 and replacing with “guideline” to ensure operating personnel are not forced to adhere to a specific sequence of steps and still have the flexibility to exercise their own judgment. Section 5 of the standard (Background) should be moved to the Guideline and Technical Basis document. A background that long does not belong in the standard piece as it detracts from the intent of the standard itself.</p>
<p><b>Response: The SDT thanks you for your comment. The background and Guidelines and Technical Basis sections have been combined.</b></p>		
ReliabilityFirst		<p>ReliabilityFirst votes in the Affirmative for this standard because the standard further enhances reliability by clearing up confusion and ambiguity of reporting events which were previously reported under the EOP-004-1 and CIP-001-1 standards. Even though ReliabilityFirst votes in the Affirmative, we offer the following comments for consideration: 1. Requirement R1, Part 1.2a. ReliabilityFirst recommends further prescribing whom the Responsible Entity needs to communicate with. The phrase “...</p>

Organization	Yes or No	Question 4 Comment
		<p>and other organizations needed for the event type..." in Part 1.2 essentially leaves it up to the Responsible Entity to determine (include in their process) whom they should communicate each applicable event to. ReliabilityFirst recommends added a fourth column under Attachment 1, which lists whom the Responsible Entity is required to communicate with, for each applicable event. 2. VSL for Requirement R2a. Requirement R2 requires the Responsible Entity to "implement its event reporting Operating Plan" and does not require the entity to submit a report. For consistency with the requirement, ReliabilityFirst recommends modifying the VSLs to begin with the following type of language: "The Responsible Entity implemented its event reporting Operating Plan more than 24 hours but..." This recommendation is based on the FERC Guideline 3, VSL assignment should be consistent with the corresponding requirement and should not expand on, nor detract from, what is required in the requirement.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT believes that implementing your Operating Plan means that you report an event. Therefore the VSLs are entirely consistent with the requirement.</b></p>		
DECo		<p>Requirement R3 for annual test specifically states that ERO is not included during test. Implies that local law enforcement or state law enforcement will be included in test. Hard to coordinate with many Local organizations in our area.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the language in Requirement R3 and believes that the changes will address your suggestion.</b></p>		
Alliant Energy		<p>Section 5 of the standard (Background) should be moved to the Guideline and Technical Basis document. A background that long does not belong in the standard piece as it detracts from the intent of the standard itself.</p>
<p><b>Response: The SDT thanks you for your comment. The background and Guidelines and Technical Basis sections have been combined.</b></p>		

Organization	Yes or No	Question 4 Comment
MidAmerican Energy		See the NSRF comments.
<p><b>Response: The SDT thanks you for your participation. Please review the response to that commenter.</b></p>		
MEAG Power		<p>Should these administrative activities be sent over to NAESB? R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB’s domain? R2, R3 &amp; R4: These are not appropriate for a Standard. If you don’t annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn’t need to pile on. Mike Moon and Jim Merlo have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.</p>
Public Utility District No. 1 of Snohomish County		<p>SNPD suggest moving these administrative activities to NAESB. R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB’s domain? R2, R3 &amp; R4: These are not appropriate for a Standard. If you don’t annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn’t need to pile on. Gerry Cauley and Mike Moon have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.</p>
<p><b>Response: The SDT thanks you for your comment. SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need. While it may be appropriate to have NAESB to adopt this obligation at some in the future, the SDT was charged with addressing deficiencies at this time. The SDT has removed all references to filing reports to DOE from the earlier versions. Today’s only reference provides for NERC’s acceptance of the use of their form when it is appropriate.</b></p>		

Organization	Yes or No	Question 4 Comment
Springfield Utility Board		SUB appreciates the opportunity to provide comments. While Staff was concerned with the consolidation of CIP and non-CIP NERC Reliability Standards (as to how they'll be audited), the Project 2009-01 SDT has done an excellent job in providing clarification around identifying and reporting events, particularly related to the varying definitions of "sabotage".
<b>Response: The SDT thanks you for your support.</b>		
Tacoma Power		Tacoma Power disagrees with the requirement to perform annual testing of each communication plan. We do not see any added value in performing annual testing of each communication plan. There are already other Standard requirements to performing routine testing of communications equipment and emergency communications with other agencies. The "proof of compliance" to the Standard should be in the documentation of the reports filed for any qualifying event, within the specified timelines and logs or phone records that it was communicated per each specified communication plan. Tacoma Power has none at this time. Thank you for considering our comments.
<b>Response: The SDT thanks you for your comment. The SDT has revised Requirement R3 and we believe that our changes address your suggestion.</b>		
Exelon Corporation and its affiliates		<p>Thanks to the SDT. Significant progress was made in revising the proposed standard language. We appreciate the effort and have only a few remaining requests:</p> <ul style="list-style-type: none"> <li>o We understand that CIP-008 dictates the 1-hour reporting obligation for Cyber Security Incidents and this iteration of EOP-004 delineates the CIP-008 requirements. Please confirm that per the exemption language in the CIP standards (as consistent with the March 10, 2011 FERC Order (docket # RM06-22-014) nuclear generating units are not subject to this reporting requirement.</li> </ul> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2</b></p>

Organization	Yes or No	Question 4 Comment
		<p><b>will not contain a one-hour reporting requirement.</b></p> <p>o EOP-004 still lists “Generation Loss” as a 24 hour reporting criteria without any time threshold guidance for the generation loss. Exelon previously commented to the SDT (without the comment being addressed) that Generation Loss should provide some type of time threshold. If the 2000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? In considering clarification language, the SDT should review the BAL standards on the disturbance recovery period for appropriate timing for closeness of trips.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b><math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p>o The “physical threat that could impact” requirement remains vague and it’s not clear the relevance of such information to NERC or the Regions. If a train derailment occurred near a generation facility (as stated in the footnote), are we to expect that NERC is going to send out a lesson learned with suggested corrective actions to protect generators from that occurring? The value in that event reporting criteria seems low. The requirement should be removed.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated</b></p>



Organization	Yes or No	Question 4 Comment
		<p>based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>o The event concerning voltage deviation of +/- 10% does not specify which type of voltage. In response to this comment in the previous comment period, the SDT indicated that the entity could determine the type of voltage. It would be clearer to specify in the standard and avoid future interpretation at the audit level.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p>

Organization	Yes or No	Question 4 Comment
		<p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b>  <b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>o As requested previously, for nuclear facilities, EOP-004 reporting should be coordinated with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security or cyber event. Please contact the NRC about this project to ensure that required communication and reporting in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. Each nuclear generating site licensee must have an NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan (E-Plan). Exelon again asks that the proposed reporting process and flow chart be coordinated with the NRC to ensure it does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans. In the alternative, the EOP-004 language should include acceptance of NRC required reporting to meet the EOP-004 requirements.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b>  <b>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.”</b>  <b>As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</b></p>

Organization	Yes or No	Question 4 Comment
		<p>o The proposed standard notes that the text boxes will be moved to the Guideline and Technical Basis Section which we support. However, it's not clear whether all the information in the background section will remain part of the standard. If this section is to remain as proposed concerted revision is needed to ensure that the discussion language matches the requirement language. At present, it does not. For instance, the flow chart on page 9 indicates when to report to law enforcement while the requirements merely state that communications to law enforcement be addressed within the operating plan.</p> <p><b>The background sections will remain in the standard. The flowchart on Page 9 is an example only and may differ from your Operating Plan.</b></p> <p>o Exelon voted negative vote on this ballot due to the need for further clarification and reconciliation between NERC EOP-004 and the NRC.</p> <p><b>The SDT team does not believe that reporting under EOP-004 can in anyway 'conflicts' with any other reporting obligations that nuclear or any other type of GO/GOP may have. By allowing applicable entities to use the OE-417 form, the drafting team believes it has given industry reasonable accommodation to reduce duplicative reporting. The same is true for other agencies as well. If an entity submits to NERC the same that was submitted to the other regulatory agency, then this submission will be acceptable. Based on the historical frequency with which GO/GOPs report under the current EOP-004-1 the drafting team does not believe this places and inordinate burden on the applicable entities.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>Alberta Electric System Operator</p>		<p>The Alberta Electric System Operator will need to modify parts of this standard to fit the provincial model and current legislation when it develops the Alberta Reliability Standard.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		

Organization	Yes or No	Question 4 Comment
Puget Sound Energy, Inc.		<p>The effective date language in the Implementation Plan is inconsistent with the effective date language in the proposed standard.</p> <p><b>The SDT checked the language and found both to be identical.</b></p> <p>In addition, the statement of effective date in the Implementation Plan is ambiguous - will EOP-004-2 be effective in accordance with the first paragraph or when it is "assigned an effective date" as stated in the second paragraph?</p> <p><b>The second paragraph deals with EOP-004-1, the currently mandatory and enforceable standard.</b></p> <p>All requirements should be assigned a Lower Violation Risk Factor. Medium risk factors require direct impact on the Bulk Electric System and the language there regarding "instability, separation, or cascading failures" is present to distinguish the Medium risk factor from the High risk factor. Since all of the requirements address after-the-fact reporting, there can be no direct impact on the Bulk Electric System. In addition, if having an Operating Plan under Requirement R1 is a Lower risk factor, then it does not make sense that reviewing that Operating Plan annually under Requirement R4 has a higher risk factor.</p> <p><b>The SDT disagrees. Please review the VRF documentation that was posted with the standard for the analysis of the requirements.</b></p> <p>The shift away from "the distracting element of motivation", i.e., removing "Sabotage" from the equation, runs the risk of focusing solely on what happened, how to fix it, and waiting for the next event to occur. That speaks to a reactive approach rather than a proactive one. There is a concern with the removal of the FBI from the reporting mix. Basically, the new standard will involve reporting a suspicious event or attack to local law enforcement and leaving it up to them to decide on reporting to the FBI. Depending on their evaluation, an event which is significant for a responsible entity might not rise to the priority level of the local law enforcement agency for them to report it to the FBI. While this might reduce the reporting requirements a bit, it might do so to the responsible entity's detriment.</p>

Organization	Yes or No	Question 4 Comment
		<p>The Operating Plan developed by each responsible entity may indeed have certain event types reported directly to the FBI. It is up the entity to determine the appropriate notifications. Entities in Canada would not report anything to the FBI.</p> <p>In Attachment 2 - item 4, would it be possible for the boxes be either alpha-sorted or sorted by priority?</p> <p><b>The SDT has made changes to Attachment 2 to list the Events in order of their listing in Attachment 1.</b></p> <p>There is a disconnect between footnote 1 on page 18 (Don't report copper theft) and the Guideline section, which suggests reporting forced intrusion attempt at a substation.</p> <p><b>Forced Intrusion was removed from the Guidelines section. The SDT has deleted footnote 1 based on comments received from the industry, however, retained the concept in the event type "Physical threats to a Facility" as:</b></p> <p><b>"Do not report copper theft unless it degrades normal operation of a Facility."</b></p> <p>Also, in the section discussing the removal of sabotage, the Guideline mentions certain types of events that should be reported to NERC, DHS, FBI, etc., while that specificity with respect to entities has been removed from the reporting requirement.</p> <p><b>The SDT disagrees with your assessment on reporting. Entities know best to whom and what reporting obligations they have on the applicable event types. The SDT has learned that states vary in organization of their law enforcement agencies. As such it is impossible for the SDT to outline those obligations in a consistent and uniform manner. Entities can establish a single or multiple contact lists as needed for the different event types.</b></p>
<p><b>Response: The SDT thanks you for your comments.</b></p>		
Kansas City Power & Light		The flowchart states, "Notification Protocol to State Agency Law Enforcement".

Organization	Yes or No	Question 4 Comment
		<p>Please correct this to, “Notification to State, Provincial, or Local Law Enforcement”, to be consistent with the language in the background section part, “A Reporting Process Solution - EOP-004”.</p> <p>Evidence Retention - it is not clear what the phrase “prior 3 calendar years” represents in the third paragraph of this section regarding data retention for requirements and measures for R2, R3, R4 and M2, M3, M4 respectively. Please clarify what this means. Is that different than the meaning of “since the last audit for 3 calendar years” for R1 and M1?</p>
<p><b>Response: The SDT thanks you for your comment. The flowchart is an example only and was not meant to show every permutation. The evidence retention paragraph has been revised to reflect the ‘since last audit’ language.</b></p>		
United Illuminating Company		<p>The measures M3 and M4 require evidence to be dated and time stamped. The time stamp is excessive and provides no benefit. A dated document is sufficient. The measure M2 requires in addition to a record of the transmittal of the EOP-004 Attachment 2 form or DOE-417 form that an operator log or other operating documentation is provided. It is unclear why this supplemental evidence of operator logs is required. We are assuming that the additional operator logs or documentation is required to demonstrate that the communication was completed to organizations other than NERC and DOE of the event. If true then the measure should be clear on this topic. For communication to NERC and DOE use the EOP-004 Form or OE-417 form and retain the transmittal record. For communication to other organizations pursuant to R1 Part 1.2 evidence may include but not limited to, operator logs, transmittal record, attestations, or voice recordings.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has removed the time-stamp provision. The SDT agrees and adopts your suggestion.</b></p>		
New York Independent System Operator		<p>The NYISO is part of and supports comments submitted by NPCC Reliability Standards Committee and the IRC Standards Review Committee. However the NYISO would also like to comment on the following items: o NERC has been proposing the future</p>

Organization	Yes or No	Question 4 Comment
		<p>development of performance based standards, which is directly related to reliability performance. Requirement 2 of this standard is simply a reporting requirement. We believe that this does not fall into a category of a performance based standard. NERC has the ability to ask for reports on events through ROP provisions and now the new Event Analysis Process. It does not have to make it part of the compliance program. Some have indicated that need for timely reporting of cyber or sabotage events. The counter argument is that the requirement is reporting when confirmed which would delay any useful information to fend off a simultaneous threat. Also NERC has not provided any records of how previous timely (1 hour) reporting has mitigated reliability risks. o The NERC Event Analysis Process was recently approved by the NERC OC and is in place. This was the model program for reporting outside the compliance program that the industry was asking for. This should replace the need for EOP-004.o NERC has presented Risk Based Compliance Monitoring (RBCM) to the CCC, MRC, BOT and at Workshops. This involves audit teams monitoring an entities controls to ensure they have things in place to maintain compliance with reliability rules. The proposed EOP-004 has created requirements that are controls to requirement R2, which is to file a report on predefined incidents. The RBCM is being presented as the auditor will make determinations on the detail of the sampling for compliance based on the assessment of controls an entity has in place to maintain compliance. It is also noted that compliance will not be assessed against these controls. As the APS example for COM-002 is presented in the Workshop slides, the issue is that EOP-004 R1, R3 and R4 are controls for reporting; 1) have a plan, 2) test the plan, and 3) review the plan. While R2 is the only actionable requirement. The NYISO believes that all reporting requirements have been met by OE-417 and EAP reporting requirements and that EOP-004 has served its time. At a minimum, the NYISO would suggest that EOP-004 be simplified to just R2 (reporting requirement) and the other requirements be placed at the end of the RSAW to demonstrate a culture of compliance as presented by NERC.</p>
<p><b>Response: The SDT thanks you for your comment. Please review the responses to those commenters. The SDT appreciates your suggestion, however, most of your comment is beyond the scope of the SDT’s charge. The SDT would like to note your statement</b></p>		

Organization	Yes or No	Question 4 Comment
<p>on reporting requirements having been met by the OE-417 and EAP requirements. The SDT fails to see how NERC gains situational awareness and the opportunity to pass along lessons learned when the aforementioned reports are not forwarded to the appropriate ERO group. The SDT would also note that the ERO does not have access to the OE-417 filings unless they are provided and the EAP does not include reporting for some of the event types listed in Attachment 1. The SDT will forward your comment to appropriate officials for their consideration.</p>		
<p>Hydro One</p>		<p>The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring. - The performance based action to “implement its event reporting Operating Plan” on defined events, as required in R2, could be considered a valid requirement. However, the concern is that this requirement could be superseded by the NERC Events Analysis Process and existing OE-417 Reporting.- The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. However, controls should not be part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2.NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well-established process that has regulatory obligations. NERC enforcement of reporting is redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p> <p>The SDT appreciates your suggestion, however, most of your comment is beyond the scope of the SDT’s charge. The SDT would like to note your statement on reporting requirements having been met by the OE-417 and EAP requirements. This statement is not true for Canadian entities. The SDT fails to see how NERC gains situational awareness and the opportunity to pass along lessons learned when the aforementioned reports are not forwarded to the appropriate ERO group. The SDT would also note that the ERO does not have access to the OE-417 filings unless they are provided and the EAP does not include reporting for some of the event types listed in Attachment 1. The SDT will forward your comment to appropriate officials for their consideration.</p> <p>Form EOP-004, Attachment 2: Event Reporting Form: - Delete from the Task column</p>



Organization	Yes or No	Question 4 Comment
		<p>the words “or partial”.- Delete from the Task column the words “physical threat that could impact the operability of a Facility”.</p> <p><b>The SDT has proposed changes to the language within Attachment 2 which we believe corrects the point made.</b></p> <p>VSL’s may have to be revised to reflect revised wording. The standard as proposed is not supportive of Gerry Cauley’s performance based standard initiative</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b>  <b>Or</b>  <b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p>

Organization	Yes or No	Question 4 Comment
<b>Response: The SDT thanks you for your comment.</b>		
Northeast Power Coordinating Council		<p>The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring. a. The performance based action to “implement its event reporting Operating Plan” on defined events, as required in R2, could be considered a valid requirement. However, the concern is that this requirement could be superseded by the NERC Events Analysis Process and existing OE-417 Reporting. b. The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. However, controls should not be part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting is redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p> <p><b>The SDT appreciates your suggestion however; most of your comment is beyond the scope of the SDT’s charge. The SDT would like to note your statement on reporting requirements having been met by the OE-417 and EAP requirements. This statement is not true for Canadian entities. The SDT fails to see how NERC gains situational awareness and the opportunity to pass along lessons learned when the aforementioned reports are not forwarded to the appropriate ERO group. The SDT would also note that the ERO does not have access to the OE-417 filings unless they are provided and the EAP does not include reporting for some of the event types listed in Attachment 1. The SDT will forward your comment to appropriate officials for their consideration.</b></p> <p>Form EOP-004, Attachment 2: Event Reporting Form: Delete from the Task column the words “or partial”. Delete from the Task column the words “physical threat that</p>

Organization	Yes or No	Question 4 Comment
		<p>could impact the operability of a Facility”.</p> <p><b>The SDT has proposed changes to the language within Attachment 2 which we believe corrects the point made.</b></p> <p>VSL’s may have to be revised to reflect revised wording.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>American Public Power Association</p>		<p>The SDT needs to provide some relief for the small entities in regards to the VSL in the compliance section. APPA believes there should be no High or Severe VSLs for this standard. This is a reporting/documentation standard and does not affect BES reliability at all. It is APPA’s opinion that this standard should be removed from the mandatory and enforceable NERC Reliability Standards and turned over to a working group within the NERC technical committees. Timely reporting of this outage data is already mandatory under Section 13(b) of the Federal Energy Administration Act of 1974. There are already civil and criminal penalties for violation of that Act. This standard is a duplicative mandatory reporting requirement with multiple monetary penalties for US registered entities. If this standard is approved, NERC must address this duplication in their filing with FERC. This duplicative reporting and the differences in requirements between DOE-OE-417 and NERC EOP-004-2 require an analysis by FERC of the small entity impact as required by the Regulatory Flexibility of Act of 1980</p>
<p><b>Response: The SDT thanks you for your comment. VSLs refer to how closely the entity met the requirements of the standard; it is the VRF that measures impact to reliability. The SDT believes use of the high and severe VSLs is appropriate. The SDT believes that size is not the important criteria in determining an impact on reliability. The reporting thresholds are based on the BES. No entity, including small entities is required to report on equipment that is not categorized as BES, which should give small entities relief from reporting on non-impactive assets.</b></p>		
<p>Pepco Holdings Inc</p>		<p>The SDT's efforts have resulted in a very good draft.</p>

Organization	Yes or No	Question 4 Comment
<b>Response: The SDT thanks you for your support.</b>		
ISO/RTO Standards Review Committee		<p>The SRC offers some other comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see below for an SRC proposed alternative approach: The SRC does not agree with the MEDIUM VRF assigned to Requirement R4. R4 is a requirement to conduct an annual review of the Event Reporting Operating Plan mandated in Requirement R1. R1 however is assigned a VRF of LOWER. We are unable to rationalize why a subsequent review of a plan should have a higher reliability risk impact than the development of the plan itself. Hypothetically, if an entity doesn't develop a plan to begin with, then it will be assigned a LOWER VRF, and the entity will have no plan to review annually and hence it will not be deemed non-compliant with requirement R4. The entity can avoid being assessed violating a requirement with a MEDIUM VRF by not having the plan to begin with, for which the entity will be assessed violating a requirement with a LOWER VRF. We suggest changing the R4 VRF to LOWER.</p> <p><b>The SDT has revised the requirements and R4 has been deleted along with its VRF/VSL.</b></p> <p>The SRC requests that the SDT post the following Alternative Proposal for Industry comments as required by the Standards Process to obtain Industry consensus and as permitted by FERC: An equally effective alternative is to withdraw this standard and to make the contents of the SDT's posted standard a NERC Guideline.</p> <ol style="list-style-type: none"> <li>a. This alternative is more in line with new NERC and FERC proposals</li> <li>b. This alternative retains the reporting format</li> </ol> <p>Comments 1. The FERC Order 693 directives regarding "sabotage" have already been addressed by the SDT (i.e. the concept was found outside the scope of NERC standards)</p> <p>2. Current Industry actions already address the needs cited in the Order:</p>

Organization	Yes or No	Question 4 Comment
		<p>a. Approved Reporting Processes already exists i. The Operating Committee’s Event Analysis Process ii. Alert Reporting</p> <p>b. The Data already exists i. Reliability Coordinators Information System (which creates hundred if not thousands of “reports” per year) ii. The DOE’s OE 417 Report itself provides part of the FERC discussed data</p> <p>3. The proposed standard is not supportive of Gerry Cauley’s performance based standard initiative or of FERC’s offer to reduce procedural standards</p> <p>a. The proposed requirement is a process not an outcome i. The proposal is more focused on reporting and could divert the attention of reliability entities from addressing a situation to collecting data for a report</p> <p>b. The proposed “events” are subjective and if followed will create an unmanageable burden on NERC staff i. Reporting “damage” to facilities can be interpreted as anything from a dent in a generator to the total destruction of a transformer ii. The reporting requirements on all applicable entities will create more questions about differences between the reports of the various entities - rather than leading to conclusions about patterns among events that indicate a global threat iii. Reporting any “physical threat” is too vague and subjective iv. Reporting “damage to a facility that affects an IROL” is subjective and can be seen to require reporting of damage on every facility in an interconnected area.</p> <p>v. Reporting “Partial loss of monitoring” is a data quality issue that can be anything from the loss of a single data point to the loss of an entire SCADA system vi. Testing the filling out of a Report does not make it easier to fill out the report later (moreover the reporting is already done often enough -see 2.b.i)c. The proposed requirements will create a disincentive to improving current Reporting practices (the more an entity designs into its own system the more it will be expected to do and the more likely it will be penalized for failing to comply)i. Annual reviews of the reporting practices fall into the same category, why have a detailed process to review when a simple one will suffice?</p>

Organization	Yes or No	Question 4 Comment
		<p>4. The proposed standard does not provide a feedback loop to either the data suppliers or to potentially impacted functional entities a. If the “wide area” data analysis indicates a threat, there is no requirement to inform the impacted entities b. As a BES reliability issue there is no performance indicators or metrics to show the value of this standard i. The SRC recognizes that specific incidents cannot be identified but if this is to be a reliability standard some information must be provided. A Guideline could be designed to address this concern.</p> <p>5. The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring.</p> <p>a. The performance based action to report on defined events, as required in R2, could be considered a valid requirement. However we have concerns as noted in Bullet 3 above. The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. NERC is moving in the direction to assess entities’ controls, outside of the compliance enforcement arm. The industry is being informed that NERC Audit staff will conduct compliance audits based on the controls that the entity has implemented to ensure compliance. The SRC is interested in supporting this effort and making it successful. However, if this is the direction NERC is moving, we should not be making controls part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2.</p> <p>6. For FERC-jurisdictional entities, NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting would be redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT will bring this request to the attention of the SC for consideration as this request is beyond the scope of work identified in this project.</b></p>		
LG&E and KU Services		The Violation Severity Level for Requirement R2 should be revised to read “...hours

Organization	Yes or No	Question 4 Comment
		after recognizing an event requiring reporting..." This will make the language in the VSL consistent with the language in Attachment 1.
<b>Response: The SDT thanks you for your comment. The VSLs have been reviewed and revised based upon the revisions to the requirements.</b>		
SPP Standards Review Group		The VRF for R1 is Lower which is fine. The issue is that R4, which is the review of the plan contained in R1, has a Medium VRF. We recommend moving the VRF of R4 to Lower. We recommend deleting the phrase ‘...supplemented by operator logs or other operating documentation...’ as found in the first sentence of M2. A much clearer reference is made to operator logs and other operating documentation in the second sentence. The duplication is unnecessary. What will happen with the accompanying information contained in the Background section in the draft standard? Will it be moved to the Guideline and Technical Basis at the end of the standard as the information contained in the text boxes? This is valuable information and should not be lost.
<b>Response: The SDT thanks you for your comment. The SDT has revised the requirements and R4 has been deleted along with its VRF/VSL. The background has been moved to the Guidelines and Technical Basis section.</b>		
Utility Services		There are no other comments at this time.
<b>Response: The SDT thanks you for your participation.</b>		
Dynergy Inc.		Use of the term "Part x.x" throughout the Standard is somewhat confusing. I can't recall other Standards using that type of term. Suggest using the term "Requirement" instead.
<b>Response: The SDT thanks you for your comment. The standard has been rewritten and revised in accordance with your suggestion.</b>		
Central Lincoln		We agree with the comments provided by both PNGC and APPA.

Organization	Yes or No	Question 4 Comment
<p><b>Response: The SDT thanks you for your comment. Please review the responses to those commenters.</b></p>		
PNGC Comment Group		We appreciate the hard work of the SDT.
<p><b>Response: The SDT thanks you for your support.</b></p>		
PPL Corporation NERC Registered Affiliates		<p>We appreciate the inclusion of the Process Flowchart on Page 9 of the draft standard. We submit for your consideration, removing the line from the NO decision box to the 'Report Event to ERO, Reliability Coordinator' box. It seems if the event does not need reporting per the decision box, this line is not needed. The decision box on 'Report to Law Enforcement ?' does not have a Yes or No. Perhaps, this decision box is misplaced, or is it intended to occur always and not have a different path with different actions? I.e. should it be a process box? Thank you for your work on this standard.</p>
PPL Electric Utilities		<p>We appreciate the inclusion of the Process Flowchart on Page 9 of the draft standard. We submit for your consideration, removing the line from the NO decision box to the 'Report Event to ERO, Reliability Coordinator' box. It seems if the event does not need reporting per the decision box, this line is not needed. For clarity in needed actions, please consider using a decision box following flowcharting standards such as, a decision box containing a question with a Yes and a No path. The decision box on 'Report to Law Enforcement ?' does not have a Yes or No. Perhaps, this decision box is misplaced, or is it intended to occur always and not have a different path with different actions? I.e. should it be a process box? Thank you for your work on this standard.</p>
<p><b>Response: The SDT thanks you for your comment. The flowchart was provided as an example and guidance for entities to use if they so choose. Entities can elect to create their own flowchart based upon their needs.</b></p>		
Independent Electricity System Operator		We do not agree with the MEDIUM VRF assigned to Requirement R4. Re stipulates a requirement to conduct an annual review of the event reporting Operating Plan in



Organization	Yes or No	Question 4 Comment
		<p>Requirement R1, which itself is assigned a VRF of LOWER. We are unable to rationalize why a subsequent review of a plan should have a higher reliability risk impact than the development of the plan itself. Hypothetically, if an entity doesn't develop a plan to begin with, then it will be assigned a LOWER VRF, and the entity will have no plan to review annually and hence it will not be deemed non-compliant with requirement R4. The entity can avoid being assessed violating a requirement with a MEDIUM VRF by not having the plan to begin with, for which the entity will be assessed violating a requirement with a LOWER VRF. We suggest changing the R4 VRF to LOWER.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the requirements and R4 has been deleted along with its VRF/VSL.</b></p>		
SMUD & BANC		<p>We feel issues were addressed, but still have concern with 'damage'. We certainly support that any 'destruction' of a facility that meets any of the three criteria be a reportable issue. But 'damage', if it's going to be included should have some objective definition that sets a floor. Much like the copper theft issue, we don't see the benefit of reporting plain vandalism (gun-shot insulators results from actual or suspected intentional human action) to NERC unless the 'damage' has some tangible impact on the reliability of the system or are acts of an orchestrated sabotage (i.e. removal of bolt in a transmission structure).</p>
<p><b>Response: The SDT thanks you for comment. The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p>		

Organization	Yes or No	Question 4 Comment
		<p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state;</p> <p>Damage or destruction of its Facility that results from actual or suspected intentional human action.</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
ISO New England Inc		We requests that the SDT post the following Alternative Proposal for Industry

Organization	Yes or No	Question 4 Comment
		<p>comments as required by the Standards Process to obtain Industry consensus and as permitted by FERC: An equally effective alternative is to withdraw this standard and to make the contents of the SDT’s posted standard a NERC Guideline.a. This alternative is more in line with new NERC and FERC proposalsb. This alternative retains the reporting formatComments1. The FERC Order 693 directives regarding “sabotage” have already been addressed by the SDT (i.e. the concept was found outside the scope of NERC standards)2. Current Industry actions already address the needs cited in the Order:a. Approved Reporting Processes already existsi. The Operating Committee’s Event Analysis Processii. Alert Reporting b. The Data already existsi. Reliability Coordinators Information System (which creates hundred if not thousands of “reports” per year)ii. The DOE’s OE 417 Report itself provides part of the FERC discussed data3. The proposed standard is not supportive of Gerry Cauley’s performance based standard initiative or of FERC’s offer to reduce procedural standardsa. The proposed requirement is a process not an outcomei. The proposal is more focused on reporting and could divert the attention of reliability entities from addressing a situation to collecting data for a reportb. The proposed “events” are subjective and if followed will create an unmanageable burden on NERC staffi. Reporting “damage” to facilities can be interpreted as anything from a dent in a generator to the total destruction of a transformerii. The reporting requirements on all applicable entities will create more questions about differences between the reports of the various entities - rather than leading to conclusions about patterns among events that indicate a global threatiii. Reporting any “physical threat” is too vague and subjective iv. Reporting “damage to a facility that affects an IROL” is subjective and can be seen to require reporting of damage on every facility in an interconnected area.</p> <p>v. Reporting “Partial loss of monitoring” is a data quality issue that can be anything from the loss of a single data point to the loss of an entire SCADA system</p> <p>vi. Testing the filling out of a Report does not make it easier to fill out the report later (moreover the reporting is already done often enough -see 2.b.i)c. The proposed requirements will create a disincentive to improving current Reporting practices (the</p>

Organization	Yes or No	Question 4 Comment
		<p>more an entity designs into its own system the more it will be expected to do and the more likely it will be penalized for failing to comply)i. Annual reviews of the reporting practices fall into the same category, why have a detailed process to review when a simple one will suffice?4. The proposed standard does not provide a feedback loop to either the data suppliers or to potentially impacted functional entitiesa. If the “wide area” data analysis indicates a threat, there is no requirement to inform the impacted entitiesb. As a BES reliability issue there is no performance indicators or metrics to show the value of this standardi. We recognize that specific incidents cannot be identified but if this is to be a reliability standard some information must be provided. A Guideline could be designed to address this concern. 5. The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring. a. The performance based action to report on defined events, as required in R2, could be considered a valid requirement. However we have concerns as noted in Bullet 3 above.The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. NERC is moving in the direction to assess entities’ controls, outside of the compliance enforcement arm. The industry is being informed that NERC Audit staff will conduct compliance audits based on the controls that the entity has implemented to ensure compliance. We are interested in supporting this effort and making it successful. However, if this is the direction NERC is moving, we should not be making controls part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. 6. For FERC-jurisdictional entities, NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting would be redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT will bring this request to the attention of the SC for consideration as this request is beyond the scope of work identified in this project.</b></p>		
Brazos Electric Power		We thank the work of the SDT on this project. However, additional improvements

Organization	Yes or No	Question 4 Comment
Cooperative		should be made as described in the comments submitted by ACES Power Marketing.
<b>Response: The SDT thanks you for your comment. Please review the responses to that commenter.</b>		
FirstEnergy		<p>While FE voted affirmative on this draft, upon further review we request clarification be made in the next draft of the standard regarding the applicability of the Nuclear Generator Operator. Per FE's previous comments, nuclear generator operators already have specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(s)(xi). We had asked that the SDT contact the NRC about this project to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. In addition, EOP-004 must acknowledge that there may be NRC reporting forms that have the equivalent information contained in their Attachment 2. For what the NRC considers a Reportable Event, Nuclear plants are required to fill out NRC form 361 and/or form 366. We do not agree with the drafting team's response to ours and Exelon's comments that "The NRC does not fall under the jurisdiction of NERC and so therefore it is not within scope of this project." While the statement is correct, we believe that requirements should not conflict with or duplicate other regulatory requirements. We remain concerned that the standard with regard to Nuclear GOP applicability causes duplicative regulatory reporting with existing reporting requirements of the NRC. Therefore, we ask:1. That NERC and the drafting team please investigate these issues further and revise the standard to clarify the scope for nuclear GOPs, and2. For any reporting deemed in the scope for nuclear GOP after NERC's and the SDT's investigation per our request in #1 above, that the SDT consider the ability to utilize information from NRC reports as meeting the EOP-004-2 requirements similar to the allowance of using the DOE form as presently proposed.</p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: The SDT thanks you for your comment. The SDT team does not believe that reporting under EOP-004 can in anyway ‘conflicts’ with any other reporting obligations that nuclear or any other type of GO/GOP may have. By allowing applicable entities to use the OE-417 form, the drafting team believes it has given industry reasonable accommodation to reduce duplicative reporting. The same is true for other agencies as well. If an entity submits to NERC the same that was submitted to the other regulatory agency, then this submission will be acceptable. Based on the historical frequency with which GO/GOPs report under the current EOP-004-1 the drafting team does not believe this places and inordinate burden on the applicable entities.</b></p>		
<p>American Electric Power</p>		<p>While we do not necessarily disagree with modifying this standard, we do have serious concerns with the possibility that Form OE-417 form would not also be modified to match any changes made to this standard. To the degree they would be different, this would create unnecessary confusion and burden on operators.</p> <p><b>While we appreciate the point raised, the SDT does not have any authority with regard to the language contained within the DOE OE-417 form. The Department of Energy is responsible for the design and contents of the 417 form. As a part of the SDT’s work in this proposal, we met with and collaborated with the DOE staff responsible for the 417 form establish a common understanding of reportable events. We hope that if the DOE desires to make further changes, they will pass along information for consideration in a future NERC SAR.</b></p> <p>If CIP-008 is now out of scope within the requirements of this standard, the task “reportable Cyber Security Incident” should be removed from Attachment 2.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>Progress Energy</p>		<p>Within attachment 1 (Reportable Events) an exclusion is allowed for weather related threats. PGN recommends a more generic approach to include natural events such as forest fires, sink holes, etc. This would alleviate some reporting burdens in areas that</p>

Organization	Yes or No	Question 4 Comment
		are prone to these types of events.
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the language in accordance with your suggestion to “weather or natural disaster related threats”.</b></p>		
Xcel Energy		<p>Xcel Energy appreciates the work of the drafting team and believes the current draft is an improvement over the existing standard. However, we would like to see the comments provided here and above addressed prior to submitting an AFFIRMATIVE vote.1) Suggest enhancing the “Example of Reporting Process...” flowchart as follows: EVENT &gt; Refer to Ops Plan for Event Reporting &gt; Refer to Law Enforcement? &gt; Yes/No &gt; ....</p> <p><b>The SDT has provided the flowchart as an example and guidance for entities. Entities can choose to create their own version of the flowchart for use in their Operating Plan.</b></p> <p>2) Attachment 1 - in both the 1 hour and the 24 hour reporting they are qualified with “within x hours of recognition of the event”. Is this the intent, so that if an entity recognizes at some point after an event that the time clock starts?</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p><b>The SDT envisions when the entity is made aware of an applicable event contained in Attachment 1, that they would report the event within 24 hours. Any entity could enhance their Operating Plan to describe as much detail as they wanted to provide to their employees as they see fit.</b></p> <p>3) VSLs - R3 &amp; R4 “Severe” should remove the “OR...”, as this is redundant. Once an entity has exceeded the 3 calendar months, the Severe VSL is triggered.</p> <p><b>The SDT has revised the requirements and accordingly the VSLs.</b></p> <p>4) The Guideline and Technical Basis page 22 should be corrected to read “The</p>

Organization	Yes or No	Question 4 Comment
		<p>changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting.”</p> <p><b>Response: Thank you for the grammatical correction.</b></p> <p>5) Also in the following section of the Guideline and Technical Basis (page 23) the third bullet item should be qualified to exclude copper theft: Examples of such events include:</p> <ul style="list-style-type: none"> <li>o Bolts removed from transmission line structures</li> <li>o Detection of cyber intrusion that meets criteria of CIP-008-3 or its successor standard</li> <li>o Forced intrusion attempt at a substation (excluding copper theft)</li> <li>o Train derailment near a transmission right-of-way</li> <li>o Destruction of Bulk Electric System equipment</li> </ul> <p><b>Response: Thank you for the correction; however, as a result of other changes made to the standard, the SDT is proposing to remove the third bulleted item from this list.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Edison Mission Marketing & Trading, Inc.		No
Idaho Power Co.		No
Arizona Public Service Company		None

END OF REPORT



# Consideration of Comments

## Project 2009-01 Disturbance Sabotage and Reporting

The Project 2009-01 Drafting Team thanks all commenters who submitted comments on Draft 5 of EOP-004-2. The standard was posted for a 30-day public comment period from August 29, through September 27, 2012. Stakeholders were asked to provide feedback on the standard and associated documents through a special electronic comment form. There were 56 sets of comments, including comments from approximately 181 different people from approximately 125 companies, representing 9 of the 10 Industry Segments as shown in the table on the following pages.

All comments submitted may be reviewed in their original format on the standard's [project page](#).

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Mark Lauby, at 404-446-2560 or at [mark.lauby@nerc.net](mailto:mark.lauby@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

### Summary Consideration:

The Disturbance and Sabotage Reporting standard drafting team has opted to pursue a recirculation ballot for EOP-004-2 after making a few clarifications to the Guidelines and Technical Basis section to address stakeholder concerns raised during the second successive ballot:

- Distribution Providers – Some concerns were raised with respect to applicability of the standard to all Distribution Providers. The concerns relate to DPs that do not own BES Facilities. While these entities would not have any events to report under R2, they would still be applicable under R1 and R3. The team discussed this issue and has addressed this concern with additional language in the Guidelines and Technical Basis Section of the standard as follows:

#### “Distribution Provider Applicability Discussion

The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have

<sup>1</sup> The appeals process is in the Standard Processes Manual: [http://www.nerc.com/files/Appendix\\_3A\\_StandardsProcessesManual\\_20120131.pdf](http://www.nerc.com/files/Appendix_3A_StandardsProcessesManual_20120131.pdf)

any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more than 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.”

- **Duplicative Reporting** – If an entity is registered as an RC, BA and TOP, they should only have to submit a single report. The team discussed and has addressed this concern with additional language in the Guidelines and Technical Basis Section of the standard as follows:

“Multiple Reports for a Single Organization

For entities that have multiple registrations, the DSR SDT intends that these entities will only have to submit one report for any individual event. For example, if an entity is registered as a Reliability Coordinator, Balancing Authority and Transmission Operator, the entity would only submit one report for a particular event rather submitting three reports as each individual registered entity.”

With regards to the concern regarding multiple entities submitting a report for the same event, the team does not see this as being an issue for industry and will not make any further revisions to address this.

Other issues were raised by stakeholders and a discussion of those is below:

- **24 Hour Reporting** – Several stakeholders had concerns regarding the 24 hour reporting requirement. Commenters suggest that events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator’s burden, which reduces the operator’s effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. To this end, the DSR SDT has added clarifying language to R2 as follows:

R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*

- Paragraph 81** – On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 of that order (“P81”), invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program.
- Reporting** – Some comments were submitted regarding the reporting burden of this standard. The revised standard combines two standards into one and removes the analysis portion of the current mandatory and enforceable standards (EOP-004-1 and CIP-001-2a). The analysis provisions will be addressed in the NERC Events Analysis Program upon approval of EOP-004-2. This revised standard involves notification only and does not require any investigation or analysis.
- Attachment 1 comments** – Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. . The team has elected to move forward to recirculation ballot.
- Violation Risk Factors** - Many stakeholders had concerns with the VRFs for R2 and R3 being assigned as “medium”. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower

the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.

- **Violation Severity Levels** - Other stakeholders suggested revision to the VSLs for Requirement R1 based on if the event reporting Operating Plan fails to include one or more of the event types listed in Attachment 1. The SDT agrees and has revised the VSLs for R1 as follows:

Lower: The Responsible Entity had an Operating Plan, but failed to include one applicable event type.

Moderate: The Responsible Entity had an Operating Plan, but failed to include two applicable event types.

High: The Responsible Entity had an Operating Plan, but failed to include three applicable event types.

Severe: The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types OR the Responsible Entity failed to have an event reporting Operating Plan.

**Index to Questions, Comments, and Responses**

- 1. The DSR SDT has revised EOP-004-2 by combining Requirements R3 and R4 into a single requirement (Requirement R3) to, “... validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year.” Do you agree with this revision? If not, please explain in the comment area below. ....15
- 2. The DSR SDT has revised the VSLs to reflect the language in the revised requirements. Do you agree with the proposed VRFs and VSLs? If not, please explain in the comment area below.....25
- 3. Do you have any other comment, not expressed in the questions above, for the DSR SDT?.....37

**The Industry Segments are:**

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	Guy Zito	Northeast Power Coordinating Council											X
Additional Member		Additional Organization		Region	Segment Selection									
1.	Alan Adamson	New York State Reliability Council, LLC		NPCC	10									
2.	Carmen Agavrioloai	Independent Electricity System Operator		NPCC	2									
3.	Greg Campoli	New York Independent System Operator		NPCC	2									
4.	Sylvain Clermont	Hydro-Quebec TransEnergie		NPCC	1									
5.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.		NPCC	1									
6.	Gerry Dunbar	Northeast Power Coordinating Council		NPCC	10									
7.	Mike Garton	Dominion Resources Services, Inc.		NPCC	5									
8.	Kathleen Goodman	ISO - New England		NPCC	2									

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																		
			1	2	3	4	5	6	7	8	9	10									
9.	Michael Jones	National Grid	NPCC	1																	
10.	David Kiguel	Hydro One Networks Inc.	NPCC	1																	
11.	Michael Lombardi	Northeast Utilities	NPCC	1																	
12.	Randy MacDonald	New Brunswick Power Transmission	NPCC	9																	
13.	Bruce Metruck	New York Power Authority	NPCC	6																	
14.	Silvia Parada Mitchell	NextEra Energy, LLC	NPCC	5																	
15.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10																	
16.	Robert Pellegrini	The United Illuminating Company	NPCC	1																	
17.	Si-Truc Phan	Hydro-Quebec TransEnergie	NPCC	1																	
18.	David Ramkalawan	Ontario Power Generation, Inc.	NPCC	5																	
19.	Brian Robinson	Utility Services	NPCC	8																	
20.	Michael Schiavone	National Grid	NPCC	1																	
21.	Wayne Sipperly	New York Power Authority	NPCC	5																	
22.	Donald Weaver	New Brunswick System Operator	NPCC	2																	
23.	Ben Wu	Orange and Rockland Utilities	NPCC	1																	
24.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC	3																	
2.	Group	Ron Sporseen	PNGC Comment Group			X		X	X					X							
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																	
1.	Joe Jarvis	Blachly-Lane Electric Cooperative	WECC	3																	
2.	Dave Markham	Central Electric Cooperative	WECC	3																	
3.	Dave Hagen	Clearwater Power Company	WECC	3																	
4.	Roman Gillen	Consumer's Power Inc.	WECC	1, 3																	
5.	Roger Meader	Coos-Curry Electric Cooperative	WECC	3																	
6.	Bryan Case	Fall River Electric Cooperative	WECC	3																	
7.	Rick Crinklaw	Lane Electric Cooperative	WECC	3																	
8.	Annie Terracciano	Northern Lights Inc.	WECC	3																	
9.	Aleka Scott	PNGC Power	WECC	4																	
10.	Heber Carpenter	Raft River Electric Cooperative	WECC	3																	
11.	Steve Eldrige	Umatilla Electric Cooperative	WECC	1, 3																	
12.	Marc Farmer	West Oregon Electric Cooperative	WECC	4																	

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																
			1	2	3	4	5	6	7	8	9	10							
13.	Margaret Ryan	PNGC Power	WECC	8															
14.	Rick Paschall	PNGC Power	WECC	3															
3.	Group	Greg Rowland	Duke Energy		X		X		X	X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>														
1.	Doug Hils	Duke Energy	RFC	1															
2.	Lee Schuster	Duke Energy	FRCC	3															
3.	Dale Goodwine	Duke Energy	SERC	5															
4.	Greg Cecil	Duke Energy	RFC	6															
4.	Group	Chang Choi	Tacoma Public Utilities		X		X	X	X	X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>														
1.	Chang Choi	City of Tacoma	WECC	1															
2.	Travis Metcalfe	Tacoma Public Utilities	WECC	3															
3.	Keith Morissette	Tacoma Public Utilities	WECC	4															
4.	Chris Mattson	Tacoma Power	WECC	5															
5.	Michael Hill	Tacoma Public Utilities	WECC	6															
5.	Group	Kent Kujala	Detroit Edison				X	X	X										
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>														
1.	Alexander Eizans		RFC	3, 4, 5															
2.	Barbara Holland		RFC	3, 4, 5															
3.	Jeffrey DePriest		RFC	3, 4, 5															
6.	Group	Gerry Beckerle	SERC OC Standards Review Group		X		X												
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>														
1.	Roger Powers	City of Springfield, IL - CWLP	SERC	1, 3															
2.	Dan Roethemeyer	Dynegy	SERC	5															
3.	Melinda Montgomery	Entergy	SERC	1, 3, 6															
4.	Terry Bilke	MISO	SERC	2															
5.	Scott Brame	NCEMC	SERC	4, 1, 3, 5															
6.	William Berry	OMU	SERC	3, 5															



Group/Individual	Commenter	Organization		Registered Ballot Body Segment													
				1	2	3	4	5	6	7	8	9	10				
7. Tim Hattaway	PowerSouth	SERC	1, 5														
8. Brett Koelsch	Progress Energy Carolinas	SERC	1, 3, 5, 6														
9. Vicky Budreau	SCPSA	SERC	1, 3, 5, 6														
10. Gary Hutson	SMEPA	SERC	1, 3, 5, 6														
11. Marsha Morgan	Southern Co. Services	SERC	1, 5														
12. Randy Hubbert	Southern Co. Services	SERC	1, 5														
13. Joel Wise	TVA	SERC	1, 3, 5, 6														
14. Stuart Goza	TVA	SERC	1, 3, 5, 6														
15. Jim Case	Entergy	SERC	1, 3, 6														
16. Mike Bryson	PJM	SERC	2														
17. Mike Hirst	Cogentrix	SERC	5														
7. Group	Larry Raczkowski	FirstEnergy		X		X	X	X	X								
<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>														
1. William J Smith	FirstEnergy Corp	RFC	1														
2. Stephan Kern	FirstEnergy Energy Delivery	RFC	3														
3. Douglas Hohlbaugh	Ohio Edison Company	RFC	4														
4. Kenneth Dresner	FirstEnergy Solutions	RFC	5														
5. Kevin Query	FirstEnergy Solutions	RFC	6														
8. Group	Mike Garton	Dominion		X		X	X	X									
<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>														
1. Louis Slade	Dominion Resources Services, Inc.	RFC	5, 6														
2. Randi Heise	Dominion Resources Services, Inc.	MRO	5, 6														
3. Connie Lowe	Dominion Resources Services, Inc.	NPCC	5, 6														
4. Mike Crowley	Virginia Electric and Power Company	SERC	1, 3, 5, 6														
9. Group	WILL SMITH	MRO NSRF		X	X	X	X	X	X								
<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>														

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
1.	CHUCK LAWRENCE	ATC	MRO	1																
2.	TOM BREENE	WPS	MRO	3, 4, 5, 6																
3.	JODI JENSON	WAPA	MRO	1, 6																
4.	KEN GOLDSMITH	ALTW	MRO	4																
5.	ALICE IRELAND	XCEL/NSP	MRO	1, 3, 5, 6																
6.	DAVE RUDOLPH	BEPC	MRO	1, 3, 5, 6																
7.	ERIC RUSKAMP	LES	MRO	1, 3, 5, 6																
8.	JOE DEPOORTER	MGE	MRO	3, 4, 5, 6																
9.	SCOTT NICKELS	RPU	MRO	4																
10.	TERRY HARBOUR	MEC	MRO	1, 3, 5, 6																
11.	MARIE KNOX	MISO	MRO	2																
12.	LEE KITTELSON	OTP	MRO	1, 3, 5																
13.	SCOTT BOS	MPW	MRO	1, 3, 5																
14.	TONY EDDLEMAN	NPPD	MRO	1, 3, 5																
15.	MIKE BRYTOWSKI	GRE	MRO	1, 3, 5, 6																
16.	DAN INMAN	MPC	MRO	1, 3, 5, 6																
10.	Group	Chris Higgins	Bonneville Power Administration		X		X		X	X										
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																
1.	Jim Burns	BPA, Technical Operations	WECC	1																
2.	Fran Halpin	BPA, Duty Scheduling	WECC	5																
3.	Erika Doot	BPA, Generation Support	WECC	3, 5, 6																
4.	John Wylder	BPA, Transmission	WECC	1																
5.	Deanna Phillips	BPA, FERC Compliance	WECC	1, 3, 5, 6																
6.	Russell Funk	BPA, Transmission	WECC	1																
11.	Group	Robert Rhodes	SPP Standards Review Group			X														
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																
1.	John Allen	City Utilities of Springfield	SPP	1, 4																
2.	Doug Callison	Grand River Dam Authority	SPP	1, 3, 5																
3.	Jonathan Hayes	Southwest Power Pool	SPP	2																
4.	Bo Jones	Westar Energy	SPP	1, 3, 5, 6																

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
5.	Allen Klassen	Westar Energy	SPP	1, 3, 5, 6										
6.	Tiffany Lake	Westar Energy	SPP	1, 3, 5, 6										
7.	Tara Lightner	Sunflower Electric Power Corporation	SPP	1										
8.	Kyle McMenamin	Xcel Energy	SPP	1, 3, 5, 6										
9.	Jerry McVey	Sunflower Electric Power Corporation	SPP	1										
10.	Fred Meyer	Empire District Electric Company	SPP	1										
11.	Terri Pyle	Oklahoma Gas & Electric Company	SPP	1, 3, 5										
12.	Don Schmit	Nebraska Public Power District	MRO	1, 3, 5										
13.	Katie Shea	Westar Energy	SPP	1, 3, 5, 6										
14.	Sean Simpson	Board of Public Utilities, City of McPherson	SPP	NA										
15.	Bryan Taggart	Westar Energy	SPP	1, 3, 5, 6										
16.	Mark Wurm	Board of Public Utilities, City of McPherson	SPP	NA										
12.	Group	Jason Marshall	ACES Power Marketing Standards Collaborators								X			
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.	Susan Sosbe	Wabash Valley Power Association	RFC	3										
2.	Clem Cassmeyer	Western Farmers Electric Cooperative	SPP	1, 5										
3.	Megan Wagner	Sunflower Electric Power Corporation	SPP	1										
4.	Scott Brame	North Carolina Electric Membership Corporation	SERC	1, 3, 4, 5										
5.	Bob Solomon	Hoosier Energy	RFC	1										
6.	Robert Thomasson	Big Rivers Electric Corporation	SERC											
7.	Shari Heino	Brazos Electric Power Cooperative	ERCOT	1, 5										
8.	John Shaver	Arizona Electric Power Cooperative	WECC	4, 5										
9.	John Shaver	Southwest Transmission Cooperative	WECC	1										
10.	Mohan Sachdeva	Buckeye Power	RFC	3, 4										
11.	Michael Brytowski	Great River Energy	MRO	1, 3, 5, 6										
13.	Individual	Janet Smith, Regulatory Affairs Supervisor	Arizona Public Service Company		X		X		X	X				
14.	Individual	Emily Pannel	Southwest Power Pool Regional Entity											X

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
15.	Individual	Antonio Grayson	Southern Company	X		X		X	X					
16.	Individual	Daniela Hammons	CenterPoint Energy	X										
17.	Individual	Lee Layton	Blue Ridge EMC	X		X								
18.	Individual	Anthony Jablonski	ReliabilityFirst											X
19.	Individual	Jonathan Appelbaum	The United Illuminating Company	X										
20.	Individual	Russ Schneider	Flathead Electric Cooperative, Inc.			X	X							
21.	Individual	Oliver Burke	Entergy Services, Inc. (Transmission)	X										
22.	Individual	Nazra Gladu	Manitoba Hydro	X		X		X	X					
23.	Individual	Steve Grega	Lewis County PUD	X				X						
24.	Individual	Steve Alexanderson P.E.	Central Lincoln			X	X						X	
25.	Individual	Jack Stamper	Clark Public Utilities	X										
26.	Individual	Russell A. Noble	Cowlitz PUD			X	X	X						
27.	Individual	Chantel Haswell	Public Service Enterprise Group	X		X		X	X					
28.	Individual	Mike Hirst	Cogentrix Energy					X						
29.	Individual	Dave Willis	Idaho Power Co.	X		X								
30.	Individual	Michelle R D'Antuono	Ingelside Cogeneration LP					X						
31.	Individual	Howard Rulf	Wisconsin Electric Power company dba We Energies			X	X	X						
32.	Individual	Melissa Kurtz	US Army Corps of Engineers					X						
33.	Individual	David Jendras	Ameren Services	X		X		X	X					
34.	Individual	Michael Falvo	Independent Electricity System Operator		X									
35.	Individual	RoLynda Shumpert	South Carolina Electric and Gas	X		X		X	X					
36.	Individual	David Revill	Georgia Transmission Corporation	X										
37.	Individual	Andrew Gallo	City of Austin dba Austin Energy	X		X	X	X	X					
38.	Individual	Andrew Z.Pusztai	american Transmission Company	X										

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
39.	Individual	Don Schmit	Nebraska Public Power Disstrict	X		X		X						
40.	Individual	Terry Harbour	MidAmerican Energy	X		X		X	X					
41.	Individual	Kathleen Goodman	ISO New England Inc.		X									
42.	Individual	d mason	City and County of San Francisco - Hetch Hetchy Water and Power					X						
43.	Individual	Tracy Richardson	Springfield Utility Board			X								
44.	Individual	Rich Salgo	NV Energy	X		X		X						
45.	Individual	Thad Ness	American Electric Power	X		X		X	X					
46.	Individual	Charles Yeung	Southwest Power Pool RTO		X									
47.	Individual	Nathan Mitchell	American Public Power Association			X	X							
48.	Individual	Don Jones	Texas Reliability Entity											X
49.	Individual	Christine Hasha	ERCOT		X									
50.	Individual	Denise M. Lietz	Puget Sound Energy Inc.	X		X		X						
51.	Individual	Maggy Powell	Exelon Corporation and its affiliates	X		X		X	X					
52.	Individual	Christina Bigelow	Midwest Independent Transmission System Operator, Inc.		X									
53.	Individual	Scott Berry	Indiana Municipal Power Agency				X							
54.	Individual	Darryl Curtis	Oncor Electric Delivery	X										
55.	Individual	Tony Kroskey	Brazos Electric Power Cooperative, Inc.	X										
56.	Individual	Alice Ireland	Xcel Energy	X		X		X	X					

If you wish to express support for another entity’s comments without entering any additional comments, you may do so here.

Organization	Supporting Comments of “Entity Name”
PNGC Comment Group	Central Lincoln PUD
Blue Ridge EMC	R3 is another example of a "paper chase", creating (or rather continuing) an administrative burden for the utility. The standard should only require that the entity have a plan and the accountability should be "did the entity follow the plan when needed, including proving that the appropriate contacts were made?"
<p><b>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. Also, if the information in the plan is out of date, then the plan will not be effective.</b></p>	
Flathead Electric Cooperative, Inc.	Central Lincoln
US Army Corps of Engineers	MRO NSRF
Nebraska Public Power District	Midwest Reliability Organization (MRO) NERC Standards Review Forum (NSRF); AND Southwest Power Pool RTO
MidAmerican Energy	MidAmerican supports the MRO NSRF comments
ISO New England Inc.	NPCC

1. The DSR SDT has revised EOP-004-2 by combining Requirements R3 and R4 into a single requirement (Requirement R3) to, “... validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year.” Do you agree with this revision? If not, please explain in the comment area below.

**Summary Consideration:** The majority of stakeholders agree with the combination of R3 and R4 and with the new language of R3 to “validate” the contact information. A few commenters suggested that Requirement R3 is administrative and should be removed under the provisions of “Paragraph 81”. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program.

Organization	Yes or No	Question 1 Comment
CenterPoint Energy	No	CenterPoint Energy supports the concept of combining Requirements R3 and R4; however, the Company still prefers an annual review requirement which would include validating the contact information and content of the Operating Plan overall. Therefore, CenterPoint Energy recommends the following revised language for Requirement R3: “Each Responsible Entity shall review and update the Operating Plan at least every 15 months.” The Company also suggests that the Measure be worded as follows: “Evidence may include, but is not limited to dated documentation reflecting changes to the Operating Plan including updated contact information if necessary.”

Organization	Yes or No	Question 1 Comment
<p>Response: Thank you for your comment. The SDT appreciates the suggestion on validating the content of the Operating Plan, but at this time, we feel that the step is not necessary to meet the directive from FERC Order 693. As to the comment on extending the review period to 15 months, following much discussion and review of the industry comments, we are staying with the language as proposed.</p>		
<p>American Electric Power</p>	<p>No</p>	<p>In the spirit of Paragraph 81 efforts, we request the removal of R3 as it is solely administrative in nature, existing only to support R2. This is more of an internal control and does not appear to rise to the level of being an industry-wide requirement. In addition, having two requirements rather than one increases the likelihood of being found non-compliant for multiple requirements rather than a single requirement.</p>
<p>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. , CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</p>		
<p>City and County of San Francisco - Hetch Hetchy Water and Power</p>	<p>No</p>	<p>Measure M3 specifically identifies two types of acceptable compliance evidence: Voice Recording and Log entries. Specifying only these two forms of evidence creates a risk that some auditors will reject other forms of R3 compliance evidence which are equally valid, such as emails or written call records. Although M3 states that acceptable evidence is not limited to Voice Recordings or Log Entries, we have concern that other</p>



Organization	Yes or No	Question 1 Comment
		methods of complying with R3 may not be accepted.
<p>Response: Thank you for your comment. The SDT believes that the phrase “may include, but are not limited to” addresses your concern. The SDT will present your comment to the NERC Compliance staff in an effort to inform audit staffs on what evidence is permissible.</p>		
Blue Ridge EMC	No	See previous comments
<p>Response: Thank you for previous comments. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. Also, if the information in the plan is out of date, then the plan will not be effective.</p>		
Detroit Edison	No	<p>The requirement is too prescriptive and difficult to document. Requirement should be for annual review of Operating Plan. This allows for entity to review plan and document this the same as other Standards that require annual review (i.e. annual review blocks on documents).The requirement as written is vague and difficult to document. Annual review of reporting process is already a requirement.</p>
<p>Response: Thank you for your comments. While the SDT appreciates the view that the Operating Plan should be reviewed annually, the SDT feels that the requirement only needs to address the validity of the contact information contained within the Operating Plan in order to meet the FERC directive in Order 693. If the entity is aware of changes within its operations that would make a more extensive review advisable, it can choose to do so; but where there have been no significant changes to an entity’s operations in the last year, ensuring the validity of the contact information should be sufficient.</p>		
Manitoba Hydro	No	This seems like an administrative only requirement. It would be too difficult to validate or measure.
<p>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. The measure calls for an entity to have “dated records to show that it validated all contact information contained in the Operating Plan each calendar year. Such evidence may include, but are not limited to, dated voice recordings and operating logs or other communication documentation.” The SDT does not believe that this is an administrative</p>		

Organization	Yes or No	Question 1 Comment
<p>requirement because, if the information in the Operating Plan is out of date, then the plan will not be effective.</p>		
<p>ACES Power Marketing Standards Collaborators</p>	<p>No</p>	<p>We believe that the revision to R3 and elimination of R4 are great improvements to the standard as a lot of the unnecessary burdens have been removed. However, Requirement R3 is still not needed, has several issues with it and should be eliminated. (1) While validating contact information annually in a reporting plan makes sense, it does not rise to level of importance of requiring sanctions for failure to do so. Furthermore, it does nothing to assure reliability. Shortly after the contact information has been updated, it could change. This does not mean that validation should be more frequent but simply that is an unnecessary administrative burden. If contact information changes, the registered entity will have to find it. For reliability purposes, why does it matter if they do this in the 24-hour reporting period after the event or annually before the event? (2) Requirement R3 is administrative and is not consistent with the recent direction that NERC and FERC have taken toward compliance. Violations of this requirement are likely to be candidates for FFT treatment and this is exactly the kind of requirement that FERC invited NERC to propose for retirement in Paragraph 81 of the order approving the FFT process. Furthermore, it appears to meet at least two criteria (Administrative and periodic updates) that the Paragraph 81 drafting team has proposed to use to identify candidate requirements for retirement. The requirement is also not consistent with the direction NERC has taken on internal controls. How is an auditor reviewing that contact information has been updated in an Operating Plan forward looking or for that matter beneficial to reliability? Imagine a registered entity fails to update their contact information but still reports an event within the 24 hour reporting time frame to the appropriate parties. They are in technical violation of R3 but have met the spirit of the standard. (3) Requirement R3 is not a results-based requirement. It simply compels a registered entity “how to” meet reporting deadlines. Certainly, if a</p>

Organization	Yes or No	Question 1 Comment
		<p>registered entity has current contact information on hand, it will be easier to notify appropriate parties of events quickly. However, it does limit a registered entity's ability to identify its own unique and possibly better way to meet a requirement. "How to" requirements prevent unique and superior solutions.</p>
<p><b>Response:</b> Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. The SDT does not believe that this is an administrative requirement because, if the information in the Operating Plan is out of date, then the plan will not be effective.</p> <p>On March 15, 2012, FERC issued an order on NERC's Find, Fix and Track process and in paragraph 81 ("P81") invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission's request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</p>		
NV Energy	No	<p>Without further clarification of what is expected by "validate all contact information" I cannot support this requirement. On the surface, "validate" appears to be acceptable terminology, as it means to me a review of the contact names and contact information (perhaps cell #, home phone, text address, email address, etc) that would be evidenced through an attestation of completion of review along with records showing the updates made to the contact information pursuant to the review. However, when the Measure is considered, it refers to evidence such as operator logs, voice recordings, etc. This seems to indicate that the</p>

Organization	Yes or No	Question 1 Comment
		<p>expectation is that each contact is tested, by dialing, texting, emailing, etc with some sort of confirmation that each contact was successful. If this is what is necessary to satisfy the "validate" requirement, I believe it is excessive, burdensome and unnecessary. I suggest modification of the Measure language to clearly allow for an entity to demonstrate compliance by a showing that it reviewed the contact information and made changes as deemed necessary by its review, and to remove the reference to operator logs and voice recordings as the evidence of measure.</p>
<p><b>Response: Thank you for your comment. The SDT agrees with your comment and views your direction as being consistent with the standard’s intent. The SDT will submit your comment to NERC Compliance staff for their consideration. The SDT intends for operator logs and voice recordings to be acceptable as evidence, but not the only acceptable evidence. The use of the language “such as” in the measure indicates this.</b></p>		
Bonneville Power Administration	Yes	BPA agrees with the revision and recognizes that it will involve a large amount of validation workload for entities with a large footprint.
<p><b>Response: Thank you for your comment.</b></p>		
Dominion	Yes	Dominion supports the combination of Requirements R3 and R4 into a single requirement (Requirement R3), although we remain concerned that validation requiring a phone call could be perceived as a nuisance by that entity.
<p><b>Response: Thank you for your comment. The SDT appreciates this concern but feels that the requirement is necessary to address the FERC directive in the Order 693. The SDT does not believe that validation of the contact information will be a nuisance. If the information in the Operating Plan is out of date, then the plan will not be effective.</b></p>		
Duke Energy	Yes	Duke Energy commends the excellent work of the Standard Drafting Team in incorporating previous comments into the current posted draft of the

Organization	Yes or No	Question 1 Comment
		standard.
<b>Response: Thank you for your comment.</b>		
ERCOT	Yes	ERCOT considers replacing R3 and R4 with the new R3 is an improvement and we thank the drafting team for making the change.
<b>Response: Thank you for your comment.</b>		
ReliabilityFirst	Yes	Even though ReliabilityFirst votes in the Affirmative, we offer the following comment regarding Requirement R3 for consideration. ReliabilityFirst recommends changing the word “validate” to “verify” in Requirement R3. ReliabilityFirst believes not only does the entity need to validate contact information is correct, they should verify (i.e. authenticate though test) that the contact information is correct.
<b>Response: Thank you for your comment. The SDT feels that the action you define is consistent with our intent.</b>		
Independent Electricity System Operator	Yes	IESO agrees that the intent of Requirement R3 to have the Registered Entities validate the contact information in the contact lists that they may have for the events applicable to them is achieved. IESO also agrees that the elimination of conducting an annual test of the communications process and review of the event reporting Operating Plan in merging the previous R3 and R4 into this new R3 will give entities an opportunity to develop a plan that suits its business needs.
<b>Response: Thank you for your comment.</b>		
Indiana Municipal Power Agency	Yes	IMPA agrees with the removal of a “test” and going with a validation requirement for the contact information in the Operating Plan.

Organization	Yes or No	Question 1 Comment
<b>Response: Thank you for your comment.</b>		
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration believes that an annual validation of contact information is sufficient for a reporting procedure. R2 provides sufficient impetus for Responsible Entities to keep their Operating plan current - as a missed report will lead to a violation. Furthermore, external agencies and law enforcement officials will be reluctant to participate in validation tests, as dozens of nearby BES entities will overwhelm them with such requests.
<b>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. If the information in the Operating Plan is out of date, then the plan will not be effective.</b>		
SPP Standards Review Group	Yes	We feel that replacing R3 and R4 with the new R3 is an improvement and we thank the drafting team for making the change.
<b>Response: Thank you for your support.</b>		
PNGC Comment Group	Yes	
Tacoma Public Utilities	Yes	
SERC OC Standards Review Group	Yes	
FirstEnergy	Yes	
MRO NSRF	Yes	
Arizona Public Service Company	Yes	
Southwest Power Pool Regional Entity	Yes	

Organization	Yes or No	Question 1 Comment
Southern Company	Yes	
The United Illuminating Company	Yes	
Entergy Services, Inc. (Transmission)	Yes	
Lewis County PUD	Yes	
Central Lincoln	Yes	
Clark Public Utilities	Yes	
Cowlitz PUD	Yes	
Public Service Enterprise Group	Yes	
Cogentrix Energy	Yes	
Idaho Power Co.	Yes	
Wisconsin Electric Power company dba We Energies	Yes	
Ameren Services	Yes	
South Carolina Electric and Gas	Yes	
Georgia Transmission Corporation	Yes	
City of Austin dba Austin Energy	Yes	
american Transmission Company	Yes	

Organization	Yes or No	Question 1 Comment
MidAmerican Energy	Yes	
Springfield Utility Board	Yes	
Southwest Power Pool RTO	Yes	
American Public Power Association	Yes	
Texas Reliability Entity	Yes	
Puget Sound Energy Inc.	Yes	
Exelon Corporation and its affiliates	Yes	
Midwest Independent Transmission System Operator, Inc.	Yes	
Oncor Electric Delivery	Yes	
Xcel Energy	Yes	



2. The DSR SDT has revised the VSLs to reflect the language in the revised requirements. Do you agree with the proposed VRFs and VSLs? If not, please explain in the comment area below.

**Summary Consideration:** Many stakeholders had concerns with the VRFs for R2 and R3 being assigned as “medium”. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.

Other stakeholders suggested revision to the VSLs for Requirement R1 based on if the event reporting Operating Plan fails to include one or more of the event types listed in Attachment 1. The SDT agrees and has added the following VSLs to R1, in addition to the language that was previously included in the “Severe” VSL:

**Lower:** The Responsible Entity had an Operating Plan, but failed to include one applicable event type.

**Moderate:** The Responsible Entity had an Operating Plan, but failed to include two applicable event types.

**High:** The Responsible Entity had an Operating Plan, but failed to include three applicable event types.

**Severe:** The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.

Organization	Yes or No	Question 2 Comment
Detroit Edison	No	Under VSLs for R2- We disagree with the reporting time frames. Making the time requirement as soon as 24 hours puts this reporting requirement on the real time operators. Many of the situations listed in the EOP-004 attachment are not included in the OE-417 report. The Unofficial Comment Form states the reporting obligations serve to provide input to the NERC Event Analysis Program. This program has removed the 24 hour reporting requirement and

Organization	Yes or No	Question 2 Comment
		changed it to 5 business days.
<p>Response: Thank you for your comments. The reporting obligation under this standard is to provide notification of events to NERC Situation Awareness group. The SDT, in consultation with the DOE and NERC Events Analysis group, have recognized the where there is duplication of reporting and provided for the common use of the different group’s forms. This standard is not a replacement or substitution for any other obligations to other agencies. However, the SDT recognizes the concern with having real time operations staff submitting the report. To this end, the DSR SDT has added clarifying language to R2 as follows:</p> <p style="padding-left: 40px;"><b>R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</b></p>		
Texas Reliability Entity	No	(1) VSLs for R1 should have a lower level VSL if the event reporting Operating Plan fails to include one or more of the event types listed in Attachment 1. (2) VSL for R1 is incorrectly stated as there are no “parts” to R1.
<p>Response: Thank you for your comment. 1) The SDT agrees and has added the following VSLs for R1, in addition to the language that was previously included in the “Severe” VSL:</p> <p style="padding-left: 40px;"><b>Lower: The Responsible Entity had an Operating Plan, but failed to include one applicable event type.</b></p> <p style="padding-left: 40px;"><b>Moderate: The Responsible Entity had an Operating Plan, but failed to include two applicable event types.</b></p> <p style="padding-left: 40px;"><b>High: The Responsible Entity had an Operating Plan, but failed to include three applicable event types.</b></p> <p style="padding-left: 40px;"><b>Severe: The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.</b></p> <p>2) This was correct in the clean version of the standard.</p>		
ACES Power Marketing Standards Collaborators	No	Because R3 is administrative, the VRF should be Lower. The requirement simply compels that that registered entity update a document which is purely administrative.
<p>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a</p>		

Organization	Yes or No	Question 2 Comment
<p>is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Bonneville Power Administration	No	<p>BPA does not agree with the VRFs and VSLs. BPA believes that the violation levels for administrative errors are too high. For more information, please reference comments to question #3.</p>
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF. Please see the response to your question 3 comments.</p>		
CenterPoint Energy	No	<p>CenterPoint Energy suggests that the phrase “which caused a negative impact to the Bulk Electric System” be added to each Violation Severity Level. For example, the wording would appear as follows: “The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 24 hours but less than or equal to 36 hours after meeting an event threshold for reporting which caused a negative impact to the Bulk Electric System”. Additionally or alternatively, the Company proposes that the above phrase be added to the Threshold(s) for Reporting in Attachment 1 to focus on events that have an impact or effect on the Bulk Electric System.</p>
<p><b>Response:</b> Thank you for your comment. The SDT does not believe such a change is necessary. Each event type listed is applicable to BES reliability.</p>		

Organization	Yes or No	Question 2 Comment
MidAmerican Energy	No	Change the VRFs / VSLs to match suggested changes in Question 3
<p><b>Response:</b> Thank you for your comment. The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. Please see the response to your question 3 comments.</p>		
The United Illuminating Company	No	Do not agree that the VRF for R3 is medium. Failure to Validate contact information will not likely lead to instability and Cascade. Reporting under EOP-004 is not an immediate action, and given a 24 hour reporting window a proper contact point can be identified on-the-fly. R2 is properly identified as the Medium VRF since a failure to report whether due to an improper Operating plan or improper contact list may lead to a BES cascade.
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Southwest Power Pool Regional Entity	No	In R2, SPP RE does not understand why the VSLs are based on who was or was not contacted rather than when it was reported. An entity could decide to put only two entities in its Event Reporting Operating Plan. If the entity fails to submit an appropriate event report, it is open to a Severe VSL on the top set of VSLs but only a moderate on the lower set of VSLs. This seems to be a disconnect for applying the VSLs for the same facts and circumstances.
<p><b>Response:</b> Thank you for your comment. The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. The VSLs were written based on two potential failures to meet the requirement. The first is based on the time the report was submitted while the second was based on the entity submitting the report within 24 hours but not to all applicable entities.</p>		

Organization	Yes or No	Question 2 Comment
Midwest Independent Transmission System Operator, Inc.	No	MISO agrees with the comments submitted by the SERC Operating Committee that the VRFs for R2 and R3 should be “Lower” instead of “Medium,” since these are administrative requirements. MISO further respectfully suggests that implementing another standard that requires reporting every incident identified in a plan within 24 hours and that classifies failure to do so a “Severe” violation, will likely cause entities to limit the scope of their plans. NERC, therefore, would not receive information that appears unimportant to a single entity but could be important in the context of similar events across the country.
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p> <p>The SDT does not agree with your second comment and believes that entities will report the appropriate events.</p>		
Oncor Electric Delivery	No	Oncor suggest the following additions to VSL language for R1 to align more closely with the measures described in M1Lower VSL - Entity has one applicable event type not properly identified in its event reporting Operating Plan. High VSL - Entity has more than one applicable event type not properly identified in its event reporting Operating Plan. Severe VSL - The Responsible Entity failed to have an event reporting Operating Plan
<p><b>Response:</b> Thank you for your comment. Based on comments from you and others, we have added the following VSLs for R1, in addition to the language that was previously included in the “Severe” VSL:</p> <p><b>Lower:</b> The Responsible Entity had an Operating Plan, but failed to include one applicable event type.</p>		

Organization	Yes or No	Question 2 Comment
<p><b>Moderate: The Responsible Entity had an Operating Plan, but failed to include two applicable event types.</b></p> <p><b>High: The Responsible Entity had an Operating Plan, but failed to include three applicable event types.</b></p> <p><b>Severe: The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.</b></p>		
Exelon Corporation and its affiliates	No	<p>R2 VSLs - By measuring the amount of time taken to report and the number of entities to receive the report, the VSLs track more with size and location than with a failure to report. For instance, an entity failing to report at all to one entity would be deemed a lower VSL while an entity reporting to many, but failing to report to three entities would be deemed a high VSL.</p> <p>R3 VSL - The severe VSLs do not seem commensurate to oversight. A three month delay in validating that phone numbers are correct, for phone numbers that are accurate, does not track with a severe infraction.</p>
<p><b>Response: Thank you for your comment. The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. The SDT will forward your suggestions to NERC for future consideration of the VSL language.</b></p>		
Blue Ridge EMC	No	R3 VSLs are silly.
<p><b>Response: Thank you for your comment. The SDT followed the NERC guidelines for setting the appropriate VSLs.</b></p>		
Tacoma Public Utilities	No	<p>Regarding the Severe VSL for R1, the reference to “Parts 1.1 and 1.2” appears to be outdated. For R2, change “the Responsible Entity failed to submit an event report...to X entity(ies) within 24 hours” to “the Responsible Entity failed to submit an event report...to only X entity(ies) within 24 hours.” (Add ‘only.’)</p>
<p><b>Response: Thank you for your comment. The SDT agrees with your first suggestion and this was correct in the clean version of the standard that was posted. Your second suggestion will be forwarded to NERC for future consideration.</b></p>		

Organization	Yes or No	Question 2 Comment
SPP Standards Review Group	No	<p>Since EOP-004 is about after-the-fact reporting, we suggest that all the VRFs be Lower. This would mean lowering R2 and R3 from Medium.</p> <p>The third component of the Severe VSL for R2 is more severe than the other two components. In an attempt to be more consistent across all the VSLs, we propose the following for the High VSL for R2: The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours after meeting an event threshold for reporting. OR The Responsible Entity failed to submit an event report (e.g., written or verbal) to three or more entities identified in its event reporting Operating Plan within 24 hours. We propose the following, deleting the first two components as shown in the current draft, for the Severe VSL for R2: The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p> <p>The VSLs were written to account for tardiness of reports, for failing to report to certain entities and for not submitting a report at all. The investigators will apply the appropriate VSL based on the type of violation found.</p>		
ERCOT	No	<p>Since EOP-004 is related to ex-post reporting, which has nothing to do with operational or planning risk, this is an administrative requirement and, accordingly, the VRFs should all be Low. This would mean lowering the VRF for R2 and R3 to Low.</p> <p>The third component of the Severe VSL for R2 is more severe than the other two components. In an attempt to be more consistent across all the VSLs, we</p>

Organization	Yes or No	Question 2 Comment
		<p>propose the following for the High VSL for R2: The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours after meeting an event threshold for reporting. OR The Responsible Entity failed to submit an event report (e.g., written or verbal) to three or more entities identified in its event reporting Operating Plan within 24 hours. ERCOT proposes that the first two components of the Severe VSL for R2 be deleted and replaced with: The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>
<p><b>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</b></p> <p><b>The VSLs were written to account for tardiness of reports, for failing to report to certain entities and for not submitting a report at all. The investigators will apply the appropriate VSL based on the type of violation found.</b></p>		
Duke Energy	No	<p>The Lower VSL for R3 should be clarified. The phrase “validated 75% or more” should be modified to say “validated at least 75% but less than 100%”.</p>
<p><b>Response: Thank you for your comment. The SDT agrees and has made the correction.</b></p>		
SERC OC Standards Review Group	No	<p>The VRF for R2 should be “Lower” instead of “Medium” since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be “Lower” instead of “Medium” since it is an administrative requirement.</p>
<p><b>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC</b></p>		



Organization	Yes or No	Question 2 Comment
<p>Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Southern Company	No	<p>The VRF for R2 should be “Lower” instead of “Medium” since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be “Lower” instead of “Medium” since it is an administrative requirement. In addition we suggest that the VSL for R1 should have a lower level VSL for an Operating Plan that may have one event type missing from the Operating Plan.</p>
<p>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Cogentrix Energy	No	<p>The VRF for R2 should be “Lower” instead of “Medium” since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be “Lower” instead of “Medium” since it is an administrative requirement.</p>
<p>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a</p>		

Organization	Yes or No	Question 2 Comment
<p>is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Xcel Energy	No	<p>The VSLs for column for R2 provide a range of severity based on the number of contacts made (or not made) but this seems to be arbitrarily defined. A smaller entity may only have two or three contacts so missing one or more here may be a much higher risk than for a larger utility that may have ten or more contacts. The VSLs should be drafted to include percentages instead of whole numbers. The Lower VSL column for R3 states, “...OR The Responsible Entity validated 75% or more of the contact information contained in the operating plan.” This could be interpreted that even someone completed 100% (which is more than 75%) a low VSL could be assigned. This VSL should be drafted in similar fashion to the Moderate, High and Severe VSLs and include a range (i.e. less than 100% but more than 75%).</p>
<p><b>Response:</b> Thank you for your comment. The SDT followed the NERC guidelines for VRFs and VSLs in setting the appropriate levels. The SDT will forward your suggestions to NERC for future consideration.</p>		
Manitoba Hydro	No	<p>This seems like an administrative only requirement. It would be too difficult to validate or measure.</p>
<p><b>Response:</b> Thank you for your comment. Please see the response to your comment in question 1.</p>		
Independent Electricity System Operator	No	<p>We agree with the VRF for R2, but have a concern over the VRFs assigned to R1 (Lower) and R3 (Medium). Having an event reporting operating plan (R1) is a first step toward meeting the intent of this standard, annually validating it (R3) is a maintenance requirement which arguably can be regarded as equally important but its reliability risk impact for failure to comply should be no higher</p>

Organization	Yes or No	Question 2 Comment
		than having no plan to begin with. We therefore suggest that the VRFs for R1 and R3 be at least the same, or that R1’s VRF be higher than that for R3.
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Southwest Power Pool RTO	No	We question the reliability benefits of this requirement.
<p><b>Response:</b> Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. If the information in the Operating Plan is out of date, then the plan will not be effective.</p>		
Lewis County PUD	No	
American Electric Power	No	
<p><b>Response:</b> Thank you for your participation.</p>		
ReliabilityFirst	Yes	Even though ReliabilityFirst votes in the Affirmative, we offer the following comments for consideration regarding the VSLs: VSL for Requirement R2 - ReliabilityFirst questions whether there is justification for the gradation of VSLs out to 60 hours for the reporting an event. Without justification, ReliabilityFirst believes the timeframe should be shortened to eight hour increments with a severe VSL being more than 48 hours late. ReliabilityFirst believes that being more than a day late (24 hours) falls within the entity completely not meeting the intent of submitting the report with the required 24 hour timeframe.
<p><b>Response:</b> Response: Thank you for your comment. The SDT followed the NERC guidelines for VRFs and VSLs in setting the</p>		

Organization	Yes or No	Question 2 Comment
appropriate levels.		
PNGC Comment Group	Yes	
FirstEnergy	Yes	
Arizona Public Service Company	Yes	
Entergy Services, Inc. (Transmission)	Yes	
Clark Public Utilities	Yes	
Public Service Enterprise Group	Yes	
Idaho Power Co.	Yes	
Ingelside Cogeneration LP	Yes	
Wisconsin Electric Power company dba We Energies	Yes	
Ameren Services	Yes	
South Carolina Electric and Gas	Yes	
Georgia Transmission Corporation	Yes	
City of Austin dba Austin Energy	Yes	
Springfield Utility Board	Yes	
American Public Power Association	Yes	

3. Do you have any other comment, not expressed in the questions above, for the DSR SDT?

**Summary Consideration:** Most stakeholders who responded to this question provide comments suggesting specific revisions to the requirements or to the event types listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.

Organization	Question 3 Comment
Detroit Edison	<p>"Suspicious activity" and "suspicious device" should be eliminated from Attachment 1, Event types: 'Physical threats to a Facility' and 'Physical threat to a BES Control Center'. By including 'suspicious activity' in the standard, I believe the project team went outside of the scope of the project, which was intended to be a merger of the two standards. Regarding standard CIP 001, the threshold for reporting is "Disturbances or unusual occurrences, suspected or determined to be caused by sabotage....", as its title suggested: Sabotage Reporting. Suspicious activity, which is not defined by the standard, clearly has a much lower threshold than sabotage, or even suspected sabotage. The reporting requirement of 24 hours, also increases the burden on the entity to either rush to investigate and make a determination regarding suspicious activity in less than 24 hours, or not perform due diligence and report uninvestigated "suspicious" activity, which normally turns out to not be a "Physical Threat". Suspicious activity should be duly investigated by the entity, local law enforcement, or the FBI as appropriate; and then reported if it has been determined to be a physical threat, or cannot be explained. Reporting within 24 hours will devalue the information inputted, as most cases of suspicious activity are innocuous, and the standard lacks a process of follow up, which would remove the those incidents from intelligence databases. Regarding suspicious devices, determination is usually immediate, (in less than 24 hours), and then the device would be classified as either "sabotage" or "no threat". The standard is not clear whether suspicious devices still have to be reported, even if they are immediately determined as not a "Physical Threat to a Facility or BES Control Center." Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-</p>

Organization	Question 3 Comment
	<p>01) - Reporting Concepts states: The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002- Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting." Attachment 1 in existing EOP-004-1 is much easier to follow (specifies time requirement to file). Also R2 states DOE OE-417 may be utilized to file reports, however Standard time requirement for update report is 48 hours, OE-417 has changed time requirement on updated filing to 72 hours. Difference can cause confusion and possible penalties. The real time operator must focus on maintaining system reliability. Putting unnecessary reporting obligations on RT puts more importance on the reporting structure than on maintaining reliability. Let 8/5 support personnel perform the reporting tasks and keep the 24/7 on shift operators focusing on the BES.</p>
<p><b>Response: Thank you for the comment. The SDT disagrees with your position on the inclusion of suspicious activities. Suspicious activities are events and notification of such events is a part of the existing and CIP-001 and EOP-004 standards. Reporting under EOP-004 is for notification purposes only. The standard does not require any analysis of events and does not require any follow up reports as you suggest.</b></p>	
<p>City of Austin dba Austin Energy</p>	<p>(1) City of Austin dba Austin Energy (AE) requests that the SDT clarify whether R3 requires that each Registered Entity subject to EOP-004-2 verify NERC’s contact information each year. It appears this would be overly burdensome for NERC to respond to individual requests. (2) AE also asks that NERC’s fax number be included in the contact information at the beginning of Attachment 1 and at the Event Reporting Form in Attachment 2. NERC included the fax number as a viable contact method in its recent NERC Alert notifying the industry of the changed information. (3) AE requests that the SDT increase the threshold for reporting loss of firm load to approximately 300 MW for all entities to align the reporting threshold with the OE-417 threshold. Otherwise, smaller entities would have to report firm load losses between 200 and 299 MW to NERC but not to the DOE. This could be administratively confusing to those responsible for reporting. (4) Attachment 1 lists the threshold for reporting generation loss at approximately 1,000MW for the ERCOT Interconnection. ERCOT planning is based on a single contingency of 1,375MW. For this reason, AE believes the minimum threshold for a</p>

Organization	Question 3 Comment
	<p>disturbance should be greater than the single contingency amount of &gt;1,375MW for the ERCOT Interconnection.</p>
<p><b>Response:</b> Thank you for your comment. The SDT does not feel it is necessary to specific how the validation occurs and has left this to the entity to determine how to do this. The SDT agrees with the inclusion of the fax number. The SDT will forward the other suggestions to NERC for future consideration. However, it should be noted that these suggestions have not been adopted due to consistency with other standards.</p>	
<p>ACES Power Marketing Standards Collaborators</p>	<p>(1) For the first “Damage or destruction of a Facility” event in Attachment 1, the threshold for reporting should be modified. The threshold for reporting would only include damage or destruction that necessitates the need for action to prevent an Emergency. It does not include if an Emergency actually occurs. Based on the definition of Emergency which states that it is an “abnormal system condition that requires... action to prevent or limit”, we think the threshold should be changed to “Damage or destruction of a Facility... that results in a BES Emergency”. Per the definition, the Emergency is what necessitates action which is what the threshold appeared to be focused on. (2) In the second “Damage or destruction of a Facility” event in Attachment 1, the threshold regarding “intentional human action” is ambiguous and suffers from the same difficulties as defining sabotage. What constitutes intentional? How do we know something was intentional without a law enforcement investigation? If a car runs into a transmission tower, was this an accident or intentional human action? It could be either. This appears to be the same issue that prevented the drafting team from defining sabotage.(3) Under the “Physical threats to a BES control center” event in Attachment 1, the event should very clearly define if this applies to backup control centers or not. (4) Under the “Complete loss of off-site power to a nuclear generating plant (grid supply)” event” in Attachment 1, the entity with reporting responsibility is not coordinated with NUC-001. NUC-001 used the term transmission entity to mean an entity that is responsible for providing NPIR services. They did not use only TOP because there are other entities that provide this service. Please coordinate the “Entity with Reporting Responsibility” with that standard. (5) We continue to believe that the draft standard has not satisfied the complete scope of the SAR regarding elimination of redundancy. The draft standard will continue to require redundant reporting by various entities. For instance, under the event “Loss of Firm Load” in Attachment</p>

Organization	Question 3 Comment
	<p>1, the DP, TOP, and BA all are required to report. The response to our last set of comments regarding this issue was that “the industry can benefit from having such differing perspectives when events occur”. This response seems to confuse event analysis with event reporting. The purpose of the standard is to simply report that an event happened. In fact, the reporting form only requires the submitting entity to report the type of event. The description of what happened is optional. What additional perspectives could be gained from having multiple registered entities in the same electrical footprint report that an event happened. If the purpose is to analyze the event, this is covered in the events analysis process. Furthermore, once NERC becomes aware of the event they have the authority to request data and information from other registered entities. Please eliminate the duplicate reporting requirements. Other events that may require duplicate reporting include: Damage or destruction of a Facility, Physical threats to a Facility, BES Emergency resulting in automatic firm load shedding, Loss of firm load, System separation, Generation loss, and Complete loss of off-site power to a nuclear generating plant.(6) In the second “Damage or destruction of a Facility” event and “Physical Threats to a Facility” events, Distribution Provider should be removed. The Distribution Provider does not have any Facilities which is defined as “a set of electrical equipment that operates as a single Bulk Electric System Element”. The DP’s transformers interconnecting to the BES are not Facilities and the latest NERC BOT definition explicitly does not include them in Inclusion I1. If a DP did own Facilities, it would be registered as a TO or GO. Inclusion of the DP will compel the DP to provide evidence that it does not have Facilities which is an unnecessary compliance burden that does not support reliability. (7) The “BES Emergency resulting in automatic firm load shedding” should not apply to the DP. In the existing EOP-004 standard, Distribution Provider is not included and the load shed information still gets reported. (8) For the “Voltage deviation on a Facility” event in Attachment 1, we suggest changing “area” in the threshold for reporting to “Transmission Operator Area” as it is a defined term. (9) For the “System separation (islanding)” event, please remove BA. Because islanding and system separation, involve Transmission Facilities automatically being removed from service, this is largely a Transmission Operator issue. This position is further supported by the approval of system restoration standard (EOP-005-2) that gives the responsibility to restore the system to the TOP. (10) The response to our comments requesting that Measure 2 specifically identify that attestations are</p>



Organization	Question 3 Comment
	<p>acceptable forms of evidence to indicate that no events have occurred indicated that the measure cannot permit use of attestations. Other standards that have been recently approved by the board specifically permit the use of attestations. FAC-003-2 M1 and M2, TOP-001-2 M1-M11 and TOP-003-2 M5 all permit the use of attestations. We ask that the drafting team to reconsider including a specific reference that an attestation is acceptable to indicate no event has occurred given these new facts. (11) In requirement R1, we suggest changing “in accordance with EOP-004-2 Attachment 1” to “to report events identified in EOP-004-2 Attachment 1”. It makes more sense since the attachment is a list of events that require reporting. The other language sounds like additional requirements will be established in Attachment 1.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Southwest Power Pool Regional Entity</p>	<p>(1) SPP RE thinks the following Generation reporting threshold is unclear: "Total generation loss, within one minute, of ¥ 2,000 MW for entities in the Eastern or Western Interconnection". What has to happen within one minute? It reads as if you have to make a report within one minute. If the intent is that a report has to be made within 24 hours if the loss is for more than one minute it should read, "Total generation loss ¥ 2,000 MW for more than one minute for entities in the Eastern or Western Interconnection". What is the intent of the one minute requirement?</p> <p>(2) It appears per R1 that entities are no longer required to include Regional Entities in their reporting chains. SPP RE believes Regional Entities must be included in the reporting chain so they can fulfill their obligations under their delegation agreements.</p> <p>(3) SPP RE thinks this standard was changed substantially enough that it should have been opened for a new ballot pool.</p>

Organization	Question 3 Comment
	<p>Response: Thank you for comment. 1) The intent of the “one minute” language is to avoid having to report when a generator has a slow run back rather than a sudden loss. Typically, a unit will trip instantly and the loss will be clear. Other times, the generation will slowly decline and the SDT does not intend for this to be reported. The reporting requirement is to submit a report for an applicable event within 24 hours. 2) Entities are required to report to the ERO only and may submit reports to others, including the RE. The SDT envisions the reports generated through EOP-004-2 act as an input to the Events Analysis Process which includes participation by the Regional Entity. 3) The SDT followed the standards development process which allows significant revision to the standards as long as it proceeds to a successive ballot. The NERC Standard Processes Manual clearly states that a ballot pool stays in place until balloting is completed on a standard. On occasion, the Standards Committee has determined that it is necessary to form a new ballot pool for a project because the ballot pool has been in place for several years and many of the original ballot pool members are no longer available to vote, but this is not the normal practice.</p>
<p>Ameren Services</p>	<p>(1) This draft refers to a number of activities in the Operations Plan that each entity is to have on hand as the primary guide of actions to be taken when an event occurs. Although there is information related to the requirements that should be included in the Operations Plan, the drafting team has not defined a structure on the format, the minimum information to be included or the direct audience for the Operations Plan. In addition, there is no guidance on the disposition, distribution of the Operations Plan which is left to the entity to determine. We request that the drafting team provide a defined structure for entities concerning the development and implementation of the Operations Plan.</p> <p>(2) Page 14 (Attachment 2) - Voltage Deviation of a Facility - This appears to be a contradiction to VAR-001-2 R10 for TOP which states IROL events will be corrected within 30 minutes. We request the 15 minute reporting criteria be changed to also state 30 minutes.</p> <p>(3) Throughout Document - "Report to the ERO and Regional Entity" - NERC and DHS established the ES-ISAC as a confidential location to report all events that happen on the BES. As these events are of a Sabotage / Disturbance nature, they should all go through the ES-ISAC both as a single location for distribution, and as a best practice that the industry has started.</p> <p>(4) There seems to be some differences between the red-line and clean versions which may need some clarification. For example, (a) In the redline version, the revision history box appears to indicate the inclusion of parts of CIP-008, and in the “Clean” version this has been</p>

Organization	Question 3 Comment
	<p>removed from the revision history box. (b) The red-line version includes a drawing at two places versus once in the clean version. (c) The correlation between the clean and redline documents is not very clear and there appears to be gaps in the reporting and tracking framework structure.</p>
<p><b>Response: Thank you for comment. 1)-3) Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot. 4) In removing tables and diagrams, the redline version tends to show both the old and new with only a red line down the side of the page. The clean version of the standard is the final version.</b></p>	
<p>Texas Reliability Entity</p>	<p>(A) Regional Entity should be capitalized in R1. (B) COMMENTS ON ATTACHMENT 1:In the previous comment period on this Standard, Texas RE submitted comments that we feel were not adequately addressed. There were several responses to comments regarding the Events Table that need deeper review and consideration:(1) In the Events Table, under Transmission Loss, the SDT indicated that reporting is triggered only if three or more Transmission Facilities operated by a single TOP are lost. Also, generators that are lost as a result of transmission loss events must be included when counting Facilities. As Texas RE indicated in previous comments to this Standard, determining event reporting requirements by the entity that owns/operates the facility is not an appropriate measure. If the industry wants to learn from events, these types of issues must be addressed. Including the RC as one of the Entity(s) with Reporting Responsibility may alleviate this concern. The RC would have overall view of the system and could provide the reports on multi-element events where the elements are owned/operated by different entities. For the SDT to believe that “There may be times where an entity may wish to report when a threshold has not been reached because of their experience with their system” is worthy to note but falls short of the reliability implications caused by those entities that will not report. The industry needs to learn from events and failure to report will facilitate failure to learn.</p> <p>(2) In the Events Table, under Transmission Loss, there has been considerable discussion</p>

Organization	Question 3 Comment
	<p>recently within the Events Analysis Subcommittee (EAS) regarding the definition of the phrase “contrary to design.” The EAS is currently working on possible guidelines to interpret this event type. The SDT may want to consider including the EAS language into the Guidelines and Technical Basis for this Standard.</p> <p>(3) In the Events Table, under “Unplanned BES Control Center evacuation” and “Complete loss of voice communication capability,” and “Complete loss of monitoring capability,” GOPs should be included. GOPs also operate control centers that would be subject to these kinds of occurrences. As Texas RE indicated in previous comments to this Standard, in CIP-002-5 Attachment 1 there is a “High Impact Rating” for the following: “1.4 Each Control Center, backup Control Center, and associated data centers used to perform the functional obligations of the Generation Operator that includes control 1) for generation equal to or greater than an aggregate of 1500 MW in a single Interconnection or 2) that includes control of one or more of the generation assets that meet criteria 2.3, 2.6, and 2.9.” In the ERCOT Region, we experienced an event where a GOP control center lost an ICCP link that carried real-time information regarding its generation fleet (over 10,000 MWs). Without inclusion of the GOP here the event may not get recorded. While it was a “virtual” loss, the impact to the BES through generation control actions could be significant and the event should be reported and analyzed. For the GOP control centers that do exist, the reporting of such events should be a requirement. Based on the minimum of these two examples, why would the SDT NOT include GOP as being applicable?</p> <p>(4) In the Events Table, under “BES Emergency requiring public appeal for load reduction,” the definition of Emergency is “Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities....” Is it the intent of the SDT to exclude public appeals issued in anticipation of a possible emergency, before a BES Emergency is officially declared?</p> <p>(5) In the Events Table, under “BES Emergency resulting in automatic firm load shedding,” the SDT may want to consider including the RC as one of the Entity(s) with Reporting Responsibility. The RC would have overall view of the system and should provide the reports on events where the multiple entities may be involved. We have UVLS schemes in our region</p>

Organization	Question 3 Comment
	<p>where the total MW shed is greater than 100 MW, but the individual TOP MW shed is less than 100 MW.</p> <p>(6) In the Events Table, consider whether the item for “Voltage deviation on Facility” should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator or power system stabilizer) could have a similar impact on the BES as other reportable items. Note: We made this comment last time, and the SDT’s posted response was non-responsive to this concern. The SDT noted “Further, we note that such events do not rise to the level of notification to the ERO” but the SDT failed to recognize that “Voltage deviation on a Facility” does exactly that - notifies the ERO but from a TOP perspective only. Texas RE is trying to establish the correct Responsible Entity for reporting “Voltage deviation on a Facility” (in this case a generator regardless of the cause and other obligations the owner may have with other Reliability Standards).</p>
<p><b>Response: Thank you for comment. A) The SDT agrees and has made the correction. B) Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Central Lincoln</p>	<p>1) Central Lincoln must again point out the lack of proportionality for gunshot insulators and similar events under “Damage or destruction of a Facility.” Please see our last set of comments. These incidents are fairly common in the west, and typically do not cause an immediate outage. They are generally discovered months after the fact, yet the discovery starts the 24 hour clock running as if the situation had suddenly changed. Prior SDT response: “... this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.” There is already a great lag in awareness regarding the damaged insulator. Months or more can pass prior to discovery by the entity. We fail to see how it becomes so urgent upon discovery. Prior SDT response: “The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.”We do not share the SDT’s</p>

Organization	Question 3 Comment
	<p>vision. If an Operating Plan redefined suspected intentional human action so the act of preparing a gun for firing, aligning the sights on an insulator and pulling the trigger was not included, we believe the entity that operates under that plan would be found non-compliant under the language of this standard. We do not offer a simple change in text that will fix the problem, we are only pointing out the problem exists. Murphy dictates discovery will occur at the most inopportune time, which will be during an after hours outage on a stormy holiday weekend night when many employees are out of town and those that are available are already fully engaged. The entity is then faced with choosing to delay restoration or violating the standard. When proposing a zero defect event driven requirement event driven such as this one, we ask the SDT to consider all possible scenarios in which the event may occur.</p> <p>2) We note that Distribution Providers are listed in the Applicability Section. We also note that there is no requirement in the Statement of Compliance Registry Criteria for Distribution Providers to own or operate BES Facilities, own or operate UFLS or UVLS of 100 MW, or to have load exceeding 200 MW. DP’s that cannot meet any of the thresholds of Attachment 1 would still need an Operating Plan under R1 and annually validate the possibly null contact list in its OP under R3. We suggest that DPs that cannot meet the thresholds of Attachment 1 be removed from the Applicability Section.</p>
<p><b>Response: Thank you for comment. 1) Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p><b>2) To your suggestion on DPs, the SDT has clarified, in the Guidelines and Technical Basis Section of the standard, that DPs who do not meet the threshold reporting requirements can conduct an annual review of the threshold requirements and be exempted from R1 and R3 for that period. Once the DP has met the threshold reporting requirements, they will then have to comply with the standard.</b></p> <p><b>“Distribution Provider Applicability Discussion</b></p> <p><b>The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not</b></p>	

Organization	Question 3 Comment
	<p>all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more that 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.”</p>
<p>Duke Energy</p>	<ol style="list-style-type: none"> <li>1) There are discrepancies between the red-lined EOP-004-2 and the Clean EOP-004-2 that were posted for this project. Our comments are based upon the Clean EOP-004-2.</li> <li>2) Attachment 1 and Attachment 2 have the ERO email and phone number listed. If these ever change, does the standard have to go through the revision and balloting process again, or is there an easier way to incorporate such changes?</li> <li>3) Attachment 1 - When an event occurs that meets the Threshold for Reporting, it’s not clear whether all listed entities have to report or not. Several Event Types need this clarity added. For example, if a TOP loses voice communication capability, do both the TOP and RC have to report?</li> <li>4) Attachment 1 - Damage or destruction of a Facility, applicable to BA, TO, TOP, GO, GOP, DP. The Threshold for Reporting should be further clarified by adding the sentence “Do not report theft or damage unless it degrades normal operation of a Facility.” This would eliminate unnecessary reporting of copper theft or vandalism.</li> <li>5) Attachment 1 - Physical threats to a Facility. The Threshold for Reporting should be modified by deleting the sentence “Do not report theft unless it degrades normal operation of a Facility”. This sentence isn’t needed here, and fits better with “Damage or destruction of a Facility” as noted in 4) above.</li> <li>6) Attachment 1 - Transmission loss. This event type should be deleted because it is duplicated</li> </ol>

Organization	Question 3 Comment
	<p>under TADS reporting and PRC-004 Protection System Misoperations reporting.</p> <p>7) Attachment 1 - Unplanned BES control center evacuation, Complete loss of voice communication capability, and Complete loss of monitoring capability. The Threshold for Reporting on all three of these Event Types is 30 minutes, and should be extended to 2 hours, consistent with the transition time identified in EOP-008 “Loss of Control Center Functionality”.</p>
<p><b>Response:</b> Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
<p>ERCOT</p>	<p>As a general matter, this standard imposes an ex-post reporting obligation. Consistent with the ongoing P 81 standard review/elimination effort, this standard is arguably a candidate for elimination under the principles guiding that effort. The obligation proposed in the standards are better suited for inclusion in the Rules of Procedure or as a guideline because they are strictly administrative in nature.</p> <p><b>Response:</b> On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-</p>



Organization	Question 3 Comment
	<p><b>004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</b></p> <p>To the extent the SDT continues to pursue this effort, ERCOT offers the following additional comments. ERCOT has commented on the listing in the Entity with Reporting Responsibility column of Attachment 1. Consistent with those prior comments, the current version still fails to adequately create a bright line threshold for particular events. For example, in the Transmission loss event, although the TOP is listed, there is no direction regarding which TOP is required to file the event report. Is it the TOP in whose TOP area the loss occurred or is it a neighboring TOP who observes the loss? Clearly, the responsibility for reporting lies with the host system, but that responsibility is not clearly designated. There are several other similar events where there is no bright line. We suggest that the drafting team return the deleted language to the Entity with Reporting Responsibility column in those instances where the current version fails to provide a bright line in the Threshold column. Regarding multiple reports for a single event, that aspect of the proposed draft should be revised to only require a single report. While additional information may be available from others, let the Event Analysis team perform their function. This would eliminate the redundant reporting that is currently required as the standard is written.</p> <p><b>Response: Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p>ERCOT requests that the reference to “cyber attack” be removed from the Guideline and Technical Basis section of the document since all reporting of cyber events has been removed from the standard and retained in CIP-008.</p> <p><b>Response: This correction has been made.</b></p>

Organization	Question 3 Comment
<p><b>Response: Thank you for comment. Please see responses above.</b></p>	
<p>American Public Power Association</p>	<p>As stated in our comments on the previous draft: It is APPA’s opinion that this standard should be removed from the mandatory and enforceable NERC Reliability Standards and turned over to a working group within the NERC technical committees. Timely reporting of this outage data is already mandatory under Section 13(b) of the Federal Energy Administration Act of 1974. There are already civil and criminal penalties for violation of that Act. This standard is a duplicative mandatory reporting requirement with multiple monetary penalties for US registered entities. If this standard is approved, NERC must address this duplication in their filing with FERC. This duplicative reporting and the differences in requirements between DOE-OE-417 and NERC EOP-004-2 require an analysis by FERC of the small entity impact as required by the Regulatory Flexibility of Act of 1980</p>
<p><b>Response: Thank you for the comment. The SDT does not believe that there is duplicative reporting. The reports that you mention do not go to NERC under the FPA. We will forward your suggestion to NERC for consideration in the preparation of the filing for approval.</b></p>	
<p>NV Energy</p>	<p>Aside from the comment referring to the new R3 and the term "validate", I applaud the SDT for the improvements made in the remainder of the Standard. This is a much simpler and straightforward approach to meeting the directives in this project and greatly simplifies the processes necessary on the part of the registered entities.</p>
<p><b>Response: Thank you for your comment.</b></p>	
<p>CenterPoint Energy</p>	<p>CenterPoint Energy appreciates the revisions made to the draft Standard based on stakeholder feedback and believes that the changes made are positive overall. However, the Company recommends the additional changes noted below for a favorable vote. In the Rationale for R1, CenterPoint Energy recommends that the 2nd sentence in the 1st paragraph be revised as follows, “In addition, these event reports may serve as input to the NERC Events Analysis Program.”, as not all events listed in Attachment 1 will serve as input in to the NERC Events Analysis Program. CenterPoint Energy also proposes that the Standard Drafting Team (SDT)</p>

Organization	Question 3 Comment
	<p>add "There cannot be a violation of Requirement R2 without an event." as noted in the Consideration of Issues and Directives to the Requirement. For Attachment 1, CenterPoint Energy recommends the following revisions: CenterPoint Energy continues to be concerned that the uses of the terms “suspicious” and “suspected” are too broad. The Company proposes that the SDT remove the terms from the Thresholds for Reporting or add “which caused a negative impact to the Bulk Electric System” or “that causes an Adverse Reliability Impact...” to each phrase where the terms are used. CenterPoint Energy proposes that the threshold for reporting the event, “BES Emergency requiring manual firm load shedding” is too low. It appears the SDT was attempting to align this threshold with the DOE reporting requirement. However, as the SDT has stated, there are several valid reasons why this should not be done. Therefore, CenterPoint Energy recommends the threshold be revised to “Manual firm load shedding â%¥ 300 MW”. CenterPoint Energy also recommends a similar revision to the threshold for reporting associated with the “BES Emergency resulting in automatic firm load shedding” event. (“Firm load shedding â%¥ 300 MW (via automatic under voltage or under frequency load shedding schemes, or SPS/RAS”) For the event of “System separation (islanding)”, CenterPoint Energy believes that 100 MW is inconsequential and proposes 300 MW instead. For “Generation loss”, CenterPoint Energy suggests that the SDT add "only if multiple units" to the criteria of “1,000 MW for entities in the ERCOT or Quebec Interconnection”.</p>
<p><b>Response:</b> Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
<p>PNGC Comment Group</p>	<p>Comments: The PNGC Comment group remains concerned that the “Applicability” section will inadvertently subject Distribution Providers to requirements that they should be excluded from. Please consider the two examples below and note that we’re talking about probably hundreds of small DPs being subject to these unnecessary requirements without any increase to the reliability of the BES. Example 1: Small DP with a peak load of 50 MWs. They have no</p>

Organization	Question 3 Comment
	<p>BES Facilities and their system is radial. Even though this utility will never have a reporting requirement per Attachment A, they are still subject to R1 and R3 plus the associated compliance (read financial) risk for non-conformance. An easy fix to this issue would be for DPs without BES Facilities and with less than 200 MW annual peak load to be excluded in the Applicability section. Example 2: Small DP with a peak load of 50 MWs. Their only BES Facilities are two Automatic UFLS relays that are capable of shedding 15 MWs. DP's Host Balance Authority (HBA) has a peak load of 10,000 MWs, meaning their UFLS plan requires them to have the capacity to shed 3000 MWs should system conditions warrant. Is it the SDT's intent for this DP to have an Operating Plan in place for "damage", "destruction", or "physical threat" for these two relays that are capable of shedding only 15 MWs out of a 3000 MW HBA UFLS plan? The SDT set a 100 MW threshold for reporting of automatic UFLS load shedding so why have reporting requirements for the threat to 15 MWs worth of UFLS relays? Once again the easy fix is to modify the Applicability section. We suggest: 4.1.7. Distribution Provider: with &gt;= 200 MW annual peak load, or;&gt;= 100 MW Automatic firm load shedding</p>
<p><b>Response:</b> Thank you for comment. To your suggestion on DPs, the SDT has clarified, in the Guidelines and Technical Basis of the Standard, that DPs who do not meet the threshold reporting requirements can conduct an annual review of the threshold requirements and be exempted from R1 and R3 for that period. Once the DP has met the threshold reporting requirements, they will then have to comply with the standard.</p> <p><b>"Distribution Provider Applicability Discussion</b></p> <p>The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the "Threshold for Reporting" for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more that 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan</p>	

Organization	Question 3 Comment
<p>to comply with the requirements of the standard.”</p>	
<p>Cowlitz PUD</p>	<p>Cowlitz approves of the improvement efforts on Attachment 1. However, Cowlitz must again point out the fallacy of potentially inundating the ERO with nuisance reporting of minor vandalism and accidental damage. For example, gunshot “target practice” of insulators and structures will apply under “Damage or destruction of a Facility.” Such incidents are fairly common in the west, and typically do not cause an immediate outage. They are generally discovered months or years after the fact, yet the discovery starts the 24 hour compliance clock running as if the urgency is just as important as a recent event. If there is already a great lag in awareness regarding the damaged Facility, Cowlitz fails to see how it becomes so urgent upon discovery.-----Again, Cowlitz points out the sentence structure “Damage or destruction of its Facility that results from actual or suspected intentional human action” does not restrict the human action as malicious or sabotage. “Intentional human action” could be innocent, such as a land owner attempting to fall a tree for fire wood. The intent was not to damage the Facility, but the “intentional human action” to obtain fire wood resulted in the damage of the Facility. This does not comport with prior SDT response: “... this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was ‘damaged or destroyed’ intentionally by a human.” Therefore, if this is the SDT’s intent Cowlitz suggests this change: Damage or destruction of its Facility that causes immediate impaired operation or loss of the Facility from suspected or actual malicious human intent. Do not report mischievous vandalism, as defined in the Operating Plan, where immediate loss of, or immediate impaired operation of the Facility has not occurred. -----Prior SDT response: “The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.” Cowlitz does not share the SDT’s vision. The Standard as written does not specifically address the ability to “further define” terms used in the Attachment. Past allowance of audit teams to allow registered entity definitions, e.g. “annual,” was to address gaps in standards until the standards could be revised. If this is truly the intent of the SDT, then requirement R1 would need revision such as: “The Operating plan shall define what a suspected intentional human action is.” Cowlitz respectfully requests that ambiguity be avoided.----- Cowlitz notes that Distribution Providers are listed in the Applicability Section with no qualifiers. Cowlitz</p>

Organization	Question 3 Comment
	<p>points out that there is no requirement in the Statement of Compliance Registry Criteria for Distribution Providers to own or operate BES Facilities, own or operate UFLS or UVLS of 100 MW, or to have load exceeding 200 MW. DP’s that cannot meet any of the thresholds of Attachment 1 would still need an Operating Plan under R1 and annually validate the possibly null contact list in its OP under R3. Cowlitz requests that DPs that cannot meet the thresholds of Attachment 1 be removed from the Applicability Section. Not doing so will increase compliance risk without any reliability return.</p>
<p><b>Response:</b> Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p> <p>To your suggestion on DPs, the SDT has clarified, in the Guidelines and Technical Basis Section of the Standard, that DPs who do not meet the threshold reporting requirements can conduct an annual review of the threshold requirements and be exempted from R1 and R3 for that period. Once the DP has met the threshold reporting requirements, they will then have to comply with the standard.</p> <p>“Distribution Provider Applicability Discussion</p> <p>The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more that 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.”</p>	
Wisconsin Electric Power company	Damage or destruction of a Facility, Damage or destruction of its Facility that results from

Organization	Question 3 Comment
dba We Energies	<p>actual or suspected intentional human action.: By the Functional Model, I do not believe the BA function has Facilities by the NERC Glossary definition. This would not apply to a BA. The line above this would adequately cover BA reporting. Remove a BA from applicability for this line.</p> <p>Physical threats to a Facility: The BA function does not have Facilities. Remove a BA from applicability for this line. There could be a separate line for Physical Threats to a Facility within an RC, FOP, BA Area as there is for Damage or Destruction of a Facility. Voltage deviation on a Facility: Please specify what voltage this is, nominal, rated, etc. This should also be &gt; 10% deviation. Exactly at 10% could be at the edge of an allowed range.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
Manitoba Hydro	<p>Does the Background, Guidelines and Technical Basis form part of the standard itself once published? Or are these just parts of the package that accompany the standard during circulation for comment?</p> <p><b>The background, guidance and technical basis will remain with the standard and provides clarification on the SDT’s intent and direction</b></p> <p>Compliance 1.2: The reference to Responsible Entity is bracketed and in lowercase. We are not clear why.</p> <p><b>This was corrected in the clean version.</b></p> <p>VSLs, R1, Severe VSL: The words "in the event reporting Operating Plan" are missing from the end of this sentence.</p> <p><b>This was corrected in the clean version.</b></p>

Organization	Question 3 Comment
	<p>VSLs, R2, Lower VSL: The violation occurs if the Responsible Entity has submitted an event report to one entity whereas Moderate VSL, High VSL and Severe VSL, the level of severity of the VSL increases depending on the number of entities that the Responsible Entity fails to submit an event report to. The drafting here is not as precise as it should be. The way the Lower VSL is written, it will also be triggered when the Responsible Entity has complied with the requirement. For example, if the Responsible Entity is required to report an event to 5 entities, and it does, it will still mean that it has "submitted an event report to one entity identified in the event reporting (also, the 'ing' is missing on the Lower VSL reference)Operating Plan". It is also duplicative. For example, if the Responsible Entity submitted a report to only one entity, and failed to submit a report to 4 others, they fall under the Lower VSL and the Higher VSL (we are assuming in this case, the violation will be found to be the higher VSL). Perhaps what the drafting team intended to do was to make the Lower VSL, which the Responsible Entity failed to submit an event report...to one entity identified....</p> <p><b>The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. The VSLs were written based on two potential failures to meet the requirement. The first is based on the time the report was submitted while the second was based on the entity submitting the report within 24 hours but not to all applicable entities. If a violation is determined, it will be for either being late with the report or for not submitting the report to everyone. The appropriate VSL will be applied ONLY if a violation is found.</b></p> <p>The Guidelines and Technical Basis contain a reference to R4 which no longer exists in the standard.</p> <p><b>This reference has been removed.</b></p>
<p><b>Response: Thank you for comment. Please see responses above.</b></p>	
<p>Dominion</p>	<p>Dominion reads Requirement R1 as explicitly requiring only the inclusion of reporting to the ERO in the Operating Plan. We acknowledge that the requirement also contains additional entities in parenthesis which infers the inclusion of a larger group (and which appears to be supported by the rationale box). Dominion suggests the SDT explicitly state which entities, at a minimum, be included, for reporting, in the Operating Plan. We suggest adding a column to</p>



Organization	Question 3 Comment
	<p>Attachment 1 and including entities to which the event must be reported. As an examples; o All event types should include local law enforcement o Events for which the BA, RC, TOP bear responsibility should probably also be reported to the regional entity o Events for which the Facility Owner bears responsibility should probably also be reported to the respective BA and TOP, who would in turn determine whether to notify their respective RC. The RC would in turn determine if additional entities need to be contacted. Requirement R2 establishes a 24 hour reporting threshold; however, the “NOTE” provided on Attachment 1 seems to contradict Requirement 2 and could therefore lead to compliance issues. Dominion suggests that Requirement R2 be revised to agree with the “NOTE” on Attachment 1. For example, Requirement R2 could be reworded as: Except as noted on Attachment 1, Each Responsible Entity shall...Also under the “NOTE” in Attachment 1, why has the facsimile number for the ERO been removed? The DOE still provides a facsimile number for reporting. Attachment 2: Event Reporting Form #4; need to update the below to reflect the same naming convention of the events in Attachment 1, the “t” should not be capitalized in Physical Threat and add an ‘s’ behind threat. Add (islanding) behind System separation and capitalize the ‘U’ in unplanned control center evacuation.</p>
<p><b>Response:</b> Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
<p>Southern Company</p>	<p><b>NOTE:</b> The SDT received assistance from Southern Company personnel in parsing these comments as show below. As submitted, the formatting of the original comments was lost and very difficult for the SDT to read and understand.</p> <p>Event Type Entity with Reporting Responsibility Threshold for Reporting SOCO Comment:</p> <p><b>Damage or destruction of a Facility</b> RC, BA, TOP Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area, excluding weather or natural disaster related threats, that results in actions to avoid a BES</p>

Organization	Question 3 Comment
	<p>Emergency. – No Comment</p> <p><b>Damage or destruction of a Facility</b> BA, TO, TOP, GO, GOP, DP Damage or destruction of its Facility that results from actual or suspected intentional human action.:</p> <p>Do not report damage unless it degrades normal operation of a Facility.</p> <p>How does the SDT define “intentional human action?” Further, how is the phrase “suspected intentional human action” defined? This phrase is very broad. Is “intentional human action” identified as actions intended to damage facilities or does it include accidental actions by individuals? For example, if a person accidentally shot insulators off of a 230 kV line resulting in damage, would that be considered reportable “intentional human action?”</p> <p>In addition, what is that actual trigger for reporting? Does it require that the action has been discovered or is it from the time the event occurs? Further, 24 hours is a very brief time period -- how is an entity to conduct an investigation within that time period to determine if damage or destruction could have resulted from “actual or suspected” human action and also determine if it could have been “intentional”?</p> <p>In Southern’s cases, and likely in other entities case, operating personnel submit the reports to the regulatory entities for events that fall under this standard. Southern is concerned, that the threshold for reporting for “Damage or destruction of a Facility” and “Physical threats to a Facility” is so broad that numerous reports would need to be filed that 1) may be a result of something that does not pose harm to reliability and should not be of interest to the regulators, and 2) would introduce additional burden to operating personnel that are monitoring the system every moment of the day. With the current proposed “Threshold for Reporting”, the reporting requirement would hamper the ability of system operating personnel to perform their core real-time system operator tasks which would harm reliability.</p> <p><b>Physical threats to a Facility</b> BA, TO, TOP, GO, GOP, DP Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility. OR Suspicious device or activity at a Facility. Do not report theft</p>

Organization	Question 3 Comment
	<p>unless it degrades normal operation of a Facility.</p> <p>Please provide some clarity as to what is considered suspicious activity. For example, would someone taking a photo of a BES substation fall into this category? Please provide examples of what may be considered suspicious activity and how NERC and others may use this information and what actions they would take as a result of receiving this information.</p> <p>In addition, what is that actual trigger for reporting? Is it when the threat is discovered or from when it should have or could have been discovered? Further, 24 hours is a very brief time period -- how is an entity to conduct an investigation within that time period in order to determine if the physical threat has the potential to degrade the normal operation of the Facility or that the “suspicious activity”?</p> <p><b>Physical threats to a BES control center</b> RC, BA, TOP Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center. OR Suspicious device or activity at a BES control center. – No Comment</p> <p><b>BES Emergency requiring public appeal for load reduction</b> Initiating entity is responsible for reporting. Public appeal for load reduction event.</p> <p>It is unclear which entity would be responsible for reporting this event. For example, if the RC/TOP/BA were to identify the need to do this and instruct an LSE to issue the public appeal, who would report the event?</p> <p><b>BES Emergency requiring system-wide voltage reduction</b> Initiating entity is responsible for reporting System wide voltage reduction of 3% or more.</p> <p>It is unclear which entity would be responsible for reporting this event. For example, if the RC were to identify the need to do this and instruct a TOP to reduce voltage, who would report the event?</p> <p><b>BES Emergency requiring manual firm load shedding</b> Initiating entity is responsible for reporting Manual firm load shedding ≥ 100 MW. – No Comment</p>

Organization	Question 3 Comment
	<p><b>BES Emergency resulting in automatic firm load shedding</b> DP, TOP Automatic firm load shedding <math>\hat{\%}\approx 100</math> MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS). – No Comment</p> <p><b>Voltage deviation on a Facility</b> TOP Observed within its area a voltage deviation of <math>\pm 10\%</math> of nominal voltage sustained for <math>\geq 15</math> continuous minutes. Please change “nominal” to “expected” or “scheduled”</p> <p><b>IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)</b> RC Operate outside the IROL for time greater than IROL Tv (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only). – No Comment</p> <p><b>Loss of firm load</b> BA, TOP, DP Loss of firm load due to equipment failures/system operational actions for <math>\geq 15</math> Minutes: <math>\geq 300</math> MW for entities with previous year’s demand <math>\geq 3,000</math> MW OR <math>\geq 200</math> MW for all other entities This should not be as a result of weather or natural disasters.</p> <p><b>System separation(islanding)</b> RC, BA, TOP Each separation resulting in an island <math>\hat{\%}\approx 100</math> MW – No Comment</p> <p><b>Generation loss</b> BA, GOP Total generation loss, within one minute, of <math>\hat{\%}\approx 2,000</math> MW for entities in the Eastern or Western Interconnection OR <math>\hat{\%}\approx 1,000</math> MW for entities in the ERCOT or Quebec Interconnection – No Comment</p> <p><b>Complete loss of off-site power to a nuclear generating plant (grid supply)</b> TO, TOP Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement – No Comment</p> <p><b>Transmission loss</b> TOP Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing). – No Comment</p> <p><b>Unplanned BES control center evacuation</b> RC, BA, TOP Unplanned evacuation from BES control center facility for 30 continuous minutes or more. – No Comment</p>

Organization	Question 3 Comment
	<p><b>Complete loss of voice communication capability</b> RC, BA, TOP Complete loss of voice communication capability affecting a BES control center for 30 continuous minutes or more. – No Comment</p> <p><b>Complete loss of monitoring capability</b> RC, BA, TOP Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (i.e., State Estimator or Contingency Analysis) is rendered inoperable. – No Comment</p> <p><b>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b> Guideline and Technical Basis Comments</p> <p>In the Summary of Key Concepts section of the Guideline and Technical Basis, the DSR SDT explains that the proposed Standard does not include any real-time operating notifications for events listed in Attachment 1. The DSR SDT should consider language in the Standard which codifies this approach. Southern Company notes that the proposed standard does not mention any exclusion of real-time notification.</p> <p><b>Response: The SDT does not believe that this revision is necessary as the requirement R2 clearly states that events are to be reported within 24 hours.</b></p> <p>The Law Enforcement Reporting section of the Guideline and Technical Basis unintentionally expands on the purpose of the Standard by stating that “The Standard is intended to reduce the risk of Cascading events.” The stated purpose of the Standard is “To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.” The phrase in the Guideline should be removed or modified in order to avoid any uncertainty about the Standard’s purpose.</p> <p><b>Response: The SDT has made the requested clarification to the Guidelines and Technical Basis section.</b></p>

Organization	Question 3 Comment
	<p>The DSR SDT should consider integrating the content of the Concept Paper into the Guideline and Technical Basis. Presently, the Concept Paper appears as an add-on at the end of the document. When the Concept Paper existed as a stand-alone document, various segments such as “Introduction” and “Summary of Concepts and Assumptions” were helpful to stakeholders and standards developers. The revised merged document in the present draft does not need two separate sections addressing concepts nor does it need an introduction at the midway point. Additionally, two other areas are either duplicative or contribute to ambiguity within the supplemental information. First, it is not clear that the segment on Concepts and Assumptions includes any actual assumptions. The section should be modified or deleted to address this concern. Second, the segment entitled ‘What about sabotage?’ seems to contain topics similar to those on the first page of the Guideline. Again, the DSR SDT should consider integrating all of the necessary information into a more comprehensive document.</p> <p><b>Response: The SDT has chosen to leave these sections in tact because it helps convey the development process as well as the information about the team’s insights.</b></p>
<p><b>Response: Thank you for comment. Please see responses above.</b></p>	
FirstEnergy	<p>FirstEnergy Corp (FE) appreciates the work done by the SDT by incorporating the comments and revisions from the previous draft. FE would like to see the time parameters in Requirement 3 and Measure 3 to be changed from “each calendar year” to “at least once every 12 months”. This is similar to the wording that is being used in the CIP standards</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
Oncor Electric Delivery	<p>For reporting consistency, under the Event Type labeled “Generation Loss”, in Appendix 1 of EOP-004-2, Oncor recommends that the reporting threshold of 1,000 KW for the ERCOT Interconnection be raised to 1,400 MW to match the 1,000 MW level in the current version of</p>

Organization	Question 3 Comment
	<p>the ERO Event Analysis Program.</p> <p>Under the Event Type labeled “Damage or Destruction of a “Facility”, Appendix 1, with the threshold that states, “ Damage or destruction of its Facility that results from actual or suspected intentional human action”, Oncor suggest the addition of the following language to address intentional human action that is theft in nature but is not intended to disrupt the normal operation of the BES: “Do not report theft unless it degrades the normal operation of a Facility.”</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Georgia Transmission Corporation</p>	<p>GTC recommends a minor change to Attachment 2 associated with the complete loss of off-site power to nuclear generating plant. NUC-001-2 R9.3.5 describes provisions for restoration of off-site power and applies to both the Nuclear Plant Generator Operator and the applicable Transmission Entities. To maintain consistency, GTC recommends modification to this row in EOP-004-2 Attachment 2 such that the “Nuclear Plant Generator Operator” is the Responsible Entity with reporting responsibility. (A TO may not have visibility to all off-site power resources for a nuclear generating plant if multiple TO’s are providing off-site power.)At a minimum, GTC recommends if the SDT believes the TO and TOP should remain involved, these entities should be limited to “TO and TOP that are responsible for providing services related to Nuclear Plant Interface Requirements (NPIRs)” which is also consistent with NUC-001-2.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	

Organization	Question 3 Comment
South Carolina Electric and Gas	<p>Has the drafting team considered how reports from R2 tie in with reports required by the NERC Event Analysis process? It appears that reporting deadlines conflict between the two. The SDT should clarify that the event types "Damage or Destruction" listed in attachment 1 do not pertain to "cyber events", to avoid duplication of the CIP-008 requirements.</p>
<p><b>Response: Thank you for comment. Reporting under this standard is for the notification of events to the NERC Situation Awareness Group. Reports in this standard can be the initial reports for the EA group, but are not designed to address the balance of the EA program. The SDT had removed the cyber security obligations in this draft.</b></p>	
Xcel Energy	<p>In attachment one, the “Threshold for Reporting” under Damage or Destruction of a Facility appears to closely follow the definition of sabotage that EOP-004-2 says it is trying to do away with. This definition should be drafted to better correlate with the other physical threats and include the language, “which has the potential to degrade the normal operation of the Facility”.</p> <p>Additionally in Attachment 1, both the Physical threats to a Facility and Physical threats to a BES control center include the wording, “Suspicious device or activity...”. What constitutes suspicious activity? With no definition this interpretation is left to the Entity which is again something the DSR SDT says they would like to eliminate.</p> <p>Lastly, in the Guideline and Technical Basis section, under A Reporting Process Solution - EOP-004 it states, “A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.” This appears to be in direct conflict with the Rationale for R1 which states, “An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.”</p>



Organization	Question 3 Comment
	<p>CIP-001-2a required “communication contacts, as applicable, with local Federal Bureau of Investigation (FBI)...” so if the CIP-001-2a procedure is included this does not seem to meet the requirements of the operating plan required under EOP-004-2. Also, if the intent of the Operating Plan is to include all local law enforcement and not FBI the operating plan would become very detailed and when validated annually as required in R3, this becomes very burdensome on an entity.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>American Electric Power</p>	<p>In the spirit of Paragraph 81 efforts, we request the removal of R1. R1 is administrative in nature, existing only to support R2. Reporting an event externally might necessitate the need for a plan/procedure/policy/job aide, but requiring it is an overreach. Having two requirements rather than one increases the likelihood of being found non-compliant for multiple requirements rather than a single requirement. The Paragraph 81 project team has already recommended removing the requirement to have contact information with law enforcement from CIP-001 R4. Notwithstanding our comments above, we recommend removing the phrase “and other organizations...” from R1. If this requirement is to remain, it needs to be very specific regarding who needs to be included in the reporting.R2 –</p> <p>We recommend removing “per their Operating Plan” from R2 so it reads “Each Responsible Entity shall report events within 24 hours of meeting an event type threshold for reporting.” If an entity deviates from its plan but still meets the intent of the requirement (e.g. reporting to NERC with 24 hours), this could be viewed as a finding of non-compliance. We need to get away from “compliance for compliance’s sake”, and focus solely on those efforts which will benefit the reliability of the BES.</p> <p>Attachment 1 Page 13, Row 1 (Clean Version): This is too open-ended and would likely lead to voluminous reporting. As it currently reads, “Damage or destruction of a Facility within its</p>

Organization	Question 3 Comment
	<p>Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency” could bring all copper thefts into scope. Thefts should not need to be reported unless the theft results in reliability concerns as specified by other criteria or parameters in Attachment 1.</p> <p>Attachment 1 Page 13, Row 2 (Clean Version): The threshold “Damage or destruction of its Facility that results from actual or suspected intentional human action” should be eliminated entirely. For the event Damage or destruction of a Facility, the threshold for reporting is set too low.</p> <p>Attachment 1 Page 13, Row 3 (Clean Version): We suggest modifying the text to read “Do not report theft... unless the theft results in reliability concerns as specified by other criteria or parameters in Attachment 1.”</p> <p>Attachment 1 Page 14, Row 4 (Clean Version): Regarding “Loss of Firm Load”, we suggest making it clear that the MW threshold is an aggregate value for those entities whose TOP is responsible for multiple operating companies or legal entities. In addition, is it necessary to include the DP as an entity with reporting responsibility? Its inclusion could create confusion by further segmenting the established threshold.</p> <p>Attachment 1 Page 15, Row 1 (Clean Version): Including “Transmission loss” as currently drafted would result in much more reporting than is necessary or warranted. As currently drafted, it could bring more events into scope than intended, especially for larger entities.</p> <p>EOP-004 Attachment 2: Event Reporting Form: AEP remains concerned that industry would be required to report similar information to multiple Federal entities, in this case to both NERC (Attachment 2) and the DOE (OE-417). In addition, the reporting requirements are not clear for every kind of event as to which entity the reports must be forwarded to, and it is unclear how information would be passed to other entities as necessary.</p> <p>EOP-004 Attachment 2: Event Reporting Form: This form is a further example of mixing security concepts with operational concepts. Not only is not advisable, it does not serve the interests of either concept.</p>

Organization	Question 3 Comment
	<p>Response: Thank you for your comment. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration. As the Paragraph 81 efforts are beyond the scope of this project, the SDT can only pass along your suggestion to that project team for action there.</p> <p>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>
<p>Midwest Independent Transmission System Operator, Inc.</p>	<p>MISO respectfully submits that several of the thresholds for reporting in EOP-004 - Attachment 1 should be modified to clarify when the reporting obligation is triggered, and to ensure that entities are reporting events of the type and significance intended. In particular, MISO focuses on the following draft thresholds in EOP-004 - Attachment 1:</p> <ul style="list-style-type: none"> <li>o The requirement that an entity report when “[d]amage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency.” A BES Emergency is defined as “Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System.” RCs and BAs take actions each and every day to “avoid a BES Emergency.” At the time of those actions, they are reacting to conditions that their operating personnel are observing on the</li> </ul>

Organization	Question 3 Comment
	<p>BES. There is no way for an RC or a BA to discern whether the conditions to which they reacted resulted from the “damage or destruction of a Facility” and there is no requirement for Transmission Operators and/or Owners to report “damage or destruction of a Facility” to their BA or RC. Accordingly, RCs and BAs will likely, often not be sufficiently informed to determine if their actions require them to submit a report. Responsible entities are likely to expend significant time and resources reporting daily operations and actions routinely taken to respond to observed BES conditions as they present themselves. These actions may be in response to congestion, equipment outages, relay malfunctions, etc. Whether or not the initiating factor was “damage to or destruction of a Facility” will often be an unknown factor and - even if such is known - the genesis of that damage and/or what constitutes damage (as discussed below) present further potential for confusion and over-reporting. Nonetheless, the lack of clarity in the standard is likely to result in some RCs and BAs preparing reports whether or not they definitely ascertain the underlying cause for the system conditions that prompted them to take actions “to avoid a BES Emergency.” The preparation and submission of such reports, in many cases, will not facilitate the stated objective of this standard, which is the improvement of the reliability of the Bulk Electric System. In addition, with respect to damage or destruction of a Facility, it is debatable as to what would be considered “damage.” For example, would an improper repair or outage that results in damage to a Facility that requires a more extended repair or outage be deemed “damage” to that Facility under this standard? These ambiguities will likely result in significant over-reporting, over-burdening responsible entities, and inundating Regional Entities and NERC with information that is not useful for the purpose of facilitating the reliable operation of the Bulk Electric System. These effects would undermine the express purpose of the standard and the potential value of information if the reporting obligations are appropriately defined, assigned, and scoped. For these reasons, MISO recommends that the SDT revise the standard to: (1) remove the requirement for RCs and BAs to report the “damage or destruction of a Facility” as it is redundant of the immediately subsequent requirement, (2) to remove reporting responsibility from BAs to report the “damage or destruction of a Facility” as this obligation is more properly placed with the TO, TOP, GO , GOP, and DP, and (3) provide guidance to the remaining responsible entities, TO, TOP, GO , GOP, and DP, regarding when “damage” to a Facility should be reported, e.g., an illustrative list of the types of “damage” that would yield information and/or trends that</p>

Organization	Question 3 Comment
	<p>would facilitate the improvement of the reliability of the BES.</p> <p>o The requirement to report “[p]hysical threats to a Facility” and/or “[p]hysical threats to a BES Control Center” With respect to physical threats to Facilities or BES Control Centers, what is considered a “physical threat” and/or a “suspicious device or activity”? Is a crank call count that the building is on fire a physical threat? Is the return of a disgruntled employee suspicious? MISO understands and supports the reporting and analysis of threats and even certain types of suspicious activities, etc. It is merely concerned that the reporting threshold expressed in this standard will result in the reporting of substantial amounts of data that will not facilitate the improvement of the reliability of the BES and that the volume of reports may delay or otherwise obscure the detection of notable trends. Accordingly, MISO recommends that the SDT revise the standard to: (1) require the reporting only of substantial physical threats that are likely to have an adverse impact on the reliable operation of the Bulk Electric System, and (2) to provide an illustrative list of the types of “suspicious activity or devices” as guidance to responsible entities.</p> <p>o Timing of reports Finally, MISO respectfully suggests that NERC re-assess the timing requirements as related to the objectives expressed within this standard. MISO believes that NERC should clarify that its “situational awareness” staff will review submitted information to determine whether there are indications of possible coordinated attack and to quickly inform responsible entities that there are signals of possible coordinated attack. This clarification could be made in the standard, or the standard could describe the process that NERC staff will use. Unless such review and information is provided, the need that the standard attempts to address will not be fully met. Conversely, many of the events listed in Attachment A that require reporting do not need to be reported within 24 hours and would not offer significant benefit or value if reported within that time period as NERC and Regional Entities primarily utilize such information to capture metrics or perform after-the-fact events analysis. Accordingly, MISO respectfully suggests that, while performing analysis to determine clarifications that would result in the appropriate definition, assignment, and scope of reporting obligations, NERC should also examine the events and identify those events for which a longer time period for reporting would be suitable. This would significantly reduce the administrative burden on responsible entities and likely result in more comprehensive,</p>

Organization	Question 3 Comment
	<p>rigorous, and beneficial reporting.</p>
	<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>
<p>Indiana Municipal Power Agency</p>	<p>On page 6 of 23 of the draft standard document, second paragraph under Rationale for R1, the SDT uses the words “Every industry participant that owns or operates elements or devices on the grid has a formal or informal process...” The use of these words implies that this requirement and others in this standard may apply to every industry entity regardless if they are a registered entity or not. IMPA understands that standards can only apply to entities that are registered with NERC, but we still prefer to see different wording in this sentence. IMPA recommends using “Every registered entity that owns or operates elements or devices on the grid has a formal or informal process...”</p> <p><b>We have revised “industry participants” to Registered Entity”.</b></p> <p>Another concern is on pages 18, 19, and 20 of 23. It is not clear what exactly is required of a registered entity and the law enforcement reporting process. IMPA understands it is up to the entity to decide just how its event reporting Operating Plan is made up and who is contacted for the events in attachment 1. These pages are confusing when it comes to the listing of stakeholders in the reporting process on page 18 of 23 and then when the SDT states that an entity may just notify the state or provincial or local level law enforcement agency. The SDT needs to clarify that the listing of stakeholders on page 18 of 23 is just a suggestive listing and that if the entity so decides per its reporting Operating Plan that notification of the local law enforcement agency is sufficient (the thought that the local law enforcement agency can coordinate with additional law enforcement agencies if it sees the need). The requirement to contact the FBI in CIP-001 is not a requirement in EOP-004-2 unless the registered entity puts that requirement in its event reporting Operating Plan.</p> <p><b>The information on law enforcement in the Guidelines and Technical Basis section is</b></p>

Organization	Question 3 Comment
	<p>designed to provide <i>one</i> example of how an entity <i>could</i> report to law enforcement. It is not intended to be the <i>only</i> possible way.</p> <p>As a clarification, in the Background section’s second paragraph, it should read “retiring both EOP-004-1 and CIP-001-2a” as opposed to CIP-002-2a as written above in this comment document.</p> <p>We have searched the comment form and cannot find this.</p>
<p><b>Response: Thank you for your comment. Please see responses above.</b></p>	
<p>Cogentrix Energy</p>	<p>Overall: The standard makes good stride in eliminating the redundancy of CIP-001 and EOP-004. M1 States: “... and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1”. It is unclear in the statement that the protocols go with Attachment 1 and entities to receive report are part of Attachment 2. While this draft is an improvement on the previous draft, the proposed R2 is unacceptable, and should be amended to, at a minimum, require reporting by the end of the next business day, instead of within 24 hours. Events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator’s burden, which reduces the operator’s effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. For some event types where in order to provide real time situational awareness over a wide area (for example coordinated sabotage event) it may be appropriate to have more timely reporting. If the intent of this standard is to address sabotage reporting there needs to be an understanding of the actions to be taken by those receiving the reports so the reporting entities can incorporate those actions into their plan. As a minimum, NERC should have a process in place to assess the reports and take appropriate actions.</p> <p>Attachment 1: Threshold for reporting should not be defined such that multiple reports would be required for the same event. For example, both the TOP and RC being required to report</p>

Organization	Question 3 Comment
	<p>the outage of a transmission line.</p> <p>2nd event type (Damage or destruction of a Facility): Add the following sentence to the Threshold for Reporting: “Do not report theft or damage unless it degrades normal operation of a Facility.”</p> <p>4th event type (Physical threats to a BES control center): The term “BES control center” needs to be clarified.</p> <p>5th, 6th, and 7th event types: In instances where a reliability directive is issued, is the “initiating entity” the entity that issues the directive or the entity that carried out the directive.</p> <p>9th event type (Voltage deviation on a Facility): Change “nominal” to “expected or scheduled.”</p> <p>15th event type (Transmission loss): It is not clear what is meant by “contrary to design.” This is so broad that it could be interpreted as requiring reporting misoperations within the reporting time frame before even an initial investigation can begin. This needs to be clarified and tied to the impact on the reliability of the BES.</p>
<p><b>Response:</b> Thank you for your comment. The full Measure M1 states: “Each Responsible Entity will have a dated event reporting Operating Plan that includes, but is not limited to the protocol(s) and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1 and in accordance with the entity responsible for reporting.” It is expected that the Operating Plan will contain the entities to which a report will be submitted. The Measure indicates evidence needs to be provided showing that these entities received the event report. The protocol(s) refer to the Operating Plan and could include any procedures for identification of events as well as communicating to other entities.</p> <p>In response to your suggestion on Requirement R2, the DSR SDT has added clarifying language to R2 as follows:</p> <p><b>R2.</b> Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</p> <p>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation</p>	



Organization	Question 3 Comment
ballot.	
Northeast Power Coordinating Council	Paragraph 81 efforts are underway to eliminate requirements that have little or no reliability benefit. This Standard only addresses documentation and has no impact on reliability.
<p><b>Response:</b> Thank you for your comment. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the Paragraph 81 efforts are beyond the scope of this project, the SDT can only pass along your suggestion to that project team for action there.</p>	
Puget Sound Energy Inc.	<p>Puget Sound Energy appreciates the Standard Drafting Team's work to streamline and clarify the proposed standard. In addition, we understand that the Standard Drafting Team faces a significant challenge in developing workable thresholds for reporting under this standard. Unfortunately, Puget Sound Energy cannot support the proposed standard because the reporting thresholds remain too vague and, thus, too broad - especially those related to damage or destruction of a Facility and those related to physical threats. The first four events listed on Attachment 1 are not brightline rules, because they each involve significant elements of judgment and interpretation. An example of our concern relates to the phrase "... that results from actual or suspected intentional human action." Puget Sound Energy, like many regulated entities, is staffed only with System Operators at night and on weekends. As a result, the 24-hour reporting requirement necessarily requires the System Operators to submit the required reports. So, how is a System Operator going to judge whether a human action is "intentional"? As a result, it will be necessary to report any event in which human action is</p>

Organization	Question 3 Comment
	<p>involved because there is no way for a System Operator to know for sure whether the action is intentional or not. And, regulated entities will need to instruct their System Operators to make such reports, because the failure to submit a report of even one event listed in EOP-004 Attachment 1 is assigned a severe VSL under the proposed standard. We believe that the proposed threshold language will likely result in a flood of event reports that will not improve situation awareness.</p>
	<p><b>Response:</b> Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p> <p>In response to your concern on the 24-hour reporting requirement, the DSR SDT has added clarifying language to R2 as follows:</p> <p><b>R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</b></p>
<p>Exelon Corporation and its affiliates</p>	<p>Thanks to the drafting team for all the work on this revision. Significant progress was made, though Exelon has some remaining comments:</p> <ul style="list-style-type: none"> <li>o It’s not clear why the team separated ‘Damage or destruction of a Facility’ into two rows. Please advise.</li> </ul> <p><b>Response:</b> The first row applies to the RC, which may not own any Facilities but has them under their operational control. This event applies to damage or destruction whereby the RC, TOP or BA has to take action to avoid a BES Emergency. The second row is simply damage or destruction of a Facility. It is expected that this second type of event would not be severe enough to have to take action to avoid a BES Emergency.</p> <ul style="list-style-type: none"> <li>o Damage or destruction of a Facility - The threshold for "damage or destruction of a Facility"</li> </ul>

Organization	Question 3 Comment
	<p>is too open-ended without qualifying the device or activity as “confirmed”. Event reporting for nuclear generating units are initiated when an incident such as tampering is "confirmed". EOP-004 should include some threshold of proof for a reason to believe that no other possibility exists for "damage or destruction of a facility" event other than actual or suspected intentional human action.</p> <p><b>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p>o Physical threats to a Facility - Reporting of every “suspicious activity” such as photographing equipment or site could result in an unwieldy volume of reports and dilute the data from depicting quality insight. For example, nuclear generating units are required to report all unauthorized and/or suspicious activity to the NRC. Please confirm that the intent of this threshold for notification would include all unauthorized and/or suspicious activity.</p> <p><b>The SDT concurs that the intent of the threshold for notification would include all unauthorized and/or suspicious activity.</b></p> <p>o Physical threats to a BES control center - please confirm that reporting responsibility falls to the RC, BA, TOP and not GOs. In addition, please confirm that by use of the lower case “control center” other definitions in development through other standards development projects (e.g. CIP version 5) and that may be added to the NERC Glossary will not apply until formally vetted in a future EOP-004 standards development project.</p> <p><b>The entities listed for this event type are the RC, BA and TOP only. No other entities are applicable for this event type. If the lower case “control center” is replaced by a definition developed in future standards actions, a change to EOP-004-2 to use the defined term would require notice to the industry and a ballot of the revised standard in some manner. The DSR</b></p>

Organization	Question 3 Comment
	<p><b>SDT does not have control over how that would be accomplished.</b></p> <ul style="list-style-type: none"> <li>o Loss of firm load - “Loss of firm load for 15 Minutes: 300 MW for entities with previous year’s demand 3,000 MW”. Please clarify whether the team intends for this to apply to a single event a loss of more than 300 MW due to non-concurrent multiple distribution outages that total &gt; 300MW.</li> </ul> <p><b>This event relates to a single incident of the loss of firm load.</b></p> <ul style="list-style-type: none"> <li>o Generation loss - Exelon appreciates the timing clarification added to the generation loss threshold. The phrase “within one minute” should also be included in the threshold for the ERCOT and Quebec Interconnections to read: “Total generation loss, within one minute, of 2,000 MW for entities in the Eastern or Western Interconnection OR Total generation loss, within one minute, of 1,000 MW for entities in the ERCOT or Quebec Interconnection”</li> </ul> <p><b>The phrase “within one minute” applies to everything listed in the event. To clarify this, we have inserted a colon after the word “of” and moved “≥ 2,000 MW for entities in the Eastern or Western Interconnection” down one line.</b></p> <ul style="list-style-type: none"> <li>o The Law Enforcement Reporting section in the Guideline and Technical Basis states: "The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of the BES from malicious physical or cyber attack." Since CIP-008 now covers reporting of cyber incidents the reference to cyber should be removed.</li> </ul> <p><b>We have made the correction in your last point regarding “cyber attacks” and have removed it from the Guidelines and Technical Basis section.</b></p>
<p><b>Response: Thank you for your comment. Please see responses embedded above.</b></p>	
<p>MRO NSRF</p>	<p>The NSRF requests that the SDT address the following concerns and clarifications in Attachment 1;</p> <ul style="list-style-type: none"> <li>1) Please explore redundancy reporting event Item #14; Complete loss of off-site power to a</li> </ul>

Organization	Question 3 Comment
	<p>nuclear generating plant with obligations of NUC-001-2.1 R9.4.4."Provisions for supplying information necessary to report to government agencies, as related to NPIRs." The NSRF understands the importance concerning safety issues with a nuclear plant. A multiple unit coal facility may have a larger reliability impact to the BES than a nuclear plant. The SDT is stating that the fuel source is a reporting issue, not the reliability of a plant loosing off sight power. Recommend that this item be deleted.</p> <p>2) Item 2 in Attachment 1 would obligate an entity to report any loss of (copper) grounds either on a T-Line or grounds associated with a transformer or breakers and that this level of reporting should not rise to the NERC level. Believes that additional qualifying language similar to Item 1 be incorporated into the threshold and read as follows:"Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency."</p> <p>3) Item 3 Attachment 1 needs clarification since a physical threat needs to be actual and confirmed so that the TO or TOP repositions the system. In addition, the SDT needs to clarify what the phrase "normal operations" means. (Is this a ratings issue? or a result in how the System Operator operates the system.)</p> <p>4) Item 3 should provide clarification as to "Suspicious device or activity at a Facility" to determine when threshold raises to the level of reporting. We are concerned that, based on an Auditors perception, these words could be interpreted in several different ways. In addition, we believe that language needs to be included that the threat causes the reporting entity to change to an abnormal operating state. This situation could be interpreted differently by the auditor or the entity at the time of the event. Recommend the following language: "Suspicious device or activity at a Facility with the potential to degrade the normal operation of the Facility". This language is similar to the first threshold.</p> <p>5) The term Initiating entity is used three times within Attachment 1 and needs to be more clearly defined or reworded. Is it the entity that identifies the needs of a Public Appeal or the entity that makes the public appeal the initiating entity? The word "initiating" does not provide clarity but only provides uncertainty to the industry. The Standard needs to be clear on who has the responsibility as the "initiating". Recommend the following: a. For public</p>

Organization	Question 3 Comment
	<p>appeal, under Entity with Reporting Responsibility; “entity that issues a public appeal to the public” b. For system wide voltage reduction, under Entity with Reporting Responsibility; “entity that activates a voltage reduction” c. For manual load shedding, under Entity with Reporting Responsibility; “entity that activates manual load shedding”</p> <p>6) The NSRF recommends transmission loss to read as: “contrary to protection system design” found in threshold for reporting within the Attachment for a Transmission loss event.</p> <p>7) In Requirement 2/ Measure 2, recommend adding “upon recognition of “ as a starting point to the 24 hour reporting requirement, within the threshold of reporting where perceived threats are the threshold, or transmission loss, when contrary to design is determined.</p>
<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p><b>7) This was the intent of the drafting team and we have made this clarification to R2 and M2.</b></p>	
<p>Independent Electricity System Operator</p>	<p>The proposed implementation plan may conflict with Ontario regulatory practice respecting the effective date of the standard. It is suggested that this conflict be removed by: Moving the last part “, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.” to right after “this standard is approved by applicable regulatory approval” in the Effective Dates Section on P.2 of the draft standard, and the proposed Implementation Plan.</p>
<p><b>Response: Thank you for your comment. The SDT used the standard language provide by NERC Legal and intended to address all of the jurisdictions in which the standard may become enforceable. We will refer your suggestion to NERC Legal for consideration in the preparation of the filing.</b></p>	
<p>Bonneville Power Administration</p>	<p>The proposed standard does not have any oral reporting option for system operators and thus appears to be administrative in nature. Due to this and the fact that administrative staff are</p>

Organization	Question 3 Comment
	<p>not available on weekends, the “24 hour” reporting requirements should be modified to “Next Business Day” to allow for weekend delays in reporting. BPA believes that there are too many minor events that have to be reported within 24 hours. Reporting during the next business day would suffice. Some examples include: A 115 shunt capacitor bank failure for the first event type does not seem important enough to require reporting within 24 hours just because action has to be taken to raise generation or switching of line. A failure of a line tower that has proper protective action to clear the line and also has automatic (SPS) to properly protect as designed the BES system (a good normal practice) from overloads or voltage issues does not seem important enough to require reporting within 24 hours either.</p>
<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Clark Public Utilities</p>	<p>The SDT has not adequately addressed my comments from the last draft regarding damage or destruction of its facility that results from actual or suspected intentional human action. The SDT needs to limit what it means by damage. As an example, if someone breaks into a substation and paints graffiti on a breaker that is part of the BES, the breaker has been "damaged." However, the breaker's ability to function has not been compromised and there are no emergency actions that need to be taken. There is no reason for an emergency reporting procedure to require this to be reported. The SDT needs to add the same modifier for damage that it added in the previous event threshold for reporting. The reference for this type of damage should be as follows: Event: Damage or destruction of a Facility. Entity with Reporting Responsibility: BA, TO, TOP, GO, GOP, DP. Threshold for Reporting: Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency.</p>
<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has</b></p>	

Organization	Question 3 Comment
<p>reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
<p>Lewis County PUD</p>	<p>We are a small utility with little impact to the BES with a small hydro on the end of a 230kV line. CIP-001 requires us to contact the FBI who has repeatedly instructed us to call the local sheriff office. The sheriff office has instructed us to call 911 and they will contact the FBI as needed. Therefore, 911 is our only contact number and our plan if vandalism, property destruction or sabotage is to have a supervisor call 911 and report. I do not think calling 911 to confirm the contact number serves any propose. Our plan will be simple with not a lot detail. The drafting team should recognize the reality of small utilities and state the required plan may be simple and not follow the flowchart in the draft standard.</p>
<p><b>Response:</b> Thank you for your comment. The SDT did recognize your circumstances and set the requirements to provide the flexibility to address the diversity of entities to which the standard is intended to apply.</p>	
<p>SPP Standards Review Group</p>	<p>We have made previous comments in the past regarding the listing in the Entity with Reporting Responsibility column of Attachment 1. While we concur with some of the changes that the drafting team has made regarding the addition of a bright line in the Threshold for Reporting column, there remain events where there is no line at all. For example, in the Transmission loss event, the TOP is listed and there is no distinction regarding which TOP is required to file the event report. Is it the TOP in whose TOP area the loss occurred or is it a neighboring TOP who observes the loss. Clearly, the responsibility for reporting lies with the host system. There are several other similar events where the bright line is non-existent and needs to be added. We suggest that the drafting team return the deleted language to the Entity with Reporting Responsibility column in those instances where the bright line has not been added in the Threshold column. Regarding multiple reports for a single event, we again believe that only a single report should be required. While additional information may be available from others, let the Event Analysis personnel do their job investigating an event and eliminate any redundant reporting that is currently required as the standard is written.</p> <p>If not, this standard, if approved, would then appear to be a likely candidate for Phase 2 of the</p>



Organization	Question 3 Comment
	Paragraph 81 project.
	<p>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</p>
SERC OC Standards Review Group	<p>While this draft is an improvement on the previous draft, the proposed R2 is unacceptable, and should be amended to, at a minimum, require reporting by the end of the next business day, instead of within 24 hours. Events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator’s burden, which reduces the operator’s effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. For some event types where in order to provide real time situational awareness over a wide area (for example coordinated sabotage event) it may be appropriate to have more timely reporting .If the intent of this standard is to address sabotage reporting there needs to be an understanding of the actions to be taken by those receiving the reports so the reporting entities can incorporate those actions into their</p>

Organization	Question 3 Comment
	<p>plan. As a minimum, NERC should have a process in place to assess the reports and take appropriate actions.</p> <p>Attachment 1: Threshold for reporting should not be defined such that multiple reports would be required for the same event. For example, both the TOP and RC being required to report the outage of a transmission line.</p> <p>2nd event type (Damage or destruction of a Facility): Add the following sentence to the Threshold for Reporting: “Do not report theft or damage unless it degrades normal operation of a Facility.”</p> <p>4th event type (Physical threats to a BES control center): The term “BES control center” needs to be clarified.</p> <p>5th, 6th, and 7th event types: In instances where a reliability directive is issued, is the “initiating entity” the entity that issues the directive or the entity that carried out the directive.</p> <p>9th event type (Voltage deviation on a Facility): Change “nominal” to “expected or scheduled.”</p> <p>15th event type (Transmission loss): It is not clear what is meant by “contrary to design.” This is so broad that it could be interpreted as requiring reporting misoperations within the reporting time frame before even an initial investigation can begin. This needs to be clarified and tied to the impact on the reliability of the BES. The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review Group only and should not be construed as the position of SERC Reliability Corporation, its board, or its officers.</p>
<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
Tacoma Public Utilities	Why does the text “...but is not limited to...” in M1 have to be included? Does this mean that

Organization	Question 3 Comment
	<p>there are unwritten requirements that an auditor might look for? What if, in trying to validate contact information, contacts do not confirm their information?</p> <p>Regarding the Loss of firm load row in Attachment 1, an exception should be made for weather or natural disaster related threats in the Threshold for Reporting.</p> <p>Regarding the Transmission loss row in Attachment 1, it is not quite clear which types of BES Elements would meet the Threshold for Reporting. Is it just lines, buses, and transformers? What about reactive resources? What about generators that unexpectedly trip offline during a fault on the transmission system?</p>
<p><b>Response: Thank you for your comment. In Measure M1 the text “but is not limited to” is intended to provide flexibility for each entity to determine, based on its assets and unique situation, to develop an Operating Plan that appropriately supports reliability. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
MidAmerican Energy	<p>Yes. 1) MidAmerican Energy agrees with and supports MRO NSRF comments.</p> <p>2) Add additional wording to clearly provide for compliance when events are found more than 24 hours after an event. Add the following to the end of R2. Add, Events not identified until sometime later after they occurred shall be reported within 24 hours.</p> <p>3) In R3 add "external" for R3 to read Validate "external" contact information.</p> <p>4) In EOP-004-2 Attachment 1 - the wording “Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency” is not specific or measureable and therefore ambiguous. Zero defect standards which carry penalties must be specific. Please reword to "Intentional human action to destroy a NERC BES facility whose loss could result in actions to avoid a BES Emergency". This clearly aligns with the EOP-004 intent of sabotage and emergency reporting. EOP-004 should not report on unexpected conditions such as when a system operator attempts to reclose a line</p>

Organization	Question 3 Comment
	<p>during a storm believing the line tripped for a temporary fault due to debris, when in fact the fault was permanent and damaged a transformer.</p>
<p><b>Response: Thank you for your comment. See response to MRO NSF comments.</b></p> <p><b>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>american Transmission Company</p>	<p>Yes A. ATC requests that the Standards Drafting Team address the following concerns and clarifications in Attachment 1:</p> <p>a.) Reporting event #14 in Attachment 1, is duplicative with respect to Nuclear Reliability Standard NUC-001-2.1 R 9.4.4. Reporting event #14 requires entities to report to NERC a “Complete loss of off-site power to a nuclear generating plant” while Nuclear Reliability Standard NUC-001-2.1 R9.4.4., i.e. includes “Provisions for supplying information necessary to report to government agencies, as related to Nuclear Plant Interface Requirements (NPIRs)”. In addition, ATC believes the reporting related to event #14 in Attachment 1 is not a “reliability” issue, and more appropriately covered under Standard NUC-001 as a “Nuclear Safety Shutdown” issue. Therefore, ATC recommends that Item #14 in Attachment 1 of EOP-004-2 be deleted.</p> <p>b.) In Attachment 1, reporting event #2, i.e. “Damage or destruction of a Facility” could obligate an entity to report any loss of copper grounds either on a T-Line or grounds associated with a transformer or breakers. ATC believes this does not rise to a reporting level such as NERC. ATC believes that additional qualifying language similar to reporting item #1 be incorporated into the threshold and read as follows: “Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency.”</p> <p>c.) In Attachment 1, reporting event #3 i.e. “Physical threats to a Facility” needs clarification</p>

Organization	Question 3 Comment
	<p>since a physical threat needs to be actual and confirmed so that the TO or TOP repositions the system. In addition, the SDT needs to clarify what the phrase “normal operations” means. Is this a ratings issue? Or a result in how the Operator operates the system.</p> <p>d.) In Attachment 1, reporting event #3 threshold i.e. “Suspicious device or activity at a Facility” needs clarification to determine when it raises to the level of reporting. These words could be interpreted in several different ways. In addition, ATC believe that language needs to be added that the threat causes the reporting entity to change to an abnormal operating state. ATC recommends the threshold be revised to read: “Suspicious device or activity at a Facility with the potential to degrade the normal operation of the Facility”.</p> <p>e.) In Attachment 1, the term “Initiating entity” is used three times for reporting events and needs to be clearly defined or reworded. Is it the entity that identifies the needs of a Public Appeal or the entity that makes the public appeal the initiating entity? The Standard needs to be clear on who has the responsibility as the “initiating” party, especially when multiple parties may be involved. ATC recommends the following:1) For public appeal, under Entity with Reporting Responsibility; it is the “entity that issues a public appeal to the public”2) For system wide voltage reduction, under Entity with Reporting Responsibility; it is the “entity that activates a voltage reduction”3) For manual load shedding, under Entity with Reporting Responsibility; it is the “entity that activates manual load shedding”</p> <p>f.) In Attachment 1, reporting event #15 i.e. “Transmission Loss”, the threshold includes the phrase “contrary to design”. ATC recommends this be clarified to read “contrary to protection system design”.</p> <p>B. In EOP-004-2 Requirement 2/ Measure 2 both have the following language:”Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting.” ATC recommends adding “upon recognition” as a starting point to the 24 hour reporting requirement. This would be revised to read: “Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of an event type threshold”</p>

**Response: Thank you for your comment. A) Many suggestions were made regarding the language of certain events listed in**

Organization	Question 3 Comment
	<p data-bbox="157 284 1879 430"><b>Attachment 1.</b> Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p> <p data-bbox="157 446 1396 487"><b>B)</b> This was the intent of the drafting team and we have made this clarification to R2 and M2.</p>

END OF REPORT

## **Exhibit E**

Analysis of how VRFs and VSLs Were Determined Using Commission Guidelines

## Violation Risk Factor and Violation Severity Level Assignments

### Project 2009-01 – Disturbance and Sabotage Reporting

This document provides the drafting team's justification for assignment of violation risk factors (VRFs) and violation severity levels (VSLs) for each requirement in

#### EOP-004-2 — Event Reporting

Each primary requirement is assigned a VRF and a set of one or more VSLs. These elements support the determination of an initial value range for the Base Penalty Amount regarding violations of requirements in FERC-approved Reliability Standards, as defined in the ERO Sanction Guidelines.

#### Justification for Assignment of Violation Risk Factors in EOP-004-2

The Disturbance and Sabotage Reporting Standard Drafting Team applied the following NERC criteria when proposing VRFs for the requirements in EOP-004-2:

##### ***High Risk Requirement***

A requirement that, if violated, could directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures, or could hinder restoration to a normal condition.

##### ***Medium Risk Requirement***

A requirement that, if violated, could directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system. However, violation of a medium risk requirement is unlikely to lead to bulk electric system instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly and adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. However, violation of a medium risk requirement is unlikely, under emergency, abnormal, or restoration conditions anticipated by the preparations, to lead to bulk electric system instability, separation, or cascading failures, nor to hinder restoration to a normal condition.



***Lower Risk Requirement***

A requirement that is administrative in nature and a requirement that, if violated, would not be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system; or, a requirement that is administrative in nature and a requirement in a planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. A planning requirement that is administrative in nature.

The SDT also considered consistency with the FERC Violation Risk Factor Guidelines for setting VRFs:<sup>1</sup>

**Guideline (1) — Consistency with the Conclusions of the Final Blackout Report**

The Commission seeks to ensure that Violation Risk Factors assigned to Requirements of Reliability Standards in these identified areas appropriately reflect their historical critical impact on the reliability of the Bulk-Power System.

In the VSL Order, FERC listed critical areas (from the Final Blackout Report) where violations could severely affect the reliability of the Bulk-Power System:<sup>2</sup>

- Emergency operations
- Vegetation management
- Operator personnel training
- Protection systems and their coordination
- Operating tools and backup facilities
- Reactive power and voltage control
- System modeling and data exchange
- Communication protocol and facilities
- Requirements to determine equipment ratings
- Synchronized data recorders
- Clearer criteria for operationally critical facilities
- Appropriate use of transmission loading relief.

**Guideline (2) — Consistency within a Reliability Standard**

The Commission expects a rational connection between the sub-Requirement Violation Risk Factor assignments and the main Requirement Violation Risk Factor assignment.

<sup>1</sup> North American Electric Reliability Corp., 119 FERC ¶ 61,145, order on reh'g and compliance filing, 120 FERC ¶ 61,145 (2007) (“VRF Rehearing Order”).

<sup>2</sup> Id. at footnote 15.

### **Guideline (3) — Consistency among Reliability Standards**

The Commission expects the assignment of Violation Risk Factors corresponding to Requirements that address similar reliability goals in different Reliability Standards would be treated comparably.

### **Guideline (4) — Consistency with NERC’s Definition of the Violation Risk Factor Level**

Guideline (4) was developed to evaluate whether the assignment of a particular Violation Risk Factor level conforms to NERC’s definition of that risk level.

### **Guideline (5) — Treatment of Requirements that Co-mingle More Than One Obligation**

Where a single Requirement co-mingles a higher risk reliability objective and a lesser risk reliability objective, the VRF assignment for such Requirements must not be watered down to reflect the lower risk level associated with the less important objective of the Reliability Standard.

The following discussion addresses how the SDT considered FERC’s VRF Guidelines 2 through 5. The team did not address Guideline 1 directly because of an apparent conflict between Guidelines 1 and 4. Whereas Guideline 1 identifies a list of topics that encompass nearly all topics within NERC’s Reliability Standards and implies that these requirements should be assigned a “High” VRF, Guideline 4 directs assignment of VRFs based on the impact of a specific requirement to the reliability of the system. The SDT believes that Guideline 4 is reflective of the intent of VRFs in the first instance and therefore concentrated its approach on the reliability impact of the requirements.

#### ***VRF for EOP-004-2:***

There are three requirements in EOP-004-2. Requirement R1 was assigned a Lower VRF while Requirements R2 and R3 were assigned a Medium VRF.

#### ***VRF for EOP-004-2, Requirements R1:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The Requirement specifies which entities are required to have processes for recognition of events and for communicating with other entities. This Requirement is the only administrative Requirement within the Standard. The VRF is only applied at the Requirement level. FERC’s Guideline 3 — Consistency among Reliability Standards. This requirement calls for an entity to have processes for recognition of events and communicating with other entities. This requirement is administrative in nature and deals with the means to report events after the fact. All event reporting requirements in Attachment 1 are for 24 hours after recognition that an event has occurred. The current approved VRFs for EOP-004-1 are

all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program.

- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. Failure to have an event reporting Operating Plan is not likely to directly affect the electrical state or the capability of the bulk electric system. Development of the Operating Plan is a requirement that is administrative in nature and is in a planning time frame that, if violated, would not, under emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system.. Therefore this requirement was assigned a Lower VRF.
- FERC’s Guideline 5 — Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R1 contains only one objective which is to have an Operating Plan with two distinct processes. Since the requirement is to have an Operating Plan, only one VRF was assigned.

***VRF for EOP-004-2, Requirement R2:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to implement its Operating Plan and is assigned a Medium VRF. There is one other similar Requirement in this Standard which specifies an annual validation of the information contained in the Operating Plan (R3). Both of these Requirements are assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R2 is a requirement for entities to report events using the process for recognition of events per Attachment 1. Failure to report events within 24 hours is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not report events. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R2 mandates that Responsible Entities implement their Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to notify another entity of the event failure, but there is a slight chance that it could occur. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R2 addresses a single objective and has a single VRF.

**VRF for EOP-004-2, Requirement R3:**

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to perform an annual validation of the information contained in the Operating Plan and is assigned a Medium VRF. There is one other similar Requirement in this Standard which specifies that the Responsible Entity implement its Operating Plan (R2).. Both of these Requirements is assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R3 is a requirement for entities to perform an annual validation of the information contained of the information in the Operating Plan. Failure to perform an annual validation of the information contained in the Operating Plan is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not perform an annual test of the Operating Plan and it is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R3 mandates that Responsible Entities perform an annual validation of the information contained of the information in the Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to perform an annual test of the Operating Plan, but there is a slight chance that it could occur if the Operating Plan is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R3 addresses a single objective and has a single VRF.

**Justification for Assignment of Violation Severity Levels for EOP-004-2:**

In developing the VSLs for the EOP-004-2 standard, the SDT anticipated the evidence that would be reviewed during an audit, and developed its VSLs based on the noncompliance an auditor may find during a typical audit. The SDT based its assignment of VSLs on the following NERC criteria:

Lower	Moderate	High	Severe
Missing a minor element (or a small percentage) of the required performance The performance or product measured has significant value as it almost meets the full intent of the requirement.	Missing at least one significant element (or a moderate percentage) of the required performance. The performance or product measured still has significant value in meeting the intent of the requirement.	Missing more than one significant element (or is missing a high percentage) of the required performance or is missing a single vital component. The performance or product has limited value in meeting the intent of the requirement.	Missing most or all of the significant elements (or a significant percentage) of the required performance. The performance measured does not meet the intent of the requirement or the product delivered cannot be used in meeting the intent of the requirement.

FERC’s VSL guidelines are presented below, followed by an analysis of whether the VSLs proposed for each requirement in EOP-004-2 meet the FERC Guidelines for assessing VSLs:

**Guideline 1: Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance**

Compare the VSLs to any prior levels of non-compliance and avoid significant changes that may encourage a lower level of compliance than was required when levels of non-compliance were used.

**Guideline 2: Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties**

A violation of a “binary” type requirement must be a “Severe” VSL.

Do not use ambiguous terms such as “minor” and “significant” to describe noncompliant performance.

**Guideline 3: Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement**

VSLs should not expand on what is required in the requirement.

**Guideline 4: Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations**

. . . unless otherwise stated in the requirement, each instance of non-compliance with a requirement is a separate violation. Section 4 of the Sanction Guidelines states that assessing penalties on a per violation per day basis is the “default” for penalty calculations.

**VSLs for EOP-004-2 Requirements R1:**

R#	Compliance with NERC's VSL Guidelines	<p>Guideline 1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>Guideline 2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 3</p> <p>Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>Guideline 4</p> <p>Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>
<b>R1</b>	Meets NERC's VSL guidelines. The requirement calls for the entity to have an Operating Plan and is binary in nature. The VSL is therefore set to "Severe".	The proposed requirement is a revision of CIP-001-1, R1-R4, and EOP-004-1, R2. The Requirement has no Parts and is binary in nature. The binary VSL does not lower the current level of Compliance.	The proposed VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed binary VSL uses the same terminology as used in the associated requirement, and is, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R2:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R2</b>	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a revision of EOP-004-1, R3. There is only a Severe VSL for that requirement. However, the reporting of events is based on timing intervals listed in EOP-004 Attachment 1. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a report is not submitted, then the VSL is Severe. This maintains the current VSL.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.



**VSLs for EOP-004-2 Requirement R3:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
R3	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a new Requirement. The test of the Operating Plan is based on the calendar year. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a test is not performed, then the VSL is Severe.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

**Exhibit F**

Record of Development of Proposed Reliability Standard

## Project 2009-01 Disturbance and Sabotage Reporting

### Related Files

**Status:**

Adopted by the Board of Trustees on November 6, 2012, pending regulatory approval.

**Background:**

This project will entail revision to the following existing standards:

- CIP-001-1 – Sabotage Reporting
- EOP-004-1 – Disturbance Reporting

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Draft	Action	Dates	Results	Consideration of Comments
<p><b>Draft 6</b></p> <p><b>EOP-004-2</b>  <a href="#">Clean(89)</a>    <a href="#">Redline to last posted(90)</a></p> <p>Implementation Plan  <a href="#">Clean(91)</a></p> <p><b>Supporting Materials:</b>  <a href="#">Mapping Document(92)</a></p>	<p>Recirculation Ballot and Non-binding poll</p> <p><a href="#">Info(97)</a></p> <p><a href="#">Vote &gt;&gt;</a></p>	<p>10/24/12                      -                      11/05/12                      (closed)</p>	<p><a href="#">Summary(98)</a></p> <p><a href="#">Ballot Results(99)</a></p> <p><a href="#">Non-binding Poll Results(100)</a></p>	

<p>Consideration of Issues and Directives(93)</p> <p>VRF/VSL Justification(94)</p> <p>CIP-001-2a(95)</p> <p>EOP-004-1(96)</p>				
<p><b>Draft 5</b> EOP-004-2 Clean (71)   Redline to Last Posted(72)</p> <p>Implementation Plan Clean(73)   Redline to Last Posted(74)</p> <p><b>Supporting Materials:</b></p> <p>Comment Form (Word)(75)</p> <p>Mapping Document(76)</p> <p>Consideration of Issues and Directives(77)</p> <p>VRF/VSL Justification(78)</p> <p>CIP-001-2a(79)</p> <p>EOP-004-1(80)</p>	<p>Successive Ballot and Non-binding Poll</p> <p>Info(81)</p> <p>Vote&gt;&gt;</p>	<p>09/18/12 - 09/27/12 (closed)</p>	<p>Updated Summary(83)</p> <p>Ballot Results(84)</p> <p>Non-binding Poll Results(85)</p>	
	<p>Comment Period</p> <p>Info(82)</p> <p>Submit Comments&gt;&gt;</p>	<p>08/29/12 - 09/27/12 (closed)</p>	<p>Comments Received(86)</p> <p>Meeting Results(87)</p>	<p>Consideration of Comments(88)</p>
<p><b>Draft 4</b> <b>EOP-004-2</b> Clean(51)   Redline to Last Posted (52)</p>	<p>Successive Ballot and Non-binding Poll</p> <p>Updated Info(63)</p>	<p>05/15/12- 05/24/12 (closed)</p>	<p>Summary(66)</p> <p>Ballot Results(67)</p>	



<p><b>Supporting Materials:</b>  Comment Form (Word) <b>(53)</b></p> <p>Implementation Plan  Clean <b>(54)</b>   Redline to Last Posted <b>(55)</b></p> <p>Mapping Document <b>(56)</b></p> <p>Consideration of Issues and Directives <b>(57)</b></p> <p>VRF/VSL Justification <b>(58)</b></p> <p>Proposed NERC RoP Section 812 <b>(59)</b></p> <p>CIP-001-2a <b>(60)</b></p> <p>CIP-008-3 <b>(61)</b></p> <p>EOP-004-1 <b>(62)</b></p>	<p>Info <b>(64)</b>  Vote &gt;&gt;</p> <p>Comment Period</p> <p>Info <b>(65)</b></p> <p>Submit Comments &gt;&gt;</p>	<p>04/25/12 - 05/24/12 (closed)</p>	<p>Non-binding Poll Results <b>(68)</b></p> <p>Comments Received <b>(69)</b></p>	<p>Consideration of Comments <b>(70)</b></p>
<p><b>Draft 3 EOP-004-2</b>  Clean <b>(34)</b>   Redline to Last Posted <b>(35)</b></p> <p><b>Supporting Materials:</b>  Comment Form (Word) <b>(36)</b></p> <p>Implementation Plan  Clean <b>(37)</b>   Redline to Last Posted <b>(38)</b></p> <p>Mapping</p>	<p>Join Ballot Pools &gt;&gt;</p> <p>Formal Comment Period</p> <p>Info <b>(43)</b></p> <p>Submit Comments &gt;&gt;</p> <p>Initial Ballot and Non-Binding Poll</p> <p>Updated Info <b>(44)</b>  Info <b>(45)</b></p> <p>Vote &gt;&gt;</p>	<p>10/28/11 - 11/28/11 (closed)</p> <p>10/28/11 - 12/12/11 (closed)</p> <p>12/02/11 - 12/12/11 (closed)</p>	<p>Comments Received <b>(46)</b></p> <p>Summary <b>(47)</b></p> <p>Full Record <b>(48)</b></p> <p>Non-Binding Poll</p>	<p>Consideration of Comments <b>(50)</b></p>

<p>Document <b>(39)</b></p> <p>VRF/VSL Justification <b>(40)</b></p> <p>CIP-001-1 <b>(41)</b></p> <p>EOP-004-1 <b>(42)</b></p>			Results <b>(49)</b>	
<p><b>Draft 2 EOP-004-2</b> clean <b>(25)</b>   redline to last posted <b>(26)</b></p> <p><b>Supporting Materials:</b> Comment Form (Word) <b>(27)</b></p> <p>Implementation Plan <b>(28)</b></p> <p>CIP-001-1 <b>(29)</b></p> <p>EOP-004-1 <b>(30)</b></p>	<p>Info <b>(31)</b></p> <p>Formal Comment Period &gt;&gt;</p>	<p>03/09/11 - 04/08/11</p>	<p>Comments Received <b>(32)</b></p>	<p>Consideration of Comments <b>(33)</b></p>
<p><b>Draft 1 EOP-004-2</b> EOP-004-2 <b>(19)</b></p> <p><b>Supporting Materials:</b> Comment Form (Word) <b>(20)</b></p> <p>Mapping Document <b>(21)</b></p>	<p>Informal Comment Period</p> <p>Submit Comments &gt;&gt;</p> <p>Info <b>(22)</b></p>	<p>09/15/10 - 10/15/10</p>	<p>Comments Received <b>(23)</b></p>	<p>Consideration of Comments <b>(24)</b></p>
<p>Concept Paper Supporting Disturbance and Sabotage Reporting</p> <p>Concept Paper <b>(12)</b></p>	<p>Comment Period</p> <p>Submit Comments &gt;&gt;</p> <p>Info <b>(16)</b></p>	<p>03/17/10 - 04/16/10 (closed)</p>	<p>Comments Received <b>(17)</b></p>	<p>Consideration of Comments <b>(18)</b></p>

<p><b>Supporting Materials:</b>  Comment Form (Word) <b>(13)</b>  CIP-001-1 - Sabotage Reporting <b>(14)</b>  EOP-004-1 - Disturbance Reporting <b>(15)</b></p>				
<p>Nominations for Standard Drafting Team</p> <p><b>Supporting Materials:</b>  Nomination Form (Word) <b>(10)</b></p>	<p><a href="#">Info</a> <b>(11)</b></p> <p><a href="#">Submit Nomination &gt;&gt;</a></p>	<p>09/16/09  -  09/30/09 (closed)</p>		
<p>Draft 2 Disturbance and Sabotage Reporting SAR 2</p> <p><a href="#">Clean</a> <b>(8)</b>   <a href="#">Redline to Last Posting</a> <b>(9)</b></p>				
<p>Nominations for SAR Drafting Team</p> <p><b>Supporting Materials:</b>  Nomination Form (Word) <b>(6)</b></p>	<p><a href="#">Info</a> <b>(7)</b></p> <p><a href="#">Submit Nomination &gt;&gt;</a></p>	<p>04/29/09  -  05/13/09 (closed)</p>		
<p>Proposed SAR  Draft SAR</p>	<p>Comment Period</p> <p><a href="#">Info</a> <b>(3)</b>  <a href="#">Submit Comments &gt;&gt;</a></p>	<p>04/22/09  -  05/21/09 (closed)</p>	<p><a href="#">Comments Received</a> <b>(4)</b></p>	<p><a href="#">Consideration of Comments</a> <b>(5)</b></p>

Version 1 (1)

**Supporting  
Materials:**  
Comment Form  
(Word) (2)





## Standard Authorization Request Form

Title of Proposed Project:	Disturbance and Sabotage Reporting (Project 2009-01)
Request Date	April 2, 2009
Approved by SC for posting:	April 15, 2009

SAR Requester Information	SAR Type <i>(Check a box for each one that applies.)</i>
Name Patrick Brown	<input type="checkbox"/> New Standard
Primary Contact Patrick Brown Manager, NERC and Regional Coordination PJM Interconnection	<input checked="" type="checkbox"/> Revision to existing Standards: CIP-001-1 and EOP-004-1
Telephone 610-666-4597	<input checked="" type="checkbox"/> Withdrawal of existing Standard
E-mail brownp@pjm.com	<input type="checkbox"/> Urgent Action

<p><b>Purpose (Describe the proposed standard action: Nomination of a proposed standard, revision to a standard, or withdrawal of a standard and describe what the standard action will achieve.)</b></p> <p>This project will entail revision to existing standards CIP-001-1 – Sabotage Reporting and EOP-004-1 – Disturbance Reporting. The standards may be merged to eliminate redundancy and provide clarity on sabotage events. EOP-004 has some ‘fill-in-the-blank’ components to eliminate. The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.</p>
<p><b>Industry Need</b> (Provide a justification for the development or revision of the standard, including an assessment of the reliability and market interface impacts of implementing or not implementing the standard action.)</p> <p>The existing requirements need to be revised to be more specific – and there needs to be more clarity in what sabotage looks like.</p>
<p><b>Brief Description</b> (Provide a paragraph that describes the scope of this standard action.)</p> <p>CIP-001 may be merged with EOP-004 to eliminate redundancies. Acts of sabotage have to be reported to the DOE as part of EOP-004. Specific references to the DOE form need to be</p>

**Standards Authorization Request Form**

---

eliminated.

EOP-004 has some 'fill-in-the-blank' components to eliminate.

The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information).

**Detailed Description** (Provide a description of the proposed project with sufficient details for the standard drafting team to execute the SAR.)

See "Issues to be Considered by Drafting Team" tables for each standard at the end of this SAR for more detailed information.

**Standards Authorization Request Form**

**Reliability Functions**

<b>The Standard will Apply to the Following Functions</b> <i>(Check box for each one that applies.)</i>		
<input checked="" type="checkbox"/>	Reliability Coordinator	Responsible for the real-time operating reliability of its Reliability Coordinator Area in coordination with its neighboring Reliability Coordinator's wide area view.
<input checked="" type="checkbox"/>	Balancing Authority	Integrates resource plans ahead of time, and maintains load-interchange-resource balance within a Balancing Authority Area and supports Interconnection frequency in real time.
<input type="checkbox"/>	Interchange Authority	Ensures communication of interchange transactions for reliability evaluation purposes and coordinates implementation of valid and balanced interchange schedules between Balancing Authority Areas.
<input type="checkbox"/>	Planning Coordinator	Assesses the longer-term reliability of its Planning Coordinator Area.
<input type="checkbox"/>	Resource Planner	Develops a >one year plan for the resource adequacy of its specific loads within a Planning Coordinator area.
<input type="checkbox"/>	Transmission Planner	Develops a >one year plan for the reliability of the interconnected Bulk Electric System within its portion of the Planning Coordinator area.
<input type="checkbox"/>	Transmission Service Provider	Administers the transmission tariff and provides transmission services under applicable transmission service agreements (e.g., the pro forma tariff).
<input type="checkbox"/>	Transmission Owner	Owns and maintains transmission facilities.
<input checked="" type="checkbox"/>	Transmission Operator	Ensures the real-time operating reliability of the transmission assets within a Transmission Operator Area.
<input type="checkbox"/>	Distribution Provider	Delivers electrical energy to the End-use customer.
<input type="checkbox"/>	Generator Owner	Owns and maintains generation facilities.
<input checked="" type="checkbox"/>	Generator Operator	Operates generation unit(s) to provide real and reactive power.
<input type="checkbox"/>	Purchasing-Selling Entity	Purchases or sells energy, capacity, and necessary reliability-related services as required.
<input type="checkbox"/>	Market Operator	Interface point for reliability functions with commercial functions.
<input checked="" type="checkbox"/>	Load-Serving Entity	Secures energy and transmission service (and reliability-related services) to serve the End-use Customer.

***Reliability and Market Interface Principles***

<b>Applicable Reliability Principles</b> <i>(Check box for all that apply.)</i>	
<input checked="" type="checkbox"/>	1. Interconnected bulk power systems shall be planned and operated in a coordinated manner to perform reliably under normal and abnormal conditions as defined in the NERC Standards.
<input type="checkbox"/>	2. The frequency and voltage of interconnected bulk power systems shall be controlled within defined limits through the balancing of real and reactive power supply and demand.
<input checked="" type="checkbox"/>	3. Information necessary for the planning and operation of interconnected bulk power systems shall be made available to those entities responsible for planning and operating the systems reliably.
<input checked="" type="checkbox"/>	4. Plans for emergency operation and system restoration of interconnected bulk power systems shall be developed, coordinated, maintained and implemented.
<input type="checkbox"/>	5. Facilities for communication, monitoring and control shall be provided, used and maintained for the reliability of interconnected bulk power systems.
<input type="checkbox"/>	6. Personnel responsible for planning and operating interconnected bulk power systems shall be trained, qualified, and have the responsibility and authority to implement actions.
<input type="checkbox"/>	7. The security of the interconnected bulk power systems shall be assessed, monitored and maintained on a wide area basis.
<input checked="" type="checkbox"/>	8. Bulk power systems shall be protected from malicious physical or cyber attacks.
<b>Does the proposed Standard comply with all of the following Market Interface Principles?</b> <i>(Select 'yes' or 'no' from the drop-down box.)</i>	
1. A reliability standard shall not give any market participant an unfair competitive advantage. Yes	
2. A reliability standard shall neither mandate nor prohibit any specific market structure. Yes	
3. A reliability standard shall not preclude market solutions to achieving compliance with that standard. Yes	
4. A reliability standard shall not require the public disclosure of commercially sensitive information. All market participants shall have equal opportunity to access commercially non-sensitive information that is required for compliance with reliability standards. Yes	

**Standards Authorization Request Form**

---

***Related Standards***

<b>Standard No.</b>	<b>Explanation</b>
COM-003-1	Operations Communications Protocols – this standard may include some requirements that require coordination with the requirements addressed in this project

***Related SARs***

<b>SAR ID</b>	<b>Explanation</b>

***Regional Variances***

<b>Region</b>	<b>Explanation</b>
ERCOT	
FRCC	
MRO	
NPCC	
SERC	
RFC	
SPP	
WECC	

<b>Issues to be Considered by Drafting Team</b>	
<b>Project 2009-01 – Disturbance and Sabotage Reporting</b>	
<b>Standard #</b>	<b>Title</b>
<b>CIP-001-0</b>	Sabotage Reporting
<b>Issues</b>	FERC Order 693

	<p>Disposition: Approved with modifications</p> <ul style="list-style-type: none"> <li>• Consider the need for wider application of the standard. Consider whether separate, less burdensome requirements for smaller entities may be appropriate.</li> <li>• Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event.</li> <li>• In the interim, provide advice to entities about the reporting of particular circumstances as they arise.</li> <li>• Consider FirstEnergy's suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</li> <li>• Incorporate a periodic review or updating of the sabotage reporting procedures and for their periodic testing. Consider a staggered schedule of annual testing and formal review every two to three years.</li> <li>• Include a requirement to report a sabotage event to the proper government authorities. Develop the language to specifically implement this directive.</li> <li>• Explore ways to reduce redundant reporting, including central coordination of sabotage reports and a uniform reporting format.</li> </ul> <p>V0 Industry Comments</p> <ul style="list-style-type: none"> <li>• Object to multi-site requirement</li> <li>• Definition of sabotage required</li> </ul> <p>VRF comments</p> <ul style="list-style-type: none"> <li>• Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures.</li> </ul> <p>Other</p> <ul style="list-style-type: none"> <li>• Modify standard to conform to the latest version of NERC's Reliability Standards Development Procedure, the NERC Standard Drafting Team Guidelines, and the ERO Rules of Procedure.</li> </ul> <p>NERC Audit and Observation Team</p> <ul style="list-style-type: none"> <li>• Applicability — How does this standard pertain to Load Serving Entities, LSE's.</li> <li>• Registered Entities have sabotage reporting processes and procedures in place but not all personnel has been trained.</li> <li>• Question: How do you "and make the operator aware"</li> <li>• R4 — "What is meant by: "establish contact with the FBI". Is a phone number adequate? Many entities which call the FBI are referred back to the local authority. The AOT noted that on the FBI website it states to contact the local authorities. Is this a question for Homeland Security to deal with for us?"</li> <li>• R4 — Establish communications contacts, as applicable with local FBI and RAMP officials. Some entities are very remote and the sheriff is the only local authority does the FBI still need to be contacted?</li> </ul> <p>FERC's December 20, 2007 and April 4, 2008 Orders in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000</p> <ul style="list-style-type: none"> <li>• In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none owned physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to</li> </ul>
--	---

**Standards Authorization Request Form**

	<p>ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be applied. Each drafting team responsible for reliability standards applicable to LSEs is to review and change as necessary, requirements in the applicable reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:</p> <ul style="list-style-type: none"> <li>• FERC’s December 20, 2007 Order (<a href="http://www.nerc.com/files/LSE_decision_order.pdf">http://www.nerc.com/files/LSE_decision_order.pdf</a> )</li> <li>• NERC’s March 4, 2008 (<a href="http://www.nerc.com/files/FinalFiledLSE3408.pdf">http://www.nerc.com/files/FinalFiledLSE3408.pdf</a> ),</li> <li>• FERC’s April 4, 2008 Order (<a href="http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf">http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf</a> ) and</li> <li>• NERC’s July 31, 2008 (<a href="http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf">http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf</a> ) compliance filings to FERC on this subject.</li> </ul>
--	---

<b>Issues to be Considered by Drafting Team</b>	
<b>Project 2009-01 — Disturbance and Sabotage Reporting</b>	
<b>Standard #</b>	<b>Title</b>
<b>EOP-004-1</b>	Disturbance Reporting
<b>Issues</b>	<p>FERC Order 693 Disposition: Approved with modification</p> <ul style="list-style-type: none"> <li>• Include any requirements for users, owners, and operators of the bulk power system to provide data that will assist NERC in the investigation of a blackout or disturbance.</li> <li>• Change NERC’s Rules of Procedure to assure the Commission receives these reports in the same frame as the DOE.</li> <li>• Consider APPA’s concern about generator operators and LSEs analyzing performance of their equipment and provide data and information on the equipment to assist others with analysis.</li> <li>• Consider all comments offered in a future modification of the reliability standard.</li> </ul> <p>Fill-in-the-Blank Team Comments</p> <ul style="list-style-type: none"> <li>• Consider changes to R1 and R3.4 to standardize the disturbance reporting requirements (requirements for disturbance reporting need to be added to this standard)</li> <li>• Regions currently have procedures, but not in the form of a standard. The drafting team will need to review regional requirements to determine reporting requirements for the North American standard.</li> </ul> <p>VO Industry Comments</p> <ul style="list-style-type: none"> <li>• R3 – too many reports, narrow requirement to RC</li> <li>• How does this apply to generator operator?</li> </ul> <p>Other</p> <ul style="list-style-type: none"> <li>• Modify standard to conform to the latest version of NERC’s Reliability Standards Development Procedure, the NERC Standard Drafting Team Guidelines, and the ERO Rules of Procedure.</li> </ul> <p>NERC Audit and Observation Team</p> <ul style="list-style-type: none"> <li>• R3.1 — Can there be a violation without an event?</li> </ul>

Event Analysis Team

- Reliability Issue: Coordination and follow up on lessons learned from event analyses Consider adding to EOP-004 – Disturbance Reporting. Proposed requirement: Regional Entities (REs) shall work together with Reliability Coordinators, Transmission Owners, and Generation Owners to develop an Event Analysis Process to prevent similar events from happening and follow up with the recommendations. This process shall be defined within the appropriate NERC Standard.

FERC's December 20, 2007 and April 4, 2008 Orders in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000

- In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none owned physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be applied. Each drafting team responsible for reliability standards applicable to LSEs is to review and change as necessary, requirements in the applicable reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:
  - FERC's December 20, 2007 Order ([http://www.nerc.com/files/LSE\\_decision\\_order.pdf](http://www.nerc.com/files/LSE_decision_order.pdf) )
  - NERC's March 4, 2008 (<http://www.nerc.com/files/FinalFiledLSE3408.pdf> ),
  - FERC's April 4, 2008 Order (<http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf> ) and
  - NERC's July 31, 2008 (<http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf> ) compliance filings to FERC on this subject.



## Unofficial Comment Form for Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Please **DO NOT** use this comment form. Please use the [electronic comment form](#) located at the link below to submit comments on the proposed SAR for revisions to the existing Disturbance and Sabotage Reporting standards. Comments must be submitted by **May 21, 2009**. If you have questions please contact Stephen Crutchfield at [Stephen.crutchfield@nerc.net](mailto:Stephen.crutchfield@nerc.net) or by telephone at 609-651-9455.

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### Background Information

This project will entail revision to the following existing standards:

- CIP-001-1 — Sabotage Reporting
- EOP-004-1 — Disturbance Reporting

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to identify in real-time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives, will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure, and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

## Unofficial Comment Form — Project 2009-01 — SAR for Disturbance and Sabotage Reporting

---

**\*Please use the electronic comment form to submit your final responses to NERC.**

1. Do you agree that there is a reliability-related reason to support modifying CIP-001-1 and EOP-004-1? If not, please explain in the comment area.

Yes

No

Comments:

2. Do you agree with the scope of the proposed SAR? If not, please explain what should be added or deleted to the proposed scope.

Yes

No

Comments:

3. Are you aware of any associated business practices that we should consider with this SAR? If yes, please explain in the comment area.

Yes

No

Comments:

4. CIP-001-1 applies to the Reliability Coordinator, Transmission Operator, Balancing Authority, Generator Operator, and the Load-serving Entity. EOP-004-1 applies to the same entities, plus the Regional Reliability Organization. Do you agree with the applicability of the existing CIP-001-1 and the existing EOP-004-1? If no, please identify what you believe should be modified.

Yes

No

Comments:

5. If you have any other comments on the SAR or proposed modifications to CIP-001-1 and EOP-004-1 that you haven't provided in response to the previous questions, please provide them here.

Comments:

## Standards Announcement

Comment Period Open

April 22–May 21, 2009

Now available at: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance Sabotage Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Project Name:**

2009-01 — Disturbance and Sabotage Reporting

### **Due Date and Submittal Information:**

The comment period is open **until 8 p.m. EDT on May 21, 2009**. Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Lauren Koller at [Lauren.Koller@nerc.net](mailto:Lauren.Koller@nerc.net). An off-line, unofficial copy of the comment form is posted on the project page: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance Sabotage Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Content for Comment Period:**

- A proposed SAR for revisions to the existing Disturbance and Sabotage Reporting standards

### **Other Materials Posted:**

- CIP-001-1 — Sabotage Reporting
- EOP-004-1 — Disturbance Reporting

### **Project Background:**

This project will entail revision to the following existing standards:

- CIP-001-1 — Sabotage Reporting
- EOP-004-1 — Disturbance Reporting

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

### **Applicability of Standards in Project:**

- Reliability Coordinators
- Balancing Authorities
- Transmission Operators
- Generator Operators
- Load Serving Entities
- Regional Reliability Organizations

### **Standards Development Process**

The [Reliability Standards Development Procedure](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance,  
please contact Shaun Streeter at [shaun.streeter@nerc.net](mailto:shaun.streeter@nerc.net) or at 609.452.8060.*



**Project 2009-01 Disturbance and Sabotage Reporting Comment Received  
April 29, 2009 through May 13, 2009**

- Individual or group. (40 Responses)**
- Name (28 Responses)**
- Organization (28 Responses)**
- Group Name (12 Responses)**
- Contact Organization (12 Responses)**
- Question 1 (39 Responses)**
- Question 1 Comments (40 Responses)**
- Question 2 (40 Responses)**
- Question 2 Comments (40 Responses)**
- Question 3 (38 Responses)**
- Question 3 Comments (40 Responses)**
- Question 4 (39 Responses)**
- Question 4 Comments (40 Responses)**
- Question 5 (0 Responses)**
- Question 5 Comments (40 Responses)**

Individual
Stephen V. Fisher
Lands Energy Consulting
Yes
I have worked with 5 Northwest public utilities on developing procedures related to CIP-001-1 and EOP-004-1. All 5 utilities operate electric systems in fairly remote locations and are embedded in a larger utility's Balancing Authority/Transmission Operator area. A. CIP-001-1 - Developing procedures to unambiguously identify acts of sabotage has been particularly challenging for these systems. In general, it's hard for them to determine whether the most prevalent forms of malicious and intentional system damage that they incur - copper theft and gun shot insulators/equipment - should qualify as acts of sabotage. Although none of the systems consider copper theft to be acts of sabotage, two of the systems consider gun shot insulators/equipment to be acts of sabotage. The other systems look for intent to disrupt electric system operations as a key component of their sabotage identification procedures. Additional guidance from NERC in the form of CIP-001-1 modifications or a companion guidelines document on sabotage identification would provide much needed guidance for these procedures. B. EOP-004-1 - This standard was clearly drafted with the larger electric systems in mind. I have one client that serves 3300 commercial/residential customers from 4-115/13 kV substation transformers and one large industrial customer (80% of its energy load) from a 230/13 kV substation. 75% of the client's load is served from three substations attached to a long, 115 kV transmission line operated by the Bonneville Power Administration. Whenever the line relays open on a permanent fault (which happens 2-3 times per year), the client loses over 50% of its customers (but no more than 10-15 MW during winter peak), thereby necessitating the preparation of a Disturbance Report. To allow utilities to concentrate on operating their systems, without fear of violating EOP-004-1 for failure to report trivial outages, I would remove LSEs from the obligation to report disturbances - leave the reporting to the BA/TOP for large outages in their footprint.
No
I would like to see the SAR expanded to cover the issues I mentioned in my prior comment. Otherwise, the scope of the SAR looks fine to me.
No
No
CIP-001-1 - Yes. In many cases, the staff of an LSE embedded in another entity's BA/TOP area is more

likely to discover an act of sabotage directed toward a BA/TOP-owned facility that could affect the BES than the asset owner. This is because the LSE likely has more operating staff in the area. I have included a requirement in my clients' Sabotage Identification and Reporting Procedures that the client treat acts of sabotage to a third party's system discovered by client employees as though the act was directed toward client facilities. EOP-004-1 - As mentioned before, I would eliminate the LSE from the applicability list and leave the responsibility for disturbance reporting and response to the TOP/BA. However, I would retain a responsibility for the LSEs to cooperate (when requested) with any disturbance investigation.

One final comment on CIP-001-1. My clients received universally rude treatment from the FBI field offices when they attempted to establish the contacts required by the Standard. If the FBI doesn't see value in establishing these contacts, remove the requirement from the Standard. Making sure the LSE knows the FBI field office phone number is probably all the Standard should require.

Individual

Brent Hebert

Calpine Corporation

Yes

Communication of facility status or emergencies between merchant generators registered as GOP and the RC, BA, GOP, or LSE in which the facility resides should be coordinated for EOP -004 reporting. The reporting to NERC/DOE should come from the RC, BA, GOP, or LSE.

Yes

No

The reporting requirements of EOP - 004 are needed for the RC, BA, LSE and the GOP that operates or controls generation in a system as defined by NERC. (System – A combination of generation, transmission, and distribution components). A disturbance is described as an unplanned event that produces and abnormal system condition, any perturbation to the electric system, and the unexpected change in ACE that is caused by the sudden failure of generation or interruption of load. The GOP operating/controlling generation within a system has the ability to analyze system conditions to determine if reporting is necessary. A NERC registered GOP that is a merchant generator within another company's system does not have the ability for a wide area view and cannot analyze system conditions beyond the interconnection point of the facility. Moreover, in most cases the reporting requirements outlined in the Interconnection Reliability Operating Limits and Preliminary Disturbance Report do not apply to the merchant generator that is not a generation only BA. The applicability of the standard does encompass the true merchant generation entities required to register as GOP. Similarly, the OE-417 table 1 reporting requirements generally do not apply to a true merchant generating entity that is required to register as a GOP.

Individual

Steve Toth

Covanta

Yes

Yes - the key to Sabotage reporting requirements is identifying what the 'definition' is of an actual or potential 'Sabotage' event. Like any other standard, if FERC/NERC leave it up to 2000+ entities to establish their own definitions of 'Sabotage', you may likely get 2000+ answers. That is not a controlled and coordinated approach. I offer the following definition, "Sabotage - Deliberate or malicious destruction of property, obstruction of normal operations, or injury to personnel by outside agents." Examples of sabotage events could include, but are not limited to, suspicious packages left near site electrical generating or electrical transmission assets, identified destruction of generating assets, telephone/e mail received threats to destroy or interrupt electrical generating efforts, etc." These have passed multiple NERC regional audits and reviews to date.

Yes

No
Yes
It would be a welcome enhancement to the end users to understand to communication link between all "appropriate parties" who shall be notified of potential or actual sabotage events.... which also needs to be defined.
Individual
Harvie Beavers
Colmac Clarion
Yes
Yes
No
Yes
Need single report for Sabotage so whatever is required results in notification of all parties (State Emergency Management, Homeland Security, FBI, Grid Reliability Chain of Command). Any and all of these can 'expand' knowledge later but all seem to require 'instant' notification.
Individual
Russell A. Noble
Cowlitz County PUD
Yes
The standards as written now create reporting on local customer quality of service outage events not related to BPS disturbances. Sabotage reporting has degenerated into reporting of mischievous vandalism and minor theft occurrences. This creates compliance documentation overburden and waste of limited funds needed for true BPS reliability concerns, and also adds nuisance calls to the FBI and Homeland Security.
No
Added to the scope: For EOP-004 add a provision for a reporting flow rather than everything going to the RE and NERC, that is something going like the DP and TOP reports to the BA, the BA to the RE, and the RE to NERC. This would allow for multiple related reports to be combined into a single coherent report as the reporting goes up the chain. For CIP-001 consider reporting flow as above with local law enforcement notification. Let an upper entity in the reporting chain decide when to contact Federal Agencies such as the BA or the RC.
No
No
Replace LSE with DP, and the Regional Reliability Organization with the Regional Entity.
Local Law enforcement agencies often are not friendly to Federal involvement with smaller problems they consider their "turf." Need to make sure the small stuff stays with them, however have a system of internal reporting that will catch coordinated sabotage efforts (multiple attacks on DPs and small BAs) at the RC or RE level who then can report to the Federal agencies. Currently EOP-004-1 requires small entities to report a "disturbance" if half of their firm customer load is lost. For some entities, this can be one small substation going down due to a bird. The "50% of total demand" requirement should be removed or improved to better define a true BPS disturbance.
Individual
Michael Puscas

United Illuminating
Yes
Yes
No
No
Add Distribution Provider
Individual
George Pettyjohn
Reliant Energy
Yes
EOP-004-1 indicates that Generators should analyze disturbances on the bulk electrical system or their facilities. Generators do not have the capability of analyzing the bulk electrical system other than Frequency. Even so, generators can not unilaterally respond to what it thinks are disturbances. In the case of CAISO The Participating Generator Agreement prevents me from making any unilateral moves save for the direct frequency emergencies. If the System operator or Reliability Coordinator informs the generator that there is a disturbance and that logs and readouts etc. are required then the generator should respond with all available information for the subject hours or time. Clearer responsibilities provide clearer results.
No
I think Generator operators should be excluded except to provide requested information from the System Operator or Reliability coordinator.
No
No
EOOP-004-1 should exclude the generator operator from disturbance reporting except providing the system operator or reliability coordinator with appropriate unit operation information upon request. Acts of sabotage should be identified clearly and reported to the indicated authorities.
Individual
Judith A. James
Texas Regional Entity
Yes
Yes
No
No
Add GO and TO to the list of applicability. The intent of CIP-001-1 when it was first written was to have the proper and most likely entities associated directly with operations to be the ones to begin the reporting process in the case of sabotage on the system. In the ERCOT Region and other regions in the US, the GOP may not be physically located at the site. The GOP is often removed from the minute-by-minute responsibilities of plant operations and, therefore, may be less able to react to physical sabotage at the location/plant/facility in a timely manner. The concern is that, in the case of an actual sabotage event, the failure to report to the appropriate authorities in a timely manner may jeopardize the reliability of the BPS. Therefore, the Generator Owner (GO) should be added to the list of applicability for CIP-001-1, because it is



the GO that is more likely to be on location at the generation site and thus aware of sabotage when it first occurs. This would disallow for any possible communication gap and put responsibility on all of the appropriate entities to report such an event. Additionally, and for the same reasons as adding the GO, the Transmission Owner (TO) should also be added to the list of applicability for reporting sabotage on its facilities.

Individual

Edward C. Stein

self

Yes

Yes

No

Yes

Individual

Chris Scanlon

Exelon

Yes

Yes

Consolidation of redundant requiremnts and clarifications of difficult to follow / interpret standards should be a high priority at NERC.

No

We are not sure what this question means. Who's Associated Business practices, NERC, Applicable Entities in the Standard, our business practices?

No

CIP-001, remove LSE's from the standard for the reasons identified in the FERC LSE order. Ad TO and DP. EOP-004, remove LSE's from the standard for the reasons identified in the FERC LSE order. Remove RRO's, they are not a user, owner, operator of the BES. Add DP or TO. Consider conditional applicability as in the UFLS standards, " the TO or DP who performs the functions specified in the standard..."

Exelon agrees this is a worthwhile project and that reliability will be enhanced and the compliance process will be simplified by clarifying terminology and reporting requirements in these standards. If nothing else, defining "Sabotage" so as to end interpretations of this term and the related requirements is necessary.

Group

SERC OC Standards Review Group

Entergy Services, Inc

No

The EOP-004-1 standard is an unnecessary duplication of existing DOE reporting requirements. This essentially exposes an entity to fines by NERC, enforced by FERC, for failure to comply with a DOE regulation, which seems improper to us. In addition, reporting requirements do not have an impact on the reliability of the BES

Yes

No

Business practices should not be considered in a standard.
No
The EOP-004-1 standard should not apply to the RRO.
Group
WECC
WECC
Yes
Yes
No
Yes
No
Group
Project 2007-02 Operating Personnel Comms Protocols SDT
NERC OPCP SDT
No
The Operating Personnel Communication Protocols standard drafting team respectfully requests that the Sabotage Reporting SAR Drafting Team incorporate the following into your proposed SAR: "Each Reliability Coordinator, Balancing Authority, and Transmission Operator shall have procedures for the communication of information concerning the Cyber and Physical emergency alerts in accordance with the conditions described in Attachment 1 Security Emergency Alerts ." The Operating Personnel Communications Protocols Project 2007-02 was initiated to ensure that real time system operators use standardized communication protocols during normal and emergency operations to improve situational awareness and shorten response time. The SDT developed a new COM-003-1 Standard that has yet to be posted and is dependent upon revising at least two other standards (CIP-001 and TOP Standard). COM-003 contains requirements that specify: 1. Use of three-part communication; 2. English language; 3. Common time zone; 4. NATO alpha-numeric alphabet; 5. Mutually agreed line identifiers; 6. The use of pre-defined system condition terminology such as those contained in the RCWG Alert Level Guide and EOP-002-2. This request is based on recent NERC Standards Committee direction to our team to incorporate the Reliability Coordinator Working Group's (RCWG) Alert Level Guide into a Standard. The consensus of our team is that a TOP Standard is the most appropriate location for the Transmission Emergency Alert language from the Guide as the energy emergency alert language is currently described in EOP-002-2. The RCWG Guide proposes the use of pre-defined system condition descriptions for use during emergencies for reliability related information. This guide was developed in response to a Blackout Report recommendation. Our team placed the Transmission Emergency Alert language into a TOP standard. Since the Sabotage Reporting SAR DT intends to modify CIP-001, we seek your consent to incorporate the cyber and physical security alert language to comply with the wishes of the Standards Committee. We believe that the CIP-001 Standard is the most appropriate location for this language for the following reasons: • The levels of emergency conditions related to the cyber and physical security of the electric system is directly related to Critical Infrastructure Protection. • The current version of CIP-001 already requires the timely reporting of actual and suspected security emergency conditions and the use of pre-defined terminology supports the efficient sharing of such information. The OPCP SDT includes the following text for the record. It is a proposed draft revision of CIP-001. A. Introduction 1. Title: Security Incidents 2. Number: CIP-001-2 3. Purpose: To ensure the recognition, communication and response to cyber and physical security incidents suspected or determined to be caused by sabotage. 4. Applicability 4.1. Reliability Coordinators. 4.2. Balancing Authorities. 4.3. Transmission Operators. 4.4. Generator Operators. 4.5. Load Serving Entities. 5. Effective

Date: The standard is effective the first day of the first calendar quarter after applicable regulatory approvals (or the standard otherwise becomes effective the first day of the first calendar quarter after NERC BOT adoption in those jurisdictions where regulatory approval is not required).

**B. Requirements R1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of security threats on its facilities and multi site security threats affecting larger portions of the Interconnection.

**R2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning the physical and cyber security status of their facilities in accordance with the conditions described in Attachment 1-CIP-001-1.

**R3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with security threat or incident response guidelines, including personnel to contact, for reporting security threats and incidents.

**R4.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

**C. Measures M1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1

**M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

**M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

**D. Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Enforcement Authority Regional Entity**

**1.2. Compliance Monitoring Period and Reset** One or more of the following methods will be used to verify compliance: - Compliance Audits - Self-certifications - Spot Checking - Compliance Violation Investigations - Self-Reporting - Complaints

**1.3. Data Retention** The Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator and Distribution Provider shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

- o The Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator and Distribution Provider shall retain its current, in force document and any documents in force since the last compliance audit.
- o If a Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator or Distribution Provider is found non-compliant, it shall keep information related to the non-compliance until found compliant.
- o The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

**1.4. Additional Compliance Information** None.

**2. Levels of Non-Compliance:**

**2.1. Level 1:** There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

- 2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).
- 2.1.2** Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).
- 2.1.3** Has not established communications contacts, as specified in R4.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).

**2.4. Level 4:** .Not applicable.

**E. Regional Differences** None.

**Version History**

Version	Date	Action
0	April 1, 2005	Effective Date New
0	August 8, 2005	Removed "Proposed" from Effective Date
1	November 1, 2006	Adopted by Board of Trustees
1	April 4, 2007	Regulatory Approval — Effective Date New
2	March 2009	Added SEA attachment and updates to Effective Date and Compliance sections.

**New Attachment 1-CIP-001-2 Physical Security Emergency Alerts General Requirements**

**1. Initiation by Reliability Coordinator.** A Physical Security Emergency Alert may be initiated only by a Reliability Coordinator at:

- a. The Reliability Coordinator's own decision,
- b. By request from a Transmission Operator,
- c. By request from a Balancing Authority, or
- d. By request from federal, state, or local Law Enforcement Officials.

**2. Situations for initiating alert.** An Alert may be initiated for the following reasons:

- a. A physical threat affecting a control center, grid or generator asset has been identified, or
- b. A physical attack affecting a control center, grid or generator asset has occurred or is imminent.

**3.**

Notification. A Reliability Coordinator who initiates a Physical Security Emergency Alert shall notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify other Reliability Coordinators of the situation via the Reliability Coordinator Information System (RCIS) using the "CIP" category. Additionally, conference calls between Reliability Coordinators shall be held as necessary to communicate system conditions. The Reliability Coordinator shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area and other Reliability Coordinators when the alert has changed levels or ended. Physical Security Emergency Alert Levels To ensure that all Reliability Coordinators clearly understand potential and actual Physical Security Emergency Alerts, NERC has established three levels of Security Emergency Alerts. The Reliability Coordinators will use these terms when explaining security alerts to each other. The Reliability Coordinator may declare whatever alert level is necessary, and need not proceed through the alerts sequentially.

1. Alert 1 – "Control Center / Bulk Electric System asset threat identified" Circumstances: A credible threat of physical attack on a Bulk Electric System asset has been communicated to the Reliability Coordinator. No physical attack has occurred at this point. Determining the credibility of any threat is a subjective process, but the following factors should be considered: a. The nature and specificity of the threat, b. The timing of the threat, c. Mode of threat communication, and d. The criticality of the threatened asset. During a Physical Security Emergency Alert Level 1, Reliability Coordinators, Transmission Operators and Balancing Authorities shall have the following responsibilities:
  - i. Notification The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under "CIP" and notify all Transmission Operators and Balancing Authorities in its Reliability Area.
  - ii. Updating Status during the Physical Security Emergency Alert The declaring Entity shall update the Reliability Coordinator of any changes in the situation until the Alert Level 1 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.
2. Alert 2 – "Verified Physical attack at a single site" Circumstances: A Reliability Coordinator, Transmission Operator, or Balancing Authority has identified a physical attack upon a control center, generator asset, or other bulk electric system asset. During a Physical Security Emergency Alert Level 2, Reliability Coordinators, Transmission Operators and Balancing Authorities shall have the following responsibilities:
  - i. Notification The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under "CIP" and notify all Transmission Operators and Balancing Authorities in its Reliability Area.
  - ii. Updating Status during the Physical Security Emergency Alert The declaring Entity shall update the Reliability Coordinator of the situation a minimum of once per hour until the Alert Level 2 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.
3. Alert 3 – "Verified Physical attack at multiple sites" Circumstances: Multiple attacks have been confirmed on control centers, generator assets or other bulk electric system assets. A Reliability Coordinator shall declare a Physical Security Emergency Alert 3 whenever:
  - a. A Transmission Operator or Balancing Authority reports multiple physical attacks on bulk electric system assets,
  - b. Multiple Transmission Operators or Balancing Authorities report one or more physical attacks on their bulk electric system assets.
  - i. Notification The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under "CIP" and notify all Transmission Operators and Balancing Authorities in its Reliability Area.
  - ii. Updating Status during the Physical Security Emergency Alert The declaring Entity(ies) shall update the Reliability Coordinator of the situation a minimum of once per hour until the Alert Level 3 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.
4. Alert 0 – "Termination of Alert Level" Circumstances: The threat which prompted the Physical Security Emergency Alert Level has diminished or has been removed.
  - i. Notification The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall notify all other Reliability Coordinators via the RCIS, and it shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area that the Alert Level has been terminated.

Cyber Security Emergency Alerts  
Cyber Assets – Those programmable electronic devices and communication networks, including hardware, software, and data, associated with bulk electric system assets.  
Cyber Security Incident – Any malicious act or suspicious event that compromises, or attempts to compromise, the electronic or physical security perimeter of a critical cyber asset or disrupts or attempts to disrupt the operation of a critical cyber asset.  
Critical Cyber Asset – Those cyber assets essential to the reliable operation of critical assets.  
Electronic Security Perimeter – The logical border surrounding the network or group of sub-networks to which the critical cyber assets are connected, and for which access is controlled.  
Physical Security Perimeter – The physical border surrounding computer rooms, telecommunications rooms, operations

centers and other locations in which critical cyber assets are housed and for which access is controlled.

General Requirements

1. Initiation - A Cyber Security Emergency Alert shall be initiated by:
  - a. The Reliability Coordinator's analysis,
  - b. By request from any NERC functional Model entity that Com-003-0 is applicable to.
  - c. By request from federal, state, or local Law Enforcement Officials.
2. Situations for initiating alert. An Alert shall be initiated for the following reasons:
  - a. A cyber threat affecting a control center or bulk electric system asset has been identified, or
  - b. A cyber attack affecting a control center or bulk electric system has occurred or is imminent.
3. Notification. An entity who initiates a Cyber Security Emergency Alert shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator shall notify FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security. The Reliability Coordinator shall also notify as necessary other Reliability Coordinators of the situation via the Reliability Coordinator Information System (RCIS) using the "CIP" category. The Reliability Coordinator shall notify all Transmission Operators and Balancing Authorities in its Reliability Area and other Reliability Coordinators when the alert has changed levels or ended.

Cyber Security Emergency Alert Levels To ensure that all applicable entities clearly understand potential and actual Cyber Security Emergency Alerts, three levels of Security Emergency Alerts shall be used. The Reliability Coordinators will use these terms when communicating security alerts to each other. When declaring the applicable alert level it is important to note that the applicable level can be determined without sequentially proceeding through levels. As an example given circumstances an Alert Level 3 could be called without previously being in an Alert Level 1 or Level 2 state.

1. Alert 1 – "Verified Control Center / Bulk Electric System Cyber Asset threat identified or imminent" What is "verified" - unknown or unauthorized access to a cyber device, unknown or unauthorized change to a cyber device (i.e., config file, O/S, firmware change. 'Verified' could mean the elimination of a false positive in your security monitoring system. 'Verified' could also be the differentiation between malicious and non-malicious (ie human error, not following policy, etc) intent. What is a "threat" - A threat can be perceived as any action or event that occurs where the monitoring authority was not previously made aware that that action would occur. With flimsy change control or access controls, field staff or technical staff performing troubleshooting or other maintenance may access or change devices without notifying the monitoring entity. The monitoring entity would have to treat this as a threat and take appropriate action to either isolate that device from the rest of the system, notify appropriate authority, dispatch a crew, etc Examples of threats - Over and above the examples above, another threat example could be a notification from DHS or other security agency that they have reason to believe a hack, virus or other cyber terrorism activity could occur. Also, noticing a distinct change in network traffic which could imply someone has intercepted your data and can manipulate it before sending it from the control room to the device being controlled or manipulating the data coming from the device before a controller seeing it and forcing them to perform an incorrect control event in reaction to erroneous data. Circumstances: A credible threat of Cyber attack on a Control Center or Bulk Electric System asset has been communicated to the Reliability Coordinator. No cyber attack has occurred at this point. Determining the credibility of any threat is a subjective process, but the following factors should be considered:
  - a. The nature and specificity of the threat,
  - b. The timing of the threat,
  - c. Mode of threat communication, and
  - d. The criticality of the threatened asset.During a Cyber Security Emergency Alert Level 1, applicable entities shall have the following responsibilities:
  - i. Notification An entity who initiates a Cyber Security Emergency Alert Level 1 shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator shall post the declaration of the alert level along with the location of the affected facility on the RCIS under "CIP" and notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify as necessary the FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security.
  - ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity shall update those applicable entities of any changes in the situation until the Alert Level 1 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.
2. Alert 2 – "Verified Cyber attack on a Control Center or Bulk Electric System asset" Circumstances: An applicable entity has identified a cyber attack upon a control center or bulk electric system asset. During a Cyber Security Emergency Alert Level 2, applicable entities shall have the following responsibilities:
  - i. Notification An entity who initiates a Cyber Security Emergency Alert Level 2 shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator responsible shall post the declaration of the alert level along with the location of the affected facility on the RCIS under "CIP" and notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify the FBI local office,

Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security. ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity shall provide updates of the situation a minimum of once per hour until the Alert Level 2 is terminated. The Reliability Coordinator shall update the RCIS as changes occur. 3. Alert 3 – “Verified Cyber attack at one or more Control Center or Bulk Electric System cyber asset” Circumstances: An applicable entity has identified a cyber attack upon a control center or bulk electric system asset and shall declare a Cyber Security Emergency Alert 3 whenever: a. A Transmission Operator or Balancing Authority reports one or more cyber attacks on bulk electric system that render an asset(s) unavailable. i. Notification An entity who initiates a Cyber Security Emergency Alert Level 3 shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify the FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security. ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity(ies) shall provide an update of the situation a minimum of once per hour until the Alert Level 3 is terminated. The Reliability Coordinator shall update the RCIS as changes occur. 4. Alert 0 – “Termination of Alert Level” Circumstances: The threat which prompted the Cyber Security Emergency Alert Level has diminished or has been removed. i. Notification An entity who initiates a Cyber Security Emergency Alert shall make notification as per the NERC Functional model or as Regional / local instruction when situation has diminished or returned to normal. The Reliability Coordinator shall notify all other Reliability Coordinators via the RCIS, and it shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area that the Alert Level has been terminated.

Individual

Jimmy Hartmann

ERCOT ISO

Yes

No

The scope should be modified to provide for a different treatment of reporting requirements that are administrative in nature, or that are after-the-fact (thus cannot impact reliability unless analysis and follow-up is not performed; even then, the impact would be at some future time). Reporting requirements which are of the nature to assist in identification of system concerns or which serve to prevent or mitigate on-going system problems (including, but not limited to, actual or attempted sabotage activity) should remain in standards, but should be separate and apart from the administrative reporting.

No

No

The Regional Reliability Organization is not a registered Functional Entity in the NERC registry. The applicability must be revised to more appropriately assign the requirements to registered functional entities. Also, the industry needs to recognize that there are other resources than generation for which the operators need to be included. Perhaps a demand-side resource should have a resource operator. This particular SAR may not be the appropriate venue for this, but control of resources which can be used to mitigate sabotage events or disturbance events may need to be addressed.

Due to the fact that both the CIP-001-1 and EOP-004-1 have similar reporting standards, initially combining the two sounds like a correct analysis. However, after further consideration and due to the critical nature of its intended function involving Security aspects, the CIP-001 should be intensely evaluated to determine if its intended purpose meets the threshold or criteria to stand alone. The existing standards for CIP-001-1 Sabotage Reporting may help prevent future mitigation actions caused by sabotage events. EOP-004-1 Disturbance Reporting is administrative in nature, thus the jeopardy of the Bulk Electric System reliability is

impacted only if analysis is not performed or if corrective follow-up actions are not implemented. Combining EOP-004 Standard requirements under the umbrella of the CIP -001 Standard would create a high profile Disturbance Reporting Standard. The industry would be better served if information defining sabotage was provided as well as a technical reference document on recognizing sabotage that would also clarify or state any personnel training requirements. All aspects of the intended functions must be reviewed before merging the two standards. At a minimum, we must consider modification that provides improved understanding of the reporting standards and implications as they are currently written.

Group

PSEG Enterprise Group Inc Companies

Public Service Electric and Gas Company

Yes

Yes

No

Yes

The PSEG Companies ask that the drafting team allow sufficient flexibility for sabotage recognition and reporting requirements such that nothing precludes utilizing a single corporate-wide program for both bulk electric system assets and other businesses. PSEG's Sabotage Recognition, Response and Reporting Program is directed to all business areas which are directed to follow the same internal protocol that also satisfies the NERC Standards requirements. For example, for gas assets, PSEG's gas distribution business follows the PSEG corporate-wide program for sabotage recognition and response. PSEG agrees that some modifications should be made to CIP-001 (ex. better define or give examples of sabotage) and EOP-004 to make them clearer • If they are merged, then Sabotage will not be in the title (or the primary focus) because several of the Disturbances that reporting is required for in EOP-004 have nothing to do with sabotage. • EOP-004 has criteria listed in 4 places to determine when to send a report: o Criteria listed in EOP-004 Attachment 1 o Criteria listed in EOP-004 Attachment 2 o Criteria listed in top portion of Table 1-EOP-004 o Criteria listed in bottom portion of Table 1-EOP-004 Therefore, it would be much easier if there was one table of criteria for reference that addressed all of the reportable conditions and all of the applicable reports. • If the 2 standards are merged as suggested in the SAR, any differences in the reporting obligation for actual or attempted sabotage and reporting of disturbances must be clear.

Group

Northeast Power Coordinating Council

Northeast Power Coordinating Council

Yes

No

The SAR needs to be more specific in defining its objectives. CIP-001 Requirement R1 currently states: R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection. The SDT needs to include the following objectives: 1. Develop clear definitions for the terms "operating personnel" and "sabotage events." The definition of "operating personnel," should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term "sabotage event" needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement

individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined. 2. Define the obligations of Registered Entity operating personnel - who are required to be "aware of" such "sabotage events," e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term "aware" in the standard. "Aware" can be interpreted in accordance with its largely passive, dictionary-based meaning, where being "aware" simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of "aware" could refer to more active wording, involving more than mere awareness, e.g., "alert and quick to respond," pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies. EOP-004 The SDT needs to work on the following areas. 1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states: Introduction ...The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: ... c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance ..." The sense of Attachment 1 is internally inconsistent between the introduction ("occurs") and the required actions in 6c ("could have resulted in a system disturbance"). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase "or could have resulted in" a potential system disturbance. This inconsistency should be clarified.

No

Yes

Individual

Rick Terrill

Luminant Power

Yes

Yes

Yes

The SAR drafting team should include in the SAR scope a review of the NRC sabotage and event reporting requirements to ensure there are no overlapping or conflicting requirements between NERC, FERC, and the NRC. The SAR scope should include a review of the CIP Cyber Security Standards and coordination with the CIP SDT to ensure that cyber sabotage reporting definitions are in concert, and ensure that cyber sabotage reporting requirements are not duplicated in multiple standards.

Yes

None

Individual

Rao Somayajula

ReliabilityFirst Corporation

Yes

Yes

No

Yes



Individual
Tony Kroskey
Brazos Electric Power Cooperative, Inc.
Yes
Yes
No
No
May need to consider adding Transmission Owner. I don't see a need for the RRO to be included as they are not owner/operators of grid facilities.
Individual
Paul Golden
PacifiCorp
Yes
Yes
No
No
LSE's don't generally own/operate facilities/systems that would experience a logical or physical sabotage event.
Group
Kansas City Power & Light
Kansas City Power & Light
Yes
Agree with the SAR that clarity would be helpful in establishing criteria regarding what constitutes sabotage reporting.
No
Agree with the scope of the SAR except for the applicable entities. See response to question #4.
No
No
Do not agree Load Serving Entities need to continue to be included for sabotage. According the NERC Functional Model, an LSE provides for estimating customer load and provides for the acquisition of transmission and energy to meet customer load demand. An LSE has no real impact on maintaining the reliability of electric network short of their planning function. Unfortunately, an LSE needs to be included for disturbance reporting to the DOE under certain conditions for loss of customer load. This may be a reason to maintain a separation of CIP-001 and EOP-004 so as not to unnecessarily include an LSE when it is not needed.
If it is desirable to keep CIP-001 and EOP-004 separate, it is recommended the SDT consider adding a reference in CIP-001 to the DOE reporting form either by name or by internet link in the standard.

Individual
Terry Harbour
MidAmerican Energy
No
MidAmerican Energy believes only EOP-004-1 is confusing and needs to be modified or clarified. There is no need to combine the two standards. Standard EOP-004 could be clarified to eliminate references to sabotage which are already covered by CIP-001-1. Standard EOP-004 should be strictly limited to system events, not sabotage.
No
See the responses to questions 1 and 5.
Yes
Attachment TOP-005, section 2.9 speaks of "Multi-site sabotage" with no definition. The ES-ISAC 2008 advisory is an associated standard or practice on sabotage. All references to sabotage should be eliminated or retired except for CIP-001.
No
MidAmerican Energy believes the requirement for the Regional Reliability Organization should be removed from EOP-004-1 since the RRO is a holdover from making the standards enforceable. It is no longer appropriate for the regions to be named as responsible entities within the standards.
Conflicting time frames exist from document updates. Reporting should be consolidated to one form and / or site to minimize conflicts, confusion, and errors. 1) Reporting requirements for the outage of 50,000 or more customers in EOP-004-1 requires a report to be made within one hour while the form OE-417 requires a report be made within six hours of the outage. The six hour reference on the updated OE-417 form is the correct reference. 2) Reporting for either CIP-001 or EOP-004 should center on the DOE Form OE-417. This would eliminate confusion, simplify reporting for system operators thereby directly enhancing reliability during system events. This would also eliminate much of the duplicate material and attachments in EOP-004 3) Although it is beyond the scope of this SAR, the industry would benefit if there was a central location or link on the NERC website containing all reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable System Operators to more efficiently locate and report events.
Individual
Darryl Curtis
Oncor Electric Delivery
Yes
Yes
No
Yes
No Additional Comments
Individual
Chris de Graffenried on behalf of Con Edison & O&R
Consolidated Edison Co. of New York, Inc.
Yes
No
GENERAL – CECONY and ORU support the general objectives of the SAR to merge existing standards CIP-001-1 – Sabotage Reporting and EOP-004-1 – Disturbance Reporting to improve clarity and remove redundancy. However, the SAR needs to be more specific in defining its objectives. CIP-001 Requirement R1

currently states: R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection. The SDT needs to include the following objectives: 1. Develop clear definitions for the terms "operating personnel" and "sabotage events." The definition of "operating personnel," should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term "sabotage event" needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined. 2. Define the obligations of Registered Entity operating personnel - who are required to be "aware of" such "sabotage events," e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term "aware" in the standard. "Aware" can be interpreted in accordance with its largely passive, dictionary-based meaning, where being "aware" simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of "aware" could refer to more active wording, involving more than mere awareness, e.g., "alert and quick to respond," pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies. EOP-004 The SDT needs to work on the following areas. 1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states: Introduction ...The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: ... c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance ..." The sense of Attachment 1 is internally inconsistent between the introduction ("occurs") and the required actions in 6c ("could have resulted in a system disturbance"). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase "or could have resulted in" a potential system disturbance. This inconsistency should be clarified.

No

Yes

Individual

Wayne Pourciau

Georgia System Operations Corp.

Yes

There is a need to eliminate burdensome reporting deadlines which interfere with the reliable operations or recovery of the BES. There is also a need to move requirements for reporting to NERC or Regional Entities (except for reporting of threats to physical or cyber security) from the Requirements section of Reliability Standards to elsewhere.

No

The scope of the SAR should be to move all requirements to report to NERC or Regional Entities out of the Requirements section of all Reliability Standards to elsewhere. This does not include reporting, communicating, or coordinating between reliability entities. The NERC/Region reporting requirements could be consolidated in another document and referenced in the Supporting References section of the Reliability Standards. The deadlines for reporting should be changed to realistic timeframes that do not interfere with operating the BES or responding to incidents yet still allow NERC and the Regions to accomplish their missions.

No

Business practices should not be part of a Reliability Standard. Neither should NERC/Region reporting requirements (except for reporting of threats to physical or cyber security). NERC may need to take some action in the case of threats but does not and cannot take any operational action for most of the reporting requirements that are presently in the Requirements section of the Reliability Standards.

No

EOP-004 should be retired. CIP-001 should not apply to LSEs other than those that are retail marketers.

Entity reporting to NERC/Regions is needed by NERC and the Regions to accomplish their missions of overseeing the reliability of the BES and enforcing compliance with Reliability Standards. An entity not reporting as quickly as possible does not harm the integrity of the Interconnection. In fact, it increases the risk to the BES to be investigating details and filling out forms during a time when attention should be on correcting or mitigating an incident.

Individual

Bob Thomas

Illinois Municipal Electric Agency

Yes

Simplification of reporting requirements should facilitate reliability.

Yes

Yes

A one-stop reporting tool/site would facilitate efficient reporting and compliance; e.g., further development of the ES-ISAC/CIPIS to include all reportable categories and automatic notification of required parties. A single report form would be best.

Yes

IMEA recommends the following considerations: Simplification of reportable events and the reporting process should be the overriding objective. NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting (Version 2.0) should be updated to support this standards development initiative. At some point in the process, it may help if examples are given of events actually reported that did not need to be reported.

Individual

Kasia Mihalchuk

Manitoba Hydro

Yes

Yes

No

Yes

Group

IRC Standards Review Committee

IESO

Yes

Yes

No
No
We agree with the applicability of CIP-001-1 but question the need to include the RRO in EOP-004-1. Requirement R1 of EOP-004-1 can be turned into an industry developed and approved procedural requirement with details included in an appendix; whereas R5 can be changed to a requirement for the responsible entities to act on recommendations and to self-report compliance. Tracking and reviewing status of recommendation do not need to be performed by the RRO, or any entity for that matter, if a self-reporting mechanism is developed.
We suggest that the revision not be conducted with a preconceived notion that the two standards must be combined since there are some differences between sabotage and emergency system conditions, and in the communication and reporting processes and channels. We suggest the SDT start off with a neutral position to focus on improving the standards, then assess the pros and cons of merging the two based on technical merit only.
Group
Pepco Holdings, Inc. - Affiliates
Pepco Holdings, Inc.
Yes
PHI recommends merging these two standards into one.
Yes
No
No
As specified in Order 693, Regional Reliability Organizations are not to be assigned applicability. The revised standard(s) should contain the reporting form either directly or by reference and the RRO should be removed. The other EOP-004 requirements for RROs are now considered normal monitoring activities of the Regional Entities.
Consider CIP-008-2 as potentially having overlaps with the proposed standard
Individual
Jim Sorrels
AEP
Yes
No
Sabotage is a term of intent that is often determined after the fact by the registered entity and/or law enforcement officials. In fact, it is often difficult to determine in real-time the intent of a suspicious event. We would suggest that suspicious events become reportable at the point that the event is determined to have had sabotage intent. The entities should have a methodology to collect evidence, to have the evidence analyzed, and to report those events that are determined to have had the intent of sabotage.
Yes
The current reporting process necessitates multiple reports be sent to multiple parties, which is inefficient and may, inadvertently, result in alignment issues between the separate reports. We would recommend that a single report that combines NERC (CIPIS) and NERC ESISAC information be provided to NERC (CIPIS) that is systematically (programmatically) forwarded to all necessary entities. Further, updates to incidents would also go through NERC with the same electronic processing. Currently, we are not aware of a formal method to report incidents to the FBI, which should be also included in the distribution. The current reporting mechanism to the FBI JTTF is by telephone and the NERC platform described would provide more consistent reporting.
No

We would recommend that the Load Serving Entity (LSE) be removed from both standards, and that the Generator Owner and Transmission Owner be added to the resulting standard.
Group
FirstEnergy
FirstEnergy Corp.
Yes
Yes
We agree with the scope but would also like to see the following considered: 1. References to the DOE reporting process in EOP-004 need to be revised. They currently refer to the old EIA form. 2. Besides "sabotage", it may be helpful to clearly define "vandalism". It is vaguely written in the standards. Also, the process of "public appeals" for the DOE reportable requirements needs to be more clearly defined. 3. Consolidate documents covering reporting requirements. There are currently several documents that require reporting (EOP-004, CIP-001, DOE oe-417, and NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting). NERC also has the "Bulk Power System Disturbance Classification Scale" that does not completely align with all the reporting requirements. Therefore we recommend keeping this as simple as possible by combining all the reporting requirements into one standard. It would be beneficial to not require operators to have to go to 4 different documents to determine what to report on.
No
Although we are not aware of any NAESB business practices that need to be reviewed in conjunction with these proposed revisions, the SDT should consider reviewing current RTO procedures and practices that may require the need for variances in the revised standards.
No
The Regional Reliability Organization should be removed from the applicability of EOP-004-1. Any report they receive would be from the other entities listed. For consistency, the entities should report to the appropriate law enforcement agency. A report to the Reliability Entity should also be made for that entities information only.
1. Under Industry Need it states: "The existing requirements need to be revised to be more specific – and there needs to be more clarity in what sabotage looks like." The use of the phrase "more specific" should be qualified by adding "while not being too prescriptive". As with other reliability standards, we do not want a standard that causes unwarranted and unnecessary additional work and costs to an entity to comply. 2. As pointed out by the NERC Audit and Observation Team in the "Issues to be considered" for CIP-001, clarification is needed regarding contacting the FBI. Prior audits dwelled heavily on FBI notification. For example, our policy states that Corporate Security notifies the FBI. In recent events it appears that local law enforcement handles day to day activities. The notification process for contacting the FBI needs clarification along with specific instances in which to call them. Who should make the call to the FBI? It appears that a protocol needs to be developed to clarify what events require notifying the FBI. It could be as simple as after an incident a standard form is completed and forwarded to the FBI, letting them decide if follow up is needed. 3. We suggest aligning all reporting requirements for consistency. The items requiring reporting and the timelines to report are very inconsistent between NERC and the DOE. NERC's timelines are also not consistent with their own Security Guideline for the Electricity Sector: Threat and Incident Reporting.
Individual
Greg Rowland
Duke Energy
Yes
We agree that additional clarity is needed regarding sabotage and disturbance reporting. Requirements should be tightened up and triggering events/thresholds of materiality need to be better defined.
No
While we agree with the need for clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each

requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities. Also, requirements to report possible non-compliances should be eliminated. We strongly support voluntary self-reporting, but not mandatory self-reporting.

No

No

It's unclear to us that the RRO should continue to be an applicable entity.

Individual

Howard Rulf

We Energies

Yes

No

Consider including the sabotage issues in IRO-014-1 R 1.1.1 footnote 1 and TOP-005-1 Attachment 1, 2.9.

No

Yes

Group

Electric Market Policy

Dominion Resources Inc.

Yes

Comments: Agree with the statement that sabotage is hard to determine in real time by operations staffs. The determination of sabotage should be left up to law enforcement. They have the knowledge and peer contacts needed to adequately determine whether physical or cyber intrusions are merely malicious acts or coordinated efforts (sabotage). The operators should only be required to report physical and cyber intrusions to law enforcement. All other reporting requirements should apply to law enforcement once a determination of sabotage has been made. If the recommendations above are not to be accepted, then we have the following comments: CIP-001-1 1) R1 – states entities “shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and “multi-site sabotage” affecting larger portions of the Interconnection. The SAR notes that the industry objects to the multi-site requirement, most likely because the term is ambiguous. If this term remains in the standard, it needs to be clearly defined and responsibilities for obtaining (how do you get this information and from whom?) and distributing need to be included. 2) R1 – audits have shown confusion over the requirement to make operating personnel aware of sabotage events. The term operating personnel needs to be defined. Are they the individuals responsible for operating the facility, coordinating with other entities (i.e., RC, BA, TOP, GOP, and LSE)? It has been suggested that notification is required to all personnel at a facility. Keep in mind the purpose of the standard is to ensure sabotage events are properly reported, not to address emergency response. 3) R1 – The SAR (NERC Audit and Observation Team) notes that Registered Entities have processes and procedures in place, but not all personnel have been trained. There is no specific training requirement in the standard. 4) R2 & R3 – I agree with the SAR that sabotage needs to be defined and these requirements should be more specific with respect to the information to be communicated. It seems to me that the standard should mirror the criteria contained in DOE OE-417. The emphasis should be placed on ensuring that the same information communicated to DOE is shared with the appropriate parties in the Interconnection. 5) R4 – I agree with the SAR (NERC Audit and Observation Team) comments regarding the intention of this requirement. There is no language that directs contact with FBI or RCMP

although that is what is implied by the Purpose statement. 6) VRF Comments – I’m not sure what is intended by the statement “Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures.” The purpose of the standard is that of communication. No operational decisions or actions are directed by this standard, nor does it require entities to address operational aspects resulting from sabotage. 7) The potential exists for overlapping sabotage reporting requirements at nuclear power plants due to multiple regulators (Nuclear Regulatory Commission (NRC) – 10 CFR 73 and Federal Energy Regulatory Commission (FERC) – NUC-001-1). Some entities may have revised existing NRC driven procedures to accommodate reporting requirements of both regulators. Because of the restrictions placed on NRC driven documents (i.e., procedures are classified as “safeguards information”), it can be difficult to demonstrate compliance to NERC and/or FERC without ensuring that the individuals are qualified for receipt of such information per 10 CFR 73. Additionally, multiple procedures may have the unintended consequence of delaying appropriate communication. EOP-004-1 Consider removing Attachment 2 as the information is duplicated in DOE Form OE-417. A simple reference to the form should suffice.

Yes

No

No

Applicability should not apply to LSE unless they have physical assets. If they do not have such assets, they are unable to determine how many customers are out, how much load was lost or the duration of an outage. We continue to question the need for the LSE entity in reliability standards. End use customer load is either connected to transmission or distribution facilities. So, the applicable planner has to plan for that load when designing its facilities or the load will not have reliable service. To the extent that energy and capacity for that load is supplied by an entity other than the TO or DP, the TO or DP should have interconnection requirements that compel the supplier to provide any and all data necessary to meet the requirements of reliability standards.

CIP-008-1 Incident Reporting and Response Planning – include some requirements that require coordination with the requirements addressed in this project.

Individual

Jianmei Chai

Consumers Energy Company

Yes

Yes

No

Yes

Individual

Mike Sonnelitter

NextEra Energy Resources, LLC

Yes

No

The scope of the SAR should not include Generator Operators.

No



No
The scope of the proposed SAR should not include the Generator Operator.
No comment.
Individual
D. Bryan Guy
Progress Energy
No
No. It is not clear that the issues listed in a revised standard will improve reliability. Revision based on redundancy is not sufficient reason for combination. Extensive documentation efforts have been made to comply with the current Standards. Unless combining these Standards provides compelling Reliability benefit, it is not worth the industry's resources to revise existing documentation and processes for the sake of eliminating redundancy. Redundancy issues were raised prior to the ERO adopting the initial Standard set into law. We have noted the other issues raised in the SAR, however, it is still unclear where the Reliability benefit of this SAR is evidenced.
No
No. If this SAR moves forward other standards may need to be considered. For example, in CIP-008, incident reporting for cyber incidents leads to filing of the OE-417 form.
Yes
Yes. If this SAR moves forward other practices such as those required by CIP-008 (cyber incident reporting via the OE-417 form) may need to be considered.
Yes
Group
Bonneville Power Administration
BPA Transmission Reliability Program
No
Eliminating a single standard by consolidating two standards does not improve reliability. All of the defined actions are indeed being taken now.
No
Leave as is, all requirements for reporting are now covered. A common definition of sabotage is already widely available.
No
Yes
Individual
Kirit Shah
Ameren
Yes
No
There seems to be an open slate including the following language in the scope "The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information)." The unnamed improvements should be limited to those requirements that relate only to Disturbance and Sabotage NOT a general wish list(or witch hunt).

No
Yes
None
Group
MRO NERC Standards Review Subcommittee
Michael Brytowski
Yes
No
The MRO NSRS would like to keep the references to the DOE reporting form.
Yes
No
As FERC has directed, the RRO should be removed since they are not owners or operators of the BES.
A. The SAR states that there may be impact on a related standard, COM-003-1 (page SAR-5). Is the SDT referring to Project 2007-02, Operating Personnel Communication Protocols? If so, this is a SAR too and should not be used as a reference. B. CIP-001-1 and EOP-004-1 should be combined into one EOP Standard. C. Within EOP-004-1 there is industry confusion on what form to submit in the event of an event. There should only be one form for the new combination Standard eliminating the need for reporting form attachments. It should be the DOE Form, OE-417. Although it is beyond the scope of this SAR, it would greatly benefit industry if there was a central location on the NERC website containing ALL reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable the System Operators to efficiently locate the most current version of the appropriate form in order to report events. D. The word Disturbance is primarily used in other Standards as in, Disturbance Control Standard or system separation due to a disturbance. Should the NERC definition be updated? Should the word "Sabotage" be defined by NERC? Additionally, we recommend that one definition of "Sabotage" be utilized industry-wide, instead of varying definitions by multiple groups like the DOE, ESIAC, etc.

## Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

The Disturbance and Sabotage Reporting SAR Drafting Team (DSR SAR DT) thanks all commenters who submitted comments on the first draft SAR. The SAR was posted for a 30-day public comment period from April 22, 2009 through May 21, 2009. The stakeholders were asked to provide feedback on the documents through a special Electronic Comment Form. There were 40 sets of comments, including comments from more than 120 different people from over 60 companies representing 9 of the 10 Industry Segments as shown in the table on the following pages.

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

The majority of stakeholders agree that there is a reliability related need to support modifying CIP-001-1 and EOP-004-1. Of those stakeholders providing comments, they predominantly agreed with the reliability-related reason for the SAR but offered the following concerns:

- 1) Concerns with applicability of the requirements: The SAR DT notes that applicability will be determined by the final requirements that are written for the standard.
- 2) Concerns on combining the standards: The SAR DT notes that the Purpose of the SAR indicates that the standards *may* be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).
- 3) Concerns with the definition of sabotage and the inclusion of vandalism, thresholds for defining sabotage, etc.
- 4) Concerns on onerous or duplicative reporting: The Brief Description section of the SAR states "Specific references to the DOE form need to be eliminated". This should address its concerns.

The SAR DT does not feel that the SAR should be revised based on these comments. The SAR DT will forward these comments to the Standard Drafting Team for its consideration in the drafting of the standards.

The majority of stakeholders agree with the scope of the SAR. Several stakeholders offered suggestions for items to include in the SAR, however the SAR DT believes that these comments may be too prescriptive to include with the SAR. The team feels that inclusion of these types of comments would prevent the Standard Drafting Team from having the ability to develop standard(s) based on stakeholder consensus. The SAR DT will forward these comments to the Standard Drafting Team for its consideration. Some of the comments received include:

- 1) The inclusion of specific definitions in the SAR (operating personnel, sabotage events, obligations): The SAR DT believes that this would be too prescriptive and believe that this should be addressed by the Standard Drafting Team.
- 2) Consolidate documents covering reporting requirements: The SAR DT agrees and suggests that the Standard Drafting Team investigate a "one-stop-shopping" solution for the various reports required, including the DOE report.

Stakeholders did not identify any associated business practices for consideration under the SAR. One stakeholder identified a related standard that references multi-site sabotage. The team has included a reference to TOP-005, section 2.9 (Appendix 1) in the SAR under Related Standards. Two stakeholders suggested that Business Practices should not be considered in a standard. The SAR DT notes that standard development projects must not invalidate business practices that are already in place and aids in coordination with North American Energy Standards Board (NAESB).

Many stakeholders had comments regarding applicability of the two standards. Based on these comments, the SAR DT has added Transmission Owner, Generator Owner and Distribution Provider to the Applicability section of the SAR as *possible* entities in the standard(s) developed under this SAR as the Standard Drafting team may have a need to include them in the standard(s). The applicability of Load-Serving Entity or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process. The three main comments were:

- 1) Regional Reliability Organization applicability: Several commenters do not feel the RRO should be in the standards. The DSR SAR DT concurs and notes that the SAR states that "EOP-004 has some 'fill-in-the-blank' components to eliminate". This will remove the RRO from applicability.
- 2) Load-Serving Entity/Distribution Provider: Several stakeholders do not feel that the standards should be applicable to LSEs, but should apply to Distribution Providers. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.
- 3) Transmission Owner/Generator Owner: Several stakeholders have indicated a need to include the TO as an applicable entity. A couple of those would also include the GO. The SAR DT discussed the addition of the TO and GO. The team has a concern that there may be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.

Stakeholders provided many good comments that should be considered in the development of the standards under this project. The SAR DT does not believe that these comments require any significant revisions to the SAR, but will forward these comments to the Standard Drafting Team for its consideration in drafting the standard(s). The comments include:

- 1) Consolidation of reports: The SAR DT agrees with this concept and will forward the comment to the Standard Drafting Team for its consideration.
- 2) Concerns about pre-determination of combining CIP-001 and EOP-004 into one standard: The SAR states: CIP-001 may be merged with EOP-004 to eliminate redundancies. The two standards may be left separate.

- 3) Reporting criteria in multiple tables: The team agrees that it would be easier if there were only one table. Part of this scope of this project is to eliminate redundancies and make general improvements to the standard. The team also agrees that the requirements developed should be clear in their reliability objective.

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Gerry Adamski, at 609-452-8060 or at [gerry.adamski@nerc.net](mailto:gerry.adamski@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

---

<sup>1</sup> The appeals process is in the Reliability Standards Development Procedures: <http://www.nerc.com/standards/newstandardsprocess.html>.

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

---

**Index to Questions, Comments, and Responses**

1. Do you agree that there is a reliability-related reason to support modifying CIP-001-1 and EOP-004-1? If not, please explain in the comment area. ....12

2. Do you agree with the scope of the proposed SAR? If not, please explain what should be added or deleted to the proposed scope. ....20

3. Are you aware of any associated business practices that we should consider with this SAR? If yes, please explain in the comment area. ....38

4. CIP-001-1 applies to the Reliability Coordinator, Transmission Operator, Balancing Authority, Generator Operator, and the Load-serving Entity. EOP-004-1 applies to the same entities, plus the Regional Reliability Organization. Do you agree with the applicability of the existing CIP-001-1 and the existing EOP-004-1? If no, please identify what you believe should be modified.....43

5. If you have any other comments on the SAR or proposed modifications to CIP-001-1 and EOP-004-1 that you haven't provided in response to the previous questions, please provide them here. ....51

## Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	Jim Case	SERC OC Standards Review Group	X		X								
Additional Member		Additional Organization		Region			Segment Selection							
1.	Al McMeekin	SCE&G		SERC			1, 3, 5							
2.	Eugene Warnecke	Ameren		SERC			1, 3, 5							
3.	Gary Hutson	SMEPA		SERC			1, 3, 5							
4.	Melinda Montgomery	Entergy		SERC			1, 3							
5.	Tom Sims	Southern		SERC			1, 3, 5							
6.	Marc Butts	Southern		SERC			1, 3, 5							
7.	Chris Bradley	BREC		SERC			1, 3, 5							
8.	Tom Kanzlik	SCE&G		SERC			1, 3, 5							
9.	Paul Turner	Ga Systems Operations Corp.		SERC			3							
10.	Phil Creech	Progress Energy Carolinas		SERC			1, 3, 5							
11.	Vicky Budreau	SCPSA		SERC			1, 3, 5, 9							
12.	Renee Free	SCPSCA		SERC			9							
13.	Mike Clements	TVA		SERC			1, 3, 5, 9							
14.	Travis Sykes	TVA		SERC			1, 3, 5							

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

	Commenter	Organization	Industry Segment										
			1	2	3	4	5	6	7	8	9	10	
15.	John Troha	SERC	RFC							10			
2.	Group	Harry Tom	Project 2007-02 Operating Personnel Comms Protocols SDT	X	X			X				X	X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>					
1.	Lloyd Snyder	GSOC	SERC									1	
2.	Tom Irvine	HydroOne	NPCC									1, 9	
3.	Alan Allgower	ERCOT	ERCOT									10	
4.	Harvie Beavers	Colmac Clarion/Piney Creek LP	RFC									5	
5.	Mark L. Bradley	ITC	MRO									1	
6.	Mike Brost	JEA	FRCC									1	
7.	William D Ellard	CAISO	WECC									10	
8.	Ronald Goins	MISO	MRO									10	
9.	Leanne Harrison	PJM	RFC									10	
10.	James McGovern	ISO-NE	NPCC									10	
11.	Wayne Mitchell	Entergy	SERC									1	
12.	John Stephens	City Utilities of Springfield	RFC									1	
13.	Fred Waites	Southern Company	SERC									1	
3.	Group	Kenneth D. Brown	PSEG Enterprise Group Inc Companies	X		X							
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>					
1.	Clint Bogan	PSEG Fossil LLC	RFC									5	
2.	James Hebson	PSEG Energy Resources & Trade	RFC									6	
3.	Gary Grysko	PSEG Power Connecticut	NPCC									5	
4.	Dominic DiBari	PSEG Texas LLC	ERCOT									5	
4.	Group	Guy Zito	Northeast Power Coordinating Council										X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>					
1.	Ralph Rufrano	New York Power Authority	NPCC									5	
2.	Alan Adamson	New York State Reliability Council	NPCC									10	



Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

	Commenter	Organization	Industry Segment											
			1	2	3	4	5	6	7	8	9	10		
3.	Greg Campoli	New York Independent System Operator	NPCC								2			
4.	Roger Champagne	Hydro-Quebec TransEnergie	NPCC								2			
5.	Kurtis Chong	Independent Electricity System Operator	NPCC								2			
6.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC								1			
7.	Manuel Couto	National Grid	NPCC								1			
8.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC								1			
9.	Brian Evans-Mongeon	Utility Services	NPCC								8			
10.	Mike Garton	Dominion Resources Services, inc.	NPCC								5			
11.	Mike Gildea	Constellation Energy	NPCC								6			
12.	Brian Gooder	Ontario Power Generation Incorporated	NPCC								5			
13.	Kathleen Goodman	ISO - New England	NPCC								2			
14.	David Kiguel	Hydro One Networks, Inc.	NPCC								1			
15.	Michael Lombardi	Northeast Utilities	NPCC								1			
16.	Randy MacDonald	New Brunswick System Operator	NPCC								2			
17.	Bruce Metruck	New York Power Authority	NPCC								6			
18.	Robert Pellegrini	The United Illuminating Company	NPCC								1			
19.	Michael Schiavone	National Grid	NPCC								1			
20.	Michael Sonnelitter	FPL Energy/NextEra Energy	NPCC								5			
21.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC								3			
22.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC								10			
23.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC								10			
5.	Group	Michael Gammon	Kansas City Power & Light	X		X		X	X					
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>			<b>Segment Selection</b>							
1.	Joe Doetzl	Kansas City Power & Light	SPP								1, 3, 5, 6			
2.	John Breckenridge	Kansas City Power & Light	SPP								1, 3, 5, 6			
6.	Group	Ben Li	IRC Standards Review Committee		X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>			<b>Segment Selection</b>							

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

	Commenter	Organization	Industry Segment									
			1	2	3	4	5	6	7	8	9	10
1.	James Castle	NYISO	NPCC						2			
2.	Charles Yeung	SPP	SPP						2			
3.	Anita Lee	AESO	WECC						2			
4.	Matt Goldberg	ISO-NE	NPCC						2			
5.	Bill Phillips	MISO	MRO						2			
6.	Steve Myers	ERCOT	ERCOT						2			
7.	Lourdes Estrada-Salineró	CAISO	WECC						2			
7.	Group	Richard Kafka	Pepco Holdings, Inc. - Affiliates									
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>				<b>Segment Selection</b>					
1.	Kara Dundas	Conectiv Energy Supply, Inc.	RFC				5					
2.	Tony Gabrielli	Conectiv Energy Supply, Inc.	RFC				5					
3.	George Gacser	Potomac Electric Power Co.	RFC				1, 3, 5					
4.	E. W. Stowe	Pepco Holdings, Inc	RFC				1, 3, 5					
5.	Mark Godfrey	Pepco Holdings, Inc	RFC				1, 3					
8.	Group	Sam Ciccone	FirstEnergy									
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>				<b>Segment Selection</b>					
1.	Jim Eckels	FE	RFC				1					
2.	John Martinez	FE	RFC				1					
3.	John Reed	FE	RFC				1					
4.	Dave Folk	FE	RFC				1, 3, 4, 5, 6					
5.	Doug Hohlbaugh	FE	RFC				1, 3, 4, 5, 6					
6.	Larry Hartley	FE	RFC				3					
9.	Group	Jalal Babik	Electric Market Policy									
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>				<b>Segment Selection</b>					
1.	Louis Slade		SERC				6					
2.	Mike Garton		NPCC				5					

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
10.	Group	Denise Koehn	Bonneville Power Administration	X		X		X	X					
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>						<b>Segment Selection</b>				
		1. Theodore Snodgrass	Dispatch	WECC						1				
11.	Group	Michael Brytowski	MRO NERC Standards Review Subcommittee											X
		<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>						<b>Segment Selection</b>				
		1. Carol Gerou	MRO	MRO						10				
		2. Neal Balu	WPS	MRO						3, 4, 5, 6				
		3. Pam Sordet	XCEL	MRO						1, 3, 5, 6				
		4. Joe DePoorter	MGE	MRO						3, 4, 5, 6				
		5. Ken Goldsmith	ALTW	MRO						4				
		6. Jim Haigh	WAPA	MRO						1, 6				
		7. Terry Harbour	MEC	MRO						1, 3, 5, 6				
		8. Joseph Knight	GRE	MRO						1, 3, 5, 6				
		9. Scott Nickels	RPU	MRO						3, 4, 5, 6				
		10. Dave Rudolph	BEPC	MRO						1, 3, 5, 6				
		11. Eric Ruskamp	LES	MRO						1, 3, 5, 6				
12.	Individual	Stephen V. Fisher	Lands Energy Consulting											
13.	Individual	Brent Hebert	Calpine Corporation					X						
14.	Individual	Steve Toth	Covanta					X						
15.	Individual	Harvie Beavers	Colmac Clarion					X						
16.	Individual	Russell A. Noble	Cowlitz County PUD			X								
17.	Individual	Michael Puscas	United Illuminating	X		X								
18.	Individual	George Pettyjohn	Reliant Energy					X						

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

		Commenter	Organization	Industry Segment											
				1	2	3	4	5	6	7	8	9	10		
19.	Individual	Judith A. James	Texas Regional Entity												
20.	Individual	Edward C. Stein	self									X			
21.	Individual	Chris Scanlon	Exelon	X		X		X	X						
22.	Individual	Mike Davis	WECC												X
23.	Individual	Jimmy Hartmann	ERCOT ISO		X										
24.	Individual	Rick Terrill	Luminant Power					X							
25.	Individual	Rao Somayajula	ReliabilityFirst Corporation												X
26.	Individual	Tony Kroskey	Brazos Electric Power Cooperative, Inc.	X											
27.	Individual	Paul Golden	PacifiCorp	X		X		X	X						
28.	Individual	Terry Harbour	MidAmerican Energy	X											
29.	Individual	Darryl Curtis	Oncor Electric Delivery	X											
30.	Individual	Chris de Graffenried on behalf of Con Edison & O&R	Consolidated Edison Co. of New York, Inc.	X		X			X						
31.	Individual	Wayne Pourciau	Georgia System Operations Corp.			X									
32.	Individual	Bob Thomas	Illinois Municipal Electric Agency				X								
33.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X						
34.	Individual	Jim Sorrels	AEP	X		X		X	X						

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
35.	Individual	Greg Rowland	Duke Energy	X		X		X	X					
36.	Individual	Howard Rulf	We Energies			X	X	X						
37.	Individual	Jianmei Chai	Consumers Energy Company			X	X	X						
38.	Individual	Mike Sonnelitter	NextEra Energy Resources, LLC					X						
39.	Individual	D. Bryan Guy	Progress Energy	X		X		X						
40.	Individual	Kirit Shah	Ameren	X		X		X	X					

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**1. Do you agree that there is a reliability-related reason to support modifying CIP-001-1 and EOP-004-1? If not, please explain in the comment area.**

**Summary Consideration:** The majority of stakeholders agree that there is a reliability related need to support modifying CIP-001-1 and EOP-004-1. Of those stakeholders providing comments, they predominantly agreed with the reliability-related reason for the SAR but offered the following concerns:

- 1) Applicability of the requirements: The SAR DT notes that applicability will be determined by the final requirements that are written for the standard.
- 2) Combining the standards: The SAR DT notes that the Purpose of the SAR indicates that the standards *may* be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).
- 3) Definition of sabotage and the inclusion of vandalism, thresholds for defining sabotage, etc.
- 4) Onerous or duplicative reporting: The Brief Description section of the SAR states “Specific references to the DOE form need to be eliminated”. This should address any concerns.

The SAR DT will forward these comments to the Standard Drafting Team for its consideration in the drafting of the standards.

Organization	Yes or No	Question 1 Comment
SERC OC Standards Review Group	No	The EOP-004-1 standard is an unnecessary duplication of existing DOE reporting requirements. This essentially exposes an entity to fines by NERC, enforced by FERC, for failure to comply with a DOE regulation, which seems improper to us. In addition, reporting requirements do not have an impact on the reliability of the BES
<p><b>Response: The DSR SAR DT thanks you for your comment. The Brief Description section of the SAR states “Specific references to the DOE form need to be eliminated”.</b></p>		
MidAmerican Energy	No	MidAmerican Energy believes only EOP-004-1 is confusing and needs to be modified or clarified. There is no need to combine the two standards. Standard EOP-004 could be clarified to eliminate references to sabotage which are already covered by CIP-001-1. Standard EOP-004 should be strictly limited to system events, not sabotage.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT notes that the Purpose of the SAR indicates that the standards <i>may</i> be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting Team to make this determination through the Standard Development Process (with stakeholder input).</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
Bonneville Power Administration	No	Eliminating a single standard by consolidating two standards does not improve reliability. All of the defined actions are indeed being taken now.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT notes that the Purpose of the SAR indicates that the standards <i>may</i> be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).</b></p>		
Progress Energy	No	No. It is not clear that the issues listed in a revised standard will improve reliability. Revision based on redundancy is not sufficient reason for combination. Extensive documentation efforts have been made to comply with the current Standards. Unless combining these Standards provides compelling Reliability benefit, it is not worth the industry's resources to revise existing documentation and processes for the sake of eliminating redundancy. Redundancy issues were raised prior to the ERO adopting the initial Standard set into law. We have noted the other issues raised in the SAR, however, it is still unclear where the Reliability benefit of this SAR is evidenced.
<p><b>Response: The DSR SAR DT thanks you for your comment. Industry consensus indicates that eliminating redundancy between standards is required to avoid potential double jeopardy issues with compliance to the standards. Furthermore, one of the FERC Order 693 directives for CIP-001 is:</b></p> <p><b>Explore ways to reduce redundant reporting, including central coordination of sabotage reports and a uniform reporting format.</b></p>		
Kansas City Power & Light	Yes	Agree with the SAR that clarity would be helpful in establishing criteria regarding what constitutes sabotage reporting.
<p><b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for CIP-001 is:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p>		
Pepco Holdings, Inc. - Affiliates	Yes	PHI recommends merging these two standards into one.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT notes that the Purpose of the SAR indicates that the standards <i>may</i> be merged to eliminate redundancy and provide clarity. It will be up to the Standard Drafting team to make this determination through the Standard Development Process (with stakeholder input).</b></p>		
Electric Market Policy	Yes	Comments: Agree with the statement that sabotage is hard to determine in real time by operations staffs. The determination of sabotage should be left up to law enforcement. They have the knowledge and peer contacts needed to adequately determine whether physical or cyber intrusions are merely malicious acts or coordinated efforts (sabotage).

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
		<p>The operators should only be required to report physical and cyber intrusions to law enforcement. All other reporting requirements should apply to law enforcement once a determination of sabotage has been made. If the recommendations above are not to be accepted, then we have the following comments:</p> <p>CIP-001-1</p> <p>1) R1 states entities shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection. The SAR notes that the industry objects to the multi-site requirement, most likely because the term is ambiguous. If this term remains in the standard, it needs to be clearly defined and responsibilities for obtaining (how do you get this information and from whom?) and distributing need to be included.</p> <p>2) R1 audits have shown confusion over the requirement to make operating personnel aware of sabotage events. The term operating personnel needs to be defined. Are they the individuals responsible for operating the facility, coordinating with other entities (i.e., RC, BA, TOP, GOP, and LSE)? It has been suggested that notification is required to all personnel at a facility. Keep in mind the purpose of the standard is to ensure sabotage events are properly reported, not to address emergency response.</p> <p>3) R1 The SAR (NERC Audit and Observation Team) notes that Registered Entities have processes and procedures in place, but not all personnel have been trained. There is no specific training requirement in the standard.</p> <p>4) R2 &amp; R3 I agree with the SAR that sabotage needs to be defined and these requirements should be more specific with respect to the information to be communicated. It seems to me that the standard should mirror the criteria contained in DOE OE-417. The emphasis should be placed on ensuring that the same information communicated to DOE is shared with the appropriate parties in the Interconnection.</p> <p>5) R4 I agree with the SAR (NERC Audit and Observation Team) comments regarding the intention of this requirement. There is no language that directs contact with FBI or RCMP although that is what is implied by the Purpose statement.</p> <p>6) VRF Comments I'm not sure what is intended by the statement Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures? The purpose of the standard is that of communication. No operational decisions or actions are directed by this standard, nor does it require entities to address operational aspects resulting from sabotage.</p> <p>7) The potential exists for overlapping sabotage reporting requirements at nuclear power plants due to multiple regulators (Nuclear Regulatory Commission (NRC) 10 CFR 73 and Federal Energy Regulatory Commission (FERC) NUC-001-1). Some entities may have revised existing NRC driven procedures to accommodate reporting requirements of both regulators. Because of the restrictions placed on NRC driven documents (i.e., procedures are classified as safeguards information), it can be difficult to demonstrate compliance to NERC and/or FERC without ensuring that the individuals are qualified for receipt of such information per 10 CFR 73. Additionally, multiple procedures may have the unintended consequence of delaying appropriate communication. EOP-004-1 Consider removing Attachment 2 as the information is</p>



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
		duplicated in DOE Form OE-417. A simple reference to the form should suffice.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team notes that your comments relate directly to potential revisions of the standard requirements. The team will pass your comments along to the Standards Drafting Team for its consideration. For item 4, one of the FERC Order 693 directives for CIP-001 is:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p>		
Lands Energy Consulting	Yes	<p>I have worked with 5 Northwest public utilities on developing procedures related to CIP-001-1 and EOP-004-1. All 5 utilities operate electric systems in fairly remote locations and are embedded in a larger utility's Balancing Authority/Transmission Operator area.</p> <p>A. CIP-001-1 - Developing procedures to unambiguously identify acts of sabotage has been particularly challenging for these systems. In general, it's hard for them to determine whether the most prevalent forms of malicious and intentional system damage that they incur - copper theft and gun shot insulators/equipment - should qualify as acts of sabotage. Although none of the systems consider copper theft to be acts of sabotage, two of the systems consider gun shot insulators/equipment to be acts of sabotage. The other systems look for intent to disrupt electric system operations as a key component of their sabotage identification procedures. Additional guidance from NERC in the form of CIP-001-1 modifications or a companion guidelines document on sabotage identification would provide much needed guidance for these procedures.</p> <p>B. EOP-004-1 - This standard was clearly drafted with the larger electric systems in mind. I have one client that serves 3300 commercial/residential customers from 4-115/13 kV substation transformers and one large industrial customer (80% of its energy load) from a 230/13 kV substation. 75% of the client's load is served from three substations attached to a long, 115 kV transmission line operated by the Bonneville Power Administration. Whenever the line relays open on a permanent fault (which happens 2-3 times per year), the client loses over 50% of its customers (but no more than 10-15 MW during winter peak), thereby necessitating the preparation of a Disturbance Report. To allow utilities to concentrate on operating their systems, without fear of violating EOP-004-1 for failure to report trivial outages, I would remove LSEs from the obligation to report disturbances - leave the reporting to the BA/TOP for large outages in their footprint.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>A. The team notes that your comments relate directly to potential revisions of the standard requirements. The team will pass your comments along to the Standards Drafting Team for its consideration.</b></p> <p><b>B. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process. The team</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
<b>will pass your comments along to the Standards Drafting Team for its consideration.</b>		
Calpine Corporation	Yes	Communication of facility status or emergencies between merchant generators registered as GOP and the RC, BA, GOP, or LSE in which the facility resides should be coordinated for EOP -004 reporting. The reporting to NERC/DOE should come from the RC, BA, GOP, or LSE.
<b>Response: The DSR SAR DT thanks you for your comment. The team concurs that reporting should be coordinated and will pass your comments along to the Standards Drafting Team for its consideration.</b>		
Covanta	Yes	Yes - the key to Sabotage reporting requirements is identifying what the 'definition' is of an actual or potential 'Sabotage' event. Like any other standard, if FERC/NERC leave it up to 2000+ entities to establish their own definitions of 'Sabotage', you may likely get 2000+ answers. That is not a controlled and coordinated approach. I offer the following definition, "Sabotage - Deliberate or malicious destruction of property, obstruction of normal operations, or injury to personnel by outside agents." Examples of sabotage events could include, but are not limited to, suspicious packages left near site electrical generating or electrical transmission assets, identified destruction of generating assets, telephone/e mail received threats to destroy or interrupt electrical generating efforts, etc." These have passed multiple NERC regional audits and reviews to date.
<b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for CIP-001 is: Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event. The team will pass your comments along to the Standards Drafting Team for its consideration.</b>		
Cowlitz County PUD	Yes	The standards as written now create reporting on local customer quality of service outage events not related to BPS disturbances. Sabotage reporting has degenerated into reporting of mischievous vandalism and minor theft occurrences. This creates compliance documentation overburden and waste of limited funds needed for true BPS reliability concerns, and also adds nuisance calls to the FBI and Homeland Security.
<b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for CIP-001 is: Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event. This should address the concern of sabotage vs. vandalism/theft reporting.</b>		
Reliant Energy	Yes	EOP-004-1 indicates that Generators should analyze disturbances on the bulk electrical system or their facilities. Generators do not have the capability of analyzing the bulk electrical system other than Frequency. Even so, generators can not unilaterally respond to what it thinks are disturbances. In the case of CAISO The Participating Generator

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
		Agreement prevents me from making any unilateral moves save for the direst frequency emergencies. If the System operator or Reliability Coordinator informs the generator that there is a disturbance and that logs and readouts etc. are required then the generator should respond with all available information for the subject hours or time. Clearer responsibilities provide clearer results.
<p><b>Response: The DSR SAR DT thanks you for your comment. While the team agrees that generators may not have the capability to analyze events, the team note that you concern is regarding applicability of requirements. The final wording of the requirements developed by the Standard Drafting Team will determine the applicability.</b></p>		
Georgia System Operations Corp.	Yes	There is a need to eliminate burdensome reporting deadlines which interfere with the reliable operations or recovery of the BES. There is also a need to move requirements for reporting to NERC or Regional Entities (except for reporting of threats to physical or cyber security) from the Requirements section of Reliability Standards to elsewhere.
<p><b>Response: The DSR SAR DT thanks you for your comment. Specific revisions to the requirements will be vetted during the standard development process.</b></p>		
Illinois Municipal Electric Agency	Yes	Simplification of reporting requirements should facilitate reliability.
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p>		
Duke Energy	Yes	We agree that additional clarity is needed regarding sabotage and disturbance reporting. Requirements should be tightened up and triggering events/thresholds of materiality need to be better defined.
<p><b>Response: The DSR SAR DT thanks you for your comment. One of the FERC Order 693 directives for this project is:</b> Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</p>		
MRO NERC Standards Review Subcommittee	Yes	
Colmac Clarion	Yes	
United Illuminating	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
PSEG Enterprise Group Inc Companies	Yes	
Northeast Power Coordinating Council	Yes	
IRC Standards Review Committee	Yes	
FirstEnergy	Yes	
Texas Regional Entity	Yes	
Edward C. Stein	Yes	
Exelon	Yes	
WECC	Yes	
ERCOT ISO	Yes	
Luminant Power	Yes	
ReliabilityFirst Corporation	Yes	
Brazos Electric Power Cooperative, Inc.	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 1 Comment
PacifiCorp	Yes	
Oncor Electric Delivery	Yes	
Consolidated Edison Co. of New York, Inc.	Yes	
Manitoba Hydro	Yes	
AEP	Yes	
We Energies	Yes	
Consumers Energy Company	Yes	
NextEra Energy Resources, LLC	Yes	
Ameren	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

2. Do you agree with the scope of the proposed SAR? If not, please explain what should be added or deleted to the proposed scope.

**Summary Consideration:** The majority of stakeholders agree with the scope of the SAR. Several stakeholders offered suggestions for items to include in the SAR, however the SAR DT believes that these comments may be too prescriptive to include with the SAR. The team feels that inclusion of these types of comments would prevent the Standard Drafting Team from having the ability to develop standard(s) based on stakeholder consensus. The SAR DT will forward these comments to the Standard Drafting Team for its consideration. Some of the comments received include:

- 1 The inclusion of specific definitions in the SAR (operating personnel, sabotage events, obligations): The SAR DT believes that this would be too prescriptive and believe that this should be addressed by the Standard Drafting Team.
- 2 Consolidate documents covering reporting requirements: The SAR DT agrees and suggests that the Standard Drafting Team investigate a “one-stop-shopping” solution for the various reports required, including the DOE report.

Organization	Yes or No	Question 2 Comment
Project 2007-02 Operating Personnel Comms Protocols SDT	No	<p>The Operating Personnel Communication Protocols standard drafting team respectfully requests that the Sabotage Reporting SAR Drafting Team incorporate the following into your proposed SAR: “Each Reliability Coordinator, Balancing Authority, and Transmission Operator shall have procedures for the communication of information concerning the Cyber and Physical emergency alerts in accordance with the conditions described in “Attachment 1 Security Emergency Alerts.”</p> <p>The Operating Personnel Communications Protocols Project 2007-02 was initiated to ensure that real time system operators use standardized communication protocols during normal and emergency operations to improve situational awareness and shorten response time. The SDT developed a new COM-003-1 Standard that has yet to be posted and is dependent upon revising at least two other standards (CIP-001 and TOP Standard).</p> <p>COM-003 contains requirements that specify:</p> <ol style="list-style-type: none"> <li>1. Use of three-part communication;</li> <li>2. English language;</li> <li>3. Common time zone;</li> <li>4. NATO alpha-numeric alphabet;</li> <li>5. Mutually agreed line identifiers;</li> <li>6. The use of pre-defined system condition terminology such as those contained in the RCWG Alert Level Guide and EOP-002-2.</li> </ol>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>This request is based on recent NERC Standards Committee direction to our team to incorporate the Reliability Coordinator Working Group’s (RCWG) Alert Level Guide into a Standard. The consensus of our team is that a TOP Standard is the most appropriate location for the Transmission Emergency Alert language from the Guide as the energy emergency alert language is currently described in EOP-002-2. The RCWG Guide proposes the use of pre-defined system condition descriptions for use during emergencies for reliability related formation. This guide was developed in response to a Blackout Report recommendation. Our team placed the Transmission Emergency Alert language into a TOP standard.</p> <p>Since the Sabotage Reporting SAR DT intends to modify CIP-001, we seek your consent to incorporate the cyber and physical security alert language to comply with the wishes of the Standards Committee. We believe that the CIP-001 Standard is the most appropriate location for this language for the following reasons:</p> <ul style="list-style-type: none"> <li>• The levels of emergency conditions related to the cyber and physical security of the electric system is directly related to Critical Infrastructure Protection.</li> <li>• The current version of CIP-001 already requires the timely reporting of actual and suspected security emergency conditions and the use of pre-defined terminology supports the efficient handling of such information.</li> </ul> <p>The OPCP SDT includes the following text for the record. It is a proposed draft revision of CIP-001.</p> <p><b>A. Introduction</b></p> <ol style="list-style-type: none"> <li>1. Title: Security Incidents</li> <li>2. Number: CIP-001-2</li> <li>3. Purpose: To ensure the recognition, communication and response to cyber and physical security incidents suspected or determined to be caused by sabotage.</li> <li>4. Applicability             <ol style="list-style-type: none"> <li>4.1. Reliability Coordinators.</li> <li>4.2. Balancing Authorities.</li> <li>4.3. Transmission Operators.</li> <li>4.4. Generator Operators.</li> <li>4.5. Load Serving Entities.</li> </ol> </li> <li>5. Effective Date: The standard is effective the first day of the first calendar quarter after applicable regulatory approvals (or the standard otherwise becomes effective the first day of the first calendar quarter after NERC OT adoption in those jurisdictions where regulatory approval is not required).</li> </ol>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p><b>B. Requirements</b></p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of security threats on its facilities and multi site security threats affecting larger portions of the Interconnection.</p> <p>R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning the physical and cyber security status of their facilities in accordance with the conditions described in Attachment 1-CIP-001-1.</p> <p>R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with security threat or incident response guidelines, including personnel to contact, for reporting security threats and incidents.</p> <p>R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.</p> <p><b>C. Measures</b></p> <p>M1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1</p> <p>M2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.</p> <p>M3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited o procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or CMP officials to communicate sabotage events (Requirement 4).</p> <p><b>D. Compliance</b></p> <p>1. Compliance Monitoring Process</p> <p>1.1. Compliance Enforcement Authority Regional Entity</p> <p>1.2. Compliance Monitoring Period and Reset</p> <p>One or more of the following methods will be used to verify compliance:</p> <p>- Compliance Audits</p>



Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<ul style="list-style-type: none"> <li>- Self-Certifications</li> <li>- Spot Checking</li> <li>- Compliance Violation Investigations</li> <li>- Self-Reporting</li> <li>- Complaints</li> </ul> <p>1.3. Data Retention</p> <p>The Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator and Distribution Provider shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:</p> <ul style="list-style-type: none"> <li>o The Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator and Distribution Provider shall retain its current, in force document and any documents in force since the last compliance audit.</li> <li>o If a Transmission Operator, Transmission Owner, Balancing Authority, Reliability Coordinator, Generator Operator or Distribution Provider is found non-compliant, it shall keep information related to the non-compliance until found compliant.</li> <li>o The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.</li> </ul> <p>1.4. Additional Compliance Information</p> <p>None.</p> <p>2. Levels of Non-Compliance:</p> <p>2.1. Level 1: There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:</p> <ul style="list-style-type: none"> <li>2.1.1 Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).</li> <li>2.1.2 Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).</li> <li>2.1.3 Has not established communications contacts, as specified in R4.</li> </ul> <p>2.2. Level 2: Not applicable.</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>2.3. Level 3: Has not provided its operating personnel with sabotage response procedures or guidelines (R3).</p> <p>2.4. Level 4: Not applicable.</p> <p>E. Regional Differences None.</p> <p>Version History            Version Date Action Change Tracking            0 April 1, 2005 Effective Date New            0 August 8, 2005 Removed "Proposed" from Effective Date            Errata 1 November 1, 2006 Adopted by Board of Trustees            Amended 1 April 4, 2007 Regulatory approval — Effective Date            New 2 March 2009 Added SEA attachment and updates to Effective Date and compliance sections. New</p> <p><b>Attachment 1-CIP-001-2 Physical Security Emergency Alerts</b></p> <p>General requirements</p> <p>1. Initiation by Reliability Coordinator.</p> <p>A Physical Security Emergency Alert may be initiated only by a Reliability Coordinator at:</p> <ul style="list-style-type: none"> <li>a. The Reliability Coordinator's own decision,</li> <li>b. By request from a Transmission Operator,</li> <li>c. By request from a Balancing Authority, or</li> <li>d. By request from federal, state, or cal Law Enforcement Officials.</li> </ul> <p>2. Situations for initiating alert.</p> <p>An Alert may be initiated for the following reasons:</p> <ul style="list-style-type: none"> <li>a. A physical threat affecting a control center, grid or generator asset has been identified, or</li> <li>b. A physical attack affecting a control center, grid or generator asset has occurred or is imminent.</li> </ul> <p>3. Notification.</p> <p>A Reliability Coordinator who initiates a Physical Security Emergency Alert shall notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify other Reliability Coordinators of the situation via the Reliability Coordinator Information System (RCIS) using the "CIP" category. Additionally, conference calls between Reliability Coordinators shall be held as necessary to communicate system conditions.</p> <p>The Reliability Coordinator shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area and other Reliability Coordinators when the alert has changed levels or ended.</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>Physical Security Emergency Alert Levels</p> <p>To ensure that all Reliability Coordinators clearly understand potential and actual Physical Security Emergency Alerts, NERC as established three levels of Security Emergency Alerts. The Reliability Coordinators will use these terms when explaining security alerts to each other. The Reliability Coordinator may declare whatever alert level is necessary, and need not proceed through the alerts sequentially.</p> <p>1. Alert 1 – “Control Center / Bulk Electric system asset threat identified” Circumstances: A credible threat of physical attack on a Bulk Electric System asset has been communicated to the Reliability Coordinator. No physical attack has occurred at this point. Determining the credibility of any threat is a subjective process, but the following factors should be considered:</p> <ul style="list-style-type: none"> <li>a. The nature and specificity of the threat,</li> <li>b. The timing of the threat,</li> <li>c. Mode of threat communication, and</li> <li>d. The criticality of the threatened asset. During a Physical Security Emergency Alert Level 1, Reliability Coordinators, Transmission Operators and Balancing Authorities shall have the following responsibilities: <ul style="list-style-type: none"> <li>i. Notification: The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area.</li> <li>ii. Updating Status during the Physical Security Emergency Alert The declaring Entity shall update the reliability Coordinator of any changes in the situation until the Alert Level 1 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> </li> </ul> <p>2. Alert 2 – “Verified Physical attack at a single site” circumstances: A Reliability Coordinator, Transmission Operator, or Balancing Authority has identified a physical attack upon a control center, generator asset, or other bulk electric system asset. During a Physical Security Emergency Alert Level 2, Reliability Coordinators, Transmission Operators and Balancing Authorities shall have the following responsibilities:</p> <ul style="list-style-type: none"> <li>i. Notification: The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area.</li> <li>ii. Updating Status during the Physical Security Emergency Alert The Declaring Entity shall update the Reliability Coordinator of the situation a minimum of once per hour until the Alert Level 2 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> <p>3. Alert 3– “Verified Physical attack at multiple sites” Circumstances: Multiple attacks have been confirmed on control centers, generator assets or other bulk electric system assets. A Reliability Coordinator shall declare Physical Security</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>Emergency Alert 3 whenever:</p> <ul style="list-style-type: none"> <li>a. A Transmission Operator or Balancing Authority reports multiple physical attacks on bulk electric system assets,</li> <li>b. Multiple Transmission Operators or Balancing authorities report one or more physical attacks on their bulk electric system assets.</li> <li>i. Notification: The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area.</li> <li>ii. Updating Status during the Physical Security Emergency Alert The declaring Entity(ies) shall update the Reliability Coordinator of the situation a minimum of once per hour until the Alert Level 3 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> <p>4. Alert 0 – “Termination of Alert Level” Circumstances: The threat which prompted the Physical Security Emergency Alert Level has diminished or has been removed.</p> <ul style="list-style-type: none"> <li>i. Notification The Reliability Coordinator responsible for initiating the Physical Security Emergency Alert shall notify all other Reliability Coordinators via the RCIS, and it shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area that the Alert Level has been terminated.</li> </ul> <p>Cyber Security Emergency Alerts Cyber Assets – Those programmable electronic devices and communication networks, including hardware, software, and data, associated with bulk electric system assets.</p> <p>Cyber Security Incident - Any malicious act or suspicious event that compromises, or attempts to compromise, the electronic or physical security perimeter of a critical cyber asset or disrupts or attempts to disrupt the operation of a critical cyber asset.</p> <p>Critical Cyber Asset – Those cyber assets essential to the reliable operation of critical assets.</p> <p>Electronic Security Perimeter – The logical border surrounding the network or group of sub-networks to which the critical cyber assets are connected, and for which access is controlled.</p> <p>Physical Security Perimeter – The physical border surrounding computer rooms, telecommunications rooms, operations centers and other locations in which critical cyber assets are housed and for which access is controlled.</p> <p>General Requirements</p> <p>1. Initiation - A Cyber Security Emergency Alert shall be initiated by:</p> <ul style="list-style-type: none"> <li>a. The Reliability Coordinator’s analysis,</li> <li>b. By request from any NERC functional Model entity that Com-003-0 is applicable to.</li> </ul>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>c. By request from federal, state, or local Law Enforcement Officials.</p> <p>2. Situations for initiating alert. An Alert shall be initiated for the following reasons:</p> <p>a. A cyber threat affecting a control center or bulk electric system asset has been identified, or</p> <p>b. A cyber attack affecting a control center or bulk electric system has occurred or is imminent.</p> <p>3. Notification.</p> <p>An entity who initiates a Cyber Security Emergency Alert shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator shall notify FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security. The Reliability Coordinator shall also notify as necessary other Reliability Coordinators of the situation via the Reliability Coordinator Information System (RCIS) using the “CIP” category. The Reliability Coordinator shall notify all Transmission Operators and Balancing Authorities in its Reliability Area and other Reliability Coordinators when the alert has changed levels or ended.</p> <p>Cyber Security Emergency Alert Levels</p> <p>To ensure that all applicable entities clearly understand potential and actual Cyber Security Emergency Alerts, three levels of Security Emergency Alerts shall be used.</p> <p>The Reliability Coordinators will use these terms when communicating security alerts to each other. When declaring the applicable alert level it is important to note that the applicable level can be determined without sequentially proceeding through levels.</p> <p>As an example given circumstances an Alert Level 3 could be called without previously being in an Alert Level 1 or Level 2 state.</p> <p>1. Alert 1 – “Verified Control Center / Bulk Electric System Cyber Asset threat identified or imminent” What is “verified” - unknown or unauthorized access to a cyber device, unknown or unauthorized change to a cyber device (i.e., config file, I/S, firmware change. ‘Verified’ could mean the elimination of a false positive in your security monitoring system. ‘Verified’ could also be the differentiation between malicious and non-malicious (ie human error, not following policy, etc) intent. What is a “threat” - A threat can be perceived as any action or event that occurs where the monitoring authority was not previously made aware that that action would occur. With flimsy change control or access controls, field staff or technical staff performing troubleshooting or other maintenance may access or change devices without notifying the monitoring entity. The monitoring entity would have to treat this as a threat and take appropriate action to either isolate that device from the rest of the system, notify appropriate authority, dispatch a crew, etc.</p> <p>Examples of threats - Over and above the examples above, another threat example could be a notification from DHS or other security agency that they have reason to believe a hack, virus or other cyber terrorism activity could occur. Also, noticing a distinct change in network traffic which could imply someone has intercepted your data and can manipulate</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>before sending it from the control room to the device being controlled or manipulating the data coming from the device before a controller seeing it and forcing them to perform an incorrect control event in reaction to erroneous data.</p> <p>Circumstances: A credible threat of Cyber attack on a Control Center or Bulk Electric System asset has been communicated to the Reliability Coordinator. No cyber attack has occurred t this point. Determining the credibility of any threat is a subjective process, but the following factors should be considered:</p> <ul style="list-style-type: none"> <li>a. The nature and specificity of the threat,</li> <li>b. The timing of the threat,</li> <li>c. Mode of threat communication, and</li> <li>d. The criticality of the threatened asset. During a Cyber Security Emergency Alert Level 1, applicable entities shall have the following responsibilities: <ul style="list-style-type: none"> <li>i. Notification An entity who initiates a Cyber Security Emergency Alert Level 1 shall make notification as per the NERC Functional model r as Regional / local instruction. The Reliability Coordinator shall post the declaration of the alert level long with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify as necessary the BI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security.</li> <li>ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity shall update those applicable entities of any changes in the situation until the Alert Level 1 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul> </li> </ul> <p>2. Alert 2 – “Verified Cyber attack on a Control Center or Bulk Electric System asset”</p> <p>Circumstances: An applicable entity has identified a cyber attack upon a control center or bulk electric system asset. During a Cyber Security Emergency Alert Level 2, applicable entities shall have the following responsibilities:</p> <ul style="list-style-type: none"> <li>i. Notification An entity who initiates a Cyber Security Emergency Alert Level 2 shall make notification as per the NERC Functional model or as Regional / cal instruction. The Reliability Coordinator responsible shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities in its Reliability Area. The Reliability Coordinator shall also notify the FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security.</li> <li>ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity shall provide updates of the situation a minimum of once per hour until the Alert Level 2 is terminated. The Reliability Coordinator shall update the RCIS as changes occur.</li> </ul>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
		<p>3. Alert 3 – “Verified Cyber attack at one or more Control Center or Bulk Electric System cyber asset”</p> <p>Circumstances: An applicable entity has identified a cyber attack upon a control center or bulk electric system asset and shall declare a Cyber Security Emergency Alert 3 whenever:</p> <ul style="list-style-type: none"> <li>a. A Transmission Operator or Balancing Authority reports one or more cyber attacks on bulk electric system that render an asset(s) unavailable.</li> <li>i. Notification An entity who initiates a Cyber Security Emergency Alert Level 3 shall make notification as per the NERC Functional model or as Regional / local instruction. The Reliability Coordinator shall post the declaration of the alert level along with the location of the affected facility on the RCIS under “CIP” and notify all Transmission Operators and Balancing Authorities its Reliability Area. The Reliability Coordinator shall also notify the FBI local office, Electricity Sector Information Sharing Analysis Center (ESISAC) and Department of Homeland Security.</li> <li>ii. Updating Status during the Cyber Security Emergency Alert The declaring Entity(ies) shall provide an update of the situation minimum of once per hour until the Alert Level 3 is terminated. The Reliability Coordinator shall update he RCIS as changes occur.</li> </ul> <p>4. Alert 0 – “Termination of Alert Level” Circumstances: The threat which prompted the Cyber Security Emergency Alert Level has diminished or has been removed. i. Notification An entity who initiates a Cyber Security Emergency Alert shall make notification as per the NERC Functional model or as Regional / local instruction when situation has diminished or returned to normal. The Reliability Coordinator shall notify all other Reliability Coordinators via the RCIS, and it shall also notify all Transmission Operators and Balancing Authorities in its Reliability Area that the Alert Level has been terminated.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The standards in this Project 2009-01 SAR are designed to specify reporting requirements for disturbance and sabotage events. The DSR SAR DT believes that the suggested additions go beyond the intended scope of the revisions to the standards, and do not feel that communications protocols belong in these reporting standards. The proposed revisions and Alert Levels are real-time requirements, and the team feels that these would be more appropriately addressed in an IRO or COM standard.</b></p>		
<p>Northeast Power Coordinating Council</p>	<p>No</p>	<p>The SAR needs to be more specific in defining its objectives.</p> <p>CIP-001Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <p>1. Develop clear definitions for the terms “operating personnel” and “sabotage events.” The definition of “operating personnel,” should be clarified and limited to staff at BES facilities. Operating personnel should report only those events</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
		<p>which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term “sabotage event” needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</p> <p>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such “sabotage events,” e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term “aware” in the standard. “Aware” can be interpreted in accordance with its largely passive, dictionary-based meaning, where being “aware” simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of “aware” could refer to more active wording, involving more than mere awareness, e.g., “alert and quick to respond,” pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</p> <p>EOP-004 - The SDT needs to work on the following areas.</p> <p>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states: Introduction “The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance - The sense of Attachment 1 is internally inconsistent between the introduction (“occurs”) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase “or could have resulted in” a potential system disturbance. This inconsistency should be clarified.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>CIP-001: The inclusion of specific definitions in the SAR as you suggest (operating personnel, sabotage events, obligations) are too prescriptive and could prevent better definitions from being developed during the Standards Development stage of the project. The team will pass your comments along to the standard drafting team for its consideration.</b></p> <p><b>EOP-004: Your comment addresses specific revisions to the standard. The team will pass your comments along to the standard drafting team for its consideration.</b></p>		
Kansas City Power & Light	No	Agree with the scope of the SAR except for the applicable entities. See response to question #4.
<p><b>Response: The DSR SAR DT thanks you for your comment. Please see response to Q4.</b></p>		



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
MRO NERC Standards Review Subcommittee	No	The MRO NSRS would like to keep the references to the DOE reporting form.
<p><b>Response: The DSR SAR DT thanks you for your comment. The DSR SAR DT understands your comment to indicate that you would like to see a “one stop” reporting form for disturbances and sabotage events. The DSR SAR DT agrees with you and will pass this comment along to the standard drafting team for its consideration in developing the standard(s).</b></p>		
Lands Energy Consulting	No	I would like to see the SAR expanded to cover the issues I mentioned in my prior comment. Otherwise, the scope of the SAR looks fine to me.
<p><b>Response: The DSR SAR DT thanks you for your comment. Please see response to Q1 on other issues.</b></p>		
Bonneville Power Administration	No	Leave as is, all requirements for reporting are now covered. A common definition of sabotage is already widely available.
<p><b>Response: The DSR SAR DT thanks you for your comment. Most stakeholders desire more clarity around the definition of sabotage as well as examples of what is and is not sabotage as opposed to vandalism.</b></p>		
Cowlitz County PUD	No	<p>Added to the scope:</p> <p>For EOP-004 add a provision for a reporting flow rather than everything going to the RE and NERC. That is something going like the DP and TOP reports to the BA, the BA to the RE, and the RE to NERC. This would allow for multiple related reports to be combined into a single coherent report as the reporting goes up the chain.</p> <p>For CIP-001 consider reporting flow as above with local law enforcement notification. Let an upper entity in the reporting chain decide when to contact Federal Agencies such as the BA or the RC.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The DSR SAR DT feels that your comments are “how” comments that should be addressed in standard drafting stage. The team will pass this comment along to the standard drafting team for its consideration.</b></p>		
Reliant Energy	No	I think Generator operators should be excluded except to provide requested information from the System Operator or Reliability coordinator.
<p><b>Response: The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
<b>determine the applicability to GOPs. The team will pass your comment on to the Standard Drafting Team for its consideration.</b>		
ERCOT ISO	No	The scope should be modified to provide for a different treatment of reporting requirements that are administrative in nature, or that are after-the-fact (thus cannot impact reliability unless analysis and follow-up is not performed; even then, the impact would be at some future time). Reporting requirements which are of the nature to assist in identification of system concerns or which serve to prevent or mitigate on-going system problems (including, but not limited to, actual or attempted sabotage activity) should remain in standards, but should be separate and apart from the administrative reporting.
<b>Response: The DSR SAR DT thanks you for your comment. The team concurs with the concepts on reporting as you suggest, however the team does not feel that this should be addressed in the SAR. The team suggests that this is more appropriately addressed in the standard drafting process, and the team will pass your comment along to the standard drafting team for its consideration in drafting the standard.</b>		
MidAmerican Energy	No	See the responses to questions 1 and 5.
<b>Response: The DSR SAR DT thanks you for your comment. Please see responses to Q1 and Q5.</b>		
We Energies	No	Consider including the sabotage issues in IRO-014-1 R 1.1.1 footnote 1 and TOP-005-1 Attachment 1, 2.9.
<b>Response: The DSR SAR DT thanks you for your comment. The team has added references to these two standards in the “Related Standards” section for the SAR.</b>		
NextEra Energy Resources, LLC	No	The scope of the SAR should not include Generator Operators.
<b>Response: The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will determine the applicability to GOPs. The team will pass your comment on to the Standards Drafting Team for its consideration.</b>		
Progress Energy	No	No. If this SAR moves forward other standards may need to be considered. For example, in CIP-008, incident reporting for cyber incidents leads to filing of the OE-417 form.
<b>Response: The DSR SAR DT thanks you for your comment. The SAR states “Specific references to the DOE form need to be eliminated.” This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states:</b>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
<p>Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</p> <p><b>This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>		
Ameren	No	<p>There seems to be an open slate including the following language in the scope. The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information). The unnamed improvements should be limited to those requirements that relate only to Disturbance and Sabotage NOT a general wish list (or witch hunt).</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The passage that you mention is the intent of each SAR and is a stock statement that is included in almost every SAR. The SAR is limited to the standards listed in the SAR which is approved by the NERC SC to move to standards development.</b></p>		
Consolidated Edison Co. of New York, Inc.	No	<p>GENERAL CECONY and ORU support the general objectives of the SAR to merge existing standards CIP-001-1 Sabotage Reporting and EOP-004-1 Disturbance Reporting to improve clarity and remove redundancy.</p> <p>However, the SAR needs to be more specific in defining its objectives.</p> <p>CIP-001Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <ol style="list-style-type: none"> <li>1. Develop clear definitions for the terms operating personnel and sabotage events. The definition of operating personnel, should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term sabotage event needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</li> <li>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such sabotage events, e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term aware in the standard. Aware can be interpreted in accordance with its largely passive, dictionary-</li> </ol>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 2 Comment
		<p>based meaning, where being aware simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of aware could refer to more active wording, involving more than mere awareness, e.g., alert and quick to respond, pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</p> <p>EOP-004 - The SDT needs to work on the following areas.</p> <p>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states:</p> <p>Introduction The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: ?c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance.</p> <p>The sense of Attachment 1 is internally inconsistent between the introduction (occurs) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase or could have resulted in a potential system disturbance. This inconsistency should be clarified.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>CIP-001: The inclusion of specific definitions in the SAR as you suggest (operating personnel, sabotage events, obligations) are too prescriptive and could prevent better definitions from being developed during the standard drafting stage of the project. The team will pass your comments along to the standard drafting team for its consideration.</b></p> <p><b>EOP-004: Your comment addresses specific revisions to the standard. The team will pass your comments along to the standard drafting team for its consideration.</b></p>		
Georgia System Operations Corp.	No	<p>The scope of the SAR should be to move all requirements to report to NERC or Regional Entities out of the Requirements section of all Reliability Standards to elsewhere. This does not include reporting, communicating, or coordinating between reliability entities. The NERC/Region reporting requirements could be consolidated in another document and referenced in the Supporting References section of the Reliability Standards. The deadlines for reporting should be changed to realistic timeframes that do not interfere with operating the BES or responding to incidents yet still allow NERC and the Regions to accomplish their missions.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team does not feel that this should be addressed explicitly in the SAR, but suggests that this is more appropriately addressed in the standard drafting stage for full industry vetting of the concepts. The team will pass your comment along to the standard drafting team for its consideration in developing the standard.</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
AEP	No	Sabotage is a term of intent that is often determined after the fact by the registered entity and/or law enforcement officials. In fact, it is often difficult to determine in real-time the intent of a suspicious event. We would suggest that suspicious events become reportable at the point that the event is determined to have had sabotage intent. The entities should have a methodology to collect evidence, to have the evidence analyzed, and to report those events that are determined to have had the intent of sabotage.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs that it is difficult to determine sabotage in real-time. The team does not feel that this should be addressed explicitly in the SAR and suggests that this is more appropriately addressed in the standard drafting stage for full industry vetting of the concepts. The team will pass your comment along to the standard drafting team for its consideration in developing the standard.</b></p>		
Duke Energy	No	While we agree with the need for clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities. Also, requirements to report possible non-compliances should be eliminated. We strongly support voluntary self-reporting, but not mandatory self-reporting.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs that each requirement should be evaluated for its reliability need, and the team will pass your comment along to the standard drafting team for its consideration in the drafting stage of the standard.</b></p>		
FirstEnergy	Yes	<p>We agree with the scope but would also like to see the following considered:</p> <ol style="list-style-type: none"> <li>1. References to the DOE reporting process in EOP-004 need to be revised. They currently refer to the old EIA form.</li> <li>2. Besides "sabotage", it may be helpful to clearly define "vandalism". It is vaguely written in the standards. Also, the process of "public appeals" for the DOE reportable requirements needs to be more clearly defined.</li> <li>3. Consolidate documents covering reporting requirements. There are currently several documents that require reporting (EOP-004, CIP-001, DOE oe-417, and NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting). NERC also has the "Bulk Power System Disturbance Classification Scale" that does not completely align with all the reporting requirements. Therefore we recommend keeping this as simple as possible by combining all the reporting requirements into one standard. It would be beneficial to not require operators to have to go to 4 different documents to determine what to report on.</li> </ol>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
<p><b>The Brief Description of the SAR states:</b> Specific references to the DOE form need to be eliminated.</p> <p><b>The team will pass your comment along to the standard drafting team for its consideration.</b></p> <p><b>The team concurs that this should be considered in drafting the standards. The team will pass your comment along to the standard drafting team for its consideration.</b></p>		
Exelon	Yes	Consolidation of redundant requirements and clarifications of difficult to follow / interpret standards should be a high priority at NERC.
<p><b>Response: The DSR SAR DT thanks you for your comment. One of the FERC directives for CIP-001 is: Explore ways to reduce redundant reporting, including central coordination of sabotage reports and a uniform reporting format.</b></p>		
Electric Market Policy	Yes	
SERC OC Standards Review Group	Yes	
PSEG Enterprise Group Inc Companies	Yes	
IRC Standards Review Committee	Yes	
Pepco Holdings, Inc. - Affiliates	Yes	
Calpine Corporation	Yes	
Covanta	Yes	
Colmac Clarion	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 2 Comment
United Illuminating	Yes	
Texas Regional Entity	Yes	
Edward C. Stein	Yes	
WECC	Yes	
Luminant Power	Yes	
ReliabilityFirst Corporation	Yes	
Brazos Electric Power Cooperative, Inc.	Yes	
PacifiCorp	Yes	
Oncor Electric Delivery	Yes	
Illinois Municipal Electric Agency	Yes	
Manitoba Hydro	Yes	
Consumers Energy Company	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**3. Are you aware of any associated business practices that we should consider with this SAR? If yes, please explain in the comment area.**

**Summary Consideration:** Stakeholders did not identify any associated business practices for consideration under the SAR. One stakeholder identified a related standard that references multi-site sabotage. The team has included a reference to TOP-005, section 2.9 (Appendix 1) in the SAR under Related Standards. Two stakeholders suggested that Business Practices should not be considered in a standard. The SAR DT notes that standard development projects must not invalidate business practices that are already in place. This question is required to be asked per the Standard Drafting Team Guidelines (page 8) and aids in coordination with North American Energy Standards Board. One stakeholder suggested a “one-stop-shopping” solution. The SAR DT agrees with this approach and will forward this comment to the Standard Drafting Team.

Organization	Yes or No	Question 3 Comment
MRO NERC Standards Review Subcommittee	Yes	
Luminant Power	Yes	The SAR drafting team should include in the SAR scope a review of the NRC sabotage and event reporting requirements to ensure there are no overlapping or conflicting requirements between NERC, FERC, and the NRC. The SAR scope should include a review of the CIP Cyber Security Standards and coordination with the CIP SDT to ensure that cyber sabotage reporting definitions are in concert, and ensure that cyber sabotage reporting requirements are not duplicated in multiple standards.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team notes that your comments relate directly to potential revisions of the standard itself. Part of this SAR is to eliminate redundancies as well. The team will pass your comments along to the Standards Drafting Team for its consideration. This project is designed to address physical asset reporting, not cyber assets. Therefore, cyber assets will not be included in this SAR.</p>		
MidAmerican Energy	Yes	Attachment TOP-005, section 2.9 speaks of “Multi-site sabotage” with no definition. The ES-ISAC 2008 advisory is an associated standard or practice on sabotage. All references to sabotage should be eliminated or retired except for CIP-001.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team has included a reference to TOP-005, section 2.9 (Appendix 1) in the SAR under Related Standards. Project 2009-01 is designed to address physical asset reporting, not cyber asset sabotage and disturbance reporting. The standard drafting team will remove redundancies per the SAR.</p>		



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 3 Comment
Illinois Municipal Electric Agency	Yes	A one-stop reporting tool/site would facilitate efficient reporting and compliance; e.g., further development of the ES-ISAC/CIPIS to include all reportable categories and automatic notification of required parties. A single report form would be best.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees with your suggestion and will pass this along to the Standard Drafting Team for its consideration in developing standards.</b></p>		
AEP	Yes	The current reporting process necessitates multiple reports be sent to multiple parties, which is inefficient and may, inadvertently, result in alignment issues between the separate reports. We would recommend that a single report that combines NERC (CIPIS) and NERC ESISAC information be provided to NERC (CIPIS) that is systematically (programmatically) forwarded to all necessary entities. Further, updates to incidents would also go through NERC with the same electronic processing. Currently, we are not aware of a formal method to report incidents to the FBI, which should be also included in the distribution. The current reporting mechanism to the FBI JTTF is by telephone and the NERC platform described would provide more consistent reporting.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees with your suggestion and will pass this along to the Standard Drafting Team for its consideration in developing standards. This project is designed to address physical asset reporting, not cyber assets.</b></p>		
Progress Energy	Yes	Yes. If this SAR moves forward other practices such as those required by CIP-008 (cyber incident reporting via the OE-417 form) may need to be considered.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states “Specific references to the DOE form need to be eliminated.” This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states: Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality. This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that the general layout and sequencing of requirements in CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>		
Exelon	No	We are not sure what this question means. Who's Associated Business practices, NERC, Applicable Entities in the Standard, our business practices?
<p><b>Response: The DSR SAR DT thanks you for your comment. “Business practices” refers to any business practice of any stakeholder (e.g. North American Energy Standards Board business practices).</b></p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 3 Comment
SERC OC Standards Review Group	No	Business practices should not be considered in a standard.
<p><b>Response: The DSR SAR DT thanks you for your comment. Standard development projects must not invalidate business practices that are already in place. This question is required to be asked per the Standard Drafting Team Guidelines (page 8) and aids in coordination with North American Energy Standards Board.</b></p>		
FirstEnergy	No	Although we are not aware of any NAESB business practices that need to be reviewed in conjunction with these proposed revisions, the SDT should consider reviewing current RTO procedures and practices that may require the need for variances in the revised standards.
<p><b>Response: The DSR SAR DT thanks you for your comment. The Standard Drafting Team will review any procedures or practices that are identified for potential variances.</b></p>		
Georgia System Operations Corp.	No	Business practices should not be part of a Reliability Standard. Neither should NERC/Region reporting requirements (except for reporting of threats to physical or cyber security). NERC may need to take some action in the case of threats but does not and cannot take any operational action for most of the reporting requirements that are presently in the Requirements section of the Reliability Standards.
<p><b>Response: The DSR SAR DT thanks you for your comment. Standard development projects must not invalidate business practices that are already in place. This question is required to be asked per the Standard Drafting Team Guidelines (page 8) and aids in coordination with North American Energy Standards Board. The team disagrees with your assertion about reporting. Instances of sabotage are often not identified until after the fact, and these should be reported to alert other entities of the sabotage and for “lessons learned”.</b></p>		
PSEG Enterprise Group Inc Companies	No	
Northeast Power Coordinating Council	No	
Kansas City Power & Light	No	
IRC Standards Review Committee	No	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 3 Comment
Pepco Holdings, Inc. - Affiliates	No	
Electric Market Policy	No	
Bonneville Power Administration	No	
Lands Energy Consulting	No	
Covanta	No	
Colmac Clarion	No	
Cowlitz County PUD	No	
United Illuminating	No	
Reliant Energy	No	
Texas Regional Entity	No	
Edward C. Stein	No	
PacifiCorp	No	
WECC	No	
ERCOT ISO	No	
ReliabilityFirst Corporation	No	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

---

Organization	Yes or No	Question 3 Comment
Brazos Electric Power Cooperative, Inc.	No	
Oncor Electric Delivery	No	
Consolidated Edison Co. of New York, Inc.	No	
Manitoba Hydro	No	
Duke Energy	No	
We Energies	No	
Consumers Energy Company	No	
NextEra Energy Resources, LLC	No	
Ameren	No	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**4. CIP-001-1 applies to the Reliability Coordinator, Transmission Operator, Balancing Authority, Generator Operator, and the Load-serving Entity. EOP-004-1 applies to the same entities, plus the Regional Reliability Organization. Do you agree with the applicability of the existing CIP-001-1 and the existing EOP-004-1? If no, please identify what you believe should be modified.**

**Summary Consideration: Many stakeholders had comments regarding applicability of the two standards. The three main concerns were:**

- 1 Regional Reliability Organization applicability: Many commenters do not feel the RRO should be in the standards. The DSR SAR DT concurs and notes that the SAR states that “EOP-004 has some ‘fill-in-the-blank’ components to eliminate”. This will remove the RRO from applicability.
- 2 Load-Serving Entity/Distribution Provider: Many stakeholders do not feel that the standards should be applicable to LSEs, but should apply to Distribution Providers. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.
- 3 Transmission Owner/Generator Owner: Many stakeholders have indicated a need to include the TO as an applicable entity. A couple of those would also include the GO. The SAR DT discussed the addition of both the TO and GO. The team has a concern that there will be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the Standard Development Process.

Organization	Yes or No	Question 4 Comment
SERC OC Standards Review Group	No	The EOP-004-1 standard should not apply to the RRO.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
Kansas City Power &	No	Do not agree Load Serving Entities need to continue to be included for sabotage. According the NERC Functional Model,

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
Light		an LSE provides for estimating customer load and provides for the acquisition of transmission and energy to meet customer load demand. An LSE has no real impact on maintaining the reliability of electric network short of their planning function. Unfortunately, an LSE needs to be included for disturbance reporting to the DOE under certain conditions for loss of customer load. This may be a reason to maintain a separation of CIP-001 and EOP-004 so as not to unnecessarily include an LSE when it is not needed.
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration.</b></p>		
IRC Standards Review Committee	No	We agree with the applicability of CIP-001-1 but question the need to include the RRO in EOP-004-1. Requirement R1 of EOP-004-1 can be turned into an industry developed and approved procedural requirement with details included in an appendix; whereas R5 can be changed to a requirement for the responsible entities to act on recommendations and to self-report compliance. Tracking and reviewing status of recommendation do not need to be performed by the RRO, or any entity for that matter, if a self-reporting mechanism is developed.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
Pepco Holdings, Inc. - Affiliates	No	As specified in Order 693, Regional Reliability Organizations are not to be assigned applicability. The revised standard(s) should contain the reporting form either directly or by reference and the RRO should be removed. The other EOP-004 requirements for RROs are now considered normal monitoring activities of the Regional Entities.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
FirstEnergy	No	The Regional Reliability Organization should be removed from the applicability of EOP-004-1. Any report they receive would be from the other entities listed. For consistency, the entities should report to the appropriate law enforcement agency. A report to the Reliability Entity should also be made for that entities information only.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some ‘fill-in-the-blank’ components to eliminate. This will remove the RRO from applicability.</b></p>		
Electric Market Policy	No	Applicability should not apply to LSE unless they have physical assets. If they do not have such assets, they are unable to

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
		<p>determine how many customers are out, how much load was lost or the duration of an outage. We continue to question the need for the LSE entity in reliability standards. End use customer load is either connected to transmission or distribution facilities. So, the applicable planner has to plan for that load when designing its facilities or the load will not have reliable service. To the extent that energy and capacity for that load is supplied by an entity other than the TO or DP, the TO or DP should have interconnection requirements that compel the supplier to provide any and all data necessary to meet the requirements of reliability standards.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration.</b></p>		
MRO NERC Standards Review Subcommittee	No	As FERC has directed, the RRO should be removed since they are not owners or operators of the BES.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some 'fill-in-the-blank' components to eliminate. This will remove the RRO from applicability.</b></p>		
Lands Energy Consulting	No	<p>CIP-001-1 - Yes. In many cases, the staff of an LSE embedded in another entity's BA/TOP area is more likely to discover an act of sabotage directed toward a BA/TOP-owned facility that could affect the BES than the asset owner. This is because the LSE likely has more operating staff in the area. I have included a requirement in my clients' Sabotage Identification and Reporting Procedures that the client treat acts of sabotage to a third party's system discovered by client employees as though the act was directed toward client facilities. EOP-004-1 - As mentioned before, I would eliminate the LSE from the applicability list and leave the responsibility for disturbance reporting and response to the TOP/BA. However, I would retain a responsibility for the LSEs to cooperate (when requested) with any disturbance investigation.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the standard as the Standard Drafting team may have a need to include them in the standard(s). The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration.</b></p>		
Calpine Corporation	No	The reporting requirements of EOP - 004 are needed for the RC, BA, LSE and the GOP that operates or controls generation in a system as defined by NERC. (System - A combination of generation, transmission, and distribution components). A disturbance is described as an unplanned event that produces and abnormal system condition, any

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
		<p>perturbation to the electric system, and the unexpected change in ACE that is caused by the sudden failure of generation or interruption of load. The GOP operating/controlling generation within a system has the ability to analyze system conditions to determine if reporting is necessary. A NERC registered GOP that is a merchant generator within another company's system does not have the ability for a wide area view and cannot analyze system conditions beyond the interconnection point of the facility. Moreover, in most cases the reporting requirements outlined in the Interconnection Reliability Operating Limits and Preliminary Disturbance Report do not apply to the merchant generator that is not a generation only BA. The applicability of the standard does encompass the true merchant generation entities required to register as GOP. Similarly, the OE-417 table 1 reporting requirements generally do not apply to a true merchant generating entity that is required to register as a GOP.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees that generators may not have a wide area view and the capability to analyze events. The final wording of the requirements developed by the Standard Drafting Team will determine the applicability. The team will pass your comment on to the Standards Drafting Team for its consideration. The SAR calls for the removal of references to the DOE form OE-417.</b></p>		
Cowlitz County PUD	No	Replace LSE with DP, and the Regional Reliability Organization with the Regional Entity.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team has added DP to the applicability of the SAR. The SAR calls for removing the fill-in-the-blank standard elements which will remove the RRO.</b></p>		
United Illuminating	No	Add Distribution Provider
<p><b>Response: The DSR SAR DT thanks you for your comment. The team has added DP to the applicability of the SAR.</b></p>		
Reliant Energy	No	EOOP-004-1 should exclude the generator operator from disturbance reporting except providing the system operator or reliability coordinator with appropriate unit operation information upon request. Acts of sabotage should be identified clearly and reported to the indicated authorities.
<p><b>Response: The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will determine the applicability to GOPs. The team will pass your comment on to the Standards Drafting Team for its consideration.</b></p>		
Texas Regional Entity	No	Add GO and TO to the list of applicability. The intent of CIP-001-1 when it was first written was to have the proper and most likely entities associated directly with operations to be the ones to begin the reporting process in the case of sabotage on the system. In the ERCOT Region and other regions in the US, the GOP may not be physically located at the site. The GOP is often removed from the minute-by-minute responsibilities of plant operations and, therefore, may be less



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
		<p>able to react to physical sabotage at the location/plant/facility in a timely manner. The concern is that, in the case of an actual sabotage event, the failure to report to the appropriate authorities in a timely manner may jeopardize the reliability of the BPS. Therefore, the Generator Owner (GO) should be added to the list of applicability for CIP-001-1, because it is the GO that is more likely to be on location at the generation site and thus aware of sabotage when it first occurs. This would disallow for any possible communication gap and put responsibility on all of the appropriate entities to report such an event. Additionally, and for the same reasons as adding the GO, the Transmission Owner (TO) should also be added to the list of applicability for reporting sabotage on its facilities.</p>
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The SAR DT discussed the addition of the TO and GO. The team was concerned that there may be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting Process. The team will pass your comment along to the Standard Drafting Team for its consideration concerning applicability.</p>		
NextEra Energy Resources, LLC	No	The scope of the proposed SAR should not include the Generator Operator.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. Other commenters have questioned the ability of Generator Operators to have a wide area view and to be able to analyze disturbances on the system. The team agrees that generators may not have a wide area view and the capability to analyze system events. The final wording of the requirements (i.e. reporting vs. data provision) developed by the Standard Drafting Team will determine the applicability to GOPs. The team will pass your comment on to the Standards Drafting Team for its consideration.</p>		
Exelon	No	CIP-001, remove LSE's from the standard for the reasons identified in the FERC LSE order. Ad TO and DP. EOP-004, remove LSE's from the standard for the reasons identified in the FERC LSE order. Remove RRO's, they are not a user, owner, operator of the BES. Add DP or TO. Consider conditional applicability as in the UFLS standards, " the TO or DP who performs the functions specified in the standard..."
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The SAR DT discussed the addition of the TO. The team is concerned that there may be duplication of requirements between the TO/TOP if the TO is added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting Process. The SAR calls for elimination of fill in the blanks elements, which will remove the RRO from the standard. The team will pass your comment along to the Standard Drafting Team for its consideration concerning conditional applicability.</p>		

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
ERCOT ISO	No	The Regional Reliability Organization is not a registered Functional Entity in the NERC registry. The applicability must be revised to more appropriately assign the requirements to registered functional entities. Also, the industry needs to recognize that there are other resources than generation for which the operators need to be included. Perhaps a demand-side resource should have a resource operator. This particular SAR may not be the appropriate venue for this, but control of resources which can be used to mitigate sabotage events or disturbance events may need to be addressed.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR calls for elimination of fill-in-the-blank elements, which will remove the RRO from the standard. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The team will pass your comment along to the Standard Drafting Team for its consideration concerning conditional applicability. This SAR is for reporting rather than control actions as you mention.</b></p>		
Brazos Electric Power Cooperative, Inc.	No	May need to consider adding Transmission Owner. I don't see a need for the RRO to be included as they are not owner/operators of grid facilities.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR DT discussed the addition of the TO. The team is concerned that there may be duplication of requirements between the TO/TOP if the TO is added to the SAR. That being said, the TO has been added to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The SAR calls for elimination of fill in the blank elements, which will remove the RRO from the standard. The team will pass your comment along to the Standard Drafting Team for its consideration concerning conditional applicability.</b></p>		
PacifiCorp	No	LSE's don't generally own/operate facilities/systems that would experience a logical or physical sabotage event.
<p><b>Response: The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process.</b></p>		
MidAmerican Energy	No	MidAmerican Energy believes the requirement for the Regional Reliability Organization should be removed from EOP-004-1 since the RRO is a holdover from making the standards enforceable. It is no longer appropriate for the regions to be named as responsible entities within the standards.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR calls for elimination of fill-in-the-blank elements, which will remove the RRO from the standard.</b></p>		

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Yes or No	Question 4 Comment
Georgia System Operations Corp.	No	EOP-004 should be retired. CIP-001 should not apply to LSEs other than those that are retail marketers.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The SAR calls for EOP-004 to be revised. The Standard Drafting Team may, with stakeholder approval, retire it. CIP-001: NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting process.</p>		
AEP	No	We would recommend that the Load Serving Entity (LSE) be removed from both standards, and that the Generator Owner and Transmission Owner be added to the resulting standard.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. NERC has recognized, through its Compliance Registry, that there are asset owning LSEs and non-asset owning LSEs. The SAR DT believes that an asset owning LSE may be a Distribution Provider based on the Functional Model v4. The team has added DP to the applicability of the SAR. The applicability of LSE or Distribution Provider will ultimately be determined by the Standard Drafting Team as it develops the requirements in the standard drafting stage of the process. The SAR DT discussed the addition of the TO and GO. The team has a concern that there may be duplication of requirements between the TO/TOP and GO/GOP if the TO and GO are added to the SAR. That being said, the team added the TO and GO to the applicability of the SAR so that the Standard Drafting team may consider these entities for applicability. The applicability of requirements will ultimately be determined by the Standard Drafting Team as it develops the requirements through the standard drafting Process. The team will pass your comment along to the Standard Drafting Team for its consideration concerning applicability.</p>		
Duke Energy	No	It's unclear to us that the RRO should continue to be an applicable entity.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team concurs and notes that the SAR states: EOP-004 has some 'fill-in-the-blank' components to eliminate. This will remove the RRO from applicability.</p>		
Covanta	Yes	It would be a welcome enhancement to the end users to understand to communication link between all "appropriate parties" who shall be notified of potential or actual sabotage events.... which also needs to be defined.
<p><b>Response:</b> The DSR SAR DT thanks you for your comment. The team concurs, and will pass this comment on to the standard drafting team for its consideration.</p>		
Edward C. Stein	Yes	
WECC	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Yes or No	Question 4 Comment
Luminant Power	Yes	
ReliabilityFirst Corporation	Yes	
Oncor Electric Delivery	Yes	
Consolidated Edison Co. of New York, Inc.	Yes	
Illinois Municipal Electric Agency	Yes	
Manitoba Hydro	Yes	
We Energies	Yes	
Consumers Energy Company	Yes	
PSEG Enterprise Group Inc Companies	Yes	
Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Colmac Clarion	Yes	
Progress Energy	Yes	
Ameren	Yes	

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

**5. If you have any other comments on the SAR or proposed modifications to CIP-001-1 and EOP-004-1 that you haven't provided in response to the previous questions, please provide them here.**

**Summary Consideration:** Stakeholders provided many good comments that should be considered in the development of the standards under this project. The SAR DT does not believe that these require any revisions to the SAR and will forward these comments to the Standard Drafting Team for its consideration in developing the standard(s). These include:

- 1 Consolidation of reports: The SAR DT agrees with this concept and will forward the comment to the Standard Drafting Team for its consideration.
- 2 Concerns about pre-determination of combining CIP-001 and EOP-004 into one standard: The SAR states: CIP-001 *may* be merged with EOP-004 to eliminate redundancies. The two standards may be left separate.
- 3 Reporting criteria in multiple tables: The team agrees that it would be easier if there were only one table. Part of this SAR is to eliminate redundancies and make general improvements to the standard. The team also agrees that the requirements developed should be clear in their reliability objective.

Organization	Question 5 Comment
PSEG Enterprise Group Inc Companies	<p>The PSEG Companies ask that the drafting team allow sufficient flexibility for sabotage recognition and reporting requirements such that nothing precludes utilizing a single corporate-wide program for both bulk electric system assets and other businesses. PSEG's Sabotage Recognition, Response and Reporting Program is directed to all business areas which are directed to follow the same internal protocol that also satisfies the NERC Standards requirements. For example, for gas assets, PSEG's gas distribution business follows the PSEG corporate-wide program for sabotage recognition and response. PSEG agrees that some modifications should be made to CIP-001 (ex. better define or give examples of sabotage) and EOP-004 to make them clearer? If they are merged, then Sabotage will not be in the title (or the primary focus) because several of the Disturbances that reporting is required for in EOP-004 have nothing to do with sabotage. EOP-004 has criteria listed in 4 places to determine when to send a report:</p> <ul style="list-style-type: none"> <li>o Criteria listed in EOP-004 Attachment 1</li> <li>o Criteria listed in EOP-004 Attachment 2</li> <li>o Criteria listed in top portion of Table 1-EOP-004</li> <li>o Criteria listed in bottom portion of Table 1-EOP-004</li> </ul> <p>Therefore, it would be much easier if there was one table of criteria for reference that addressed all of the reportable conditions and all of the applicable reports. If the 2 standards are merged as suggested in the SAR, any differences in the reporting obligation for actual or attempted sabotage and reporting of disturbances must be clear.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Question 5 Comment
	<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees that it would be easier if there were only one table. Part of this project is to eliminate redundancies and make general improvements to the standard. The team also agrees that the requirements developed should be clear in their reliability objective. The team will forward your comment to the standard drafting team for its consideration in the drafting of the standard.</b></p>
Kansas City Power & Light	<p>If it is desirable to keep CIP-001 and EOP-004 separate, it is recommended the SDT consider adding a reference in CIP-001 to the DOE reporting form either by name or by internet link in the standard.</p>
	<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR SDT recommends eliminating all references to the DOE report, so there won't be a reference to it in CIP-001.</b></p>
IRC Standards Review Committee	<p>We suggest that the revision not be conducted with a preconceived notion that the two standards must be combined since there are some differences between sabotage and emergency system conditions, and in the communication and reporting processes and channels. We suggest the SDT start off with a neutral position to focus on improving the standards, then assess the pros and cons of merging the two based on technical merit only.</p>
	<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states: CIP-001 may be merged with EOP-004 to eliminate redundancies. The two standards may be left separate.</b></p>
Pepco Holdings, Inc. - Affiliates	<p>Consider CIP-008-2 as potentially having overlaps with the proposed standard</p>
	<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states "Specific references to the DOE form need to be eliminated." This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states:</b></p> <p><b>Consider FirstEnergy's suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality. This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>
FirstEnergy	<ol style="list-style-type: none"> <li>1. Under Industry Need it states: "The existing requirements need to be revised to be more specific and there needs to be more clarity in what sabotage looks like." The use of the phrase "more specific" should be qualified by adding "while not being too prescriptive". As with other reliability standards, we do not want a standard that causes unwarranted and unnecessary additional work and costs to an entity to comply.</li> <li>2. As pointed out by the NERC Audit and Observation Team in the "Issues to be considered" for CIP-001, clarification is needed regarding contacting the FBI. Prior audits dwelled heavily on FBI notification. For example, our policy states that Corporate Security notifies the FBI. In recent events it appears that local law enforcement handles day to day activities. The notification process for</li> </ol>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Question 5 Comment
	<p>contacting the FBI needs clarification along with specific instances in which to call them. Who should make the call to the FBI? It appears that a protocol needs to be developed to clarify what events require notifying the FBI. It could be as simple as after an incident a standard form is completed and forwarded to the FBI, letting them decide if follow up is needed.</p> <p>3. We suggest aligning all reporting requirements for consistency. The items requiring reporting and the timelines to report are very inconsistent between NERC and the DOE. NERC's timelines are also not consistent with their own Security Guideline for the Electricity Sector: Threat and Incident Reporting.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p>The team concurs that the standards should provide the “what” without the “how”. The standard drafting team will develop the standards using the NERC Standard Development Process that includes stakeholder consensus. The team does not feel it is necessary to add the “not too prescriptive” qualifier to the SAR.</p> <p>The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</p> <p>The team concurs with your comment and notes that other commenters have suggested “one stop shopping” reporting for disturbances and sabotage. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</p>	
Electric Market Policy	CIP-008-1 Incident Reporting and Response Planning include some requirements that require coordination with the requirements addressed in this project.
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states “Specific references to the DOE form need to be eliminated.” This will remove the linkage that you identify between CIP-001 and CIP-008. There is also a directive from FERC Order 693 in the SAR that states:</b></p> <p><b>Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</b></p> <p><b>This allows the standard drafting team to delineate physical and cyber assets. The DSR SAR DT also notes that CIP-008 might be a good framework for drafting the standard requirements pertaining to sabotage and disturbance reporting of physical assets.</b></p>	
MRO NERC Standards Review Subcommittee	<p>A. The SAR states that there may be impact on a related standard, COM-003-1 (page SAR-5). Is the SDT referring to Project 2007-02, Operating Personnel Communication Protocols? If so, this is a SAR too and should not be used as a reference.</p> <p>B. CIP-001-1 and EOP-004-1 should be combined into one EOP Standard.</p> <p>C. Within EOP-004-1 there is industry confusion on what form to submit in the event of an event. There should only be one form for the new combination Standard eliminating the need for reporting form attachments. It should be the DOE Form, OE-417. Although it is beyond the scope of this SAR, it would greatly benefit industry if there was a central location on the NERC website containing ALL reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable the System Operators to efficiently locate the most current version of the appropriate form in order to report events.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Question 5 Comment
	<p>D. The word Disturbance is primarily used in other Standards as in, Disturbance Control Standard or system separation due to a disturbance. Should the NERC definition be updated? Should the word "Sabotage" be defined by NERC? Additionally, we recommend that one definition of "Sabotage" be utilized industry-wide, instead of varying definitions by multiple groups like the DOE, ESIAC, etc.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p> <p><b>A. It does reference project 2007-02, and it has been noted in the SAR.</b></p> <p><b>B. Will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p> <p><b>C. The team concurs with your comment and notes that other commenters have suggested "one stop shopping" reporting for disturbances and sabotage. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p> <p><b>D. References to DOE are to be removed from the standards per the SAR. FERC Order 693 directives include definition of sabotage for CIP-001.</b></p>	
Lands Energy Consulting	<p>One final comment on CIP-001-1. My clients received universally rude treatment from the FBI field offices when they attempted to establish the contacts required by the Standard. If the FBI doesn't see value in establishing these contacts, remove the requirement from the Standard. Making sure the LSE knows the FBI field office phone number is probably all the Standard should require.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
Colmac Clarion	<p>Need single report for Sabotage so whatever is required results in notification of all parties (State Emergency Management, Homeland Security, FBI, Grid Reliability Chain of Command). Any and all of these can 'expand' knowledge later but all seem to require 'instant' notification.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The team concurs with your comment and notes that other commenters have suggested "one stop shopping" reporting for disturbances and sabotage. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
Cowlitz County PUD	<p>Local Law enforcement agencies often are not friendly to Federal involvement with smaller problems they consider their "turf." Need to make sure the small stuff stays with them, however have a system of internal reporting that will catch coordinated sabotage efforts (multiple attacks on DPs and small BAs) at the RC or RE level who then can report to the Federal agencies. Currently EOP-004-1 requires small entities to report a "disturbance" if half of their firm customer load is lost. For some entities, this can be one small substation going down due to a bird. The "50% of total demand" requirement should be removed or improved to better define a true BPS disturbance.</p>



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Question 5 Comment
<p><b>Response: The DSR SAR DT thanks you for your comment. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
Exelon	<p>Exelon agrees this is a worthwhile project and that reliability will be enhanced and the compliance process will be simplified by clarifying terminology and reporting requirements in these standards. If nothing else, defining "Sabotage" so as to end interpretations of this term and the related requirements is necessary.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment.</b></p>	
ERCOT ISO	<p>Due to the fact that both the CIP-001-1 and EOP-004-1 have similar reporting standards, initially combining the two sounds like a correct analysis. However, after further consideration and due to the critical nature of its intended function involving Security aspects, the CIP-001 should be intensely evaluated to determine if its intended purpose meets the threshold or criteria to stand alone. The existing standards for CIP-001-1 Sabotage Reporting may help prevent future mitigation actions caused by sabotage events. EOP-004-1 Disturbance Reporting is administrative in nature, thus the jeopardy of the Bulk Electric System reliability is impacted only if analysis is not performed or if corrective follow-up actions are not implemented. Combining EOP-004 Standard requirements under the umbrella of the CIP -001 Standard would create a high profile Disturbance Reporting Standard. The industry would be better served if information defining sabotage was provided as well as a technical reference document on recognizing sabotage that would also clarify or state any personnel training requirements. All aspects of the intended functions must be reviewed before merging the two standards. At a minimum, we must consider modification that provides improved understanding of the reporting standards and implications as they are currently written.</p>
<p><b>Response: The DSR SAR DT thanks you for your comment. The SAR states: CIP-001 may be merged with EOP-004 to eliminate redundancies. The two standards may be left separate. One of the FERC Order 693 directives for CIP-001 states:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p> <p><b>The Standard Drafting Team will follow the NERC Standard Development Process in making revisions under this SAR, including a thorough review of the requirements of both standards. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
MidAmerican Energy	<p>Conflicting time frames exist from document updates. Reporting should be consolidated to one form and / or site to minimize conflicts, confusion, and errors. 1) Reporting requirements for the outage of 50,000 or more customers in EOP-004-1 requires a report to be made within one hour while the form OE-417 requires a report be made within six hours of the outage. The six hour reference on the updated OE-417 form is the correct reference. 2) Reporting for either CIP-001 or EOP-004 should center on the DOE Form OE-417. This would eliminate confusion and simplify reporting for system operators thereby directly enhancing reliability during system events. This would also eliminate much of the duplicate material and attachments in EOP-004. 3) Although it is beyond the scope of this SAR, the industry would benefit if there was a central location or link on the NERC website containing all</p>

Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting

Organization	Question 5 Comment
	reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable System Operators to more efficiently locate and report events.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team notes that other commenters have suggested “one stop shopping” reporting for disturbances and sabotage. The team concurs that timeframes for similar reports should be the same. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s).</b></p>	
Georgia System Operations Corp.	Entity reporting to NERC/Regions is needed by NERC and the Regions to accomplish their missions of overseeing the reliability of the BES and enforcing compliance with Reliability Standards. An entity not reporting as quickly as possible does not harm the integrity of the Interconnection. In fact, it increases the risk to the BES to be investigating details and filling out forms during a time when attention should be on correcting or mitigating an incident.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team agrees that non-reporting, in the administrative sense, may not harm the integrity of the Interconnection. The team suggests that the appropriate avenue for addressing this concern is through the development of Violation Risk Factors and Violation Severity Levels for each requirement. These compliance elements will be developed during the standard drafting stage of the development process.</b></p>	
Illinois Municipal Electric Agency	IMEA recommends the following considerations: Simplification of reportable events and the reporting process should be the overriding objective. NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting (Version 2.0) should be updated to support this standards development initiative. At some point in the process, it may help if examples are given of events actually reported that did not need to be reported.
<p><b>Response: The DSR SAR DT thanks you for your comment. The team notes that other commenters have suggested “one stop shopping” reporting for disturbances and sabotage. The team agrees that NERC’s Security Guide should be in sync with the standards. The team will forward this comment to the standard drafting team for its consideration in developing the standard(s). One of the FERC Order 693 directives for CIP-001 states:</b></p> <p><b>Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</b></p> <p><b>Events that were reported, but didn’t need to be, may be identified in “lessons learned”.</b></p>	
WECC	No
Luminant Power	None
Oncor Electric Delivery	No Additional Comments

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

---

Organization	Question 5 Comment
NextEra Energy Resources, LLC	No comment.
Ameren	None

## Unofficial Nomination Form for SAR Drafting Team for Disturbance and Sabotage Reporting (Project 2009-01)

Please use the [electronic nomination form](#) located at the link below. If you have any questions, please contact David Taylor at [david.taylor@nerc.net](mailto:david.taylor@nerc.net) or by telephone at 609-651-5089.

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

**By submitting the following information you are indicating your commitment to actively participate in SAR Drafting Team meetings if appointed to the SAR Drafting Team by the Standards Committee.**

Name:

Organization:

Address:

Telephone:

E-mail:

**Project 2009-01 Disturbance and Sabotage Reporting** will entail revising existing standards CIP-001 — Sabotage Reporting and EOP-004 — Disturbance Reporting to eliminate redundancies and provide clarity on sabotage events. The project includes addressing several issues identified by stakeholders, FERC directives from Order 693, and may include improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Please briefly describe (no more than a couple of paragraphs) your experience and qualifications directly related to the issues to be addressed by the Disturbance and Sabotage Reporting SAR Drafting Team. We are seeking a cross section of the industry to participate on the team, but in particular are seeking individuals with experience in management of real-time bulk power operations activities. Please include any previous experience related to developing or applying IEEE or other industry related standards as this type of experience might be beneficial to include on the team, but is not a requisite to be appointed to the team.

**Nomination Form for Disturbance and Sabotage Reporting SAR Drafting Team (Project 2009-01)**

<p>Are you currently a member of any NERC or Regional Entity SAR or standard drafting team? If yes, please list each team here.</p>	<p><input type="checkbox"/> No <input type="checkbox"/> Yes:</p>
<p>Have you previously worked on any NERC or Regional Entity SAR or standard drafting teams? If yes, please list them here.</p>	<p><input type="checkbox"/> No <input type="checkbox"/> Yes:</p>

<p>Please identify the NERC Region(s) for which you are able to represent your company's position relative to the topics addressed in the SAR:</p> <p><input type="checkbox"/> ERCOT <input type="checkbox"/> FRCC <input type="checkbox"/> MRO <input type="checkbox"/> NPCC <input type="checkbox"/> RFC <input type="checkbox"/> SERC <input type="checkbox"/> SPP <input type="checkbox"/> WECC <input type="checkbox"/> Not Applicable or None of the Above</p>	<p>Please identify the Industry Segment(s) for which you are able to represent your company's position relative to the topics addressed in the SAR:</p>	
	<input type="checkbox"/>	1 — Transmission Owners
	<input type="checkbox"/>	2 — RTOs and ISOs
	<input type="checkbox"/>	3 — Load-serving Entities
	<input type="checkbox"/>	4 — Transmission-dependent Utilities
	<input type="checkbox"/>	5 — Electric Generators
	<input type="checkbox"/>	6 — Electricity Brokers, Aggregators, and Marketers
	<input type="checkbox"/>	7 — Large Electricity End Users
	<input type="checkbox"/>	8 — Small Electricity End Users
	<input type="checkbox"/>	9 — Federal, State, and Provincial Regulatory or other Government Entities
<input type="checkbox"/>	10 — Regional Reliability Organizations and Regional Entities	
<input type="checkbox"/>	Not applicable	
<p>Please identify the Functional Entities<sup>1</sup> for which you are able to represent your company's position relative to the topics addressed in the SAR:</p>		

<sup>1</sup> These functions are defined in the [NERC Functional Model](#), which is available on the NERC Web site.

**Nomination Form for Disturbance and Sabotage Reporting SAR Drafting Team (Project 2009-01)**

<input type="checkbox"/> Balancing Authority <input type="checkbox"/> Compliance Enforcement Authority <input type="checkbox"/> Distribution Provider <input type="checkbox"/> Generator Operator <input type="checkbox"/> Generator Owner <input type="checkbox"/> Interchange Authority <input type="checkbox"/> Load-serving Entity <input type="checkbox"/> Market Operator	<input type="checkbox"/> Planning Coordinator <input type="checkbox"/> Transmission Operator <input type="checkbox"/> Transmission Owner <input type="checkbox"/> Transmission Planner <input type="checkbox"/> Transmission Service Provider <input type="checkbox"/> Purchasing-selling Entity <input type="checkbox"/> Resource Planner <input type="checkbox"/> Reliability Coordinator
<p><b>Please provide the names and contact information for two references who could attest to your technical qualifications and your ability to work well in a group. NERC staff may contact these references.</b></p>	
Name and Title:  Organization:	Office Telephone:  E-mail:
Name and Title:  Organization:	Office Telephone:  E-mail:

## Standards Announcement

Nomination Period Opens for Standard Authorization Request  
(SAR) Drafting Team

April 29–May 13, 2009

Now available at: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance Sabotage Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Nominations for SAR Drafting Team (Project 2009-01 — Disturbance and Sabotage Reporting)**

The Standards Committee is seeking industry experts to serve on the Disturbance and Sabotage Reporting SAR Drafting Team (see project background below). The SAR drafting team will assist the requester in further developing the SAR and considering stakeholder comments.

If you are interested in serving on this standard drafting team, please complete the following electronic nomination form **by May 13, 2009**:

<https://www.nerc.net/nercsurvey/Survey.aspx?s=bf869d5cbde94f9788c7606a2f50829f>

Please contact Dave Taylor at [david.taylor@nerc.net](mailto:david.taylor@nerc.net) or at 609-651-5089 with any questions about the team.

### **Project Background:**

Project 2009-01 — Disturbance and Sabotage Reporting will entail revising existing standards CIP-001-1 — Sabotage Reporting and EOP-004-1 — Disturbance Reporting to eliminate redundancies and provide clarity on sabotage events. The project includes addressing several issues identified by stakeholders, FERC directives from Order 693, and may include improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

More information about the project is available on the following page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance Sabotage Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Standards Development Process**

The [Reliability Standards Development Procedure](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance,  
please contact Shaun Streeter at [shaun.streeter@nerc.net](mailto:shaun.streeter@nerc.net) or at 609.452.8060.*

## Standard Authorization Request Form

<b>Title of Proposed Standard:</b> Disturbance and Sabotage reporting (Project 2009-01)
<b>Request Date:</b> April 2, 2009
<b>Approved by SC for posting:</b> April 15, 2009
<b>Revision Date:</b> August 13, 2009

<b>SAR Requester Information</b>	<b>SAR Type</b> <i>(Check a box for each one that applies.)</i>
Name: Patrick Brown	<input type="checkbox"/> New Standard
Primary Contact: Patrick Brown Manager, NERC and Regional Coordination PJM Interconnection	<input checked="" type="checkbox"/> Revision to existing Standard
Telephone: 610-666-4597	<input checked="" type="checkbox"/> Withdrawal of existing Standard
E-mail: brownp@pjm.com	<input type="checkbox"/> Urgent Action

<p><b>Purpose</b> <i>(Describe the proposed standard action: Nomination of a proposed standard, revision to a standard, or withdrawal of a standard and describe what the standard action will achieve.)</i></p> <p>This project will entail revision to existing standards CIP-001-1 – Sabotage Reporting and EOP-004-1 – Disturbance Reporting. The standards may be merged to eliminate redundancy and provide clarity on sabotage events. EOP-004 has some ‘fill-in-the-blank’ components to eliminate. The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.</p>
<p><b>Industry Need</b> <i>(Provide a justification for the development or revision of the standard, including an assessment of the reliability and market interface impacts of implementing or not implementing the standard action.)</i></p> <p>The existing requirements need to be revised to be more specific – and there needs to be more clarity in what sabotage looks like.</p>
<p><b>Brief Description</b> <i>(Provide a paragraph that describes the scope of this standard action.)</i></p> <p>CIP-001 may be merged with EOP-004 to eliminate redundancies. Acts of sabotage have to be reported to the DOE as part of EOP-004. Specific references to the DOE form need to be eliminated.</p> <p>EOP-004 has some ‘fill-in-the-blank’ components to eliminate.</p> <p>The development may include other improvements to the standards deemed appropriate by</p>



## Standards Authorization Request Form

---

the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information).

**Detailed Description** (Provide a description of the proposed project with sufficient details for the standard drafting team to execute the SAR.)

See "Issues to be Considered by Drafting Team" tables for each standard at the end of this SAR for more detailed information.

**Standards Authorization Request Form**

**Reliability Functions**

<b>The Standard will Apply to the Following Functions</b> <i>(Check box for each one that applies.)</i>		
<input checked="" type="checkbox"/>	Reliability Coordinator	Responsible for the real-time operating reliability of its Reliability Coordinator Area in coordination with its neighboring Reliability Coordinator's wide area view.
<input checked="" type="checkbox"/>	Balancing Authority	Integrates resource plans ahead of time, and maintains load-interchange-resource balance within a Balancing Authority Area and supports Interconnection frequency in real time.
<input type="checkbox"/>	Interchange Authority	Ensures communication of interchange transactions for reliability evaluation purposes and coordinates implementation of valid and balanced interchange schedules between Balancing Authority Areas.
<input type="checkbox"/>	Planning Coordinator	Assesses the longer-term reliability of its Planning Coordinator Area.
<input type="checkbox"/>	Resource Planner	Develops a >one year plan for the resource adequacy of its specific loads within a Planning Coordinator area.
<input type="checkbox"/>	Transmission Planner	Develops a >one year plan for the reliability of the interconnected Bulk Electric System within its portion of the Planning Coordinator area.
<input type="checkbox"/>	Transmission Service Provider	Administers the transmission tariff and provides transmission services under applicable transmission service agreements (e.g., the pro forma tariff).
<input checked="" type="checkbox"/>	Transmission Owner	Owns and maintains transmission facilities.
<input checked="" type="checkbox"/>	Transmission Operator	Ensures the real-time operating reliability of the transmission assets within a Transmission Operator Area.
<input checked="" type="checkbox"/>	Distribution Provider	Delivers electrical energy to the End-use customer.
<input checked="" type="checkbox"/>	Generator Owner	Owns and maintains generation facilities.
<input checked="" type="checkbox"/>	Generator Operator	Operates generation unit(s) to provide real and reactive power.
<input type="checkbox"/>	Purchasing-Selling Entity	Purchases or sells energy, capacity, and necessary reliability-related services as required.
<input type="checkbox"/>	Market Operator	Interface point for reliability functions with commercial functions.
<input checked="" type="checkbox"/>	Load-Serving Entity	Secures energy and transmission service (and reliability-related services) to serve the End-use Customer.

## Standards Authorization Request Form

### **Reliability and Market Interface Principles**

<b>Applicable Reliability Principles</b> <i>(Check box for all that apply.)</i>	
<input checked="" type="checkbox"/>	1. Interconnected bulk power systems shall be planned and operated in a coordinated manner to perform reliably under normal and abnormal conditions as defined in the NERC Standards.
<input type="checkbox"/>	2. The frequency and voltage of interconnected bulk power systems shall be controlled within defined limits through the balancing of real and reactive power supply and demand.
<input checked="" type="checkbox"/>	3. Information necessary for the planning and operation of interconnected bulk power systems shall be made available to those entities responsible for planning and operating the systems reliably.
<input checked="" type="checkbox"/>	4. Plans for emergency operation and system restoration of interconnected bulk power systems shall be developed, coordinated, maintained and implemented.
<input type="checkbox"/>	5. Facilities for communication, monitoring and control shall be provided, used and maintained for the reliability of interconnected bulk power systems.
<input type="checkbox"/>	6. Personnel responsible for planning and operating interconnected bulk power systems shall be trained, qualified, and have the responsibility and authority to implement actions.
<input type="checkbox"/>	7. The security of the interconnected bulk power systems shall be assessed, monitored and maintained on a wide area basis.
<input checked="" type="checkbox"/>	8. Bulk power systems shall be protected from malicious physical or cyber attacks.
<b>Does the proposed Standard comply with all of the following Market Interface Principles?</b> <i>(Select 'yes' or 'no' from the drop-down box.)</i>	
1. A reliability standard shall not give any market participant an unfair competitive advantage. Yes	
2. A reliability standard shall neither mandate nor prohibit any specific market structure. Yes	
3. A reliability standard shall not preclude market solutions to achieving compliance with that standard. Yes	
4. A reliability standard shall not require the public disclosure of commercially sensitive information. All market participants shall have equal opportunity to access commercially non-sensitive information that is required for compliance with reliability standards. Yes	

## Standards Authorization Request Form

---

### *Related Standards*

<b>Standard No.</b>	<b>Explanation</b>
COM-003-1	Operations Communications Protocols – this standard may include some requirements that require coordination with the requirements addressed in this project. (still in standard development stage)
IRO-014-1	R1.1.1, footnote 1 lists sabotage. The standard drafting team should consider this reference and the impact of their work on this specific item.
TOP-005-1.1	Attachment 1, item 2.9 is “Multi-site sabotage”. The standard drafting team should consider this reference and the impact of their work on this specific item.

### *Related SARs*

<b>SAR ID</b>	<b>Explanation</b>

### *Regional Variances*

<b>Region</b>	<b>Explanation</b>
ERCOT	
FRCC	
MRO	
NPCC	
SERC	
RFC	
SPP	
WECC	

<b>Issues to be Considered by Drafting Team</b> <b>Project 2009-01 — Disturbance and Sabotage Reporting</b>	
Standard #	Title
CIP-001-0	Sabotage Reporting
<b>Issues</b>	<p>FERC Order 693</p> <p>Disposition: Approved with modifications</p> <ul style="list-style-type: none"> <li>• Consider the need for wider application of the standard. Consider whether separate, less burdensome requirements for smaller entities may be appropriate.</li> <li>• Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</li> <li>• In the interim, provide advice to entities about the reporting of particular circumstances as they arise.</li> <li>• Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</li> <li>• Incorporate a periodic review or updating of the sabotage reporting procedures and for their periodic testing. Consider a staggered schedule of annual testing and formal review every two to three years.</li> <li>• Include a requirement to report a sabotage event to the proper government authorities. Develop the language to specifically implement this directive.</li> <li>• Explore ways to reduce redundant reporting, including central coordination of sabotage reports and a uniform reporting format.</li> </ul> <p>V0 Industry Comments</p> <ul style="list-style-type: none"> <li>• Object to multi-site requirement</li> <li>• Definition of sabotage required</li> </ul> <p>VRF comments</p> <ul style="list-style-type: none"> <li>• Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures.</li> </ul> <p>Other</p> <ul style="list-style-type: none"> <li>• Modify standard to conform to the latest version of NERC’s Reliability Standards Development Procedure, the NERC Standard Drafting Team Guidelines, and the ERO Rules of Procedure.</li> </ul> <p>NERC Audit and Observation Team</p> <ul style="list-style-type: none"> <li>• Applicability — How does this standard pertain to Load Serving Entities, LSE's.</li> <li>• Registered Entities have sabotage reporting processes and procedures in place but not all personnel has been trained.</li> <li>• Question: How do you “and make the operator aware”</li> <li>• R4 — “What is meant by: “establish contact with the FBI”. Is a phone number adequate? Many entities which call the FBI are referred back to the local authority. The AOT noted that on the FBI website it states</li> </ul>

	<p>to contact the local authorities. Is this a question for Homeland Security to deal with for us?"</p> <ul style="list-style-type: none"> <li>• R4 — Establish communications contacts, as applicable with local FBI and RAMP officials. Some entities are very remote and the sheriff is the only local authority does the FBI still need to be contacted?</li> </ul> <p>FERC's December 20, 2007 and April 4, 2008 Orders in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000</p> <ul style="list-style-type: none"> <li>• In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none owned physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be applied. Each drafting team responsible for reliability standards applicable to LSEs is to review and change as necessary, requirements in the applicable reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:             <ul style="list-style-type: none"> <li>• FERC's December 20, 2007 Order (<a href="http://www.nerc.com/files/LSE_decision_order.pdf">http://www.nerc.com/files/LSE_decision_order.pdf</a> )</li> <li>• NERC's March 4, 2008 (<a href="http://www.nerc.com/files/FinalFiledLSE3408.pdf">http://www.nerc.com/files/FinalFiledLSE3408.pdf</a> ),</li> <li>• FERC's April 4, 2008 Order (<a href="http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf">http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf</a> ) and</li> <li>• NERC's July 31, 2008 (<a href="http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf">http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf</a> ) compliance filings to FERC on this subject.</li> </ul> </li> </ul>
--	---

<b>Issues to be Considered by Drafting Team</b>	
<b>Project 2009-01 — Disturbance and Sabotage Reporting</b>	
<b>Standard #</b>	<b>Title</b>
<b>EOP-004-1</b>	Disturbance Reporting
<b>Issues</b>	<p>FERC Order 693</p> <p>Disposition: Approved with modification</p> <ul style="list-style-type: none"> <li>• Include any requirements for users, owners, and operators of the bulk power system to provide data that will assist NERC in the investigation of a blackout or disturbance.</li> <li>• Change NERC's Rules of Procedure to assure the Commission receives these reports in the same frame as the DOE.</li> <li>• Consider APPA's concern about generator operators and LSEs analyzing performance of their equipment and provide data and information on the equipment to assist others with analysis.</li> <li>• Consider all comments offered in a future modification of the reliability standard.</li> </ul>

	<p>Fill-in-the-Blank Team Comments</p> <ul style="list-style-type: none"><li>• Consider changes to R1 and R3.4 to standardize the disturbance reporting requirements (requirements for disturbance reporting need to be added to this standard)</li><li>• Regions currently have procedures, but not in the form of a standard. The drafting team will need to review regional requirements to determine reporting requirements for the North American standard.</li></ul> <p>V0 Industry Comments</p> <ul style="list-style-type: none"><li>• R3 – too many reports, narrow requirement to RC</li><li>• How does this apply to generator operator?</li></ul> <p>Other</p> <ul style="list-style-type: none"><li>• Modify standard to conform to the latest version of NERC's Reliability Standards Development Procedure, the NERC Standard Drafting Team Guidelines, and the ERO Rules of Procedure.</li></ul> <p>NERC Audit and Observation Team</p> <ul style="list-style-type: none"><li>• R3.1 — Can there be a violation without an event?</li></ul> <p>Event Analysis Team</p> <ul style="list-style-type: none"><li>• Reliability Issue: Coordination and follow up on lessons learned from event analyses Consider adding to EOP-004 – Disturbance Reporting. Proposed requirement: Regional Entities (REs) shall work together with Reliability Coordinators, Transmission Owners, and Generation Owners to develop an Event Analysis Process to prevent similar events from happening and follow up with the recommendations. This process shall be defined within the appropriate NERC Standard.</li></ul> <p>FERC's December 20, 2007 and April 4, 2008 Orders in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000</p> <ul style="list-style-type: none"><li>• In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none owned physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be applied. Each drafting team responsible for reliability standards applicable to LSEs is to review and change as necessary, requirements in the applicable reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:<ul style="list-style-type: none"><li>• FERC's December 20, 2007 Order (<a href="http://www.nerc.com/files/LSE_decision_order.pdf">http://www.nerc.com/files/LSE_decision_order.pdf</a> )</li><li>• NERC's March 4, 2008 (<a href="http://www.nerc.com/files/FinalFiledLSE3408.pdf">http://www.nerc.com/files/FinalFiledLSE3408.pdf</a> ),</li><li>• FERC's April 4, 2008 Order (<a href="http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf">http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf</a> ) and</li><li>• NERC's July 31, 2008 (<a href="http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf">http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf</a> ) compliance filings to FERC on this subject.</li></ul></li></ul>
--	--

Comments received on Project 2009-01 — Disturbance and Sabotage Reporting

The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) received many suggestions for improvements to the standards during the SAR comment period. These comments do not indicate any revisions to the SAR, but the DSRSDT thought that these comments merited further consideration during the standard drafting phase of the project. The comments below are being compiled for use by the Standard Development Team.

Organization	Comment
Electric Market Policy	<p>Comments: Agree with the statement that sabotage is hard to determine in real time by operations staffs. The determination of sabotage should be left up to law enforcement. They have the knowledge and peer contacts needed to adequately determine whether physical or cyber intrusions are merely malicious acts or coordinated efforts (sabotage). The operators should only be required to report physical and cyber intrusions to law enforcement. All other reporting requirements should apply to law enforcement once a determination of sabotage has been made. If the recommendations above are not to be accepted, then we have the following comments:</p> <p>CIP-001-1</p> <ol style="list-style-type: none"> <li>1) R1 states entities shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection. The SAR notes that the industry objects to the multi-site requirement, most likely because the term is ambiguous. If this term remains in the standard, it needs to be clearly defined and responsibilities for obtaining (how do you get this information and from whom?) and distributing need to be included.</li> <li>2) R1 audits have shown confusion over the requirement to make operating personnel aware of sabotage events. The term operating personnel needs to be defined. Are they the individuals responsible for operating the facility, coordinating with other entities (i.e., RC, BA, TOP, GOP, and LSE)? It has been suggested that notification is required to all personnel at a facility. Keep in mind the purpose of the standard is to ensure sabotage events are properly reported, not to address emergency response.</li> <li>3) R1 The SAR (NERC Audit and Observation Team) notes that Registered Entities have processes and procedures in place, but not all personnel have been trained. There is no specific training requirement in the standard.</li> <li>4) R2 &amp; R3 I agree with the SAR that sabotage needs to be defined and these requirements should be more specific with respect to the information to be communicated. It seems to me that the standard should mirror the criteria contained in DOE OE-417. The emphasis should be placed on ensuring that the same information communicated to DOE is shared with the appropriate parties in the Interconnection.</li> <li>5) R4 I agree with the SAR (NERC Audit and Observation Team) comments regarding the intention of this requirement. There is no language that directs contact with FBI or RCMP although that is what is implied by the Purpose statement.</li> </ol>



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>6) VRF Comments I'm not sure what is intended by the statement Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures? The purpose of the standard is that of communication. No operational decisions or actions are directed by this standard, nor does it require entities to address operational aspects resulting from sabotage.</p> <p>7) The potential exists for overlapping sabotage reporting requirements at nuclear power plants due to multiple regulators (Nuclear Regulatory Commission (NRC) 10 CFR 73 and Federal Energy Regulatory Commission (FERC) NUC-001-1). Some entities may have revised existing NRC driven procedures to accommodate reporting requirements of both regulators. Because of the restrictions placed on NRC driven documents (i.e., procedures are classified as safeguards information), it can be difficult to demonstrate compliance to NERC and/or FERC without ensuring that the individuals are qualified for receipt of such information per 10 CFR 73. Additionally, multiple procedures may have the unintended consequence of delaying appropriate communication. EOP-004-1 Consider removing Attachment 2 as the information is duplicated in DOE Form OE-417. A simple reference to the form should suffice.</p>
Lands Energy Consulting	<p>I have worked with 5 Northwest public utilities on developing procedures related to CIP-001-1 and EOP-004-1. All 5 utilities operate electric systems in fairly remote locations and are embedded in a larger utility's Balancing Authority/Transmission Operator area.</p> <p>A. CIP-001-1 - Developing procedures to unambiguously identify acts of sabotage has been particularly challenging for these systems. In general, it's hard for them to determine whether the most prevalent forms of malicious and intentional system damage that they incur - copper theft and gun shot insulators/equipment - should qualify as acts of sabotage. Although none of the systems consider copper theft to be acts of sabotage, two of the systems consider gun shot insulators/equipment to be acts of sabotage. The other systems look for intent to disrupt electric system operations as a key component of their sabotage identification procedures. Additional guidance from NERC in the form of CIP-001-1 modifications or a companion guidelines document on sabotage identification would provide much needed guidance for these procedures.</p> <p>B. EOP-004-1 - This standard was clearly drafted with the larger electric systems in mind. I have one client that serves 3300 commercial/residential customers from 4-115/13 kV substation transformers and one large industrial customer (80% of its energy load) from a 230/13 kV substation. 75% of the client's load is served from three substations attached to a long, 115 kV transmission line operated by the Bonneville Power Administration. Whenever the line relays open on a permanent fault (which happens 2-3 times per year), the client loses over 50% of its customers (but no more than 10-15 MW during winter peak), thereby necessitating the preparation of a Disturbance Report. To allow utilities to concentrate on operating their systems, without fear of violating EOP-004-1 for failure to report trivial outages, I would remove LSEs from the obligation to report disturbances - leave the reporting to the BA/TOP for large outages in their footprint.</p>
Calpine Corporation	Communication of facility status or emergencies between merchant generators registered as GOP and the RC, BA,

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>GOP, or LSE in which the facility resides should be coordinated for EOP -004 reporting. The reporting to NERC/DOE should come from the RC, BA, GOP, or LSE.</p>
Covanta	<p>Yes - the key to Sabotage reporting requirements is identifying what the 'definition' is of an actual or potential 'Sabotage' event. Like any other standard, if FERC/NERC leave it up to 2000+ entities to establish their own definitions of 'Sabotage', you may likely get 2000+ answers. That is not a controlled and coordinated approach. I offer the following definition, "Sabotage - Deliberate or malicious destruction of property, obstruction of normal operations, or injury to personnel by outside agents." Examples of sabotage events could include, but are not limited to, suspicious packages left near site electrical generating or electrical transmission assets, identified destruction of generating assets, telephone/e mail received threats to destroy or interrupt electrical generating efforts, etc." These have passed multiple NERC regional audits and reviews to date.</p>
Northeast Power Coordinating Council	<p>The SAR needs to be more specific in defining its objectives.</p> <p>CIP-001 Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <ol style="list-style-type: none"> <li>1. Develop clear definitions for the terms “operating personnel” and “sabotage events.” The definition of “operating personnel,” should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term “sabotage event” needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</li> <li>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such “sabotage events,” e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term “aware” in the standard. “Aware” can be interpreted in accordance with its largely passive, dictionary-based meaning, where being “aware” simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of “aware” could refer to more active wording, involving more than mere awareness, e.g., “alert and quick to respond,” pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</li> </ol>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>EOP-004 - The SDT needs to work on the following areas.</p> <p>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states: Introduction “The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance - The sense of Attachment 1 is internally inconsistent between the introduction (“occurs”) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase “or could have resulted in” a potential system disturbance. This inconsistency should be clarified.</p>
FirstEnergy	<p>We agree with the scope but would also like to see the following considered:</p> <p>1. References to the DOE reporting process in EOP-004 need to be revised. They currently refer to the old EIA form.</p> <p>2. Besides "sabotage", it may be helpful to clearly define "vandalism". It is vaguely written in the standards. Also, the process of "public appeals" for the DOE reportable requirements needs to be more clearly defined.</p> <p>3. Consolidate documents covering reporting requirements. There are currently several documents that require reporting (EOP-004, CIP-001, DOE oe-417, and NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting). NERC also has the "Bulk Power System Disturbance Classification Scale" that does not completely align with all the reporting requirements. Therefore we recommend keeping this as simple as possible by combining all the reporting requirements into one standard. It would be beneficial to not require operators to have to go to 4 different documents to determine what to report on.</p>
MRO NERC Standards Review Subcommittee	<p>The MRO NSRS would like to keep the references to the DOE reporting form.</p>
Cowlitz County PUD	<p>Added to the scope:</p> <p>For EOP-004 add a provision for a reporting flow rather than everything going to the RE and NERC. That is something going like the DP and TOP reports to the BA, the BA to the RE, and the RE to NERC. This would allow for multiple related reports to be combined into a single coherent report as the reporting goes up the chain.</p> <p>For CIP-001 consider reporting flow as above with local law enforcement notification. Let an upper entity in the reporting chain decide when to contact Federal Agencies such as the BA or the RC.</p>
Reliant Energy	<p>I think Generator operators should be excluded except to provide requested information from the System Operator or</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	Reliability coordinator.
ERCOT ISO	The scope should be modified to provide for a different treatment of reporting requirements that are administrative in nature, or that are after-the-fact (thus cannot impact reliability unless analysis and follow-up is not performed; even then, the impact would be at some future time). Reporting requirements which are of the nature to assist in identification of system concerns or which serve to prevent or mitigate on-going system problems (including, but not limited to, actual or attempted sabotage activity) should remain in standards, but should be separate and apart from the administrative reporting.
Consolidated Edison Co. of New York, Inc.	<p>GENERAL CECONY and ORU support the general objectives of the SAR to merge existing standards CIP-001-1 Sabotage Reporting and EOP-004-1 Disturbance Reporting to improve clarity and remove redundancy.</p> <p>However, the SAR needs to be more specific in defining its objectives.</p> <p>CIP-001 Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <ol style="list-style-type: none"> <li>1. Develop clear definitions for the terms operating personnel and sabotage events. The definition of operating personnel, should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term sabotage event needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</li> <li>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such sabotage events, e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term aware in the standard. Aware can be interpreted in accordance with its largely passive, dictionary-based meaning, where being aware simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of aware could refer to more active wording, involving more than mere awareness, e.g., alert and quick to respond, pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</li> </ol> <p>EOP-004 - The SDT needs to work on the following areas.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states:</p> <p>Introduction The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: ?c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance.</p> <p>The sense of Attachment 1 is internally inconsistent between the introduction (occurs) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase or could have resulted in a potential system disturbance. This inconsistency should be clarified.</p>
Georgia System Operations Corp.	<p>The scope of the SAR should be to move all requirements to report to NERC or Regional Entities out of the Requirements section of all Reliability Standards to elsewhere. This does not include reporting, communicating, or coordinating between reliability entities. The NERC/Region reporting requirements could be consolidated in another document and referenced in the Supporting References section of the Reliability Standards. The deadlines for reporting should be changed to realistic timeframes that do not interfere with operating the BES or responding to incidents yet still allow NERC and the Regions to accomplish their missions.</p>
AEP	<p>Sabotage is a term of intent that is often determined after the fact by the registered entity and/or law enforcement officials. In fact, it is often difficult to determine in real-time the intent of a suspicious event. We would suggest that suspicious events become reportable at the point that the event is determined to have had sabotage intent. The entities should have a methodology to collect evidence, to have the evidence analyzed, and to report those events that are determined to have had the intent of sabotage.</p>
Duke Energy	<p>While we agree with the need for clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities. Also, requirements to report possible non-compliances should be eliminated. We strongly support voluntary self-reporting, but not mandatory self-reporting.</p>
NextEra Energy Resources, LLC	<p>The scope of the SAR should not include Generator Operators.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
Luminant Power	The SAR drafting team should include in the SAR scope a review of the NRC sabotage and event reporting requirements to ensure there are no overlapping or conflicting requirements between NERC, FERC, and the NRC. The SAR scope should include a review of the CIP Cyber Security Standards and coordination with the CIP SDT to ensure that cyber sabotage reporting definitions are in concert, and ensure that cyber sabotage reporting requirements are not duplicated in multiple standards.
Illinois Municipal Electric Agency	A one-stop reporting tool/site would facilitate efficient reporting and compliance; e.g., further development of the ES-ISAC/CIPIS to include all reportable categories and automatic notification of required parties. A single report form would be best.
AEP	The current reporting process necessitates multiple reports be sent to multiple parties, which is inefficient and may, inadvertently, result in alignment issues between the separate reports. We would recommend that a single report that combines NERC (CIPIS) and NERC ESISAC information be provided to NERC (CIPIS) that is systematically (programmatically) forwarded to all necessary entities. Further, updates to incidents would also go through NERC with the same electronic processing. Currently, we are not aware of a formal method to report incidents to the FBI, which should be also included in the distribution. The current reporting mechanism to the FBI JTTF is by telephone and the NERC platform described would provide more consistent reporting.
Kansas City Power & Light	Do not agree Load Serving Entities need to continue to be included for sabotage. According the NERC Functional Model, an LSE provides for estimating customer load and provides for the acquisition of transmission and energy to meet customer load demand. An LSE has no real impact on maintaining the reliability of electric network short of their planning function. Unfortunately, an LSE needs to be included for disturbance reporting to the DOE under certain conditions for loss of customer load. This may be a reason to maintain a separation of CIP-001 and EOP-004 so as not to unnecessarily include an LSE when it is not needed.
Electric Market Policy	Applicability should not apply to LSE unless they have physical assets. If they do not have such assets, they are unable to determine how many customers are out, how much load was lost or the duration of an outage. We continue to question the need for the LSE entity in reliability standards. End use customer load is either connected to transmission or distribution facilities. So, the applicable planner has to plan for that load when designing its facilities or the load will not have reliable service. To the extent that energy and capacity for that load is supplied by an entity other than the TO or DP, the TO or DP should have interconnection requirements that compel the supplier to provide any and all data necessary to meet the requirements of reliability standards.
Lands Energy Consulting	CIP-001-1 - Yes. In many cases, the staff of an LSE embedded in another entity's BA/TOP area is more likely to discover an act of sabotage directed toward a BA/TOP-owned facility that could affect the BES than the asset owner. This is because the LSE likely has more operating staff in the area. I have included a requirement in my clients'

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>Sabotage Identification and Reporting Procedures that the client treat acts of sabotage to a third party's system discovered by client employees as though the act was directed toward client facilities. EOP-004-1 - As mentioned before, I would eliminate the LSE from the applicability list and leave the responsibility for disturbance reporting and response to the TOP/BA. However, I would retain a responsibility for the LSEs to cooperate (when requested) with any disturbance investigation.</p>
<p>Calpine Corporation</p>	<p>The reporting requirements of EOP - 004 are needed for the RC, BA, LSE and the GOP that operates or controls generation in a system as defined by NERC. (System - A combination of generation, transmission, and distribution components). A disturbance is described as an unplanned event that produces and abnormal system condition, any perturbation to the electric system, and the unexpected change in ACE that is caused by the sudden failure of generation or interruption of load. The GOP operating/controlling generation within a system has the ability to analyze system conditions to determine if reporting is necessary. A NERC registered GOP that is a merchant generator within another company's system does not have the ability for a wide area view and cannot analyze system conditions beyond the interconnection point of the facility. Moreover, in most cases the reporting requirements outlined in the Interconnection Reliability Operating Limits and Preliminary Disturbance Report do not apply to the merchant generator that is not a generation only BA. The applicability of the standard does encompass the true merchant generation entities required to register as GOP. Similarly, the OE-417 table 1 reporting requirements generally do not apply to a true merchant generating entity that is required to register as a GOP.</p>
<p>Covanta</p>	<p>It would be a welcome enhancement to the end users to understand to communication link between all "appropriate parties" who shall be notified of potential or actual sabotage events.... which also needs to be defined.</p>
<p>Reliant Energy</p>	<p>EOOP-004-1 should exclude the generator operator from disturbance reporting except providing the system operator or reliability coordinator with appropriate unit operation information upon request. Acts of sabotage should be identified clearly and reported to the indicated authorities.</p>
<p>Texas Regional Entity</p>	<p>Add GO and TO to the list of applicability. The intent of CIP-001-1 when it was first written was to have the proper and most likely entities associated directly with operations to be the ones to begin the reporting process in the case of sabotage on the system. In the ERCOT Region and other regions in the US, the GOP may not be physically located at the site. The GOP is often removed from the minute-by-minute responsibilities of plant operations and, therefore, may be less able to react to physical sabotage at the location/plant/facility in a timely manner. The concern is that, in the case of an actual sabotage event, the failure to report to the appropriate authorities in a timely manner may jeopardize the reliability of the BPS. Therefore, the Generator Owner (GO) should be added to the list of applicability for CIP-001-1, because it is the GO that is more likely to be on location at the generation site and thus aware of sabotage when it first occurs. This would disallow for any possible communication gap and put responsibility on all of the appropriate entities to report such an event. Additionally, and for the same reasons as adding the GO, the Transmission Owner</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	(TO) should also be added to the list of applicability for reporting sabotage on its facilities.
Exelon	CIP-001, remove LSE's from the standard for the reasons identified in the FERC LSE order. Ad TO and DP. EOP-004, remove LSE's from the standard for the reasons identified in the FERC LSE order. Remove RRO's, they are not a user, owner, operator of the BES. Add DP or TO. Consider conditional applicability as in the UFLS standards, " the TO or DP who performs the functions specified in the standard..."
ERCOT ISO	The Regional Reliability Organization is not a registered Functional Entity in the NERC registry. The applicability must be revised to more appropriately assign the requirements to registered functional entities. Also, the industry needs to recognize that there are other resources than generation for which the operators need to be included. Perhaps a demand-side resource should have a resource operator. This particular SAR may not be the appropriate venue for this, but control of resources which can be used to mitigate sabotage events or disturbance events may need to be addressed.
AEP	We would recommend that the Load Serving Entity (LSE) be removed from both standards, and that the Generator Owner and Transmission Owner be added to the resulting standard.
NextEra Energy Resources, LLC	The scope of the proposed SAR should not include the Generator Operator.
PSEG Enterprise Group Inc Companies	<p>The PSEG Companies ask that the drafting team allow sufficient flexibility for sabotage recognition and reporting requirements such that nothing precludes utilizing a single corporate-wide program for both bulk electric system assets and other businesses. PSEG's Sabotage Recognition, Response and Reporting Program is directed to all business areas which are directed to follow the same internal protocol that also satisfies the NERC Standards requirements. For example, for gas assets, PSEG's gas distribution business follows the PSEG corporate-wide program for sabotage recognition and response. PSEG agrees that some modifications should be made to CIP-001 (ex. better define or give examples of sabotage) and EOP-004 to make them clearer? If they are merged, then Sabotage will not be in the title (or the primary focus) because several of the Disturbances that reporting is required for in EOP-004 have nothing to do with sabotage. EOP-004 has criteria listed in 4 places to determine when to send a report:</p> <ul style="list-style-type: none"> <li>o Criteria listed in EOP-004 Attachment 1</li> <li>o Criteria listed in EOP-004 Attachment 2</li> <li>o Criteria listed in top portion of Table 1-EOP-004</li> <li>o Criteria listed in bottom portion of Table 1-EOP-004</li> </ul> <p>Therefore, it would be much easier if there was one table of criteria for reference that addressed all of the reportable</p>



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	conditions and all of the applicable reports. If the 2 standards are merged as suggested in the SAR, any differences in the reporting obligation for actual or attempted sabotage and reporting of disturbances must be clear.
FirstEnergy	<p>2. As pointed out by the NERC Audit and Observation Team in the "Issues to be considered" for CIP-001, clarification is needed regarding contacting the FBI. Prior audits dwelled heavily on FBI notification. For example, our policy states that Corporate Security notifies the FBI. In recent events it appears that local law enforcement handles day to day activities. The notification process for contacting the FBI needs clarification along with specific instances in which to call them. Who should make the call to the FBI? It appears that a protocol needs to be developed to clarify what events require notifying the FBI. It could be as simple as after an incident a standard form is completed and forwarded to the FBI, letting them decide if follow up is needed.</p> <p>3. We suggest aligning all reporting requirements for consistency. The items requiring reporting and the timelines to report are very inconsistent between NERC and the DOE. NERC's timelines are also not consistent with their own Security Guideline for the Electricity Sector: Threat and Incident Reporting.</p>
MRO NERC Standards Review Subcommittee	<p>B. CIP-001-1 and EOP-004-1 should be combined into one EOP Standard.</p> <p>C. Within EOP-004-1 there is industry confusion on what form to submit in the event of an event. There should only be one form for the new combination Standard eliminating the need for reporting form attachments. It should be the DOE Form, OE-417. Although it is beyond the scope of this SAR, it would greatly benefit industry if there was a central location on the NERC website containing ALL reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable the System Operators to efficiently locate the most current version of the appropriate form in order to report events.</p>
Lands Energy Consulting	One final comment on CIP-001-1. My clients received universally rude treatment from the FBI field offices when they attempted to establish the contacts required by the Standard. If the FBI doesn't see value in establishing these contacts, remove the requirement from the Standard. Making sure the LSE knows the FBI field office phone number is probably all the Standard should require.
Colmac Clarion	Need single report for Sabotage so whatever is required results in notification of all parties (State Emergency Management, Homeland Security, FBI, Grid Reliability Chain of Command). Any and all of these can 'expand' knowledge later but all seem to require 'instant' notification.
Cowlitz County PUD	Local Law enforcement agencies often are not friendly to Federal involvement with smaller problems they consider their "turf." Need to make sure the small stuff stays with them, however have a system of internal reporting that will catch coordinated sabotage efforts (multiple attacks on DPs and small BAs) at the RC or RE level who then can report to the Federal agencies. Currently EOP-004-1 requires small entities to report a "disturbance" if half of their firm customer

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	load is lost. For some entities, this can be one small substation going down due to a bird. The "50% of total demand" requirement should be removed or improved to better define a true BPS disturbance.
ERCOT ISO	Due to the fact that both the CIP-001-1 and EOP-004-1 have similar reporting standards, initially combining the two sounds like a correct analysis. However, after further consideration and due to the critical nature of its intended function involving Security aspects, the CIP-001 should be intensely evaluated to determine if its intended purpose meets the threshold or criteria to stand alone. The existing standards for CIP-001-1 Sabotage Reporting may help prevent future mitigation actions caused by sabotage events. EOP-004-1 Disturbance Reporting is administrative in nature, thus the jeopardy of the Bulk Electric System reliability is impacted only if analysis is not performed or if corrective follow-up actions are not implemented. Combining EOP-004 Standard requirements under the umbrella of the CIP -001 Standard would create a high profile Disturbance Reporting Standard. The industry would be better served if information defining sabotage was provided as well as a technical reference document on recognizing sabotage that would also clarify or state any personnel training requirements. All aspects of the intended functions must be reviewed before merging the two standards. At a minimum, we must consider modification that provides improved understanding of the reporting standards and implications as they are currently written.
MidAmerican Energy	Conflicting time frames exist from document updates. Reporting should be consolidated to one form and / or site to minimize conflicts, confusion, and errors. 1) Reporting requirements for the outage of 50,000 or more customers in EOP-004-1 requires a report to be made within one hour while the form OE-417 requires a report be made within six hours of the outage. The six hour reference on the updated OE-417 form is the correct reference. 2) Reporting for either CIP-001 or EOP-004 should center on the DOE Form OE-417. This would eliminate confusion and simplify reporting for system operators thereby directly enhancing reliability during system events. This would also eliminate much of the duplicate material and attachments in EOP-004. 3) Although it is beyond the scope of this SAR, the industry would benefit if there was a central location or link on the NERC website containing all reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable System Operators to more efficiently locate and report events.
Illinois Municipal Electric Agency	IMEA recommends the following considerations: Simplification of reportable events and the reporting process should be the overriding objective. NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting (Version 2.0) should be updated to support this standards development initiative. At some point in the process, it may help if examples are given of events actually reported that did not need to be reported.

## Standard Authorization Request Form

<b>Title of Proposed Standard:</b> Disturbance and Sabotage reporting (Project 2009-01)
<b>Request Date:</b> April 2, 2009
<b>Approved by SC for posting:</b> April 15, 2009
<b>Revision Date:</b> <del>July 22, 2009</del> August 13, 2009

<b>SAR Requester Information</b>	<b>SAR Type</b> <i>(Check a box for each one that applies.)</i>
Name: Patrick Brown	<input type="checkbox"/> New Standard
Primary Contact: Patrick Brown Manager, NERC and Regional Coordination PJM Interconnection	<input checked="" type="checkbox"/> Revision to existing Standard
Telephone: 610-666-4597	<input checked="" type="checkbox"/> Withdrawal of existing Standard
E-mail: brownp@pjm.com	<input type="checkbox"/> Urgent Action

<p><b>Purpose (Describe the proposed standard action: Nomination of a proposed standard, revision to a standard, or withdrawal of a standard and describe what the standard action will achieve.)</b></p> <p>This project will entail revision to existing standards CIP-001-1 – Sabotage Reporting and EOP-004-1 – Disturbance Reporting. The standards may be merged to eliminate redundancy and provide clarity on sabotage events. EOP-004 has some ‘fill-in-the-blank’ components to eliminate. The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.</p>
<p><b>Industry Need</b> (Provide a justification for the development or revision of the standard, including an assessment of the reliability and market interface impacts of implementing or not implementing the standard action.)</p> <p>The existing requirements need to be revised to be more specific – and there needs to be more clarity in what sabotage looks like.</p>
<p><b>Brief Description</b> (Provide a paragraph that describes the scope of this standard action.)</p> <p>CIP-001 may be merged with EOP-004 to eliminate redundancies. Acts of sabotage have to be reported to the DOE as part of EOP-004. Specific references to the DOE form need to be eliminated.</p> <p>EOP-004 has some ‘fill-in-the-blank’ components to eliminate.</p>

## Standards Authorization Request Form

---

The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information).

**Detailed Description** (Provide a description of the proposed project with sufficient details for the standard drafting team to execute the SAR.)

See "Issues to be Considered by Drafting Team" tables for each standard at the end of this SAR for more detailed information.

**Standards Authorization Request Form**

**Reliability Functions**

<b>The Standard will Apply to the Following Functions</b> <i>(Check box for each one that applies.)</i>		
<input checked="" type="checkbox"/>	Reliability Coordinator	Responsible for the real-time operating reliability of its Reliability Coordinator Area in coordination with its neighboring Reliability Coordinator's wide area view.
<input checked="" type="checkbox"/>	Balancing Authority	Integrates resource plans ahead of time, and maintains load-interchange-resource balance within a Balancing Authority Area and supports Interconnection frequency in real time.
<input type="checkbox"/>	Interchange Authority	Ensures communication of interchange transactions for reliability evaluation purposes and coordinates implementation of valid and balanced interchange schedules between Balancing Authority Areas.
<input type="checkbox"/>	Planning Coordinator	Assesses the longer-term reliability of its Planning Coordinator Area.
<input type="checkbox"/>	Resource Planner	Develops a >one year plan for the resource adequacy of its specific loads within a Planning Coordinator area.
<input type="checkbox"/>	Transmission Planner	Develops a >one year plan for the reliability of the interconnected Bulk Electric System within its portion of the Planning Coordinator area.
<input type="checkbox"/>	Transmission Service Provider	Administers the transmission tariff and provides transmission services under applicable transmission service agreements (e.g., the pro forma tariff).
<input checked="" type="checkbox"/> <input type="checkbox"/>	Transmission Owner	Owns and maintains transmission facilities.
<input checked="" type="checkbox"/>	Transmission Operator	Ensures the real-time operating reliability of the transmission assets within a Transmission Operator Area.
<input checked="" type="checkbox"/>	Distribution Provider	Delivers electrical energy to the End-use customer.
<input checked="" type="checkbox"/> <input type="checkbox"/>	Generator Owner	Owns and maintains generation facilities.
<input checked="" type="checkbox"/>	Generator Operator	Operates generation unit(s) to provide real and reactive power.
<input type="checkbox"/>	Purchasing-Selling Entity	Purchases or sells energy, capacity, and necessary reliability-related services as required.
<input type="checkbox"/>	Market Operator	Interface point for reliability functions with commercial functions.
<input checked="" type="checkbox"/>	Load-Serving Entity	Secures energy and transmission service (and reliability-related services) to serve the End-use Customer.

## Standards Authorization Request Form

### ***Reliability and Market Interface Principles***

<b>Applicable Reliability Principles</b> <i>(Check box for all that apply.)</i>	
<input checked="" type="checkbox"/>	1. Interconnected bulk power systems shall be planned and operated in a coordinated manner to perform reliably under normal and abnormal conditions as defined in the NERC Standards.
<input type="checkbox"/>	2. The frequency and voltage of interconnected bulk power systems shall be controlled within defined limits through the balancing of real and reactive power supply and demand.
<input checked="" type="checkbox"/>	3. Information necessary for the planning and operation of interconnected bulk power systems shall be made available to those entities responsible for planning and operating the systems reliably.
<input checked="" type="checkbox"/>	4. Plans for emergency operation and system restoration of interconnected bulk power systems shall be developed, coordinated, maintained and implemented.
<input type="checkbox"/>	5. Facilities for communication, monitoring and control shall be provided, used and maintained for the reliability of interconnected bulk power systems.
<input type="checkbox"/>	6. Personnel responsible for planning and operating interconnected bulk power systems shall be trained, qualified, and have the responsibility and authority to implement actions.
<input type="checkbox"/>	7. The security of the interconnected bulk power systems shall be assessed, monitored and maintained on a wide area basis.
<input checked="" type="checkbox"/>	8. Bulk power systems shall be protected from malicious physical or cyber attacks.
<b>Does the proposed Standard comply with all of the following Market Interface Principles?</b> <i>(Select 'yes' or 'no' from the drop-down box.)</i>	
1. A reliability standard shall not give any market participant an unfair competitive advantage. Yes	
2. A reliability standard shall neither mandate nor prohibit any specific market structure. Yes	
3. A reliability standard shall not preclude market solutions to achieving compliance with that standard. Yes	
4. A reliability standard shall not require the public disclosure of commercially sensitive information. All market participants shall have equal opportunity to access commercially non-sensitive information that is required for compliance with reliability standards. Yes	

## Standards Authorization Request Form

---

### *Related Standards*

Standard No.	Explanation
COM-003-1	Operations Communications Protocols – this standard may include some requirements that require coordination with the requirements addressed in this project. (still in standard development stage)
IRO-014-1	R1.1.1, footnote 1 lists sabotage. The standard drafting team should consider this reference and the impact of their work on this specific item.
TOP-005-1.1	Attachment 1, item 2.9 is “Multi-site sabotage”. The standard drafting team should consider this reference and the impact of their work on this specific item.

### *Related SARs*

SAR ID	Explanation

### *Regional Variances*

Region	Explanation
ERCOT	
FRCC	
MRO	
NPCC	
SERC	
RFC	
SPP	
WECC	

<b>Issues to be Considered by Drafting Team</b> <b>Project 2009-01 — Disturbance and Sabotage Reporting</b>	
Standard #	Title
CIP-001-0	Sabotage Reporting
<b>Issues</b>	<p>FERC Order 693</p> <p>Disposition: Approved with modifications</p> <ul style="list-style-type: none"> <li>• Consider the need for wider application of the standard. Consider whether separate, less burdensome requirements for smaller entities may be appropriate.</li> <li>• Define “sabotage” and provide guidance on triggering events that would cause an entity to report an event.</li> <li>• In the interim, provide advice to entities about the reporting of particular circumstances as they arise.</li> <li>• Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</li> <li>• Incorporate a periodic review or updating of the sabotage reporting procedures and for their periodic testing. Consider a staggered schedule of annual testing and formal review every two to three years.</li> <li>• Include a requirement to report a sabotage event to the proper government authorities. Develop the language to specifically implement this directive.</li> <li>• Explore ways to reduce redundant reporting, including central coordination of sabotage reports and a uniform reporting format.</li> </ul> <p>V0 Industry Comments</p> <ul style="list-style-type: none"> <li>• Object to multi-site requirement</li> <li>• Definition of sabotage required</li> </ul> <p>VRF comments</p> <ul style="list-style-type: none"> <li>• Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures.</li> </ul> <p>Other</p> <ul style="list-style-type: none"> <li>• Modify standard to conform to the latest version of NERC’s Reliability Standards Development Procedure, the NERC Standard Drafting Team Guidelines, and the ERO Rules of Procedure.</li> </ul> <p>NERC Audit and Observation Team</p> <ul style="list-style-type: none"> <li>• Applicability — How does this standard pertain to Load Serving Entities, LSE’s.</li> <li>• Registered Entities have sabotage reporting processes and procedures in place but not all personnel has been trained.</li> <li>• Question: How do you “and make the operator aware”</li> <li>• R4 — “What is meant by: “establish contact with the FBI”. Is a phone number adequate? Many entities which call the FBI are referred back to the local authority. The AOT noted that on the FBI website it states to</li> </ul>



**Standards Authorization Request Form**

	<p>contact the local authorities. Is this a question for Homeland Security to deal with for us?"</p> <ul style="list-style-type: none"> <li>R4 — Establish communications contacts, as applicable with local FBI and RAMP officials. Some entities are very remote and the sheriff is the only local authority does the FBI still need to be contacted?</li> </ul> <p>FERC's December 20, 2007 and April 4, 2008 Orders in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000</p> <ul style="list-style-type: none"> <li>In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none owned physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be applied. Each drafting team responsible for reliability standards applicable to LSEs is to review and change as necessary, requirements in the applicable reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:             <ul style="list-style-type: none"> <li>FERC's December 20, 2007 Order (<a href="http://www.nerc.com/files/LSE_decision_order.pdf">http://www.nerc.com/files/LSE_decision_order.pdf</a> )</li> <li>NERC's March 4, 2008 (<a href="http://www.nerc.com/files/FinalFiledLSE3408.pdf">http://www.nerc.com/files/FinalFiledLSE3408.pdf</a> ),</li> <li>FERC's April 4, 2008 Order (<a href="http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf">http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf</a> ) and</li> <li>NERC's July 31, 2008 (<a href="http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf">http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf</a> ) compliance filings to FERC on this subject.</li> </ul> </li> </ul>
--	--

<b>Issues to be Considered by Drafting Team</b>	
<b>Project 2009-01 — Disturbance and Sabotage Reporting</b>	
<b>Standard #</b>	<b>Title</b>
<b>EOP-004-1</b>	Disturbance Reporting
<b>Issues</b>	<p>FERC Order 693</p> <p>Disposition: Approved with modification</p> <ul style="list-style-type: none"> <li>Include any requirements for users, owners, and operators of the bulk power system to provide data that will assist NERC in the investigation of a blackout or disturbance.</li> <li>Change NERC's Rules of Procedure to assure the Commission receives these reports in the same frame as the DOE.</li> <li>Consider APPA's concern about generator operators and LSEs analyzing performance of their equipment and provide data and information on the equipment to assist others with analysis.</li> <li>Consider all comments offered in a future modification of the reliability standard.</li> </ul>

	<p>Fill-in-the-Blank Team Comments</p> <ul style="list-style-type: none"><li>• Consider changes to R1 and R3.4 to standardize the disturbance reporting requirements (requirements for disturbance reporting need to be added to this standard)</li><li>• Regions currently have procedures, but not in the form of a standard. The drafting team will need to review regional requirements to determine reporting requirements for the North American standard.</li></ul> <p>V0 Industry Comments</p> <ul style="list-style-type: none"><li>• R3 – too many reports, narrow requirement to RC</li><li>• How does this apply to generator operator?</li></ul> <p>Other</p> <ul style="list-style-type: none"><li>• Modify standard to conform to the latest version of NERC's Reliability Standards Development Procedure, the NERC Standard Drafting Team Guidelines, and the ERO Rules of Procedure.</li></ul> <p>NERC Audit and Observation Team</p> <ul style="list-style-type: none"><li>• R3.1 — Can there be a violation without an event?</li></ul> <p>Event Analysis Team</p> <ul style="list-style-type: none"><li>• Reliability Issue: Coordination and follow up on lessons learned from event analyses Consider adding to EOP-004 – Disturbance Reporting. Proposed requirement: Regional Entities (REs) shall work together with Reliability Coordinators, Transmission Owners, and Generation Owners to develop an Event Analysis Process to prevent similar events from happening and follow up with the recommendations. This process shall be defined within the appropriate NERC Standard.</li></ul> <p>FERC's December 20, 2007 and April 4, 2008 Orders in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000</p> <ul style="list-style-type: none"><li>• In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none owned physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be applied. Each drafting team responsible for reliability standards applicable to LSEs is to review and change as necessary, requirements in the applicable reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:<ul style="list-style-type: none"><li>• FERC's December 20, 2007 Order (<a href="http://www.nerc.com/files/LSE_decision_order.pdf">http://www.nerc.com/files/LSE_decision_order.pdf</a> )</li><li>• NERC's March 4, 2008 (<a href="http://www.nerc.com/files/FinalFiledLSE3408.pdf">http://www.nerc.com/files/FinalFiledLSE3408.pdf</a> ),</li><li>• FERC's April 4, 2008 Order (<a href="http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf">http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf</a> ) and</li><li>• NERC's July 31, 2008 (<a href="http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf">http://www.nerc.com/files/FinalFiled-CompFiling-LSE-07312008.pdf</a> ) compliance filings to FERC on this subject.</li></ul></li></ul>
--	--

Comments received on Project 2009-01 — Disturbance and Sabotage Reporting

The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) received many suggestions for improvements to the standards during the SAR comment period. These comments do not indicate any revisions to the SAR, but the DSRSDT thought that these comments merited further consideration during the standard drafting phase of the project. The comments below are being compiled for use by the Standard Development Team.

Organization	Comment
Electric Market Policy	<p>Comments: Agree with the statement that sabotage is hard to determine in real time by operations staffs. The determination of sabotage should be left up to law enforcement. They have the knowledge and peer contacts needed to adequately determine whether physical or cyber intrusions are merely malicious acts or coordinated efforts (sabotage). The operators should only be required to report physical and cyber intrusions to law enforcement. All other reporting requirements should apply to law enforcement once a determination of sabotage has been made. If the recommendations above are not to be accepted, then we have the following comments:</p> <p>CIP-001-1</p> <ol style="list-style-type: none"> <li>1) R1 states entities shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection. The SAR notes that the industry objects to the multi-site requirement, most likely because the term is ambiguous. If this term remains in the standard, it needs to be clearly defined and responsibilities for obtaining (how do you get this information and from whom?) and distributing need to be included.</li> <li>2) R1 audits have shown confusion over the requirement to make operating personnel aware of sabotage events. The term operating personnel needs to be defined. Are they the individuals responsible for operating the facility, coordinating with other entities (i.e., RC, BA, TOP, GOP, and LSE)? It has been suggested that notification is required to all personnel at a facility. Keep in mind the purpose of the standard is to ensure sabotage events are properly reported, not to address emergency response.</li> <li>3) R1 The SAR (NERC Audit and Observation Team) notes that Registered Entities have processes and procedures in place, but not all personnel have been trained. There is no specific training requirement in the standard.</li> <li>4) R2 &amp; R3 I agree with the SAR that sabotage needs to be defined and these requirements should be more specific with respect to the information to be communicated. It seems to me that the standard should mirror the criteria contained in DOE OE-417. The emphasis should be placed on ensuring that the same information communicated to DOE is shared with the appropriate parties in the Interconnection.</li> <li>5) R4 I agree with the SAR (NERC Audit and Observation Team) comments regarding the intention of this requirement. There is no language that directs contact with FBI or RCMP although that is what is implied by the Purpose statement.</li> </ol>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>6) VRF Comments I'm not sure what is intended by the statement Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures? The purpose of the standard is that of communication. No operational decisions or actions are directed by this standard, nor does it require entities to address operational aspects resulting from sabotage.</p> <p>7) The potential exists for overlapping sabotage reporting requirements at nuclear power plants due to multiple regulators (Nuclear Regulatory Commission (NRC) 10 CFR 73 and Federal Energy Regulatory Commission (FERC) NUC-001-1). Some entities may have revised existing NRC driven procedures to accommodate reporting requirements of both regulators. Because of the restrictions placed on NRC driven documents (i.e., procedures are classified as safeguards information), it can be difficult to demonstrate compliance to NERC and/or FERC without ensuring that the individuals are qualified for receipt of such information per 10 CFR 73. Additionally, multiple procedures may have the unintended consequence of delaying appropriate communication. EOP-004-1 Consider removing Attachment 2 as the information is duplicated in DOE Form OE-417. A simple reference to the form should suffice.</p>
Lands Energy Consulting	<p>I have worked with 5 Northwest public utilities on developing procedures related to CIP-001-1 and EOP-004-1. All 5 utilities operate electric systems in fairly remote locations and are embedded in a larger utility's Balancing Authority/Transmission Operator area.</p> <p>A. CIP-001-1 - Developing procedures to unambiguously identify acts of sabotage has been particularly challenging for these systems. In general, it's hard for them to determine whether the most prevalent forms of malicious and intentional system damage that they incur - copper theft and gun shot insulators/equipment - should qualify as acts of sabotage. Although none of the systems consider copper theft to be acts of sabotage, two of the systems consider gun shot insulators/equipment to be acts of sabotage. The other systems look for intent to disrupt electric system operations as a key component of their sabotage identification procedures. Additional guidance from NERC in the form of CIP-001-1 modifications or a companion guidelines document on sabotage identification would provide much needed guidance for these procedures.</p> <p>B. EOP-004-1 - This standard was clearly drafted with the larger electric systems in mind. I have one client that serves 3300 commercial/residential customers from 4-115/13 kV substation transformers and one large industrial customer (80% of its energy load) from a 230/13 kV substation. 75% of the client's load is served from three substations attached to a long, 115 kV transmission line operated by the Bonneville Power Administration. Whenever the line relays open on a permanent fault (which happens 2-3 times per year), the client loses over 50% of its customers (but no more than 10-15 MW during winter peak), thereby necessitating the preparation of a Disturbance Report. To allow utilities to concentrate on operating their systems, without fear of violating EOP-004-1 for failure to report trivial outages, I would remove LSEs from the obligation to report disturbances - leave the reporting to the BA/TOP for large outages in their footprint.</p>
Calpine Corporation	<p>Communication of facility status or emergencies between merchant generators registered as GOP and the RC, BA, GOP, or LSE in which the facility resides should be coordinated for EOP -004 reporting. The reporting to NERC/DOE should</p>

**Consideration of Comments on Project 2009-01 – SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	come from the RC, BA, GOP, or LSE.
Covanta	<p>Yes - the key to Sabotage reporting requirements is identifying what the 'definition' is of an actual or potential 'Sabotage' event. Like any other standard, if FERC/NERC leave it up to 2000+ entities to establish their own definitions of 'Sabotage', you may likely get 2000+ answers. That is not a controlled and coordinated approach. I offer the following definition, "Sabotage - Deliberate or malicious destruction of property, obstruction of normal operations, or injury to personnel by outside agents." Examples of sabotage events could include, but are not limited to, suspicious packages left near site electrical generating or electrical transmission assets, identified destruction of generating assets, telephone/e mail received threats to destroy or interrupt electrical generating efforts, etc." These have passed multiple NERC regional audits and reviews to date.</p>
Northeast Power Coordinating Council	<p>The SAR needs to be more specific in defining its objectives.</p> <p>CIP-001 Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <ol style="list-style-type: none"> <li>1. Develop clear definitions for the terms “operating personnel” and “sabotage events.” The definition of “operating personnel,” should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term “sabotage event” needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</li> <li>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such “sabotage events,” e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term “aware” in the standard. “Aware” can be interpreted in accordance with its largely passive, dictionary-based meaning, where being “aware” simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of “aware” could refer to more active wording, involving more than mere awareness, e.g., “alert and quick to respond,” pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</li> </ol> <p>EOP-004 - The SDT needs to work on the following areas.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states: Introduction “The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance - The sense of Attachment 1 is internally inconsistent between the introduction (“occurs”) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase “or could have resulted in” a potential system disturbance. This inconsistency should be clarified.</p>
FirstEnergy	<p>We agree with the scope but would also like to see the following considered:</p> <ol style="list-style-type: none"> <li>1. References to the DOE reporting process in EOP-004 need to be revised. They currently refer to the old EIA form.</li> <li>2. Besides "sabotage", it may be helpful to clearly define "vandalism". It is vaguely written in the standards. Also, the process of "public appeals" for the DOE reportable requirements needs to be more clearly defined.</li> <li>3. Consolidate documents covering reporting requirements. There are currently several documents that require reporting (EOP-004, CIP-001, DOE oe-417, and NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting). NERC also has the "Bulk Power System Disturbance Classification Scale" that does not completely align with all the reporting requirements. Therefore we recommend keeping this as simple as possible by combining all the reporting requirements into one standard. It would be beneficial to not require operators to have to go to 4 different documents to determine what to report on.</li> </ol>
MRO NERC Standards Review Subcommittee	<p>The MRO NSRS would like to keep the references to the DOE reporting form.</p>
Cowlitz County PUD	<p>Added to the scope:</p> <p>For EOP-004 add a provision for a reporting flow rather than everything going to the RE and NERC. That is something going like the DP and TOP reports to the BA, the BA to the RE, and the RE to NERC. This would allow for multiple related reports to be combined into a single coherent report as the reporting goes up the chain.</p> <p>For CIP-001 consider reporting flow as above with local law enforcement notification. Let an upper entity in the reporting chain decide when to contact Federal Agencies such as the BA or the RC.</p>
Reliant Energy	<p>I think Generator operators should be excluded except to provide requested information from the System Operator or Reliability coordinator.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
ERCOT ISO	<p>The scope should be modified to provide for a different treatment of reporting requirements that are administrative in nature, or that are after-the-fact (thus cannot impact reliability unless analysis and follow-up is not performed; even then, the impact would be at some future time). Reporting requirements which are of the nature to assist in identification of system concerns or which serve to prevent or mitigate on-going system problems (including, but not limited to, actual or attempted sabotage activity) should remain in standards, but should be separate and apart from the administrative reporting.</p>
Consolidated Edison Co. of New York, Inc.	<p>GENERAL CECONY and ORU support the general objectives of the SAR to merge existing standards CIP-001-1 Sabotage Reporting and EOP-004-1 Disturbance Reporting to improve clarity and remove redundancy.</p> <p>However, the SAR needs to be more specific in defining its objectives.</p> <p>CIP-001 Requirement R1 currently states:</p> <p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.</p> <p>The SDT needs to include the following objectives:</p> <ol style="list-style-type: none"> <li>1. Develop clear definitions for the terms operating personnel and sabotage events. The definition of operating personnel, should be clarified and limited to staff at BES facilities. Operating personnel should report only those events which meet a clear, recognizable threshold as reportable potential sabotage events. There should be a consistent continent-wide list of examples or typical reportable and non-reportable events to help guide operating personnel. The term sabotage event needs to be defined. Clarification is required regarding when the determination of a sabotage event is made, e.g., upon first observation (requiring operating personnel be educated in discerning sabotage events), or upon later investigation by trained security personnel and law enforcement individuals. The terms potential or suspected sabotage event for reporting purposes should be clarified or defined.</li> <li>2. Define the obligations of Registered Entity operating personnel - who are required to be aware of such sabotage events, e.g., who, what, where, when, why and how, and what they are to do in response to this awareness. The SDT should clarify the use of the term aware in the standard. Aware can be interpreted in accordance with its largely passive, dictionary-based meaning, where being aware simply means knowing about something, such as a sabotage event. Alternatively, the Reliability Standard meaning of aware could refer to more active wording, involving more than mere awareness, e.g., alert and quick to respond, pointing to and requiring a specific affirmative response, i.e., reporting to the appropriate systems, governmental agencies, and regulatory bodies.</li> </ol> <p>EOP-004 - The SDT needs to work on the following areas.</p> <ol style="list-style-type: none"> <li>1. NERC reporting needs to be clarified. For example, Attachment 1 paragraph 6c states:</li> </ol>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	<p>Introduction The entity on whose system a reportable disturbance occurs shall notify NERC ... 6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in: ?c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance.</p> <p>The sense of Attachment 1 is internally inconsistent between the introduction (occurs) and the required actions in 6c (could have resulted in a system disturbance). The initial intent appears to be only to report actual system disturbances. Yet, paragraph 6c adds the phrase or could have resulted in a potential system disturbance. This inconsistency should be clarified.</p>
Georgia System Operations Corp.	<p>The scope of the SAR should be to move all requirements to report to NERC or Regional Entities out of the Requirements section of all Reliability Standards to elsewhere. This does not include reporting, communicating, or coordinating between reliability entities. The NERC/Region reporting requirements could be consolidated in another document and referenced in the Supporting References section of the Reliability Standards. The deadlines for reporting should be changed to realistic timeframes that do not interfere with operating the BES or responding to incidents yet still allow NERC and the Regions to accomplish their missions.</p>
AEP	<p>Sabotage is a term of intent that is often determined after the fact by the registered entity and/or law enforcement officials. In fact, it is often difficult to determine in real-time the intent of a suspicious event. We would suggest that suspicious events become reportable at the point that the event is determined to have had sabotage intent. The entities should have a methodology to collect evidence, to have the evidence analyzed, and to report those events that are determined to have had the intent of sabotage.</p>
Duke Energy	<p>While we agree with the need for clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities. Also, requirements to report possible non-compliances should be eliminated. We strongly support voluntary self-reporting, but not mandatory self-reporting.</p>
NextEra Energy Resources, LLC	<p>The scope of the SAR should not include Generator Operators.</p>
Luminant Power	<p>The SAR drafting team should include in the SAR scope a review of the NRC sabotage and event reporting requirements to ensure there are no overlapping or conflicting requirements between NERC, FERC, and the NRC. The SAR scope</p>



**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	should include a review of the CIP Cyber Security Standards and coordination with the CIP SDT to ensure that cyber sabotage reporting definitions are in concert, and ensure that cyber sabotage reporting requirements are not duplicated in multiple standards.
Illinois Municipal Electric Agency	A one-stop reporting tool/site would facilitate efficient reporting and compliance; e.g., further development of the ES-ISAC/CIPIS to include all reportable categories and automatic notification of required parties. A single report form would be best.
AEP	The current reporting process necessitates multiple reports be sent to multiple parties, which is inefficient and may, inadvertently, result in alignment issues between the separate reports. We would recommend that a single report that combines NERC (CIPIS) and NERC ESISAC information be provided to NERC (CIPIS) that is systematically (programmatically) forwarded to all necessary entities. Further, updates to incidents would also go through NERC with the same electronic processing. Currently, we are not aware of a formal method to report incidents to the FBI, which should be also included in the distribution. The current reporting mechanism to the FBI JTTF is by telephone and the NERC platform described would provide more consistent reporting.
Kansas City Power & Light	Do not agree Load Serving Entities need to continue to be included for sabotage. According the NERC Functional Model, an LSE provides for estimating customer load and provides for the acquisition of transmission and energy to meet customer load demand. An LSE has no real impact on maintaining the reliability of electric network short of their planning function. Unfortunately, an LSE needs to be included for disturbance reporting to the DOE under certain conditions for loss of customer load. This may be a reason to maintain a separation of CIP-001 and EOP-004 so as not to unnecessarily include an LSE when it is not needed.
Electric Market Policy	Applicability should not apply to LSE unless they have physical assets. If they do not have such assets, they are unable to determine how many customers are out, how much load was lost or the duration of an outage. We continue to question the need for the LSE entity in reliability standards. End use customer load is either connected to transmission or distribution facilities. So, the applicable planner has to plan for that load when designing its facilities or the load will not have reliable service. To the extent that energy and capacity for that load is supplied by an entity other than the TO or DP, the TO or DP should have interconnection requirements that compel the supplier to provide any and all data necessary to meet the requirements of reliability standards.
Lands Energy Consulting	CIP-001-1 - Yes. In many cases, the staff of an LSE embedded in another entity's BA/TOP area is more likely to discover an act of sabotage directed toward a BA/TOP-owned facility that could affect the BES than the asset owner. This is because the LSE likely has more operating staff in the area. I have included a requirement in my clients' Sabotage Identification and Reporting Procedures that the client treat acts of sabotage to a third party's system discovered by client employees as though the act was directed toward client facilities. EOP-004-1 - As mentioned before, I would eliminate the

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	LSE from the applicability list and leave the responsibility for disturbance reporting and response to the TOP/BA. However, I would retain a responsibility for the LSEs to cooperate (when requested) with any disturbance investigation.
Calpine Corporation	The reporting requirements of EOP - 004 are needed for the RC, BA, LSE and the GOP that operates or controls generation in a system as defined by NERC. (System - A combination of generation, transmission, and distribution components). A disturbance is described as an unplanned event that produces and abnormal system condition, any perturbation to the electric system, and the unexpected change in ACE that is caused by the sudden failure of generation or interruption of load. The GOP operating/controlling generation within a system has the ability to analyze system conditions to determine if reporting is necessary. A NERC registered GOP that is a merchant generator within another company's system does not have the ability for a wide area view and cannot analyze system conditions beyond the interconnection point of the facility. Moreover, in most cases the reporting requirements outlined in the Interconnection Reliability Operating Limits and Preliminary Disturbance Report do not apply to the merchant generator that is not a generation only BA. The applicability of the standard does encompass the true merchant generation entities required to register as GOP. Similarly, the OE-417 table 1 reporting requirements generally do not apply to a true merchant generating entity that is required to register as a GOP.
Covanta	It would be a welcome enhancement to the end users to understand to communication link between all "appropriate parties" who shall be notified of potential or actual sabotage events.... which also needs to be defined.
Reliant Energy	EOOP-004-1 should exclude the generator operator from disturbance reporting except providing the system operator or reliability coordinator with appropriate unit operation information upon request. Acts of sabotage should be identified clearly and reported to the indicated authorities.
Texas Regional Entity	Add GO and TO to the list of applicability. The intent of CIP-001-1 when it was first written was to have the proper and most likely entities associated directly with operations to be the ones to begin the reporting process in the case of sabotage on the system. In the ERCOT Region and other regions in the US, the GOP may not be physically located at the site. The GOP is often removed from the minute-by-minute responsibilities of plant operations and, therefore, may be less able to react to physical sabotage at the location/plant/facility in a timely manner. The concern is that, in the case of an actual sabotage event, the failure to report to the appropriate authorities in a timely manner may jeopardize the reliability of the BPS. Therefore, the Generator Owner (GO) should be added to the list of applicability for CIP-001-1, because it is the GO that is more likely to be on location at the generation site and thus aware of sabotage when it first occurs. This would disallow for any possible communication gap and put responsibility on all of the appropriate entities to report such an event. Additionally, and for the same reasons as adding the GO, the Transmission Owner (TO) should also be added to the list of applicability for reporting sabotage on its facilities.
Exelon	CIP-001, remove LSE's from the standard for the reasons identified in the FERC LSE order. Ad TO and DP. EOP-004,

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
	remove LSE's from the standard for the reasons identified in the FERC LSE order. Remove RRO's, they are not a user, owner, operator of the BES. Add DP or TO. Consider conditional applicability as in the UFLS standards, " the TO or DP who performs the functions specified in the standard..."
ERCOT ISO	The Regional Reliability Organization is not a registered Functional Entity in the NERC registry. The applicability must be revised to more appropriately assign the requirements to registered functional entities. Also, the industry needs to recognize that there are other resources than generation for which the operators need to be included. Perhaps a demand-side resource should have a resource operator. This particular SAR may not be the appropriate venue for this, but control of resources which can be used to mitigate sabotage events or disturbance events may need to be addressed.
AEP	We would recommend that the Load Serving Entity (LSE) be removed from both standards, and that the Generator Owner and Transmission Owner be added to the resulting standard.
NextEra Energy Resources, LLC	The scope of the proposed SAR should not include the Generator Operator.
PSEG Enterprise Group Inc Companies	<p>The PSEG Companies ask that the drafting team allow sufficient flexibility for sabotage recognition and reporting requirements such that nothing precludes utilizing a single corporate-wide program for both bulk electric system assets and other businesses. PSEG's Sabotage Recognition, Response and Reporting Program is directed to all business areas which are directed to follow the same internal protocol that also satisfies the NERC Standards requirements. For example, for gas assets, PSEG's gas distribution business follows the PSEG corporate-wide program for sabotage recognition and response. PSEG agrees that some modifications should be made to CIP-001 (ex. better define or give examples of sabotage) and EOP-004 to make them clearer? If they are merged, then Sabotage will not be in the title (or the primary focus) because several of the Disturbances that reporting is required for in EOP-004 have nothing to do with sabotage. EOP-004 has criteria listed in 4 places to determine when to send a report:</p> <ul style="list-style-type: none"> <li>o Criteria listed in EOP-004 Attachment 1</li> <li>o Criteria listed in EOP-004 Attachment 2</li> <li>o Criteria listed in top portion of Table 1-EOP-004</li> <li>o Criteria listed in bottom portion of Table 1-EOP-004</li> </ul> <p>Therefore, it would be much easier if there was one table of criteria for reference that addressed all of the reportable conditions and all of the applicable reports. If the 2 standards are merged as suggested in the SAR, any differences in the reporting obligation for actual or attempted sabotage and reporting of disturbances must be clear.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
FirstEnergy	<p>2. As pointed out by the NERC Audit and Observation Team in the "Issues to be considered" for CIP-001, clarification is needed regarding contacting the FBI. Prior audits dwelled heavily on FBI notification. For example, our policy states that Corporate Security notifies the FBI. In recent events it appears that local law enforcement handles day to day activities. The notification process for contacting the FBI needs clarification along with specific instances in which to call them. Who should make the call to the FBI? It appears that a protocol needs to be developed to clarify what events require notifying the FBI. It could be as simple as after an incident a standard form is completed and forwarded to the FBI, letting them decide if follow up is needed.</p> <p>3. We suggest aligning all reporting requirements for consistency. The items requiring reporting and the timelines to report are very inconsistent between NERC and the DOE. NERC's timelines are also not consistent with their own Security Guideline for the Electricity Sector: Threat and Incident Reporting.</p>
MRO NERC Standards Review Subcommittee	<p>B. CIP-001-1 and EOP-004-1 should be combined into one EOP Standard.</p> <p>C. Within EOP-004-1 there is industry confusion on what form to submit in the event of an event. There should only be one form for the new combination Standard eliminating the need for reporting form attachments. It should be the DOE Form, OE-417. Although it is beyond the scope of this SAR, it would greatly benefit industry if there was a central location on the NERC website containing ALL reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable the System Operators to efficiently locate the most current version of the appropriate form in order to report events.</p>
Lands Energy Consulting	<p>One final comment on CIP-001-1. My clients received universally rude treatment from the FBI field offices when they attempted to establish the contacts required by the Standard. If the FBI doesn't see value in establishing these contacts, remove the requirement from the Standard. Making sure the LSE knows the FBI field office phone number is probably all the Standard should require.</p>
Colmac Clarion	<p>Need single report for Sabotage so whatever is required results in notification of all parties (State Emergency Management, Homeland Security, FBI, Grid Reliability Chain of Command). Any and all of these can 'expand' knowledge later but all seem to require 'instant' notification.</p>
Cowlitz County PUD	<p>Local Law enforcement agencies often are not friendly to Federal involvement with smaller problems they consider their "turf." Need to make sure the small stuff stays with them, however have a system of internal reporting that will catch coordinated sabotage efforts (multiple attacks on DPs and small BAs) at the RC or RE level who then can report to the Federal agencies. Currently EOP-004-1 requires small entities to report a "disturbance" if half of their firm customer load is lost. For some entities, this can be one small substation going down due to a bird. The "50% of total demand" requirement should be removed or improved to better define a true BPS disturbance.</p>

**Consideration of Comments on Project 2009-01 — SAR for Disturbance and Sabotage Reporting**

Organization	Comment
ERCOT ISO	<p>Due to the fact that both the CIP-001-1 and EOP-004-1 have similar reporting standards, initially combining the two sounds like a correct analysis. However, after further consideration and due to the critical nature of its intended function involving Security aspects, the CIP-001 should be intensely evaluated to determine if its intended purpose meets the threshold or criteria to stand alone. The existing standards for CIP-001-1 Sabotage Reporting may help prevent future mitigation actions caused by sabotage events. EOP-004-1 Disturbance Reporting is administrative in nature, thus the jeopardy of the Bulk Electric System reliability is impacted only if analysis is not performed or if corrective follow-up actions are not implemented. Combining EOP-004 Standard requirements under the umbrella of the CIP -001 Standard would create a high profile Disturbance Reporting Standard. The industry would be better served if information defining sabotage was provided as well as a technical reference document on recognizing sabotage that would also clarify or state any personnel training requirements. All aspects of the intended functions must be reviewed before merging the two standards. At a minimum, we must consider modification that provides improved understanding of the reporting standards and implications as they are currently written.</p>
MidAmerican Energy	<p>Conflicting time frames exist from document updates. Reporting should be consolidated to one form and / or site to minimize conflicts, confusion, and errors. 1) Reporting requirements for the outage of 50,000 or more customers in EOP-004-1 requires a report to be made within one hour while the form OE-417 requires a report be made within six hours of the outage. The six hour reference on the updated OE-417 form is the correct reference. 2) Reporting for either CIP-001 or EOP-004 should center on the DOE Form OE-417. This would eliminate confusion and simplify reporting for system operators thereby directly enhancing reliability during system events. This would also eliminate much of the duplicate material and attachments in EOP-004. 3) Although it is beyond the scope of this SAR, the industry would benefit if there was a central location or link on the NERC website containing all reporting forms, including FERC, NERC, DOE, and ESIAC. This would enable System Operators to more efficiently locate and report events.</p>
Illinois Municipal Electric Agency	<p>IMEA recommends the following considerations: Simplification of reportable events and the reporting process should be the overriding objective. NERC's Security Guideline for the Electricity Sector: Threat and Incident Reporting (Version 2.0) should be updated to support this standards development initiative. At some point in the process, it may help if examples are given of events actually reported that did not need to be reported.</p>

**Unofficial Nomination Form for Standard Drafting Team for Disturbance and Sabotage Reporting (Project 2009-01)**

Please **DO NOT** use this form. Please use the [electronic nomination form](#) located at the link below. If you have any questions, please contact Stephen Crutchfield at [stephen.crutchfield@nerc.net](mailto:stephen.crutchfield@nerc.net) or by telephone at 609-651-9455.

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

**By submitting the following information you are indicating your commitment to actively participate (including physically attending face-to-face) Standard Drafting Team meetings if appointed to the Standard Drafting Team by the Standards Committee.**

Name:	
Organization:	
Address:	
Telephone:	
E-mail:	

**Project 2009-01 Disturbance and Sabotage Reporting** will entail revising existing standards CIP-001 — Sabotage Reporting and EOP-004 — Disturbance Reporting to eliminate redundancies and provide clarity on sabotage events. The project includes addressing several issues identified by stakeholders, FERC directives from Order 693, and may include improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Please briefly describe (no more than a couple of paragraphs) your experience and qualifications directly related to the issues to be addressed by the Disturbance and Sabotage Reporting Standard Drafting Team. We are seeking a cross section of the industry to participate on the team, but in particular are seeking individuals with experience in management of real-time bulk power operations activities. Please include any previous experience related to developing or applying IEEE or other industry related standards as this type of experience might be beneficial to include on the team, but is not a requisite to be appointed to the team.

Are you currently a member of any NERC or Regional Entity SAR or standard drafting team? If yes, please list each	<input type="checkbox"/> No <input type="checkbox"/> Yes:

**Unofficial Nomination Form for Disturbance and Sabotage Reporting Standard Drafting Team  
(Project 2009-01)**

---

team here.	
------------	--

Have you previously worked on any NERC or Regional Entity SAR or standard drafting teams? If yes, please list them here.	<input type="checkbox"/> No <input type="checkbox"/> Yes:
--	--

Please identify the NERC Region(s) for which you are able to represent your company's position relative to the topics addressed in the SAR:  <input type="checkbox"/> ERCOT <input type="checkbox"/> FRCC <input type="checkbox"/> MRO <input type="checkbox"/> NPCC <input type="checkbox"/> RFC <input type="checkbox"/> SERC <input type="checkbox"/> SPP <input type="checkbox"/> WECC <input type="checkbox"/> Not Applicable or None of the Above	Please identify the Industry Segment(s) for which you are able to represent your company's position relative to the topics addressed in the SAR: <table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="width: 30px;"><input type="checkbox"/></td><td>1 — Transmission Owners</td></tr> <tr><td><input type="checkbox"/></td><td>2 — RTOs and ISOs</td></tr> <tr><td><input type="checkbox"/></td><td>3 — Load-serving Entities</td></tr> <tr><td><input type="checkbox"/></td><td>4 — Transmission-dependent Utilities</td></tr> <tr><td><input type="checkbox"/></td><td>5 — Electric Generators</td></tr> <tr><td><input type="checkbox"/></td><td>6 — Electricity Brokers, Aggregators, and Marketers</td></tr> <tr><td><input type="checkbox"/></td><td>7 — Large Electricity End Users</td></tr> <tr><td><input type="checkbox"/></td><td>8 — Small Electricity End Users</td></tr> <tr><td><input type="checkbox"/></td><td>9 — Federal, State, and Provincial Regulatory or other Government Entities</td></tr> <tr><td><input type="checkbox"/></td><td>10 — Regional Reliability Organizations and Regional Entities</td></tr> <tr><td><input type="checkbox"/></td><td>Not applicable</td></tr> </table>	<input type="checkbox"/>	1 — Transmission Owners	<input type="checkbox"/>	2 — RTOs and ISOs	<input type="checkbox"/>	3 — Load-serving Entities	<input type="checkbox"/>	4 — Transmission-dependent Utilities	<input type="checkbox"/>	5 — Electric Generators	<input type="checkbox"/>	6 — Electricity Brokers, Aggregators, and Marketers	<input type="checkbox"/>	7 — Large Electricity End Users	<input type="checkbox"/>	8 — Small Electricity End Users	<input type="checkbox"/>	9 — Federal, State, and Provincial Regulatory or other Government Entities	<input type="checkbox"/>	10 — Regional Reliability Organizations and Regional Entities	<input type="checkbox"/>	Not applicable
<input type="checkbox"/>	1 — Transmission Owners																						
<input type="checkbox"/>	2 — RTOs and ISOs																						
<input type="checkbox"/>	3 — Load-serving Entities																						
<input type="checkbox"/>	4 — Transmission-dependent Utilities																						
<input type="checkbox"/>	5 — Electric Generators																						
<input type="checkbox"/>	6 — Electricity Brokers, Aggregators, and Marketers																						
<input type="checkbox"/>	7 — Large Electricity End Users																						
<input type="checkbox"/>	8 — Small Electricity End Users																						
<input type="checkbox"/>	9 — Federal, State, and Provincial Regulatory or other Government Entities																						
<input type="checkbox"/>	10 — Regional Reliability Organizations and Regional Entities																						
<input type="checkbox"/>	Not applicable																						

Please identify the Functional Entities<sup>1</sup> for which you are able to represent your company's position relative to the topics addressed in the SAR:

<input type="checkbox"/> Balancing Authority <input type="checkbox"/> Compliance Enforcement Authority <input type="checkbox"/> Distribution Provider <input type="checkbox"/> Generator Operator <input type="checkbox"/> Generator Owner <input type="checkbox"/> Interchange Authority <input type="checkbox"/> Load-serving Entity <input type="checkbox"/> Market Operator	<input type="checkbox"/> Planning Coordinator <input type="checkbox"/> Transmission Operator <input type="checkbox"/> Transmission Owner <input type="checkbox"/> Transmission Planner <input type="checkbox"/> Transmission Service Provider <input type="checkbox"/> Purchasing-selling Entity <input type="checkbox"/> Resource Planner <input type="checkbox"/> Reliability Coordinator
--	--

---

<sup>1</sup> These functions are defined in the [NERC Functional Model](#), which is available on the NERC Web site.

**Unofficial Nomination Form for Disturbance and Sabotage Reporting Standard Drafting Team  
(Project 2009-01)**

---

**Please provide the names and contact information for two references who could attest to your technical qualifications and your ability to work well in a group. NERC staff may contact these references.**

Name and Title:		Office Telephone:	
Organization:		E-mail:	
Name and Title:		Office Telephone:	
Organization:		E-mail:	



## Standards Announcement

### Nomination Period Opens for Standard Drafting Team

September 16-30, 2009

Now available at: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

#### **Project 2009-01: Disturbance and Sabotage Reporting**

The Standards Committee is seeking industry experts to serve on the Disturbance and Sabotage Reporting Standard Drafting Team. The nomination period is open **until September 30, 2009**.

#### **Instructions**

If you are interested in serving on this standard drafting team, please complete the following electronic nomination form: <https://www.nerc.net/nercsurvey/Survey.aspx?s=ba96a1dc8506404889e26d05aaf490c6>. Please contact Dave Taylor at [david.taylor@nerc.net](mailto:david.taylor@nerc.net) or 609-651-5089 with any questions about the team.

#### **Project Background**

Project 2009-01 — Disturbance and Sabotage Reporting will entail revising existing standards CIP-001-1 — Sabotage Reporting and EOP-004-1 — Disturbance Reporting to eliminate redundancies and provide clarity on sabotage events. The project includes addressing several issues identified by stakeholders, FERC directives from Order 693, and may include improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

More information about the project is available on the following page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

#### **Standards Development Process**

The [Reliability Standards Development Procedure](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance,  
please contact Shaun Streeter at [shaun.streeter@nerc.net](mailto:shaun.streeter@nerc.net) or at 609.452.8060.*

## **Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) Reporting Concepts**

### **Introduction**

The SAR for Project 2009-01 Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and is progressing toward developing standards based on the SAR. This concepts paper is designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The DSR SDT is also proposing to investigate incorporation of the cyber incident reporting aspects of CIP-008 under this project. This will be coordinated with the Cyber Security — Order 706 Standard Drafting Team (Project 2008-06).

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives to determine a prudent course of action with respect to these standards.

This concept paper provides stakeholders with a proposed “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. This concept paper provides the background information and thought process of the DSR SDT.

The proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. TOP). The proposed standards deal exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

### Summary of Concepts and Assumptions:

***The Standard Will:*** Require use of a single form to report disturbances and “impact events” that threaten the reliability of the bulk electric system

- Provide clear criteria for reporting
- Include consistent reporting timelines
- Identify appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provide clarity around of who will receive the information

The drafting team will explore other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements

### ***Discussion of Disturbance Reporting***

Disturbance reporting requirements currently exist in EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DST SDT discussed the reliability needs for disturbance reporting and will consider guidance found in the document “[NERC Guideline: Threat and Incident Reporting](#)” in the development of requirements, which will include clear criteria for reporting. The new/revised standard will specify who has access to reported information about disturbances.

The DSR SDT is considering developing a reporting hierarchy that requires the Reliability Coordinator (RC) to submit the disturbance report. Any entity (Distribution Provider, Load-Serving Entity, Generator Operator) that experiences a disturbance would report the appropriate information to the Transmission Operator or Balancing Authority (if applicable) who would then report to the RC. The RC would then submit the report to NERC, the affected Regional Entity (RE) and/or Department of Energy (DOE) as appropriate. By having the RC submit the report, situational awareness would be enhanced. All affected entities would be aware of the disturbance and relevant information. Also, the flow of information between entities would be enhanced and a more comprehensive report could be developed.

### ***Discussion of “Impact Event” Reporting***

There are situations worthy of reporting because they have the potential to impact reliability. The DSR SDT proposes calling such incidents ‘impact events’ with the following definition:

An impact event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences.

Impact event reporting facilitates situational awareness, which allows potentially impacted parties to prepare for and possibly mitigate the reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of impact events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008
- Forced intrusion attempt at a substation
- Train derailment near a transmission right-of-way
- Destruction of Bulk Electrical System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that reporting material risks to the Bulk Electrical System using the impact event categorization, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

The DSR SDT discussed the reliability needs for impact event reporting and will consider guidance found in the document “[NERC Guideline: Threat and Incident Reporting](#)” in the development of requirements, which will include clear criteria for reporting.

Certain types of impact events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of impact events may have different reporting requirements. For example, an impact event that is related to copper theft may only need to be reported to the local law enforcement authorities. The new standard will specify who has access to reported information about impact events.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. As envisioned, the standard will only require Functional entities to report the incidents and provide information or data necessary for these analyses. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability.

Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### ***Collection of Reportable Information or “One stop shopping”***

The goal of the DSR SDT is to have one reporting form for all functional entities (US, Canada, Mexico) to submit to NERC. Ultimately, it may make sense to develop an electronic version to expedite completion, sharing and storage. Ideally, entities would complete a single form which could then be distributed to jurisdictional agencies and functional entities as appropriate. Specific reporting forms<sup>1</sup> that exist today (i.e. - OE-417, etc) could be included as part of the electronic form to accommodate US entities with a requirement to submit the form. Or may be removed (but still be mandatory for US entities under Public Law 93-275) to streamline the proposed consolidated reliability standard for all North American entities (US, Canada, Mexico). Jurisdictional agencies may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE. Functional entities may include the RC, TOP, and BA for situational awareness. Applicability of the standard will be determined based on the specific requirements.

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT is planning to update the listing of reportable events from discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences may still exist.

The reporting proposed by the DSR SDT is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information is not necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

---

<sup>1</sup> The DOE Reporting Form, OE-417 is currently a part of the EOP-004 standard. If this report is removed from the standard, it should be noted that this form is still required by law as noted on the form: NOTICE: This report is mandatory under Public Law 93-275. Failure to comply may result in criminal fines, civil penalties and other sanctions as provided by law. For the sanctions and the provisions concerning the confidentiality of information submitted on this form, see General Information portion of the instructions. Title 18 USC 1001 makes it a criminal offense for any person knowingly and willingly to make to any Agency or Department of the United States any false, fictitious, or fraudulent statements as to any matter within its jurisdiction.

## Unofficial Comment Form for Project 2009-01 — Disturbance and Sabotage Reporting

Please **DO NOT** use this form to submit comments. Please use the [electronic form](#) located at the site below to submit comments on the proposed Concepts Paper for Disturbance and Sabotage Reporting. Comments must be submitted by **April 16, 2010**. If you have questions please contact Stephen Crutchfield by email at [Stephen.crutchfield@nerc.net](mailto:Stephen.crutchfield@nerc.net) or by telephone at 609-651-9455.

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Background:**

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and is progressing toward developing standards based on the SAR. The concepts paper was developed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed. Please review the redlined SAR and then answer the following questions.

This initial comment period is requesting industry input on the direction herein proposed by the DSR SDT. Should your organization feel that the direction proposed is not the direction that should be pursued then your comments on what direction the SDT should take would be greatly appreciated. The "concept paper" lays out the foundation for the reporting requirements in the standard. We are not seeking input or guidance on the definition of physical or cyber sabotage, what type of disturbances should be reported, who should do reporting, or to whom or what organizations will be receiving the reports. All of these points will be addressed by the SDT in later phases of the project and we will be seeking important industry guidance at those times. The SDT does recognize the importance of all of that data and information, but at this time, we are only seeking input on the direction of the concepts we propose to build upon.

1. The details of reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and will consider guidance found in the document “NERC Guideline: Threat and Incident Reporting” in the development of requirements. Do you agree with using the existing guidance as the foundation for disturbance reporting? Please explain your response (yes or no) in the comment area.

Yes

No

Comments:

2. The DSR SDT is considering developing a reporting hierarchy for disturbances that requires entities to submit information to the Reliability Coordinator and then for the Reliability Coordinator to submit the report. Do you agree with this hierarchy concept? Please explain your response (yes or no) in the comment area.

Yes

No

Comments:

3. The goal of the DSR SDT is to have one report form for all functional entities (US, Canada, Mexico) to submit to NERC. Do you agree with this change? Please explain your response (yes or no) in the comment area.

Yes

No

Comments:

4. The goal of the DSR SDT is to eliminate the need to file duplicate reports. The standards will specify information required by NERC for reliability. To the extent that this information is also required for other reports (e.g. DOE OE-417), those reports will be allowed to supplement the NERC report in lieu of duplicating the entries in the NERC report. Do you agree with this concept? Please explain your response (yes or no) in the comment area.

Yes

No

Comments:

5. In its discussion concerning sabotage, the DSR SDT has determined that the spectrum of all sabotage-type events is not well understood throughout the industry. In an effort to provide clarity and guidance, the DSR SDT developed the concept of an impact event.

By developing impact events, it allows us to identify situations in the “gray area” where sabotage is not clearly defined. Other types of events may need to be reported for situational awareness and trend identification. Do you agree with this concept? Please explain your response (yes or no) in the comment area.

Yes

No

Comments:

6. If you are aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004 please provide them here.

Comments:

7. If you have any other comments on the Concepts Paper that you haven't already provided in response to the previous questions, please provide them here.

Comments:



**A. Introduction**

1. **Title:** **Sabotage Reporting**
2. **Number:** CIP-001-1
3. **Purpose:** Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
5. **Effective Date:** January 1, 2007

**B. Requirements**

- R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

**C. Measures**

- M1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1
- M2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

Regional Reliability Organizations shall be responsible for compliance monitoring.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to verify compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Reliability Coordinator, Transmission Operator, Generator Operator, Distribution Provider, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

#### **1.4. Additional Compliance Information**

None.

**2. Levels of Non-Compliance:**

**2.1. Level 1:** There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

**2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).

**2.1.2** Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).

**2.1.3** Has not established communications contacts, as specified in R4.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).

**2.4. Level 4:** Not applicable.

**E. Regional Differences**

None indicated.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed "Proposed" from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Amended

## A. Introduction

1. **Title:** **Disturbance Reporting**
2. **Number:** EOP-004-1
3. **Purpose:** Disturbances or unusual occurrences that jeopardize the operation of the Bulk Electric System, or result in system equipment damage or customer interruptions, need to be studied and understood to minimize the likelihood of similar events in the future.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Regional Reliability Organizations.
5. **Effective Date:** January 1, 2007

## B. Requirements

- R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.
- R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.
- R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.
  - R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until some time after they occur shall be reported within 24 hours of being recognized.
  - R3.2. Applicable reporting forms are provided in Attachments 1-EOP-004 and 2-EOP-004.
  - R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that

time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.

- R3.4.** If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.
- R4.** When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.
- R5.** The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.

### **C. Measures**

- M1.** The Regional Reliability Organization shall have and provide upon request as evidence, its current regional reporting procedure that is used to facilitate preparation of preliminary and final disturbance reports. (Requirement 1)
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, the preliminary report, computer printouts, operator logs, or other equivalent evidence that will be used to confirm that it prepared and delivered the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1.
- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to confirm that it provided information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours. (Requirement 3.3)

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

NERC shall be responsible for compliance monitoring of the Regional Reliability Organizations.

Regional Reliability Organizations shall be responsible for compliance monitoring of Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load-serving Entities.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Regional Reliability Organization shall have its current, in-force, regional reporting procedure as evidence of compliance. (Measure 1)

Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that is either involved in a Bulk Electric System disturbance or has a reportable incident shall keep data related to the incident for a year from the event or for the duration of any regional investigation, whichever is longer. (Measures 2 through 4)

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**1.4. Additional Compliance Information**

See Attachments:

- EOP-004 Disturbance Reporting Form
- Table 1 EOP-004

**2. Levels of Non-Compliance for a Regional Reliability Organization**

**2.1. Level 1:** Not applicable.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Not applicable.

**2.4. Level 4:** No current procedure to facilitate preparation of preliminary and final disturbance reports as specified in R1.

**3. Levels of Non-Compliance for a Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load- Serving Entity:**

**3.1. Level 1:** There shall be a level one non-compliance if any of the following conditions exist:

**3.1.1** Failed to prepare and deliver the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1

**3.1.2** Failed to provide disturbance information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours as specified in R3.3

**3.1.3** Failed to prepare a final report within 60 days as specified in R3.4

**3.2. Level 2:** Not applicable.

**3.3. Level 3:** Not applicable

**3.4. Level 4:** Not applicable.

**E. Regional Differences**

None identified.

**Version History**

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	May 23, 2005	Fixed reference to attachments 1-EOP-004-0 and 2-EOP-004-0, Changed chart title 1-FAC-004-0 to 1-EOP-004-0, Fixed title of Table 1 to read 1-EOP-004-0, and fixed font.	Errata
0	July 6, 2005	Fixed email in Attachment 1-EOP-004-0 from <a href="mailto:info@nerc.com">info@nerc.com</a> to <a href="mailto:esisac@nerc.com">esisac@nerc.com</a> .	Errata

**Standard EOP-004-1 — Disturbance Reporting**

---

0	July 26, 2005	Fixed Header on page 8 to read EOP-004-0	Errata
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised
1	March 22, 2007	Updated Department of Energy link and references to Form OE-411	Errata



## Attachment 1-EOP-004 NERC Disturbance Report Form

### Introduction

These disturbance reporting requirements apply to all Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load Serving Entities, and provide a common basis for all NERC disturbance reporting. The entity on whose system a reportable disturbance occurs shall notify NERC and its Regional Reliability Organization of the disturbance using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. Reports can be sent to NERC via email ([esisac@nerc.com](mailto:esisac@nerc.com)) by facsimile (609-452-9550) using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. If a disturbance is to be reported to the U.S. Department of Energy also, the responding entity may use the DOE reporting form when reporting to NERC. Note: All Emergency Incident and Disturbance Reports (Schedules 1 and 2) sent to DOE shall be simultaneously sent to NERC, preferably electronically at [esisac@nerc.com](mailto:esisac@nerc.com).

The NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports are to be made for any of the following events:

1. The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:
  - a. Modification of operating procedures.
  - b. Modification of equipment (e.g. control systems or special protection systems) to prevent reoccurrence of the event.
  - c. Identification of valuable lessons learned.
  - d. Identification of non-compliance with NERC standards or policies.
  - e. Identification of a disturbance that is beyond recognized criteria, i.e. three-phase fault with breaker failure, etc.
  - f. Frequency or voltage going below the under-frequency or under-voltage load shed points.
2. The occurrence of an interconnected system separation or system islanding or both.
3. Loss of generation by a Generator Operator, Balancing Authority, or Load-Serving Entity — 2,000 MW or more in the Eastern Interconnection or Western Interconnection and 1,000 MW or more in the ERCOT Interconnection.
4. Equipment failures/system operational actions which result in the loss of firm system demands for more than 15 minutes, as described below:
  - a. Entities with a previous year recorded peak demand of more than 3,000 MW are required to report all such losses of firm demands totaling more than 300 MW.
  - b. All other entities are required to report all such losses of firm demands totaling more than 200 MW or 50% of the total customers being supplied immediately prior to the incident, whichever is less.
5. Firm load shedding of 100 MW or more to maintain the continuity of the bulk electric system.

6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in:
  - a. Sustained voltage excursions equal to or greater than  $\pm 10\%$ , or
  - b. Major damage to power system components, or
  - c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance as defined by steps 1 through 5 above.
7. An Interconnection Reliability Operating Limit (IROL) violation as required in reliability standard TOP-007.
8. Any event that the Operating Committee requests to be submitted to Disturbance Analysis Working Group (DAWG) for review because of the nature of the disturbance and the insight and lessons the electricity supply and delivery industry could learn.

### NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report

Check here if this is an Interconnection Reliability Operating Limit (IROL) violation report.

1.	Organization filing report.		
2.	Name of person filing report.		
3.	Telephone number.		
4.	Date and time of disturbance. Date:(mm/dd/yy) Time/Zone:		
5.	Did the disturbance originate in your system?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
6.	Describe disturbance including: cause, equipment damage, critical services interrupted, system separation, key scheduled and actual flows prior to disturbance and in the case of a disturbance involving a special protection or remedial action scheme, what action is being taken to prevent recurrence.		
7.	Generation tripped.  MW Total List generation tripped		
8.	Frequency. Just prior to disturbance (Hz): Immediately after disturbance (Hz max.): Immediately after disturbance (Hz min.):		
9.	List transmission lines tripped (specify voltage level of each line).		
10.	Demand tripped (MW): Number of affected Customers:	FIRM	INTERRUPTIBLE

**Standard EOP-004-1 — Disturbance Reporting**

---

	Demand lost (MW-Minutes):		
11.	Restoration time.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		

## **Attachment 2-EOP-004**

### **U.S. Department of Energy Disturbance Reporting Requirements**

#### **Introduction**

The U.S. Department of Energy (DOE), under its relevant authorities, has established mandatory reporting requirements for electric emergency incidents and disturbances in the United States. DOE collects this information from the electric power industry on Form OE-417 to meet its overall national security and Federal Energy Management Agency's Federal Response Plan (FRP) responsibilities. DOE will use the data from this form to obtain current information regarding emergency situations on U.S. electric energy supply systems. DOE's Energy Information Administration (EIA) will use the data for reporting on electric power emergency incidents and disturbances in monthly EIA reports. In addition, the data may be used to develop legislative recommendations, reports to the Congress and as a basis for DOE investigations following severe, prolonged, or repeated electric power reliability problems.

Every Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity must use this form to submit mandatory reports of electric power system incidents or disturbances to the DOE Operations Center, which operates on a 24-hour basis, seven days a week. All other entities operating electric systems have filing responsibilities to provide information to the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity when necessary for their reporting obligations and to file form OE-417 in cases where these entities will not be involved. EIA requests that it be notified of those that plan to file jointly and of those electric entities that want to file separately.

Special reporting provisions exist for those electric utilities located within the United States, but for whom Reliability Coordinator oversight responsibilities are handled by electrical systems located across an international border. A foreign utility handling U.S. Balancing Authority responsibilities, may wish to file this information voluntarily to the DOE. Any U.S.-based utility in this international situation needs to inform DOE that these filings will come from a foreign-based electric system or file the required reports themselves.

Form EIA-417 must be submitted to the DOE Operations Center if any one of the following applies (see Table 1-EOP-004-0 — Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies):

1. Uncontrolled loss of 300 MW or more of firm system load for more than 15 minutes from a single incident.
2. Load shedding of 100 MW or more implemented under emergency operational policy.
3. System-wide voltage reductions of 3 percent or more.
4. Public appeal to reduce the use of electricity for purposes of maintaining the continuity of the electric power system.
5. Actual or suspected physical attacks that could impact electric power system adequacy or reliability; or vandalism, which target components of any security system. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.

6. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.
7. Fuel supply emergencies that could impact electric power system adequacy or reliability.
8. Loss of electric service to more than 50,000 customers for one hour or more.
9. Complete operational failure or shut-down of the transmission and/or distribution electrical system.

The initial DOE Emergency Incident and Disturbance Report (form OE-417 – Schedule 1) shall be submitted to the DOE Operations Center within 60 minutes of the time of the system disruption. Complete information may not be available at the time of the disruption. However, provide as much information as is known or suspected at the time of the initial filing. If the incident is having a critical impact on operations, a telephone notification to the DOE Operations Center (202-586-8100) is acceptable, pending submission of the completed form OE-417. Electronic submission via an on-line web-based form is the preferred method of notification. However, electronic submission by facsimile or email is acceptable.

An updated form OE-417 (Schedule 1 and 2) is due within 48 hours of the event to provide complete disruption information. Electronic submission via facsimile or email is the preferred method of notification. Detailed DOE Incident and Disturbance reporting requirements can be found at: <http://www.oe.netl.doe.gov/oe417.aspx>.

<b>Table 1-EOP-004-0</b> <b>Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies</b>				
<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
1	Uncontrolled loss of Firm System Load	≥ 300 MW – 15 minutes or more	OE – Sch-1 OE – Sch-2	1 hour 48 hour
2	Load Shedding	≥ 100 MW under emergency operational policy	OE – Sch-1 OE – Sch-2	1 hour 48 hour
3	Voltage Reductions	3% or more – applied system-wide	OE – Sch-1 OE – Sch-2	1 hour 48 hour
4	Public Appeals	Emergency conditions to reduce demand	OE – Sch-1 OE – Sch-2	1 hour 48 hour
5	Physical sabotage, terrorism or vandalism	On physical security systems – suspected or real	OE – Sch-1 OE – Sch-2	1 hour 48 hour
6	Cyber sabotage, terrorism or vandalism	If the attempt is believed to have or did happen	OE – Sch-1 OE – Sch-2	1 hour 48 hour
7	Fuel supply emergencies	Fuel inventory or hydro storage levels ≤ 50% of normal	OE – Sch-1 OE – Sch-2	1 hour 48 hour
8	Loss of electric service	≥ 50,000 for 1 hour or more	OE – Sch-1 OE – Sch-2	1 hour 48 hour
9	Complete operation failure of electrical system	If isolated or interconnected electrical systems suffer total electrical system collapse	OE – Sch-1 OE – Sch-2	1 hour 48 hour
All DOE OE-417 Schedule 1 reports are to be filed within 60-minutes after the start of an incident or disturbance All DOE OE-417 Schedule 2 reports are to be filed within 48-hours after the start of an incident or disturbance <i>All entities required to file a DOE OE-417 report (Schedule 1 &amp; 2) shall send a copy of these reports to NERC simultaneously, but no later than 24 hours after the start of the incident or disturbance.</i>				
<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
1	Loss of major system component	Significantly affects integrity of interconnected system operations	NERC Prelim Final report	24 hour 60 day

**Standard EOP-004-1 — Disturbance Reporting**

<b>2</b>	Interconnected system separation or system islanding	Total system shutdown Partial shutdown, separation, or islanding	NERC Prelim Final report	24 hour 60 day
<b>3</b>	Loss of generation	$\geq 2,000$ – Eastern Interconnection $\geq 2,000$ – Western Interconnection $\geq 1,000$ – ERCOT Interconnection	NERC Prelim Final report	24 hour 60 day
<b>4</b>	Loss of firm load $\geq 15$ -minutes	Entities with peak demand $\geq 3,000$ : loss $\geq 300$ MW All others $\geq 200$ MW or 50% of total demand	NERC Prelim Final report	24 hour 60 day
<b>5</b>	Firm load shedding	$\geq 100$ MW to maintain continuity of bulk system	NERC Prelim Final report	24 hour 60 day
<b>6</b>	System operation or operation actions resulting in:	<ul style="list-style-type: none"> <li>• Voltage excursions <math>\geq 10\%</math></li> <li>• Major damage to system components</li> <li>• Failure, degradation, or misoperation of SPS</li> </ul>	NERC Prelim Final report	24 hour 60 day
<b>7</b>	IROL violation	Reliability standard TOP-007.	NERC Prelim Final report	72 hour 60 day
<b>8</b>	As requested by ORS Chairman	Due to nature of disturbance & usefulness to industry (lessons learned)	NERC Prelim Final report	24 hour 60 day
<p>All NERC Operating Security Limit and Preliminary Disturbance reports will be filed within 24 hours after the start of the incident. If an entity must file a DOE OE-417 report on an incident, which requires a NERC Preliminary report, the Entity may use the DOE OE-417 form for both DOE and NERC reports.</p>				
<p><b><i>Any entity reporting a DOE or NERC incident or disturbance has the responsibility to also notify its Regional Reliability Organization.</i></b></p>				





NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

## Standards Announcement

Comment Period Open

March 17–April 16, 2010

**Now available at:** [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Project 2009-01: Disturbance and Sabotage Reporting**

The Disturbance and Sabotage Reporting Drafting Team is seeking comments on a proposed concepts paper for disturbance and sabotage reporting **until 8 p.m. Eastern on April 16, 2010.**

The concepts paper lays out the foundation for the reporting requirements in the standard and was developed to solicit stakeholder input regarding the drafting team's proposed reporting concepts.

### **Instructions**

Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Lauren Koller at [Lauren.Koller@nerc.net](mailto:Lauren.Koller@nerc.net). An off-line, unofficial copy of the comment form is posted on the project page: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Next Steps**

The drafting team will draft and post responses to comments received during this period.

### **Project Background**

This project will entail revising existing standards CIP-001-1 — Sabotage Reporting and EOP-004-1 — Disturbance Reporting to eliminate redundancies and provide clarity on sabotage events. The project will address several issues identified by stakeholders, as well as FERC directives from Order 693. The other changes may include improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.






























### **Standards Development Process**

The [Reliability Standards Development Procedure](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance,  
please contact Lauren Koller at [Lauren.Koller@nerc.net](mailto:Lauren.Koller@nerc.net)*

**Individual or group. (41 Responses)**  
**Name (26 Responses)**  
**Organization (26 Responses)**  
**Group Name (15 Responses)**  
**Contact Organization (15 Responses)**  
**Question 1 (39 Responses)**  
**Question 1 Comments (41 Responses)**  
**Question 2 (40 Responses)**  
**Question 2 Comments (41 Responses)**  
**Question 3 (38 Responses)**  
**Question 3 Comments (41 Responses)**  
**Question 4 (39 Responses)**  
**Question 4 Comments (41 Responses)**  
**Question 5 (37 Responses)**  
**Question 5 Comments (41 Responses)**  
**Question 6 (0 Responses)**  
**Question 6 Comments (41 Responses)**  
**Question 7 (0 Responses)**  
**Question 7 Comments (41 Responses)**

-	
	Group
	Exelon
	Exelon Transmission Strategy & Compliance
	Yes
	No
	Some of the DOE related reporting is driven by distribution events, i.e. outages greater than 50,000 customers, is it realistic to expect the RC, whose focus is on the transmission system to perform distribution related reporting?
	Yes
	Yes
	No
	We agree with the direction to identify impact events examples that would trigger reporting and not be limited to sabotage reporting only. It is important to note that when an incident occurs, some level of investigation is required before a determination can be made as to the event is sabotage or not. The focus should be on reporting events when they occur and allow follow-up investigations to make the sabotage determination. That being said, care must be taken in the development of any list of impact events so that it doesn't become or is misinterpreted to be a definitive list. Therefore if it is not on the list, it is not reportable.
	At the 2010 RFC Spring Workshop the following disturbance reporting Criteria was rolled out: All events that are required to be reported by the OE-417 and EOP-004 criteria will use those published procedures. For other events that do not meet the OE-417 and EOP-004 reporting criteria, ReliabilityFirst expects to receive notification of any events involving a sustained outage of multiple BES facilities (buses, lines, generators, and/or transformers, etc.) that are in close proximity (electrically) to one another and occur in a short time frame (such as a few minutes).
	You should consider providing clear and concise instructions as to the expectation on submitting forms, i.e. the DOE 417. There should be no guessing as to when and how reports should be submitted and who should receive them. Specific details on reporting criteria should be included.
	Individual
	Steve Fisher
	Lands Energy Consulting
	No
	My firm provides compliance consulting services to a number of smaller (50-700 MW peak load) LSE/DP registered entities. EOP-004 creates an obligation for LSEs to report "disturbances" that affect their systems. A few of the smaller of these systems receive service from Bonneville-owned transmission lines that serve only 4-6 substations. The NERC Form establishes loss of 50% of the LSE's retail customers as a reportable disturbances. One of my clients receives service from BPA at 5 substations. A single industrial customer with a substantially dedicated

	<p>substation comprises 90% of the utility's MWH load. Were it not for this customer, the utility would have been well below the registration requirement for a DP/LSE. The balance of the load, about 15 MW of peak and 4000 retail customers, is served from 5 substations. Four of these substations serving 3000 customers are served from a long Bonneville 115 kV BES transmission line that runs through a heavily treed right of way. Every time this single line experiences a permanent outage (which will happen a few times a year), the utility loses less than 10 MW of load, but 75% of its retail customers. Under the disturbance reporting criteria, this outage would constitute a reportable disturbance for the utility. When the NERC disturbance reporting criteria were adopted, I doubt that anyone conceived that they would apply to cases like I just described. Reporting trivial events like I've just described constitutes a nuisance to the entity making the report and NERC/WECC for having to process the report. The outage has no earthly effect on the reliability of the BES and certainly doesn't warrant preparation of any kind of disturbance report.</p>
	<p>Yes</p>
	<p>I would give the RC the authority to establish impact thresholds for reporting. Consistent with my earlier comment, I would set the materiality threshold for disturbance reporting purposes at LSEs (or a combination of LSEs in the case of BPA) serving at least 90,000 customers.</p>
	<p>Yes</p>
	<p>I think that the impact approach makes sense and that EOP-004 and CIP-001 are logically connected. Many entities of which I am aware link Sabotage Reporting Training to Disturbance Reporting obligation awareness already.</p>
	<p>Yes</p>
	<p>Less paperwork and fewer requirements to keep in mind during what may be once in a lifetime events are always good.</p>
	<p>No</p>
	<p>The level of complexity described will overwhelm the 20-200 employee utilities that have yet to see - and will never see - the kind of sabotage event that scares the Department of Homeland Security.</p>
	<p>I believe WECC sets its loss of load criteria for disturbance reporting at 200 MW rather than the 300 MW in the NERC reporting form.</p>
	<p>The lack of common sense that leads to a 15 MW loss of load resulting from a 115 kV line outage being catagorized as a "reportable disturbance" really hurts the credibility of the entire NERC Compliance Program. The smaller utilities look at application of EOP-004 in particular to their operation and conclude that either the EO/RRO is: a. stupid; or b. Out to persecute the smaller utilities. In reality, EOP-004 was drafted for application to Southern California Edison, where loss of 50% of customers would be 2-3 million customers. Now that's really disturbing!</p>
	<p>Individual</p>
	<p>David Kahly</p>
	<p>Kootenai Electric Cooperative</p>
	
	
	
	
	<p>No</p>
	<p>Impact events seems to add another layer of uncertainty to the reporting. Define a transmission line. Our transmission lines have very little impact on the grid. It is possible for our lines to cause a local area outage on our transmission provider - but neither is of national security interest or even regional interest. There is no power flow going on across the lines other than local power delivery supply. It seems you run more risk of losing the important reports in the snow of reporting - similar to what we have to avoid on our SCADA systems for our operators to see the key information.</p>
	
	
	<p>Group</p>
	<p>Northeast Power Coordinating Council</p>
	<p>Northeast Power Coordinating Council</p>
	<p>Yes</p>
	<p>In considering guidance found in the document "NERC Guideline: Threat and Incident Reporting", the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.</p>
	<p>No</p>
	<p>This is not a standards issue, and NERC should not dictate the reporting structure. It should be left to the RCs and their members.</p>
	<p>Yes</p>

	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
	Yes
	We agree with the objective of eliminating duplicate reporting. However, EOP-004 currently allows substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today. We agree with the recommendation to eliminate the need for filing duplicate reports such as the DOE form OE-417. There is no benefit with regard to CIP-001 in filing separate reports. Duplicate reports introduce the potential for incomplete information to be supplied to responsible parties. Removing jurisdictional agencies from the Standard, and having NERC provide either query or situational awareness to those agencies being considered, might not be easy to achieve. There is an obligation under law to require entities to report to the DOE on the OE-417 form as amended or modified. This might drive the "omitted" agencies to have reporting laws enacted as well.
	No
	We believe that physical and cyber events must be investigated before a determination of sabotage or impact event can be made. The purpose of the NERC Standards is to maintain the reliability of the BES. Therefore, impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on 'newsworthy' events or to gather information for trending. It is the law enforcement industry's responsibility to make a determination of "sabotage" or other. This determination cannot definitively be made by industry personnel, there is no expertise or time to investigate causes. It is the industry's job to mitigate effects. Examples would help provide for better guidance/direction. Industry examples would be welcomed to help reinforce developed internal processes for compliance.
	SERC and RFC are developing additional requirements at this time. We suggest that reporting be based on impact to reliability, not on 'newsworthy' events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirement.
	a. NERC should focus efforts on developing specific event reporting criteria and not base the requirement on the definition of the term 'sabotage', but on the reporting criteria itself. See comments above. b. The "opportunities for efficiency" discussed in the Concept Paper would be best achieved by focusing on those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. If there are elements that need to be reported that do not support this objective, then that reporting should not be required in reliability standards. Consider making NERC the distributor of reports to other agencies. We recognize that the key is to simplify reporting to a single form, and to the extent possible, to one agency. "Front line" reliability personnel must have the "timely" knowledge to know when a situation warrants local, area, regional, or national involvement.
	Individual
	Darryl Curtis
	Oncor Electric Delivery Company LLC
	Yes
	NERC Guideline: Threat and Incident Reporting" document should be used for guidance as it identifies best practices for reporting.
	Yes
	Oncor agrees that with this reporting hierarchy, in that dual reporting should be eliminated
	Yes
	Oncor agrees that by using the same type reporting format, there should be consistency in regard to each functional entity's expectations.
	Yes
	Oncor agrees that this effort should eliminate file duplication
	Yes
	Oncor agrees that there are no broadly used guidance documents that detail how an event may be accurately defined.
	Oncor is not aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004.
	Group
	SERC Reliability Coordinator Sub-committee (RCS)
	SERC RCS
	No
	Routine minor incidents such as copper theft and gun shots to insulators should not be reported. These types of minor events do not affect the reliability of the BPS. Existing reporting requirements are satisfactory. The focus of reporting should be on reliability related incidents and not incidents related to vandalism as such.

	No
	The RC should not be responsible for submitting the report to FERC, NERC or the RRO. The RC may not have the necessary first hand information concerning the facts of the event. Situation awareness can be maintained by including the RC in the distribution of any sabotage related reporting.
	Yes
	There should only be one report for all functional entities.
	No
	The requirement should be a single report that satisfies the need for all US governmental agencies as well as NERC and the RRO's.
	No
	Impact events that do not affect reliability should not be reported.
	We are not aware of any regional reporting requirements beyond the requirements of CIP-001, CIP-008 and EOP-004. However, the SERC RRO has shared a list of events of interest that it would like to be made aware of to maintain situation awareness.
	None.
	Group
	Arizona Public Service Company
	Arizona Public Service Company
	No
	APS supports standard revisions which streamline the reporting process for security incidents with a single form, which aligns both with EIA reporting and NERC Standards requirements, particularly those identified in the NERC Threat and Incident Reporting Guidelines. This would eliminate users issuing reports to multiple locations/government entities without a standard form or format. The DOE 417 form which is currently utilized for reporting purposes is outdated and does not account for the types of incidents as identified in the NERC Threat and Incident Reporting Guidelines. The guidelines state that an entity can report security incidents to the ESISAC , through CIPIS (Critical Infrastructure Protection Information System), and or RCIS (Reliability Coordinator Information Center). CIPIS refers an entity to the NICC and to the WECC. Additionally, APS proposes that the terms and timelines of reporting security incidents be clearly identified. Events are often detected quickly or immediately. Determining whether or not the event was sabotage and/or a reportable event; however, typically takes much longer. There is no time allowance for an entity to investigate the event to determine what actually occurred. Currently, DOE 417 provides that acts of sabotage should be reported within one hour of detection if the impact could affect the reliable operation of the bulk power system. This may affect the accuracy of the information being provided by an entity on it's initial reporting. Finally, provisions should be incorporated to address the privacy of information being submitted, including handling and storage.
	Yes
	All disturbance reporting should go through the RC.
	Yes
	APS supports the standardization of the form for consistency and format.
	Yes
	APS supports eliminating the need to file duplicate reports. This standardized form should generate and send the DOE OE-417 report, totally eliminating duplicate work. Streamline the process.
	Individual
	Edward Bedder
	Orange and Rockland Utilities, Inc.
	Yes
	However, the SDT needs to maintain clear demarcation for the criteria for reporting events, and only those events that directly effect the reliability of the BES.
	Yes
	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System. The reporting hierarchy should be to submit the information to the Reliability Coordinator, and to have the RC submit the report. This would eliminate the duplication of information.



























	Yes
	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
	Yes
	No
	Physical and cyber events must be investigated before a determination of sabotage or impact event can be made. Impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on 'newsworthy' events or to gather information for trending. It is the law enforcement industry's responsibility to make a determination of "sabotage" or other. This determination cannot definitively be made by industry (operating) personnel. If NERC's definition is expanded for CIP-001 and/or EOP-004, responsibility and timing of reporting needs to be addressed so that appropriate agencies conduct the investigation and assessment. Operating personnel need to remain focused on the primary responsibility of mitigating the effects.
	NERC's SDT effort requires a clear, consistent, and comprehensive continent-wide approach, thus mitigating any need for regional reporting requirements.
	Individual
	Kasia Mihalchuk
	Manitoba Hydro
	Yes
	The "Threat and Incident Reporting" document contains a lot of detailed information which greatly assists in determining reporting events and weeding out non important events. The document contains some examples and expected reporting time lines. Attachment 1-EOP-004, though considerably smaller and condensed it does contain some detail not mentioned in "Threat and Incident Reporting". Integrating the "Threat and Incident Reporting" into Attachment 1-EOP-004, though large in size, has lots of information and is easy to follow would be a large improvement to existing protocol OR SEE QUESTION 3 COMMENTS. Incidences we have experienced on our system, in past were difficult to delineate as reportable, who to report to and when. An improvement to this Standard is welcome.
	Yes
	The Reporting Concept states that the new hierarchy is, " Affected entity to TOP/ BA to RC. Then the RC will then submit to NERC and DOE (if required)". This will enhance the existing requirement EOP-004-1 R4 which states that the RC shall assist the affected entity by providing representatives to assist in the investigation (this is also all reiterated in Attachment 1-EOP-004) . In an disturbance, the local resources would be tied up in the rectification of the problem. Analyzing and reporting the event (is it reportable, who to report to, what is the timeline) is distracting and time consuming. By leaving the final upper level steps of reporting to NERC/DOE by the RC would be efficient.
	Yes
	This is a promising idea, though there would be different requirements for the three countries, this could easily be rectified with "drop down menus". This electronic form could contain a lot of information without distracting clutter as you "tree" down the menu depending on the event that occurred. This could also contain electronic references to information located in Attachment 1-EOP-004 and Threat and Incident Reporting.
	Yes
	This could be easily incorporated into the electronic form. You could be prompted for information required immediately, and notified for information that could be entered later. This form could contain all the enterable data that all agencies could require. If the form is live and on line, all entities could be notified (depending on the entries) of an going event immediately. Form could be web based similar to ARS program or even integrated into the ARS program.
	Yes
	Though there are some specific events already included in this new definition, more could be added to dissolve specific "gray areas" and as new ones come up. Again these examples could be added into the electronic form and could contain a large data base which would be available depending on the event that occurred.
	No. CIP-001 contains references to NERC and the DOE. CIP-008 makes exclusions for facilities regulated by US Nuclear Regulatory Commission and Canadian Nuclear Safety Commission. It also contains references to ES ISAC (Electricity Sector Information Sharing and Analysis Center). EOP-004 contains reference to NERC and DOE There is no reference to Homeland Security, FBI, etc or to Canadian equivalent references in any of these Standards. When NERC is notified of an event, it is likely other organizations will have to be notified. There should be some sort of consistency to cover all these Standards and all notifiable parties at a NERC Standards level.
	No
	Individual
	Brian Bartos
	Bandera Electric Cooperative, Inc.























	Yes
	Yes
	This approach, while I suspect will not be universally agreed to, should provide some definitive guidance in reporting.
	No preference in this area.
	Yes
	One can only assume the number of reports required in this area will continue to increase in terms of scope and to which agency wants this data. The SDT is encouraged to attempt to find a reporting format and scope that does not needlessly duplicate or complicate overall reporting obligations.
	Yes
	In principle, I agree with this concept. Would like for the SDT to pursue this further and seek additional comments at that time.
	No.
	I commend the SDT for working on this effort and wish them success.
	Group
	PacifiCorp
	PacifiCorp
	Yes
	Yes
	Yes
	Yes
	Group
	E.ON U.S. LLC
	E.ON U.S.LLC
	Yes
	E.ON U.S. believe that the guidelines provide greater clarity for reporting forced outages caused by disturbances and sabotage but there remains issues that in need of further clarification. For example, there remains too much subjectivity on the reporting of forced outages when there is "identification of valuable lessons learned"
	Yes
	The hierarchy will simplify reporting from the entity in that the RC is always notified and then the RC notifies other parties as required, (with the exception of OE-417, which still has to be filled out per law) E.ON U.S. recommends that the drafting team pay particular attention to the report process to make sure that duplicate reports are not being required. Currently information on forced outages is already communicated to the RC so formalizing a requirement to provide data to the RC may represent duplication to reports already provided.
	Yes
	E.ON U.S. supports the proposal.
	No
	Reliability standards are federal law enforced by fines that can reach up to \$1,000,000 per day of violation. There is no reason to deliberately include ambiguity, i.e. "gray areas," in requirements such that registered entities are left unable to determine what it is they must do or refrain from doing to remain compliant. "Sabotage" for the purposes of these standards must be defined. .

	Individual
	John T. Walker
	Portland General Electric
	Yes
	This process is in place and utilities are familiar with it. This is a good place to start.
	Yes
	PGE is familiar with and works closely with WECC today so the hierarchial consideration makes sense.
	Yes
	PGE supports the efforts of the Standards Drafting Team on the SAR for Project 2009-01 to consolidate the disturbance and saborage reporting processes as outlined in the concept paper.
	Yes
	PGE supports reducing the duplication of reporting.
	Yes
	PGE supports the DSR SDT's efforts to bring clarity and guidance to the spectrum of sabotage-type events.
	Individual
	Gregory Miller
	BGE
	Yes
	We have no problem with NERC using the existing guidance as the foundation for disturbance reporting; however, since this project proposes to investigate incorporation of the Cyber Incident reporting aspects of CIP-008, we feel that if adopted, this concept should be added to the NERC Guideline document "Threat and Incident Reporting".
	No
	As currently worded, BGE opposes the reporting hierarchy concept, since insufficient guidelines were proposed to prevent translation errors between the responsible entity (RE) and the RC. In addition to creating possible reporting errors, this also opens a risk that the RC could misrepresent the true intent of an RE's report contents if called upon to explain/justify a submitted report. Reporting delays are another concern with this proposal because the RE would basically be relinquishing control of the reporting process to the RC, while ultimately retaining the responsibility for ensuring the report gets submitted within the required timeframe. However, BGE recognizes that avoiding duplication and conflicting reports as well as encouraging communication are valuable. To make the reporting hierarchy concept acceptable to BGE, the DSR SDT must develop proper controls to ensure the RE has the ability to control or approve the information submitted and/or subsequently discussed with the respective authorities, and that it is done within the permissible timeframe to satisfy compliance requirements.
	Yes
	One form makes sense to us; less is better is the sense that it makes filing reports easier by not creating unnecessary complications.
	Yes
	We agree with this approach, as long as the latest version of the DOE OE-417 form is fully incorporated in the new single-reporting form, so that it maintains its credibility with the DOE.
	Yes
	We agree that "the spectrum of all sabotage-type events is not well understood throughout the industry"; however, we feel that the proposed concept of an "Impact Event" falls short of clarifying what constitutes such events. We believe that "Impact Events" needs further clarification to eliminate "gray areas" and to provide more reporting consistency between entities.
	We are not aware of any regional requirements beyond the scope of CIP-001, CIP-008 and EOP-004.
	1. If we move to a "one size fits all" single reporting form, it is important that the form be properly developed to cover any foreseeable event, which appears to be the intent of the DSR SDT, as outlined on page 4 of the concept document. Such an approach should also incorporate a single point of contact for reporting information, to avoid any confusion. 2. We would like clarification that any proposed CIP-008-related reporting requirement (including any linked reporting requirement between CIP-008 and CIP-001) is only applicable in situations where the incident/event involves a registered entity's Critical Cyber Asset.























	Individual
	Dan Roethemeyer
	Dynegy Inc.
	Yes
	We agree with using the guidance; however, please consider revising the NERC Guideline: Threat and Incident Reporting document to (i) lengthen the reporting timelines related to attempted sabotage to allow for additional time to deem the threat credible, (ii) expand the description of forced outage of generation greater than 2000 MW to include whether it is at the BA or GO level and if GO level, whether it is for one site or the combined GO's sites in a Region, and (iii) add a Responsible Party column to the Appendix A matrix.
	Yes
	This seems to be straightforward approach in that the RC is the best judge of threats to the overall system and could eliminate multiple reports of a single event.
	Yes
	Please keep it short and simple.
	Yes
	Short and simple should be the goal.
	Yes
	We agree with the concept but please provide specific examples. Also, please consider whether there are any penalties for misinterpreting an incident, who would determine if an event was a threat, and whether this could result in over reporting non-threats.
	Please consider MISO RTO-OP-023.
	N/A
	Group
	Electric Market Policy
	Dominion Resources Services, Inc.
	Yes
	Yes; however, in considering guidance found in the document "NERC Guideline: Threat and Incident Reporting" the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
	Yes
	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System.
	Yes
	Yes, we agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC.
	Yes
	Yes, we agree with the objective of eliminating duplicate reporting; however, EOP-004 currently allows substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today.
	Yes
	We believe that physical and cyber events must be investigated before a determination of sabotage or impact event can be made.
	SERC and RFC are developing additional requirements at this time. We suggest that reporting be based on impact to reliability, not on 'newsworthy' events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirements.
	a. NERC should focus efforts on developing specific event reporting criteria and not base the requirement on the definition of the term 'sabotage' but on the reporting criteria itself. b. The "opportunities for efficiency" discussed in the Concept Paper would be best achieved by focusing on those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. If there are elements that need to be reported that do not support this objective, than that reporting should not be required in reliability standards.
	Individual
	Rick Terrill
	Luminant

	No
	While the guidance is generally ok in the “NERC Guideline: Threat and Incidence Reporting”, the reporting timelines include 1 hour, 2 hours, 4 hours, 6 hours, 8 hours, 24 hours, and 48 hours. Please simplify and reduce the variation in timelines. When it comes to Sabotage reporting, some time requirements start with detection, some start with determination of sabotage and some events do not specify the trigger for the reporting clock to start. Again, please provide clarity and consistency around the start of the timeline for reporting. Generally, the reporting timing should start with the recognition or determination that a suspected or known sabotage event occurred.
	Yes
	Luminant believes that one report should be filed with the Reliability Coordinator or one responsible entity, who then files the report with all applicable entities.
	
	Yes
	Luminant agrees with the concept of reducing reporting requirements, but asks the SDT to go even further. In the concept paper, the SDT discussed that information would not be duplicated on the NERC report and the DOE OE-417 report. The concept paper described a process where one report would simply supplement the other, but two reports would still be filed when required. Can the NERC SDT work with the DOE to develop one report to meet the needs of NERC and the DOE?
	No
	Luminant would prefer to report disturbances and sabotage events. The reporting of impact events could lead to unnecessary reporting. A definition of an “impact event” may be even more confusing than sabotage events.
	
	Luminant disagrees with the direction of utilizing impact events, as this is an expansion in scope beyond the simplification of sabotage and disturbance reporting.
	Group
	MRO’s NERC Standards Review Subcommittee
	Midwestreliability Organization
	No
	We agree with using the present documentation but would like just one reporting form. We are concerned that the guidelines and reporting periods specified within the DOE OE-417 report conflict with the NERC Guidelines. For example, DOE OE-417 report requires “Suspected Physical or Cyber Impairment” to be reported within 6 hours. The NERC guidelines indicate “Suspected Activities” are to be reported within 1 hour. We recommend the SDT use the DOE OE-417 report as a guiding document, and then determine additional reporting requirements using guidance from the NERC Guideline. FERC Order 693 appears to indicate conflicts and confusion with NERC reporting requirements and DOE reporting requirements should be eliminated.
	No
	We agree a coordinated reporting process is beneficial for the entity and the Reliability Coordinator (RC). However, a hierarchy would likely lengthen the reporting timeframe, or reduce the allotted time for each entity to provide notification to the RC in order to meet DOE or NERC timelines. Communication and coordination with the RC would likely provide more accurate and complete data submissions within a timely process and create shared accountability for the report being submitted.
	Yes
	However, We believe the primary goal should focus on “each entity” being able to submit one report for all functional requirements. Entities in the US that are required to submit the DOE OE-417 form should not be required to submit an additional form developed for other entities (Canada & Mexico). One approach to satisfy this goal is for NERC to require all entities (US, Canada, & Mexico) to complete the DOE OE-417 form as their report.
	Yes
	We agree with the concept to eliminate duplicate reports. However, we are concerned with the reference of the DOE OE-417 report being a “supplement” of the NERC report rather than “accepted” as the NERC report.
	No
	Rather than attempting to define a new term (impact event), we suggest that the concept of impact event be replaced with further defining sabotage and providing guidance on trigger events (impact event) that would cause an entity to report.
	No Comment.
	Confusion often arises in the industry between the CIP standards and other reliability standards based on CIP-001 naming convention. We would suggest the SDT retire CIP-001 and incorporate requirements within the EOP-004 standard or a new EOP-xxx standard to avoid confusion rising from CIP and other NERC Reliability Standards. Additionally, we assume the SDT has been created to specifically address FERC Order 693 directives to the ERO which appears to include the following items: 1. Applicability – “possible revisions to CIP-001-1 that address our concerns regarding the need for wider application of the Reliability Standard... the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate” (FERC, 2007, para. 460). 2. Definition of Sabotage – “we direct that the ERO further define the term and provide guidance on triggering events






	<p>that would cause an entity to report an event... we believe the term sabotage is commonly understood and that common understanding should suffice in most instances... the ERO should consider FirstEnergy's suggestions to differentiate between cyber and physical sabotage and develop a threshold of materiality." (FERC, 2007, para. 461-462) 3. Periodic Review and Testing – "directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures." (FERC, 2007, para. 466) 4. Redundant Reporting – "now direct the ERO to address our underlying concern regarding mandatory reporting of a sabotage event... Regarding the potential for redundant reporting under CIP-001-1 and other government reporting standards, and the need for greater coordination... We direct the ERO to explore ways to address these concerns – including central coordination of sabotage reports and a uniform reporting format... with the appropriate governmental agencies that have levied the reporting requirements." (FERC, 2007, para. 468-469) 5. Specified Time – "the Commission directs the ERO to modify CIP-001-1 to require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specified period of time... the ERO should consider suggestions raised... to define the specified period for reporting an incident beginning from when an event is discovered or suspected to be sabotage" (FERC, 2007, para. 470). 6. Summary of CIP-001-1 – "the Commission directs the ERO to develop the following modifications... (1) further define sabotage and provide guidance as to the triggering events... (2) specify baseline requirements regarding... procedures for recognizing sabotage events... (3) incorporate a periodic review... and for the periodic testing... (4) require an applicable specified period of time. In addition... address our concerns regarding applicability to smaller entities... consolidation of the sabotage reporting forms and the sabotage reporting channels with the appropriate governmental authorities to minimize the impact of these reporting requirements on all entities." (FERC, 2007, para. 471) 7. Analyze Performance – "at a minimum, generator operators and LSEs should analyze the performance of their equipment and provide the data... The Commission directs the ERO to consider this concern in future revisions... that includes any Requirements necessary for users, owners and operators... to provide data that will assist NERC" (FERC, 2007, para. 613, 617). 8. Reporting Time Frames – "The Commission directs the ERO to change its Rules of Procedures to assure that the Commission also receives these reports within the same time frames as the DOE." (FERC, 2007, para. 618)</p>
	Individual
	James Stanton
	SPS Consulting Group Inc.
	No
	At least not exclusively. The current standards and the guidance fail to consider that different registered entities will have different scopes of awareness for when disturbances may take place. We want to avoid the situation where a generator (for example) is cited for failure to report a disturbance of which they have way of knowing occurred.
	Yes
	
	Yes
	There should have probably been one report all along.
	Yes
	Duplication is inefficient and casts the whole reporting mechanism in a questionable light.
	Yes
	The term sabotage was always too narrow a concept for the standards. At times, questionable activities are not confirmed as sabotage events until well after the fact, forcing the registered entity to speculate on whether or not to report an activity that may not be a confirmed sabotage event at the time, and hence encounter another silly violation based on imprecise terminology.
	
	Again, please consider the unique scope of the entities to which these standards are to comply. Don't dump all the requirements on all the applicable entities and perpetuate the current practice of forcing them to parse the requirements into what is logical or illogical from their perspective. The drafting team should have the expertise to do this. Identify which requirements apply to which applicable entity.
	Individual
	Andrew Gallo
	Calpine Corp.
	Yes
	
	Yes
	A Functional Entity such as a Generator Owner/Operator is not always aware that an event, such as a plant trip, is part of a wider system disturbance that rises to the level of a reportable event under EOP-004. A reporting hierarchy that allows a Generator to report the facts to its Transmission Operator and have that entity take a wider view to determine whether there is a disturbance should facilitate the reporting of actual disturbances. The SDT needs to ensure that some thought goes into the flow of information within the hierarchy and what triggers are needed to drive the reporting up the hierarchy.

	Yes
	A single approach is desirable, particularly for those entities that find themselves in multiple regions or countries.
	Yes
	Clarification, simplicity and the removal of duplicate reporting is beneficial.
	Yes
	Individual
	Steve Alexanderson
	Central Lincoln
	No
	The guidance document makes no distinction between entities that operate 24/7 dispatch and those that don't. The 1 hour and even the 24 hour reporting requirements in some cases will be impossible for entities without 24/7 dispatch to meet without changing business practices. These are the same entities that present little or no risk to the BES.
	Yes
	In the west at least, this hierarchy should be extended to include BA's as indicated in the Concepts Paper. See <a href="http://www.bpa.gov/corporate/business/reliability/Docs/2007/PNSC_RE_Data_Letter_2_070723.pdf">http://www.bpa.gov/corporate/business/reliability/Docs/2007/PNSC_RE_Data_Letter_2_070723.pdf</a> for the RC's policy on which entities it chooses to communicate with.
	Yes
	The existing reporting is needlessly complex. We appreciate the SDT's goal.
	Yes
	The existing reporting is needlessly complex. We appreciate the SDT's goal.
	Yes
	An act of vandalism may have impact. An act of sabotage may not be impactful alone, but may be part of a wider coordinated attack. Dictionary definitions speaking of "intent" are not helpful in this regard, since acts of vandalism and sabotage are both generally committed intentionally. Saboteurs, though, work for a higher cause. That cause may be political, social, environmental, etc. We ask that the SDT look beyond dictionary definitions in developing a definition of sabotage.
	Individual
	Brenda Frazer
	Edison Mission Marketing & Trading
	Yes
	Yes
	Yes
	With the realization that having a common report form may be difficult to coordinate between different agencies.
	Yes
	No
	There are too many special circumstances to try and capture. I feel this would be best delivered as a guideline.
	I don't know of any.
	No other comments.
	Individual
	Martin Bauer

	USBR
	Yes
	The reporting outlined in the proposed plan does not include a clear indication of how NERC will use the information they collect from the entities. Care needs to be taken in addressing the reporting requirements to not create a more confusing or onerous reporting process.
	No
	The existing reporting methods collect reports of disturbances and analyze them by committees of the respective coordinating councils. The new process would introduce a duplicate layer and associated staffing. It would be better to ensure communication between the existing committees of the respective coordinating councils and the RC rather than creating a new layer of review tracking and analysis. While the layered reporting hierarchy discussed in the Disturbance Reporting section of the paper will eventually help with overall event awareness, the additional delays the hierarchical approach could result in a decrease in situational (timely) awareness. Having more comprehensive information as a result of the potential enhancements each layer adds to the chain of reporting may not be more valuable than timely and well disseminated information in an actual disturbance situation. We would suggest the SDT give careful consideration to this proposed direction. It may be appropriate to consider that expedited reporting of operational impacts would outweigh the benefit of administratively intensive reporting procedures. The events reported through the existing process have not yielded material feedback other than statistical analysis. Statistical analysis is not as sensitive to timely reporting. Operational impacts which may be the result of possible sabotage may be evident through assessment of widespread outage patterns or following event analysis. Comprehensive event analysis can take anywhere from 15 days to 90 days depending on the event.
	Yes
	The Bureau of Reclamation utilizes a form for tracking unexpected events. This form contains information which the agency considers important for its one reliability improvement program. The form is also used to meet NERC standard requirements for protection system operations analysis. This form contains most of information required by DOE. The SDT should consider requiring the submission of specific information rather than lock responses in one specific form. In this manner the agency would be avoid duplicate forms, one for NERC, the other for agency purposes.
	Yes
	It should be clear what information is to be supplemented. The fewer times the information has to be handled the more efficient the process becomes. If the information exists on a required form, that legal form should be allowed. Also, if the form is already submitted, then reference to it should be sufficient rather than requiring resubmission of the form. That would require handling the information again. As explained in the previous answer, the SDT should recognize that responsible entities have already developed internal reporting processes which utilize forms for consistent responses. Those forms may contain more information than is needed by the new standard to be proposed. The entity should be allowed to submit the internal form or else duplication would be created, which may reduce the effectiveness of an entities reliability improvement program.
	Yes
	There should be a clear distinction between a cyber event and a cyber event that has a material impact on the reliability of the bulk electric system. Not all CIP-008 events will carry such a distinction. That being said, CIP 008 cannot be completely incorporated in this process. Denying access to a cyber asset is noteworthy under CIP008 but may not pose a threat to the reliability of the bulk electric system. Consider recognizing the impact on the bulk electric system when modifying definitions of adding the bulk electric system description to the definitions. This will help to clarify that disturbances, as discussed in this effort, are situations that produce an abnormal condition on the electric power system, not necessarily on ancillary or supporting systems, such as SCADA systems or the water-related systems at hydroelectric dams.
	
	The concept of "threat" evaluation criteria is somewhat vague and a great care is needed to ensure it is clear enough that the most individuals would be able to analyze an event and end up at the same threat. Otherwise it would be almost impossible to ensure compliance with a requirement which cannot accurately describe criteria to be used to ensure that proper evaluation has occurred.
	Individual
	John Alberts
	Wolverine Power Supply Cooperative, Inc.
	Yes
	I agree with referencing existing guidelines - However: My concern is that, until all reportable incidents are analyzed by the parties to which they are reported, their "impact" on the BES will not be quantified. Therefore, the tendency to want to "report all events so that their impact can be determined" or "report all events because the information can be utilized for informational purposes, regardless of impact on BES" might lead to expanded reporting requirements, some of which may have questionable value from a reliability standpoint.
	Yes
	From the perspective of a TOP, this seems to alleviate reporting burden and move it upline. I can understand the logic in wanting the reporting to flow through the RC for awareness purposes, but I can understand the RC's reluctance to bear the additional potential burden. Again, a focused effort to minimize the necessary reporting to "true impact events" should be kept in mind. regardless of who has to report. Collecting reams of data and figuring out what
























	impact it has later should not be the goal.
	Yes
	I can't see how anyone would disagree with this concept - However - I question how practical it will be to implement, since various agencies would have to collaborate and coordinate to accomplish this task.
	Yes
	I agree with the concept of minimizing duplication - See previous question 3 for concerns.
	Yes
	I agree with the concept of focusing on impact instead of the type of event (sabotage, accident, vandalism, etc.) I hope that the reporting proposal that comes out of this project will clearly make a separation between true impact events that must be reported per the standards (enforceable), vs. "other" information that may be (electively - not enforceable) reported, per some set of guidelines.
	The concepts of removing duplication, consolidation, and focusing on "impact events" sound logical. I am concerned that the focus may drift to expanded reporting, not reduced reporting.
	Individual
	Thad Ness
	American Electric Power
	Yes
	Yes
	This approach may work as long as there is a uniform process across all of the Reliability Coordinators. AEP owns and operates BES facilities under three separate RCs and having differing rules and processes would create confusion and additional burdens. There are some concerns about the time lag of reporting the information and this might not work well in all cases especially if the information and knowledge are at the local level. AEP recommends that the standard could have a default hierarchy, but this should not prohibit any entity from reporting directly.
	Yes
	Yes
	Yes
	Individual
	James McCloskey
	Central Hudson Gas & Electric
	Yes
	Central Hudson agrees with using the "NERC Guideline: Threat and Incident Reporting" in the development of requirements. Central Hudson has currently in place a NERC-DOE Threat and Incident Reporting Table developed from this NERC Guideline that allows for a quick-reference to all threat and incident reporting criteria (arranged by category) with a cross-reference to the specific reporting form (NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report, DOE Form OE-417, or NERC ES-ISAC Threat and Incident Report Form). Central Hudson recommends maintaining the option of utilizing only 1 form, the DOE Form OE-417, for incidents that require reporting to the DOE and NERC to maintain the streamlined approach to this reporting process.
	Yes
	Central Hudson agrees with this reporting hierarchy for disturbances given the "wider-view" of the Reliability Coordinator as opposed to an entity such as a Transmission Owner or Load-Serving Entity. While, based on past experience, the current process works if reports are filed to the DOE, RRO, and RC simultaneously via email for example. However, the RC is in a better position to identify multi-site incidents and escalate the reporting process if necessary.
	Yes
	Central Hudson agrees with this goal if the intent is to develop and implement an electronic version that would meet DOE requirements as well.
	Yes

	Central Hudson agrees with this concept and, as stated in a previous response, recommends that the ability of utilizing the DOE OE-417 to supplement the NERC report be maintained.
	Yes
	Central Hudson agrees with this concept, particularly if the reporting hierarchy through the RC is implemented in order to better identify trends.
	Although not beyond the scope of these standards, NPCC maintains a document and reporting form (Document C-17 - Procedures for Monitoring and Reporting Critical Operating Tool Failures) that outlines the reporting requirements, responsibilities, and obligations of NPCC RCs in response to unforeseen critical operating tool failures.
	The NERC Guideline: Threat and Incident Reporting Attachment A matrix is an extremely beneficial document that organizes reporting criteria. However, it identifies communications systems failure sub-category under the Equipment And/Or Systems Failure category as reportable with a reference to OE-417 - Schedule 1, Item 10. Item 10 on Schedule 1 addresses only failures due to attacks (not failures for other reasons).
	Individual
	Deborah Schaneman
	Platte River Power Authority
	Yes
	Yes
	Situational awareness would be enhanced. All affected entities would be aware of the disturbance and relevant information. Also, the flow of information between entities would be enhanced and a more comprehensive report could be developed.
	Yes
	Yes
	Yes
	Individual
	Howard Rulf
	We Energies
	No
	While the NERC Guideline includes readily discernible information (and we would like to see that format carried forward into any future documentation), utilize OE-417 as the foundation document in order to eliminate reporting redundancies. If supplemental references are necessary for the proposed resolution, list the document as an official attachment to the standard. Minimize the need to search in multiple locations for guideline information – some may not be aware supporting documentation exists without explicit reference within the standard.
	Yes
	A hierarchical approach in conjunction with a single, electronic form would provide consistent reporting timelines, provide clarity in the reporting process, and provide more accurate and meaningful data submissions while having shared accountability. Confusion in the current method could be alleviated while providing more consistency in the reporting of an "impact event".
	Yes
	Agree in conjunction with proposed concept that DOE OE-417 will be allowed to supplement the NERC report in lieu of duplicating entries.
	Yes
	However, also evaluate whether or not DOE OE-417 is sufficient in lieu of a NERC report. If additional information is required, duplicate format of DOE-OE-417 with additional NERC information listed at the end of the form.
	Yes
	We would prefer to refer to all sabotage, vandalism, cyber attacks, and other criminal behavior as impact events. Focusing more on the event's impact on reliability and its ramifications on the systems seems to be more useful than to try to determine the intent of the perpetrator.
	What is meant by beyond the scope of the referenced standards? We Energies also has reporting obligations with the MISO RC (MISO OP-023), RFC (PRC-002-RFC-01), and the Wisconsin and Michigan Public Service Commissions.

	<p>Give consideration to combining CIP-001 and EOP-004-1 through a common categorization. For example, "System Risk Reporting" could encompass both actual and potential events and would minimize the need to cross reference both standards, and provide one location for event and potential-event reporting. Much of the challenge in this project is in achieving a common understanding of the words sabotage and terrorism. There are nuances of meaning in the words that imply a relationship between the attacker and the victim, or a motive other than simple profit or mischief. This nuance of meaning requires the victim of the damage to discern a relationship or motive which may not be discoverable in the relatively brief time window during which the entity must report the event. In fact, they may never be known. Consequently, We Energies recommends elimination of the words sabotage and terrorism from these standards. We also recommend elimination of the word vandalism since it also implies an ability and duty to discern whether a particular act (barbed wire thrown over transformer bushings) was done out of pure mischief (vandalism) or with intent to destroy equipment for a political purpose (terrorism). And if the act was committed by a disgruntled employee, it becomes sabotage. No wonder there is confusion and indecision. Instead, We Energies recommends using the simple words "criminal damage". One need not be a prosecuting attorney or FBI Special Agent to know what this means. Simply ask, "Does it look like somebody damaged it (or hacked in) intentionally?" and, "Did we give consent?" and you're done. With elimination of sabotage, terrorism and vandalism, and all of their baggage, comes the ability to integrate both CIP 001 and EOP 004. We now have criminal damage (or cyber attack) as just another event to be evaluated against certain pre-defined impact measures. No value judgments, no speculation. Another benefit of using these simple words and tests is that operating personnel, whether in the field or at the console, will not require special awareness training in discerning these nuances of meaning. They already have experience with the equipment or cyber systems and its normal performance. Operating personnel can readily assess whether an impact event is due to equipment failure, weather or animal contact vs. intentionally caused by a person. If it appears to be criminal damage, call the local police agency. Report the event and the impact. Cooperate with the investigation. Share your knowledge of the normal condition of the equipment or performance of the system. Share your experience with similar events. It will be important to highlight that the theft of all the grounding pigtailed in a substation is different from the act of simply snipping each of them to leave the equipment electrically floating. The technical condition is the same, but this allows the police to make an inference with respect to motive, suspect profile, sophistication, etc. That's their job. They may ask us to speculate on the motive or skills of the attacker. That's okay. But at least we don't have to know or guess at it for the purpose of determining whether to report the event. No training required. With respect to notification to the FBI, We Energies recommends that the standard merely state that the owner of the damaged asset ensure the local office of the FBI is notified. The standard should permit documentation of either a direct phone call by the asset owner or obtaining an assurance from the local police that they will do so. There should be no need to prove earlier establishment of a relationship with the FBI. There should be no expectation that the entity have a signed letter from the FBI Special Agent in Charge acknowledging his agency's duty. This document means nothing. With respect to reporting within the industry, We Energies recommends that the only events to be reported "up the chain" are those that we choose to characterize as "impact events". That is, the events that meet some measurable threshold with respect to BES impact. We should describe these efficiently to avoid over-reporting of trivial events. It is apparent that we are already over-reporting since DHS HITRAC recently fed back to the industry that copper thieves attacked a substation in San Bernardino, CA taking some of the grounding conductors. The industry should have the option to report non-impact events that are unusual in some respect and which may have some mutual industry benefit in terms of prevention, awareness or recovery. Attack attempts with no impact, or observations of suspicious activity could fall into this optional category. These optional reports could be aggregated by the entity for the purpose of detecting patterns or trends, or be reported ad hoc. The ES-ISAC should be the recipient of the reports. It should be the single point of contact since it has the industry insight, engineering expertise and cross-sector relationships to analyze and return valuable intelligence to the industry. With the ES-ISAC as the recipient of the reports, efficient sharing with Federal agencies, with the regional entities and with neighboring asset owners could be automated and rapid. There is much benefit to be gained from this project, primarily in the area of creating clarity and uniformity. There is some risk that the reporting requirements will become onerous and prescriptive.</p>
	Individual
	Jianmei Chai
	Consumers Energy Company
	No
	<p>The existing guidelines ignore the fact that there are currently three overlapping and inconsistent reporting requirements for disturbances of various types: CIP-001, EOP-004, and DOE OE-417. The reporting should be such that any single event type needs to be reported only once, and to only a single agency, for any disturbance. First, CIP-001 events should be reported to the ES-ISAC under one specific requirement (or set of requirements) and removed from OE-417 and EOP-004, such that all interested agencies obtain their information from only that one source. Second, OE-417 events should be reportable ONLY to DOE, and, again, other agencies should obtain their information from only that one source. If NERC wishes to make such reporting mandatory and enforceable, the NERC requirements should indicate ONLY that such reporting should be made in accordance with OE-417. Finally, EOP-004 (or similar requirements) should require reporting to NERC ONLY in the case of events that don't fit under CIP-001 or OE-417 requirements. Alternatively, OE-417 should be submitted ONLY to NERC and they should disseminate the information. EOP-004 has several issues and inconsistencies: a. EOP-004 requires that the entity that submits form DOE-417 to provide copies to NERC. The DOE-417 form intermixes NERC entity definitions (e.g. BA, LSE, TO) with generic terms such as "Electric Utilities" and "Generating Entities". Is it the Generator Owner or Generator Operator that is required to submit the information? There should be one form or at least well defined definitions that apply to both forms. b. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change this requirement to 1 hour for several disturbances. Additionally, it incorrectly summarizes the reporting time for 50,000 customers, which is 6 hours in DOE-417 and summarized in Table 1-EOP-004-0 as 1-hour. An attachment to a standard should not be allowed to supersede the standard or create additional rules. c. EOP-004-1 R3.1 requires submittal within 24 hours. however Table 1-EOP-004-</p>



	0 which purports to summarize the standard appears to change the standard. R3.1 clearly states that events are to be reported within 24 hours of identification, however Table 1-EOP-004-0 state that the events are to be reported on the basis of the start of the disturbance. An attachment to a standard should not be allowed to supersede the standard or create additional rules. d. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change the standard. R3.1 clearly states that events are to be reported within 24 hours of identification, however Table 1-EOP-004-0 states that copies of DOE-417 are required to be submitted "simultaneously". It also states that schedules 1 and 2 are due within 24 hours of start of the event instead of 48 hours for per DOE-417 for schedule 2. An attachment to a standard should not be allowed to supersede the standard or create additional rules. e. The requirement of loss of customers should be scaled based on customers served. Loss of 50,000 customers to a utility that serves 100,000 customers is different than loss of 50,000 customers to a utility that serves 2,000,000 customers.
	No
	It would be inefficient for RC's to accumulate ALL disturbance data and submit it, and to bifurcate the reporting based on type of disturbance above and beyond OE-417 data (which should go ONLY to DOE) would make a standard very involved for an entity to comply with. We're discussing after-event data here, not data needed for current operations – and there's no reason to make it any more complicated than necessary.
	Yes
	Agreed – to the extent that it's consistent with the concept that any specific type of data is submitted to ONLY one entity.
	No
	NERC should either coordinate with DOE for a single reporting process or simply adopt the DOE's standard.
	Yes
	We agree with the concept, however, based on the information provided, it may be too vague to be of value. Terms such as "potential" and "significant" can be subjective and therefore provide little direction. We would like to see something more specific. Also, inclusion of the destruction of BES assets may be too inclusive and needs to be restricted to BES assets that will cause a specific level of impact on reliability.
	Group
	Western Electricity Coordinating Council
	WECC
	Yes
	It is comprehensive; however, we must keep in mind that the OE-417 is required under Public Law 93-275 and needs to be attached if applicable in the US.
	Yes
	There should be an established time sequence that allows the RC to review the entities material prior to forwarding to NERC. By channelling all reports through the RC situational awareness will be enhanced. Instead of "submit information", it should be clarified that entities submit complete written reports to RC in electronic format.
	Yes
	Canadian and Mexican entities should be consulted on content of report form to assure their "buy in".
	No
	This will work well for the USA entities to save us time in re-entering the same information. We believe that FERC and NERC and the Regions should have one common reporting form for North America. The OE-417 is not required by law outside of the United States. Canadian and Mexican entities may feel that US DOE has no jurisdiction in these countries, and therefore no right to required reporting as is stated on the OE-417.
	Yes
	This will help eliminate regional differences in sabotage reporting. The definition should be broad enough so it covers new types of sabotage that may evolve. Event analysis facilitates situational awareness and if it requires further investigation regarding developing patterns and severity, it should be handled by law enforcement if need be.
	There is a need to learn what reporting requirements are required by the Mexican and Canadian entities.
	As stated previously, for "One stop shopping" we need "buy in" from the foreign nationals. The way to do this is to engage their opinions and respect their jurisdictional agencies as well.
	Individual
	Amir Hammad
	Constellation Power Source Generation
	Yes
	The existing guidance is an excellent base on which to build changes to EOP-004 and CIP-001. However, the SDT

	must challenge each item in the different event categories and clarify or omit bullet points that are seemingly vague. For example, under System Disturbances, a forced outage report is needed when "a generation asset of 500 MW or above is on a forced outage for unknown reasons, or a forced outage of generation of 2,000 MW occurs..." Simply removing the 500 MW criteria would make this criterion less vague. There are other examples of this in the guideline.
	Yes
	As stated in the concept paper, a hierarchy ensures proper communications, but it has the added benefit of reducing redundancy on the Registered Entities, so long as responsibilities and accountability are clearly established.
	Yes
	
	Yes
	Constellation agrees with the concept of eliminating the need to file duplicate reports. If the single NERC reporting form is both comprehensive and easy to use, then using a single report should not be an issue. It is essential that all elements of DOE OE-417, and any similar documents, be incorporated into this single report. Not incorporating all elements will result in gaps in reporting for all Registered Entities.
	No
	Although defining an impact event would bring clarity to defining sabotage events, adding another situation would further complicate things. Furthermore, the examples of impact events used all fall under the Sabotage category in the Threat and Incident Reporting Guideline. Constellation Power Generation suggests the SDT further clarifies the items in the Sabotage category to ensure all grey area situations are included. Clarification is also needed in how a Cyber Security Incident (CIP-008) would map into the categories of Disturbance/Impact Events (CIP-001). To that point, Constellation Power Generation questions whether cyber related incidents should fall under the spectrum of sabotage type events, or remain separate and be incorporated in the CIP revisions. Having cyber related incidents separate from other sabotage events would provide the clarity and guidance that the DSR SDT is striving to achieve.
	
	Constellation Power Generation would like clarification that any proposed CIP-008-related reporting requirement (including any linked reporting requirement between CIP-008 and CIP-001) is only applicable in situations where the incident/event involves a registered entity's Critical Cyber Asset. In that vein, we want to emphasize the importance of the DSR SDT working with the CIP SDT on the cyber related events. If the DSR SDT is going to be adding clarity to cyber related events, then coordination with the CIP SDT is needed to ensure the same verbiage is being used. Furthermore, having any duplication of requirements will cause a double jeopardy scenario which would go against the SAR for the DSR SDT. As stated earlier, Constellation Power Generation also questions whether cyber related incidents should fall under the spectrum of sabotage type events, or remain separate and be incorporated in the CIP revisions.
	Group
	Public Service Enterprise Group Companies
	PSE&G
	Yes
	EOP reportable disturbances are familiar concepts in the industry.
	Yes
	The PSEG Companies believe that all entities with a reportable disturbance should report to the RC. The RC is best positioned to evaluate the impact of the event and forward the information to the appropriate entities. There should not be any intermediate entities to relay information to the RC as that can introduce delay and has the potential to introduce transcription errors. Sabotage events should be reported to the RC as well as to law enforcement. CIP-008 reporting is highly specialized and should be retained in the set of cyber security standards, not merged with CIP-001 and EOP-004.
	No
	While simplification and consistency is a laudable goal, it should not be applied to different governmental agencies (USA, Canada, Mexico) which may have different structures and processes. Moreover, results based standards should not include administrative matters such as reporting forms.
	Yes
	The PSEG Companies agree with the avoidance of duplicate reports. NERC report forms should not include anything in the DOE form, and NERC Regional report forms should not include anything in the DOE or NERC forms. Hence, a DOE report should not "supplement" a NERC form, but rather replace it unless the NERC form calls for other information for the same reportable incident, and likewise for the DOE - NERC - Regional form structure. DOE forms would be filed with DOE, NERC and the Regional Entity where the event originated. NERC forms would be filed with NERC and the region where the event originated and the Regional form filed only with the Region. In designing the NERC and Regional forms, the need to file multiple reports should be minimized, and in no event should any of the three (DOE, NERC, Region) forms contain duplicative information requests.
	Yes
	The PSEG Companies agree with the concept, but reserve judgment on the descriptions of the impacts. There is clearly a need to better define what constitutes a sabotage incident versus common theft or vandalism. Moreover,
















	where it may be impossible to determine if any given incident (e.g., several loose bolts on a transmission tower cross brace could be sabotage or could be human error in construction) falls within sabotage, a registered entity should not be second guessed in an audit if the registered entity determines not to report. Excessive unnecessary reporting can mask real incidents.
	The PSEG Companies believe that RFC is developing a regional disturbance reporting requirement for events not meeting the criteria of current DOE and NERC reports.
	If reporting does become the responsibility of the Reliability Coordinators, the RCIS should be made available view-only to registered entities with a notification when RC's have posted new entries. That will enhance the situational awareness of registered entities. The PSEG Companies disagree with inclusion of CIP-008 reporting requirements as part of the CIP-001 and EOP-004 initiative. CIP-008 reporting as part of the cyber security set of NERC standards is usually managed by specialized corporate organizations separate from those involved with the other NERC standards, and with highly specialized cyber skill sets. CIP-008 reporting requirements should remain where they are, and any perceived need for improvement addressed in the ongoing CIP Version 4 development process.
	Individual
	Greg Rowland
	Duke Energy
	Yes
	No
	The RC should not be responsible for submitting the report to FERC, NERC or the RRO. The RC may not have the necessary first hand information concerning the facts of the event. Situation awareness can be maintained by including the RC in the distribution of any sabotage related reporting.
	Yes
	There should only be one report for all functional entities to submit to NERC.
	Yes
	Since the OE-417 is a DOE required report, it must be submitted. Including the OE-417 as part of the NERC electronic form will facilitate reporting to NERC.
	No
	As FERC ordered in Order No. 693, the drafting team should further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event. Suggested definition: "Sabotage – the malicious destruction of, or damage to assets of the electric industry, with the intention of disrupting or adversely affecting the reliability of the electric grid for the purposes of weakening the critical infrastructure of our nation."
	None
	We don't think CIP-001, EOP-004 and cyber incident reporting aspects of CIP-008 should all be combined into one standard, because of the significant differences between sabotage and disturbances. We have suggested that the drafting team further define sabotage, and we have included a suggested definition in our response to question #5 above. Sabotage is very specific due to the intent (for the purpose of weakening the critical infrastructure), and the potential impact to the BES. We believe that sabotage and cyber incident reporting should remain a part of the CIP Standards due to the emphasis placed on the criticality and vulnerability of the assets needed to support reliable operation of the BES. Cyber Security and Physical Security could be placed together in the same standard (remain in CIP) and other disturbances (i.e., accidental, natural) in a separate standard. "One stop shopping" for reporting is still possible as long as the OE-417 form is included as part of the NERC electronic form. And while we agree with the need for additional clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities.
	Group
	ERCOT ISO
	ERCOT ISO
	Parts of the Guideline are helpful, but the guideline goes beyond the scope of the requirements of the current standards, which could pose potential audit concerns. ERCOT ISO strongly feels this approach for reporting should be focused on physical events only and cyber event reporting should be contained within CIP-008 only. Continue to keep physical separate from cyber.
	No
	There are some events that are truly local and should be handled by local entities and reported to local authorities (i.e. theft). If there is an impact or potential to have an impact to the BES or to the region, then hierarchical reporting would be appropriate.
	Yes

	Standardization ensures consistency and relevance of the information received.
	ERCOT ISO agrees with the concept of eliminating the need to file duplicate reports, but as stated in the Concept Paper, the DOE form (OE-417) is required by law. Based on this, the elimination of EOP-004 (after the fact reporting) is essential, since the OE-417 is mandatory and all-inclusive.
	ERCOT ISO recognizes the risks associated with "gray areas" not being clarified. While "gray areas" pose compliance risk due to differing interpretations, a risk remains that some items will go unreported. A more prescriptive approach raises an even greater risk of events not being reported. People will not report events that are not specifically listed, and will not use judgment in determining the need for reporting.
	All references to CIP-008 should be removed and we reassert that physical and cyber reporting should be separate. There is documentation available from the CIPC that the drafting team considered CIP-001 related physical sabotage reporting and specified cyber incident reporting requirements in CIP-008. ERCOT ISO requests the DSR SDT to continue to improve its guidelines and to post those guidelines for all to use, but not to create sanctionable standards whose good intentions could result in unintended adverse consequences for the Industry. ERCOT ISO also suggests that all reporting forms and guidance should be located in a central, easily accessible location, eliminating confusion and simplify reporting for system operators thereby directly enhancing reliability during system events. The industry would benefit from a central location or link on the NERC website containing all reporting forms.
	Group
	ISO RTO Council Standards Review Committee
	IESO
	Yes
	The guidelines in EOP-004 and its attachments should be retained as the foundation for reporting disturbances. One would note that such EOP Disturbances are relatively well defined reliability impacts. Thus EOP-004 disturbances are based on HOW certain events impacted the BES. [Sabotage on the other hand requires an implication of WHY an event occurred.] The original EOP-004 represents a common sense approach to defining reliability events that may be useful to analyze on a regional basis. In the current environment, Regions are not sanctionable entities but they still are valuable sources to collect, analyze and trend the few disturbances that occur in each region. To make use of Regions, however, precludes the use of sanctionable NERC standards. EOP-004 as written does not meet the NERC requirements for standards but it does meet the Industry needs for a guideline for reporting events that deserve to be reviewed. The SDT should propose deleting EOP-004 and use it as a Disturbance Reporting Guideline.
	No
	The idea of a reporting hierarchy provides an easy to follow pro forma approach. But disturbance reports should not always follow a common reporting path. A disturbance on the transmission system for example need not be routed through an "if applicable" Balancing Authority. To mandate that a BA be in the path is inappropriate. To leave the applicability open is to create a subjective compliance problem for the impacted BA. Copper theft is another example that should not require reporting up through the RC. It is a local issue and the Transmission Owner should be able to report this directly to the appropriate parties. How would a DP, LSE or GO know if an event is an "impact event"? The posed impact events are a series of conditions for sabotage but not for EOP-type disturbances. The aforementioned entities have no requirement to monitor and analyze the BES, which then means every event would be an impact event for those entities (not an EOP disturbance but an impact event). Thus every theft of copper is an impact event mandating a Disturbance Report even though the SDT notes the RC only has to send it to the "local authorities". This seems to be a misuse of the RC resources; every train derailment is an impact event requiring a Disturbance report (is that a commercial train, regional rail line a local trolley car); every teenage prank would also generate an impact event mandating a disturbance report. The SDT defined impact events are not appropriate for use in defining disturbances. There is a big difference from creating a set of guidelines to follow as opposed to creating sanctionable standards
	No
	The SRC supports NERC's initiative for Results Based Standards. The SRC understood RBS to mean the results were reliability based quantities not administrative quantities. There is no need for a NERC Reliability standard on reporting. The idea that all functional entities in each of the said countries will use one form would be a good idea if and only if all the countries and all of their agencies were willing to accept that form. The SRC does not believe that those agencies will be willing to cede what information they ask for to NERC; nor that NERC will be able to create a single form that all such agencies will accept.
	No
	The concept of eliminating duplication is laudable, but the idea of writing a standard to mandate reporting that involves reporting to governmental areas does not make sense unless NERC will do all of the reporting for the industry. A governmental agency is as likely as not to change the forms they require which would then mean two different reports (one for NERC and one for the given agency) or that the standard would have to be re-written every time there is a change.
	No
	The nature of the fact that "gray areas" exists preclude the idea of using a standard to report; particularly a standard for the vague topic of motivation such as sabotage events and the more defined disturbance events.
	The FERC Order merely asked NERC to "further define sabotage and provide guidance as to the triggering events

	that would cause an entity to report a sabotage event.” There is no requirement to create a Reporting Standard and no mention of Disturbance events. There is a strong need to avoid heavy-handed use of NERC standards particularly for such post event reporting guidelines. The SRC would urge the DSR SDT to continue to improve its guidelines and to post those guidelines for all to use, but not to create sanctionable standards whose good intentions will inevitably result in many unintended adverse consequences for the Industry. Rather, the SDT should seek to retire sanctionable requirements that require event reporting in favor of guidelines for reporting.
	Group
	Bonneville Power Administration
	BPA, Transmission Reliability Program
	No
	BPA likes the idea of consolidating information and eliminating duplication of reported information. In the report, don't include every detail possible found in the "Threat Guideline". TOP's are supposed to be operating the electrical system, not doing investigative work for copper theft incidents (see comment on #5).
	No
	The RC is made aware of these type of incidents and goes right back to incorporating that in their awareness and to focusing on system reliability. If the RC is the recipient for further distribution of information of this type they will be forever going back for more information. Eliminate the middleman in whatever concept you propose, folks have plenty to do now. Let people make good judgments with the direct field people on the seriousness of the breach with their security personnel contacting the appropriate law enforcement agency. (Or are you looking to do a simple RE reports to the RC who marks various category items on a secure website Yes/No category item indicator that can be rolled up in ES-ISAC mapboard.?)
	Yes
	As long as we don't make one form that requires extraneous information for the sake of having agreement.
	Yes
	Minimizing the number of reports is a good thing. The concept of actually sharing information should be utilized as much as practical.
	Yes
	BPA agrees with providing an industry-wide definition and guideline. We do NOT agree with requiring reports for every instance of every activity. If your definition is good, you'll get what is needed and not much chaff.
	Individual
	Kirit Shah
	Ameren
	Yes
	We agree that it makes sense to build upon existing documentation. However, we do not believe it is necessary to require event reporting to be in an enforceable standard. Rather the drafting team should consider developing a reporting guideline document and retiring the EOP-004 standard.
	Yes
	The heirarchy is appealing in the fact that the TOP/BA will be kept in the loop and receive critical information from the Generators, Distribution, LSE, etc. But there will be an inherent delay in reporting due to the fact that at every hand-off of information there will be questions for additional and/or clarified information, and there is always a possibility for the loss of information due to the transfer from one entity to the next. Further, this reporting through a heirarchy could also take away from the operators ability to respond to system events due to being tied to an information transfer ladder.
	Yes
	One report would be great for this standard. While this standard needs simplification and automation, we strongly suggest developing a guideline for reporting rather than enforceable standards.
	No
	The DOE OE-417 report should not supplement the NERC report due to the fact that the majority of reportable events are defined in/come from the OE-417 report. The NERC reporting form should be based on the OE-417 report and then include additional reporting requirements defined by NERC. However, it does not make sense to require reporting to the governmental agencies through enforceable NERC standards. The governmental agencies already have legal authority to compel reporting.
	While we are not opposed to the concept of identifying impact events, we are concerned that the drafting team may actually be expanding reporting requirements. We do not support expansion of reporting requirements unless a clear

	reliability or legal need is identified. Some of the impact events are almost never sabotage and do not warrant reporting for reliability needs and should not be included. For example, copper theft should not require reporting, in general, because it is almost never sabotage and rarely impacts reliability. If it does impact reliability because, for example, the protection system is impacted and causes more significant potential contingencies, then reporting could be required. Why is a train derailment near a transmission right of way significant? It would only be significant if an investigation identified sabotage as the reason. Furthermore, what is considered near?
	Group
	Midwest ISO Standards Collaborators
	Midwest ISO
	Yes
	We agree that it makes sense to build upon existing documentation. However, we do not believe it is necessary to require event reporting to be in an enforceable standard. Rather the drafting team should consider developing a reporting guideline document and retiring the EOP-004 standard. This is further supported by the fact that there is a role in the existing standard for the Regional Entities even though these requirements can't be enforced against the Regional Entities because they are not a user, owner or operator of the system.
	No
	We do not agree with developing a hierarchy for reporting for all disturbances and impacting events. For instance, copper theft is an example of an item that should be reported to the appropriate entities directly by the Transmission Owner. The RC does not need to be made aware of every copper theft unless it has a direct impact on reliability (affects rating, protection system, etc.) and the RC should not be burdened with expending resources for this reporting. A further example in which the hierarchy is not needed would be the case in which only one entity is impacted. If a significant event occurs on one TOP's system, then the TOP should be able to handle the reporting of all entities under its purview.. If more than one TOP is involved, then it would be necessary to involve the RC in the reporting.
	Yes
	We agree with the goal of having a single report form but believe there will be a significant challenge to get varying governmental agencies to agree on single report format.
	No
	It certainly makes sense to eliminate duplication in reporting and to allow supplemental information to be submitted in other reports. However, it does not make sense to require reporting to other governmental agencies through NERC enforceable NERC standards. Those governmental agencies already have legal authority to compel reporting. Again, we support developing a guideline for reporting rather than enforceable standards. The guideline could certainly explain the various reporting requirements and supplemental reporting requirements mentioned in the question without causing the issues we have identified in our comments.
	No
	We agree with the idea of identifying impact events but do not support the requirement for these to be always reported through the hierarchical structure identified in question 2. If an impact event only affects one entity, that entity should have the reporting requirement.
	While we are not opposed to the concept of identifying impact events, we are concerned that the drafting team may actually be expanding reporting requirements. We do not support expansion of reporting requirements unless a clear reliability or legal need is identified. Some of the impact events are almost never sabotage and do not warrant reporting for reliability needs and should not be included. For example, copper theft should not require reporting, in general, because it is almost never sabotage and rarely impacts reliability. If it does impact reliability because, for example, the protection system is impacted and causes more significant potential contingencies, then reporting could be required. Why is a train derailment near a transmission right of way significant? It would only be significant if an investigation identified sabotage as the reason. Furthermore, what is considered near?
	Group
	FirstEnergy
	FirstEnergy Corp.
	Yes
	This guideline appears to be a good starting point for developing consistency in reporting. However, we believe that after-the-fact event reporting is administrative in nature and seldom rises to the level of mandated reliability standard requirements. It is not clear what reporting would be made through this effort and how it differs from reporting made through the NERC Reliability Coordinator Information System (RCIS). With the initiative for more results-based standards being the goal of NERC, true after the fact reporting-type requirements should become administrative procedures and only be included in standards if they are truly required for preserving an Adequate Level of Reliability. If there are aspects that rise to be retained in a mandatory and enforceable reliability standard, we propose that those associated with sabotage be moved to CIP-001 and that EOP-004 be focused on operational disturbances that warrant a wide area knowledge. However, if the RCIS is the mechanism to convey real-time information and that is presently occurring outside of reliability standards, it is unclear what the delta improvement this project aims to achieve.

	No
	While we appreciate the team's effort to serialize the reporting process, with the electronic communication methods available today, it seems that reporting can be accomplished simultaneously to multiple entities without shifting the burden of reporting to others along the communications path. This is particularly true if the reporting format is standardized to a one-size-fits-all report. Additionally, it would be a great burden to the Reliability Coordinator to review all events perceived by entities to be malicious sabotage events.
	No
	While one consistent form for reporting may simplify reporting requirements, it would be very difficult to get all governmental agencies to agree to a one-size-fits all approach.
	Yes
	We agree that the simplification and consistency of reporting will improve the reporting of this information. We support the drafting team's efforts in this area and hope that all regulatory agencies will as well. However, as we have mentioned in our other comments, the reporting requirements should not be in a reliability standard unless they are proven to be necessary to maintain an Adequate Level of Reliability of the BES. Reporting of these events should be required by NERC in arenas outside of the standards.
	Yes
	The concept paper makes good progress in this area and the drafting team is on the right track, and agree that better clarity needs to be developed surrounding sabotage events. However, some of the examples stated in the paper are too vague and do not address extenuating circumstances or reasons for the events. One example sighted in the paper is "Bolts removed from transmission line structures." This statement may be too broad. For instance, if the bolts are removed from the tower and the organization is not experiencing a labor dispute, it could be considered a sabotage event with wide area implications. However, if the organization is in the middle of a labor dispute, this would be vandalism and would most likely not be of a wide area concern. Also, the number and location of towers affected could be an important determination related to the risk the event imposes on the Bulk Electric System.
	We fully agree that sabotage events need to be more clearly defined and reporting requirements need to be better coordinated. But as we have stated in previous comments, the drafting team needs to determine if standard requirements need to be developed for this type of reporting or if this is better left to administrative requirements outside the standards arena. Also, while we appreciate the team's effort to simplify reporting requirements for entities, we are concerned with the serial communication offered by the concept paper. As an example, the team proposes to have LSE report the incident to the BA and/or TOP and then have the BA and/or TOP report it to the RC and the RC to report it to NERC and the NERC report to the regulatory agencies. While this simplifies it for each individual organization, this method introduces many opportunities for errors and miscommunications. Since this is after-the-fact reporting, it is difficult to defend this type of communication path when one consistent report could be sent simultaneously to all agencies at the same time from the originating location.
	Individual
	Dan Rochester
	Independent Electricity System Operator
	Yes
	Yes
	We do not agree with the need of such a hierarchy setup solely for the purpose of making reports to the need-to-know entities. All responsible entities (RC, BA, TOP, etc.) need to file a report. With the proposed set up noted under Q3, which we support, these reports should go directly to NERC. The RC should not be held responsible for forwarding other entities' reports to NERC, and in doing so subject itself to potential non-compliance.
	Yes
	Yes, this will simplify the reporting effort. NERC may forward the reports to the other need-to-know entities.
	Yes
	We support this concept since it works well for those entities that are not required to file reports with the US agencies, e.g. the DOE.
	Yes
	We agree with the general concept. However, we suggest that the classification of "events" to be compatible if not identical to those which need to be reported in real time as required in CIP-001, for otherwise it will create confusion and unnecessary, extra work. Also, this proposal appears to focus on the sabotage-type events only but the SAR deals with both sabotage and other disturbances (e.g. emergency type of events) reporting. A parallel type of "impact event" is needed for non-sabotage-type of events.
	In the Background Section of the comment form, it is indicated that the SDT "...is NOT seeking input or guidance on the definition of physical or cyber sabotage, what type of disturbances should be reported, who should do reporting, or to whom or what organizations will be receiving the reports." Yet there are proposed definitions, with examples, in the concept paper. The SDT should make it absolutely clear that by supporting the general concept as described in

	the paper, the commenting entities are not endorsing the proposed definitions, nor the examples as elements to be included in the standard.
	Individual
	Roger Champagne
	Hydro-Québec TransÉnergie (HQT)
	Yes
	In considering guidance found in the document "NERC Guideline: Threat and Incident Reporting", the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
	Yes
	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System. The reporting hierarchy should be to submit the information to the Reliability Coordinator, and to have the RC submit the report. This would eliminate the duplication of information.
	Yes
	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
	Yes
	We agree with the objective of eliminating duplicate reporting. However, EOP-004 currently allows substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today. We agree with the recommendation to eliminate the need for filing duplicate reports such as the DOE form OE-417. There is no benefit with regard to CIP-001 in filing separate reports. Duplicate reports introduce the potential for incomplete information to be supplied to responsible parties. Removing jurisdictional agencies from the Standard, and having NERC provide either query or situational awareness to those agencies being considered, might not be easy to achieve. There is an obligation under law to require entities to report to the DOE on the OE-417 form as amended or modified. This might drive the "omitted" agencies to have reporting laws enacted as well.
	No
	We believe that physical and cyber events must be investigated before a determination of sabotage or impact event can be made. The purpose of the NERC Standards is to maintain the reliability of the BES. Therefore, impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on 'newsworthy' events or to gather information for trending. It is the law enforcement industry's responsibility to make a determination of "sabotage" or other. This determination cannot definitively be made by industry personnel, there is no expertise or time to investigate causes. It is the industry's job to mitigate effects. Examples would help provide for better guidance/direction. Industry examples would be welcomed to help reinforce developed internal processes for compliance.
	SERC and RFC are developing additional requirements at this time. We suggest that reporting be based on impact to reliability, not on 'newsworthy' events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirement.
	a. NERC should focus efforts on developing specific event reporting criteria and not base the requirement on the definition of the term 'sabotage', but on the reporting criteria itself. See comments above. b. The "opportunities for efficiency" discussed in the Concept Paper would be best achieved by focusing on those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. If there are elements that need to be reported that do not support this objective, then that reporting should not be required in reliability standards. Consider making NERC the distributor of reports to other agencies. We recognize that the key is to simplify reporting to a single form, and to the extent possible, to one agency. "Front line" reliability personnel must have the "timely" knowledge to know when a situation warrants local, area, regional, or national involvement. Finally, the SDT should keep in mind the fact that Canadian stakeholders might have some difference in the way reports are made to Security Agencies.



## **Consideration of Comments on Disturbance and Sabotage Reporting — Project 2009-01**

The Disturbance and Sabotage Reporting Standard Drafting Team thanks all commenters who submitted comments on the proposed Concepts Paper for Disturbance and Sabotage Reporting. The document was posted for a 30-day public comment period from March 17, 2010 through April 16, 2010. Stakeholders were asked to provide feedback on the standards through a special Electronic Comment Form. There were 41 sets of comments, including comments from more than 95 different people from approximately 50 companies representing 8 of the 10 Industry Segments as shown in the table on the following pages.

The comments have been sorted and organized by question number in this report; the comments are shown in the original format on the following project web page:

[http://www.nerc.com/filez/standards/Project2009-1\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-1_Disturbance_Sabotage_Reporting.html)

### **Summary Consideration:**

#### **Use of “NERC Guideline: Threat and Incident Reporting”**

Most stakeholders agree that existing guidance should be used as the foundation for disturbance reporting. Most commenters felt that the “NERC Guideline: Threat and Incident Reporting” document contains a lot of detailed information which greatly assists in determining reporting events and weaning out non important events. The most common desire was one, common form to be used for reporting and the OE-417 was considered to be a good starting point. Most respondents thought the form could be streamlined. The DSR SDT was urged to focus on applicable events and reporting timelines which are not clear now and to report items that are clearly essential to the reliability of the BES. There was some concern expressed about “over-reporting”, out of fear of non-compliance rather than the over the reliability of the BES. There was also a clear desire to separate out vandalism & copper theft from reporting requirements.

#### **Hierarchy for Reporting Disturbances**

Most stakeholders (about 2/3) agree with the concept of developing a reporting hierarchy for disturbances. Stakeholders who disagreed believed that the RC should be one of many to receive information on impact events (DOE, RRO, etc.). Such a hierarchy would lead to reporting delays (leading to lack of situational awareness), be cumbersome and complicated and clouds responsibility for who is to report what to whom. Other negative comments believed that a hierarchy would distract the RC’s focus from its primary responsibility. Those stakeholders who agreed commented that the RC should be the collection point for reports and information and take the responsibility to forward as required. This is from the concept that the RC has the “wider view” and can recognize patterns, and has the ability to “escalate” the reporting process. This would also minimize duplication of reports and information.

#### **Single Form for All Agencies**

Most stakeholders agreed with the concept of having one reporting form for all entities. Several commenters suggested that there is no need for a standard on reporting as they considered it administrative in nature. Most dissenters thought there should be a guideline, rather than an enforceable standard. There is widespread agreement that the one-size-fits-all approach would be very difficult to get agreement on, given the different countries and

agencies involved. Many stakeholders pointed out that consistency and simplification were drivers for one report form. Having multiple recipients, with different information requirements, seems to support an electronic format that would guide information only to those who need it. The concept of an electronic reporting tool will need to be further vetted and developed.

### **Supplements to NERC Form**

Most stakeholders agreed with the concept of entities being able to use information from other sources such as the OE-417 form, to supplement the NERC report form. Some thought that duplicate reports were acceptable, as long as the information was not duplicated (if # of customers lost is required on form A, don't ask on forms B & C). Several stakeholders commented on the need for an electronic, one stop reporting tool. This would avoid duplication while ensuring that the information reported goes only to intended recipients. With an electronic, one stop reporting tool, reports can be updated/corrected instantly, without repeating previously submitted information. Some stakeholders cautioned that the OE-417 can change every three years and this should be taken into account when developing an electronic reporting tool. Again, such a reporting tool would need to be vetted and developed to meet reliability needs.

### **Impact Events**

The majority of stakeholders agreed with the concept of "impact events." Some stakeholders felt that the introduction of impact events increased the risk that some items will go unreported. However, most felt that impact events would dramatically increase the number of reports being submitted, and it would be difficult to separate important information from background noise. Several respondents felt that the SDT ignored the FERC Directive, and did not define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event. Many respondents supplied the SDT with their own definition of "Sabotage". The DSR SDT believes that the concept of impact events and the specificity of what needs to be reported in the standard will be an equally efficient and effective means of address the FERC directive regarding sabotage. Some stakeholders felt that impact events add another layer of uncertainty to the reporting. Even with the switch from sabotage to impact events, several felt that "intent" was still key to determining reportability.

### **Regional Differences**

Several commenters provided information on regional reporting. The SDT will consider whether these should be included in the continent-wide standard. These include:

1. NPCC maintains a document and reporting form (Document C-17 - Procedures for Monitoring and Reporting Critical Operating Tool Failures) that outlines the reporting requirements, responsibilities, and obligations of NPCC RCs in response to unforeseen critical operating tool failures.
2. For other events that do not meet the OE-417 and EOP-004 reporting criteria, ReliabilityFirst expects to receive notification of any events involving a sustained outage of multiple BES facilities (buses, lines, generators, and/or transformers, etc.) that are in close proximity (electrically) to one another and occur in a short time frame (such as a few minutes).
3. WECC sets its loss of load criteria for disturbance reporting at 200 MW rather than the 300 MW in the NERC reporting form.
4. SERC and RFC are developing additional requirements at this time. We suggest that reporting be based on impact to reliability, not on 'newsworthy'

events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirements.

5. Some entities identified some in-force Regional Standards and other regional reporting requirements.

### **Project Scope**

Some stakeholders suggested that the SDT has gone beyond its approved scope to “further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” Further, there is no requirement to create a Reporting Standard to define sabotage. The SDT contends that the development of impact events and the reporting requirements for them will provide the clarity sought in the directive. Other stakeholders suggested that the SDT should seek to retire sanctionable requirements that require event reporting in favor of guidelines for reporting. Several commenters suggested that the introduction of impact events actually expands the reporting requirements. It should be noted that the list of impact events is expected to be explicit as to who is to report what to whom and within certain timelines.

### **Electronic Tool**

Several stakeholders provided input as to what they believed an electronic reporting tool should contain:

- 1 If the decision is made to go to a single reporting form, it should be developed to cover any foreseeable event.
- 2 The SDT should work toward a single form, located in a central location, and submitted to one common entity (NERC)
- 3 Reports should be forwarded to the ES-ISAC, not NERC, as the infrastructure is already in place for efficient sharing with Federal agencies, with the regional entities and with neighboring asset owners. Reports should flow to all affected entities in parallel, rather than series (timing issues).

Commenters also suggested that the SDT should consider the impacts of the reporting requirements on the small and very small utilities.

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Herbert Schrayshuen, at 609-452-8060 or at [Herb.Schrayshuen@nerc.net](mailto:Herb.Schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

---

<sup>1</sup> The appeals process is in the Reliability Standards Development Procedures: <http://www.nerc.com/standards/newstandardsprocess.html>.

## Index to Questions, Comments, and Responses

1. The details of reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and will consider guidance found in the document “NERC Guideline: Threat and Incident Reporting” in the development of requirements. Do you agree with using the existing guidance as the foundation for disturbance reporting? Please explain your response (yes or no) in the comment area..... 12
2. The DSR SDT is considering developing a reporting hierarchy for disturbances that requires entities to submit information to the Reliability Coordinator and then for the Reliability Coordinator to submit the report. Do you agree with this hierarchy concept? Please explain your response (yes or no) in the comment area..... 24
3. The goal of the DSR SDT is to have one report form for all functional entities (US, Canada, Mexico) to submit to NERC. Do you agree with this change? Please explain your response (yes or no) in the comment area. .... 34
4. The goal of the DSR SDT is to eliminate the need to file duplicate reports. The standards will specify information required by NERC for reliability. To the extent that this information is also required for other reports (e.g. DOE OE-417), those reports will be allowed to supplement the NERC report in lieu of duplicating the entries in the NERC report. Do you agree with this concept? Please explain your response (yes or no) in the comment area. .... 42
5. In its discussion concerning sabotage, the DSR SDT has determined that the spectrum of all sabotage-type events is not well understood throughout the industry. In an effort to provide clarity and guidance, the DSR SDT developed the concept of an impact event. By developing impact events, it allows us to identify situations in the “gray area” where sabotage is not clearly defined. Other types of events may need to be reported for situational awareness and trend identification. Do you agree with this concept? Please explain your response (yes or no) in the comment area. .... 51
6. If you are aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004 please provide them here..... 61
7. If you have any other comments on the Concepts Paper that you haven’t already provided in response to the previous questions, please provide them here..... 65

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	John Bee	Exelon	X		X		X						
	<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>					<b>Segment Selection</b>					
	1. Dan Brotzman		ComEd	RFC					1					
	2. Dave Weaver		PECO	RFC					1					
	3. Ron Schloendorn		PECO	RFC					1					
	4. John Garavaglia		ComEd	RFC					1					
	5. Karl Perman		Exelon	NA - Not Applicable					NA					
	6. Dave Belanger		Exelon Generation Co., LLC	RFC					5					
	7. Alison MacKellar		Exelon Generation Co., LLC	RFC					5					
	8. Tom Leeming		ComEd	RFC					1					
	9. Tom Hunt		PECO	RFC					1					
2.	Group	Guy Zito	Northeast Power Coordinating Council											X
	<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>					<b>Segment Selection</b>					
	1. Alan Adamson		New York State Reliability Council, LLC	NPCC					NA					
	2. Michael Schiavone		National Grid	NPCC					1					

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

	Commenter	Organization	Industry Segment											
			1	2	3	4	5	6	7	8	9	10		
3.	Roger Champagne	Hydro-Quebec TransEnergie	NPCC						2					
4.	Kurtis Chong	Independent Electricity System Operator	NPCC						2					
5.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC						1					
6.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC						1					
7.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC						10					
8.	Ben Eng	New York Power Authority	NPCC						4					
9.	Brian Evans-Mongeon	Utility Services	NPCC						8					
10.	Mike Garton	Dominion Resources Services, Inc.	NPCC						5					
11.	Brian L. Gooder	Ontario Power Generation Incorporated	NPCC						5					
12.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC						3					
13.	David Kiguel	Hydro One Networks Inc.	NPCC						1					
14.	Michael R. Lombardi	Northeast Utilities	NPCC						1					
15.	Randy MacDonald	New Brunswick System Operator	NPCC						2					
16.	Bruce Metruck	New York Power Authority	NPCC						6					
17.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC						10					
18.	Robert Pellegrini	The United Illuminating Company	NPCC						1					
19.	Saurabh Saksena	National Grid	NPCC						1					
20.	Kathleen Goodman	ISO - New England	NPCC						2					
21.	Greg Campoli	New York ISO	NPCC						2					
3.	Group	Wes Davis (SERC Staff) and Steve Corbin (Chair of SERC RCS)	SERC Reliability Coordinator Sub-committee (RCS)											X
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.	Steve Corbin	Southeastern RC	SERC											NA
2.	Joel Wise	TVA RC	SERC											NA
3.	Don Reichenbach	VACAR South RC	SERC											NA
4.	Don Shipley	ICTE RC	SERC											NA
5.	Robert Rhodes	SPP RC	SERC											NA
6.	Stan Williams	PJM RC	SERC											

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting – Project 2009-01

	Commenter	Organization	Industry Segment										
			1	2	3	4	5	6	7	8	9	10	
7.	Tim Aliff	Midwest ISO RC	SERC					NA					
4.	Group	Mike Garton	Electric Market Policy	X		X		X	X				
Additional Member		Additional Organization		Region					Segment Selection				
1.	Michael Gildea	Dominion Resources Services, Inc.		RFC					3				
2.	Louis Slade	Dominion Resources Services, Inc.		SERC					6				
5.	Group	Carol Gerou	MRO's NERC Standards Review Subcommittee										X
Additional Member		Additional Organization		Region					Segment Selection				
1.	Chuck Lawrence	American Transmission Company		MRO					1				
2.	Tom Webb	WPS Corporation		MRO					3, 4, 5, 6				
3.	Terry Bilke	Midwest ISO Inc.		MRO					2				
4.	Jodi Jenson	Western Area Power Administration		MRO					1, 6				
5.	Ken Goldsmith	Alliant Energy		MRO					4				
6.	Dave Rudolph	Basin Electric Power Cooperative		MRO					1, 3, 5, 6				
7.	Eric Ruskamp	Lincoln Electric System		MRO					1, 3, 5, 6				
8.	Joseph Knight	Great River Energy		MRO					1, 3, 5, 6				
9.	Scott Nickels	Rochester Public Utilities		MRO					4				
10.	Terry Harbour	MidAmerican Energy Company		MRO					1, 3, 5, 6				
6.	Group	Linda Perea	Western Electricity Coordinating Council										X
Additional Member		Additional Organization		Region					Segment Selection				
1.	Steve Rueckert	WECC		WECC					10				
7.	Group	Kenneth D. Brown	Public Service Enterprise Group Companies	X		X		X	X				
Additional Member		Additional Organization		Region					Segment Selection				
1.	Ron Wharton	PSE&G		RFC					1, 3				
2.	Dave Murray	PSEG Power Connecticut		NPCC					5				
3.	Jim Hebson	PSEG Energy Resource & Trade		ERCOT					6				
4.	Jerzy Sluarz	PSEG Fossil		RFC					5				

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

	Commenter	Organization	Industry Segment											
			1	2	3	4	5	6	7	8	9	10		
5	Bruce Wertz	Odessa Ector Power Partners	ERCOT					5						
6	Peter Dolan	PSEG Energy Resource & Trade	RFC					6						
8.	Group	Laura Zotter	ERCOT ISO		X									X
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						
1.	Steve Myers	ERCOT ISO	ERCOT					2, 10						
2.	Jimmy Hartmann	ERCOT ISO	ERCOT					2, 10						
3.	Christine Hasha	ERCOT ISO	ERCOT					2, 10						
9.	Group	Ben Li	ISO RTO Council Standards Review Committee		X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						
1.	Al Dicaprio	PJM	RFC					2						
2.	Jame Castle	NYISO	NPCC					2						
3.	Lourdes Estrada-Salinerio	CAISO	WECC					2						
4.	Matt Goldberg	ISO-NE	NPCC					2						
5.	Steve Myers	ERCOT	ERCOT					2						
6.	Bill Phillips	MISO	RFC					2						
7.	Mark Thompson	AESO	WECC					2						
8.	Charles Yeung	SPP	SPP					2						
10.	Group	Denise Koehn	Bonneville Power Administration	X		X		X	X					
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						
1.	Tedd Snodgrass	BPA, Transmission Dispatch	WECC					1						
2.	Jim Burns	BPA, Transmission Technical Operations	WECC					1						
3.	Jeff Millenor	BPA, Security & Emergency Response	WECC					1, 3, 5, 6						
11.	Group	Jason L. Marshall	Midwest ISO Standards Collaborators		X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>				<b>Segment Selection</b>						



**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
1.		Bob Thomas	IMEA	SERC						4				
2.		Jim Cyrulewski	JDRJC Associates, LLC	RFC						8				
3.		Joe Knight	Great River Energy	MRO						1, 3, 5, 6				
4.		Randi Woodward	Minnesota Power	MRO						1				
5.		Kirit Shah	Ameren	SERC						1				
12.	Group	Sam Ciccone	FirstEnergy	X		X	X	X	X					
		Additional Member	Additional Organization	Region					Segment Selection					
1.		Doug Hohlbaugh	FE	RFC						1, 3, 4, 5, 6				
2.		Dave Folk	FE	RFC						1, 3, 4, 5, 6				
13.	Individual	Thomas Glock	Arizona Public Service Company	X		X		X						
14.	Individual	Sandra Shaffer	PacifiCorp	X		X		X	X					
15.	Individual	Brent Ingebrigtsen	E.ON U.S. LLC	X		X		X	X					
16.	Individual	Steve Fisher	Lands Energy Consulting											
17.	Individual	David Kahly	Kootenai Electric Cooperative			X								
18.	Individual	Darryl Curtis	Oncor Electric Delivery Company LLC	X										
19.	Individual	Edward Bedder	Orange and Rockland Utilities, Inc.	X										
20.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X					
21.	Individual	Brian Bartos	Bandera Electric Cooperative, Inc.	X		X								
22.	Individual	John T. Walker	Portland General Electric	X										
23.	Individual	Gregory Miller	BGE	X										

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
24.	Individual	Dan Roethemeyer	Dynegy Inc.					X						
25.	Individual	Rick Terrill	Luminant					X						
26.	Individual	James Stanton	SPS Consulting Group Inc.								X			
27.	Individual	Andrew Gallo	Calpine Corp.					X						
28.	Individual	Steve Alexanderson	Central Lincoln			X								
29.	Individual	Brenda Frazer	Edison Mission Marketing & Trading					X						
30.	Individual	Martin Bauer	USBR					X						
31.	Individual	John Alberts	Wolverine Power Supply Cooperative, Inc.	X		X	X	X	X					
32.	Individual	Thad Ness	American Electric Power	X		X		X	X					
33.	Individual	James McCloskey	Central Hudson Gas & Electric	X		X								
34.	Individual	Deborah Schaneman	Platte River Power Authority	X		X		X						
35.	Individual	Howard Rulf	We Energies			X	X	X						
36.	Individual	Jianmei Chai	Consumers Energy Company			X	X							
37.	Individual	Amir Hammad	Constellation Power Source Generation					X						
38.	Individual	Greg Rowland	Duke Energy	X		X		X	X					
39.	Individual	Kirit Shah	Ameren	X		X		X	X					
40.	Individual	Dan Rochester	Independent Electricity System Operator		X									

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

---

		Commenter	Organization	Industry Segment										
				1	2	3	4	5	6	7	8	9	10	
41.	Individual	Roger Champagne	Hydro-Québec TransEnergie (HQT)	X										

1. The details of reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and will consider guidance found in the document “NERC Guideline: Threat and Incident Reporting” in the development of requirements. Do you agree with using the existing guidance as the foundation for disturbance reporting? Please explain your response (yes or no) in the comment area.

**Summary Consideration:** Most stakeholders agree that existing guidance should be used as the foundation for disturbance reporting. Most commenters felt that the “NERC Guideline: Threat and Incident Reporting” document contains a lot of detailed information which greatly assists in determining reporting events and weaning out non important events. The most common desire expressed was to have one common form for all reporting, and the OE-417 was suggested as a good starting point. Most respondents thought the form could be streamlined. The DSR SDT was urged to focus on applicable events and reporting timelines which are not clear now and to report items that are clearly essential to the reliability of the BES. There was some concern expressed about “over-reporting”, out of fear of non-compliance rather reporting based on the reliability of the BES. There was also a clear desire to exclude vandalism & copper theft from reporting requirements.

Several specific suggestions were made to modify existing reporting requirements, and the drafting team will consider these when developing the proposed requirements.

Organization	Yes or No	Question 1 Comment
ERCOT ISO	Possible Yes	Parts of the Guideline are helpful, but the guideline goes beyond the scope of the requirements of the current standards, which could pose potential audit concerns. ERCOT ISO strongly feels this approach for reporting should be focused on physical events only and cyber event reporting should be contained within CIP-008 only. Continue to keep physical separate from cyber.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). The DSR SDT will take into consideration your comment on keeping cyber and physical events separate.</p>		
Arizona Public Service Company	No  Then Yes	APS supports standard revisions which streamline the reporting process for security incidents with a single form, which aligns both with EIA reporting and NERC Standards requirements, particularly those identified in the NERC Threat and Incident Reporting Guidelines. This would eliminate users issuing reports to multiple locations/government entities without a standard form or format. The DOE 417 form which is currently utilized

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>for reporting purposes is out-dated and does not account for the types of incidents as identified in the NERC Threat and Incident Reporting Guidelines. The guidelines state that an entity can report security incidents to the ESISAC , through CIPIS (Critical Infrastructure Protection Information System), and or RCIS (Reliability Coordinator Information Center). CIPIS refers an entity to the NICC and to the WECC. Additionally, APS proposes that the terms and timelines of reporting security incidents be clearly identified. Events are often detected quickly or immediately. Determining whether or not the event was sabotage and/or a reportable event; however, typically takes much longer. There is no time allowance for an entity to investigate the event to determine what actually occurred. Currently, DOE 417 provides that acts of sabotage should be reported within one hour of detection if the impact could affect the reliable operation of the bulk power system. This may affect the accuracy of the information being provided by an entity on it's initial reporting. Finally, provisions should be incorporated to address the privacy of information being submitted, including handling and storage.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s) which should streamline the reporting process (what events and what timeline should be used). c</p>		
SPS Consulting Group Inc.	No	<p>At least not exclusively. The current standards and the guidance fail to consider that different registered entities will have different scopes of awareness for when disturbances may take place. We want to avoid the situation where a generator (for example) is cited for failure to report a disturbance of which they have way of knowing occurred.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT will take into consideration what Registered Entities are to be included within the yet to be written standard(s) based on the SAR and the facilities each type of Registered Entity is required to have.</p>		
Bonneville Power Administration	No Then Yes	<p>BPA likes the idea of consolidating information and eliminating duplication of reported information. In the report, don't include every detail possible found in the “Threat Guideline”. TOP's are supposed to be operating the electrical system, not doing investigative work for copper theft incidents (see comment on #5).</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). We will consider your specific suggestion for not requiring reporting of incidents such as copper threat, when we develop the proposed requirements.</p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
Lands Energy Consulting	No	<p>My firm provides compliance consulting services to a number of smaller (50-700 MW peak load) LSE/DP registered entities. EOP-004 creates an obligation for LSEs to report "disturbances" that affect their systems. A few of the smaller of these systems receive service from Bonneville-owned transmission lines that serve only 4-6 substations. The NERC Form establishes loss of 50% of the LSE's retail customers as a reportable disturbances. One of my clients receives service from BPA at 5 substations. A single industrial customer with a substantially dedicated substation comprises 90% of the utility's MWH load. Were it not for this customer, the utility would have been well below the registration requirement for a DP/LSE. The balance of the load, about 15 MW of peak and 4000 retail customers, is served from 5 substations. Four of these substations serving 3000 customers are served from a long Bonneville 115 kV BES transmission line that runs through a heavily treed right of way. Every time this single line experiences a permanent outage (which will happen a few times a year), the utility loses less than 10 MW of load, but 75% of its retail customers. Under the disturbance reporting criteria, this outage would constitute a reportable disturbance for the utility. When the NERC disturbance reporting criteria were adopted, I doubt that anyone conceived that they would apply to cases like I just described. Reporting trivial events like I've just described constitutes a nuisance to the entity making the report and NERC/WECC for having to process the report. The outage has no earthly effect on the reliability of the BES and certainly doesn't warrant preparation of any kind of disturbance report.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT will take into consideration what Registered Entities are to be included within the yet to be written standard(s) based on the NERC Standards Committee approved SAR. The DSR SDT will review the Commissions concern that, an adversary might determine that a small LSE is the appropriate target when the adversary aims at a particular population or facility, as stated in FERC Order 693, paragraph 459. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b></p>		
SERC Reliability Coordinator Sub-committee (RCS)	No	<p>Routine minor incidents such as copper theft and gun shots to insulators should not be reported. These types of minor events do not affect the reliability of the BPS. Existing reporting requirements are satisfactory. The focus of reporting should be on reliability related incidents and not incidents related to vandalism as such.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). Reporting thresholds will be determined during the next step of the Standards Development process. The DSR SDT agrees with your comments on vandalism but a balance must be further explored to meet industry and regulatory requirements specifically under FERC Order 693.</b></p>		
Consumers Energy Company	No	<p>The existing guidelines ignore the fact that there are currently three overlapping and inconsistent reporting requirements for disturbances of various types: CIP-001, EOP-004, and DOE OE-417. The reporting should be such that any single event type needs to be reported only once, and to only a single agency, for any</p>

Organization	Yes or No	Question 1 Comment
		<p>disturbance. First, CIP-001 events should be reported to the ES-ISAC under one specific requirement (or set of requirements) and removed from OE-417 and EOP-004, such that all interested agencies obtain their information from only that one source. Second, OE-417 events should be reportable ONLY to DOE, and, again, other agencies should obtain their information from only that one source. If NERC wishes to make such reporting mandatory and enforceable, the NERC requirements should indicate ONLY that such reporting should be made in accordance with OE-417. Finally, EOP-004 (or similar requirements) should require reporting to NERC ONLY in the case of events that don't fit under CIP-001 or OE-417 requirements. Alternatively, OE-417 should be submitted ONLY to NERC and they should disseminate the information. EOP-004 has several issues and inconsistencies:</p> <p>a. EOP-004 requires that the entity that submits form DOE-417 to provide copies to NERC. The DOE-417 form intermixes NERC entity definitions (e.g. BA, LSE, TO) with generic terms such as "<u>Electric Utilities</u>" and "<u>Generating Entities</u>". Is it the Generator Owner or Generator Operator that is required to submit the information? There should be one form or at least well defined definitions that apply to both forms.</p> <p>b. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change this requirement to 1 hour for several disturbances. Additionally, it incorrectly summarizes the reporting time for 50,000 customers, which is 6 hours in DOE-417 and summarized in Table 1-EOP-004-0 as 1-hour. An attachment to a standard should not be allowed to supersede the standard or create additional rules.</p> <p>c. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change the standard. R3.1 clearly states that events are to be reported within 24 hours of identification, however Table 1-EOP-004-0 state that the events are to be reported on the basis of the start of the disturbance. An attachment to a standard should not be allowed to supersede the standard or create additional rules.</p> <p>d. EOP-004-1 R3.1 requires submittal within 24 hours, however Table 1-EOP-004-0 which purports to summarize the standard appears to change the standard. R3.1 clearly states that events are to be reported within 24 hours of identification, however Table 1-EOP-004-0 states that copies of DOE-417 are required to be submitted "simultaneously". It also states that schedules 1 and 2 are due within 24 hours of start of the event instead of 48 hours for per DOE-417 for schedule 2. An attachment to a standard should not be allowed to supersede the standard or create additional rules.</p> <p>e. The requirement of loss of customers should be scaled based on customers served. Loss of 50,000 customers to a utility that serves 100,000 customers is different than loss of 50,000 customers to a utility that serves 2,000,000 customers.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted "NERC Guideline: Threat and Incident Reporting" and</b></p>		

Organization	Yes or No	Question 1 Comment
<p>ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT agrees that present Reliability Standards can be complicated and lead to confusion when working on maintaining system reliability in the area of reporting per CIP-001-1 and EOP-004-1. We will consider the disagreements you've identified in existing reporting requirements when we develop the proposed requirements.</p>		
Central Lincoln	No	<p>The guidance document makes no distinction between entities that operate 24/7 dispatch and those that don't. The 1 hour and even the 24 hour reporting requirements in some cases will be impossible for entities without 24/7 dispatch to meet without changing business practices. These are the same entities that present little or no risk to the BES.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted "NERC Guideline: Threat and Incident Reporting" and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT will take into consideration what Registered Entities are to be included within the yet to be written standard(s) based on the SAR. The DSR SDT will establish the "requirements necessary for users, owners, and operators of the Bulk-Power-System" as stated in FERC Order 693, paragraph 617 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</p>		
MRO's NERC Standards Review Subcommittee	No Then Yes	<p>We agree with using the present documentation but would like just one reporting form. We are concerned that the guidelines and reporting periods specified within the DOE OE-417 report conflict with the NERC Guidelines. For example, DOE OE-417 report requires "Suspected Physical or Cyber Impairment" to be reported within 6 hours. The NERC guidelines indicate "Suspected Activities" are to be reported within 1 hour. We recommend the SDT use the DOE OE-417 report as a guiding document, and then determine additional reporting requirements using guidance from the NERC Guideline. FERC Order 693 appears to indicate conflicts and confusion with NERC reporting requirements and DOE reporting requirements should be eliminated.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent was to look at the posted "NERC Guideline: Threat and Incident Reporting" and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT is looking to streamline required reporting actions and remove any redundant reporting requirements if at all possible. The DOE Form OE-417 is currently mandatory under Public Law 93-275 for entities within the jurisdiction of the U.S Department of Energy. We will consider the disagreements you've identified in existing reporting requirements when we develop the proposed requirements.</p>		
Luminant	No Then Yes	<p>While the guidance is generally ok in the "NERC Guideline: Threat and Incidence Reporting", the reporting timelines include 1 hour, 2 hours, 4 hours, 6 hours, 8 hours, 24 hours, and 48 hours. Please simplify and reduce the variation in timelines. When it comes to Sabotage reporting, some time requirements start with detection, some start with determination of sabotage and some events do not specify the trigger for the reporting clock to start. Again, please provide clarity and consistency around the start of the timeline for</p>



Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
		reporting. Generally, the reporting timing should start with the recognition or determination that a suspected or known sabotage event occurred.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to streamline required reporting actions and remove any redundant reporting requirements if at all possible. The DSR SDT agrees that present Reliability Standards can be complicated and lead to confusion when working on maintaining system reliability in the area of reporting per CIP-001-1 and EOP-004-1. We will consider your specific suggestion for less variation in reporting timeframes, when we develop the proposed requirements.</b></p>		
We Energies	No Then Yes	While the NERC Guideline includes readily discernible information (and we would like to see that format carried forward into any future documentation), utilize OE-417 as the foundation document in order to eliminate reporting redundancies. If supplemental references are necessary for the proposed resolution, list the document as an official attachment to the standard. Minimize the need to search in multiple locations for guideline information - some may not be aware supporting documentation exists without explicit reference within the standard.
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT is looking to streamline required reporting actions and remove any redundant reporting requirements if at all possible. The DSR SDT agrees that present Reliability Standards can be complicated and lead to confusion when working on maintaining system reliability in the area of reporting per CIP-001-1 and EOP-004-1. The DOE Form OE-417 is currently mandatory under Public Law 93-275 for entities within the jurisdiction of the U.S Department of Energy. We will consider your recommendation regarding listing supplemental references within the body of the standard when we draft the proposed standard(s).</b></p>		
American Electric Power	Yes	
Bandera Electric Cooperative, Inc.	Yes	
Calpine Corp.	Yes	
Duke Energy	Yes	
Edison Mission Marketing & Trading	Yes	

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
Exelon	Yes	
Independent Electricity System Operator	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	
Central Hudson Gas & Electric	Yes	<p>Central Hudson agrees with using the “NERC Guideline: Threat and Incident Reporting” in the development of requirements. Central Hudson has currently in place a NERC-DOE Threat and Incident Reporting Table developed from this NERC Guideline that allows for a quick-reference to all threat and incident reporting criteria (arranged by category) with a cross-reference to the specific reporting form (NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report, DOE Form OE-417, or NERC ES-ISAC Threat and Incident Report Form). Central Hudson recommends maintaining the option of utilizing only 1 form, the DOE Form OE-417, for incidents that require reporting to the DOE and NERC to maintain the streamlined approach to this reporting process.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to have a single reporting report form (per question 3) and streamline the reporting processes that may be developed within a yet to be written requirement(s).</b></p>		
E.ON U.S. LLC	Yes	<p>E.ON U.S. believe that the guidelines provide greater clarity for reporting forced outages caused by disturbances and sabotage but there remains issues that in need of further clarification. For example, there remains too much subjectivity on the reporting of forced outages when there is “identification of valuable lessons learned”</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT concurs that further clarification is required with the ambiguous statement “identification of valuable lessons learned” contained in the guideline – use of this phrase does not meet the technical writing threshold required for inclusion in a NERC Standard. The DSR SDT’s intent was to look at the posted NERC Guideline and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). Recommendation of changes to the “NERC Guideline: Threat and Incident Reporting” should be submitted to NERC via the Critical Infrastructure Protection Committee. I</b></p>		
Public Service Enterprise Group Companies	Yes	<p>EOP reportable disturbances are familiar concepts in the industry.</p>

Organization	Yes or No	Question 1 Comment
<b>Response: The DSR SDT thanks you for your comment and support.</b>		
Orange and Rockland Utilities, Inc.	Yes	However, the SDT needs to maintain clear demarcation for the criteria for reporting events, and only those events that directly effect the reliability of the BES.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT has been directed to review all disturbance type activities and submit to the industry a well thought out set of requirements that clearly define disturbance events and what information is required to enhance an entity's situational awareness. Clear demarcation for the criteria for reporting will be determined in the near future based on the approved SAR and industry feedback. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b>		
Wolverine Power Supply Cooperative, Inc.	Yes	I agree with referencing existing guidelines - However: My concern is that, until all reportable incidents are analyzed by the parties to which they are reported, their "impact" on the BES will not be quantified. Therefore, the tendency to want to "report all events so that their impact can be determined" or "report all events because the information can be utilized for informational purposes, regardless of impact on BES" might lead to expanded reporting requirements, some of which may have questionable value from a reliability standpoint.
<b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has been directed to review all disturbance type activities and submit to the industry a well thought out set of requirements that clearly define reportable events and what information is required to enhance an entity's situational awareness. Clear demarcation for the criteria for reporting will be determined in the near future based on the approved SAR and industry feedback. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b>		
Hydro-Québec TransEnergie (HQT)	Yes	In considering guidance found in the document “NERC Guideline: Threat and Incident Reporting”, the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
Northeast Power Coordinating Council	Yes	In considering guidance found in the document “NERC Guideline: Threat and Incident Reporting”, the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will establish the “requirements necessary for users, owners, and operators of</b>		

Organization	Yes or No	Question 1 Comment
<p><b>the Bulk-Power-System” as stated in FERC Order 693, paragraph 617 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1. The intent of the proposed standard(s) is to address reporting needed for after-the-fact analyses of events as well as reporting necessary for situational awareness.</b></p>		
Western Electricity Coordinating Council	Yes	It is comprehensive; however, we must keep in mind that the OE-417 is required under Public Law 93-275 and needs to be attached if applicable in the US.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Oncor Electric Delivery Company LLC	Yes	NERC Guideline: Threat and Incident Reporting" document should be used for guidance as it identifies best practices for reporting.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Manitoba Hydro	Yes	The “Threat and Incident Reporting” document contains a lot of detailed information which greatly assists in determining reporting events and weaning out non important events. The document contains some examples and expected reporting time lines. Attachment 1-EOP-004, though considerably smaller and condensed it does contain some detail not mentioned in “Threat and Incident Reporting”. Integrating the “Threat and Incident Reporting” into Attachment 1-EOP-004, though large in size, has lots of information and is easy to follow would be a large improvement to existing protocol OR SEE QUESTION 3 COMMENTS. Incidences we have experienced on our system, in past were difficult to delineate as reportable, who to report to and when. An improvement to this Standard is welcome.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to streamline and remove any redundancies within the NERC Standard’s requirements.</b></p>		
Constellation Power Source Generation	Yes	The existing guidance is an excellent base on which to build changes to EOP-004 and CIP-001. However, the SDT must challenge each item in the different event categories and clarify or omit bullet points that are seemingly vague. For example, under System Disturbances, a forced outage report is needed when “a generation asset of 500 MW or above is on a forced outage for unknown reasons, or a forced outage of generation of 2,000 MW occurs...” Simply removing the 500 MW criteria would make this criterion less vague. There are other examples of this in the guideline.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is looking to streamline and remove any redundancies within the NERC Standard’s requirements. It is the intent of the SDT to carefully review the different event categories and provide clarity where needed to remove ambiguity.</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
ISO RTO Council Standards Review Committee	Yes	The guidelines in EOP-004 and its attachments should be retained as the foundation for reporting disturbances. One would note that such EOP Disturbances are relatively well defined reliability impacts. Thus EOP-004 disturbances are based on HOW certain events impacted the BES. [Sabotage on the other hand requires an implication of WHY an event occurred.]The original EOP-004 represents a common sense approach to defining reliability events that may be useful to analyze on a regional basis. In the current environment, Regions are not sanctionable entities but they still are valuable sources to collect, analyze and trend the few disturbances that occur in each region. To make use of Regions, however, precludes the use of sanctionable NERC standards. EOP-004 as written does not meet the NERC requirements for standards but it does meet the Industry needs for a guideline for reporting events that deserve to be reviewed. The SDT should propose deleting EOP-004 and use it as a Disturbance Reporting Guideline.
<p><b>Response: The DSR SDT thanks you for your comment. Regions are required to comply with requirements in NERC Reliability Standards – however Regions are not sanctioned the same way as users, owners and operators of the bulk power system – if a Region fails to comply with a NERC Reliability Standard, it can be fined for failure to comply under the ERO’s Rules of Procedure.</b></p>		
USBR	Yes	The reporting outlined in the proposed plan does not include a clear indication of how NERC will use the information they collect from the entities. Care needs to be taken in addressing the reporting requirements to not create a more confusing or onerous reporting process.
<p><b>Response: The DSR SDT thanks you for your comment. It is anticipated that NERC will analyze events to assess trends and identify lessons learned for industry feedback and reliability improvement.</b></p>		
FirstEnergy	Yes	This guideline appears to be a good starting point for developing consistency in reporting. However, we believe that after-the-fact event reporting is administrative in nature and seldom rises to the level of mandated reliability standard requirements. It is not clear what reporting would be made through this effort and how it differs from reporting made through the NERC Reliability Coordinator Information System (RCIS). With the initiative for more results-based standards being the goal of NERC, true after the fact reporting-type requirements should become administrative procedures and only be included in standards if they are truly required for preserving an Adequate Level of Reliability. If there are aspects that rise to be retained in a mandatory and enforceable reliability standard, we propose that those associated with sabotage be moved to CIP-001 and that EOP-004 be focused on operational disturbances that warrant wide-area knowledge. However, if the RCIS is the mechanism to convey real-time information and that is presently occurring outside of reliability standards, it is unclear what the delta improvement this project aims to achieve.
<p><b>Response: The DSR SDT thanks you for your comment. As stated in FERC Order, 693, paragraph 611, “Complete and timely data is essential for analyzing system disturbances” and in paragraph 617, “the Commission directs the ERO to develop a modification to EOP-004-1 through the</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 1 Comment
<p>Reliability Standards development process that includes any requirements necessary for users, owners, and operators of the Bulk-Power-System to provide data that will assist NERC in the investigation of a blackout or disturbance”. Some data is needed, therefore, for after-the-fact analyses. In addition, some data is needed much more quickly for situational awareness. The DSR SDT will analyze and determine what constitutes a reportable event and what information is required for situational awareness as opposed to after the fact analyses of events.</p>		
Portland General Electric	Yes	This process is in place and utilities are familiar with it. This is a good place to start.
<p><b>Response: The DSR SDT thanks you for your comment and support.</b></p>		
Ameren	Yes	We agree that it makes sense to build upon existing documentation. However, we do not believe it is necessary to require event reporting to be in an enforceable standard. Rather the drafting team should consider developing a reporting guideline document and retiring the EOP-004 standard.
<p><b>Response: The DSR SDT thanks you for your comment. As stated in FERC Order, 693, paragraph 611, “Complete and timely data is essential for analyzing system disturbances” and in paragraph 617, “the Commission directs the ERO to develop a modification to EOP-004-1 through the Reliability Standards development process that includes any requirements necessary for users, owners, and operators of the Bulk-Power-System to provide data that will assist NERC in the investigation of a blackout or disturbance”. Some data is needed, therefore, for after-the-fact analyses. In addition, some data is needed much more quickly for situational awareness. As envisioned, the requirements developed under this project will address both types of reporting requirements.</b></p>		
Midwest ISO Standards Collaborators	Yes	We agree that it makes sense to build upon existing documentation. However, we do not believe it is necessary to require event reporting to be in an enforceable standard. Rather the drafting team should consider developing a reporting guideline document and retiring the EOP-004 standard. This is further supported by the fact that there is a role in the existing standard for the Regional Entities even though these requirements can’t be enforced against the Regional Entities because they are not a user, owner or operator of the system.
<p><b>Response: The DSR SDT thanks you for your comment. As stated in FERC Order, 693, paragraph 611, “Complete and timely data is essential for analyzing system disturbances” and in paragraph 617, “the Commission directs the ERO to develop a modification to EOP-004-1 through the Reliability Standards development process that includes any requirements necessary for users, owners, and operators of the Bulk-Power-System to provide data that will assist NERC in the investigation of a blackout or disturbance”. Some data is needed, therefore, for after-the-fact analyses. In addition, some data is needed much more quickly for situational awareness. As envisioned, the requirements developed under this project will address both types of reporting requirements.</b></p>		
Dynergy Inc.	Yes	We agree with using the guidance; however, please consider revising the NERC Guideline: Threat and Incident Reporting document to (i) lengthen the reporting timelines related to attempted sabotage to allow for

Organization	Yes or No	Question 1 Comment
		additional time to deem the threat credible, (ii) expand the description of forced outage of generation greater than 2000 MW to include whether it is at the BA or GO level and if GO level, whether it is for one site or the combined GO's sites in a Region, and (iii) add a Responsible Party column to the Appendix A matrix.
<p><b>Response: The DSR SDT thanks you for your comment. Recommendation of changes to the “NERC Guideline: Threat and Incident Reporting” should be submitted to NERC via the Critical Infrastructure Protection Committee since that falls outside the scope of the SAR.</b></p> <p><b>We will consider your specific suggestions for revisions to reporting requirements when we develop the proposed requirements.</b></p>		
BGE	Yes	We have no problem with NERC using the existing guidance as the foundation for disturbance reporting; however, since this project proposes to investigate incorporation of the Cyber Incident reporting aspects of CIP-008, we feel that if adopted, this concept should be added to the NERC Guideline document "Threat and Incident Reporting".
<p><b>Response: The DSR SDT thanks you for your comment. Recommendation of changes to the “NERC Guideline: Threat and Incident Reporting” should be submitted to NERC via the Critical Infrastructure Protection Committee since that falls outside the scope of the SAR.</b></p>		
Electric Market Policy	Yes	Yes; however, in considering guidance found in the document “NERC Guideline: Threat and Incident Reporting” the SDT should maintain focus on only those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. In fact, the purpose of reporting per EOP-004 is that disturbances... need to be studied and understood to minimize the likelihood of similar events in the future.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will establish the “requirements necessary for users, owners, and operators of the Bulk-Power-System” as stated in FERC Order 693, paragraph 617 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1. As envisioned, the requirements developed under this project will address reporting requirements that are used for after-the-fact analyses as well as reporting requirements that are associated with situational awareness.</b></p>		

**2. The DSR SDT is considering developing a reporting hierarchy for disturbances that requires entities to submit information to the Reliability Coordinator and then for the Reliability Coordinator to submit the report. Do you agree with this hierarchy concept? Please explain your response (yes or no) in the comment area.**

**Summary Consideration:** Most stakeholders (about 2/3) agree with the concept of developing a reporting hierarchy for disturbances. Stakeholders who disagreed believed that the RC should be one of many to receive information on impact events (DOE, RRO, etc.). Such a hierarchy would lead to reporting delays (leading to lack of situational awareness), be cumbersome and complicated and clouds responsibility for who is to report what to whom. Other negative comments believed that a hierarchy would distract the RC’s focus from its primary responsibility. Those stakeholders who agreed commented that the RC should be the collection point for reports and information and take the responsibility to forward as required. This is from the concept that the RC has the “wider view” and can recognize patterns, and has the ability to “escalate” the reporting process. This would also minimize duplication of reports and information.

Organization	Yes or No	Question 2 Comment
BGE	No	As currently worded, BGE opposes the reporting hierarchy concept, since insufficient guidelines were proposed to prevent translation errors between the responsible entity (RE) and the RC. In addition to creating possible reporting errors, this also opens a risk that the RC could misrepresent the true intent of an RE’s report contents if called upon to explain/justify a submitted report. Reporting delays are another concern with this proposal because the RE would basically be relinquishing control of the reporting process to the RC, while ultimately retaining the responsibility for ensuring the report gets submitted within the required timeframe. However, BGE recognizes that avoiding duplication and conflicting reports as well as encouraging communication are valuable. To make the reporting hierarchy concept acceptable to BGE, the DSR SDT must develop proper controls to ensure the RE has the ability to control or approve the information submitted and/or subsequently discussed with the respective authorities, and that it is done within the permissible timeframe to satisfy compliance requirements.
<p>Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk is not transferred, and a mechanism to ensure the Responsible Entity’s reported information remains as submitted.</p>		



**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
Consumers Energy Company	No	It would be inefficient for RC's to accumulate ALL disturbance data and submit it, and to bifurcate the reporting based on type of disturbance above and beyond OE-417 data (which should go ONLY to DOE) would make a standard very involved for an entity to comply with. We're discussing after-event data here, not data needed for current operations - and there's no reason to make it any more complicated than necessary.	
Response: The DSR SDT thanks you for your comment. In order for a reporting hierarchy concept to be adopted, it will result in real efficiency gains by eliminating duplication of reports. It will not be pursued if the result is a complicated or burdensome process for responsible entities.			
Exelon	No	Some of the DOE related reporting is driven by distribution events, i.e. outages greater than 50,000 customers, is it realistic to expect the RC, whose focus is on the transmission system to perform distribution related reporting?	
Response: The DSR SDT thanks you for your comment. The DOE Reporting Form OE 417 is currently mandatory by Public Law and only applies to US entities and contains reporting thresholds that are not required by NERC. Our goal is to derive reporting thresholds that meet NERC's needs for information on bulk electric system disturbances and real-time events, not distribution level-only problems.			
USBR	No	The existing reporting methods collect reports of disturbances and analyze them by committees of the respective coordinating councils. The new process would introduce a duplicate layer and associated staffing. It would be better to ensure communication between the existing committees of the respective coordinating councils and the RC rather than creating a new layer of review tracking and analysis. While the layered reporting hierarchy discussed in the Disturbance Reporting section of the paper will eventually help with overall event awareness, the additional delays the hierarchical approach could result in a decrease in situational (timely) awareness. Having more comprehensive information as a result of the potential enhancements each layer adds to the chain of reporting may not be more valuable than timely and well disseminated information in an actual disturbance situation. We would suggest the SDT give careful consideration to this proposed direction. It may be appropriate to consider that expedited reporting of operational impacts would outweigh the benefit of administratively intensive reporting procedures. The events reported through the existing process have not yielded material feedback other than statistical analysis. Statistical analysis is not as sensitive to timely reporting. Operational impacts which may be the result of possible sabotage may be evident through assessment of widespread outage patterns or following event analysis. Comprehensive event analysis can take anywhere from 15 days to 90 days depending on the event.	
Response: The DSR SDT thanks you for your comment. We agree that reporting timeliness must be weighed against the perceived benefits of a reporting hierarchy. If the reporting hierarchy concept is adopted, it should include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted. Also it must result in real efficiency gains and support the reliability of the bulk electric system.			

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 2 Comment
ISO RTO Council Standards Review Committee	No	<p>The idea of a reporting hierarchy provides an easy to follow pro forma approach. But disturbance reports should not always follow a common reporting path. A disturbance on the transmission system for example need not be routed through an “if applicable” Balancing Authority. To mandate that a BA be in the path is inappropriate. To leave the applicability open is to create a subjective compliance problem for the impacted BA. Copper theft is another example that should not require reporting up through the RC. It is a local issue and the Transmission Owner should be able to report this directly to the appropriate parties. How would a DP, LSE or GO know if an event is an “impact event”? The posed impact events are a series of conditions for sabotage but not for EOP-type disturbances. The aforementioned entities have no requirement to monitor and analyze the BES, which then means every event would be an impact event for those entities (not an EOP disturbance but an impact event). Thus every theft of copper is an impact event mandating a Disturbance Report even though the SDT notes the RC only has to send it to the “local authorities”. This seems to be a misuse of the RC resources; every train derailment is an impact event requiring a Disturbance report (is that a commercial train, regional rail line a local trolley car); every teenage prank would also generate an impact event mandating a disturbance report. The SDT defined impact events are not appropriate for use in defining disturbances. There is a big difference from creating a set of guidelines to follow as opposed to creating sanctionable standards</p>
<p>Response: The DSR SDT thanks you for your comment. Furthermore, impact events should not include copper theft or other conditions that pose no threat to the reliability of the BES. A train derailment is only an impact event if it threatens some element of the bulk electric system such as a transmission line corridor - the derailment in itself is not an impact event. See more on impact events under the responses to Question 3.</p>		
Bonneville Power Administration	No	<p>The RC is made aware of these type of incidents and goes right back to incorporating that in their awareness and to focusing on system reliability. If the RC is the recipient for further distribution of information of this type they will be forever going back for more information. Eliminate the middleman in whatever concept you propose, folks have plenty to do now. Let people make good judgments with the direct field people on the seriousness of the breach with their security personnel contacting the appropriate law enforcement agency. (Or are you looking to do a simple RE reports to the RC who marks various category items on a secure website Yes/No category item indicator that can be rolled up in ES-ISAC map board?)</p>
<p>Response: The DSR SDT thanks you for your comment. The Reliability Coordinator’s suggested role in this is to allow them to incorporate the relevant data from responsible entities in their footprint for further analysis.</p>		
Duke Energy	No	<p>The RC should not be responsible for submitting the report to FERC, NERC or the RRO. The RC may not have the necessary first hand information concerning the facts of the event. Situation awareness can be maintained by including the RC in the distribution of any sabotage related reporting.</p>

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
SERC Reliability Coordinator Sub-committee (RCS)	No	The RC should not be responsible for submitting the report to FERC, NERC or the RRO. The RC may not have the necessary first hand information concerning the facts of the event. Situation awareness can be maintained by including the RC in the distribution of any sabotage related reporting.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted. Also it must result in real efficiency gains and support the reliability of the bulk electric system.			
ERCOT ISO	No	There are some events that are truly local and should be handled by local entities and reported to local authorities (i.e. theft). If there is an impact or potential to have an impact to the BES or to the region, then hierarchical reporting would be appropriate.	
Response: The DSR SDT thanks you for your comment. We agree - a clearly defined impact event criteria would do just as you suggest - leave local issues on the local level.			
Northeast Power Coordinating Council	No	This is not a standards issue, and NERC should not dictate the reporting structure. It should be left to the RCs and their members.	
Response: The DSR SDT thanks you for your comment. In defining a disturbance reporting hierarchy we sought to realize efficiencies. If the reporting hierarchy concept is adopted, it must result in real efficiency gains and support the reliability of the bulk electric system. It will not be adopted if the result in a complicated or burdensome process for responsible entities.			
MRO's NERC Standards Review Subcommittee	No	We agree a coordinated reporting process is beneficial for the entity and the Reliability Coordinator (RC). However, a hierarchy would likely lengthen the reporting timeframe, or reduce the allotted time for each entity to provide notification to the RC in order to meet DOE or NERC timelines. Communication and coordination with the RC would likely provide more accurate and complete data submissions within a timely process and create shared accountability for the report being submitted.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and some mechanism to ensure the responsible entities' reported information remains as submitted.			

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
Midwest ISO Standards Collaborators	No	We do not agree with developing a hierarchy for reporting for all disturbances and impacting events. For instance, copper theft is an example of an item that should be reported to the appropriate entities directly by the Transmission Owner. The RC does not need to be made aware of every copper theft unless it has a direct impact on reliability (affects rating, protection system, etc.) and the RC should not be burdened with expending resources for this reporting. A further example in which the hierarchy is not needed would be the case in which only one entity is impacted. If a significant event occurs on one TOP's system, then the TOP should be able to handle the reporting of all entities under its purview. If more than one TOP is involved, then it would be necessary to involve the RC in the reporting.	
Response: The DSR SDT thanks you for your comment. The reporting hierarchy concept is meant to apply only to disturbance reporting. We agree that copper theft and other situations that do not pose a direct threat to reliability shouldn't be reported to NERC through this standard.			
FirstEnergy	No	While we appreciate the team's effort to serialize the reporting process, with the electronic communication methods available today, it seems that reporting can be accomplished simultaneously to multiple entities without shifting the burden of reporting to others along the communications path. This is particularly true if the reporting format is standardized to a one-size-fits-all report. Additionally, it would be a great burden to the Reliability Coordinator to review all events perceived by entities to be malicious sabotage events.	
Response: The DSR SDT thanks you for your comment. The reporting hierarchy concept would only apply to disturbance reporting, not impact events. The Reliability Coordinator's suggested role in this to allow them to incorporate the relevant data from responsible entities in their footprint for further analysis. We will consider your suggestion of simultaneous submissions as a means to effectively notify the necessary parties.			
Edison Mission Marketing & Trading	Yes		
PacifiCorp	Yes		
SPS Consulting Group Inc.	Yes		
Calpine Corp.	Yes	A Functional Entity such as a Generator Owner/Operator is not always aware that an event, such as a plant trip, is part of a wider system disturbance that rises to the level of a reportable event under EOP-004. A reporting hierarchy that allows a Generator to report the facts to its Transmission Operator and have that entity take a wider view to determine whether there is a disturbance should facilitate the reporting of actual disturbances. The SDT needs to ensure that some thought goes into the flow of information within the hierarchy and what triggers are needed to drive the reporting up the hierarchy.	

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting – Project 2009-01**

Organization	Yes or No	Question 2 Comment
<p>Response: The DSR SDT thanks you for your comment. A reporting hierarchy process must include clear triggers for reporting and provide an efficient, well-defined information flow.</p>		
We Energies	Yes	<p>A hierarchical approach in conjunction with a single, electronic form would provide consistent reporting timelines, provide clarity in the reporting process, and provide more accurate and meaningful data submissions while having shared accountability. Confusion in the current method could be alleviated while providing more consistency in the reporting of an "impact event".</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Arizona Public Service Company	Yes	<p>All disturbance reporting should go through the RC.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Constellation Power Source Generation	Yes	<p>As stated in the concept paper, a hierarchy ensures proper communications, but it has the added benefit of reducing redundancy on the Registered Entities, so long as responsibilities and accountability are clearly established.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Central Hudson Gas & Electric	Yes	<p>Central Hudson agrees with this reporting hierarchy for disturbances given the "wider-view" of the Reliability Coordinator as opposed to an entity such as a Transmission Owner or Load-Serving Entity. While, based on past experience, the current process works if reports are filed to the DOE, RRO, and RC simultaneously via email for example. However, the RC is in a better position to identify multi-site incidents and escalate the reporting process if necessary.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
Wolverine Power Supply Cooperative, Inc.	Yes	<p>From the perspective of a TOP, this seems to alleviate reporting burden and move it up line. I can understand the logic in wanting the reporting to flow through the RC for awareness purposes, but I can understand the RC's reluctance to bear the additional potential burden. Again, a focused effort to minimize the necessary reporting to "true impact events" should be kept in mind, regardless of who has to report. Collecting reams of data and figuring out what impact it has later should not be the goal.</p>

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 2 Comment
<p>Response: The DSR SDT thanks you for your comment. We agree that regardless of any reporting hierarchy, the goal is to report on disturbances and events with meaningful impact on the bulk electric system. See Question 3 responses for more information on how we view impact events.</p>		
Electric Market Policy	Yes	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System.
Hydro-Québec TransEnergie (HQT)	Yes	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System. The reporting hierarchy should be to submit the information to the Reliability Coordinator, and to have the RC submit the report. This would eliminate the duplication of information.
Orange and Rockland Utilities, Inc.	Yes	Having the reporting flow through the Reliability Coordinator supports the reliability objective of assessing, monitoring, and maintaining a wide-area view of the reliability of the Bulk Electric System. The reporting hierarchy should be to submit the information to the Reliability Coordinator, and to have the RC submit the report. This would eliminate the duplication of information.
<p>Response: The DSR SDT thanks you for your comment.</p>		
Lands Energy Consulting	Yes	I would give the RC the authority to establish impact thresholds for reporting. Consistent with my earlier comment, I would set the materiality threshold for disturbance reporting purposes at LSEs (or a combination of LSEs in the case of BPA) serving at least 90,000 customers.
<p>Response: The DSR SDT thanks you for your comment. Reporting thresholds in the standard will meet NERC requirements: Reliability Coordinator's may have different reporting criteria to meet Regional requirements, but they will not appear in this yet to be written Standard.</p>		
Central Lincoln	Yes	<p>In the west at least, this hierarchy should be extended to include BA's as indicated in the Concepts Paper. See: <a href="http://www.bpa.gov/corporate/business/reliability/Docs/2007/PNSC_RE_Data_Letter_2_070723.pdf">http://www.bpa.gov/corporate/business/reliability/Docs/2007/PNSC_RE_Data_Letter_2_070723.pdf</a></p> <p>for the RC's policy on which entities it chooses to communicate with.</p>

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 2 Comment
Response: The DSR SDT thanks you for your comment. The hierarchy concept includes BAs as appropriate in the reporting structure.		
Luminant	Yes	Luminant believes that one report should be filed with the Reliability Coordinator or one responsible entity, who then files the report with all applicable entities.
Response: The DSR SDT thanks you for your comment.		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that with this reporting hierarchy, in that dual reporting should be eliminated
Response: The DSR SDT thanks you for your comment.		
Portland General Electric	Yes	PGE is familiar with and works closely with WECC today so the hierarchial consideration makes sense.
Response: The DSR SDT thanks you for your comment.		
Platte River Power Authority	Yes	Situational awareness would be enhanced. All affected entities would be aware of the disturbance and relevant information. Also, the flow of information between entities would be enhanced and a more comprehensive report could be developed.
Response: The DSR SDT thanks you for your comment.		
Ameren	Yes	The hierarchy is appealing in the fact that the TOP/BA will be kept in the loop and receive critical information from the Generators, Distribution, LSE, etc. But there will be an inherent delay in reporting due to the fact that at every hand-off of information there will be questions for additional and/or clarified information, and there is always a possibility for the loss of information due to the transfer from one entity to the next. Further, this reporting through a hierarchy could also take away from the operators ability to respond to system events due to being tied to an information transfer ladder.
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and some process to ensure the responsible entities' reported information remains as submitted. It must also ensure that it does not place any extra burden on operators that could create an additional risk to reliability.		

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
E.ON U.S. LLC	Yes	The hierarchy will simplify reporting from the entity in that the RC is always notified and then the RC notifies other parties as required, (with the exception of OE-417, which still has to be filled out per law) E.ON U.S. recommends that the drafting team pay particular attention to the report process to make sure that duplicate reports are not being required. Currently information on forced outages is already communicated to the RC so formalizing a requirement to provide data to the RC may represent duplication to reports already provided.	
Response: The DSR SDT thanks you for your comment. Avoiding duplication is a key goal of the drafting team.			
Public Service Enterprise Group Companies	Yes	The PSEG Companies believe that all entities with a reportable disturbance should report to the RC. The RC is best positioned to evaluate the impact of the event and forward the information to the appropriate entities. There should not be any intermediate entities to relay information to the RC as that can introduce delay and has the potential to introduce transcription errors. Sabotage events should be reported to the RC as well as to law enforcement. CIP-008 reporting is highly specialized and should be retained in the set of cyber security standards, not merged with CIP-001 and EOP-004.	
Response: The DSR SDT thanks you for your comment. Detection of cyber events may be specialized but report of them is not. Threats to reliability must be reported no matter what the cause. The DSR SDT proposes using the thresholds found in CIP-008 - this standard would provide a one stop form to submit the information. Note that the current CIP-008 has a reporting requirement to the ES-ISAC only.			
Manitoba Hydro	Yes	The Reporting Concept states that the new hierarchy is, "Affected entity to TOP/ BA to RC. Then the RC will then submit to NERC and DOE (if required)". This will enhance the existing requirement EOP-004-1 R4 which states that the RC shall assist the affected entity by providing representatives to assist in the investigation (this is also all reiterated in Attachment 1-EOP-004) .In an disturbance, the local resources would be tied up in the rectification of the problem. Analyzing and reporting the event (is it reportable, who to report to, what is the timeline) is distracting and time consuming. By leaving the final upper level steps of reporting to NERC/DOE by the RC would be efficient.	
Response: The DSR SDT thanks you for your comment.			
Western Electricity Coordinating Council	Yes	There should be an established time sequence that allows the RC to review the entities material prior to forwarding to NERC. By channeling all reports through the RC situational awareness will be enhanced. Instead of "submit information", it should be clarified that entities submit complete written reports to RC in electronic format.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted.			



**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization		Yes or No	Question 2 Comment
American Electric Power	Yes	This approach may work as long as there is a uniform process across all of the Reliability Coordinators. AEP owns and operates BES facilities under three separate RCs and having differing rules and processes would create confusion and additional burdens. There are some concerns about the time lag of reporting the information and this might not work well in all cases especially if the information and knowledge are at the local level. AEP recommends that the standard could have a default hierarchy, but this should not prohibit any entity from reporting directly.	
Response: The DSR SDT thanks you for your comment. Our goal is uniform reporting criteria to meet specified requirements. We will consider the risks and benefits of allowing a default hierarchical reporting structure with the ability for responsible entities to report directly to NERC.			
Bandera Electric Cooperative, Inc.	Yes	This approach, while I suspect will not be universally agreed to, should provide some definitive guidance in reporting.	
Response: The DSR SDT thanks you for your comment.			
Dynegy Inc.	Yes	This seems to be straightforward approach in that the RC is the best judge of threats to the overall system and could eliminate multiple reports of a single event.	
Response: The DSR SDT thanks you for your comment.			
Independent Electricity System Operator	Yes	We do not agree with the need of such a hierarchy setup solely for the purpose of making reports to the need-to-know entities. All responsible entities (RC, BA, TOP, etc.) need to file a report. With the proposed set up noted under Q3, which we support, these reports should go directly to NERC. The RC should not be held responsible for forwarding other entities' reports to NERC, and in doing so subject itself to potential non-compliance.	
Response: The DSR SDT thanks you for your comment. If the reporting hierarchy concept is adopted, it will include controls to ensure timely reporting, clear accountability so that risk of a violation of the standard is not transferred, and a process to ensure the responsible entities' reported information remains as submitted.			

**3. The goal of the DSR SDT is to have one report form for all functional entities (US, Canada, Mexico) to submit to NERC. Do you agree with this change? Please explain your response (yes or no) in the comment area.**

**Summary Consideration:** Most stakeholders agreed with the concept of having one reporting form for all entities. Several commenters suggested that there is no need for a standard on reporting as they considered it administrative in nature. Most thought it should be a guideline, rather than an enforceable standard. There is widespread agreement that the one-size-fits-all approach would be very difficult to get agreement on, given the different countries and agencies involved. Many stakeholders pointed out that consistency and simplification were drivers for one report form. Having multiple recipients, with different information requirements, seem to support an electronic format that would guide information only to those who need it. The concept of an electronic reporting tool would need to be further vetted and developed.

Organization	Yes or No	Question 3 Comment
Bandera Electric Cooperative, Inc.		No preference in this area.
ISO RTO Council Standards Review Committee	No	The SRC supports NERC’s initiative for Results Based Standards. The SRC understood RBS to mean the results were reliability based quantities not administrative quantities. There is no need for a NERC Reliability standard on reporting. The idea that all functional entities in each of the said countries will use one form would be a good idea if and only if all the countries and all of their agencies were willing to accept that form. The SRC does not believe that those agencies will be willing to cede what information they ask for to NERC; nor that NERC will be able to create a single form that all such agencies will accept.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The set of results-based standards is intended to provide a ‘defense-in-depth’ approach to protecting reliability of the bulk power system. While many reports are administrative and are only used to assess compliance with specific requirements, the reporting addressed in this project is focused on providing data needed to support</p>		

Organization	Yes or No	Question 3 Comment
<p>after-the-fact analyses of events, and reporting information needed to maintain situational awareness. As such, the SDT believes that these reporting requirements do need to be enforceable.</p>		
FirstEnergy	No	<p>While one consistent form for reporting may simplify reporting requirements, it would be very difficult to get all governmental agencies to agree to a one-size-fits all approach.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</p>		
Public Service Enterprise Group Companies	No	<p>While simplification and consistency is a laudable goal, it should not be applied to different governmental agencies (USA, Canada, Mexico) which may have different structures and processes. Moreover, results based standards should not include administrative matters such as reporting forms.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The set of results-based standards is intended to provide a ‘defense-in-depth’ approach to protecting reliability of the bulk power system. While many reports are administrative and are only used to assess compliance with specific requirements, the reporting addressed in this project is focused on providing data needed to support after-the-fact analyses of events, and reporting information needed to maintain situational awareness. As such, the SDT believes that these reporting requirements do need to be enforceable.</p>		
American Electric Power	Yes	
Constellation Power Source Generation	Yes	
Exelon	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
Calpine Corp.	Yes	A single approach is desirable, particularly for those entities that find themselves in multiple regions or countries.
<b>Response: The DSR SDT thanks you for your comment.</b>		
We Energies	Yes	Agree in conjunction with proposed concept that DOE OE-417 will be allowed to supplement the NERC report in lieu of duplicating entries.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		
Consumers Energy Company	Yes	Agreed - to the extent that it’s consistent with the concept that any specific type of data is submitted to ONLY one entity.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		
Arizona Public Service Company	Yes	APS supports the standardization of the form for consistency and format.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Bonneville Power Administration	Yes	As long as we don’t make one form that requires extraneous information for the sake of having agreement.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
Western Electricity Coordinating Council	Yes	Canadian and Mexican entities should be consulted on content of report form to assure their "buy in".
<p><b>Response: The DSR SDT thanks you for your comment. It is DSR SDT’s intent to discuss the need for information with appropriate jurisdictional agencies.</b></p>		
Central Hudson Gas & Electric	Yes	Central Hudson agrees with this goal if the intent is to develop and implement an electronic version that would meet DOE requirements as well.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b></p>		
E.ON U.S. LLC	Yes	E.ON U.S. supports the proposal.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
MRO's NERC Standards Review Subcommittee	Yes	However, We believe the primary goal should focus on “each entity” being able to submit one report for all functional requirements. Entities in the US that are required to submit the DOE OE-417 form should not be required to submit an additional form developed for other entities (Canada & Mexico). One approach to satisfy this goal is for NERC to require all entities (US, Canada, & Mexico) to complete the DOE OE-417 form as their report.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Wolverine Power Supply Cooperative, Inc.	Yes	I can't see how anyone would disagree with this concept - However - I question how practical it will be to implement, since various agencies would have to collaborate and coordinate to accomplish this task.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
Lands Energy Consulting	Yes	I think that the impact approach makes sense and that EOP-004 and CIP-001 are logically connected. Many entities of which I am aware link Sabotage Reporting Training to Disturbance Reporting obligation awareness already.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that by using the same type reporting format, there should be consistency in regard to each functional entity's expectations.
<b>Response: The DSR SDT thanks you for your comment.</b>		
BGE	Yes	One form makes sense to us; less is better is the sense that it makes filing reports easier by not creating unnecessary complications.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Ameren	Yes	One report would be great for this standard. While this standard needs simplification and automation, we strongly suggest developing a guideline for reporting rather than enforceable standards.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The set of results-based standards is intended to provide a ‘defense-in-depth’ approach to protecting reliability of the bulk power system. While many reports are administrative and are only used to assess compliance with specific requirements, the reporting addressed in this project is focused on providing data needed to support after-the-fact analyses of events, and reporting information needed to maintain situational awareness. As such, the SDT believes that these reporting requirements do need to be enforceable.</b>		
Portland General Electric	Yes	PGE supports the efforts of the Standards Drafting Team on the SAR for Project 2009-01 to consolidate the disturbance and sabotage reporting processes as outlined in the concept paper.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Dynegy Inc.	Yes	Please keep it short and simple.

Organization	Yes or No	Question 3 Comment
<b>Response: The DSR SDT thanks you for your comment.</b>		
ERCOT ISO	Yes	Standardization ensures consistency and relevance of the information received.
<b>Response: The DSR SDT thanks you for your comment.</b>		
USBR	Yes	The Bureau of Reclamation utilizes a form for tracking unexpected events. This form contains information which the agency considers important for its one reliability improvement program. The form is also used to meet NERC standard requirements for protection system operations analysis. This form contains most of information required by DOE. The SDT should consider requiring the submission of specific information rather than lock responses in one specific form. In this manner the agency would be avoid duplicate forms, one for NERC, the other for agency purposes.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Central Lincoln	Yes	The existing reporting is needlessly complex. We appreciate the SDT's goal.
<b>Response: The DSR SDT thanks you for your comment.</b>		
SPS Consulting Group Inc.	Yes	There should have probably been one report all along.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Duke Energy	Yes	There should only be one report for all functional entities to submit to NERC.
<b>Response: The DSR SDT thanks you for your comment.</b>		
SERC Reliability Coordinator Sub-committee (RCS)	Yes	There should only be one report for all functional entities.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Manitoba Hydro	Yes	This is a promising idea, though there would be different requirements for the three countries, this could easily be rectified with "drop down menus". This electronic form could contain a lot of information without distracting clutter as you "tree" down the menu depending on the event that occurred. This could also contain electronic

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 3 Comment
		references to information located in Attachment 1-EOP-004 and Threat and Incident Reporting.
<b>Response: The DSR SDT thanks you for your comment. We will consider your specific suggestions when we develop the reporting requirements.</b>		
Hydro-Québec TransEnergie (HQT)	Yes	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Northeast Power Coordinating Council	Yes	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Orange and Rockland Utilities, Inc.	Yes	We agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC. This would provide for a consistent reporting format across the continent.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Midwest ISO Standards Collaborators	Yes	We agree with the goal of having a single report form but believe there will be a significant challenge to get varying governmental agencies to agree on single report format.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recongnize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</b>		
Edison Mission Marketing & Trading	Yes	With the realization that having a common report form may be difficult to coordinate between differen agencies.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT acknowledges the difficulty in attempting to present a single form. However, the DSR SDT believes it may be possible to achieve consolidation since the various reports ask repetitive questions. For example, having to provide</b>		



Organization	Yes or No	Question 3 Comment
<p>contact names, telephone numbers, email addresses on multiple forms is not an effective use of time or resources. Similarly, answering the question “Describe the event” or “What steps did you take” on multiple reporting forms is also not effective. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</p>		
Independent Electricity System Operator	Yes	Yes, this will simplify the reporting effort. NERC may forward the reports to the other need-to-know entities.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Electric Market Policy	Yes	Yes, we agree with the concept that there should be one report form for all functional entities (whether located in the US, Canada, Mexico) for use in reporting to NERC.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		

4. The goal of the DSR SDT is to eliminate the need to file duplicate reports. The standards will specify information required by NERC for reliability. To the extent that this information is also required for other reports (e.g. DOE OE-417), those reports will be allowed to supplement the NERC report in lieu of duplicating the entries in the NERC report. Do you agree with this concept? Please explain your response (yes or no) in the comment area.

**Summary Consideration:** Most stakeholders agreed with the concept of entities being able to use information from other sources such as the OE-417 form, to supplement the NERC report form. Some thought that duplicate reports were acceptable, as long as the information was not duplicated (if # of customers lost is required on form A, don't ask on forms B & C). Several stakeholders commented on the need for an electronic, one stop reporting tool. This would avoid duplication while ensuring that the information reported goes only to intended recipients. With an electronic, one stop reporting tool, reports can be updated/corrected instantly, without repeating previously submitted information. Some stakeholders cautioned that the OE-417 can change every three years and this should be taken into account when developing an electronic reporting tool. Again, such a reporting tool would need to be vetted and developed to meet reliability needs.

Organization	Yes or No	Question 4 Comment
ERCOT ISO		ERCOT ISO agrees with the concept of eliminating the need to file duplicate reports, but as stated in the Concept Paper, the DOE form (OE-417) is required by law. Based on this, the elimination of EOP-004 (after the fact reporting) is essential, since the OE-417 is mandatory and all-inclusive.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We agree that the OE-417 compiles a baseline set of information for disturbances, however, it does not function as an all-inclusive report of sabotage and cyber security incidents. The DSR SDT certainly seeks to gain efficiencies through the modification of EOP-004 and CIP-001, which may include the elimination of one or both. Further, the OE-417 is only mandatory for US entities.</p>		
Midwest ISO Standards Collaborators	No	It certainly makes sense to eliminate duplication in reporting and to allow supplemental information to be submitted in other reports. However, it does not make sense to require reporting to other governmental agencies through NERC enforceable NERC standards. Those governmental agencies already have legal authority to compel reporting. Again, we support developing a guideline for reporting rather than enforceable standards. The guideline could certainly explain the various reporting requirements and supplemental reporting requirements mentioned in the question without causing the issues we have identified in our comments.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an</p>		

Organization	Yes or No	Question 4 Comment
<p>option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</p>		
Consumers Energy Company	No	NERC should either coordinate with DOE for a single reporting process or simply adopt the DOE's standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements. The DOE report does not collect all the information that NERC needs.</p>		
E.ON U.S. LLC	No	<p>Reliability standards are federal law enforced by fines that can reach up to \$1,000,000 per day of violation. There is no reason to deliberately include ambiguity, i.e. "gray areas," in requirements such that registered entities are left unable to determine what it is they must do or refrain from doing to remain compliant. "Sabotage" for the purposes of these standards must be defined.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the DSR SDT is to develop requirements for reporting that will be clear and unambiguous with respect to compliance issues. Sabotage will be included in the reporting for "impact events", but may not be called 'sabotage' as there are many different interpretations of "sabotage".</p>		
ISO RTO Council Standards Review Committee	No	<p>The concept of eliminating duplication is laudable, but the idea of writing a standard to mandate reporting that involves reporting to governmental areas does not make sense unless NERC will do all of the reporting for the Industry. A governmental agency is as likely as not to change the forms they require which would then mean two different reports (one for NERC and one for the given agency) or that the standard would have to be re-written every time there is a change.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</p>		
Ameren	No	<p>The DOE OE-417 report should not supplement the NERC report due to the fact that the majority of reportable events are defined in/come from the OE-417 report. The NERC reporting form should be based on the OE-417 report and then include additional reporting requirements defined by NERC. However, it does not make sense to require reporting to the governmental agencies through enforceable NERC standards. The governmental agencies already have legal authority to compel reporting.</p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE, which is mandatory under Public Law for US entities. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</b></p>		
SERC Reliability Coordinator Sub-committee (RCS)	No	The requirement should be a single report that satisfies the need for all US governmental agencies as well as NERC and the RRO's.
<p><b>Response: The DSR SDT thanks you for your comment. The intent of the DSR SDT is to develop standards to address the reliability needs for NERC and not governmental agency reporting criteria.</b></p>		
Western Electricity Coordinating Council	No	This will work well for the USA entities to save us time in re-entering the same information. We believe that FERC and NERC and the Regions should have one common reporting form for North America. The OE-417 is not required by law outside of the United States. Canadian and Mexican entities may feel that US DOE has no jurisdiction in these countries, and therefore no right to required reporting as is stated on the OE-417.
<p><b>Response: The DSR SDT thanks you for your comment. We agree that the OE-417 report is not required for Canadian or Mexican entities. The DSR SDT does not envision a NERC standard mandating submission of reports to DOE. If the DSR SDT is able to develop a one-stop-shopping electronic form, we plan to develop an option to have the report submitted (or not) to NERC, DOE and FERC simultaneously. If an entity chooses to submit the report manually, they will then also be responsible for following DOE regulations and other mandatory requirements.</b></p>		
American Electric Power	Yes	
Edison Mission Marketing & Trading	Yes	
Exelon	Yes	
Orange and Rockland Utilities, Inc.	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting – Project 2009-01**

Organization	Yes or No	Question 4 Comment
Arizona Public Service Company	Yes	APS supports eliminating the need to file duplicate reports. This standardized form should generate and send the DOE OE-417 report, totally eliminating duplicate work. Streamline the process.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Central Hudson Gas & Electric	Yes	Central Hudson agrees with this concept and, as stated in a previous response, recommends that the ability of utilizing the DOE OE-417 to supplement the NERC report be maintained.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Calpine Corp.	Yes	Clarification, simplicity and the removal of duplicate reporting is beneficial.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Constellation Power Source Generation	Yes	Constellation agrees with the concept of eliminating the need to file duplicate reports. If the single NERC reporting form is both comprehensive and easy to use, then using a single report should not be an issue. It is essential that all elements of DOE OE-417, and any similar documents, be incorporated into this single report. Not incorporating all elements will result in gaps in reporting for all Registered Entities.
<b>Response: The DSR SDT thanks you for your comment.</b>		
SPS Consulting Group Inc.	Yes	Duplication is inefficient and casts the whole reporting mechanism in a questionable light.
<b>Response: The DSR SDT thanks you for your comment.</b>		
We Energies	Yes	However, also evaluate whether or not DOE OE-417 is sufficient in lieu of a NERC report. If additional information is required, duplicate format of DOE-OE-417 with additional NERC information listed at the end of the form.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Wolverine Power Supply Cooperative, Inc.	Yes	I agree with the concept of minimizing duplication - See previous question 3 for concerns.
<b>Response: The DSR SDT thanks you for your comment.</b>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 4 Comment
USBR	Yes	It should be clear what information is to be supplemented. The fewer times the information has to be handled the more efficient the process becomes. If the information exists on a required form, that legal form should be allowed. Also, if the form is already submitted, then reference to it should be sufficient rather than requiring resubmission of the form. That would require handling the information again. As explained in the previous answer, the SDT should recognize that responsible entities have already developed internal reporting processes which utilize forms for consistent responses. Those forms may contain more information than is needed by the new standard to be proposed. The entity should be allowed to submit the internal form or else duplication would be created, which may reduce the effectiveness of an entities reliability improvement program.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT envisions a one-stop-shopping form that allows reports to be saved, revised and resubmitted at a later date without re-entry of data or information. However, as a caution the DSR SDT cannot guarantee the possibility to submit custom forms.</b></p>		
Lands Energy Consulting	Yes	Less paperwork and fewer requirements to keep in mind during what may be once in a lifetime events are always good.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Luminant	Yes	Luminant agrees with the concept of reducing reporting requirements, but asks the SDT to go even further. In the concept paper, the SDT discussed that information would not be duplicated on the NERC report and the DOE OE-417 report. The concept paper described a process where one report would simply supplement the other, but two reports would still be filed when required. Can the NERC SDT work with the DOE to develop one report to meet the needs of NERC and the DOE?
<p><b>Response: The DSR SDT thanks you for your comment. We will consult with the DOE to see if one report will meet the reporting needs for NERC and the DOE. NERC reliability needs will take precedence.</b></p>		
Bonneville Power Administration	Yes	Minimizing the number of reports is a good thing. The concept of actually sharing information should be utilized as much as practical.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that this effort should eliminate file duplication

Organization	Yes or No	Question 4 Comment
<b>Response: The DSR SDT thanks you for your comment.</b>		
Bandera Electric Cooperative, Inc.	Yes	One can only assume the number of reports required in this area will continue to increase in terms of scope and to which agency wants this data. The SDT is encouraged to attempt to find a reporting format and scope that does not needlessly duplicate or complicate overall reporting obligations.
<b>Response: The DSR SDT thanks you for your comment. We will consult with the DOE and FERC to see if it one report will meet the reporting needs for NERC, FERC and the DOE. NERC reliability needs will take precedence.</b>		
Portland General Electric	Yes	PGE supports reducing the duplication of reporting.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Dynergy Inc.	Yes	Short and simple should be the goal.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Duke Energy	Yes	Since the OE-417 is a DOE required report, it must be submitted. Including the OE-417 as part of the NERC electronic form will facilitate reporting to NERC.
<b>Response: The DSR SDT thanks you for your comment. We will consult with the DOE to see if it one report will meet the reporting needs for NERC and the DOE. NERC reliability needs will take precedence.</b>		
Central Lincoln	Yes	The existing reporting is needlessly complex. We appreciate the SDT's goal.
<b>Response: The DSR SDT thanks you for your comment.</b>		
Public Service Enterprise Group Companies	Yes	The PSEG Companies agree with the avoidance of duplicate reports. NERC report forms should not include anything in the DOE form, and NERC Regional report forms should not include anything in the DOE or NERC forms. Hence, a DOE report should not "supplement" a NERC form, but rather replace it unless the NERC form calls for other information for the same reportable incident, and likewise for the DOE - NERC - Regional form structure. DOE forms would be filed with DOE, NERC and the Regional Entity where the event originated. NERC forms would be filed with NERC and the region where the event originated and the Regional form filed only with the Region. In designing the NERC and Regional forms, the need to file multiple reports should be minimized, and in no event should any of the three (DOE, NERC, Region) forms contain

Organization	Yes or No	Question 4 Comment
		duplicative information requests.
<b>Response: The DSR SDT thanks you for your comment. We will consider your comment in the development of the reporting structure / forms.</b>		
Manitoba Hydro	Yes	This could be easily incorporated into the electronic form. You could be prompted for information required immediately, and notified for information that could be entered later. This form could contain all the enterable data that all agencies could require. If the form is live and on line, all entities could be notified (depending on the entries) of an going event immediately. Form could be web based similar to ARS program or even integrated into the ARS program.
<b>Response: The DSR SDT thanks you for your comment. We will consider your comment in the development of the reporting structure / forms.</b>		
FirstEnergy	Yes	We agree that the simplification and consistency of reporting will improve the reporting of this information. We support the drafting team's efforts in this area and hope that all regulatory agencies will as well. However, as we have mentioned in our other comments, the reporting requirements should not be in a reliability standard unless they are proven to be necessary to maintain an Adequate Level of Reliability of the BES. Reporting of these events should be required by NERC in arenas outside of the standards.
<b>Response: The DSR SDT thanks you for your comment. The information provided in the reports is either used after the fact for analyses or used to maintain situational awareness, and is needed for reliability.</b>		
MRO's NERC Standards Review Subcommittee	Yes	We agree with the concept to eliminate duplicate reports. However, we are concerned with the reference of the DOE OE-417 report being a "supplement" of the NERC report rather than "accepted" as the NERC report.
<b>Response: The DSR SDT thanks you for your comment. Future NERC reliability reporting needs may not totally align with DOE report information. Therefore, the OE-417 report would not necessarily substitute for the NERC report. The DOE Reporting Form OE 417 is currently mandatory by Public for US entities.</b>		
Hydro-Québec TransEnergie (HQT)	Yes	We agree with the objective of eliminating duplicate reporting. However, EOP-004 currently allows substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today. We agree with the recommendation to eliminate the need for filing duplicate reports such as the DOE form OE-417. There is no benefit with regard to CIP-001 in filing separate reports. Duplicate reports introduce the potential for incomplete information to be supplied to responsible parties.



**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 4 Comment
		Removing jurisdictional agencies from the Standard, and having NERC provide either query or situational awareness to those agencies being considered, might not be easy to achieve. There is an obligation under law to require entities to report to the DOE on the OE-417 form as amended or modified. This might drive the “omitted” agencies to have reporting laws enacted as well.
Northeast Power Coordinating Council	Yes	<p>We agree with the objective of eliminating duplicate reporting. However, EOP-004 currently allows substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today. We agree with the recommendation to eliminate the need for filing duplicate reports such as the DOE form OE-417. There is no benefit with regard to CIP-001 in filing separate reports. Duplicate reports introduce the potential for incomplete information to be supplied to responsible parties.</p> <p>Removing jurisdictional agencies from the Standard, and having NERC provide either query or situational awareness to those agencies being considered, might not be easy to achieve. There is an obligation under law to require entities to report to the DOE on the OE-417 form as amended or modified. This might drive the “omitted” agencies to have reporting laws enacted as well.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT has discussed the possibility of consolidating CIP-001 and EOP-004 to create a single reporting standard. FERC directives require modifications to the standards which also may impose additional reporting requirements (see paragraph 470 of Order 693).</b></p> <p><b>We concur with your comments regarding the legal obligations to submit certain reports. The DSR SDT is attempting to consult with appropriate governmental agencies to address this.</b></p>		
BGE	Yes	We agree with this approach, as long as the latest version of the DOE OE-417 form is fully incorporated in the new single-reporting form, so that it maintains its credibility with the DOE.
<p><b>Response: The DSR SDT thanks you for your comment. The intent is to maintain credibility with the DOE reporting requirements.</b></p>		
Independent Electricity System Operator	Yes	We support this concept since it works well for those entities that are not required to file reports with the US agencies, e.g. the DOE.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Electric Market Policy	Yes	Yes, we agree with the objective of eliminating duplicate reporting; however, EOP-004 currently allows

Organization	Yes or No	Question 4 Comment
		substitution of DOE OE-417 in place of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report. As suggested in the Concept Paper, entities meeting the criteria of OE-417 are still obligated to file a report with DOE. Given that and the fact that CIP-001 requires no actual reporting, it is not clear where duplication exists today.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT has discussed the possibility of consolidating CIP-001 and EOP-004 to create a single reporting standard. FERC directives require modifications to the standards which also may impose additional reporting requirements (see paragraph 470 of Order 693).</b></p>		

**5. In its discussion concerning sabotage, the DSR SDT has determined that the spectrum of all sabotage-type events is not well understood throughout the industry. In an effort to provide clarity and guidance, the DSR SDT developed the concept of an impact event. By developing impact events, it allows us to identify situations in the “gray area” where sabotage is not clearly defined. Other types of events may need to be reported for situational awareness and trend identification. Do you agree with this concept? Please explain your response (yes or no) in the comment area.**

**Summary Consideration:** The majority of stakeholders agreed with the concept of impact events. Some stakeholders felt that the introduction of impact events increased the risk that some items will go unreported. However, most felt that impact events would dramatically increase the number of reports being submitted, and it would be difficult to separate important information from background noise. Several respondents felt that the SDT ignored the FERC Directive, and did not define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event. Many respondents supplied the SDT with their own definition of “Sabotage”. The DSR SDT believes that the concept of impact events and the specificity of what needs to be reported in the standard will be an equally efficient and effective means of addressing the FERC directive regarding sabotage. Some stakeholders felt that impact events add another layer of uncertainty to the reporting. Even with the switch from sabotage to impact events, several felt that “intent” was still key to determining reportability.

Organization	Yes or No	Question 5 Comment
ERCOT ISO		ERCOT ISO recognizes the risks associated with “gray areas” not being clarified. While “gray areas” pose compliance risk due to differing interpretations, a risk remains that some items will go unreported. A more prescriptive approach raises an even greater risk of events not being reported. People will not report events that are not specifically listed, and will not use judgment in determining the need for reporting.
<p><b>Response: The DSR SDT thanks you for your comment. We agree that a more prescriptive approach could pose greater risks but we will attempt to clarify and define an approach to assist the industry and stakeholders for reporting impact events.</b></p>		
Constellation Power Source Generation	No	Although defining an impact event would bring clarity to defining sabotage events, adding another situation would further complicate things. Furthermore, the examples of impact events used all fall under the Sabotage category in the Threat and Incident Reporting Guideline. Constellation Power Generation suggests the SDT further clarifies the items in the Sabotage category to ensure all grey area situations are included. Clarification is also needed in how a Cyber Security Incident (CIP-008) would map into the categories of Disturbance/Impact Events (CIP-001). To that point, Constellation Power Generation questions whether cyber related incidents should fall under the spectrum of sabotage type events, or remain separate and be incorporated in the CIP revisions. Having cyber related incidents separate from other sabotage events would

Organization	Yes or No	Question 5 Comment
		provide the clarity and guidance that the DSR SDT is striving to achieve.
<p><b>Response: The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include all events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact the reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</b></p>		
Duke Energy	No	As FERC ordered in Order No. 693, the drafting team should further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event. Suggested definition: “Sabotage - the malicious destruction of, or damage to assets of the electric industry, with the intention of disrupting or adversely affecting the reliability of the electric grid for the purposes of weakening the critical infrastructure of our nation.”
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with deterring “intent” which may not be determined until after a lengthy investigation. We will continue to discuss for inclusion in a future draft of this project. The DSR SDT believes that the concept of impact events and the specificity of what needs to be reported in the standard will be an equally efficient and effective means of addressing the FERC directive regarding sabotage.</b></p>		
Kootenai Electric Cooperative	No	Impact events seems to add another layer of uncertainty to the reporting. Define a transmission line. Our transmission lines have very little impact on the grid. It is possible for our lines to cause a local area outage on our transmission provider - but neither is of national security interest or even regional interest. There is no power flow going on across the lines other than local power delivery supply. It seems you run more risk of losing the important reports in the snow of reporting - similar to what we have to avoid on our SCADA systems for our operators to see the key information.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT understands your concern and this was discussed a great deal. It is our belief that criteria of the “impact events” to be reported will be properly defined and discriminated from local events that have no impact on the reliability of the BES.</b></p>		
SERC Reliability Coordinator Sub-committee (RCS)	No	Impact events that do not affect reliability should not be reported.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees but a balance must be further explored to meet industry and regulatory requirements specifically under FERC Order 693.</b></p>		
Luminant	No	Luminant would prefer to report disturbances and sabotage events. The reporting of impact events could lead to unnecessary reporting. A definition of an “impact event” may be even more confusing than sabotage

Organization	Yes or No	Question 5 Comment
		events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT understands your concern and this was discussed a great deal. It is our belief that criteria of the “impact events” to be reported will be properly defined and discriminated from local events that have no impact on the reliability of the BES. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</p>		
Orange and Rockland Utilities, Inc.	No	<p>Physical and cyber events must be investigated before a determination of sabotage or impact event can be made. Impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on ‘newsworthy’ events or to gather information for trending. It is the law enforcement industry’s responsibility to make a determination of “sabotage” or other. This determination cannot definitively be made by industry (operating) personnel. If NERC's definition is expanded for CIP-001 and/or EOP-004, responsibility and timing of reporting needs to be addressed so that appropriate agencies conduct the investigation and assessment. Operating personnel need to remain focused on the primary responsibility of mitigating the effects.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT struggles with terms that deal with determining “intent” which may not be determined until after a lengthy investigation. We will continue to discuss these ideas for inclusion in a future draft of this project. Timing of the reporting process will be further clarified based upon your comments and those in the industry that have voiced similar concerns.</p>		
MRO's NERC Standards Review Subcommittee	No	<p>Rather than attempting to define a new term (impact event), we suggest that the concept of impact event be replaced with further defining sabotage and providing guidance on trigger events (impact event) that would cause an entity to report.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We will continue to discuss the FERC “Clarification of sabotage” directive and seek further guidance to meet this directive. The term sabotage has created conflict in its meaning among stakeholders as to when it is determined and by whom and how long an investigation would take to make that call on the intent of the saboteur. The DSR SDT is reviewing what a reportable disturbance actually is and sabotage may be a sub component of a reportable disturbance event.</p>		
Lands Energy Consulting	No	<p>The level of complexity described will overwhelm the 20-200 employee utilities that have yet to see - and will never see - the kind of sabotage event that scares the Department of Homeland Security.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT does not intend for the reporting of impact events to overwhelm smaller entities. If events do not affect the reliability of the BES, then it is our intent that they will be excluded from reporting requirements under our proposal. We will attempt to clarify and define an approach to assist the industry and stakeholders for reporting impact events. FERC cautioned the</p>		

Organization	Yes or No	Question 5 Comment
<p><b>industry that acts of sabotage may be “tested” on smaller entities and ultimately on larger entities.</b></p>		
<p>ISO RTO Council Standards Review Committee</p>	<p>No</p>	<p>The nature of the fact that “gray areas” exists preclude the idea of using a standard to report; particularly a standard for the vague topic of motivation such as sabotage events and the more defined disturbance events.</p>
<p><b>Response: The DSR SDT thanks you for your comment. We will attempt to clarify and define an approach to assist the industry and stakeholders for reporting impact events.</b></p>		
<p>Edison Mission Marketing &amp; Trading</p>	<p>No</p>	<p>There are too many special circumstances to try and capture. I feel this would be best delivered as a guideline.</p>
<p><b>Response: The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</b></p>		
<p>Exelon</p>	<p>No</p>	<p>We agree with the direction to identify impact events examples that would trigger reporting and not be limited to sabotage reporting only. It is important to note that when an incident occurs, some level of investigation is required before a determination can be made as to the event is sabotage or not. The focus should be on reporting events when they occur and allow follow-up investigations to make the sabotage determination. That being said, care must be taken in the development of any list of impact events so that it doesn't become or is misinterpreted to be a definitive list. Therefore if it is not on the list, it is not reportable.</p>
<p><b>Response: The DSR SDT thanks you for your comment. We concur and plan to allow reports to be submitted, edited and re-submitted in the one-stop-shopping reporting tool. We are suggesting the term “Impact Event” be substituted for sabotage and include only events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples.</b></p>		
<p>Midwest ISO Standards Collaborators</p>	<p>No</p>	<p>We agree with the idea of identifying impact events but do not support the requirement for these to be always reported through the hierarchical structure identified in question 2. If an impact event only affects one entity, that entity should have the reporting requirement.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSRSDT will continue to explore the benefits and weaknesses of the hierarchy reporting structure.</b></p>		
<p>Hydro-Québec TransEnergie (HQT)</p>	<p>No</p>	<p>We believe that physical and cyber events must be investigated before a determination of sabotage or impact event can be made. The purpose of the NERC Standards is to maintain the reliability of the BES. Therefore,</p>

**Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01**

Organization	Yes or No	Question 5 Comment
		<p>impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on 'newsworthy' events or to gather information for trending. It is the law enforcement industry's responsibility to make a determination of "sabotage" or other. This determination cannot definitively be made by industry personnel, there is no expertise or time to investigate causes. It is the industry's job to mitigate effects. Examples would help provide for better guidance/direction. Industry examples would be welcomed to help reinforce developed internal processes for compliance.</p>
Northeast Power Coordinating Council	No	<p>We believe that physical and cyber events must be investigated before a determination of sabotage or impact event can be made. The purpose of the NERC Standards is to maintain the reliability of the BES. Therefore, impact events should define or clarify the circumstances that would or could affect reliability. Reportable items should be based on impact to reliability, not on 'newsworthy' events or to gather information for trending. It is the law enforcement industry's responsibility to make a determination of "sabotage" or other. This determination cannot definitively be made by industry personnel, there is no expertise or time to investigate causes. It is the industry's job to mitigate effects. Examples would help provide for better guidance/direction. Industry examples would be welcomed to help reinforce developed internal processes for compliance.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with determining "intent" which may not be determined until after a lengthy investigation. We will continue to discuss issues with sabotage for inclusion in a future draft of this project. Timing of the reporting process will be further clarified based upon your comments and those in the industry that have voiced similar concerns.</b></p>		
American Electric Power	Yes	
Calpine Corp.	Yes	
PacifiCorp	Yes	
Platte River Power Authority	Yes	
Central Lincoln	Yes	<p>An act of vandalism may have impact. An act of sabotage may not be impactful alone, but may be part of a wider coordinated attack. Dictionary definitions speaking of "intent" are not helpful in this regard, since acts of vandalism and sabotage are both generally committed intentionally. Saboteurs, though, work for a higher cause. That cause may be political, social, environmental, etc. We ask that the SDT look beyond dictionary definitions in developing a definition of sabotage.</p>

Organization	Yes or No	Question 5 Comment
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with determining “intent”. The term sabotage has created conflict in its meaning among stakeholders as to when its determined and by whom and how long an investigation would take to make that call on the intent of the saboteur. We will strive to meet this challenge with the input on the right language from government agencies and industry experience expertise.</b></p>		
Bonneville Power Administration	Yes	BPA agrees with providing an industry-wide definition and guideline. We do NOT agree with requiring reports for every instance of every activity. If your definition is good, you'll get what is needed and not much chaff.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		
Central Hudson Gas & Electric	Yes	Central Hudson agrees with this concept, particularly if the reporting hierarchy through the RC is implemented in order to better identify trends.
<p><b>Response: The DSR SDT thanks you for your comment. The DSRSDT will continue to explore the benefits and weaknesses of the hierarchy reporting structure.</b></p>		
Wolverine Power Supply Cooperative, Inc.	Yes	I agree with the concept of focusing on impact instead of the type of event (sabotage, accident, vandalism, etc.)I hope that the reporting proposal that comes out of this project will clearly make a separation between true impact events that must be reported per the standards (enforceable), vs. "other" information that may be (electively - not enforceable) reported, per some set of guidelines.
<p><b>Response: The DSR SDT thanks you for your comment. We agree reportable items should be based on impact to reliability and with other commenters that expressed a desire to avoid reporting on ‘newsworthy’ events but to gather meaningful information for trending. We are suggesting the term “Impact Event” be substituted for sabotage to include only events that would impact the reliability of the BES.</b></p>		
Bandera Electric Cooperative, Inc.	Yes	In principle, I agree with this concept. Would like for the SDT to pursue this further and seek additional comments at that time.
<p><b>Response: The DSR SDT thanks you for your comment. We will seek further comments on the concept and will prepare the beginnings of the first draft soon.</b></p>		
Oncor Electric Delivery Company LLC	Yes	Oncor agrees that there are no broadly used guidance documents that detail how an event may be accurately defined.
<p><b>Response: The DSR SDT thanks you for your comment. We agree that further industry guidance of a clear and understandable standard should be sought under the new Results Based approach. We will attempt to clarify and define an approach to assist the industry and stakeholders in reporting</b></p>		



Organization	Yes or No	Question 5 Comment
<b>impact events.</b>		
Portland General Electric	Yes	PGE supports the DSR SDT's efforts to bring clarity and guidance to the spectrum of sabotage-type events.
<b>Response: The DSR SDT thanks you for your comment.</b>		
FirstEnergy	Yes	The concept paper makes good progress in this area and the drafting team is on the right track, and agree that better clarity needs to be developed surrounding sabotage events. However, some of the examples stated in the paper are too vague and do not address extenuating circumstances or reasons for the events. One example sighted in the paper is "Bolts removed from transmission line structures." This statement may be too broad. For instance, if the bolts are removed from the tower and the organization is not experiencing a labor dispute, it could be considered a sabotage event with wide area implications. However, if the organization is in the middle of a labor dispute, this would be vandalism and would most likely not be of a wide area concern. Also, the number and location of towers affected could be an important determination related to the risk the event imposes on the Bulk Electric System.
<b>Response: The DSR SDT thanks you for your comment. We concur with your comments that the number and location of the towers affected may have a "local" vs "wide area" concern. However, under the "impact event" reporting that we are proposing, both scenarios above should be reported as impact events as long as it affects the BES.</b>		
Public Service Enterprise Group Companies	Yes	The PSEG Companies agree with the concept, but reserve judgment on the descriptions of the impacts. There is clearly a need to better define what constitutes a sabotage incident versus common theft or vandalism. Moreover, where it may be impossible to determine if any given incident (e.g., several loose bolts on a transmission tower cross brace could be sabotage or could be human error in construction) falls within sabotage, a registered entity should not be second guessed in an audit if the registered entity determines not to report. Excessive unnecessary reporting can mask real incidents.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees with clearly defining a reportable impact versus common theft. Concern over reporting an incident and the audit process are within the discussions of the DSR SDT and will be fully explored to assist with the 1<sup>st</sup> Draft. The ability to identify trends could be very important compared to isolated incidents that do not impact the BES. Every effort to explore this balance of reporting will be taken into account.</b>		
SPS Consulting Group Inc.	Yes	The term sabotage was always too narrow a concept for the standards. At times, questionable activities are not confirmed as sabotage events until well after the fact, forcing the registered entity to speculate on whether or not to report an activity that may not be a confirmed sabotage event at the time, and hence encounter another silly violation based on imprecise terminology.

Organization	Yes or No	Question 5 Comment
<p><b>Response: The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include all events that would impact the reliability of the BES. Events now included in reporting requirements that do not impact reliability of the BES would be excluded from the reporting unless the DSR SDT clarifies why it should be included and under what specific instances or examples. Tightening the reporting criteria of impact events could possibly address the concern expressed by a “violation based on imprecise terminology.”</b></p>		
USBR	Yes	<p>There should be a clear distinction between a cyber event and a cyber event that has a material impact on the reliability of the bulk electric system. Not all CIP-008 events will carry such a distinction. That being said, CIP 008 cannot be completely incorporated in this process. Denying access to a cyber asset is noteworthy under CIP008 but may not pose a threat to the reliability of the bulk electric system. Consider recognizing the impact on the bulk electric system when modifying definitions of adding the bulk electric system description to the definitions. This will help to clarify that disturbances, as discussed in this effort, are situations that produce an abnormal condition on the electric power system, not necessarily on ancillary or supporting systems, such as SCADA systems or the water-related systems at hydroelectric dams.</p>
<p><b>Response: The DSR SDT thanks you for your comment. We are suggesting in our discusssion to consolidate the location of reporting into one standard. The industry has demonstrated by comments that it favors streamlining the reporting process to achieve a “one stop shop” approach. We will continue to explore the possibilities to achieve the best results for all stakeholders. A discussion of advantages /disadvantages will continue to discover options and alternatives with input from all stakeholders.</b></p>		
Western Electricity Coordinating Council	Yes	<p>This will help eliminate regional differences in sabotage reporting. The definition should be broad enough so it covers new types of sabotage that may evolve. Event analysis facilitates situational awareness and if it requires further investigation regarding developing patterns and severity, it should be handled by law enforcement if need be.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will continue to explore the “Impact Event” definition to allow for new types of events. Event analysis is clearly a goal of reporting as is situational awareness and hopefully this project will enhance the understanding and clearly define obligations to all stakeholders.</b></p>		
Manitoba Hydro	Yes	<p>Though there are some specific events already included in this new definition, more could be added to dissolve specific “gray areas” and as new ones come up. Again these examples could be added into the electronic form and could contain a large data base which would be available depending on the event that occurred.</p>
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>		

Consideration of Comments on Concept Paper for Disturbance and Sabotage Reporting — Project 2009-01

Organization	Yes or No	Question 5 Comment
BGE	Yes	We agree that "the spectrum of all sabotage-type events is not well understood throughout the industry"; however, we feel that the proposed concept of an "Impact Event" falls short of clarifying what constitutes such events. We believe that "Impact Events" needs further clarification to eliminate "gray areas" and to provide more reporting consistency between entities.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will continue to clarify the impact events concept and eliminate “gray areas” while including language to give clarity to the reporting process.</b></p>		
Dynergy Inc.	Yes	We agree with the concept but please provide specific examples. Also, please consider whether there are any penalties for misinterpreting an incident, who would determine if an event was a threat, and whether this could result in over reporting non-threats.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT may include specific examples of impact events and types of reportable events in the 1<sup>st</sup> draft of the standard (or in supplemental guidance) to help illustrate reportable criteria.</b></p>		
Consumers Energy Company	Yes	We agree with the concept, however, based on the information provided, it may be too vague to be of value. Terms such as “potential” and “significant” can be subjective and therefore provide little direction. We would like to see something more specific. Also, inclusion of the destruction of BES assets may be too inclusive and needs to be restricted to BES assets that will cause a specific level of impact on reliability.
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT struggles with terms that deal with determining “potential” and “significant”. Specific examples of criteria is being explored and discussed. We will strive to meet this challenge with the input on the right language from government agencies and industry experience expertise. Your suggestion of restricting to BES assets that will cause a specific level of impact on reliability will be discussed with the DSR SDT.</b></p>		
Independent Electricity System Operator	Yes	We agree with the general concept. However, we suggest that the classification of “events” to be compatible if not identical to those which need to be reported in real time as required in CIP-001, for otherwise it will create confusion and unnecessary, extra work. Also, this proposal appears to focus on the sabotage-type events only but the SAR deals with both sabotage and other disturbances (e.g. emergency type of events) reporting. A parallel type of “impact event” is needed for non-sabotage-type of events.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT notes that impacts events include both sabotage and non-sabotage types of events and these events include CIP-001 events.</b></p>		
Electric Market Policy	Yes	We believe that physical and cyber events must be investigated before a determination of sabotage or impact

Organization	Yes or No	Question 5 Comment
		event can be made.
<p><b>Response: The DSR SDT thanks you for your comment. We agree that sabotage requires investigation. The term “impact event” was developed to allow immediate reporting of events based on impact to the BES rather than intent.</b></p>		
We Energies	Yes	We would prefer to refer to all sabotage, vandalism, cyber attacks, and other criminal behavior as impact events. Focusing more on the event's impact on reliability and its ramifications on the systems seems to be more useful than to try to determine the intent of the perpetrator.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees with your assessment and will pursue the clarity and criteria examples to achieve reporting.</b></p>		

**6. If you are aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004 please provide them here.**

**Summary Consideration:** Several commenters provided information on regional reporting. The SDT will consider whether these should be included in the continent-wide standard. These include:

1. NPCC maintains a document and reporting form (Document C-17 - Procedures for Monitoring and Reporting Critical Operating Tool Failures) that outlines the reporting requirements, responsibilities, and obligations of NPCC Reliability Coordinators in response to unforeseen critical operating tool failures.
2. For other events that do not meet the OE-417 and EOP-004 reporting criteria, ReliabilityFirst expects to receive notification of any events involving a sustained outage of multiple BES facilities (buses, lines, generators, and/or transformers, etc.) that are in close proximity (electrically) to one another and occur in a short time frame (such as a few minutes).
3. WECC sets its loss of load criteria for disturbance reporting at 200 MW rather than the 300 MW in the NERC reporting form.
4. SERC and RFC are developing additional requirements at this time.
5. We suggest that reporting be based on impact to reliability, not on 'newsworthy' events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirements.
6. MISO RC (MISO OP-023) and RFC (PRC-002-RFC-01).

Organization	Question 6 Comment
Central Hudson Gas & Electric	Although not beyond the scope of these standards, NPCC maintains a document and reporting form (Document C-17 - Procedures for Monitoring and Reporting Critical Operating Tool Failures) that outlines the reporting requirements, responsibilities, and obligations of NPCC RCs in response to unforeseen critical operating tool failures.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b></p>	
Exelon	At the 2010 RFC Spring Workshop the following disturbance reporting Criteria was rolled out: All events that are required to be reported by the OE-417 and EOP-004 criteria will use those published procedures. For other events that do not meet the OE-417 and EOP-004 reporting criteria, ReliabilityFirst expects to receive notification of any events involving a sustained outage of multiple BES facilities (buses, lines, generators, and/or transformers, etc.) that are in close proximity (electrically) to one another and occur in a short time frame (such as a few minutes).

Organization	Question 6 Comment
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b></p>	
Lands Energy Consulting	I believe WECC sets its loss of load criteria for disturbance reporting at 200 MW rather than the 300 MW in the NERC reporting form.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will consider regional criteria when developing reporting thresholds.</b></p>	
Edison Mission Marketing & Trading	I don't know of any.
Orange and Rockland Utilities, Inc.	NERC's SDT effort requires a clear, consistent, and comprehensive continent-wide approach, thus mitigating any need for regional reporting requirements.
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT feels in many instances that region specific standards may be needed. However, the SDT will provide a clear reporting standard that can be consistently followed continent-wide.</b></p>	
MRO's NERC Standards Review Subcommittee	No Comment.
Duke Energy	None
Bandera Electric Cooperative, Inc.	No.
Manitoba Hydro	No.CIP-001 contains references to NERC and the DOE.CIP-008 makes exclusions for facilities regulated by US Nuclear Regulatory Commission and Canadian Nuclear Safety Commission. It also contains references to ES ISAC (Electricity Sector Information Sharing and Analysis Center).EOP-004 contains reference to NERC and DOE. There is no reference to Homeland Security, FBI, etc or to Canadian equivalent references in any of these Standards. When NERC is notified of an event, it is likely other organizations will have to be notified. There should be some sort of consistency to cover all these Standards and all notifiable parties at a NERC Standards level.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT absolutely understands your provided comment and have had detailed conversations surrounding “who” should be notified and “when”. Most importantly, a level of consistency should exist when reporting disturbances and sabotage events negatively impacting the BES.</b></p>	

Organization	Question 6 Comment
Oncor Electric Delivery Company LLC	Oncor is not aware of any regional reporting requirements beyond the scope of CIP-001, CIP-008 and EOP-004.
<b>Response: The DSR SDT thanks you for your comment.</b>	
Dynergy Inc.	Please consider MISO RTO-OP-023.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard. Please provide a copy of the subject document.</b>	
Electric Market Policy	SERC and RFC are developing additional requirements at this time. We suggest that reporting be based on impact to reliability, not on 'newsworthy' events. We therefore do not agree with such regional efforts and would prefer a continent wide reporting requirements.
Hydro-Québec TransEnergie (HQT)	
Northeast Power Coordinating Council	
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b>	
Public Service Enterprise Group Companies	The PSEG Companies believe that RFC is developing a regional disturbance reporting requirement for events not meeting the criteria of current DOE and NERC reports.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard.</b>	
Western Electricity Coordinating Council	There is a need to learn what reporting requirements are required by the Mexican and Canadian entities.
<b>Response: The DSR SDT thanks you for your comment. The DSR SDT is comprised of international members and we are currently researching requirements that Mexico and Canada may have.</b>	
SERC Reliability Coordinator Sub-committee (RCS)	We are not aware of any regional reporting requirements beyond the requirements of CIP-001, CIP-008 and EOP-004. However, the SERC RRO has shared a list of events of interest that it would like to be made aware of to maintain situation

Organization	Question 6 Comment
	awareness.
<p><b>Response: The DSR SDT thanks you for your comment. The SDR SDT feels there will always be a need for the Regional Entities to be kept aware of certain “hot topic” issues. However, it is the SDT’s intent to provide clear and concise reporting requirements for events impacting the BES.</b></p>	
BGE	We are not aware of any regional requirements beyond the scope of CIP-001, CIP-008 and EOP-004.
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>	
We Energies	What is meant by beyond the scope of the referenced standards? We Energies also has reporting obligations with the MISO RC (MISO OP-023), RFC (PRC-002-RFC-01), and the Wisconsin and Michigan Public Service Commissions.
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT will examine regional reporting criteria and requirements to determine whether it should be included in a continent wide standard. Please provide a copy of the subject reporting requirements for the SDT to review.</b></p>	



**7. If you have any other comments on the Concepts Paper that you haven't already provided in response to the previous questions, please provide them here.**

**Summary Consideration:** Several stakeholders provided comments in this section. Some stakeholders suggested that the SDT has gone beyond its approved scope to “further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” Further, there is no requirement to create a Reporting Standard to define sabotage. The SDT contends that the development of impact events and the reporting requirements for them will provide the clarity sought in the directive.

Other stakeholders suggested that the SDT should seek to retire sanctionable requirements that require event reporting in favor of guidelines for reporting.

Several commenters suggested that the introduction of impact events actually expands the reporting requirements. It should be noted that the list of impact events is expected to be explicit as to who is to report what to whom and within certain timelines.

Several stakeholders provided input as to what they believed an electronic reporting tool should contain:

- 1 If the decision is made to go to a single reporting form, it should be developed to cover any foreseeable event.
- 2 The SDT should work toward a single form, located in a central location, and submitted to one common entity (NERC)
- 3 Reports should be forwarded to the ES-ISAC, not NERC, as the infrastructure is already in place for efficient sharing with Federal agencies, with the regional entities and with neighboring asset owners. Reports should flow to all affected entities in parallel, rather than series (timing issues).

Commenters also suggested that the SDT should consider the impacts of the reporting requirements on the small, and very small utilities.

Organization	Question 7 Comment
BGE	<p>1. If we move to a "one size fits all" single reporting form, it is important that the form be properly developed to cover any foreseeable event, which appears to be the intent of the DSR SDT, as outlined on page 4 of the concept document. Such an approach should also incorporate a single point of contact for reporting information, to avoid any confusion.</p> <p>2. We would like clarification that any proposed CIP-008-related reporting requirement (including any linked reporting requirement between CIP-008 and CIP-001) is only applicable in situations where the incident/event involves a registered entity's Critical Cyber Asset.</p>

Organization	Question 7 Comment
<p><b>Response (Questions 3&amp;6):</b> The DSR SDT thanks you for your comment. The drafting team will explore clarification that any proposed CIP-008 related reporting requirement between CIP-008 and CIP-001 is only applicable where the incident/event involves a registered entity’s CCA. Note that CIP-002 through CIP-009 are undergoing revision under project 2008-06 – Order 706 SDT. Note that the current CIP-008 has a reporting requirement to the ES-ISAC only.</p>	
<p>Electric Market Policy</p>	<p>a. NERC should focus efforts on developing <u>specific event reporting criteria</u> and not base the requirement on the definition of the term ‘sabotage’ but on the reporting criteria itself.</p> <p>b. The “opportunities for efficiency” discussed in the Concept Paper would be best achieved by focusing on those items that are necessary to <u>maintain the reliability of the Bulk Electric System</u>. If there are elements that need to be reported that, do not support this objective, than that reporting should not be required in reliability standards.</p>
<p>Hydro-Québec TransEnergie (HQT)</p>	<p>a. NERC should focus efforts on developing specific event reporting criteria and not base the requirement on the definition of the term ‘sabotage’, but on the reporting criteria itself. See comments above.</p> <p>b. The “opportunities for efficiency” discussed in the Concept Paper would be best achieved by focusing on those items that are necessary to maintain the reliability of the Bulk Electric System. If there are elements that need to be reported that do not support this objective, then that reporting should not be required in reliability standards. Consider making NERC the distributor of reports to other agencies. We recognize that the key is to simplify reporting to a single form, and to the extent possible, to one agency. “Front line” reliability personnel must have the “timely” knowledge to know when a situation warrants local, area, regional, or national involvement. Finally, the SDT should keep in mind the fact that Canadian stakeholders might have some difference in the way reports are made to Security Agencies.</p>
<p>Northeast Power Coordinating Council</p>	<p>a. NERC should focus efforts on developing specific event reporting criteria and <u>not</u> base the requirement on the definition of the term ‘sabotage’, but on the reporting criteria itself. See comments above</p> <p>b. The “opportunities for efficiency” discussed in the Concept Paper would be best achieved by focusing on those items that are absolutely necessary to maintain the reliability of the Bulk Electric System. If there are elements that need to be reported that do not support this objective, then that reporting should not be required in reliability standards. Consider making NERC the distributor of reports to other agencies. We recognize that the key is to simplify reporting to a single form, and to the extent possible, to one agency. “Front line” reliability personnel must have the “timely” knowledge to know when a situation warrants local, area, regional, or national involvement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT agrees to focus efforts to specific event reporting criteria. SDT believes that by reporting material risks to the Bulk Electrical System using the impact event categorization it will be easier to get the relevant information for mitigation, awareness, and tracking, not based on the requirement of defining “sabotage”. The SDT believes that it is the submitter’s responsibility to submit OE-417 forms to the DOE, as stated by Public Law for US entities. The DSR SDT does recognize that it may not be possible to eliminate</p>	

Organization	Question 7 Comment
<p>reporting to multiple jurisdictional agencies due to legislative or regulatory requirements.</p>	
<p>SPS Consulting Group Inc.</p>	<p>Again, please consider the unique scope of the entities to which these standards are to comply. Don't dump all the requirements on all the applicable entities and perpetuate the current practice of forcing them to parse the requirements into what is logical or illogical from their perspective. The drafting team should have the expertise to do this. Identify which requirements apply to which applicable entity.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT will take into consideration what registered entities and thresholds are to be included in the revised standard(s) based on the SAR. The DSR SDT will establish the “requirements necessary for users, owners, and operators of the Bulk-Power-System” as stated in FERC Order 693 and the difference in reporting of events on the BES, as stated in the Purpose statement of EOP-004-1.</p>	
<p>ERCOT ISO</p>	<p>All references to CIP-008 should be removed and we reassert that physical and cyber reporting should be separate. There is documentation available from the CIPC that the drafting team considered CIP-001 related physical sabotage reporting and specified cyber incident reporting requirements in CIP-008.ERCOT ISO requests the DSR SDT to continue to improve its guidelines and to post those guidelines for all to use, but not to create sanctionable standards whose good intentions could result in unintended adverse consequences for the Industry. ERCOT ISO also suggests that all reporting forms and guidance should be located in a central, easily accessible location, eliminating confusion and simplify reporting for system operators thereby directly enhancing reliability during system events. The industry would benefit from a central location or link on the NERC website containing all reporting forms.</p>
<p><b>Response:</b> The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). The DSR SDT will take into consideration your comment on keeping cyber and physical events separate. We are suggesting in our discussion to consolidate the location of reporting into one standard. The industry has demonstrated by its comments that it prefers that the reporting process be streamlined to achieve a “one stop shop” approach. We will continue to explore the possibilities to achieve the best results for all stakeholders. A discussion of advantages /disadvantages will continue to discover options and alternatives with input from all stakeholders.</p>	
<p>Western Electricity Coordinating Council</p>	<p>As stated previously, for "One stop shopping" we need "buy in" from the foreign nationals. The way to do this is to engage their opinions and respect their jurisdictional agencies as well.</p>
<p><b>Response (Question 6):</b> The DSR SDT thanks you for your comment. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory requirements. The SDT acknowledges that it is possible to consolidate various reports that ask repetitive questions and through this process can work with foreign nationals to receive their “buy in” for a one report form for all functional entities to submit to NERC.</p>	

Organization	Question 7 Comment
<p>MRO's NERC Standards Review Subcommittee</p>	<p>Confusion often arises in the industry between the CIP standards and other reliability standards based on CIP-001 naming convention. We would suggest the SDT retire CIP-001 and incorporate requirements within the EOP-004 standard or a new EOP-xxx standard to avoid confusion arising from CIP and other NERC Reliability Standards. Additionally, we assume the SDT has been created to specifically address FERC Order 693 directives to the ERO which appears to include the following items:</p> <ol style="list-style-type: none"> <li>1. Applicability - “possible revisions to CIP-001-1 that address our concerns regarding the need for wider application of the Reliability Standard... the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate” (FERC, 2007, para. 460).</li> <li>2. Definition of Sabotage - “we direct that the ERO further define the term and provide guidance on triggering events that would cause an entity to report an event... we believe the term sabotage is commonly understood and that common understanding should suffice in most instances... the ERO should consider FirstEnergy’s suggestions to differentiate between cyber and physical sabotage and develop a threshold of materiality.” (FERC, 2007, para. 461-462)</li> <li>3. Periodic Review and Testing - “directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.” (FERC, 2007, para. 466)</li> <li>4. Redundant Reporting - “now direct the ERO to address our underlying concern regarding mandatory reporting of a sabotage event... Regarding the potential for redundant reporting under CIP-001-1 and other government reporting standards, and the need for greater coordination... We direct the ERO to explore ways to address these concerns - including central coordination of sabotage reports and a uniform reporting format... with the appropriate governmental agencies that have levied the reporting requirements.” (FERC, 2007, para. 468-469)</li> <li>5. Specified Time - “the Commission directs the ERO to modify CIP-001-1 to require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specified period of time... the ERO should consider suggestions raised... to define the specified period for reporting an incident beginning from when an event is discovered or suspected to be sabotage” (FERC, 2007, para. 470).</li> <li>6. Summary of CIP-001-1 - “the Commission directs the ERO to develop the following modifications... (1) further define sabotage and provide guidance as to the triggering events... (2) specify baseline requirements regarding... procedures for recognizing sabotage events... (3) incorporate a periodic review... and for the periodic testing... (4) require an applicable specified period of time. In addition... address our concerns regarding applicability to smaller entities... consolidation of the sabotage reporting forms and the sabotage reporting channels with the appropriate governmental authorities to minimize the impact of these reporting requirements on all entities.” (FERC, 2007, para. 471)</li> <li>7. Analyze Performance - “at a minimum, generator operators and LSEs should analyze the performance of their equipment and provide the data... The Commission directs the ERO to consider this concern in future revisions... that includes any Requirements necessary for users, owners and operators... to provide data that will assist NERC” (FERC,</li> </ol>

Organization	Question 7 Comment
	<p>2007, para. 613, 617).</p> <p>8. Reporting Time Frames - "The Commission directs the ERO to change its Rules of Procedures to assure that the Commission also receives these reports within the same time frames as the DOE." (FERC, 2007, para. 618)</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT agrees with your comments to specifically address FERC Order 693 directives to the ERO and will determine a prudent course of action with respect to these standards and pursue the suggestion to retire CIP-001 and incorporate requirements within the EOP-004 standard to avoid confusion rising from CIP and other NERC Reliability Standards.</b></p>	
<p>Constellation Power Source Generation</p>	<p>Constellation Power Generation would like clarification that any proposed CIP-008-related reporting requirement (including any linked reporting requirement between CIP-008 and CIP-001) is only applicable in situations where the incident/event involves a registered entity's Critical Cyber Asset. In that vein, we want to emphasize the importance of the DSR SDT working with the CIP SDT on the cyber related events. If the DSR SDT is going to be adding clarity to cyber related events, then coordination with the CIP SDT is needed to ensure the same verbiage is being used. Furthermore, having any duplication of requirements will cause a double jeopardy scenario which would go against the SAR for the DSR SDT. As stated earlier, Constellation Power Generation also questions whether cyber related incidents should fall under the spectrum of sabotage type events, or remain separate and be incorporated in the CIP revisions.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted "NERC Guideline: Threat and Incident Reporting" and ask the industry if DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). Note that CIP-002 through CIP-009 are undergoing revision under project 2008-06 – Order 706 SDT.</b></p>	
<p>We Energies</p>	<p>Give consideration to combining CIP-001 and EOP-004-1 through a common categorization. For example, "System Risk Reporting" could encompass both actual and potential events and would minimize the need to cross reference both standards, and provide one location for event and potential-event reporting. Much of the challenge in this project is in achieving a common understanding of the words sabotage and terrorism. There are nuances of meaning in the words that imply a relationship between the attacker and the victim, or a motive other than simple profit or mischief. This nuance of meaning requires the victim of the damage to discern a relationship or motive which may not be discoverable in the relatively brief time window during which the entity must report the event. In fact, they may never be known. Consequently, We Energies recommends elimination of the words sabotage and terrorism from these standards. We also recommend elimination of the word vandalism since it also implies an ability and duty to discern whether a particular act (barbed wire thrown over transformer bushings) was done out of pure mischief (vandalism) or with intent to destroy equipment for a political purpose (terrorism). And if the act was committed by a disgruntled employee, it becomes sabotage. No wonder there is confusion and indecision. Instead, We Energies recommends using the simple words "criminal damage". One need not be a prosecuting attorney or FBI Special Agent to know what this means. Simply ask, "Does it look like somebody damaged it (or hacked in) intentionally?" and, "Did we give consent?" and you're done. With</p>

Organization	Question 7 Comment
	<p>elimination of sabotage, terrorism and vandalism, and all of their baggage, comes the ability to integrate both CIP 001 and EOP 004. We now have criminal damage (or cyber attack) as just another event to be evaluated against certain pre-defined impact measures. No value judgments, no speculation. Another benefit of using these simple words and tests is that operating personnel, whether in the field or at the console, will not require special awareness training in discerning these nuances of meaning. They already have experience with the equipment or cyber systems and its normal performance. Operating personnel can readily assess whether an impact event is due to equipment failure, weather or animal contact vs. intentionally caused by a person. If it appears to be criminal damage, call the local police agency. Report the event and the impact. Cooperate with the investigation. Share your knowledge of the normal condition of the equipment or performance of the system. Share your experience with similar events. It will be important to highlight that the theft of all the grounding pigtailes in a substation is different from the act of simply snipping each of them to leave the equipment electrically floating. The technical condition is the same, but this allows the police to make an inference with respect to motive, suspect profile, sophistication, etc. That's their job. They may ask us to speculate on the motive or skills of the attacker. That's okay. But at least we don't have to know or guess at it for the purpose of determining whether to report the event. No training required. With respect to notification to the FBI, We Energies recommends that the standard merely state that the owner of the damaged asset ensure the local office of the FBI is notified. The standard should permit documentation of either a direct phone call by the asset owner or obtaining an assurance from the local police that they will do so. There should be no need to prove earlier establishment of a relationship with the FBI. There should be no expectation that the entity have a signed letter from the FBI Special Agent in Charge acknowledging his agency's duty. This document means nothing. With respect to reporting within the industry, We Energies recommends that the only events to be reported "up the chain" are those that we choose to characterize as "impact events". That is, the events that meet some measurable threshold with respect to BES impact. We should describe these efficiently to avoid over-reporting of trivial events. It is apparent that we are already over-reporting since DHS HITRAC recently fed back to the industry that copper thieves attacked a substation in San Bernardino, CA taking some of the grounding conductors. The industry should have the option to report non-impact events that are unusual in some respect and which may have some mutual industry benefit in terms of prevention, awareness or recovery. Attack attempts with no impact, or observations of suspicious activity could fall into this optional category. These optional reports could be aggregated by the entity for the purpose of detecting patterns or trends, or be reported ad hoc. The ES-ISAC should be the recipient of the reports. It should be the single point of contact since it has the industry insight, engineering expertise and cross-sector relationships to analyze and return valuable intelligence to the industry. With the ES-ISAC as the recipient of the reports, efficient sharing with Federal agencies, with the regional entities and with neighboring asset owners could be automated and rapid. There is much benefit to be gained from this project, primarily in the area of creating clarity and uniformity. There is some risk that the reporting requirements will become onerous and prescriptive.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is proposing to consolidate disturbance and event reporting under a single standard. The DSR SDT believes that reporting material risks to the Bulk Electrical System by using the impact event categorization, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation by the elimination of the term "sabotage". The intent is to allow potentially impacted parties to prepare for and possibly mitigate the reliability risk. The NERC Rules of</b></p>	

Organization	Question 7 Comment
	<p>Procedure (section 800) provides an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. The SDT is proposing that the new standard specify who has access to reported information and who should be notified about impact events, because agencies such as the DHS and FBI have other duties and responsibilities - an impact event that is related to copper theft may only need to be reported to the local law enforcement authorities. The goal of the DSR SDT is create clarity and uniformity by developing a single reporting form for all functional entities without regard to nationality (US, Canada, Mexico) to submit to NERC with guidance. Ideally, entities would complete a single form, which could then be distributed to jurisdictional agencies and functional entities as appropriate. The DSR SDT agrees with your assessment that there should be no expectation that the entity have a signed letter from the FBI Special Agent.</p>
<p>Bandera Electric Cooperative, Inc.</p>	<p>I commend the SDT for working on this effort and wish them success.</p>
<p><b>Response: The DSR SDT thanks you for your comment.</b></p>	
<p>Public Service Enterprise Group Companies</p>	<p>If reporting does become the responsibility of the Reliability Coordinators, the RCIS should be made available view-only to registered entities with a notification when RC's have posted new entries. That will enhance the situational awareness of registered entities.</p> <p>The PSEG Companies disagree with inclusion of CIP-008 reporting requirements as part of the CIP-001 and EOP-004 initiative. CIP-008 reporting as part of the cyber security set of NERC standards is usually managed by specialized corporate organizations separate from those involved with the other NERC standards, and with highly specialized cyber skill sets. CIP-008 reporting requirements should remain where they are, and any perceived need for improvement addressed in the ongoing CIP Version 4 development process.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The RCIS is a real-time communication and reporting tool and is outside the scope of the SDT. The goal of the DSR SDT is to develop a form to expedite report completion, sharing and storage. Ideally, entities would complete a single form, which could then be distributed to jurisdictional agencies and functional entities as appropriate. Functional entities may include the RC, TOP, and BA for situational awareness. The DSR SDT will take into consideration your comment with inclusion to CIP-008 reporting. However, the drafting team will explore clarification that any proposed CIP-008-related reporting requirement between CIP-008 and CIP-001 is only applicable where the incident/event involves a registered entity's CCA. Note that CIP-002 through CIP-009 are undergoing revision under project 2008-06 – Order 706 SDT.</b></p>	
<p>Independent Electricity System Operator</p>	<p>In the Background Section of the comment form, it is indicated that the SDT "...is NOT seeking input or guidance on the definition of physical or cyber sabotage, what type of disturbances should be reported, who should do reporting, or to whom or what organizations will be receiving the reports." <u>Yet there are proposed definitions, with examples, in the concept paper.</u> The SDT should make it absolutely clear that by supporting the general concept as described in the paper, the commenting entities are not endorsing the proposed definitions, nor the examples as elements to be included in the standard.</p>

Organization	Question 7 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT will continue to clarify the impact events concept and eliminate “gray areas” while including language to give clarity to the reporting process. Standards developed under this project will be posted for comment on specific content.</p>	
Luminant	Luminant disagrees with the direction of utilizing impact events, as this is an expansion in scope beyond the simplification of sabotage and disturbance reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES. The DSR SDT has reviewed the existing standards, the SAR; issues from the NERC database and FERC Order 693 Directives and determine this was a prudent course of action with respect to these standards to provide clear criteria for reporting.</p>	
Dynergy Inc.	N/A
Manitoba Hydro	No
Edison Mission Marketing & Trading	No other comments.
SERC Reliability Coordinator Sub-committee (RCS)	None.
USBR	The concept of "threat" evaluation criteria is somewhat vague and a great care is needed to ensure it is clear enough that the most individuals would be able to analyze an event and end up at the same threat. Otherwise it would be almost impossible to ensure compliance with a requirement which cannot accurately describe criteria to be used to ensure that proper evaluation has occurred.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We are suggesting the term “Impact Event” be substituted to include only events that would impact the reliability of the BES as opposed to requiring a threat evaluation. The DSR SDT intends to develop criteria that will assist entities in determining which events should be reported.</p>	
Wolverine Power Supply Cooperative, Inc.	The concepts of removing duplication, consolidation, and focusing on "impact events" sound logical. I am concerned that the focus may drift to expanded reporting, not reduced reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DST SDT discussed the reporting of “impact events” and will consider guidance found in the document, “<a href="#">NERC Guideline: Threat and Incident Reporting</a>” which will include clear criteria to eliminate erroneous or expanded reporting.</p>	



Organization	Question 7 Comment
ISO RTO Council Standards Review Committee	<p>The FERC Order merely asked NERC to “further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” There is no requirement to create a Reporting Standard and no mention of Disturbance events. There is a strong need to avoid heavy-handed use of NERC standards particularly for such post event reporting guidelines. The SRC would urge the DSR SDT to continue to improve its guidelines and to post those guidelines for all to use, but not to create sanctionable standards whose good intentions will inevitably result in many unintended adverse consequences for the Industry. Rather, the SDT should seek to retire sanctionable requirements that require event reporting in favor of guidelines for reporting.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). The DSR SDT will take into consideration your comment on keeping cyber and physical events separate. We are suggesting in our discussion to consolidate the location of reporting into one standard. The industry has demonstrated by its comments that the reporting process be streamlined to achieve a “one stop shop” approach. We will continue to explore the possibilities to achieve the best results for all stakeholders. A discussion of advantages /disadvantages will continue to discover options and alternatives with input from all stakeholders.</b></p>	
Lands Energy Consulting	<p>The lack of common sense that leads to a 15 MW loss of load resulting from a 115 kV line outage being categorized as a "reportable disturbance" really hurts the credibility of the entire NERC Compliance Program. The smaller utilities look at application of EOP-004 in particular to their operation and conclude that either the EO/RRO is: a. stupid; or b. Out to persecute the smaller utilities. In reality, EOP-004 was drafted for application to Southern California Edison, where loss of 50% of customers would be 2-3 million customers. Now that's really disturbing!</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT intends to develop criteria that will assist entities in determining which events should be reported. Acts of sabotage may be “tested” on smaller entities before the saboteurs move on the larger entities.</b></p>	
Central Hudson Gas & Electric	<p>The NERC Guideline: Threat and Incident Reporting Attachment A matrix is an extremely beneficial document that organizes reporting criteria. However, it identifies communications systems failure sub-category under the Equipment And/Or Systems Failure category as reportable with a reference to OE-417 - Schedule 1, Item 10. Item 10 on Schedule 1 addresses only failures due to attacks (not failures for other reasons).</p>
<p><b>Response: The DSR SDT thanks you for your comment. The intent was to look at the posted “NERC Guideline: Threat and Incident Reporting” and ask the industry if the DSR SDT should consider existing guidelines for possible inclusion into the yet to be written requirement(s). The DSR SDT has not determined at this time what bright line will be used for the yet to be drafted Standard(s). Loss of communications would be considered an impact event. The reason for the loss of communications is irrelevant.</b></p>	

Organization	Question 7 Comment
Duke Energy	<p>We don't think CIP-001, EOP-004 and cyber incident reporting aspects of CIP-008 should all be combined into one standard, because of the significant differences between sabotage and disturbances. We have suggested that the drafting team further define sabotage, and we have included a suggested definition in our response to question #5 above. Sabotage is very specific due to the intent (for the purpose of weakening the critical infrastructure), and the potential impact to the BES. We believe that sabotage and cyber incident reporting should remain a part of the CIP Standards due to the emphasis placed on the criticality and vulnerability of the assets needed to support reliable operation of the BES. Cyber Security and Physical Security could be placed together in the same standard (remain in CIP) and other disturbances (i.e., accidental, natural) in a separate standard. "One stop shopping" for reporting is still possible as long as the OE-417 form is included as part of the NERC electronic form. And while we agree with the need for additional clarity in sabotage and disturbance reporting, we believe that the Standards Drafting Team should carefully consider whether there is a reliability-related need for each requirement. Some disturbance reporting requirements are triggered not just to assist in real-time reliability but also to identify lessons-learned opportunities. If disturbance and sabotage reporting continue to be reliability standards, we believe that all linkages to lessons-learned/improvements need to be stripped out. We have other forums to identify lessons-learned opportunities and to follow-up on those opportunities.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The DSR SDT is still evaluating inclusion of CIP-008 reporting requirements with CIP-001 and EOP-004 requirements, Note that the current CIP-008 has a reporting requirement to the ES-ISAC only. The DSR SDT developed the more inclusive term "impact events" to eliminate using more confusing terms like sabotage (which is not likely to be determined until after a lengthy investigation). These standards may be combined to have all reporting requirements in a single standard, not because the items to be reported are necessarily related.</b></p>	
FirstEnergy	<p>We fully agree that sabotage events need to be more clearly defined and reporting requirements need to be better coordinated. But as we have stated in previous comments, the drafting team needs to determine if standard requirements need to be developed for this type of reporting or if this is better left to administrative requirements outside the standards arena. Also, while we appreciate the team's effort to simplify reporting requirements for entities, we are concerned with the serial communication offered by the concept paper. As an example, the team proposes to have LSE report the incident to the BA and/or TOP and then have the BA and/or TOP report it to the RC and the RC to report it to NERC and the NERC report to the regulatory agencies. While this simplifies it for each individual organization, this method introduces many opportunities for errors and miscommunications. Since this is after-the-fact reporting, it is difficult to defend this type of communication path when one consistent report could be sent simultaneously to all agencies at the same time from the originating location.</p>
<p><b>Response: The DSR SDT thanks you for your comment. The Reliability Coordinator's suggested role in this is to allow them to incorporate the relevant data from responsible entities in their footprint for further analysis. We will consider your suggestion of simultaneous submissions as a means to effectively notify the necessary parties. The SDT believes that it is the submitter's responsibility to submit OE-417 forms to the DOE. The DSR SDT does recognize that it may not be possible to eliminate reporting to multiple jurisdictional agencies due to legislative or regulatory</b></p>	

Organization	Question 7 Comment
requirements.	
Ameren	<p>While we are not opposed to the concept of identifying impact events, we are concerned that the drafting team may actually be expanding reporting requirements. We do not support expansion of reporting requirements unless a clear reliability or legal need is identified. Some of the impact events are almost never sabotage and do not warrant reporting for reliability needs and should not be included. For example, copper theft should not require reporting, in general, because it is almost never sabotage and rarely impacts reliability. If it does, impact reliability because, for example, the protection system is impacted and causes more significant potential contingencies, then reporting could be required. Why is a train derailment near a transmission right of way significant? It would only be significant if an investigation identified sabotage as the reason. Furthermore, what is considered near?</p>
Midwest ISO Standards Collaborators	<p>While we are <u>not</u> opposed to the concept of identifying impact events, we are concerned that the drafting team may actually be expanding reporting requirements. We do not support expansion of reporting requirements unless a clear reliability or legal need is identified. Some of the impact events are almost never sabotage and do not warrant reporting for reliability needs and should not be included. For example, copper theft should not require reporting, in general, because it is almost never sabotage and rarely impacts reliability. If it does impact reliability because, for example, the protection system is impacted and causes more significant potential contingencies, then reporting could be required. Why is a train derailment near a transmission right of way significant? It would only be significant if an investigation identified sabotage as the reason. Furthermore, what is considered near?</p>
<p><b>Response: The DSR SDT thanks you for your comment. It is not the intent of the DSR SDT to expand reporting requirements but rather to attempt to clarify and define an approach to assist the industry and stakeholders in reporting impact events. Furthermore, impact events should not include copper theft or other conditions that pose no threat to the reliability of the BES. A train derailment is only an impact event if it threatens some element of the power system such as a transmission line corridor - the derailment in itself is not an impact event.</b></p>	
Exelon	<p>You should consider providing clear and concise instructions as to the expectation on submitting forms, i.e. the DOE 417. There should be no guessing as to when and how reports should be submitted and who should receive them. Specific details on reporting criteria should be included.</p>
<p><b>Response : The DSR SDT thanks you for your comment. The DSR SDT intends to develop criteria for reporting impact events.</b></p>	

## Standard Development Timeline

---

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).

### Proposed Action Plan and Description of Current Draft

This is the first posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a 30-day formal comment period.

### Future Development Plan

Anticipated Actions	Anticipated Date
Initial Comment Period	September 2010
Drafting team considers comments, makes conforming changes, and proceed to second comment	October – December 2010
Comment Period/Initial Ballot	December 2010- January 2011
Successive Comment/Ballot period	February – March 2011
Receive BOT approval	April 2011

### **Effective Dates**

1. USA: First calendar day of the first calendar quarter one year after applicable regulatory authority approval for all requirements
2. Canada and Mexico: First calendar day of the first calendar quarter one year following Board of Trustees adoption unless governmental authority withholds approval

### **Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
2		Merged CIP-001-1 and EOP-004-1 into EOP-004-2; Retired EOP-004-1, R1, R3.2, R3.3, R3.4, R4, R5 and associated measures, evidence retention and VSLs. Added new requirements for ERO – R1, R7, R8.	Revision to entire standard (Project 2009-01)

### **Definitions of Terms Used in Standard**

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

**None**

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## **Introduction**

- 1. Title:** Impact Event and Disturbance Assessment, Analysis, and Reporting
- 2. Number:** EOP-004-2
- 3. Purpose:** Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES).
- 4. Applicability**
  - 4.1. Functional Entities:**
    - 4.1.1. Reliability Coordinator**
    - 4.1.2. Balancing Authority**
    - 4.1.3. Transmission Owner**
    - 4.1.4. Transmission Operator**
    - 4.1.5. Generator Owner**
    - 4.1.6. Generator Operator**
    - 4.1.7. Distribution Provider**
    - 4.1.8. Electric Reliability Organization**

## **5. Background:**

NERC established a SAR Team in 2009 to investigate revisions to the CIP-001 and EOP-004 Reliability Standards.

1. CIP-001 may be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 has some ‘fill-in-the-blank’ components to eliminate.

The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information).

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009. A “concepts paper” was designed

to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The concept paper sought comments from stakeholders on the “road map” that will be used by the SDR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the SDR SDT.

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives in order to determine a prudent course of action with respect to these standards.

The DSR SDT has proposed the following concept for *impact event*:

*An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.*

To support this concept, the DSR SDT has provided specific event for reporting including types of impact events and timing thresholds pertaining to the different types of impact events and who’s responsibility for reporting under the different impact events. This information is outlined in Attachment 1 to the proposed standard.

The DSR SDT wishes to make clear that the proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001, EOP-004. This is achieved through the RCIS and is covered in other standards (e.g. TOP). The proposed standard deals exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and impact event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

### **Summary of Concepts**

- A single form to report disturbances and impact events that threaten the reliability of the bulk electric system
- Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Clear criteria for reporting
- Consistent reporting timelines
- Clarity around of who will receive the information and how it will be used



## Requirements and Measures

- R1.** The ERO shall establish, maintain and utilize a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness.
- M1.** The ERO shall provide evidence that it established, maintained and utilized a system for the distribution of the reports it receives to the various organizations or agencies. Such evidence could include, but is not limited to, dated records indicating that reports were distributed as shown on the submitted report or electronic logs indicating distribution of reports. (R1)

### Rationale for R1

The goal of the DSR SDT is to have a generic reporting form and a system for all functional entities (US, Canada, Mexico) to submit impact event reports to NERC and other entities. Ultimately, it may make sense to develop an electronic version of the form to expedite completion, sharing and storage. Ideally, entities would complete a single electronic form on-line which could then be electronically forwarded or distributed to jurisdictional agencies and functional entities as appropriate using check boxes or other coding within the electronic form. Specific reporting forms that exist today (i.e. - OE-417, etc) could be included as part of the electronic form to accommodate US entities with a requirement to submit the form or may be removed (but still be mandatory for US entities under Public Law 93-275) to streamline the proposed consolidated reliability standard for all North American entities (US, Canada, Mexico). Jurisdictional agencies may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE. Functional entities may include the RC, TOP, and BA for situational awareness. Applicability of the standard will be determined based on the specific requirements.

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT is planning to update the listing of reportable events from discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences may still exist.

Responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at the DOE.

**R2.** Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components:

- 2.1. Method(s) for identifying impact events
- 2.2. Method(s) for assessing cause(s) of impact events
- 2.3. Method(s) for making internal and external notifications pursuant to Parts 2.5 and 2.6
- 2.4. List of internal company personnel responsible for making initial notification(s) pursuant to Parts 2.5 and 2.6.
- 2.5. List of internal company personnel to notify
- 2.6. List of external organizations to notify to include but not limited to NERC, Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.
- 2.7. Method(s) for updating the Operating Plan when there is a component change within 30 days of the notification of the change.
- 2.8. A provision for updating the Operating Plan based on lessons learned from an exercise or implementation of the Operating Plan within 30 days of identifying the lessons learned.
- 2.9. A provision for updating the Operating Plan based on applicable lessons learned from the annual NERC report issued pursuant to Requirement R8 within 30 days of NERC publishing lessons learned.

**M2.** Each Applicable Entity shall provide the current in force Operating Plan to the Compliance Enforcement Authority upon request. (R2)

### **Rationale for R2**

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to assess what happened and why it happened when impact events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized.

For the Operating Plan, the DSR SDT envisions that “assessing” includes performing sufficient analysis to be able to complete the report for reportable impact events. The main issue is to make sure an entity can a) identify when an impact event has occurred and b) be able to gather enough information to complete the report.

Parts 3.3 and 3.4 include, but not limited to, operating personnel who could be involved with any aspect of the operating plan.

The Operating Plan may include, but not be limited to, the following: how the entity is notified of event’s occurrence, person(s) initially tasked with the overseeing the assessment or analytical study, investigatory steps typically taken, and documentation of the assessment / remedial action plan.

**R3.** Each Applicable Entity shall identify and assess initial probable cause of impact events listed in Attachment 1 in accordance with its Operating Plan documented in Requirement R2.

**M3.** To the extent that an Applicable Entity has an impact event on its Facilities, the Applicable Entity shall provide documentation of its assessment or analysis. Such evidence could include, but is not limited to, operator logs, voice recordings, or power flow analysis cases. (R3)

**Rationale for R3**

The DSR SDT intends for each Applicable Entity to assess the causes of the reportable impact event and gather enough information to complete the report that is required to be filed.

**R4.** Each Applicable Entity shall conduct a drill, exercise, or Real-time implementation of its Operating Plan for reporting created pursuant to Requirement R2 at least annually, with no more than 15 months between exercises or actual use.

**M4.** The Applicable Entity shall provide evidence that it conducted a drill, exercise or Real-time implementation of the Operating Plan for reporting as specified in the requirement. Such evidence could include, but is not limited to, a dated, exercise scenario with notes on the exercise or operator logs, voice recordings, or power flow analysis cases for an actual implementation of the Operating Plan. (R4)

**Rationale for R4**

The DSR SDT intends for each Applicable Entity to conduct a drill or exercise of its Operating Plan as often as merited but no longer than 15 months from the previous exercise to prevent a long cycle of exercises (i.e., conducting an exercise in January of one year and then December of the next year). Multiple exercises in a 15 month period is not a violation of the requirement and would be encouraged to improve reliability. A drill or exercise may be a table-top exercise, a simulation or an actual implementation of the Operating Plan.

**R5.** Each Applicable Entity shall provide training to all internal personnel identified in its Operating Plan for reporting pursuant to Requirement R2 subject to the following:

- 5.1 The training includes the personnel required to respond and their required actions under the Operating Plan.
- 5.2 Training conducted at least once per calendar year, with no more than 15 months between training sessions for personnel with existing responsibilities.
- 5.3 If the Operating Plan is revised (with the exception of contact information revisions), training shall be conducted within 30 days of the Operating Plan revisions.
- 5.4 For internal personnel added to the Operating Plan or those with revised responsibilities under the Operating Plan, training shall be conducted prior to assuming the responsibilities in the plan.

**Rationale for R5**

The SDT is not prescribing how training is to be conducted and leaves that decision to each Applicable Entity as they best know how to conduct such activities. Conduct of an exercise constitutes training for compliance with this requirement.

For changes to the Operating Plan (5.3), the training may simply consist of a review of the revised responsibilities and a “sign-off” that personnel have reviewed the revisions.

**M5.** Applicable Entities shall provide the actual training material presented to verify content and the association between the people listed in the plan and those who participated in the training, documentation showing who was trained and when internal personnel were trained on the responsibilities in the Operating Plan as well as dates for personnel changes and evidence that the training was conducted following personnel changes. (R5)

**R6.** Each Applicable Entity shall report impact events in accordance with its Operating Plan created pursuant to Requirement R2 and the timelines outlined in Attachment 1.

**M6.** Registered Entities shall provide evidence demonstrating the submission of reports using the Operating Plan created pursuant to Requirement R2 for impact events. Such evidence will include a copy of the original impact event report submitted, evidence to support the type of impact event experienced; the date and time of the impact event ; as well as evidence of report submittal that includes date and time. (R6)

**R7.** The ERO shall annually review and propose revisions to the impact event table (Attachment 1) if warranted based on its analysis of reported impact events. Revisions to Attachment 1 shall follow the Reliability Standards Development Procedure.

**M7.** The ERO shall provide evidence that it reviewed the impact event table. If applicable, the ERO shall provide evidence that it followed the Reliability Standards Development Procedure to propose and implement revisions to Attachment 1. Such evidence may include, but not be limited to, documentation that compares or assesses the list of impact events (Attachment 1) against the analysis of reported impact events. (R7)

**Rationale for R7-R8**

Some of the concepts contained in Requirements R7 and R8 are contained in the NERC Rules of Procedure, section 800. The DSR SDT felt that, in order to have a complete standard for reporting impact events that improved reliability, there needed to be feedback to industry on a regular basis as well as when issues are discovered. The analysis of impact events is crucial and the subsequent dissemination of the results of that analysis must be performed.

In accordance with Sections 401(2) and 405 of the Rules of Procedures, the ERO can be set as an applicable entity in a requirement or standard. After careful consideration, the DSR SDT believes that these requirements (R7-8) are best applicable to the ERO.

**R8.** The ERO shall publish a quarterly report of the year's reportable impact events subject to the following:

- 8.1 Issued no later than 30 days following the end of the calendar quarter
- 8.2 Identifies trends on the BES
- 8.3 Identifies threats to the BES
- 8.4 Identifies other vulnerabilities to the BES
- 8.5 Documents lessons learned
- 8.6 Includes recommended actions.

**Rationale for R8**

The ERO will analyze Impact Events that are reported through requirement R6. The DSR SDT envisions the ERO issuing reports identifying trends, threats or other vulnerabilities when available or at least quarterly. The report will include lessons learned and recommended actions (such as mitigation plans) to improve reliability as applicable.

**M8.** The ERO shall provide evidence that it issued a report identifying trends, threats, or other vulnerabilities on the bulk electric system at least quarterly. Such evidence will include a copy of the report as well as dated evidence of the report's issuance. (R8)

## Compliance

### Compliance Enforcement Authority

- Regional Entity
- For requirements applicable to the ERO, an entity contracted to perform an audit.

### Compliance Monitoring and Enforcement Processes:

- Compliance Audits
- Self-Certifications
- Spot Checking
- Compliance Violation Investigations
- Self-Reporting
- Complaints

### Evidence Retention

Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator and Distribution Provider shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The ERO shall retain evidence of Requirements 1, 7 and 8, Measures 1, 7, and 8 for three calendar years.

Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator and Distribution Provider shall retain data or evidence of Requirements 2, 3, 4, and 5 and Measures 2, 3, 4, and 5 for three calendar years for the duration of any regional investigation, whichever is longer to show compliance unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.

Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator and Distribution Provider shall retain data or evidence of Requirement 6 and Measure 6 for three calendar years for the duration of any regional investigation, whichever is longer to show compliance unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

### Additional Compliance Information

To be determined.

**Variations**

None

**Interpretations**

None

**EOP-004 - Attachment 1: Impact Events Table**

NOTE: Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by an impact event and issue a written Impact Event Report within the timing in the table below. In such cases, the affected Applicable Entity shall notify its Regional Entity(ies) and NERC, and verbally provide as much information as is available at that time. The affected Applicable Entity shall then provide periodic verbal updates until adequate information is available to issue a written Preliminary Impact Event Report.

<b>EOP-004 – Attachment 1 - Actual Reliability Impact – Part A</b>			
<b>Event</b>	<b>Entity with Reporting Responsibility</b>	<b>Threshold for Reporting</b>	<b>Time to Submit Report</b>
Energy Emergency requiring Public appeal for load reduction	RC, BA	To reduce consumption in order to maintain the continuity of the BES Each public appeal for load reduction	Within 1 hour of issuing a public appeal
Energy Emergency requiring system-wide voltage reduction	RC, TO, TOP, DP	System wide voltage reduction of 3% or more	Within 1 hour after occurrence is identified
Energy Emergency requiring firm load shedding	RC, BA, TOP, DP	Firm load shedding $\geq$ 100 MW (manually or via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)	Within 24 hours after occurrence
Voltage Deviations	RC, TOP, GOP	$\pm$ 10% sustained for $\geq$ 15 minutes	Within 24 hours after 15 minute threshold
Frequency Deviations	RC, BA	$\pm$ Deviations $\geq$ than Frequency Trigger Limit (FTL) more than 15 minutes	Within 24 hours after 15 minute threshold
IROL Violation	RC, TOP	Operate outside the IROL for time greater than IROL $T_v$	Within 24 hours after $T_v$ threshold
Loss of Firm load for $\geq$ 15 Minutes	RC, BA, TO, TOP, DP	<ul style="list-style-type: none"> <li>• <math>\geq</math> 300 MW for entities with previous year's demand <math>\geq</math> 3000 MW</li> <li>• <math>\geq</math> 200 MW for all other entities</li> </ul>	Within 24 hours after 15 minute threshold
System Separation (Islanding)	RC, BA, TOP, DP	Each separation resulting in an island of generation and load $\geq$ 100 MW	Within 1 hour after occurrence is identified
Generation loss	RC, BA, GO, GOP	<ul style="list-style-type: none"> <li>• <math>\geq</math> 2,000 MW for entities in the Eastern or Western Interconnection</li> </ul>	Within 24 hours after occurrence



EOP-004 – Attachment 1 - Actual Reliability Impact – Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
		<ul style="list-style-type: none"> <li>• <math>\geq 1000</math> MW for entities in the ERCOT or Quebec Interconnection</li> <li>• An entire generating station of <math>\geq 5</math> generators with aggregate capacity of <math>\geq 500</math> MW</li> </ul>	
Transmission loss	RC, TO, TOP	<ul style="list-style-type: none"> <li>• An entire DC converter station</li> <li>• Multiple BES transmission elements (simultaneous or common-mode event)</li> </ul>	Within 24 hours after occurrence
Damage or destruction of BES equipment <sup>1</sup>	RC, BA, TO, TOP, GO, GOP, DP	Through operational error, equipment failure, or external cause	Within 1 hour after occurrence is identified

**Examples:**

- a. BES equipment that is:
  - i. A critical asset
  - ii. Affects an IROL
  - iii. Significantly affects the reliability margin of the system e.g., has the potential to result in the need for emergency actions
  - iv. Damaged or destroyed due to a non-environmental external cause
- b. Report copper theft from BES equipment only if it degrades the ability of equipment to operate correctly e.g., removal of grounding straps rendering protective relaying ineffective

EOP-004 – Attachment 1 - Potential Reliability Impact – Part B			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
Unplanned Control Center evacuation	RC, BA, TOP	Unplanned evacuation from BES control center facility	report within 1 hour after occurrence
Fuel supply emergency	RC, BA, GO, GOP	Affecting BES reliability <sup>1</sup>	report within 1 hour after occurrence
Loss of off-site power (grid supply)	RC, BA, TO, TOP, GO, GOP	Affecting a nuclear generating station	report within 1 hour after occurrence
Loss of all monitoring or voice communication capability	RC, BA, TOP	Affecting a BES control center for $\geq 30$ minutes	report within 1 hour after occurrence
Forced intrusion <sup>2</sup>	RC, BA, TO, TOP, GO, GOP	At a BES facility	report within 24 hours after occurrence
Risk to BES equipment <sup>3</sup>	RC, BA, TO, TOP, GO, GOP, DP	From a non-environmental physical threat	report within 24 hours after occurrence
Detection of a cyber intrusion to critical cyber assets	RC, BA, TO, TOP, GO, GOP, DP	That meets the criteria in CIP-008 (or its successor)	report within 24 hours after occurrence

1. Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability.
2. Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).
3. Examples include a train derailment adjacent to BES equipment, that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center).

EOP-002 - Attachment 2: Impact Event Reporting Form

EOP-004 – Confidential Impact Event Report		
	Task	Comments
1.	Entity filing the report (include Compliance Registration ID number):	
2.	Date and Time of impact event. Date: (mm/dd/yy) Time/Zone:	
3.	Name of contact person: Email address: Telephone Number:	
4.	Did the impact event originate in your system?	Yes <input type="checkbox"/> No <input type="checkbox"/>
5.	Under which NERC function are you reporting?	
6.	Brief Description of impact event: (More detail should be provided in the Sequence of Events section below.)	

**EOP-004-2 — Impact Event and Disturbance Assessment, Analysis, and Reporting**

EOP-004 – Confidential Impact Event Report			
	Task	Comments	
7.	Generation tripped off-line.  MW Total List units tripped		
8.	Frequency.  Just prior to impact event (Hz): Immediately after impact event (Hz max): Immediately after impact event (Hz min):		
9.	List transmission facilities (lines, transformers, buses, etc.) tripped and locked-out.  (Specify voltage level of each facility listed).		
10.	Demand tripped (MW): Number of affected customers: Demand lost (MW-Minutes):	FIRM	INTERRUPTIBLE

EOP-004 – Confidential Impact Event Report			
	Task	Comments	
11.	Restoration Time.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		
12.	Sequence of Events:		
13.	Identify the initial probable cause or known root cause of the impact event:		

EOP-004 – Confidential Impact Event Report	
Task	Comments
14.	Identify any protection system misoperation(s):
15.	Additional Information that the helps to further explain the event if needed. A one-line diagram may be attached, if readily available, to assist in the evaluation of the event.:

## Guideline and Technical Basis

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and is progressing toward developing standards based on the SAR. This concepts paper is designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The DSR SDT also proposed to investigate incorporation of the cyber incident reporting aspects of CIP-008 under this project. This will be coordinated with the Cyber Security - Order 706 SDT (Project 2008-06).

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives to determine a prudent course of action with respect to these standards.

This concept paper provides stakeholders with a proposed “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. This concept paper provides the background information and thought process of the DSR SDT.

The proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). The proposed standards deal exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

### Summary of Concepts and Assumptions:

**The Standard Will:** Require use of a single form to report disturbances and “impact events” that threaten the reliability of the bulk electric system

- Provide clear criteria for reporting
- Include consistent reporting timelines
- Identify appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provide clarity around of who will receive the information

The drafting team will explore other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements

### Discussion of Disturbance Reporting

Disturbance reporting requirements currently exist in EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of impact events that are to be reported under this standard (attachment 1).

### Discussion of “impact event” Reporting

There are situations worthy of reporting because they have the potential to impact reliability. The DSR SDT proposes calling such incidents ‘impact events’ with the following concept:

An impact event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences.

Impact event reporting facilitates situational awareness, which allows potentially impacted parties to prepare for and possibly mitigate the reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of impact events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008 or its successor standard
- Forced intrusion attempt at a substation
- Train derailment near a transmission right-of-way
- Destruction of Bulk Electrical System equipment



### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that reporting material risks to the Bulk Electrical System using the impact event categorization, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

The DST SDT discussed the reliability needs for impact event reporting and will consider guidance found in the document “[NERC Guideline: Threat and Incident Reporting](#)” in the development of requirements, which will include clear criteria for reporting.

Certain types of impact events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of impact events may have different reporting requirements. For example, an impact event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. As envisioned, the standard will only require Functional entities to report the incidents and provide information or data necessary for these analyses. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The goal of the DSR SDT is to have one reporting form for all functional entities (US, Canada, Mexico) to submit to NERC. Ultimately, it may make sense to develop an electronic version to expedite completion, sharing and storage. Ideally, entities would complete a single form which could then be distributed to jurisdictional agencies and functional entities as appropriate. Specific reporting forms<sup>1</sup> that exist today (i.e. - OE-417, etc) could be included as part of the

---

<sup>1</sup> The DOE Reporting Form, OE-417 is currently a part of the EOP-004 standard. If this report is removed from the standard, it should be noted that this form is still required by law as noted on the form: NOTICE: This report is mandatory under Public Law 93-275. Failure to comply may result in criminal fines, civil penalties and other sanctions as provided by law. For the sanctions and the provisions concerning the confidentiality of information submitted on this form, see General Information portion of the instructions. Title 18 USC 1001 makes it a criminal

electronic form to accommodate US entities with a requirement to submit the form, or may be removed (but still be mandatory for US entities under Public Law 93-275) to streamline the proposed consolidated reliability standard for all North American entities (US, Canada, Mexico). Jurisdictional agencies may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE. Functional entities may include the RC, TOP, and BA for situational awareness. Applicability of the standard will be determined based on the specific requirements.

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT is planning to update the listing of reportable events from discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences may still exist.

The reporting proposed by the DSR SDT is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information is not necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

---

offense for any person knowingly and willingly to make to any Agency or Department of the United States any false, fictitious, or fraudulent statements as to any matter within its jurisdiction.

## **Comment Form for the first draft of EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting [Project 2009-01]**

Please **DO NOT** use this form to submit comments on the proposed reliability standard, EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting. Comments must be submitted by **October 15, 2010**. If you have questions please contact Stephen Crutchfield by email at [Stephen.crutchfield@nerc.net](mailto:Stephen.crutchfield@nerc.net) or by telephone at 609-651-9455.

### **Background Information:**

NERC established a SAR Team in 2009 to investigate revisions to the CIP-001 and EOP-004 Reliability Standards.

1. CIP-001 may be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 has some 'fill-in-the-blank' components to eliminate.

The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information).

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009. A "concepts paper" was designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The concept paper sought comments from stakeholders on the "road map" that will be used by the SDR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the SDR SDT.

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives in order to determine a prudent course of action with respect to these standards.

The DSR SDT has proposed the following concept for *impact event*:

*An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.*

To support this concept, the DSR SDT has provided specific event for reporting including types of impact events and timing thresholds pertaining to the different types of impact events and who's responsibility for reporting under the different impact events. This information is outlined in Attachment 1 to the proposed standard.

The DSR SDT wishes to make clear that the proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001, EOP-004. This is achieved through the RCIS and is covered in other standards (e.g. TOP). The proposed standard deals exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and impact event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

### **Summary of Concepts**

- A single form to report disturbances and impact events that threaten the reliability of the bulk electric system
- Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Clear criteria for reporting
- Consistent reporting timelines
- Clarity around of who will receive the information and how it will be used

**You do not have to answer all questions. Enter All Comments in Simple Text Format.**

*Insert a "check" mark in the appropriate boxes by double-clicking the gray areas.*

1. Do you agree with the purpose statement of the proposed standard? Please explain in the comment box below.

Yes

No

---

Comments:

2. Do you agree with the applicable entities in the Applicability Section as well as assignment of applicable entities noted in Attachment 1? Please explain in the comment box below.

Yes

No

---

Comments:

3. Do you agree with the requirement R1 and measure M1? Please explain in the comment box below.

Yes

No

---

Comments:

4. Do you agree with the requirement R2 and measure M2? Please explain in the comment box below.

Yes

No

---

Comments:

5. Do you agree with the requirement R3 and measure M3? Please explain in the comment box below.

Yes

No

---

Comments:

6. Do you agree with the requirement R4 and measure M4? Please explain in the comment box below.

Yes

No

---

Comments:

7. Do you agree with the requirement R5 and measure M5? Please explain in the comment box below.

Yes

No

---

Comments:

8. Do you agree with the requirement R6 and measure M6? Please explain in the comment box below.

Yes

No

---

Comments:

9. Do you agree with the requirements for the ERO (R7-R8) or is this adequately covered in the [Rules of Procedure \(section 802\)](#)? Please explain in the comment box below.

Yes

No

---

Comments:

10. Do you agree with the impact event list in Attachment 1? Please explain in the comment box below and provide suggestions for additions to the list of impact events.

Yes

No

---

Comments:

11. Do you agree with the use of the Preliminary Impact Event Report (Attachment 2)? Please explain in the comment box below.

Yes

No

---

Comments:

12. The DSR SDT has replaced the terms “disturbance” and “sabotage” with the term “impact events”. Do you agree that the term “impact events” adequately replaces the terms “disturbance” and “sabotage” and addresses the FERC directive to “further define sabotage” in an equally efficient and effective manner? Please explain in the comment box below.

- Yes  
 No

---

Comments:

13. The DSR SDT has combined EOP-004 and CIP-001 into one standard (please review the mapping document that shows the translation of requirements from the already approved versions of CIP-001 and EOP-004 to the proposed EOP-004), EOP-004-3 and retiring CIP-001. Do you agree that there is no reliability gap between the existing standards and the proposed standard? **Please** explain in the comment box below.

- Yes  
 No

---

Comments:

14. Do you agree with the proposed effective dates? Please explain in the comment box below.

- Yes  
 No

---

Comments:

15. Do you have any other comments that you have not identified above?

- Yes  
 No

---

Comments:

**Mapping Document Showing Translation of CIP-001-1 – Sabotage Reporting and EOP-004-1 – Disturbance Reporting, into EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting**

Standard: CIP-001-1 – Sabotage Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting
R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi site sabotage affecting larger portions of the Interconnection.	Moved into EOP-004-2, R2	<p>R2. Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components:</p> <ol style="list-style-type: none"> <li>2.1. Method(s) for identifying impact events</li> <li>2.2. Method(s) for assessing cause(s) of impact events</li> <li>2.3. Method(s) for making internal and external notifications pursuant to Parts 2.5 and 2.6</li> <li>2.4. List of internal company personnel responsible for making initial notification(s) pursuant to Parts 2.5.and 2.6.</li> <li>2.5. List of internal company personnel to notify</li> <li>2.6. List of external organizations to notify to include but not limited to NERC, Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.</li> <li>2.7. Method(s) for updating the Operating Plan when there is a component change within 30 days of the notification of the change.</li> <li>2.8. A provision for updating the Operating Plan based on lessons learned from an exercise or implementation of the Operating Plan within 30 days of identifying the lessons learned.</li> <li>2.9. A provision for updating the Operating Plan based on applicable lessons learned from the annual NERC report issued pursuant to Requirement R8 within 30 days of NERC publishing lessons learned.</li> </ol>



R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.	Moved into EOP-004-2, R2	
R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.	Moved into EOP-004-2, R2	
R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.	Moved into EOP-004-2, R2	

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.	Retire this fill-in-the-blank requirement.  Replace with new reporting procedure developed by NERC EAWG.	<i>(The NERC EAWG is working to develop continent wide reporting guidelines applicable under the NERC Rules of Procedure.)</i>
R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.	Translated into EOP-004-2, R1	R1. Each Applicable Entity shall have a documented Operating Plan for identifying and assessing impact events listed in Attachment 1.
R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity experiencing a reportable incident shall	Translated into EOP-004-2, R6	R6. Each Applicable Entity shall report impact events in accordance with its Operating Plan created pursuant to Requirement R2 and the timelines

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
provide a preliminary written report to its Regional Reliability Organization and NERC.		outlined in Attachment 1.
R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until some time after they occur shall be reported within 24 hours of being recognized.	Translated into EOP-004-2, R6	R6. Each Applicable Entity shall report impact events in accordance with its Operating Plan created pursuant to Requirement R2 and the timelines outlined in Attachment 1.
R3.2. Applicable reporting forms are provided in Attachments 022-1 and 022-2.	Retire – informational statement	
R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.	Retire as a requirement. Added as a “Note” to EOP-004-Attachment1-Impact Events Table	<i>NOTE: Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by an impact event and issue a written Impact Event Report within the timing in the table below. In such cases, the affected Applicable Entity shall notify its Regional Entity(ies) and NERC, and verbally provide as much information as is available at that time. The affected Applicable Entity shall then provide periodic verbal updates until adequate information is available to issue a written Preliminary Impact Event Report.</i>
R3.4. If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity in which a disturbance occurred, a final report is required,	Retire this fill-in-the-blank requirement.  Replace with new	<i>(The NERC EAWG is working to develop continent wide reporting guidelines applicable under the NERC Rules of Procedure.)</i>

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
<p>the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.</p>	<p>reporting procedure developed by NERC EAWG.</p>	
<p>R4. When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p><i>(The NERC EAWG is working to develop continent wide reporting guidelines applicable under the NERC Rules of Procedure.)</i></p>
<p>R5. The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p><i>(The NERC EAWG is working to develop continent wide reporting guidelines applicable under the NERC Rules of Procedure.)</i></p>



NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

## Standards Announcement

30-Day Informal Comment Period Open

September 15 - October 15, 2010

Now available at: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Project 2009-01 Disturbance and Sabotage Reporting**

The Disturbance and Sabotage Reporting Standard Drafting Team is seeking comments on its preliminary draft of EOP-004-2 – Impact Event and Disturbance Assessment, Analysis, and Reporting **until 8 p.m. EDT on October 15, 2010.**

### **Transition from Reliability Standards Development Procedure Version 7 – to Standard Processes Manual**

In accordance with the Standard Processes Manual approved by FERC on September 3, 2010, the drafting team is using an “informal” comment period to solicit stakeholder feedback. The new standard development process allows drafting teams to use informal comment periods. Unlike formal comment periods where a drafting team provides a response to each comment submitted, with informal comment periods the drafting team provides a summary response to each question asked on its comment form, but the team is not obligated to provide an individual response to each comment submitted. The summary response will indicate whether stakeholders support the proposal and will identify any additional changes made based on stakeholder comments. With informal comment periods drafting teams are not required to provide an individual response to each comment submitted. This change to the process is intended to give drafting teams more time to deliberate on technical issues, as opposed to deliberating on individual responses to comments. Note that while informal comment periods are allowed in the new standard process for preliminary drafts of proposed standards, formal comment periods are still required for the final draft of each standard.

### **Instructions**

Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Next Steps**

The drafting team will draft and post a summary response to the comments received and conforming revisions to the standard. The next will be either another 30-day informal comment period or a 30-day formal comment period on the complete standard.

## Project Background

This project involves revising existing standards CIP-001-1 — Sabotage Reporting and EOP-004-1 — Disturbance Reporting to eliminate redundancies and provide clarity on sabotage events. The project will address several issues identified by stakeholders, as well as FERC directives from Order 693, including a directive to provide greater clarity to requirements associated with “sabotage.”

EOP-004-2 was drafted using the “results-based” criteria for developing a reliability standard. The results-based approach includes considerably more emphasis on the “concepts and assumptions” underlying the development of requirements and goes beyond the steps most drafting teams have previously used when developing a standard. Accordingly, the “look and feel” of a results-based standard is quite different than NERC’s existing standards. However, at the core is a set of mandatory and enforceable requirements with useful guidance supporting these requirements, an approach NERC’s legal counsel has reviewed and finds acceptable. More information about results-based standards can be found at:

[http://www.nerc.com/filez/standards/Project2010-06\\_Results-based\\_Reliability\\_Standards.html](http://www.nerc.com/filez/standards/Project2010-06_Results-based_Reliability_Standards.html)

## Standards Process

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 609.452.8060*

North American Electric Reliability Corporation  
116-390 Village Blvd.  
Princeton, NJ 08540  
609.452.8060 | [www.nerc.com](http://www.nerc.com)

**Individual or group. (60 Responses)**  
**Name (37 Responses)**  
**Organization (37 Responses)**  
**Group Name (23 Responses)**  
**Lead Contact (23 Responses)**  
**Question 1 (56 Responses)**  
**Question 1 Comments (60 Responses)**  
**Question 2 (58 Responses)**  
**Question 2 Comments (60 Responses)**  
**Question 3 (54 Responses)**  
**Question 3 Comments (60 Responses)**  
**Question 4 (56 Responses)**  
**Question 4 Comments (60 Responses)**  
**Question 5 (54 Responses)**  
**Question 5 Comments (60 Responses)**  
**Question 6 (55 Responses)**  
**Question 6 Comments (60 Responses)**  
**Question 7 (55 Responses)**  
**Question 7 Comments (60 Responses)**  
**Question 8 (54 Responses)**  
**Question 8 Comments (60 Responses)**  
**Question 9 (49 Responses)**  
**Question 9 Comments (60 Responses)**  
**Question 10 (55 Responses)**  
**Question 10 Comments (60 Responses)**  
**Question 11 (52 Responses)**  
**Question 11 Comments (60 Responses)**  
**Question 12 (53 Responses)**  
**Question 12 Comments (60 Responses)**  
**Question 13 (52 Responses)**  
**Question 13 Comments (60 Responses)**  
**Question 14 (49 Responses)**  
**Question 14 Comments (60 Responses)**  
**Question 15 (54 Responses)**  
**Question 15 Comments (60 Responses)**

-
Group
Northeast Power Coordinating Council
Guy Zito
No
<p>The proposed requirements in the standard are not focused on the core industry concern that current requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, "The existing requirements need to be revised to be more specific – and there needs to be more clarity in what sabotage looks like." Instead this proposed standard includes requirements that are more focused on "how" to report, rather than "what" to report. The draft 2 SAR has never been balloted for approval prior to standard drafting. In fact, the SAR states, "The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards." The scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seems helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting team seems to be ignored: "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The requirements for entities to develop Operating Plans and to have training</p>

for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard. The term "impact events" does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC Glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. This draft standard should not have this high a priority while other standards having a greater impact on Bulk Electric System reliability remain incomplete or unfinished. Regional reporting requirements should be in Regional Standards, and not be included in a NERC Standard.

No

Having the ERO as an applicable entity raises the issue that they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. NERC has also offered the opinion that since NERC is not a "user, owner, or operator" Standards are not enforceable against the ERO. In Attachment 1 the time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to unnecessary and possibly conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, this subject is more complex than this table reveals, and the table needs more clarification. Entities that have information about possible sabotage events should report these to NERC after the fact, and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, it is likely that there is going to be duplicate reporting. Several of the events require filing a written formal report within one hour. For example, system separation is going to require an "all hands on deck" response to the actual event. The paragraph above the table in Attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements through NERC that cross federal agency jurisdictions.

No

Having the ERO as an applicable entity raises a concern because they are also the Compliance Enforcement Authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of "applicable government, provincial or law enforcement agencies" for distribution as defined in R1. The "rationale for R1" states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. The better approach would be for the entities to complete OE-417 form and this standard simply require a copy.

No

This is an overly prescriptive requirement given that the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan is an unnecessary burden that offers no additional improvements to the reliability of the Bulk Electric System, and this is not, in fact, an Operating Plan. At most, it may be a reporting plan. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure Bulk Electric System reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Stating reporting requirements directly in the standard would produce a more uniform and effective result across the industry, contributing towards a more reliable Bulk Electric System. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate, and how will duplicative reporting be addressed (for example, DOE, Nuclear Regulatory Commission)? Also, in the "rationale for R2", please explain the reference to Parts 3.3 and 3.4.

No

"Impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditable compliance procedures. Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes a considerable amount of time for an actual cause to be determined. The determination process may require a complex root cause analysis. Further, in the case of suspected or potential sabotage, the industry can only say it doesn't know, but it may be possible. Law enforcement agencies make the determination of whether sabotage is involved, and the information may not be made available until an investigation is completed, if indeed it is ever made

available.
No
The need for a periodic drill has not been established, and appears to be overly restrictive given the intent of the standard is the reporting of impact events. Suggest this requirement be eliminated. Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in as short a time frame as may be required for real-time operating conditions notifications.
No
The need for a periodic drill has not been established, and appears to be overly restrictive given that the intent of the standard is reporting of impact events. Suggest this requirement be eliminated. There are training standards in place that cover these requirements. The relevant personnel should be "aware" of the reporting requirements. But there is not a need to have a training program with specific time frames for reporting impact events. Awareness of these reporting requirements can be achieved through whatever means are available for entities to employ to train on any of the NERC standards, and need not be dictated by requirements.
No
Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements for NERC that cross other federal agency jurisdictions. There is no need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations which is implied by the label "Operating Plan".
No
Having the ERO as an applicable entity raises concern as it is also the compliance enforcement authority. Requirement R7 is unnecessary as there are already requirements in place for three year reviews of all Standards. R8 contains requirements to release information that should be protected, such as identification of trends and threats against the Bulk Electric System. This may trigger more threats because it will be published to unwanted persons in the private sector. We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.
No
1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004. What are the examples at the bottom of page 14 supposed to illustrate? Critical Asset should have the appropriate capitalization as being a defined term. Is Critical Asset what is intended to be used here? Should the "a" list be read as ANDs or Ors? Does "loss of all monitoring communications" mean "loss of all BES monitoring "communications"? Does "loss of all voice communications" mean "loss of all BES voice communications"? Are the blue boxes footnotes or examples? Does "forced intrusion" mean "physical intrusion" (which is different from "cyber intrusion")? Regarding "Risk to BES Equipment," request clarification of "non-environmental". Regarding the train derailment example, the mixture of BES equipment and facility is confusing. Request clarification for when the clock starts ticking. Regarding "Detection of a cyber intrusion to critical cyber assets", there is concern that this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. Suggest physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.
No
There is already a DOE requirement to report certain events. There is no need to develop redundant reporting requirements to NERC that cross other federal agency jurisdictions. The heading on page 16 refers to EOP-002, but this is Standard EOP-004. If some questions do not require an answer all of the time, then the form should state that or provide a NA checkbox. While Attachment 1 details some cyber thresholds, Attachment 2 provides no means to report – which is acceptable if cyber incidents are handled by CIP-008 per the comment provided for Question 10. The Event Report Template in Appendix A is different from the most recent version, which is available at: <a href="http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf">http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf</a>
No
The use of the term "impact events" has simply replaced the terms "disturbance" and "sabotage", and has not further defined sabotage as directed by FERC. We do feel that "impact events" needs to be a defined term. While we agree with the SDT's new direction, the FERC directive has not been met. This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement and other specialized agencies, including international agencies roles in defining acts of sabotage, and not hold the registered entity wholly responsible to do so.
No



Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by the NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity. EOP-004-3 should be EOP-004-2.
No
The effective dates in Canada need to be defined. The first bullet should be sufficient. If the training and Operation Plan requirements are adopted as proposed, this may not allow sufficient time for some entities to comply, particularly those with limited number of staff, but perform functions that have multiple event reporting requirements.
Yes
Request clarification on how RCIS is part of this Standard. The form should be filled out in two stages. First stage would be the immediately available information. The second stage would be the additional information such as one line diagrams. There is concern with burdening the reporting operator on filling out forms instead of operating the Bulk Electric System. Most of the draft requirements are written as administrative in nature, and this is not most effective. Changes need to be made to (or possibly elimination of) R1, R2, R3. The standards should be changed to define what a "disturbance" is for reporting in EOP-004. Sabotage reporting as per CIP-001 should be rescinded as EOP-004 already has such a requirement.
Group
Tenaska
Brian Pillittere
Yes
Yes
Yes
No
We have adequate compliance procedures already in place for the existing CIP-001-1 and EOP-004-1 Standards. The list of required "Operating Plan" components in the proposed R2 is too specific. Maintaining the "Operating Plan" described in R2 would increase the burden on Registered Entities to comply with the Standard and this type of "laundry list" Requirement would make it more difficult to prove compliance with EOP-004-2 during an audit.
No
The probable cause of a reportable event is already required to be submitted on the OE-417 form. This Requirement is redundant.
No
This Requirement is too specific and places additional burdens on Registered Entities.
No
This Requirement is too specific and places additional burdens on Registered Entities.
No
The reporting timelines are currently listed on the OE-417 form. This Requirement is redundant.
Yes
Since the proposed EOP-004-2 Standard does not eliminate the OE-417 reporting requirement, it does not streamline the existing CIP-001-1 and EOP-004-1 reporting requirements for GO/GOP's. The "laundry list" of components required in the Operating Plan described in R2 is too specific and would make it more difficult to prove compliance during an audit. We prefer that the existing CIP-001-1 and EOP-004-1 Standards remain unchanged.
Individual
Brenda Lyn Truhe
PPL Electric Utilities
Yes
No
While we agree with the applicable entities in the Applicability Section of the revised standard, we would like the SDT to

reconsider the applicable entities identified on Attachment 1, specifically regarding duplication of reporting e.g. should TO and TOP report?
Yes
No
While we agree with documenting our process, we feel the use of the defined term Operating Plan is not required and possibly a misuse of the term. We would like to suggest using the term 'procedure'. Additionally, we would like the SDT to confirm/clarify whether Attachment 1 is a complete list of impact events. Also, please confirm that the Proposed R2.1 language 'Method(s) for identifying impact events' means identifying impact event occurrence as opposed to identifying list of impact events. i.e. does R2.1 mean recognize impact event occurrence?
No
We believe the rationale for R3 is good and provides value. However, we feel the clarity was lost when the rationale was translated to the standards language. Please consider revising language to refocus on rationale of assess and report per Attachment 1 as opposed to identify. We suggest changing the word "identify" to "recognize" and add the Rationale statement to the requirement as follows: "Each Applicable Entity shall assess the causes of the reportable event and gather available information to the complete the report."
Yes
No
We agree with the need for training on one's process. However, we suggest changes to R5.3. Consider expanding the exception criteria to exempt non-substantive changes such as errata changes, minor editorial changes, contact information changes, etc. We also suggest saying '....,training shall be conducted, or notification of changes made, within 30 days of the procedure revisions.'
No
We understand the rationale for this standard and support the project to combine EOP-004 and CIP-001 as well as the reporting requirement in CIP-008. We are concerned that it may be difficult to meet Attachment 1 Part B Potential Reliability Impact submittal times as the time to submit is 1 or 24 hour after occurrence. E.g. Risk to BES equipment, the example given is a major event and easy to conclude. Consider forced intrusion, risk to BES equipment (increased violence in remote area), or cyber intrusion – should Attachment 1 state 'report within 24 hours after detection'?
Yes
No
While we think providing an impact event list is beneficial, we would like to see Attachment 1 revised and/or clarified. Refer to response to Question 2 considering duplicate reporting. Regarding impact event 'Damage or destruction of BES equipment' and considering the first example in the 'Examples' section, does 'example a. i.' mean if the BES equipment that is damaged is not identified as a critical asset per CIP-002 that no reporting is required? Clarify the Part A and Part B, specifically: Attachment 1 Part A is labeled 'Actual Reliability Impact'. Does this title mean that for all events listed that the 'threshold for reporting' is only met if the event occurs AND there is an actual reliability impact? As opposed to Part B where the threshold for reporting is met when the event occurs and there is a potential for reliability impact? This could be broad for event 'risk to BES equipment'. Providing as much clarity as possible on the 'threshold for reporting' is beneficial to the industry and will help eliminate confusion with the existing CIP-001 standard regarding 'potential sabotage'.
Yes
For ease, timeliness, and accuracy of reporting an application with an easy to use interface would be preferred. If the reporting is done via an application, the ability to enter partial data, save and add additional info prior to submission would be helpful. Additionally, an application with drop downs to select from for impact event, NERC function, etc would be helpful. #1 - Is the 'Compliance Registration ID number' the same as the NCR number? If this is required, include as separate entry. #2 – is this the date of occurrence or detection?
Yes
Refer to clarification requested in question 10 comments.
Yes
Yes
Yes
Combining EOP-004, CIP-001 and CIP-008's reporting requirements reduces redundancy and will add clarity to the compliance activities.
Group
SERC OC Standards Review Group

Jim Case, SERC OC Chair
No
The term "impact events" does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator.
No
We find it interesting that the ERO is listed as an applicable entity. The ERO can't be an applicable entity because they are the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. NERC seems to be attempting to evade FERC jurisdiction by having a standard that enables it to write new rules that don't pass through the normal standards development process with ultimate approval by FERC. Attachment 1 is troublesome. The time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does an RC have to report an EEA if the BA is going to report it? This will lead to conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, we believe this subject is more complex than this table reveals and the table needs more clarification or it should be eliminated and leave the time frames in the other standards. Several of the events require filing a written formal report within one hour. For example, system separation certainly is going to require an "all hands on deck" response to the actual event. We note that the paragraph above the table in attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
No
The ERO cannot be subject to a requirement for which it is the compliance enforcement authority. The governance in this situation appears incomplete.
No
This is an overly prescriptive requirement that dictates details of documentation and, as such, has no place in a reliability standard. NERC needs to trust the RCs to do their jobs; this standard and this requirement in particular seems to be attempting to codify the actions that an RC would take in response to an event. The cost and burden of becoming auditably compliant with this requirement is extreme and unrealistic, especially on small entities
No
We think "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditably compliant procedures.
No
We think this requirement is unclear – we think it requires a drill for "reporting", which seems absurd! We recommend the elimination of this requirement.
No
While we support training on an annual basis for the operating plan, the concept of requiring training on reporting of after-the-fact events does not support or enhance bulk electric system reliability. We recommend the elimination of this requirement.
No
There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
No
The ERO cannot be subject to a requirement for which it is the compliance enforcement authority. The governance in this situation appears incomplete.
No
Will all reporting requirements be removed from other standards to avoid duplication? And will all future standard revisions include revisions to this standard to incorporate associated reporting requirements? There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
No
There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Yes
We do feel that this needs to be a defined term
No

Yes
Yes
We find it disturbing that NERC is headed down a path of codifying requirements that are redundant to existing DOE requirements. How does redundancy in reporting requirements improve or enhance bulk electric system reliability? Disclaimer: "The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers."
Group
PacifiCorp
Sandra Shaffer
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
No
Group
Luminant Energy
Brad Jones
Yes
No
Inclusion of both GO and GOP will result in duplicate reporting as both are responsible for reporting resource-related events such as Generation Loss, Fuel Supply Emergencies and Loss of Off-site power (grid supply). Recommend including only the GOP as it is critical that the GOP gather and communicate relevant information to the Reliability Coordinator.
Yes

Yes
Yes
No
We support the requirements outlined in R2 which create significant obligations to maintain and update the required Operating Plan. However, we believe annual drilling for a reporting process seems unnecessary, particularly given the response horizon of 24 hours for the majority of impact events. If drilling is required, the standard should allow actual events to fulfill a drilling requirement as stated in the Rationale for R4 and within the text of M4.
No
Operating Plan revisions communicated through procedure updates and employee acknowledgements of the same are sufficient when coupled with a procedural training program that occurs according to a programmed schedule.
Yes
Yes
Continually refining the Impact Event table to better define which events should be reported would be extremely valuable. Section 802 does not adequately require such refinement, thus R7 and R8 are appropriate inclusions to this standard.
No
The Impact Events Table might be easier to clarify if organized by Reporting Entity rather than Event Type as events vary substantially based on the affected BES component. For example, a GO or GOP cannot adequately determine if an event will significantly affect the reliability margin of the system or if an event results in an IROL. Examples specific to Reporting Entities would assist in more appropriate report submissions. Additionally, the footnote under examples of Damage or Destruction of BES Equipment, cites "A critical asset". This term must be clarified to indicate whether this refers to a Critical Asset as defined by CIP 002-1. Finally, the Fuel Supply Emergency item requires additional definitions as neither a GO nor a GOP can reasonably project if an individual fuel supply chain problem will result in the need for emergency actions by the RC or BA.
Yes
No
The term "Impact Event" does not adequately replace the term "Sabotage" The Impact Events table seems to provide the definition of the term "Impact Event". This table does not include sufficient definition for actual sabotage events. Additionally, it does not include any provision for suspected sabotage events. Assuming the Damage or Destruction of BES Equipment event type is intended to cover actual sabotage, the Threshold for Reporting column should include specific levels of materiality that are specific to Functional Entity. For instance, a GO and GOP could have a MW level to define materiality as a GO or GOP cannot assess impact to an IROL or system reliability margin due to equipment damage. A threshold value consistent with "Generation Loss" in the proposed EOP-004 Attachment 1 would be appropriate.
No
CIP-001-1 R3.1 includes instructions associated with the DOE OE-417 form. EOP-004-2 R2.6 should include the DOE as an example of an external organization requiring notification. Additionally, the Rationale for R1 discusses the possibility of one electronic form satisfying US entities with related disturbance reporting requirements but does not include any information about the likelihood of this outcome. Please elaborate on the process required to combine these reports.
Yes
No
Individual
Greg Froehling
Green Country Energy
Yes
Yes
Yes

No
Highly administrative version of what could accomplish the same thing. A requirement that the applicable entity shall make appropriate notifications as required by attachment A and B events. I can see the need for review and lessons learned but that needs to be done at a higher level since many entities may be involved in an "event"
No
Actually yes and no... An event may be caused, analyzed and corrected by one entity but most likely it will involve more. Low Voltage or frequency may not be caused by a generator but the generator will see the event and to have the generator assess the probable cause seems inappropriate. I can see reporting the event and duration and making notifications.
No
Another training requirement with what benefit? We must train on all of our NERC requirements now anyway to insure compliance and that's not a requirement, thats implied and I think thats enough.
Same as my comment for question 6
Yes
Now this is an excellent example of all that is needed for this requirement!
Yes
I realize this is another burden for the ERO but the information would be good to know what is going on outside the plant .
Yes
Yes
No
Yes and no ... Yes impact events is an adequit term however since it is restrained by the tables it may be helpful to define the term and scope of the term to be more inclusive of sabotage events.
Yes
With the provision that definition and scope of "impact event" are developed and tables adjusted as needed to address FERCs concerns specifically . "(1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event."
Yes
Yes
I think the drafting team has done a wonderful job of beginning the task of combining two related standards. I ask them to keep in mind the small generators, and others who do not have the wide view capability, that more than likely react to events that occur wih no knowledge of why they ocured, and limited staff to address administrative standard requirements. Many times the KISS approach is the best approach.
Individual
TransAlta Centralia Generation, LLC
TransAlta Corporation
Yes
Yes
Electrical Reliability Organization (ERO) does not appear to be a defined term in the NERC Glossary of Terms on the NERC website. Last updated April 20, 2010.
Yes
Yes
No
Clarity required Does an entity have to report on the cause of every "applicable" impact event they witness even though the event did not originate at their plant, system or region and did not adversely affect them? Essentially this would require every entity that witnessed an "applicable" event to report on its cause. In most cases they will not know the cause if they did not create the event. Measure M3 should reference Attachment 1 to indicate the Time to Submit Report'.
Yes

No
Measure M5 states applicable entities shall provide training material presented... This measure is unclear as to whether the meaning is for internal personnel or to be provided to external entities upon request? Please clarify.
No
R6 should reference Attachment 2 to make it clear that this report form must be used. M6 seems to be requesting evidence that the Confidential Impact Event Report was submitted. TransAlta suggests the submission of the actual report is evidence the report was submitted. Records of this submission can be provided on request. Web Reports Project 2009-01 has indicated online reporting is the direction they are going. If the impact report becomes an online Web report the entity submitting the report has no way of confirming the report ended up at the Compliance Enforcement Authority office after it is submitted. There needs to be some method that demonstrates the report was submitted and received.
Yes
Yes
No
We recommend the 'time to Submit Report' to start when the event is recognized verses when it occurred.
Yes
Yes
Yes
Yes
A Confidential Impact Event Report form is included in attachment 2 but nowhere in the standard does it say to use this form. This form appears to be similar to the "Preliminary Disturbance Report" form used in EOP-004-1. Clarity is required.
Individual
Doug Smeall
ATCO Electric Ltd.
Yes
Yes
Yes
Yes
Yes
Yes
No
R5.3 requires an entity to conduct training within 30 days of a revision to the Operating Plan. For an entity that covers a wide area, 30 days may not be sufficient to reach all employees.
Yes
Yes
No
Attachment 1: Part A - Transmission Loss: Only sustained outages should be reportable. Also the reporting threshold needs to be quantified for impact events, for example: a) Size of DC converter Station > 200 MW. b) Impact of loss of Multiples BES transmission elements in terms of significant load (> 200 MW for > 15 min).
No
Attachment 2 Item 4 implies that an entity is required to analyse and report on an impact event that occurred outside its

system. This is not practical as the entity will not have access to the necessary information.
Yes
Yes
Yes
No
Individual
Dan Roethemeyer
Dynegy Inc.
Yes
Statement is broad enough to cover both Standards.
Yes
Yes
No
For 2.7, 2.8, 2.9, 30 days is too stringent. Some changes may not warrant changes until a cumulative amount of changes occur. Suggest making it no later than an annual review.
Yes
No
What is the basis for the drill being annual. This is too stringent. I suggest it be every 3 years.
No
The annual training seems excessive especially if there have been no changes. You have included one exception for contact information revisions; however, it should be expanded to include exceptions for minor/non-substantial changes. Also, make training requirements (after initial training) be required for substantive changes only.
Yes
Yes
No
A 2000 MW loss needs to be more clearly defined by either the BA, ISO, RC, etc. for the applicable entity. Also, what is the distinction between the "damage or destruction of BES equipment" and the generation loss of $\geq 2000$ MWs if it is a Critical Asset which is currently drafted as those greater than 1500 MW in current draft of CIP-002-4. This could lead to 2 events with different thresholds (i.e. 1500 MW and 2000 MWs). Possibly get rid of the 2000MW criteria and let the threshold level be the same as the Critical Asset MW level. Or remove the Critical Asset threshold in the footnote to Attachment 1.
Yes
No
The term is fine but FERC wants more specific examples. GO/GOP can't determine the effect on the BES.
Yes
Yes
Yes
This does not address the inability of a GO/GOP to determine effects on the BES. Surrounding BES knowledge is limited for a GO/GOP.
Group
City of Garland
David Grubbs
Yes



Yes
No
Reason 1 Most of this is duplication of existing processes - More "Big Government" and/or "Overhead" is not needed. There are already processes in place to notify "real time" 24 X 7 organizations that take action (RC, BA, TOP, DOE, FBI, Local Law Enforcement, etc) in response to an "impact event". It is stated in your document on page five (5) "The proposed standard deals exclusively with after-the -fact reporting." The combining of CIP 001 & EOP 004 should not expand on existing implemented reporting requirements nor should it result in NERC forming a 24 X 7 department to handle 1 hour (near real time) reporting requirements. Reason 2 If this should go forward as drafted, NERC should not establish a "clearing house" for reporting requirements for Registered Entities without also taking legal responsibility for distributing those reports to required entities. It states in at least 2 places (Page 6 & Page 22) in the document that Responsible Entities are ultimately responsible for ensuring that OE-417 is received at the DOE. Thus, a Registered Entity could be penalized for violating this new standard if it did not file the reports with NERC or it could still be penalized (both criminal & civil) if they filed the reports with NERC but NERC (for whatever reason) did not follow through with ensuring the report was properly filed at the DOE.
No
There are 4 "methods" and 2 "provision" required for this requirement – in other words, 6 "paperwork" items that auditors will audit and likely penalize entities for. On page 1, the statement is made "...proposed standard in accordance with Results-Based Criteria." Having to have 4 methods and 2 provisions to end with a report (all of which is paperwork) is not a "result based" standard. It is like being required to have a "plan to plan on planning on composing and filing a report". Events need to be analyzed, communicated, and reported and should be audited as such (results based) – not audited on whether they have a book filled with methods and provisions.
No
Should be part of R2 or R6 – this is unnecessary duplication
No
Existing CIP 001 and EOP 004 are reporting standards – neither currently requires annual drills or exercises. Combining these two (2) should not entail expanding the requirements to include drills or exercises. There are existing drills / exercises that must be performed annually for compliance with CIP 008 & CIP 009 which require the same basic identifying, assessing, developing lessons learned, responding, and reporting skill sets. Requiring additional drills or exercises for this new combined standard will provide additional "business overhead" that results in basically nothing that is not obtained by the CIP 008 / 009 drills as far as securing or making the BES reliable. It does, however, result in additional audit risk at audit time.
No
This expands beyond the original CIP 001 and EOP 004 – neither explicitly requires training – combining does not mean expanding. In reality, what practical skill are you going to train on? People who perform the analysis on an event are going to have job specific training external to this standard and those same folks will maintain their skill set external to this standard. If it is going to be a results based criteria standard, then let the entities be responsible. Training on methods to fill out and file paper work does not make the BES more reliable. The vast majority of other standards do not have a training requirement section and yet, entities manage to be compliant with those standards. Compared to all the other reliability standards and their requirements, are penalties for training on filling out paper work really making the BES more secure and reliable?
No
1. The reporting requirements should not be expanded beyond CIP 001 and EOP 004-1. The goal for combining the two should be to make the process more efficient – not add on extra requirements for procedures on how to report, drills on reporting, training on reporting, etc. 2. The timelines requiring 1 hour reporting to the ERO are not needed and provide little realtime benefit to the BES. Real time or near real time reporting for "people on the ground" such as the RC, BA, TOP, FBI, Local Law Enforcement, DOE, etc. is necessary. They are in a position to take action in response to an event. On page 5, it states "The proposed standard deals exclusively with after-the-fact reporting. 1 Hour reporting requirements to the ERO in addition to existing reporting are not reasonable "after-the-fact" reporting requirements in the midst of an emergency. Also, there is not a 24X7 ERO center to report events to – why build and staff one when they already exists at the RC, BA, TOP, DOE, FBI, Local Law Enforcement, etc. – An ERO 24X7 center would be extra overhead that would provide no additional benefit in the first hour or hours of an emergency.
Yes
R7 – Yes as long as any changes to attachment 1 follow the "Reliability Standards Development Procedure. R8 - Yes as long as R8.6 is strictly "recommended actions." They should not become "required actions" as this bypasses the standard development process.
No
This report should follow exactly the OE-417 to avoid redundant, possible conflicting, and overall confusion in reporting. Note: The table has entries that are in conflict with the OE-417 and thus can cause confusion in filing multiple reports potentially causing an entity to violate Federal Law due to the confusion. By submitting the same information on

different timelines, i.e. one hour reporting under OE-417 and 24 hours under this Standard, the reports may be significantly different causing confusion from differing reports of the same event. Although we prefer the events to match the OE-417 events exactly, if the SDT decides to include a separate events table we make the following suggestions: Energy Emergency requiring system-wide voltage reduction: should be reportable at 5% not 3% voltage reduction. The standard should clearly state this was applicable for BES energy emergency conditions only, not voltage reductions for other reasons. On voltage deviations: it should be clear that this applies to widespread effects on the BES not a single distribution feeder that has a low voltage. For the Frequency deviation: Did not see a definition for the FTL (frequency trigger limit) Generation loss: the reportable loss of generation should be significantly more than 500 MW. The number of units at the location is irrelevant. Ten units at 50 MW each is no more critical than a single 500 MW unit. Under this standard, if the plant with ten 50 MW units trips it is reportable but an 800 MW single unit is not reportable. The trip of the 800 MW unit has much more effect on the system reliability. Damage or destruction of BES equipment: Should be limited to specific equipment such as a 765 kV autotransformer not a 138 kV lightning arrester. This needs to be eliminated or significantly limited as to the equipment type that is reportable.

No

The report filed should be the OE-417 ELECTRIC EMERGENCY INCIDENT AND DISTURBANCE REPORT and should be filed only on OE-417 reportable incidents. If this report is implemented as drafted, companies with multiple registration numbers and functions should only have to file one report for all functions and registrations.

No

1 In keeping with a Results Based Standard, the impact event should be a trigger for filing a report. At the time of the event, one may not know if the event was caused by sabotage. Sabotage that does not affect the BES should not be a reportable event. 2. To comply with the Commissioners request to define sabotage, Impact Event does not adequately replace "sabotage". If someone reports sabotage, people universally have a concept that someone(s) have taken some type of action to purposely harm, disable, cripple, etc something. Impact Event does not convey that same concept. 3. If Sabotage is left as a "trigger," it should not include minor acts of vandalism but only acts that impact reliability of the BES

No

EOP-004-1 R2 did not get translated to EOP-004-2 R2 - table states it is mapped to R1

No

Do not agree with this proposed draft - instead of combining 2 standards to gain efficiency, this expands the standard with unnecessary paperwork, drills, training, etc.

Yes

Do not agree with this proposed draft - instead of combining 2 standards to gain efficiency, this expands the standard with unnecessary paperwork, drills, training, etc. For reports required under this standard, companies with multiple registration numbers and functions should only have to file one report for all functions and registrations.

Individual

Kasia Mihalchuk

Manitoba Hydro

No

Though new purpose greatly clarifies the proposed EOP-004-2 and using "situational awareness" is the key to this purpose, further clarification of specific items should be added to the purpose. "Responsible Entities shall report SIGNIFICANT events to support interconnection situational awareness on events that impact the integrity of the Bulk Electric System, such as islanding, generation, transmission and load losses, load shedding, operation errors, IROL/SOL violations, sustained voltage excursions, equipment and protection failures and on suspected or acts of sabotage."

No

Since this Standard is to support situational awareness, more entities should be included such as Load Serving Entities (which was removed from EOP-004-1).

Yes

Yes, keeping R1 generic and pointing to "government", "Provincial", "law" encompasses all entities in all major interconnections.

Yes

R2 – 2.1 to 2.9 detail what is expected of an Operating Plan for Impact Events. The attachment 1 details the event, the threshold parameters and time line. Though the threshold parameters in the attachment may be questioned, this greatly clarifies the expectations of reporting events. Further events should be added to this list: "Detection of suspected or actual or acts or threats of physical sabotage"

No

Though each local entity should identify and assess initial probable cause of impact events as per their Operating Plan, the creation of this Operating Plan could be labor intensive and also guidelines for consistency within an RC region should be created. So "NO" is entered simply because a large time line would be needed to properly and efficiently implement R3 and R4.

No
Drills and exercise for implementation of the Operating Plan are important and critical, but as in question 5, or Requirement R3, careful and detailed creation of the Operating Plan are crucial to facilitate proper training, drills and exercises. So "NO" is entered simply because a large time line would be needed to properly and efficiently implement R4 and R3.
No
The comments in Question 6 and 7 encompass the training aspect of this requirement.
Yes
Attachment 1 details the impact events and the thresholds of which they should be reported.
No
Rules of Procedure appear to have a different focus then R7 and R8. Briefing on Rules of Procedure 802 Assess, review and report on: 1.1 overall electric operation 1.2 uncertainties and risks 1.3 self assessment of supply and reliability 1.4 projects on customer demand 1.5 impact of evolving electric market practices that could affect the present and future of the BES Briefing on R7 and R8 R7 – ERO shall review and propose revisions to Attachment 1 R8- ERO shall publish quarterly reports on trends, threats, vulnerabilities, lessons learned and recommended actions.
Yes
Though R7 indicated Attachment 1 will be reviewed and revised regularly the immediate addition of: "Detection of suspected or actual or acts or threats of physical sabotage" should be added.
No
Though a "Confidential Impact Event Report" is much needed the Attachment 2 needs refinement. Provide an explanation for each "task". Isolate and simplify the "Who, When and What" section. Isolate the description of event. Remove items 7 to 10. Modify Attachment 1, add columns to indicate time of event, quantity, restore time, etc as required. The Attachment 1 can be attached to Attachment 2. This could simply and speed the reporting process.
No
The majority of the items listed in Attachment 1 are typically and historically operating events. Yes these are all "impact events". Sabotage, cyber and security are typically viewed as separate events. These events are not part of "a typical day of BES operations". These are outside event and though qualify as "impact events" should still be treated separately.
No
Though CIP-001-1a already contained provisions for sabotage response guidelines, the new EOP-004-2 R2 (2.1 to 2.9) will require reexamination of existing policies to remain compliant. Upon the approval of Attachment 1, the existing disturbance guidelines will also have to be reexamined. With the addition of R3 (Identify and assess), R4 (Drills) and R5 (Training), will also require redevelopment of existing processes.
No
Individual
Philip Savage
PacifiCorp
Yes
Yes
Yes
All efforts need to be made to include OE-417 reporting requirements to safeguard against duplicate reporting and / or delinquent reporting. One report for all events is more preferable than multiple reports for one event.
Yes
Yes
Yes
No
Training required within 30 days of a revision to the Operating Plan is not feasible with 5 or 6 week shift rotations. A sixty day requirement would be more realistic.
Yes

Yes
No
Energy Emergency requiring firm load shedding - An SPS/RAS could operate shedding firm load but no Energy Emergency may exist. This requires clarification. Transmission Loss - Multiple BES transmission elements. Loss of two transmission lines in the same corridor due to a wildfire could qualify for this reporting. Once again clarification needed.
No
As previously mentioned all effort should be made to ensure duplicate reporting is not required. OE-417 requirements should be covered by this one form.
Yes
Yes
Yes
Yes
This is yet another standard with training requirements not covered under any PER standards. Having different training requirements spread throughout the standards makes it increasingly difficult to ensure all training requirements are met. Developing a "Training Standard" that lists ALL required training would streamline the process and aid greatly in compliance monitoring.
Individual
Brian Reich
Idaho Power Company
Yes
Yes
Yes
the SDT must ensure that only a single form is required for compliance (such example OE-417)
No
The SDT needs to clarify Requirement 2.9 references an annual report issued pursuant to requirement R8, however Requirement 8 references a quarterly report. These requirements should have the same time frames.
Yes
Yes
No
The 30 day Requirement is limited with real time operations. Most entities with real time operations utilize a 5 or 6 week rotating schedule to comply with PER-002. the NERC Continuing Education Program allows up to 60 days to comply, this allows the operating shifts to accommodate training within the operating schedule. The requirement 5.3 should allow 60 days to complete the training.
Yes
Yes
Yes
No
there should only be on report, utilized OE-417
Yes
Yes
Yes

Yes
By including training requirements in each standard, creates confusion and compliance or failure to comply potential. PER standards are in place for personnel training, these standards should be utilized for adding requirements that require training for NERC Standards.
Individual
Chris Hajovsky
RRI Energy, Inc.
No
The purpose does not need to mention "and the reliability of the Bulk Electric System." This is the Congressional mandate in FPA Section 215, and could be attached to every Standard, guide, notice and direction issued by FERC, NERC and Regional Entities. In addition, the purpose references "Responsible Entities." However, section 4 on "Applicability" references "Functional Entities." These terms should be consistent. Therefore, the purpose statement of the proposed standard should be corrected to read, "Functional Entities identified in Section 4 shall report impact events and their known causes to support situational awareness." CONSIDERATION: Is the phrase "shall report impact events and their known causes" really a purpose of the Proposed Standard, or is it instead merely a means to achieve the purpose of situational awareness? If the latter, the purpose statement can be further shortened to read, "Functional Entities identified in Section 4 shall support situational awareness of impact events and their known causes."
No
Agree with the "Applicability" section functional categories. Agree with the Attachment 1 lists of "Entity with Reporting Responsibility," with the following exceptions: PART A "Damage or Destruction of BES Equipment" - This item has a footnote 1 listed, but nothing at the bottom of the page for a footnote. Assuming the footnote reference is intended to reference the "Examples" at the bottom of the page, the following concerns exist: (i) "critical asset" - Is this term intended to reference a "Critical Asset" identified pursuant to the CIP-002 risk-based assessment methodology? If so, it should be capitalized. If not, who determines what constitutes a lower case "critical asset"? (ii) "Significantly affects the reliability margin of the system..." - If this is intended to be enforceable, several words need significant clarification and definition, such as "Significantly," "reliability margin," "system" (BES?), "potential," and "emergency action." The combined ambiguity of just two of those phrases would most likely result in a court holding this statement as so vague as to be unenforceable. The combined lack of clarity of all the highlighted words or phrases render this sentence meaningless. (iii) "Damaged or destroyed due to a non-environmental external cause" - "Non-environmental external cause" should be a defined term because, as is the case in item (ii) above, it is vague and subject to broad, random or arbitrary interpretation. Part B provides examples of "non-environmental physical threat" for "Risk to BES equipment." Those examples could be referenced here, or different examples included that are more applicable to the Event. The items highlighted in items (ii) and (iii) above are very similar to the unintended string of CIP-001 violations that Registered Entities experienced in 2007 and 2008 for failing to provide their own definition of "sabotage" under a sabotage reporting standard that failed to provide any guidance to the industry within the standard as to what constituted "sabotage." PART B "Detection of a cyber intrusion to critical cyber assets" - Capitalize "Critical Cyber Asset."
Yes
While including the phrase "to enhance and support situational awareness" is a good use of the Results-Based Standards development tools and framework, the phrase is already included in the purpose statement. As such, it is unnecessary in Requirement 1. If it were to be included in Requirement 1, then it would also need to be included in each of the other Requirements 2 through 8. The "Purpose" statement captures this aptly.
No
1. R2 includes the phrase "for identifying, assessing and reporting," followed by R2.1 which states "identifying," R2.2 which states "assessing" and both R2.3 and R2.6 state "notify" or "making internal and external notifications" (i.e., reporting). The language is unnecessarily redundant. RECOMMENDATION: Reword R2 phrase "for identifying, assessing and reporting," to simply state, "for addressing." 2. Rationale for R2 - The rationale section for R2 references in the third paragraph "Parts 3.3 and 3.4." Was this intended to reference R2.3 and R2.4?
No
"Identify and assess" - Auditors are as much in need of clearly worded, unambiguous Reliability Standards as Registered Entities. This phrase leaves much too wide a range of interpretations, almost guaranteeing regular and frequent disagreements during an audit between Registered Entity and Regional Entity auditor as to what constitutes "identify and assess" sufficient to meet the intent of this Requirement. Compounding this issue is the Rationale for R3 that states an Applicable Entity (which should probably read "applicable Functional Entity") should "gather enough information to complete the report that is required to be filed." While Rationale statements are not technically part of the standard, this emphasizes the current wording of the requirement as subject to random and arbitrary interpretation by auditors and Registered Entities. RECOMMENDATION: Change "identify and assess" to "document," so that the Requirement now reads "Each Applicable Entity shall document initial probable cause of impact events..." including an option for "cause not determined".
No
Every employee in a Registered Entity might potentially have exposure to an impact event, and therefore result in a list

of thousands of employees subject to the EOP-004-2 Operating Plan. Does this mean, for example, an applicable Functional Entity with 3,000 employees, each capable of potentially observing an impact event, must include them in the drill, exercise, or Real-Time implementation? Such an expectation would require a hypothetical email notice to be sent to 3,000 employees, advising them "This is a test - You observe a suspicious vehicle driving around the fence of your power plant. Perform the next action you should take." The result in this hypothetical might be 3,000 phone calls and emails to the responsible employee in the applicable Functional Entity, each needing to be documented and retained for the audit period. As stated above in question 5, auditors need guidance as much as Registered Entities. Otherwise, it is observed that they will seek the most stringent approach they observe from the best of the best practices over the first year of implementation and apply that expectation as the base-case, under which all other approaches will be deemed violations.

No

1. This Requirement is structured to result in the same heavy-handed, zero-tolerance approach that has made CIP-004 one of the top three violated Reliability Standards. The failure in CIP-004 is that, for example, a seven-year background check or annual training program that is tardy by one day results in a violation. There is no margin of error, proviso, or cure scenario. Likewise, the proposed R5 in EOP-004-2 makes it a violation if someone takes their newly established training on the day after the end of 15 months. Systems configurations are often based on quarterly monitoring for individuals needing to take training. In addition, when dealing with potentially thousands of employees, it is inevitable that any one of hundreds of reasons might result in an employee not being included in the tracking system, and rolling past the 15th month. RECOMMENDATION: To avoid further burden to Regional Entity audit and enforcement personnel as has been the case in CIP-004, develop a cure process that allows the Registered Entity to correct the training or background check tardiness with prompt correction, fill out a notification report to submit to NERC, and proceed with protecting the reliable operation of the BES, rather than tying up Registered Entity and Regional Entity staffs with data requests, enforcement paperwork and administrative actions. 2. The proposed R5.3 requires the entire applicable staff to redo the entire training within 30 days of a change to the Operating Plan. These Operating Plans will not be short documents, and formal training will not involve a 5 minute soundbite. However, for such a significant procedure as the Operating Plan, frequent changes and revisions are going to be very common, especially given the likelihood of frequent clarifications, Compliance Action Notices ("CANs"), and lessons learned issued by NERC and Regional Entities over this very detailed set of new obligations. It is not unreasonable to expect a Registered Entity to make three or more revisions to their Operating Plan in a year, which would require training for thousands of employees three times a year, for what might amount to a single sentence revision. Furthermore, the obligation to retrain on the entire training program is not limited in this requirement to only those individuals impacted by the revision. Where a change or revision only impacts 3 possible employees, this standard would require a company with 1,500 employees subject to the Operating Plan to retake the entire training. RECOMMENDATION: Clarify that upon changes to the Operating Plan, the Registered Entity may either require full training, or instead distribute a summary of the change(s) via email to affected personnel only.

No

RECOMMENDATION: Clarify that the reporting of impact events shall be to those entities identified in the Operation Plan section developed specifically in Section 2.6. Reference to Attachment 1 indicates reporting to "external" parties is the intent for R6.

Yes

We support the concept that Reliability Standard requirements and obligations that are subject to violations and penalties should all be contained in the four-corners of the Reliability Standard. If an obligation exists in the Rules of Procedures that creates a stand-alone responsibility that is subject to violation and penalty, it should be removed from the Rules of Procedure and inserted into the appropriate Reliability Standard.

Yes

Yes

Yes

Agree. However, strongly encourage this to be made into a defined term in the Glossary of Terms.

Yes

Assume reference to EOP-004-3 in the question 13 was meant to reference version 2 (EOP-004-2).

Yes

No

Individual

Bill Keagle

BGE

Yes

Yes
No
R1 With the definition of "Impact Event", are we eliminating the term "Disturbance Reporting"? If we eliminate disturbance reporting, SDT should remove the reference from the Summary of Concepts and from the title, otherwise further definition on the distinction between the two terms is needed. R1. What is the "system" described here? What type of system is anticipated – electronic, programmatic or can it be better described by using “standard reporting form”? M1. Needs to seek evidence that the "system" was used for receiving reports, as well as distributing them. M1. Examples are more appropriately used in guidance documentation than in the standard. Rationale for R1 – Final statement regarding OE-417 needs to be removed. The ERO will establish the requirement in their “system” if the standard remains as is. The Requirement does not require the responsible entities to send OE-417 to DOE.
No
R2.1 Creates the opportunity for differences in identifying impact events. BGE recommends additional clarity in the statement. Are we to use Attachment 1 as a “bright line” or can we use our Operating Plan to identify what an impact event is? R2.4 - 2.6 Does a standard need to specify both internal and external lists? 2.7 – is “component” defined anywhere? Is it a component of the BES or a component of the Operating Plan or a component of the three lists in 2.4 to 2.6? Rationale --- Parts 3.3 and 3.4?? Do you mean 2.3 and 2.4? Is the Operating Plan under scrutiny (mandatory and compensable) for all items in the last paragraph of the rationale?
No
R3. Limits responsibility to Attachment 1 events only and mandates that an “initial probable cause” be identified. Are we at liberty to define “initial probable cause” and define time period for completion in the Operating Plan? BGE believes this could cause wide difference between Operating Plans and the standard should be more prescriptive by relating to a time-table for the life of an impact event, including expected identification time, initial assessment time and analysis time leading to the reporting deadlines. BGE recommends not including examples of evidence in a measure but include it in a Guideline. Including in a measure will be translated as a requirement by an auditor.
No
M4. BGE recommends not including examples of evidence in a measure but include it in a Guideline. Including in a measure will be translated as a requirement by an auditor. Rationale for R4: If multiple exercises are performed are all of them subject to the sub-R2 requirements and to audit/audit findings?
No
Suggested revision to clarify R5: Each Applicable Entity shall provide training to all internal personnel identified in its Operating Plan on the Operating Plan annually. Training is only on Reporting, pursuant to R2, not on the Operating Plan? BGE does not believe the SDT needs to identify sub bullets on this requirement. R5.1 is not logical --- what does it mean?
Yes
Comments for clarification: R6. Use of Capital letters in Operating Plan makes it unnecessary to state "created pursuant to Requirement 2
No
R7. Make Impact Event Table all Capital Letters(it is a title). R8. Is the term "reportable impact events" new or is impact event intended to be capitalized? R8. Does a quarterly report of the year's reportable impact events include 12 months of "reportable impact events"? This is confusing. R8. In the Rationale for R8 Impact Events appears with Capital letters - why now? Shouldn't it appear with all Capital letters throughout the document as it is a defined term? R8. There are no previous requirements to report threats (R8.3) or lessons learned (R8.5) or trends (R8.2) to an ERO. Is this information from reports to the ERO or from ERO research?
No
TOP determines "system-wide" voltage reductions; why place this responsibility on a TO or DP? - Load Shedding is automatic load shedding; why 100MW? Does a DP need to provide a Report when directed by the RC, BA or TOP to shed load or reduce voltage? - No examples should be included in the standard! Need to define a "BES Transmission Element". - Table shows multiple entities in "Entity with Reporting Responsibility"; is it one or is it all entities report? - In an audit who determines "reasonably determined likely motivation" - Is it justified to expect to have "motivation" knowledge within one hour of an event? - Why are the Responsible Entities reporting Interruptible Demand tripped / lost?
No
There is considerable difference between this form and OE-417 necessitating that two forms be completed. BGE believes that the purpose of combining the standards was to reduce the number of reporting entities and number of reports to be generated by each entity. BGE believes this fails to accomplish this purpose.
Yes
The defined term “impact events” should be capitalized throughout the document to identify it as a defined term. Additionally, BGE has noted in several comments that another term is used instead of “impact events”. These terms

should be eliminated and use "impact events" instead.
Yes
None.
Yes
None.
Yes
One item that is properly addressed is the removal of Load Serving Entity from the Applicable Functional Entities. There may be a need to provide some guidance to Functional Entities when there are separate Transmission Owners and Transmission Operators or Generation Owners and Generation Operators. If they are separate, there may be redundancy in reporting. From the documentation, it doesn't seem like the SDT are combining all reports into one form as we would like to see. In the rational for R1 section, it talks of getting both forms (NERC and OE-417) together in one document (however it sounds like the forms within the document are still separate), available electronically, which only seems like a step forward. However, it does not take away the confusing process for the operators of which part of the form would need to be filled, who should be set this form depending on what part is filled, if one part of the form is filled out do the other parts need to be filled, etc. If the forms cannot be consolidated, BGE would rather the forms be separate to reduce confusion. BGE believes all these reports should require one form with one set of recipients, period. This may mean that NERC needs to get DOE to modify their OE-417 form.
Individual
John Brockhan
CenterPoint Energy
No
CenterPoint Energy does not agree with the purpose statement of the proposed standard. The directive from the Commission in FERC Order 693 and restated in the Guideline and Technical Basis is "...the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: 1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event." Instead the SDT has introduced another term, impact event, to address concerns regarding different definitions. The term, impact event and its proposed concept is too broad. Specifically the concept that an impact event "...has the potential to impact the reliability of the Bulk Electric System" leaves too much room for an entity and a regulatory body to have a difference of opinion as to whether an event should be reported. Required reporting should be limited to actual events. The reporting to follow could become overwhelming for the Responsible Entities, the ERO, and other various organization and agencies. Furthermore, situational awareness is a term that is associated with aspects of real-time. Given the analysis required before a report can be submitted, the report will not be real-time and will not sustain a purpose of supporting situational awareness. (See also comments on Q10 regarding the "Time to Submit Report".) A purpose that is more aligned with consolidation of the EOP-004 and CIP-001 standards would be as follows: Responsible Entities shall report disturbance events and acts of sabotage to support the reliability of the BES through industry awareness.
No
CenterPoint Energy does not agree with the addition of Transmission Owner and Distribution Provider to the Applicability section. Transmission Owner and Distribution provider are not currently applicable entities for either CIP-001 or EOP-004 and should not be included in the proposed combined standard. However, CenterPoint Energy does agree that LSE should be removed from the Applicability section. CenterPoint Energy appreciates the SDT's efforts in assigning entities to each event in Attachment 1. This is an improvement over the existing EOP-004 standard. It is clear, however, that with multiple entities responsible for reporting each event, there is no need to expand the Applicability Section to include Transmission Owner and Distribution Provider.
No
The ERO does not need to establish a "system for receiving reports" as the "system for receiving reports" is inherent given the requirements for reporting. The requirement also seems to add redundancy versus eliminating redundancy in the distribution of reports to applicable government, provincial or law enforcement agencies on matters already reported by Responsible Entities. If an event is suspected to be an intentional criminal act, i.e. "sabotage", the Responsible Entity would have contacted appropriate provincial or law enforcement agencies. The ERO is not in a position to add meaningful value to these reports as any information the ERO may provide is second hand. CenterPoint Energy recommends R1 and M1 be deleted.
No
CenterPoint Energy does not agree with R2 and M2 as they are focused on process and procedure. Compliance with a reporting requirement should be based on a complete and accurate report submitted in a timely manner. The process an entity uses to accomplish that task is of no consequence. CenterPoint Energy recommends R2 and M2 be deleted. However, if the SDT feels it is necessary to include this process based requirement, CenterPoint Energy believes the SDT, in requiring an overly prescriptive Operating Plan, has expanded the requirement beyond the current CIP-001-1 and EOP-004-1 which only require "...procedures for the recognition of and for making operating personnel aware..." (CIP-001-1) and "...shall promptly analyze..." (EOP-004-1). Specifically, R2.2 is not found in the current Standards. "Methods for assessing causes(s) of impact events" would vary greatly depending upon the type and severity of the



event. Responsible Entities would have a difficult time cataloging these various methods to any specific degree and if they are not specific then CenterPoint Energy questions their value in a documented method. R2.3 is not found in the current Standards and is an unnecessary requirement as the method of notification is irrelevant so long as the notification is made. R2.7, R2.8, and R2.9 are also unnecessary expansions beyond what is currently in CIP-001-1 and EOP-004-1. CIP-001-1 requires the Responsible Entity review its procedures annually and CenterPoint Energy believes this is sufficient. When taken in total, R2 requires seven (7) different processes, provisions, and methods. CenterPoint Energy recommends R2.2, R2.3, R2.7, R2.8 and R2.9 be deleted and believes this will not result in a reliability gap.

No

CenterPoint Energy does not agree with R3 and M3 as written as the Company does not agree with the requirement to have an Operating Plan (see comments to Q4 above). However, if R2 and M2 were to be deleted, and R3 was revised to read; "Each Applicable Entity shall identify and assess initial probable cause of events listed in Attachment 1.", CenterPoint Energy could agree with this requirement.

No

CenterPoint Energy does not agree with R4 and M4. See comments to Q4 above. In addition to the process vs. results based issue stated above, CenterPoint Energy believes conducting a drill to verify recognition, analysis, and reporting procedures is a waste of valuable resources and time.

No

CenterPoint Energy believes that R5 and M5 are not necessary and should be deleted. CenterPoint Energy supports an entity training its staff in any reporting responsibilities; however, such training should be the responsibility of each entity and such requirements do not belong in a NERC standard. In addition, CenterPoint Energy believes any necessary training requirements are covered in the PER Standards and therefore the addition of this requirement adds redundancy to the Standards. If a majority of the industry supports such a requirement, CenterPoint Energy cannot support R5 and M5 as written as we do not agree with the requirement to develop and maintain an Operating Plan (see comments to Q4 above). CenterPoint Energy offers the following alternate language: "Each Applicable Entity shall provide training concerning reporting requirements contained in this Standard to internal personnel involved in the recognition or analysis of events listed in Attachment 1.

No

CenterPoint Energy does not agree with R6 and M6 as written as we do not agree with the requirement to develop and maintain an Operating Plan (see comments to Q4 above) In addition CenterPoint Energy does not agree with the timelines required in Attachment 1 (see comments on Q10). CenterPoint Energy offers the following alternate language: "Each Applicable Entity shall report events outlined in Attachment 1 to applicable entities including but not limited to; NERC, and appropriate law enforcement agencies."

No

CenterPoint Energy does not believe this requirement is necessary; however, if the SDT insists on keeping this requirement then CenterPoint Energy believes it should remain as written. Any change to Attachment 1 should go through the Reliability Standards Development Procedure.

No

CenterPoint Energy appreciates the efforts of the SDT in identifying the entity with reporting responsibility. This is an improvement to the event table. CenterPoint Energy is concerned with multiple entities being listed as having Reporting Responsibility. CenterPoint Energy recommends the SDT limit this to one entity having responsibility for reporting each event. This would not preclude that entity from coordinating with other entities to gather data necessary to complete the report. In addition, CenterPoint Energy believes there are several events that should be removed from the list. "Transmission Loss" is covered by the TPL standards and does not need to be identified or reported under EOP-004. The loss of a DC converter station or multiple BES transmission elements may or may not disrupt the reliable operation of the BES, i.e. result in blackout, cascading outages, or voltage collapse. Likewise "Damage or destruction of BES equipment" in and of itself should not be the subject of reporting. If the damage or destruction results in true disruption to the reliable operation of the BES, that impact would be reported under one of the other identified events. "Voltage Deviations" is another unnecessary event. CenterPoint Energy believes a voltage event of the proposed magnitude will, more than likely, result in other events identified in Attachment 1 such as; IROL Violation or Generation Loss and would be reported under one of those triggers. Another concern is the threshold trigger of +/- 10% for 15 minutes or more. CenterPoint Energy is unclear as to the starting point to determine the deviation. In other words is the 10% deviation from nominal voltage, such as 138kV or 345kV, or the actual voltage at the time of the event? Additionally, must the deviation occur over a "wide area" or is such a deviation at one buss enough to trigger a report? Based upon these ambiguities and concerns CenterPoint Energy recommends "Voltage Deviations" be deleted from Attachment 1. The examples that follow on page 14 should also be deleted.

No

CenterPoint Energy does not agree that the term "impact event" adequately replaces "disturbances" and "sabotage". CenterPoint Energy suggests that just as the SDT has come to consensus on a concept for impact event, a definition could be derived for sabotage. "Potential", as used in the SDT's concept, is a vague term and indicates an occurrence that hasn't happened. Required reporting should be limited to actual events. CenterPoint Energy offers the following

definition of "sabotage": "An actual or attempted act that intentionally disrupts the reliable operation of the BES or results in damage to, destruction or misuse of BES facilities that result in large scale customer outages (i.e. 300MW or more)."

Yes

CenterPoint Energy agrees that there is no reliability gap between the existing standards and the proposed standard. However, CenterPoint Energy believes that the SDT went too far in developing the proposed EOP-004-2 and added additional unnecessary requirements. If the comments made above to Q1 – Q12 were to be incorporated into the proposed Standard, CenterPoint Energy believes the product would be closer to a results based Standard with no reliability gap.

Yes

CenterPoint Energy appreciates the efforts of the SDT in removing outdated and unnecessary language from the existing EOP-004 standard. Additionally, CenterPoint Energy urges the SDT to also remove the proposed "how to" prescriptive requirements. CenterPoint Energy believes the SDT team's focus should be on drafting a results-based standard for reporting actual system disturbances and acts of sabotage that disrupt the reliable operation of the BES. The SDT should not delve into trying to identify a list of events that have a potential reliability impact. As stated in response to Q10, CenterPoint Energy strongly believes that cyber-related events should not be in the scope of this standard since they are already required to be identified and reported to appropriate entities under CIP-008. Excluding cyber events from this standard further supports the elimination of redundancies within the body of standards.

Individual

Joylyn Faust

Consumers Energy

No

R 2.7, R 2.8 and R 2.9 are creating a requirement to have procedures to update procedures. Having updated procedures should be the requirement, no more.

No

NERC should either standardize on a 12 month year or an annual year for reviews.

No

Again, either 12 month year or annual year, NERC needs to standardize on one or the other. Training should apply only to those that must take action relevant the reliability of the BES. A plan would likely include notification of senior officers, however they don't need to be included in drills and training if they have no active role.

Individual

Doug White

North Carolina Electric Coops

No

The term "impact event" is not a defined term in the NERC glossary and does not draw a clear boundary or give concise guidance to aid in event recognition.

No

There is a conflict between the ERO being listed as an applicable entity and the fact that the ERO is the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that other applicable entities would be required to meet. Attachment 1 has inconsistent time frames listed for similar events. For example, EEA's are either reported within one or 24 hours depending on the nuance. Also, having more than one entity reporting an EEA can lead to conflicting information for the same event. Attachment 1 has the RC and the BA both reporting the same EEA event. Attachment 1 consolidates time frames from other standards for reporting purposes. There should either be a separate standard for "reporting" that encompasses reporting requirements for all standards or leave the time frames

and reporting requirements in the original individual standards. Several of the events require filing a written formal report within one hour. For large events like cascading outages or system separation, "all hands on deck" attention will need to be given to the actual event. Although a verbal report would be allowed in certain circumstances, attention to the actual event should take precedence over formal reporting requirements. There is already a DOE requirement to report certain events and no need to develop redundant reporting requirements in the NERC arena when this information is already available at the federal level at other agencies.
No
The ERO cannot be subject to a requirement for which it is the compliance enforcement authority.
No
This requirement dictates details of documentation of after-the-fact reporting of events which cannot impact reliability of the BES and, as such, should not be a reliability standard. The cost and burden of becoming auditably compliant with this requirement can be extreme for small entities.
No
The term "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditably compliant procedures and give guidance on what is proper to report.
No
Requiring a drill for "reporting" is unnecessary and burdensome. Reporting is covered in processes and procedures and during the normal training cycle. We recommend the elimination of this requirement.
No
Requiring training to report of after-the-fact events does not improve the reliability of the BES. We recommend the elimination of this requirement.
No
There is already a DOE requirement to report certain events. NERC should not be developing redundant reporting requirements when this information is already available at the federal level from other agencies.
No
The ERO cannot be subject to a requirement for which it is the compliance enforcement authority.
No
This list is too similar and redundant to the DOE requirements and does not provide any additional clarity on recognition of sabotage.
No
There is already a DOE requirement to report certain events. NERC should not be developing redundant reporting requirements when this information is already available at the federal level from other agencies.
Yes
No
Yes
Yes
Keep in mind that redundancy in reporting requirements from the DOE does not improve or enhance bulk electric system reliability but rather creates more work for the reporting entity.
Individual
Lauri Jones
Pacific Gas and Electric Company
No
PG&E recognizes this is an after the fact report, however, the purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. If the future intent is for this report to replace current reporting criteria the purpose statement should be expanded to reflect the true intent of the Standard.
No
PG&E recognizes the ERO is in R1, however, it does not see where the ERO's applicability is applied in Attachment 1.
Yes
No
PG&E would like clarification on whether the 30 days, is calendar days or business days.
Yes

No
PG&E believes the addition of a drill constitutes additional training and should be added to R5. PG&E is concerned as to who the target audience for this annual training would affect.
No
PG&E believes 30 days is too restrictive due to real-time operations schedule requirements. The schedule is six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Suggest extending to 60 days to meet the training criteria which follows the NERC Continuing Education revised submittal date for the Individual Learning Activities (ILA).
No
PG&E believes that if the standard is intended to be an after the fact report, we question the one and/or twenty-four hour reporting criteria and then the 30 day criteria?
Yes
Yes
No
PG&E believes the report is duplicative to the OE-417 reporting criteria.
No
PG&E believes Attachment 1 Part A or B do not clearly specify "sabotage" events, other than "forced entry" and the proposed definition of "impact event" does not meet FERC's directive to "further define sabotage" nor does it take into consideration their request to address the applicability to smaller entities.
Yes
Yes
Yes
PG&E believes as the training requirements continue to expand, having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues.
Individual
Laurie Williams
PNM Resources
No
PNM believes the purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. It is misleading and may have many thinking it is duplicative work.
No
PNM OTS does not see where the ERO's applicability is applied in Attachment 1.
Yes
No
PNM would like clarification on whether the 30 days, is calendar days or business days.
Yes
No
PNM feels the addition of a drill or exercise constitutes additional training and believes R4 should be added to R5. The WECC OTS also is interested as to what level does the annual training target, for instance, the field personnel. Will they have to complete the exercise/drill?
No
PNM believes 30 days is too restrictive due to real-time operations schedule requirements. Most work schedules are either five or six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Based on the NERC Continuing Education revised submittal date for the Individual Learning Activities (ILA), PNM would recommend 60 days. Creating an Impact Event Report is duplicative and redundant and the WECC OTS feels this is not necessary.
No
PNM believes there seems to be redundancy in reporting based on the time frames in Attachment 1, i.e. OE-417 and other required reports. If this standard is intended to be an after the fact report, why is there one/twenty-four hour

reporting criteria?
Yes
Yes
No
PNM believes the report is duplicative to the OE-417 reporting criteria.
No
PNM believes the proposed definition of "impact event" does not meet FERC's directive to "further define sabotage" nor does it take into consideration their request to address the applicability to smaller entities. Attachment 1 Part A or B do not clearly specify "sabotage" events, other than "forced entry".
Yes
Yes
Yes
PNM believes that having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues. This will become even more of an issue as training requirements continue to expand.
Individual
Val Lehner
ATC
Yes
ATC agrees with the purpose statement. However, we do not agree with the implied definition of "impact events" as represented in Attachment 1. (See specific comments about what is included in Attachment 1 for the type of events that qualify as an "impact event".)
No
The Functional Entities identified in Attachment 1 do not align with the current CIP Standard obligations (e.g. Load Serving Entities are not included).
No
ATC does not agree with R1 for three reasons: 1. The ERO cannot be assigned obligations in NERC Standards. The requirements for the ERO should be addressed by a revision to Section 801 of the Rules of Procedure. 2. This is a fill-in-the-blank requirement. The requirement, positioned as R1, does not allow for the obligations to be clearly defined. It refers to R6 which refers to R2 and Attachment 1. A clearer structure to the Standard would be to simply state that the Functional Entities have to meet the reporting obligations documented in Attachment 1 and delete the current R1.
No
The requirement should be rewritten to simply state that the Functional Entities has to meet the reporting obligations documented in Attachment 1. How the Functional Entity meets the obligations documented in Attachment 1 should be determined by the Functional Entity, not the requirement. The prescriptive nature of this requirement does not support the performance-based Standards that the industry and NERC are striving towards. In addition, requirement 2.9 creates an alternate method for NERC to develop Standards outside of the ANSI process. This requirement dictates that Functional Entities are required to incorporate lessons learned from NERC reports into their Plan, which is a requirement of this Standard.
No
ATC believes that this requirement should be deleted and that the SDT should coordinate its goal with the EAWG. We believe that the lessons learned process and identification of root cause is better covered under that process than through the NERC Mandatory Standards.
No
We do not believe that a drill that exercises a written reporting obligation will add additional reliability to the BES.
No
ATC believes it is an inherent obligation of all Functional Entities to train their appropriate staff to meet all applicable NERC Standards. Including a training requirement in some, but not all, Standards implies that the other Standards do not necessitate training. Although this is an important Standard and one that should be included in a Functional Entities' training program, ATC does not believe that this Standard is more important than the other NERC Standards and, therefore, requires a separate training provision
Yes
ATC does agree that applicable entities report on events identified in Attachment 1 (See our comments about

Attachment 1), but we do not agree that applicable entities should be required by this standard to have an Operational Plan. Please see our comments to question 4.
No
ATC feels the ERO obligations should be covered in the Rules of Procedure. We do not agree with the requirements assigned to the ERO, but believe that they should be incorporated into the ERO's Rules of Procedure
No
ATC has several areas of concern regarding Attachment 1. 1. The one hour requirement for reporting will take the Functional Entities' focus off of addressing the immediate reliability issues and instead force the FE to devote valuable resources to filling out forms which will potentially reduce reliability. 2. Part A: a. Provide a definition of "system wide" for the Energy Emergency requiring system-wide voltage reduction. b. Add in the clarity that for Energy Emergency requiring firm load shed pertains to a single event, not cumulative events. c. Insert the word "continuous" for Voltage Deviations. d. Take off the TOP for IROL violations. (We believe that an IROL violation should be reported by the RC and not by the TOP based on the nature of the event. Requiring both the RC and TOP to report will only result in multiple reports for a single event. The RC is in the best position to report on an IROL violation for its RC area.) e. Take off the TO, TOP and add the LSE for Loss of Firm Load. (As a transmission only company ATC does not have contracts with end load users. Because of this the Loss of Firm Load should be the reporting obligations of the entity closes to the end load users which is the BA, DP or LSE. Failure to modify this requirement will cause confusion as to which entity has to report Loss of Firm Load. f. Define a timeframe for Generation Loss g. Multiple should be changed to "4 or more" for Transmission Loss. (ATC is concerned that this would require reporting of events that have little or no industry wide benefits but would take up considerable Registered Entity resources.) h. Provide clarity to and tighten the definition of Damage or destruction of BES equipment. The way it is written now would require over-reporting of all damaged or destroyed equipment due to a non-environmental external cause (e.g. broken insulator). 3. Part B: a. Take off the TO and TOP for Loss of off-site power. (The GOP has the responsibility to acquire off-site power and we believe it is the GOP's sole responsibility to report the Loss of off-site power. Failure to correct this would result in multiple reporting for the same event.) b. Take off RC for Risk to BES equipment. (The RC function does not own BES equipment and we believe it is impossible for them to report on risk to BES equipment if they are not the owner or operator of that equipment. This standard should be required of the entity that owns/operates BES equipment. c. Provide guidance to the phrase "reasonably determine" in footnote. d. Examples provided do not provide a clear obligation for an entity to follow. (Question: How close is the train to the substation? (Inches away from the substation fence, ten feet away from the substation fence or 500 feet away from the substation fence.) In addition, this standard is so open to interpretation that no entity can demonstrate compliance with the action. We believe that the only solution is to delete this reporting requirement. Overall: Multiple Functional Entities impacted by the same event are required to report. No lead entity is identified. This will result in multiple reports of the same event. ATC does not believe that this built-in duplicity enhances reliability?
No
No. NERC does not have the authority to absolve the Functional Entities of the reporting obligations for the DOE Form OE-417. Therefore, there will be duplicate reporting requirements and the one hour timeframes required in Attachment 1 will take valuable resources away from mitigating the event to filling out duplicative paperwork. It is ATC's position that the OE-417 report be used as the main reporting template until NERC and the DOE can develop a single reporting template. Task #14 in the report should be modified to say, "Identify any known protection system misoperation(s)." If this report is to be filed within 24 hrs, there will not be enough time to assess all operations to determine any misoperation. As a case in point, it typically takes at least 24 hrs to receive final lightning data; therefore, not all data is available to make a determination.
Yes
Yes, if ATC's recommended changes are made to Attachment 1 and the Standard.
Yes
ATC agrees with this effort and does not currently see a reliability gap
Yes
Yes, if ATC's recommended changes are made to the Standard. However, if the changes are not supported then ATC recommends that the implantation time be changed to two years. Entities will need time to develop both the plan called for in this standard and to train the personnel identified in the plan.
Yes
ATC believes that it is not evident in this draft that the SDT has worked collaboratively with the Events Analysis working group to leverage their work. ATC believes that NERC must coordinate this project and the EAWG efforts. The EAWG is proposing to modify NERC Rules of Procedure but the SDT is suggesting requirement for the ERO be build within the standard. We believe that the Rules of Procedure is the proper course to take to for identifying NERC obligations, but what is clear is that NERC itself does not seem to have an overall plan for event reporting and analysis. Lastly, ATC would like to see the SDT expand the mapping document to include the work of the EAWG. The industry needs to be presented with a clear picture as to how all these things will work together along with their reporting obligations. The definition of an "impact event" needs to be revised. First, if these events are to include any equipment failure or mis-operation that impacts the BES, the standard is requiring more than is intended based upon the reading of the requirements. PRC-004 already covers the reporting of protection system mis-operations, and if reading this definition

verbatim, it would lead one to conclude that those same mis-operations reported under PRC-004 shall also be reported under EOP-004. The definition should be revised to something like: "An impact event is a system disturbance affecting the Bulk Electric System beyond loss of a single element under normal operating conditions and does not include events normally reported under PRC-004. Such events may be caused by..."

Group

Santee Cooper

Terry L. Blackwell

No

Since this standard is written to report events after-the-fact and not for a System Operator to perform corrective action, we believe the words situational awareness should be removed from the purpose. Situational Awareness is typically used for real-time operations. Also, any events that require reporting should be clearly defined in Attachment 1 and leave no room for interpretation by an entity.

No

Standards cannot be applicable to an ERO because they are the compliance enforcement authority, and the ERO is not a user, owner, or operator of the BES. Since we are reporting events that may affect the BES, why does a DP need to be included as an applicable entity for this standard? If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity. If NERC is going to require a separate reporting of events from DOE, then NERC should look at these events closely to determine if any of the defined events should be eliminated or modified from the current DOE form. (For example: Is shedding 100 MW of firm load really a threat to the BES?) Why does Attachment 1 have multiple entities reporting the same event? An RC should not have to report an EEA if the BA is required to report it. This will lead to conflicting reports for the same event. Attachment 1 is just a consolidation of the time frame from other standards. It appears no review was done for consistency of time frames for similar events.

No

It cannot apply to the ERO.

No

The words "operating plan" should be removed from the requirement. This standard deals exclusively with after-the-fact reporting. This requirement is also overly prescriptive.

No

Does the initial probable cause have to be reported within the timing associated in Attachment 1? Entities may not have enough information that soon to report the initial probable cause. This should be done with events analysis.

No

There is no need to drill for administrative reporting! This requirement should be deleted.

No

The concept of requiring training on reporting of after-the-fact events does not support or enhance bulk electric system reliability. We recommend the elimination of this requirement.

No

If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity

No

Standards cannot be applicable to an ERO because they are the compliance enforcement authority, and the ERO is not a user, owner, or operator of the BES.

No

The SDT should review the list of events closely to determine if the defined events actually impact the BES. (For example: Is shedding 100 MW of firm load really a threat to the BES?)

No

If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity.

No

The term "impact events" needs to be more clearly defined.

No

It is very difficult to assess this question with the standard as currently written.

No

With the proposed training and drill requirements in the current written standard, one year is not enough time.

Yes

We don't believe that entities should be subjected to duplicate reporting to existing DOE requirements. How does redundancy in reporting requirements improve or enhance bulk electric system reliability?

Individual
Martin Bauer
US Bureau of Reclamation
No
The purpose is more closely related to the concept that "Responsible Entities shall document and analyze impact events and their known causes and disseminate the impact event documentation to support situational awareness". Not all impact events are to be reported. The analysis of the impact events is what is needed to achieve a lessons learned.
Yes
The question is focused on a limited area of Attachment A. There other problematic areas of Attachment 1 will be addressed in subsequent comments.
No
This standard should describe the ERO process of event documentation, analysis, and dissemination. Allowing the ERO to develop a event documentation, analysis, and dissemination process, which becomes a requirement on the Entities, must be derived through the Standards Development Process. The requirement, as it is currently worded, allows the ERO to develop standard requirements. If the intent is to only develop a means of collecting, which does not impose a requirement, the wording should state so. Otherwise, if the ERO wants to require that reports are posted to a specific location by the Entity, then it is a requirement and must go through the Standards Development Process. Secondly, there is already a single reporting form identified. It is not clear why the SDT could not accept that form as the reporting tool.
No
R2 does not reconcile with Attachment A or the sub paragraphs. As an example, the requirement 2.6 states "List of organizations to notify ...." All sub paragraphs use the term notify. Notify as used in Attachment A is when a report cannot be provided in the time frame listed in Attachment A. Therefore there is no requirement in this standard for the Operating Plan to have a provision for reporting. The subparagraph 2.8 indicates that the Entity must update it plan based on the lessons learned published by NERC. It would be appropriate to require a review and update of the plan based on the lessons learned.
Yes
This is provided that the report submitted in Attachment A does not include the probable cause. It is highly unlikely that a probable cause may be determined within the reporting timelines.
No
There is no rationale offered on why 15 months was selected. Without a defined basis the time period is arbitrary. It would be appropriate to let the Entity determine and document the time interval. That would allow the time frame to be sensitive to the complexity of the Operating Plan. Some entities are geographically dispersed and a single Operating Plan may be difficult to test at one time or within 15 months. The allowance for real time events or actual use is a good move and may make it easier to define a suitable time frame by the Entity.
No
The measure is vague and redundant. The Entity is required to provide information to be used to "verify content". The information may be used to demonstrate compliance but who will verify the content is adequate and on what basis. Secondly, the measure requires training information be provided twice, once to demonstrate who participated and then to show who was trained. This is all unnecessary and could be remedied by simply stating that "evidence shall demonstrate that all individuals listed in the plan have received training on their role in the plan"
Yes
No
Requirements 7 and 8 are covered in the Section 801. 801. Objectives of the Reliability Assessment and Performance Analysis Program. The objectives of the NERC reliability assessment and performance analysis program are to: (1) conduct, and report the results of, an independent assessment of the overall reliability and adequacy of the interconnected North American bulk power systems, both as existing and as planned; (2) analyze off-normal events on the bulk power system; (3) identify the root causes of events that may be precursors of potentially more serious events; (4) assess past reliability performance for lessons learned; (5) disseminate findings and lessons learned to the electric industry to improve reliability performance; and (6) develop reliability performance benchmarks. The final reliability assessment reports shall be approved by the board for publication to the electric industry and the general public.
No
The Attachment is very vague and without modification creates a Pseudo definition of BES equipment in the example provided. The example now indicates that something is BES equipment if it is "Damaged or destroyed due to a non-environmental external cause". Perhaps the example should be reworded to "BES equipment whose operation effects or causes:" and then adjust each of the line items to clarify what was intended. Next, the Attachment A example redefines reportable levels for Risk to BES Equipment - From a non-environmental physical threat as "Report copper theft from BES equipment only if it degrades the ability of equipment to operate correctly". Who makes that



determination? Not all events will be known within 24 hours. As example, Risk to BES Equipment - From a non-environmental physical threat may not be known until more thorough examination or investigation takes place. Also the reportable level appears to be defined by the Entity. While agree with that, we will end up with the same criticism from FERC when the level is set to "high" in FERC's mind. The reporting times are unrealistic for complicated events. Notification is reasonable but not reporting. Many organizations's have internal processes the reports must be vetted through before they become public and subject to compliance scrutiny.
No
There is already a reporting form for disturbances. The SDT should reconcile this standard with all the other reporting that is being requested and not add more.
No
The two are distinctly different. Disturbances are what happened, sabotage is why. We can easily tell what happened. Determining why it happened (e.g. sabotage) takes time.
No
The two could be combined with no realibility gap based on the concept rather than the proposed standard. As the standard is currently written, there is a reliability gap. Consider that after the fact reporting of a sabotage event (other than criminal acts which may have been witnessed) usually take some time to investigate and analyze.
No
There is a 15 month training requirement. If the standard goes into effect in one year, most entities will not have had an opportunity to develop their new Operating Plans and train their staff. The effective date should recognize Operating Plans need to be revised and then training needs to be implemented. The most aggressive schedule is 18 months. Two years would be more appropriate. The implementation date could recognize the Operating Plan development as one phase and the training as the second.
Yes
The SDT should consider that in reality it would be more streamlined to require immediate notification of an event for situational awareness, and then give adequate time for analysis of the cause. Reports that have an arbitrary rush will be diseased with low quality information and not much value in the long run to the BES. The Attachment A should be constructed around notification of situational awareness. The reporting timeline should be constructed around the different levels severity. The more severe the event, usually the more complicated the event is to analyze. Simple events usually do not have a significant impact.
Individual
Wayne Pourciau
Georgia System Operations Corporation
Yes
No
This standard should not apply to distribution systems or Distribution Providers. It should apply only to the BES.
Yes
Yes it would reduce duplication of effort and should ensure that the various entities and agencies all have consistent information. It should be simpler and quicker to file than what is needed to meet the current standard. However, the system should allow for partial reporting and hierarchical reporting. Entities up the ladder in a reporting hierarchy may fill in additional info (usually from a wider scope of view) than what lower level entities are aware of. It would be better for information to go up a hierarchy than for bits and pieces to go to the ERO from many entities. Terminology may be different in each of the bits and pieces yet the same idea may be intended. The ERO may mistake multiple reports as being different events when they are all related to one event. The system should give an entity the ability to select the entities that should receive the impact event report. If hierarchical reporting is not enabled by the system, then entities should be allowed to work out a reporting hierarchy as a group and entities at lower levels should not be required to report over the NERC system. Some higher level entity would enter the information on the NERC system as coordinated by the entities within a group.
Yes
An entity-developed Operating Plan will allow the flexibility needed to address different entity relationships around the country, e.g., generating companies, cooperatives, munis, large IOUs, small IOUs, RTOs/ISOs, non-independent market area, and so on. However, all applicable entities should not be required to report directly to NERC or the region. The system should allow for partial reporting and hierarchical reporting. Entities within an area should be allowed to coordinate their plans to define reporting procedures within their area. They could have an entity at some wide scope top level that reports to NERC and the region the information collected from multiple narrow scope lower levels within their wide area. If every small lower level entity directly reported to NERC and the Region, it could create situational confusion rather than situation awareness.
Yes
It directly supports the purpose of the standard.
Yes

We agree with R4 with "... at least annually, with no more than 15 months ..." replaced with "... at least once per calendar year, with no more than 15 months ..." as in R5.
Yes
Yes
It directly supports the purpose of the standard.
No
It should not be necessary for the ERO to require itself to do these things. NERC's authority should be sufficient to do these things as part of its mission. With quarterly trending and analysis of threats, vulnerabilities, lessons learned, and recommended actions in R8, R7 (an annual review) should not be necessary. The quarterly activity could include proposing revisions to Attachment 1 if warranted. An alternative would be to perform annual trending and analysis of threats, vulnerabilities, lessons learned, and proposed revisions to Attachment 1 if warranted. Also, the Reliability Standards Development Procedure has been replaced with the Standard Processes Manual.
Yes
We support the concept of Impact Events and listing and describing them in a table. However, we have some concerns. Reporting of impact events should not be applicable to a DP. The timelines outlined in Attachment 1 should be targets to try to meet but it should not be a compliance violation of the reporting requirement if it is not met. Regarding the NOTE before the table, verbal reports and updates should be allowed for other than certain adverse conditions like severe weather as well as adverse conditions. The first priority for all entities should be addressing the effects of the impact event. It may not be possible to assess the damage or the cause of an impact event in the allotted time. All entities should make their best effort to quickly report under any circumstances what they know about the event even if it is not complete. They should be allowed to report up through a hierarchy. The written report should not be issued until adequate information is available. Change "Preliminary Impact Event Report" to "Confidential Impact Event Report." Capitalization throughout this table is inconsistent. Sometimes an event is all capitalized. Sometimes not. It is not in synch with the NERC Glossary. All terms that remain capitalized in the next draft (other than when used as a title or heading) should be defined in the Glossary of Terms Used in NERC Reliability Standards. Examples of inconsistencies: Unplanned Control Center evacuation, Loss of off-site power, Voltage Deviations. -Energy Emergency requiring a public appeal or a system-wide voltage reduction: All The NERC Glossary defines Energy Emergency as a condition when a LSE has exhausted all other options and can no longer provide its customers' expected energy requirements. The events should not be described as an Energy Emergency requiring public appeal or system-wide voltage reductions. If public appeal and system-wide voltage reductions are still an option then all options have not been exhausted, the LSE can still provide its customers' energy requirements, and it is not an Energy Emergency. We suggest using "Energy Emergency Alert" rather than "Energy Emergency." -Energy Emergency requiring firm load shedding: load shedding via automatic UFLS or UVLS would not necessarily be due to an Energy Emergency. Other events could cause frequency or voltage to trigger a load shed. Most likely an entity would be seeing the Energy Emergency coming and would be using manual load shedding. -Forced intrusion and detection of cyber intrusion to critical cyber assets: CIP-008 is not referenced for a forced intrusion. CIP-008 is referenced for a detection of cyber intrusion impact event. Aren't there reportable events per CIP-008 that involve physical intrusion that are not intrusions at a BES facility? -Risk to BES equipment: The threshold states that it is for a non-environmental threat but the examples given are environmental threats. Please clarify.
Yes
We support having one form for reporting however every applicable entity should not be required to fill it out and send it to NERC. See previous comments about hierarchical reporting. The title of the report is "Confidential Impact Event Report." Some suggested modifications: The form could have a blank added to enter the event "description" as described in the first column of Attachment 1. The first seven lines contain information that would most likely be filled out every time. The other lines except line 13 may or may not be applicable every time. It is required (R3) for an entity to access the initial probable cause of all impact events so line 13 will most likely be filled out every time. Please move the probable cause line up to line 7 or 8 (depending on if the event description line is added).
Yes
The new term is much more clear than those two terms. This will improve uncertainty and confusion regarding whether or not something should be reported.
Yes
The new single standard will cover all necessary reporting requirements that are in the current two standards. They are being combined into EOP-004-2 not EOP-004-3.
Yes
Yes
Light years better than the current CIP-001-1 and EOP-004-1! With some changes from this comment period, we should have a clearer set of realistic requirements which could likely pass the ballot. Thanks go out to the drafting team for bringing clarity to this topic. Capitalization throughout this document is inconsistent. It is not in synch with the NERC Glossary. All terms that remain capitalized in the next draft (other than when used as a title or heading) should be

defined in the Glossary of Terms Used in NERC Reliability Standards. Examples of not in synch with the Glossary: Registered Entity, Responsible Entity, Law Enforcement. These are not defined in the Glossary. The requirements that apply to entities should not use the word "analysis." "Assessment" should be used. Analysis is a different process (an ERO process) and is being addressed by another group within NERC (Dave Nevius). This EOP-004 drafting team and the NERC analysis group should closely coordinate such that there are no conflicts and the combined requirements/processes are realistic (mainly regarding timelines).

Individual

Rex Roehl

Indeck Energy Services

No

Suggestion: "Functional Entities identified in Section 4 shall support situational awareness of impact events and their known causes."

No

---ERO should not be included in this or any other standard! FERC can decide whether NERC is doing a good job without having standards requirements to audit to. If NERC needs to be included in a standard, then it should stand alone so that the RSAW for all of the other audits don't need to include those requirements. ---"Loss of off-site power (grid supply)" is important at control centers and other large generators. The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---"Footnote 1. Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability." is ambiguous. Everything in the Standards program can "Affecting BES reliability". The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---"Footnote 2. Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES)." is well intentioned but ambiguous. For example, if I know the motivation is to blow up the plant, then by this footnote, I don't have to report. The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---All terms should be used from or added to the Glossary.

No

This standard is an inappropriate place to define this requirement. NERC needs to be held accountable, but it should be independent of the standard. What if NERC fails to do it by the effective date of the standard, all Registered Entities will violate the standard until NERC is done. The effective date needs to be set based on NERC completing the system defined in R1.

No

R2 needs to state that the Operating Plan needs to only those Attachment 1 events applicable to the Registered Entity. The Operating Plan should contain a list of these events so that the other Requirements can reference the Operating Plan and not Attachment 1 for the list of events. For example a GO/GOP <2,000 MW would not need to address this type of event and it wouldn't be listed in its Operating Plan. It would be unnecessarily cumbersome, to describe events which are not covered within the Operating Plan.

No

R3 should reference the events covered by the Operating Plan, as listed in it, rather than in Attachment 1. If the Plan is deficient, it is a violation of R2 and not every other Requirement that references the Plan.

No

In M4, it is suggested that data from a real event would be evidence. R4 should be satisfied if the Operating Plan is used for a real event within 15 months of the last drill or event.

No

It is wholly unreasonable to re-train everyone for each change to the Operating Plan. Suggestion: Clarify that upon changes to the Operating Plan, the Registered Entity may either require full training, or instead distribute a summary of the change to affected personnel only.

No

---This is the first mention of the time lines in Attachment 1. If they are part of the standard, then they should be incorporated to the Operating Plan in R2 and then need not be mentioned again, only compliance with the plan. ---In M6, the last part, "evidence to support the type of impact event experienced; the date and time of the impact event ; as well as evidence of report submittal that includes date and time" is redundant. All of that should be in the report to NERC. If not, then it's not important to keep.

No

Reviewing Attachment 1 annually is unnecessary. Events don't change much and if they do, a SAR is needed to consider the changes. NERC should not be included in any standard!

No

Loss of off-site power is important to more than just nuclear plants--but which ones? Control centers or other large generators. But not small generators! Should there be a common element to Attachment 1, like the potential to cause a Reportable Disturbance, or maybe there need to be multiple criteria like that.

No
The form needs to identify whether it is a preliminary or final report. An identifier should be created to tie the final to the preliminary one. Some fields, 1,2 3 5 & 6, are required for the preliminary report and should be labeled as such. With the 1 hour reporting deadline for some events, the details may not be known. 12 & 13 should be required for the final report. 13 should designate whether the cause is preliminary or final. 7-11 & 14 are optional, and the form should state this, and based on some types of events. It's confusing to have irrelevant blanks on the form.
No
Impact Events is OK. It needs to be balloted as a definition for the Glossary like Protection System.
No
Bomb threat has totally been lost.
Yes
Good start on a unified event reporting standard!
Individual
Jonathan Appelbaum
United Illuminating
No
UI suggests adding the phrase: and the ERO shall provide quarterly reports; Responsible Entities shall report impact events and their known causes, and the ERO shall provide quarterly reports, to support situational awareness and the reliability of the Bulk Electric System (BES).
Yes
Yes
No
R2.9 requires provisions to update the Operating Plan based on the annual ERO report developed in R8. The ERO report does not appear to be providing lessons learned to be applied to the Operating Plan for impact event reporting, but more focused on trends and threats to the BES. Also 30 days after the report is published by NERC is not enough time for the entity to read, and assess the report, and then to administratively update the Operating Plan. UI agrees that the Operating Plan should be reviewed annually and updated subsequent to the review within 30 days.
Yes
Yes
Suggest R4 be improved to state that a Registered Entity is only required to conduct a drill or execute real-time implementation of the Operating Plan for one impact event listed in the attachment. In other words the Registered Entity is not required to drill on reporting each type of impact event on an annual basis.
Yes
R5.3 coupled with the rationale provided is a sensible approach. It is important that the rationale is not forgotten.
Yes
No
The rules of procedure adequately cover this.
No
UI agrees but the listing needs to be improved for clarity in certain instances. For example, EOP-004 Attachment 1 Part A – Example iii – uses the phrase “significantly affects the reliability margin of the system.” Significantly is an immeasurable concept and does not provide guidance to the Entity. The phrase “reliability margin” is not defined and is open to interpretation. Perhaps utilize “resource adequacy”, if that is all that intended, or use “adequate level of reliability”.
No
The standard does not appear to require the use of Attachment 2. Placing the form within the Standard may require the use of the Standards Development Process to modify the form. UI suggests the form is maintained outside the Standard to allow it to be adjusted. UI would prefer NERC to establish an internet based reporting tool to convey the initial reports.
Yes
The term impact event can substitute for sabotage and disturbance. The use of Forced Intrusion is a bright line for reporting.
Yes

No
UI believes the implementation should be staged. For R1 and R2: First calendar day of the first calendar quarter one year after applicable regulatory authority approval for all. This provides sufficient time to draft a procedure. Then time needs to be provided to provide training prior to implementation of R3 and R6. UI believes two calendar quarters should be provided to complete training; therefore R3 and R6 is effective six calendar quarters following regulatory approval. Implementation for R4 should state that the initial calendar year begins on the date R2 is effective and entities have 12 months following that date to complete their first drill. R5 requires training once per calendar year. Implementation for R5 should state that the initial calendar year begins on the date R2 is effective and entities have 12 months following that date to complete their first drill.
No
Group
Arizona Public Service Company
Jana Van Ness, Director Regulatory Compliance
Yes
No
AZPS recommends excluding 4.1.7 Distribution Providers, as Distribution Providers generally operate at levels below 100kV.
Yes
Yes
AZPS agrees with R2, however, the use of the term "Operating Plan" is confusing. A more accurate term would be "Event Reporting Plan."
Yes
Yes
AZPS agrees with R4, however, the use of the term "Operating Plan" is confusing and leads one to believe an Operating Drill is necessary for a "reporting plan drill." A more accurate term to use would be "Event Reporting Plan."
No
AZPS believes the required training is too restrictive for minor changes/edits to the Event Reporting Plan.
Yes
AZPS believes that Operating Plan should be replaced with "Event Reporting Plan."
No
AZPS believes that the list in Attachment 1 would be complete, as long as the text box of examples is included. The examples demonstrate what is necessary.
Yes
Yes
Yes
Yes
Yes
No
Group
Pacific Northwest Small Public Power Utility Comment Group
Steve Alexanderson
Yes
No
See #15

No
See #15
No
Comments: When applying R3 to row 11 of attachment 1, the comment group notes that applicable entities are expected to assess probable cause of BES equipment damage, including that which may be the result of criminal behavior. At best this would needlessly duplicate the efforts of law enforcement. A more likely result is that entity involvement would interfere with law enforcement and ultimately hinder prosecution of those responsible. Also See #15
No
See #15
No
See #15
No
See #15
No
Footnote 1 is missing from Part A, although it is referenced in column 1 row 11. Is this the Examples? The purpose of the Examples is unclear. Is it meant to limit the scope to those enumerated? This is not stated, but if not it should be removed since it adds confusion. What is meant by non-environmental? All external causes of damage or destruction come from the environment by definition. Please specify what is intended or remove the word.
No
We found no "Preliminary Impact Event Report" in the posted draft standard, so we assume the question is regarding the "Confidential Impact Report" (Attachment 2). It is unclear what role the form plays, since no requirement refers to it. If this is the form to report impact events per R6, then R6 should reference it. The comment group cautions that the use of the word "confidential" should be carefully considered, since many filled out forms that originally contained the word are now posted on the NERC website for all to see. If there are limits to the extent and/or duration of the confidentiality this should be clearly stated in the form, or the word should be avoided. Protection System misoperation reporting is already covered by PRC-004. Including it here is redundant, and doubly jeopardizes an entity for the same event.
No
The comment group fails to see how changing the words meet the directive. Sabotage implies an organized intentional attack that may or may not result in an electrical disturbance. The distinction between sabotage and vandalism is important since sabotage on a small system may be the first wave of an attack on many entities. The proposed standard asks us to treat insulator damage caused by a frustrated hunter (an act of vandalism) the same as attack by an unfriendly foreign government (an act of sabotage). The comment group does not agree that these should be treated equally.
Yes
The proposed standard has a huge impact on small DPs. DPs that presently do not maintain 24/7 dispatch centers will need to begin doing so to meet the reporting deadlines such as 1 hour after an occurrence is identified (possibly identified by a third party) or 24 hour after an occurrence (regardless of when it was discovered by the DP). The planning, assessing, drilling, training, and reporting requirements (R2-R6), as well as documentation (M2-M6) by small entities will cause utility rates to rise, will reduce local level of service, and will not represent a corresponding increase to the reliability of the BES. The SDT concept of clear criteria for reporting has not been met, since R2 effectively directs the applicable entities to develop their own criteria. The decision of which types of events will be reported to which external organizations has been left up to the applicable entity. The comment group notes that there is no coordination of effort required between the applicable entities and the RCs or TOs that issue reliability directives. Energy Emergencies requiring voltage reduction or load shedding are likely to be communicated to applicable entities via directives. The likely result of this lack of coordination is that entities will plan, drill, and train for an event, but when the directive comes it will not be the one planned, drilled, and trained for. Coordination between those sending and receiving directives would ensure the probable events and directed responses are the ones planned, drilled, and trained for.
Group
NERC Staff
Mallory Huggins
Yes
Yes

No
NERC staff is concerned about this requirement's applicability to the ERO. We feel that such a responsibility needs mentioning in the Rules of Procedure, the Compliance Monitoring and Enforcement Program (CMEP), or in a guideline document rather than in a standard requirement. Further, the requirement specifies "how" to manage the event data, not "what" should be monitored.
Yes
Yes
Yes
Yes
Yes
No
NERC staff believes that requirements R7 and R8 are not needed because they are intrinsic expectations from its Rules of Procedure. Furthermore, these elements are necessary for analysis in support of the Reliability Metrics efforts NERC is leading under its Reliability Assessment and Performance Analysis program.
No
The SDT should clarify its use of the term "critical asset" in the Examples section under Part A of the table. The term or versions of the term are used in different contexts in the NERC Reliability Standards. For instance, in CIP-002-1, Requirement 1, the Critical Asset Identification Method is used to identify its critical assets. In EOP-008-0, Requirement 1.3, the applicable entity is required to list its "critical facilities" in its contingency plan for the loss of control center functionality. The team should confirm what it is referring to in this proposed standard. To avoid confusion, the SDT may want to consider using a different term here or better clarify its meaning. Further, there exists the potential to have disparate reporting criteria in this proposed standard relative to the criteria being proposed by the Events Analysis Working Group as part of the Events Analysis Process document dated October 1, 2010. In particular, the following areas should be reconciled between the drafting team and the EAWG to ensure a consistent set of threshold criteria: Voltage Deviations --EOP-004-2: Greater than or equal to 15 minutes --EAWG Process: Greater than or equal to 5 minutes System Separation (Islanding) --EOP-004-2: Greater than or equal to 100 MW --EAWG Process: Greater than or equal to 1000 MWs System Separation (Islanding) --EOP-004-2: Does not address intentional islanding as in the case of Alberta, Florida, New Brunswick --EAWG Process: Addresses intentional islanding as in the case of Alberta, Florida, New Brunswick SPS/RAS --EOP-004-2: Does not expressly address proper SPS/RAS operations or failure, degradation, or misoperation of SPS/RAS --EAWG Process: Expressly addresses proper SPS/RAS operations or failure, degradation, or misoperation of SPS/RAS Transmission Loss --EOP-004-2: Identifies Multiple BES transmission elements --EAWG Process: Provides specificity in Category 1a and 1b regarding transmission events Damage or destruction of BES equipment --EOP-004-2: Through operational error, equipment failure, or external cause but not linked to loss of load --EAWG Process: Identifies in Category 2h equipment failures linked to loss of firm system demands Forced intrusion --EOP-004-2: Addressed --EAWG Process: Not addressed Risk to BES equipment --EOP-004-2: Addressed --EAWG Process: Not addressed Detection of a cyber intrusion to critical cyber assets --EOP-004-2: Addressed --EAWG Process: Not addressed
No
Item 15: A one-line diagram should be attached to assist in the understanding and evaluation of the event. Two additional items are recommended: --Ongoing reliability impacts/system vulnerability – this would capture areas where one is not able to meet operating reserves or is in an overload condition, below voltage limits, etc. in real-time --Reliability impacts with next contingency – this would capture potential impacts as outlined above with the next contingency.
No
NERC staff is concerned with the ambiguity of the term "impact event." The definition of the term is not clear, in part because it includes using the words "impact" and "event" (and thus violates the frowned-up practice of using a word to define the word itself). NERC staff recommends the SDT consider using the term "Event." The following definition (modified from the one used the INPO Human Performance Fundamentals Desk Reference, P. 11) would apply: Event: "An unwanted, undesirable change in the state of plants, systems or components that leads to undesirable consequences to the safe and reliable operation of the Bulk Electric System." Supporting statement following the definition: "An event is often driven by deficiencies in barriers and defenses, latent organizational weaknesses and conditions, errors in human performance and factors, and equipment design or maintenance issues." Further, if this is intended for use in this standard, it should be presented as an addition to Glossary to avoid confusion with the use of the term event in other standards. Of course, this would require an analysis of how the term "Event" as defined herein would affect the other standards to which the term is used. In the end, this is the cleanest manner for the standards.

Yes
No
In order to provide explicit dates, the language should be modified to state: "First calendar day of the first calendar quarter one year after the date of the order providing applicable regulatory authority approval for all requirements."
Yes
NERC staff commends the SDT on its work so far. Merging CIP-001 and EOP-004 is a significant improvement and eliminates some current redundancies for reporting events. NERC staff believes opportunities to improve the proposed standard still exist. In particular, the team should consider possible redundancies with the Reliability Coordinator Working Group (RCWG) reporting guidelines, the Electricity Sector - Information Sharing and Analysis Center (ES-ISAC) reporting requirements for sharing information across sectors, and the Events Analysis Working Group (EAWG) efforts to develop event reporting processes. Ideally, the SDT and the EAWG should work together to develop a single consistent set of reporting criteria that can be utilized in both the EAWG event reporting process and in the requirements of the EOP-004-2 Reliability Standard.
Group
MRO's NERC Standards Review Subcommittee
Carol Gerou
Yes
Thank you for the clarification of "known causes", this will allow entities to report what they currently know when submitting an impact report.
Yes
The NSRS believes it is important for the ERO to provide valuable Lessons learned to our electrical industry, thus enhancing the reliability of the BES.
Yes
No
A. As detailed in R2, the Operating Plan shall contain provisions for "identifying, assessing, and reporting impact events". R2.8, and R2.9 do not have a correlation to R2's Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change. The NSRS believes the components of this Operating Plan are only 1) identifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in the components of an entity's Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the words "lessons learned" would be required to be in your Operating Plan. It is solely up to an entity to implement a "Lesson Learned" and not the place for this SDT to require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. B. In R2.8 & R2.9, It may be difficult to implement lessons learned within 30 days. The NSRS recommends to incorporate lessons learned within 12 calendar months if lesson learned are not deleted from the R2.8 & R2.9.
Yes
The NSRS thanks the SDT for stating "initial probable cause" as this is in direct correlation to the Purpose which states "known causes".
Yes
The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be exercised once per calendar year.
No
R5.2. The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be trained once per calendar year. R5.3 As detailed in R2, the Operating Plan shall contain provisions for "identifying, assessing, and reporting impact events". Where, R2.7 states to update the Operating Plan when there is a component change. The NSRS believes the components of this Operating Plan are 1) identifying impact events, 2) assessing impact events, and 3) reporting impact events. These components relate to training when the Operating Plan is revised per, R5.3, only. As written, every memo, simulations, blog, etc that contain the words "lessons learned" would be required to be in your Operating Plan and trained on every time one was issued or heard about internally or externally. Recommend that the Operating Plan be revised and training occurs when a change occurs to the entity's Operating Plan, consisting of 1) identifying impact events, 2) assessing impact events, and 3) reporting impact events, only.
Yes
Yes
Should read "In accordance with Sections 401(2) and 405 of the Rules of Procedures, the ERO can be set as an applicable entity in a requirement or standard". As stated in the text box.
No



Please provide a phone number and provision within the Note of EOP-004 – Attachment 1: Impact Events table for an entity to contact NERC if unable to contact NERC within the time described. Voltage Deviations – recommend adding the word “(continuous)” after sustained in Threshold column. This could be interpreted as an aggregate value over any length of time. Frequency deviations - recommend adding the word “(continuous)” after 15 minutes’ in Threshold column. This could be interpreted as an aggregate value over any length of time. CIP-008 R1.3 states the entity is to report Cyber Security Incidents to the ES\_ISAC. Does the EOP-004 Attachment 2 fulfill this requirement?

No

Number 4 of the reporting form does not take into consideration of potential impact events. Recommend that “Did the impact event originate in your system?” to “Did the impact event originate or affect your system?”. This will provide clarity to entities.

Yes

As an industry we have looked at sabotage as a sub component of a disturbance. Sabotage is hard to measure since it is based on a perpetrator’s intent and thus very hard to determine.

Yes

Within the above question, the SDT is asking about EOP-004-2 not -3.

Yes

Yes

Please provide an e-mail address for the submittal of the report to NERC (and any other parties above a Regional Entity) within this Standard and a fax number as a backup to electronic submittal. EOP-004 Attachment 2: Impact Event Reporting Form (note in the proposed standards it states EOP-002) seems to be written for Actual Impact Events only. Perhaps another section could be added for “Potential” Impact Events.

Individual

Amir Y Hammad

Constellation Power Generation and Constellation Commodities Group

Yes

No

Constellation Power Generation and Constellation Commodities Group disagrees with the inclusion of Generator Owners. Since one of the goals in revising this standard is to streamline impact event reporting obligations, Generator Operators are the appropriate entity to manage event reporting as the entity most aware of events should they arise. At times, the information required to complete a report may warrant input from entities connected to generation, but the operator remains the best entity to fulfill the reporting obligation.

Yes

No

Constellation Power Generation and Constellation Commodities Group has several issues with this requirement, but in general, this requirement is heavily prescriptive, administrative in nature, and is unclear whether it will positively impact BES reliability. As examples of administrative requirements that have no impact on reliability, please consider the following comments: •Listing personnel in R2.4, - merely having a list of personnel does not add to the sufficiency of an Operating Plan, but it does create a burdensome obligation to maintain a list. As well, specifying “personnel” may limit plans from designating job titles or other designations that may more appropriately and consistently carry reporting responsibility in the Operating Plan. •R2.5 is unclear as to the intent of the requirement – what is threshold of notification? Is the list to be those that have a role in the event response or a list of all within the facility who may receive news notification of the event? Also, as explained above for 2.4, a list is not a beneficial to reliability, but is administratively burdensome. •What is the reasoning for the 30 day timeframe in R2.7 R2.8 and R2.9? The timeframe is not based on a specific necessity, and creates an unreasonable time frame for changing the Operating Plan, in particular if lessons learned are either short turn adjustments or comprehensive programmatic changes that warrant more time to properly institute. In addition, coupled with other requirements (R4, R5, R8), the updating requirements of R2.7, R2.8 and R2.8 potentially create a continually updating Operating Plan which could create enough confusion to reduce the effectiveness of the Operating Plan. The updating and time frame requirements do not impact reliability, but again impose significant administrative burden and compliance exposure. •R2.9 is particularly problematic for its connection to R8. R8 requires NERC to create quarterly reports with lessons learned and R2.9 requires the registered entities to amend their Operating Plans? What if NERC doesn’t write an annual or quarterly report? Are the registered entities out of compliance? The “summary of concepts” for this latest revision, as written by the SDT, includes the following items: •A single form to report disturbances and impact events that threaten the reliability of the bulk electric system •Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements •Clear criteria for reporting •Consistent reporting timelines •Clarity around of who will receive the information and how it will be used Many of the sub-requirements in R2 do not address any of these items and do not serve to establish a high quality, enforceable and reliability focused standard. Constellation Power Generation therefore

recommends that R2 be amended to read as follows: R2. Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 2.1. Method(s) for identifying impact events listed in Attachment 1 2.2. Method(s) for assessing cause(s) of impact events listed in Attachment 1 2.3. Method(s) for making internal and external notifications should an impact event listed in Attachment 1 occur. 2.4. Method(s) for updating the Operating Plan. 2.5 Method(s) for making operation personnel aware of changes to the Operating Plan.

No

This requirement introduces double jeopardy for registered entities. If an entity does not include methods for identifying impact events and for assessing cause per R2.1 and R2.2 in their Operating Plan, they will be out of compliance with R2. Without the methods in R2 the registered entity is out of compliance with R3 as well for failing to identify and assess. Constellation Power Generation therefore recommends that R3 be amended to be incremental to R2 and read as follows: R3. Each Applicable Entity shall implement their Operating Plan(s) to identify and assess cause of impact events listed in Attachment 1.

No

It is not clear how this requirement to conduct drills and exercises relates to the concepts spelled out by the SDT: oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements oClear criteria for reporting oConsistent reporting timelines oClarity around of who will receive the information and how it will be used R4 does not address any of the above items and should therefore be removed from this standard.

No

Constellation Power Generation questions how R5 relates to the SDT's "summary of concepts": oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements oClear criteria for reporting oConsistent reporting timelines oClarity around of who will receive the information and how it will be used However, Constellation Power Generation believes that security awareness is an important aspect of personnel security and proposes an annual training similar to what was in the previous standards. Constellation Power Generation therefore recommends two requirement changes that would achieve security awareness without the burdensome administrative aspects. First, as stated earlier, a sub requirement in R2 should be added which reads as follows: R2.5 Method(s) for making operation personnel aware of changes to the Operating Plan. Second, this training requirement should be rewritten as follows: Each Applicable Entity shall provide training to all operation personnel at least annually.

Yes

No

The impact event table (Attachment #1), as part of a standard, would have to be FERC approved every time it is edited. That would cause it to go through NERC's Standard Development Process, and would cause a revision to the standard each time. This will also cause revisions to each and every registered entity's Operating Plan. Overall, this requirement causes a large administrative burden on all entities, and does not improve reliability. As stated earlier, the "summary of concepts" for this latest revision, as written by the SDT, includes the following items: oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements oClear criteria for reporting oConsistent reporting timelines oClarity around of who will receive the information and how it will be used Requirement 7 and 8 do not address any of these items. Furthermore, for R8, it is requiring NERC to send out quarterly reports, yet entities are supposed to amend their Operating Plans based on an annual NERC report. This requirement is confusing and is not consistent with earlier requirements. Constellation Power Generation believes that these two requirements should be removed.

No

Constellation Power Generation and Constellation Commodities Group questions why the generation loss line item includes generating facilities of 5 or more generators with an aggregate of 500 MW or greater? The number of units makes no difference for reporting, as is evident in the generation thresholds written before this inclusion. The examples of damaged or destroyed BES equipment are confusing, and do not clarify the reporting event. What if a GSU at a small plant (20 MW) were to fail? Is that reportable? Constellation Power Generation believes that equipment failures that are not suspicious do not need to be reported. Finally, Constellation Power Generation and Constellation Commodities Group believes that the "loss of offsite power affecting a nuclear generation station" should be removed for the following reasons: 1)The purpose of this reliability standard is stated as being: "Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES). " While the "situational awareness" portion of the purpose could be interpreted as all-inclusive, the real element deals with BES reliability. Off-site power sources to nuclear units have nothing to do with BES reliability. Why should nuclear units be treated differently? 2)The issue of concern for a loss of offsite power at a nuclear station is continued power supply (other than emergency diesels) to power equipment to cool the reactor core. A nuclear unit automatically shuts down when off-site power supply is lost. Availability of off-site power is a reactor safety concern (i.e., NRC

regulatory concern and a one-hour report to the NRC) – not a reliability concern that FERC/NERC would have jurisdiction over. 3)There is a nuclear-specific reliability standard (NUC-001) that contemplated off-site power availability. That standard contained no reporting requirements outside of those that may be already established in current procedures. Why try to impose one here? 4)A loss of offsite power will result in an emergency declaration at the nuclear facility. Notifications will be made to federal (NRC), state, and local authorities. The control room crew is already overly-burdened with notifications – any additional call to NERC/Regional Reliability orgs will add insult-to-injury for no beneficial reason. If NERC is interested, they should obtain info from NRC. 5)If all else fails and the item is to remain on the table, it needs to be clarified as a “complete” loss of off-site power lasting greater than X minutes (i.e., would we have to report a complete momentary loss that was rectified in short order by an auto-reclose or quick operator action?).

No

It is unclear if an entity has to answer all the questions. In addition, “Preliminary” is not currently included in the report title.

Yes

Yes

No

Based on the drastic differences between the previous revisions to these standards, and this proposed revision, 24 months would be a more reasonable timeframe for an effective date.

Yes

As stated earlier, the “summary of concepts” for this latest revision, as written by the SDT, includes the following items:  
oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system  
oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements  
oClear criteria for reporting  
oConsistent reporting timelines  
oClarity around of who will receive the information and how it will be used  
Each and every requirement should be mapped to one of these 5 items; otherwise, it should not be included in this standard. Summarizing all of the comments above, Constellation Power Generation proposes the following revision to EOP-004-2: 1. Title: Impact Event and Disturbance Assessment, Analysis, and Reporting 2. Number: EOP-004-2 3. Purpose: Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES). 4. Applicability 4.1. Functional Entities: 4.1.1. Reliability Coordinator 4.1.2. Balancing Authority 4.1.3. Transmission Operator 4.1.4. Generator Operator 4.1.5. Distribution Provider 4.1.6. Electric Reliability Organization Requirements and Measures R1. The ERO shall establish, maintain and utilize a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness. R2. Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 2.1. Method(s) for identifying impact events listed in Attachment 2.2. Method(s) for assessing cause(s) of impact events listed in Attachment 1 2.3. Method(s) for making internal and external notifications should an impact event listed in Attachment 1 occur. 2.4. Method(s) for updating the Operating Plan. 2.5 Method(s) for making operation personnel aware of changes to the Operating Plan. R3. Each Applicable Entity shall implement their Operating Plan(s) to identify and assess cause of impact events listed in Attachment 1. R4. Each Applicable Entity shall provide training to all operation personnel at least annually. R5. Each Applicable Entity shall report impact events in accordance with its Operating Plan created pursuant to Requirement 2 and the timelines outlined in Attachment 1.

Group

FirstEnergy

Sam Ciccone

No

Since this standard is after-the-fact reporting, the phrase "situational awareness" may not be appropriate since that phrase is attributed by a large part of the industry to real-time, minute-to-minute awareness of the system. We suggest the following rewording of the purpose statement: "To ensure Applicable Entities report impact events and their known causes to enhance and support the reliability of the Bulk Electric System (BES)".

No

We do not support the ERO as an applicable entity of a reliability standard because they are not a user, owner or operator of the bulk electric system. Any expectation of the ERO should be defined in the Rules of Procedure.

No

FirstEnergy proposes that requirement R1 and Measure M1 be deleted. A requirement assignment to the ERO is problematic and should not appear in a reliability standard. The team should keep in mind that all requirements will require VSL assignments that form the basis of sanctions. FE does not believe it is appropriate for the ERO to be exposed to a compliance violation investigation as the ERO is not a functional entity as envisioned by the Functional Model. If this "after-the-fact" reporting is truly needed for reliability then the standard must be written in a manner that does not obligate the ERO to reliability requirements. It would be acceptable and appropriate for a requirement to

reference the "ERO Process" desired by R1, however, that process should be reflected in the Rules of Procedure and not a reliability standard.
No
The term Operating Plan(s) is not the appropriate term for this standard. These should be called Reporting Plan(s). Operating Plans are usually designed to be applied during the operating timeframe. Parts 2.2 and 2.6 – We suggest changes to these two subparts as well as a new 2.2.1 and 2.6.1 as follows: 2.2. Method(s) for assessing the initial probable cause(s) of impact events (Add) 2.2.1. Method(s) for assessing the external organizations to be notified. 2.6. List of external organizations to notify in accordance with Part 2.2.1. to include but not limited to NERC, Regional Entity, and Governmental Agencies. (Add) 2.6.1. Method(s) for notifying Law Enforcement as determined by Part 2.2.1. Parts 2.4 and 2.6: This should be a list of job titles for ease of maintenance. An entity may choose to use someone in a job position that is a 24 by 7 operation with several personnel that cover that position over the 24 by 7 period. Listing each person by name should not be required as personnel change while the operating responsibility related to the job title can remain constant. We suggest changing the wording to "2.4. List of the job titles of internal company personnel responsible for making initial notification(s) in accordance with Parts 2.5.and 2.6. 2.5. List of the job titles of internal company personnel to notify." Part 2.6 – We are under the impression that the phrase "include but not limited to" should not be used according to the NEW SDT guidelines. We suggest changing this to say "List of external organizations to notify that includes at a minimum, NERC, Regional Entity, and Governmental Agencies. (A provincial agency is a governmental agency)." Part 2.7. is overly burdensome. FE suggests the team revise to simply reflect annual updates that should consider component changes and updates from lessons learned. This also permits parts 2.8 and 2.9 to be deleted. FE proposes the following text for Requirement R2.7 "Annual review, not to exceed 15 months between reviews, and update as needed of the Reporting Plan that considers component changes and continuous improvement changes from lessons learned." Parts 2.8 and 2.9 - FE proposes to delete part 2.8 and 2.9. We do not see a need for these changes since the plan must be updated annually and will cover lessons learned.
No
M3 – Power flow analysis would be used to assess the impact of the event on the BES, not to determine initial probable cause. It is more likely that DME would provide the data for the initial probable cause evaluation. We suggest rewording M3 as follows: "To the extent that an Applicable Entity has an impact event on its Facilities, the Applicable Entity shall provide documentation of its assessment or analysis. Such evidence could include, but is not limited to, operator logs, voice recordings, or disturbance monitoring equipment reports. (R3)"
No
FE suggests that this requirement be deleted. FE does not see a reliability need for conducting a drill on reporting. This is overly burdensome and should not be included within this reliability standard. Training on the plan and periodic reminder of reporting obligations should suffice.
No
Requirement R5 and Part 5.1 – The wording in Part 5.1 is too prescriptive and shouldnot require training on the specific actions of personnel. Also, R5 should not require training for personnel that may only receive the report and are not required to do anything. Therefore we suggest rewording R5 and 5.1 as follows: "R5. Each Applicable Entity identified in Attachment 1 shall have a Reporting Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 5.1 The training includes the personnel required to respond under the Reporting Plan." Part 5.3 – We suggest removing subpart 5.3. This requirement is overly burdensome and not necessary. We believe that the requirements for annual review and update of the plan as well as training sufficiently cover reviews of changes to the plan. Part 5.4 – The last phrase "training shall be conducted prior to assuming the responsibilities in the plan" should account for emergency situations when the entity does not have time to train the replacement before they are to assume a responsibility.
No
M6 – NERC's system should be capable of making this evidence available for the entities and provide a "return-receipt" of the reports that we send them. Also, M6 should be revised to state "Applicable Entities" as opposed to "Registered Entities".
No
FE disagrees with the ERO as an applicable entity within a reliability standard. See our responses to Questions 2 and 3 above. We do not believe the desired ERO process is adequately covered in section 802. Section 802 deals with assessments and not event reporting.
No
1. The table in Att. 1 and the requirements should alleviate the potential for duplicate reporting. For example, If the RC submits a report regarding a Voltage deviation in its footprint, the report should be submitted by the RC on behalf of the RC, TOP, and GOP, and not require the TOP and GOP to submit duplicate reports. 2. Regarding the "Note" before the table – We agree that under certain conditions it is not possible to issue a written report in a given time period. However, the ERO and RE should also be required to confirm receipt of the verbal communication in writing to prove that the entity communicated the event as these verbal notifications may be done by an entity using an unrecorded line. 3. Organizations with many registered entities should be permitted to submit one report to cover multiple entities under one parent company name. We suggest this be made clear in the Tables, the reporting form, and in the requirements. 4. Voltage Deviations Event – We suggest the team provide more clarity with regard to the types and locations of

voltage deviations that constitute an event. 5. Examples of BES Equipment in Part A of "Actual Reliability Impact" Table – Is the phrase "critical asset" referring to the CIP defined term? If so, this should be capitalized. 6. Under the "Time to Submit Report" column of the table, we suggest that all of the phrases end in "after identification of the occurrence". 7. Frequency Trigger Limit (FTL) for the Frequency Deviation event should be replaced with the values the FTL represent. The FTL is part of the BAAL Standards which have not been approved by the industry and are not in effect. It is possible that these terms are not used by those not participating in the field trial of the BAAL standards.

Yes

Although we agree with the report, it should be clear that organizations with many registered entities can submit one report to cover multiple entities under one parent company.

No

For the most part we support this definition of impact events. However, we have the following suggestions: 1. We believe that it warrants an official NERC glossary definition. 2. The term "potential" in the definition should point to the specific events detailed in Attachment 1 Part B. 3. Since the standard does not cover environmental events, the phrase "environmental conditions" in the definition is not an impact event in the context of this standard.

Yes

Yes

No

Individual

Carol Bowman

City of Austin dba Austin Energy

Yes

Yes

Yes

Austin Energy would like to see OE-417 incorporated into the electronic form This will reduce the callout of EOP-004-2 and OE-417 forms in our checklists / documents and one form can be submitted to NERC and DOE.

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Austin Energy would like to see OE-417 incorporated into the electronic form This will reduce the callout of EOP-004-2 and OE-417 forms in our checklists / documents and one form can be submitted to NERC and DOE.

Yes

Yes

If we can use OE 417 for NERC and DOE we do not perceive a reliability gap.

Group

Electric Market Policy

Mike Garton

No
The term "impact events" does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. As conveyed in Dominion's comments on NERC Reliability Standards Development Plan 2011 – 2013, Dominion does not see this draft standard as needing to be in the queue while other standards having more impact to bulk electric reliability remain incomplete or unfinished.
No
Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. Attachment 1 is troublesome. The time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, we believe this subject is more complex than this table reveals and the table needs more clarification. Several of the events require filing a written formal report within one hour. For example, system separation certainly is going to require an "all hands on deck" response to the actual event. We note that the paragraph above the table in attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
No
Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of "applicable government, provincial or law enforcement agencies" for distribution as defined in R1. The "rationale for R1" states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. It seems like the better approach would be for the entities to complete OE-417 form and this standard simply require a copy.
No
This is an overly prescriptive requirement given the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan lacks continuity with the ERO Event Analysis Process that is currently slated to begin industry field testing on October 25, 2010. Suggest the SDT coordinate EOP-004-2 efforts with this process. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate and how will duplicative reporting be addressed (for example, DOE, Nuclear Regulatory Commission)? Also, in the "rationale for R2", please explain the reference to Parts 3.3 and 3.4.
No
We think "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build audit ready compliant procedures.
No
The need for a periodic drill has not been established and appears to be overly restrictive given the intent of the standard is reporting of impact events. Suggest this requirement be eliminated.
No
The need for a periodic training has not been established and appears to be overly restrictive given the intent of the standard is reporting of impact events. Suggest this requirement be eliminated.
No
Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
No
Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority.
No
1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would appear to overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity

at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004.
No
There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Yes
The use of the term "impact events" has simply replaced the terms "disturbance" and "sabotage" and has not further defined sabotage as directed by FERC. We do feel that impact events needs to be a defined term.
No
Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity.
Yes
No
Individual
John Bee
Exelon
No
The purpose states that Responsible Entities SHALL report impact events – this implies that ALL impact events need to be reported regardless of magnitude, suggest rewording to say "... shall report applicable impact events ..." to allow for evaluation of each impact for applicability in accordance with Attachment 1).
No
Attachment 1, Part B, footnote 1. A GO is unlikely to know if a fuel supply problem would cause a reliability concern because one GO may not know the demand for an entire region. Attachment 1, Part B, footnote 1. What is the definition of an "emergency" related to problems with a fuel supply chain? What time threshold of projected need would constitute a 1 hour report? Attachment 1, Part A – Voltage Deviations - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 minutes, this should be a TOP RC function only. Attachment 1, Part A – Generation Loss of ≥ 2, 000 MW for a GO/GOP does not provide a time threshold. If the 2, 000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? Attachment 1, Part A – Damage or destruction of BES equipment • The event criteria is ambiguous and does not provide clear guidance; specifically, the note needs to provide more explicit criteria related to parts (iii) and (iv) to remove the need for interpretation especially since this is a 1 hour reportable occurrence. In addition, determination of the aggregate impact of damage may not be immediately understood – does the 1 hour report time clock start on initiation of event or following confirmation of event? • The initiating event needs to explicitly state that it is a physical and not cyber. Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security – Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard. • If the damage or destruction is related to a deliberate act, consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event. Attachment 1, Part B – Loss of off-site power (grid supply) affecting a nuclear generating station – this event classification should be removed from EOP-004. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design and may not result in a loss of generation (i.e., unit trip); furthermore, if a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). The 1 hour notification in EOP-004 on a loss of off-site power (grid supply) to a nuclear generating station should be commensurate with other federal required notifications. Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential transient on the unit. Attachment 1, Part B – Forced intrusion at a BES facility – Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event. Attachment 1, Part B – Risk to BES equipment from a non-environmental physical threat – this event leaves the interpretation of what constitutes a "risk" with the reporting entity. Need more specific criteria for this event. Attachment 1, Part B – Detection of a cyber intrusion to critical cyber assets - Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security – Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard.
No
This requirement should include explicit communications to the NRC (if applicable) of any reports including a nuclear

generating unit as a jurisdictional agency to ensure notifications to other external agencies are coordinated with the NRC. Depending on the event, a nuclear generator operator (NRC licensee) has specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(2)(xi). In general, the DSR SDT should include discussions with the NRC to ensure communications are coordinated or consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator for consistency.

No

R.2.4 and 2.5 - should not be required to have a list of internal personnel. If an entity has an Operating Plan that covers internal and external notifications that should be sufficient. R2.2.7, 2.8, 2.9 – R4 requires an annual drill. Updating the plan if required following an annual drill should be sufficient Why does an entity need to develop a stand alone Operating Plan if there is an existing process to address identification, assessing and reporting certain events? 30 day implementation for a component change or lesson learned does not seem reasonable or commensurate with the potential impact to the BES and should not be a required element of EOP-004. What is the communication protocol for lessons learned outside of the annual NERC report? What process will be followed and who will review, evaluate, and disseminate lessons learned that warrant updating the Operating Plan?

No

: Agree that Each Applicable Entity shall identify and assess initial probable cause of impact events; disagree with aspects and time requirements in Attachment 1.

No

If drills remain as a component of the standard, an effort to consolidate updating an entities plan with a requirement to drill the plan should be made. . Each entity/utility should be able to dictate/determine if they need a drill for a particular event. Is this document implying a drill for every type of event?

No

Exelon doesn't feel that the 30 day requirement is achievable and recommends an annual review. Training for all participants in a plan should not be required. Many organizations have dozens if not hundreds of procedures that a particular individual must use in the performance of various tasks and roles. Checking a box which states someone read a procedure does not add any value, it is an administrative burden with no contribution to reliability. It is Exelon's opinion that training requirements should be covered in the PER standards and that the audience to be trained should be identified. R5.4 requires internal personnel that have responsibilities related to the Operating Plan cannot assume the responsibilities unless they have completed training. This requirement places an unnecessary burden on the registered entities to track and maintain a data base of all personnel trained and should not be a requirement for job function. A current procedure and/or operating plan that addresses each threshold for reporting should provide adequate assurance that the notifications will be made per an individual's core job responsibilities.

No

The time durations in the attachment are too short, it would be impossible to collect all the data necessary to report out on an impact event in the defined time to report. The SDT should evaluate each event for the most appropriate entity responsible to ensure there is minimal confusion on who has the responsibility and eliminate duplication of reporting when feasible.

No

The listed Impact Events is lacking specific physical security related events. . In general, all impact events need to be as explicit as possible in threshold criteria to eliminate any interpretation on the part of a reporting entity. Ambiguity in what constitutes an "impact event" and what the definition of "occurrence" is will ultimately lead to confusion and differing interpretations.

No

Exelon agrees with the use of the report but feels that # 5 should consist of check boxes. #12, 13, and 14 will take more time then allotted by the reporting requirements to acquire, cannot be accomplished in an hour. Attachment 2 should have a provision for the reporting entity to enter (N/A) based on function (see below) Check box #8 A GO/GOP may not have the information to determine what the frequency was prior to or immediately after an impact event. This information should be the responsibility of a TOP or RC. Check box #9 A GO/GOP may not have the information to determine what transmission facilities tripped and locked out. This information should be the responsibility of a TO, TOP or RC. Check box #10 A GO/GOP may not have the information to determine the number of affected customers or the demand lost (MW-Minutes). This information should be the responsibility of a TO, TOP, or RC.

No

Need to better define sabotage and provide examples, the term "impact events" create confusions as to what constitutes an event. The definition of impact event is vague and needs to be quantified or qualified with a term such as "significant". Otherwise, almost any event could be deemed to be an impact event. Attachment 1 needs to clearly define that damage or destruction of BES equipment does not include cyber sabotage. Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security – Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard. In general, all impact events need to be as explicit as possible in threshold criteria to eliminate any interpretation on the part of a reporting entity.



Ambiguity in what constitutes an "impact event" and what the definition of "occurrence" is will ultimately lead to confusion and differing interpretations.
No
Reporting form doesn't allow for investigations which result in no impact events found or identified.
Yes
Agree with the proposed implementation date. A 12 month implementation will provide adequate time to generate, implement and provide any necessary training by a registered entity.
Yes
The standard is lacking guidance for DOE Form OE-417 reporting as outlined in the current version of EOP-004 and doesn't contain any non-BES related reporting. What is the governing process for OE-417 reporting?. Need clarification if one entity can respond on behalf to all entities in one company. Need a provision for entities to provide one report for all entities. Radiological sabotage is a defined term within the NRC glossary of terms. It would seem that a deliberate act directed towards a plant would also constitute an "impact event." In general, the DSR SDT should include discussions with the NRC to ensure communications are coordinated or consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator for consistency. The definition of sabotage is defined by NRC is as follows: Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.
Individual
Kirit Shah
Ameren
No
The purpose talks about reporting impact events and their known causes. We have no problem with this generic intent, but the purpose says nothing about the very burdensome expectation of verbal updates to NERC and Regional Entities (Attachment 1, top of first page), Preliminary Impact Event Reports (Attachment 1, top of first page, are these Attachment 2?), "Actual" Impact Event Reports (Attachment 1 - Part A) and "Potential" Impact Event Reports (Attachment 1 - Part B). These multiple levels of reporting and events need to be greatly reduced.
Yes
Yes
No
While we agree with the intent to list certain minimum requirements for the Operating Plan, the draft list is too lengthy and prescriptive. This merely creates opportunities for failure to comply rather than the real purpose of reporting data that can be used to meaningfully increase the reliability of the BES by identifying trends of events that may otherwise be ignored.
No
There are too many missing details on how this will be accomplished. As stated before, this Draft requires too much time be invested in verbal reports, "Preliminary" reports, "Final" reports and even "Confidential" reports (Attachment 2). If the goal is to report ASAP details on events which could impact BES reliability, all of these reports will need to be made at the worst possible time - when Operators are trying to collect data, analyze what they find and correct major problems on the system. And if the reports are wrong or not issued fast enough, the Operators will be keenly aware of potential fines and violations.
No
Establishing a program with trigger actions expected to require reporting several times a year, combined with adequate initial, and on-going, training should preclude the need for mandatory drills as an added compliance burden.
Yes
Yes
No
NERC's current heavy case load should justify reviewing the impact review table only once every 2 years.
No
We have numerous comments about the Attachments. (1) What are the requirements for "verbal" reporting to NERC and Regional entities? (2) What are the requirements for a "Preliminary" Impact Event Report? (3) The Voltage Deviations Event is unclear (a) Are these consecutive minutes? (b) Where is the voltage measured? (generator terminals? Point of Interconnections? Anywhere?) (c) must each Entity report separately? (d) What is the +/- 10% measured against (Generator Voltage Schedule?) (4) For Generation loss events how is an "entity" defined? (a

corporate parent? each registered entity? other?) (5) Are the "Examples" in the Attachment 1 - Part A really Examples, or mandatory situations? (6) Can you define "Damage"? (7) Can you define "external cause"? (8) Can you give examples of "non-environmental external causes"? (9) The footnote 1 reference for "Damage or destruction of BES equipment" doesn't match up with the a. and b. footnotes or the 1. footnote of Attachment A - Part B. (10) How is the Operator supposed to determine what Event affects the reliability of the BES fast enough to decide whether or not to report? (11) is the Loss of off-site power (grid supply) event to a nuclear plant already covered by NUC-001?(12) What are "critical cyber assets" since CIP-002-4 will eliminate that term? (13) When is Attachment 2 supposed to be used? (14) What is meant by the word "Confidential" in the title of the Attachment 2 report? How would the SDT propose a GO/GOP handle the reporting for the following situation? A CTG unit is dispatched and the unit is started, synchronized and put on the bus. Immediately the Operator receives a high gas alarm from the GSU. The Operator quickly shuts the unit down and de-energizes the GSU. There are no relay targets and no obvious reason for the problem. After several weeks of analysis it's determined there was an internal fault in the GSU and it must be replaced. How would the SDT recommend all the reporting requirements in this situation be addressed with the current draft?

No

It is unclear when this should be used, or why.

Yes

However, the term Impact Event should be a new defined term. When the SDT determines this, it should use the term consistently on both pages 5 and 21 of the SDT document.

No

It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than in the existing standards.

Yes

Yes

We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting.

Individual

Thad Ness

American Electric Power (AEP)

No

It is unclear what the relationship between this project and the newly revamped NERC Event Analysis Process. We support moving towards one process opposed to separate obligations that may be in conflict. In addition, AEP supports the concept of a central clearinghouse such as the RCIS that is shared by the industry. We support fewer punitive requirements and more prompting for using tools to make multiple entities aware of reliability related issues shortly after the fact.

No

AEP does not agree with the addition of the Generator Owner to the standard. The Generator Owner does not have visibility to the real time operational status of a unit. As a result, the Generator Owner lacks the ability to recognize impact events and report them to the Regional Entity or NERC within the time frames specified in the standard. Reporting requirements for impact events should be the responsibility of the Generator Operator.

Yes

Overall we support the concepts; however, it is unclear if the ERO can be held accountable for compliance with NERC Requirements. If this requirement is removed there needs to be some mechanism for the ERO to establish a single clearinghouse.

No

Component 2.2 "Method(s) of assessing cause(s) of impact events" is very vague. Furthermore, there are concerns whether these methods can be accomplished within one hour as might be required per Attachment 1, in addition to operating the system. Component 2.6 – need to add the statement "as appropriate for type of impact event" Components 2.7 through 2.9 – are good concepts to consider for future inclusion, but at this point in time these appear to be overreaching objectives. We recommend the SDT take smaller increments towards future progress at measure and reasonable pace. Furthermore, if Component 2.9 is retained it should only pertain to lessons learned on the reporting of impact events not all recommendations regarding remediation of the impact events themselves. Furthermore, the 30 day window to update the Operating Plans is aggressive considering the other priorities that may be present day to day.

No

Not clear how this is different from R6 since it relies on the same timetable in Attachment 1.

Yes

Yes
No
It is not clear how this is different from R3 since it relies on the same timetable in Attachment 1.
No
Are the times listed for the initial probable reporting under R3 or the reporting under R6? Many of these items do not constitute emergency conditions. We view many of these as too onerous and would divert operating staff from monitoring and operating the BES. In addition, some terms (i.e. Frequency Trigger Limits) are not currently defined terms. Furthermore, there are existing requirements that have obligations for entities to provide this information to the RC. For example "Detection of a cyber intrusion to critical cyber assets" is already covered under CIP-008. This creates duplicate (and potentially competing) requirements. AEP also contends that some of the timelines are very aggressive and not consummate with perceived need for the information. Transmission loss of multiple BES transmission elements (simultaneous or common-mode event) within 24 hours after occurrence is overly aggressive and should provide more specific criteria.
Yes
Yes
Yes
The standard needs to be modified to allow the ability for one entity to report on behalf of other entities. For example the loss of Generation over the threshold could be reported by the RC opposed to the GO individually, if mutually agreed upon before the fact.
Group
Bonneville Power Administration
Denise Koehn
Yes
Known causes are difficult under 1 hour reporting requirements (Unusual events are even harder to narrow down in 24 hours and may take weeks.) The System Operators and RC's handle situational awareness and reliability events, this is an extra wide view and learning for reporting only.
Yes
Yes
As long as the 2.4 list is position based, not based on each individual that fills the position. (There is a concern of listing all 2.4 monitoring/reporting personnel in the company that cover the impact event, since there are different function groups and shift work. Documentation trails are difficult with personnel changes.) Because the CIP is being added, it requires an Operating Plan (instead of procedure) with 30 day revision timelines, so it increases the burden for electrical grid event reporting function. R2.9 language refers to R8 "annual" report; however R8 language is "quarterly" reporting of past year. It appears this standard is going to be in an update status 4 times per year, plus any event modifications plus personnel changes. This could be overly burdensome due to the expanding world of cyber security.
Yes
Known causes are difficult under 1 hour reporting requirements. (Unusual events are even harder to narrow down in 24 hours and may take weeks.)
No
There was no drill required for CIP-001 (a drill was in CIP-008, but the purpose did not list combining CIP-008). A drill is not needed for reporting Electrical Grid events, designate it as excluded in the intent of the requirement.
Yes
There was no training required for CIP-001 or in CIP-008. (The proposed EOP-008 purpose did not list incorporating CIP-008). Training was not really needed for reporting Electrical Grid events.
Yes
The requirement needs to specify who (ERO) to report to. Attachment 1 doesn't say to report to the ERO either. Clarify or remove the difference between the report submitted and evidence of the type of impact event required in the measurement.

Yes
R2.9 language refers to R8 "annual" report; however R8 language is "quarterly" reporting. It appears this standard is going to be in an update status 4 times per year minimum, plus any event modifications plus personnel changes. Overly burdensome.
No
BPA suggests the following: Change loss of multiple BES to 3 or more. Loss of a double circuit configuration due to lightning doesn't need a report (it's a studied contingency). Add qualifier to damage/destruction of BES equipment, since a failed PCB or a system transformer normally doesn't have a MAJOR impact to the grid. Add qualifier to Loss of "ALL" off-site power affecting nuclear... The unplanned evacuation of control center is a busy time for the backup control center, yet this standard requires 1 hour reporting. Suggest changing to 24 hours.
Yes
Item 8: list Hz minimum on the second line prior to Hz max since that is the typical frequency excursion order. The Operating Plan is going to have to include the Compliance Registration ID number, since Operating Personnel don't carry that information around and it is not readily available.
The definition of an impact event in EOP-004-2 seems clear, however the term "mis-operation" still may imply intent in the action of an individual. The SDT should consider further defining that term.
No
BPA supports the concept behind the revisions to EOP-004-2. Creating a single reporting methodology will improve the processes and lead to more consistency. BPA recommends that the Standards Drafting Team (SDT) coordinate any revisions in the reporting requirements with those found in CIP-008-3 to ensure that there are no conflicts. BPA asks the SDT to consider the impact of these changes on CIP-008-3 and work with the CIP SDT to ensure that the wording of the two requirements is similar and clear. Based on Attachment 1 part A of EOP-004-2, certain cyber security events, intrusions for example, would have to be reported under both EOP-004-2 and CIP-008-3. That puts a burden on a Registered Entity to take additional steps to coordinate reporting or face potential compliance risk for correctly reporting an event under one standard and failing to report it under the other standard. The mapping document had errors: a. CIP-001 R1 to EOP-004 R2.9 (annual vs quarterly). b. EOP-004-1 R2 was translated to R2 & R3 of version 2. c. EOP-004-1 R3 was translated to R6 of version 2 (which doesn't say to whom to report).
Yes
Yes
The document retention times in EOP-004-3 should be spelled out more clearly. The Compliance summary does so (but needs some punctuation clarification regarding investigation), the SDT should consider making that part of the requirements or clarifying the wording in the requirements.
Group
PSEG Companies
Kenneth D. Brown
No
The following sentence should be added. "This standard is not intended to be for real-time operations reporting."
No
For many items, there are multiple entities listed with reporting obligations. For example, loss of off-site power to a nuclear plant lists RC, BA, TOP, TO, GO and GOP. This appears to result in the potential for the sending of 6 separate reports within the hour for the same event, which in wide area disturbances overload the recipients. The drafting team should consider revising the lists where possible to a single, or absolute minimum number, entity. Those items reportable OE-417 should be removed from Attachment 1. For example, voltage reduction, loss of load for greater than 15 minutes. The trigger for voltage reduction should be the time of issuance of the directive to reduce voltage in an emergency, not when "identified."
No
The top of this form should have the following statement added: "This form is not required if OE-417 is required to be filed."

Group
E.ON U.S. LLC
Brent Ingebrigtsen
No
The proposed standard does not list the Load Serving Entity as an Applicable Entity, but the possible events that the standard addresses are within the scope of the LSE. Some functions of the LSE listed within the Functional Model are addressed in the proposed standard. Existing CIP-001-1a and EOP-004-1 are both applicable to the LSE.
No
The Version History contained with EOP-004-2 indicates that CIP-001-1 and EOP-004-1 are "Merged", however, the actions do not reflect the retirement of CIP-001-1a and therefore, it is unclear if there will be remaining redundancies or potential gaps with the new version EOP-004-2 and CIP-001-1a.
Yes
The new standard should incorporate all other disturbance, sabotage, or "impact event" reporting standards, such as CIP-008-3. At the very least it should reference those other standards that have within their scope same/similar events in order to ensure complete reporting and full compliance. Suggesting that one standard provides the single reporting procedure, when in actuality it does not, is counterproductive. The discussion of "impact event" clearly indicates the SDT's intent to include sabotage events in the proposed standard EOP-004-2.
Individual
Joe Knight
Great River Energy
Yes
Thank you for the clarification of "known causes", this will allow entities to report what they currently know when submitting an impact report.
Yes
We believe that it is important for the ERO to provide valuable Lessons learned to our electrical industry, thus enhancing the reliability of the BES.
Yes
No
A. As detailed in R2, the Operating Plan shall contain provisions for "identifying, assessing, and reporting impact events". R2.8, and R2.9 do not have a correlation to R2's Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change. We believe that the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in the components of an entity's Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the words "lessons learned" would be required to be in your Operating Plan. It is solely up to an entity to implement a "Lesson Learned" and not the place for this SDT to require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. B. In R2.8 & R2.9, It may be difficult to implement lessons learned within 30 days. We suggest that lessons learned should be incorporated within 12 calendar months if lessons learned are not deleted from the R2.8 & R2.9.
Yes
While we agree that it makes sense to report on the cause of an event. we disagree with the need for an Operatina

Plan as identified in R2
No
We disagree with the need to conduct a drill for reporting
No
We believe that this task should be incorporated into the Job Task Analysis for the System Operators and that this requirement should be deleted as being redundant.
No
We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
Yes
No
Comments: Please provide a phone number and provision within the Note of EOP-004 – Attachment 1: Impact Events table for an entity to contact NERC if unable to contact NERC within the time described. Voltage Deviations – recommend adding the word “(continuous)” after sustained in Threshold column. This could be interpreted as an aggregate value over any length of time. Frequency deviations - recommend adding the word “(continuous)” after 15 minutes’ in Threshold column. This could be interpreted as an aggregate value over any length of time. CIP-008 R1.3 states the entity is to report Cyber Security Incidents to the ES_ISAC. Does the EOP-004 Attachment 2 fulfill this requirement? We request clarification on the Transmission Loss threshold events that constitute reporting. We also want clarification on what constitutes the loss of a DC Converter station and is there a time duration that constitutes the need for reporting or does each trip need to be reported? For example during a commutation spike the DC line could be lost for less than a minute. Does this loss require a report to be submitted? Is the SDT stating that each time a company loses their DC line, they are required to file a report even though it may not have an effect on the bulk system? What is the threshold for this loss? The SDT needs to clarify that duplicative reporting is not required and that only one entity needs to report. For instance, the first three categories regarding energy emergencies could be interpreted to require the BA and RC to both report. The reporting responsibilities in this table should be clarified based on who has primary reporting responsibility for the task per the NERC Functional Model and require only one report. For instance, since balancing load, generation and interchange is the primary function of a BA per the NERC Functional Model, only the BA should be required to provide this report. The term Frequency Trigger Limit (FTL) is not currently defined in the NERC Glossary. The term FTL needs to be introduced at the beginning of the standard and defined as a new term.
No
NERC and the DOE need to coordinate and decide on which report they want to use and whichever report it is needs to include all information required by both entities. The way this standard is currently written there is the potential that two government entities may need to be reported to is a relatively short period of time. It is not clear what benefit providing the Compliance Registration ID number provides. Many of the registered entities employees that will likely have to submit the report, particularly given the one-hour reporting requirement for some impact events, will not be aware of this registration ID. However, they will know for what functions they are registered. We recommend removing the need to enter this compliance registration ID or extending the time frame for reporting to allow back office personnel to complete the form. For item two, please change “Time/Zone:” with “Time (include time zone)”. As written it is a little confusing.
No
We believe the SAR scope regarding addressing sabotage has not been addressed at all. It appears that impact event essentially replaces sabotage. This standard needs to make it clear that sabotage, in some cases, cannot be identified until an investigation is performed by the appropriate policing agencies such as the FBI. Intent plays an important role in determining sabotage and only these agencies are equipped to make these assessments.
No
It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than in the existing standards.
Yes
Yes
We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting. Please provide an e-mail address for the submittal of the report to NERC (and any other parties above a Regional Entity) within this Standard and a fax number as a backup to electronic submittal.
Individual
Greg Rowland

Duke Energy
No
The Purpose statement says that reporting under this standard supports situational awareness. However this is in conflict with Section 5. Background, where the DSR SDT makes clear that this standard includes no real-time operating notifications, and that this proposed standard deals exclusively with after-the-fact reporting. We also disagree with the stated concept of "impact event". Including the phrase "or has the potential to impact" in the concept makes it impossibly broad for practical application and compliance.
Yes
No
The requirement again states the intent is to "enhance and support situational awareness", which doesn't sync with "after-the-fact reporting". We question why NERC needs to create this report and system for distributing impact event reports to various organizations and agencies for after-the-fact reporting, when we are still required to make real-time reports under other standards. For example, the Rational specifically recognizes that this standard won't release us from the DOE's OE-417 reporting requirement. We don't see that this provides value, unless NERC can find a way to eliminate redundancy in reporting.
No
Sections 2.4 and 2.5 should allow identification of responsible positions/job titles rather than specific people. Section 2.9 only allows 30 days for updates to our plan based upon lessons learned coming out of an annual report. 60-90 days would be more appropriate. Also, Section 2.9 says it's an annual report, while R8 only requires quarterly reports.
Yes
Yes
No
Strike the word "all" in the requirement. All personnel don't need to be trained – for example, the plan may contain references to some personnel as potential sources of the information that will then be reported. Also, Section 5.3 only allows 30 days for training, which may be impossible with rotating shift personnel and training schedules. 60 days is more appropriate.
Yes
Yes
However, R8 only addresses quarterly reports, and R2 Section 2.9 states that there will be an annual report.
No
<ul style="list-style-type: none"> <li>• General Comment – many timeframes in Attachment 1 are within one hour. This is inconsistent with the stated aim of the standard, which is after-the-fact reporting, as opposed to real-time operating notifications under RCIS and other standards (e.g. TOP). This standard should not be structured to require another layer of real-time reporting.</li> <li>• Voltage Deviation – Plus or minus 10% of what voltage?</li> <li>• Frequency Deviation – this is Interconnection-wide. Do you really want a report from every RC and BA in the Eastern Interconnection??</li> <li>• Transmission Loss – "Multiple BES transmission elements" should be changed to "Three or more BES transmission elements". Also, the time to submit the report should be based upon 24 hours after the occurrence is identified.</li> <li>• Damage or destruction of BES equipment – need clarity on the "Examples". Is the intent to report an event that meets any one of the four "part a." sub-bullets? i. – critical asset should be capitalized. Disagree with the phrase "has the potential to result" in section iii. – it should just say "results". Section iv. is too wide open. It should instead say "Damaged or destroyed with malicious intent to disrupt or adversely affect the reliability of the electric grid."</li> <li>• Unplanned Control Center evacuation – see our General Comment above. Clearly in this case the reporting individuals are evacuating and cannot report in one hour. 24 hours should be more than adequate for after-the-fact reporting.</li> <li>• Fuel Supply Emergency, Loss of off-site power, and Loss of all monitoring or voice communication capability – see our General Comment above. Time to report should be 24 hours after occurrence is identified.</li> <li>• Forced intrusion, Risk to BES equipment, Detection of a cyber intrusion to critical cyber assets – time to report should be 24 hours after occurrence is identified, and critical cyber assets should be capitalized.</li> </ul>
Yes
However, Attachment 2 is titled "Impact Event Reporting Form".
No
We disagree with the stated concept of "impact event". Including the phrase "or has the potential to significantly impact" in the concept makes it impossibly broad for practical application and compliance. By not attempting to define "sabotage", the standard creates a broad reporting requirement. "Disturbance" is already adequately defined. "Sabotage" should be defined as "the malicious destruction of, or damage to assets of the electric industry, with the intention of disrupting or adversely affecting the reliability of the electric grid for the purposes of weakening the critical infrastructure of our nation."

Yes
Yes
No
Individual
Nathan Lovett
Georgia Transmission Corporation
No
These events generally are Operator Functions and should not apply to a TO. 1. Energy Emergency requiring system-wide voltage reduction 2. Loss of firm load greater than 15 min. 3. Transmission loss (multiple BES transmission elements) 4. Damage or destruction to BES equipment ( thru operational error or equipment failure) 5. Loss of off-site power affecting a nuclear generating station
No
The only two events that apply to a TO are the ones related to CIP: 1. Forced intrusion (report if motivation cannot be determined, i.e. to steal copper) 2. Detection of a cyber intrusion to critical cyber assets ( criteria of CIP-008) Everything in this standard applies to a TOP and therefore E-004-2 and CIP-001 should not be combined
Group
WECC
Steve Rueckert
No
The purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. It is misleading and may have many thinking it is duplicative work.
No
The ERO's applicability is not applied in Attachment 1.
R1 is appropriate for after-the-fact reporting. However, as proposed this standard eliminates all real-time notifications, including the CIP-001-1 R3 notice to appropriate parties in the Interconnection. New requirement R2.6 lists external parties to notify but it does not include the Reliability Coordinator. It is important that the RC be notified of suspected sabotage. The RC's wide-area interconnection view and interaction with BAs may help recognize coordinated sabotage actions. Any "impact event" where sabotage is suspected as the root cause should require additional and real-time notifications.
No
Need clarification on whether the 30 days is calendar days or business days. As noted in the comment to question 3, any impact event where sabotage is suspected should be treated differently from those where sabotage is not suspected.
Yes
No
The addition of a drill or exercise constitutes additional training and believes R4 should be added to R5. Clarification is needed as to what level does the annual training target, for instance, the field personnel. Will they have to complete the exercise/drill?
No



<p>Thirty days is too restrictive due to real-time operations schedule requirements. Most work schedules are either five or six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Based on the NERC Continuing Education revised submittal date for the Individual Learning Activities (ILA), the requirement should be changed to require training to be conducted within 60 days.</p>
No
<p>There seems to be redundancy in reporting based on the time frames in Attachment 1, i.e. OE-417 and other required reports. If this standard is intended to be an after the fact report, why is there one/twenty-four hour reporting criteria?</p>
Yes
<p>For strictly after-the-fact reporting the list of Attachment 1 is appropriate. However, as noted in our earlier comments, actual or suspected sabotage events can have a potentially significant impact on reliability and should be treated differently, with additional real-time reporting requirements. It is important that such events be identified and recognized for reliability purposes and that notices include the RC.</p>
No
<p>The report is duplicative to the OE-417 reporting criteria.</p>
No
<p>The proposed definition of "impact event" does not meet FERC's directive to "further define sabotage" nor does it take into consideration their request to address the applicability to smaller entities. Attachment 1 Part A or B do not clearly specify "sabotage" events, other than "forced entry". The purpose of CIP-001-1 and its requirements is to address the specific issue of possible sabotage of BES facilities. This is entirely different than a "disturbance" or an "event" on the BES. The proposed definition for "impact events" is essentially any event that has either impacted the BES or has the potential to impact the BES, caused only by three specific things; equipment failure or misoperation, environmental conditions, or human action. Several of these "impact events could be a result of sabotage. Actual or potential sabotage clearly poses a risk to the reliability of the BES. It is important that the risks related to sabotage be reflected in either EOP or CIP</p>
<p>A potential gap may exist. Attacks on BES facilities, via either vandalism or sabotage, are very different events than impact events on the system. From a Compliance standpoint, a revised standard to address the FERC directive on sabotage should be developed as an EOP standard (that is grouped with 693 Standards) rather than as a CIP Standard (CIP-001-1).</p>
Yes
Yes
<p>Having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues. This will become even more of an issue as training requirements continue to expand. CIP-001-1 has surprisingly been one of the most violated standards during the initial period. However, most entities have now developed and demonstrated a decent compliance process. Unless a revised standard to address the FERC directive on sabotage is developed (as suggested in 13 above) this proposed standard appears to eliminate sabotage reporting as a reliability standard to the potential detriment of BES reliability.</p>
Individual
Chris de Graffenried
Consolidated Edison Co. of NY, Inc.
No
<p>Comments: The purpose is not clear because it uses the term "impact events". This term should be defined in the NERC glossary, and should not include words such as "potential".</p>
No
<p>Comments: NERC's role as the Standard enforcement organization for the power industry will be in conflict if NERC is also identified as an applicable entity. What compliance organization will audit NERC's performance? This is presently not clear.</p>
No
See response to Question 2.
No
<p>Requirement R2 • Lead-in paragraph - Following the words "Attachment 1" add a period and the words "The Operating Plans shall" and then delete "that" and make "includes" singular. • R2.1, 2.2, 2.3, 2.7 - Replace the word "Method(s)" with the word "Procedure(s)". • 2.6 – After the word "notify" add a period, then insert the words "For example, external organizations may include" and delete the words "to include but not limited to." • 2.8 – After the words "Operating Plan based on" add the word "applicable". Rational R2 After the words "Every industry participant that owns or operates," add the words "Bulk Electric System." Then delete the words "on the grid."</p>

Yes
We agree, however, the term "impact event" must be part of the NERC glossary.
Yes
No
Requirement 5 – Training should be targeted only at those responsible for implementing the Operating Plan (OP), not all those mentioned in the OP. R5 – After the words "internal personnel" add the words "responsible for implementing." The delete the words "identified in" and "for reporting pursuant to Requirement R2." 5.4 – Following the words "For internal personnel" add the words "responsible for implementing the Operation Plan." Between the words "revised responsibilities" add the word "implementation." M5 – After the words "between the people" add the words "responsible for implementing the Operating Plan"
No
R2 requires applicable entities to have an Operating Plan which are company specific procedures and process required to be compliant with EOP-004. Therefore, R6 should be deleted since it is redundant with R2.
No
See response to Question 2 Requirement 7 Delete the words "and propose revisions to" Following the words (Attachment 1) add a period. Following that period add the words "The ERO shall revise the table" Requirement 8 RECOMMEND DELETION OF R8 – CONFIDENTIALITY CONCERNS WILL MAKE ESTABLISHING A PUBLICATION REQUIREMENT EXTREMELY CHALLENGING.
No
It is absolutely essential that the work on EOP-004 and that on the NERC Event Analysis Process (EAP) be fully coordinated. We find that there are a number of inconsistencies between these two documents. The EAP and EOP-004 are not aligned. In order to operate and report effectively entities need consistent requirements. Attachment 1 Frequency Deviations – The term "Frequency Trigger Limit (FTL)" is not defined. Only defined terms should be used, or the term should be defined. If the term is defined in another standard it should be moved to the Glossary of Terms for wider use. Loss of Firm load for 15 Minutes – The text under the rightmost column entitled, Time to Submit Report, appears to be incomplete in our copy. Transmission loss and Damage or destruction of BES equipment – At the end of the wording for both under the column entitled "Threshold for Reporting" add the words "that significantly affects the integrity of interconnected system operations." Examples – Capitalize "Critical Asset" as this is a defined term.
No
It is not clear why the DOE form cannot be used. NERC should make every effort to minimize paper work for entities responding to system events.
No
The definition is open for interpretation beyond events identified in Attachment 1. In addition, all Standards are supposed to have Rationales. In the Draft Standard, the Rationales do not address the concept of Potential, and how it relates to an actual system event. Additional work needs to be done addressing the meaning of "potential".
Yes
Yes
Yes
Overriding Comment and Concern: It is absolutely essential that the work on EOP-004 and that on the NERC Event Analysis Process (EAP) be fully coordinated. We find that there are a number of inconsistencies between these two documents. The EAP and EOP-004 are not aligned. In order to operate and report effectively entities need consistent requirements.
Group
Pepco Holdings, Inc - Affiliates
Richard Kafka
Yes
Yes
Yes
No
For R 2.7, 2.8 and 2.9, 30 days may be too short a time for large entities with multiple subsidiaries to do the necessary notice and coordination. PHI suggests 90 days.

Yes
Yes
No
30 days may be too short a time for large entities with multiple subsidiaries to do the necessary notice and coordination. PHI suggests 90 days.
Yes
Yes
No
Some items with one hour reporting (such as Unplanned Control Center evacuation) may be so disruptive to operations that one hour is too short. 4 hours suggested.
No
The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
No
The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
No
The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
Yes
Yes
The EAWG is developing processes that will be enforced through the Rules of Procedure. It may be inappropriate to reference the EAWG process in the Mapping Document.
Individual
Kathleen Goodman
ISO New England Inc.
No
The proposed requirements in the standard are not focused on the core industry concern that current requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, "The existing requirements need to be revised to be more specific – and there needs to be more clarity in what sabotage looks like." Instead this proposed standard includes requirements that are more focused on "how" to report, rather than "what" to report. The draft 2 SAR has never been balloted for approval prior to standard drafting. In fact, the SAR states, "The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards." The scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seems helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting team seems to be ignored: "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard. The term "impact events" does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC Glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. This draft standard should not have this high a priority while other standards having a greater impact on Bulk Electric System reliability remain incomplete or unfinished. Regional reporting requirements should be in Regional Standards, and not be included in a NERC Standard.
No
Having the ERO as an applicable entity raises the issue that they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other

applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. NERC has also offered the opinion that since NERC is not a "user, owner, or operator" Standards are not enforceable against the ERO. In Attachment 1 the time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to unnecessary and possibly conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, this subject is more complex than this table reveals, and the table needs more clarification. Entities that have information about possible sabotage events should report these to NERC after the fact, and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, it is likely that there is going to be duplicate reporting. Several of the events require filing a written formal report within one hour. For example, system separation is going to require an "all hands on deck" response to the actual event. The paragraph above the table in Attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements through NERC that cross federal agency jurisdictions.

No

Having the ERO as an applicable entity raises a concern because they are also the Compliance Enforcement Authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of "applicable government, provincial or law enforcement agencies" for distribution as defined in R1. The "rationale for R1" states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. The better approach would be for the entities to complete OE-417 form and this standard simply require a copy.

No

This is an overly prescriptive requirement given that the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan is an unnecessary burden that offers no additional improvements to the reliability of the Bulk Electric System, and this is not, in fact, an Operating Plan. At most, it may be a reporting plan. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure Bulk Electric System reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Stating reporting requirements directly in the standard would produce a more uniform and effective result across the industry, contributing towards a more reliable Bulk Electric System. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate, and how will duplicative reporting be addressed (for example, DOE, Nuclear Regulatory Commission)? Also, in the "rationale for R2", please explain the reference to Parts 3.3 and 3.4.

No

We think "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditable compliance procedures. Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes a considerable amount of time for an actual cause to be determined. The determination process may require a complex root cause analysis. Further, in the case of suspected or potential sabotage, the industry can only say it doesn't know, but it may be possible. Law enforcement agencies make the determination of whether sabotage is involved, and the information may not be made available until an investigation is completed, if indeed it is ever made available.

No

The need for a periodic drill has not been established, and appears to be overly restrictive given the intent of the standard is the reporting of impact events. Suggest this requirement be eliminated. Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in as short a time frame as may be required for real-time operating conditions notifications.

No

The need for a periodic drill has not been established, and appears to be overly restrictive given that the intent of the standard is reporting of impact events. Suggest this requirement be eliminated. There are training standards in place that cover these requirements. We agree the relevant personnel should be "aware" of the reporting requirements. But

there is not a need to have a training program with specific time frames for reporting impact events. Awareness of these reporting requirements can be achieved through whatever means are available for entities to employ to train on any of the NERC standards, and need not be dictated by requirements.
No
Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements for NERC that cross other federal agency jurisdictions. There is no need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations which is implied by the label "Operating Plan."
No
Having the ERO as an applicable entity raises concern as it is also the compliance enforcement authority. Requirement R7 is unnecessary as there are already requirements in place for three year reviews of all Standards. R8 contains requirements to release information that should be protected, such as identification of trends and threats against the Bulk Electric System. This may trigger more threats because it will be published to unwanted persons in the private sector. We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.
No
1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004. What are the examples at the bottom of page 14 supposed to illustrate? Critical Asset should have the appropriate capitalization as being a defined term. Is Critical Asset what is intended to be used here? Should the "a" list be read as ANDs or Ors? Does "loss of all monitoring communications" mean "loss of all BES monitoring communications"? Does "loss of all voice communications" mean "loss of all BES voice communications"? Are the blue boxes footnotes or examples? Does "forced intrusion" mean "physical intrusion" (which is different from "cyber intrusion")? Regarding "Risk to BES Equipment," request clarification of "non-environmental". Regarding the train derailment example, the mixture of BES equipment and facility is confusing. Request clarification for when the clock starts ticking. Regarding "Detection of a cyber intrusion to critical cyber assets", there is concern that this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. Suggest physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.
No
There is already a DOE requirement to report certain events. There is no need to develop redundant reporting requirements to NERC that cross other federal agency jurisdictions. The heading on page 16 refers to EOP-002, but this is Standard EOP-004. If some questions do not require an answer all of the time, then the form should state that or provide a NA checkbox. While Attachment 1 details some cyber thresholds, Attachment 2 provides no means to report – which is acceptable if cyber incidents are handled by CIP-008 per the comment provided for Question 10. The Event Report Template in Appendix A is different from the most recent version, which is available at: <a href="http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf">http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf</a>
No
The use of the term "impact events" has simply replaced the terms "disturbance" and "sabotage", and has not further defined sabotage as directed by FERC. We do feel that "impact events" needs to be a defined term. While we agree with the SDT's new direction, the FERC directive has not been met. This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement and other specialized agencies, including international agencies roles in defining acts of sabotage, and not hold the registered entity wholly responsible to do so.
No
Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by the NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity. EOP-004-3 should be EOP-004-2.
No
If the training and Operation Plan requirements are adopted as proposed, this may not allow sufficient time for some entities to comply, particularly those with limited number of staff, but perform functions that have multiple event reporting requirements.
Yes
Request clarification on how RCIS is part of this Standard. The form should be filled out in two stages. First stage would be the immediately available information. The second stage would be the additional information such as one line diagrams. There is concern with burdening the reporting operator on filling out forms instead of operating the Bulk

Electric System. Most of the draft requirements are written as administrative in nature, and this is not most effective. Changes need to be made to (or possibly elimination of) R1, R2, R3. The standards should be changed to define what a "disturbance" is for reporting in EOP-004. Sabotage reporting as per CIP-001 should be rescinded as EOP-004 already has such a requirement.
Group
We Energies
Howard Rulf
No
Impact event needs to be clarified first, and DP references in Attachment 1 clarified. Distribution is not BES.
No
The need for a DP to be included needs to be clarified. The Purpose points to BES. A DP does not have BES equipment.
Yes
No
R2.3, R2.4: "Part" is not a defined term or used in the NERC Standard Process Manual. R2: Attachments are not mentioned in the NERC Standard Process Manual. Is this a mandatory or informational part of the standard? R2.6 (and possibly R2.5): There does not seem to be discretion in notifications. Are all people or organizations on the notify lists always contacted for every impact event? Even Law Enforcement? R2.7: What is a "component? A Plan component? A BES component? R2.9: There is no annual NERC report issued pursuant to R8. R8 requires quarterly reporting.
No
A DP may not have Facilities (a BES element). See NERC Glossary definition of Facility.
Yes
No
Please clarify who is to be trained. As written, R5 requires any internal personnel identified in the plan, including CEO, Vice Presidents, etc., to be trained.
No
The proposed definition of "impact event" needs to be clarified.
Yes
No
I did not compare this standard to the OE-417 form. Please do not require operators to fill out a second form during an emergency within one hour. Energy Emergency requiring Public appeal...: "Public " is not a defined term. Energy Emergency requiring system-wide voltage...: DP does not control BES voltage. Energy Emergency requiring firm load shed...: TOP does not have load it would shed for an Energy Emergency. Frequency Deviations: Why is a BA reporting? This will be every BA in the Interconnection reporting the same Frequency Deviation. Frequency Deviations: Frequency Trigger Limit is not a defined term, and is not defined in this standard. Loss of Firm Load...: TO and TOP may coordinate or direct load shed, but they do not serve firm load. Damage or destruction of BES... There is no footnote 1 on this page. I assume it is the examples on the page. Are these "examples" of a larger set or are these all that is required? Critical Asset is a defined term. Forced Intrusion: "facility" or Facility? An RC and BA do not have Facilities.
No
The data required to assess an impact event thoroughly will often not be available or apparent. Immediate reporting should fall to the RE with assistance/information from the affected entities. There do not seem to be provisions for when it is impossible to take the time to fill out a form or when it is impossible to send a form. I did not compare this standard to the OE-417 form. Please do not require operators to fill out a second form during an emergency within one hour.
No
Impact Event could replace disturbance and sabotage but not in its present form. The proposed definition of impact event "An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action." Is too vague. The "potential to impact the reliability" is too broad and open to interpretation. It needs to be specific so entities know what is and is not an impact event and so an auditor clearly knows what it is. Define "impact event" as the items listed in Attachment 1. As you have done, focusing on an event's impact on reliability is more important than determining an individuals intent (sabotage v.s. theft).
Yes

Yes
Yes
Please be careful to capitalize defined terms. If the intent is to not use the defined term, use another word. "Forced intrusion" (cutting a fence, breaking in a door) may not be discovered for quite some time after it occurs. Should it be reported as soon as discovered? Even if there was no impact event (disturbance)? "Destruction of a Bulk Electric System Component" seems pretty specific. However, if a transformer kicks off line due to criminal damage, yet is considered repairable, is the event reportable?
Group
PPL Supply
Annette M. Bannon
Yes
No
While we agree with the list of functional entities identified in the Applicability Section, we do not agree with assignment of applicable entities noted in Attachment 1. As the functional entities are identified in Attachment 1, there will likely be duplicate reporting for many impact events. By applying reporting responsibilities to both the Gen Owner and Gen Operator, this will result in duplicate reporting for plants with multiple owners. It also increases the burden on the Gen Operator who is required to report the event to NERC and to other Gen Owners in a timely manner to allow other Gen Owners to meet the NERC reporting timeline. We suggest that the reporting requirements associated with generators be applied to the Gen Operator only.
Yes
No
While we agree with concept addressed in R2, we don't agree with use of the defined term Operating Plan. Consider working the requirement as follows: "Each Applicable Entity identified in Attachment 1 shall have a documented process or program that includes the following components:..." Also, please consider changing 2.1 to be"Method(s) for recognizing the occurrence of impact events." The current wording could be interpreted to mean, "create a list of the impact events."
No
Please consider changing the word "identify" to "recognize" and adding the Rationale statement to the requirement as follows: "Each Applicable Entity shall assess the causes of the reportable event and gather available information to complete the report."
Yes
No
We generally agree with R5 but recommend two changes to 5.3. Consider expanding the exception criteria to exempt non-substantive changes such as errata changes, minor editorial changes, contact information changes, etc. Also, consider changing "training shall be conducted" to "training or communication/notification of changes shall be conducted."
No
It may be difficult to meet Attachment 1 Part B Potential Reliability Impact submittal times as the time to submit is 1 or 24 hours after occurrence. Consider changing the Time to Submit Report for Forced intrusion, Risk to BES equipment, and Detection of a cyber intrusion to be "report within 24 hours after detection".
Yes
No
Attachment 1 Part A is labeled "Actual Reliability Impact". Does this title mean that for all events listed the "threshold for reporting" is only met if the event occurs AND there is an actual reliability impact? As opposed to Part B where the threshold for reporting is met when the event occurs and there is a potential for reliability impact? This could be broad for events like "Risk to BES equipment."
Yes
Yes
Yes

Yes
No
Individual
Amanda Stevenson
E.ON Climate & Renewables
Yes
No
1. Voltage deviation events are too vague for GOP. How does voltage deviations apply to GOP's or specifically renewables i.e., wind farms? 2. Define what an "entity" is. 3. Define what a "generating station" is. 4. Define what a "BES facility" is. 5. Define what a control center is. 6. Renewable energy/generators should be taken into consideration when crafting the events.
Yes
A generic ERCO approved electronic (form that can be submitted on-line) reporting form will help to add more clarity & consistency to the Impact event reporting process.
No
Administrative burden to some of the components such as 2.5.
No
Redundant with R4.
No
1. Voltage deviation events are too vague for GOP. How does voltage deviations apply to GOP's or specifically renewables i.e., wind farms? 2. Define what an "entity" is. 3. Define what a "generating station" is. 4. Define what a "BES facility" is. 6. Define what a control center is.
Yes
Suggestions on the form: if an entity has not had time to fully determine the cause of an Impact Event such as for "Question # 4: Did the impact event originate in your system, yes or no?", perhaps more time is needed that 24 hours to determine the cause.
No
Acts of Sabotage is still not defined and if the registered entities are required to reports acts of sabotage, NERC still needs to define this further.
Yes
Yes
Refrain from having redundant reporting forms if at all possible. This can create confusion and lead to unnecessary penalty amounts and violations for registered entities. potential" impacts of an event on the BES need to be clearly defined in the standard.
Individual
Christine Hasha
ERCOT ISO
No
ERCOT ISO believes that according to the timelines allotted in Attachment 1, it may not be possible for the entity to identify the "known cause" of an event. The requirements list identification of "initial probable cause". This is more reasonable under the timelines noted in Attachment 1.
No
ERCOT ISO recommends that the Electric Reliability Organization be removed from the standard. The Electric Reliability Organization should not be responsible for reliability functions and therefore should be excluded from reliability standards.
No
Recommend that requirements for the Electric Reliability Organization be removed. However, if the requirements are



retained, ERCOT ISO recommends the following wording change to be consistent with other standards. "R1. The ERO shall create, implement, and maintain a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness."

No

ERCOT ISO recommends the use of "Registered Entity" in place of "Applicable Entity". This would provide consistency with other requirements and Attachment 1. Recommend the following changes to the subrequirements. "2.6. List of external organizations to notify to include but not limited to NERC, Regional Entity, relevant entities within the interconnection, Law Enforcement, and Governmental or Provincial Agencies." "2.7. Process for updating the Operating Plan within 30 days of any changes not of an administrative nature. This includes updates to reflect any lessons learned as a result of an exercise or actual event." Remove requirement 2.8 and move content to requirement 2.7. "2.8. Process for updating the Operating Plan within 30 days of publication the NERC annual report of lessons learned." Add "2.9. Process to ensure updates are communicated to personnel responsible for under the Operating Plan within 30 days of the change being completed."

No

ERCOT ISO recommends the use of "Registered Entity" in place of "Applicable Entity". This would provide consistency with other requirements and Attachment 1. The measure for this requirement notes the obligation for "documentation". This is not addressed in the requirement. The measure also notes "on its Facilities". This clarification of scope should be addressed in the requirement. R3. Each Registered Entity shall identify, assess, and document initial probable cause of impact events on its Facilities listed in Attachment 1.

No

ERCOT ISO believes that a drill or exercise of its Operating Plan is unnecessary. The intent of the drill can be addressed within the training requirements under R5.

Yes

ERCOT ISO believes the content of training can include an exercise or drill.

No

ISO recommends the following changes to the language of the requirement. R6. Each Applicable Entity shall report impact events in accordance with Attachment 1.

No

Recommend that the Electric Reliability Organization be removed. The Electric Reliability Organization should not be responsible for reliability functions and therefore should be excluded from reliability standards.

No

ERCOT ISO requests the reporting timeframes be changed to reflect a 24 hour requirement for all events in Attachment 1. During an impact event, operating personnel are generally involved in event resolution and not available immediately to submit reports. ERCOT ISO requests that the "Detection of a cyber intrusion to a critical cyber asset" be removed. There are established processes defined for incident response supporting CIP-008. By including this element in Attachment 1, the Operating requirement R2 would also require procedure documents for cyber security incident response. This would be redundant and would remove the responsibility away from the subject matter experts for cyber security incident response.

No

ERCOT ISO requests the use of a single report format to meet all requirements from NERC and DOE. There is no value added in requiring different reporting to different agencies.

No

Yes

Yes

Yes

Yes

ERCOT ISO supports the comments provided by the SRC. However, if the standard is to be established, ERCOT ISO has offered the comments contained herein as improvements to the requirements proposed. The requirements listed do not take into consideration the hierarchical reporting necessary for events (i.e.: GO to GOP to BA). The current structure will lead to redundant and conflicting reporting from multiple entities. This will lead to confusion in the analysis of the event. Any system developed and used to report impact events must include notification to the other relevant entities (i.e.: Reliability Coordinator, Balancing Authority, Transmission Operator, and Generator Operator). The proposed standard should not rely on a centralized system that does not follow the established hierarchy of dissemination of information.

Individual

Terry Harbour

MidAmerican Energy
Yes
No
While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an energy emergency requiring public appeals?
No
No
R2 and R5 coupled with R8 will drive quarterly updates (in addition to drills, etc) and training to the literally hundreds to thousands of people per company for the proper internal operating personnel and management will actually hurt the development of a culture of compliance by overwhelming personnel with constant plan changes and training. The standards drafting team should remove all 30 day references or provide the technical basis of why revising plans and training to "changes and lessons learned" quarterly all within 30 days is the right use of reliability resources to improve the grid. The addition of the 30 day constraints and new vague criteria in Attachment one such as "damage to a BES element through and external cause" or "transmission loss of multiple BES elements which could mean two or more" is the opposite of clear standards writing or results based standards. We disagree with requiring an Operating Plan for identifying, assessing, and reporting impact events. This is an administrative requirement that has no clear reliability benefit. Furthermore, it is questionable that event reporting even meets the basic definition of an Operating Plan. Per the NERC glossary of terms, Operating Plans contain Operating Procedures or Operating Processes which encompass taking action real-time on the BES not reporting on it. As detailed in R2, the Operating Plan shall contain provisions for "identifying, assessing, and reporting impact events". R2.8, and R2.9 do not have a correlation to R2's Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change, the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in the components of an entity's Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the words "lessons learned" would be required to be in your Operating Plan. It is solely up to an entity to implement a "Lesson Learned" and not the place for this SDT to require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. In R2.8 & R2.9, It may be difficult to implement lessons learned within 30 days. The NSRS recommends to incorporate lessons learned within 12 calendar months if lesson learned are not deleted from the R2.8 & R2.9.
No
No
No
: R5.2. The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be trained once per calendar year. R5.3 As detailed in R2, the Operating Plan shall contain provisions for "identifying, assessing, and reporting impact events". Where, R2.7 states to update the Operating We disagree with the need to provide formal training. We could agree with the need to communicate to System Operators and other pertinent personnel the criteria for reporting so that they know when system events need to be reported.
No
We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
Yes
No
New vague criteria in Attachment one such as "damage to a BES element through and external cause" or "transmission loss of multiple BES elements which could mean two or more" is the opposite of clear standards writing or results based standards.
No
Yes
Yes

Yes
Yes
This entire standard needs to be revised to consider a results based standard.
Individual
Michael Gammon
Kansas City Power & Light
Yes
Yes
Consideration should be given to the need for a preliminary impact event report to be filed by the Reliability Coordinator and the Registered Entity. If two reports should be filed, should they both contain the same information.
Yes
Although we support situational awareness for the other registered entities, impact event reports should be distributed anonymously to communicate the information while protecting the registered entity.
No
We agree with the rationale for R8 requiring NERC to analyze Impact Events that are reported through R6 and publish a report that includes lessons learned but disagree with R2.9 obligating an entity to update its Operating Plan based on applicable lessons learned from the report. Whether lessons learned are applicable to an entity is subjective. If an update based on lessons learned from an annual NERC report is required, the requirement should clearly state the necessity of the update is determined by the entity and the entity's Reliability Coordinator or NERC can not make that determination then find the entity in violation of the requirement. In addition, if an update based on lessons learned from a NERC report is required, NERC should publish the year-end report (R8) on approximately the same day annually (i.e. January 31) and allow an entity at least 60 days to analyze the report and incorporate any changes it deems necessary in its Operating Plan. In addition, the language using quarterly and annual as a requirements between R2.9 and R8 is confusing.
No
We believe R3 and M3 are unnecessary as a stand alone requirement and measure and propose combining this requirement and measure with R6 and M6. Identifying and assessing the initial probable cause of an impact event is the obvious starting point in the reporting process and ultimate completion of the required report. Evidence to support the identification and assessment of the impact event and evidence to support the completion and submittal of the report are really one in the same.
No
We believe R4 and M4 are clearly unnecessary. Thoughtful preparation of an Operating Plan per R2 that specifically addresses personnel responsibilities and appropriate evidence gathering combined with the training requirement in R5 is sufficient.
No
We agree with the need for the Operating plan and the provision of formal training to impacted personnel. We believe that the personnel references are too open-ended to be productive and measurable. This leaves all applicable entities open to subjectivity in assessment and may produce a large administrative burden to demonstrate compliance with no associated benefit to improved reliability.
No
We believe R3 and M3 are unnecessary as a stand alone requirement and measure and propose combining these requirements with R6 and M6. Identifying and assessing the initial probable cause of an impact event is the obvious starting point in the reporting process and ultimate completion of the required report. Evidence to support the identification and assessment of the impact event and evidence to support the completion and submittal of the report are really one in the same.
No
We agree with the rationale for R8 requiring NERC to analyze Impact Events that are reported through R6 and publish a report that includes lessons learned but disagree with R2.9 obligating an entity to update its Operating Plan based on applicable lessons learned from the report. Whether lessons learned are applicable to an entity is subjective. If an update based on lessons learned from an annual NERC report is required, the requirement should clearly state the necessity of the update is determined by the entity and the entity's Reliability Coordinator or NERC can not make that determination then find the entity in violation of the requirement. In addition, if an update based on lessons learned from a NERC report is required, NERC should publish the year-end report (R8) on approximately the same day annually (i.e. January 31) and allow an entity at least 60 days to analyze the report and incorporate any changes it deems necessary in its Operating Plan. Again, the language referencing annual and quarterly in these two requirements is confusing.
No

We agree with the event descriptions listed in Attachment 1 and the review and revision of the impact table by the ERO is appropriately addressed in R7 but the time periods allowed to complete the new, longer preliminary report is insufficient. The correlation of this with the timing of the reporting quarterly and annually or pushing information for other entities' situational awareness does not allow the registered entity adequate time to thoughtfully consider the event and proposed root cause.

No

For easier classification and analysis of events for both external reporting to the ERO and internal reporting for the applicable entity, the form should include Event Type. The DSR SDT should code each event type and include the codes as part of Attachment 1.

Yes

Should the word disturbance be removed from the title of EOP004-2 to avoid confusion and simply be called Impact Event and Assessment, Analysis and Reporting.

Yes

No

April 2011 is too soon for considerations applicable to the creation of an Operating Plan.

Yes

The standard addressed a preliminary report it should also address the requirements of a final report.

Group

Southern Company - Transmission

J T Wood

No

We find it interesting that the ERO is listed as an applicable entity. The ERO is responsible for multiple requirements in this standard that shapes the ultimate actual rules that the other applicable entities would be required to meet. Can the NERC/ERO be accountable for a feedback loop to the industry? Feedback is preferable but would NERC/ERO self-report a violation to the requirement?

Yes

We do have one concern in that we are hopeful that NERC will develop a system that will allow a one stop shop of reporting.

No

The Operating Plan has a different connotation for different operations folks. We suggest that we call it an Impact Event Reporting Plan.

Yes

Yes

No

We suggest that the time frame be changed to 60 or 90 days in 5.3. 5.4 needs to have a time frame associated with it; we suggest that it be 60 or 90 days.

No

The time to submit report column needs to be more flexible with time frames.

Yes

No

The time to submit report column needs to be more flexible with time frames. The Entity with Reporting Responsibility column needs to be more descriptive in which there are multiple entities with hierarchy reporting.

Yes

Yes

Yes

Yes

Yes

The only concern that we have with the proposed standard is that it feels like it is creating dual, not quite redundant, reporting requirements for cyber intrusions in concert with CIP-008. Hopefully, there will not have to be a redundant reporting requirement if we continue to merge efforts with the CIP Drafting Team. Since we will no longer use the word SABOTAGE in the new EOP-004, we are hoping the industry and the CIP Drafting Team will give us the criteria they wish for us to use in order to report CIP-008 incidents. We will then achieve a "ONE STOP SHOP" reporting standard.

Individual

Ron Gunderson

Nebraska Public Power District

No

The background states there is no real-time reporting requirement in this standard, but the purpose states a purpose is for situational awareness. This implies real-time reporting. The purpose clearly identify the standard is for after the fact reporting to permit analysis of events, trend data, and identify lessons learned.

Yes

Yes

Yes

No

Since the reporting under this standard is for after the fact reporting, the minimum time to report should be the end of the next business day. The combination of the extremely short time periods to file a report and the amount of detail required in attachment 2 will lead to a reduction in the reliability of the BES. System Operators will be forced to take focus off their primary responsibility to respond to the event in order to complete the report within the required timeframe (within an hour for some events). During non-business hours the only personnel available to complete the reports will be those responsible for real-time operation of the BES. Since the background indicates this standard is only for after the fact reporting, the minimum required time to submit the report should be one business day to permit completion of the report without distracting from the real-time operation of the BES. Real-time reporting requirements are covered in other standards and should be to the Reliability Coordinator and from the Reliability Coordinator to NERC. For after the fact reporting, there is absolutely no reliability benefit for requiring reporting to be completed on such a short timeframe. This is especially true due to the amount of data required by Attachment 2.

No

If the standard requires submission of the report within an hour (which is not appropriate), there must be an abbreviated form that can be quickly filled out by checking boxes and not require substantial narrative. The existing form has too much free form text that takes time to enter and with the short timeframe for reporting will distract the entities responsible for real-time reliability of the BES from that task by forcing them to complete after the fact reports. It is unrealistic to expect entities to staff personnel to complete the reporting 24 x 7 for unlikely events, so the task will fall to System Operators who should be focusing on operating the BES at the time of these events instead of providing after the fact reporting to entities that do not have responsibility for real-time operation of the BES. Real-time reporting to the RC and/or BA is covered under other standards and is necessary for the RC to have situational awareness, but is not covered under this standard. The registered entities may report to the proper law enforcement entities when the situation warrants, but again this form is not the appropriate way to handle that reporting requirement.

Yes

I agree there is a lot of interpretation and confusion as to what sabotage or a Cyber Incident is, so would welcome better clarity. Whether "impact events" can more effectively clarify, is yet to be seen. "it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation." "An impact event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences." I do know that Cyber Sabotage may take time or days to become aware so not sure how that might expedite reporting and awareness.

Yes

Appears they only changed R1 for CIP-001 and moving R2-R4 directly over to EOP-004-2. R1 adds much more detail on our part for a company operating plan but would definitely help some of the present confusion.

Individual

Dan Rochester
Independent Electricity System Operator
No
(1) Our understanding of the proposed revision as conveyed in the SAR was to provide clarity and reduce redundancy on reporting the latest and even on-going events on the system that may be caused by system changes and/or sabotage. The intent is to ensure the proper authorities are informed of such events so that they may take appropriate and necessary actions to identify causes and/or mitigate or limit the extent of interruptions. We also supported a suggestion in the SAR to assess the merit of merging CIP-001 and EOP-004 to remove redundancy, although we suggested that this should not be a presumption when revising the standard(s). This posting appears to indicate that only EOP-004 will be revised at this time, and CIP-001 which deals with sabotage reporting will remain in effect. With this assumption, the proposed standard appears to contain a mixture of reporting two types of events of different time frame – the first type being those events that need to be reported soon or immediately after they occur (e.g. impact events that appear to be the result of a sabotage) with an aim to curb/contain these events by the appropriate authorities; the second type being the events that can be reported sometime well after the fact, e.g. system disturbances due to weather or switching or other known causes that are not of malicious nature. Combining the two types of requirement does not appear to be clearly conveyed in the SAR. We therefore suggest the SDT review the main purpose and content in the proposed EOP-004 to ensure consistency with the SAR, and in relation to the purpose and requirements already contained in CIP-004. (2) With respect to disseminating reports and related information after the fact, we wonder if a data collection process, such as RoP 1900, can serve the purpose without having to create a standard or a requirement to achieve this. (3) Most of the requirements appear to be administrative in nature and they stipulate the how but not the what, which in our view does not conform with the Results-based standard concept and does not rise to the level of a reliability standard. (4) A number of requirements proposed in the draft standard are quite vague and cannot be measured. Details of this assessment is provided below.
No
We do not agree with the inclusion of TO and GO. They are not operating entities and do not need to collect or provide information pertaining to impact events, which are the results and phenomena observe under operating conditions in the operation horizon, and such information collection and provision are the responsibility of the TOP and GOP.
No
R1 does not directly convey the need for reporting. The requirement could be written to require the responsible entities to report impact events to the ERO using a process to be described in the standard and according to a set of reporting criteria. Whether or not there is a “system” makes little difference if it complies with the requirement to provide the reports on time. In addition, an ERO established system which, without being included in the standard and posted for public comment and eventually balloted, may not be acceptable to the entities that are responsible for reporting to the ERO. Further, a reliability standard should not need to bother with how the ERO disseminate this information to applicable government, provincial or law enforcement agencies. This is the obligation of the ERO and if required, can be included in the Rules of Procedure.
No
R2 is not needed. An entity does not need to have an “operating plan” to identify and report on impact events; it needs only to report on the events listed in Attachment 1 in a form depicted in Attachment 2. How does the entity do this, and whether or not an operating plan is in place, or whether its staff is trained to provide the report should not need to be included in a reliability standard for so long as the responsible entity provides the report in the required form on time. If the responsible entity fails to report the listed events in the depicted format, it will be found non-compliant, and that’s it – no more and no less. If the “operating plan” really means an established data collection and reporting procedure, then the requirement should be revised to more clearly convey the intent.
No
We agree that the responsible entity needs to identify and assess initial probable cause of impact events but not in accordance with any operating plan in R2. Each operating entity (RC, BA, TOP) has an inherent responsibility to identify the cause of any system events to ensure it complies with a number of related operational standards. R3, in fact, could be revised to require the Responsible Entity to include the probable cause of impact events in its report, rather than asking it to “identify and assess” since this is not measurable. Also, the ERO may be removed from the Applicability Section depending on the response to our comments under Q9.
No
Along the line of our comments on R2 for an operating plan (whose need we do not agree with), a drill, exercise, or Real-time implementation of the Operating Plan for reporting is also not necessary.
No
Along the line of our comments on R2 for an Operating Plan (whose need we do not agree with), any training on developing and providing the report is unnecessary. What matters is that the report is provided to the needed organizations or entities on time and in the required format according to established procedure. How this is accomplished goes outside of the purpose of reliability standard requirements.
No
We agree with having a requirement to report impact events in accordance with the timelines outlined in Attachment 1.

but not with the requirements indicated in R2.
No
We agree with the need to update the list as needed, but it does not have to be the ERO who takes on a reliability standard to do so. It can simply be an annual project in the standards development work plan to review Attachment 1 as part of a standard. The industry will then be provided an opportunity to weigh on the changes. Also, we do not see the reliability results or benefits of R8. The ERO can issue the report quarterly but who are audiences? What reliability purpose does it serve if no further actions are pursued upon receiving the report? Can this be done as a standing item for the ERO at, say, the BoT meeting? Or, can this be a part of the quarterly communication from the ERO to the industry? To make this a reliability standard is an over-kill, and does not conform with the results-based standard concept. From our perspective, both R7 and R8 can be removed, and the ERO can be removed from the Applicability Section as well.
No
We do not support the 1 hour reporting time frames for Emergency Energy, System Separation, unplanned Control Center evacuation, Loss of off-site power, Loss of monitoring or voice communication. Energy emergency is broadcast on the RCIS which also goes to the ERO so its explicit reporting is not necessary (System Operations please verify). During other events listed above, the responsible entities will likely be concentrating its effort in returning the system to a stable and reliable state. Reporting to anyone not having direct actions to control, mitigate and contain the disturbances is secondary to restoring the system to a reliable state. Since these are after the fact reports for awareness and/or analysis and not for real-time responses, these can be reported at a later time, up to 24 hours after the initial occurrence without any detriment to reliability, or at the very earliest: up to 1 hour after the system has returned to a reliable state, or after the backup control centre is fully functional, or after backup power is restored to the nuclear power plant, or after monitoring or voice communication is restored.
TBD
We do not have a view on what name is assigned to the reportable events for so long they are listed in Attachment 1. However, the heading of the Table contains the words "Actual Reliability Impact", which does not accurately reflect the content inside the table and which may introduce confusion with the term "impact event". We suggest to change them to "Reportable Impact Events". As we read the Summary of Concept and Assumption, there appears to be a slightly different lists at the bottom of P. 21. With these events included, the meaning of "impact event" would seem to be too broad. Rather than calling those events listed in Attachment 1 "impact events", why not simply call them "reportable events"?
No
We do not agree with the mapping. The proposed mapping attempts to merge the reporting in CIP-001-1 which has more of an on-going awareness nature to alert operating and government authorities of suspected sabotage to prompt investigation with a possible aim to identify the cause and develop remedies to curb the sabotage/events. The proposed EOP-004-2 appears to be more of a post-event reporting for need-to-know purpose only. This is not consistent with the purpose of the SAR.
We do not agree with the proposed standard. We therefore are unable to agree on any implementation plan.
No
Individual
Catherine Koch
Puget Sound Energy
Yes
However, further definition of "known causes" would be helpful as sometime the root cause analysis doesn't uncover the actual cause for sometime after the timeframes outlined in Attachment 1.
Yes
No
The language of R1 and M1 does not support the DSR SDT's goal of having a single form and system for reporting. The standard should specify the form and system rather than deferring that decision to the ERO. The language of R1 and M1 leaves the form and system to the ERO's discretion, which could lead to multiple forms and frequent revisions to them. This would lead to difficulties in tracking the reporting requirements. In addition, it is impossible to comment intelligently regarding the overall impact of the proposed standard and its requirements and measures without the reporting form and system being specified in the standard.
No
While the concept of an operating plan is reasonable, the requirements for update in sections 2.7, 2.8 and 2.9 will lead to an immense amount of work for the entities subject to the standard. In addition, constant revisions to the operating plan makes it difficult to cement a habit through this procedure. The proposed update schedule does not strike the appropriate balance between the need to respond to lessons learned and the value of plan continuity.
Yes

However, this requirement doesn't address the timing required for this analysis. This may be intentional and appreciated because at times the analysis can take months when the events are complex in nature.
Yes
No
The fact that proposed requirement R2 will require frequent updates to the operating plan means that the training required under this plan will occur quite frequently as well, leading to operator confusion. Even the comment allowing a review and "sign-off" will not completely mitigate this result.
Yes
It is assumed that for the purposes of M6, NERC and the regions would already have access to these reports.
No
This is adequately covered by section 802 of the Rules of Procedure. There seems to be some conflict between R2.9 and R8 regarding timeframes and the specific elements required.
No
The proposed standard does not adequately ensure that the impact events subject to its requirements are limited to those listed in Attachment 1. In order to ensure that this is true, the term "impact event" should be a defined term and that definition should clearly limit impact events to those listed in Attachment 1.
No
Attachment 2 is not referenced in the requirements of the proposed standard. As a result, it is not clear when its submission would be required.
No
With some of the tight timeframes for reporting, it is reasonable to focus on impact rather than motivation. Requiring further analysis of the event in order to assess the possibility that the event was caused by sabotage, however, may be necessary to address FERC's concerns with respect to sabotage.
Yes
No
There are no effective dates listed in the proposed standard. The proposed effective date should allow at least one year for entities to implement the requirements of the standard. In addition, if requirement R1 remains, then the requirement to implement an operating plan should only be triggered by the ERO's finalization of the form and system for reporting impact events and should provide at least six months for the implementation of the operating plan.
Yes
The DSR SDT's concepts for implementing a new structure for reporting are appropriate. Proper implementation of those concepts is likely to result in a very much improved standard. However, the proposed standard falls well short of implementing the concepts and is not much of an improvement on the current standard.
Group
Midwest ISO Standards Collaborators
Jason L. Marshall
Yes
No
While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an energy emergency requiring public appeals?
Yes
No
We disagree with requiring an Operating Plan for identifying, assessing, and reporting impact events. This is an administrative requirement that has no clear reliability benefit. Furthermore, it is questionable that event reporting even meets the basic definition of an Operating Plan. Per the NERC glossary of terms, Operating Plans contain Operating Procedures or Operating Processes which encompass taking action real-time on the BES not reporting on it. What is an impact event? It appears that this undefined, ambiguous term was substituted for sabotage which is also undefined and ambiguous. One of the SARs stated goals was to "provide clarity on sabotage events". This does not provide clarity.
No
While we agree that it makes sense to report on the cause of an event, we disagree with the need for an Operating Plan as identified in R2.



No
We disagree with the need to conduct a drill for reporting.
No
We disagree with the need to provide formal training. We could agree with the need to communicate to System Operators and other pertinent personnel the criteria for reporting so that they know when system events need to be reported.
No
We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
No
We do not agree with the requirements and we do not believe it is adequately covered in section 802. First, section 802 deals with assessments not event reporting. Secondly, since attachment 1 is part of a standard, it should not be modified outside of the Reliability Standards Development process.
No
Several categories require duplicate reporting. For instance, the first three categories regarding energy emergencies could be interpreted to require the BA and RC to both report. The reporting responsibilities in this table should be clarified based on who has primary reporting responsibility for the task per the NERC Functional Model and require only one report. For instance, since balancing load, generation and interchange is the primary function of a BA per the NERC Functional Model, only the BA should be required to provide this report. As another option, perhaps the registered entity initiating the action should submit the report. If the BA did not take action and the RC had to direct the BA to take action, one could argue that perhaps the RC should submit the report then. However, if the BA takes action appropriately on their own, the BA should submit it. If the TOP reduces voltage for a capacity and energy emergency per a directive of the BA, then the BA should report the event.
No
This form differs from the DOE reporting forms. We do not believe different reporting forms should be required. The DOE form should be sufficient for NERC reporting. It is not clear what benefit providing the Compliance Registration ID number provides. Many of the registered entities employees that will likely have to submit the report, particularly given the one-hour reporting requirement for some impact events, will not be aware of this registration ID. However, they will know for what functions they are registered. We recommend removing the need to enter this compliance registration ID or extending the time frame for reporting to allow back office personnel to complete the form. For item two, please change "Time/Zone:" with "Time (include time zone)". As written it is a little confusing.
No
We believe the SAR scope regarding addressing sabotage has not been addressed at all. It appears that impact event essentially replaces sabotage. This standard needs to make it clear that sabotage, in some cases, cannot be identified until an investigation is performed by the appropriate policing agencies such as the FBI. Intent plays an important role in determining sabotage and only these agencies are equipped to make these assessments.
No
It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than in the existing standards.
Yes
Yes
We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting.
Group
IRC Standards Review Committee
Ben Li
No
The proposed requirements in the standard are not focused on the core industry concern that current requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, "The existing requirements need to be revised to be more specific – and there needs to be more clarity in what sabotage looks like." Instead this proposed standard includes requirements that are more focused on "how" to report, rather than "what" to report. The SAR states that: "The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards." The SRC believes the scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of

sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seem helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting team seems to be ignored, "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard.

No

Entities that have information about possible sabotage events should report these to NERC after the fact and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an EEA for example?

Yes

Note that ERCOT does not sign on to this particular comment.

No

The SRC suggests that this is not, in fact, an Operating Plan. At most, it may be a reporting plan or reporting procedure. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure bulk power reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. The Operating Plan requirements as proposed seem only to be suitable for real-time notifications. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Unlike the real-time operating notifications which have relatively short reporting time frames, there is sufficient time for personnel to make appropriate communications within their organizations to make timely after the fact reports under NERC Section 1600 authority. Would it be feasible for NERC to issue a standing requirement for timely after-the-fact reports under NERC Section 1600 authority?

No

Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes quite some time for an actual cause to be determined. The determination process may require a root cause analysis of some complexity. Further, in the case of suspected or potential sabotage, the industry can only say it doesn't know, but it may be possible. It really is the law enforcement agencies who make the determination of whether sabotage is involved and the info may not be made available until an investigation is completed, if indeed it is ever made available.

No

Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are really training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in a short time frame as may be required for real-time operating notifications.

No

We do not agree with the need for R5. We do not see the need for a standard requirement that stipulates training the personnel on reporting events. What matters is that the reports are provided to the needed organizations or entities on time and in the required format according to established procedure. Stipulating a training requirement to achieve this reporting is micro-managing and overly prescriptive.

No

There is not a need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations.

No

We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.

No

We do not agree with the requirement to report "detection of a cyber intrusion to critical cyber assets" as this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. We suggest that physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.

No

Attachment 2 is not referenced in the standard requirements. Is it a part of the standard that an entity must use to file the impact event reports to a specific recipient. If so, this needs to be referenced in the standard. We question the need for using a fixed format for reports that vary from "shedding firm load" to "damaging equipment". The nature of impact events varies from one event to another and hence a fixed format or pre-determined form may not be able to provide

the appropriate template that is suitable for use for all events. We urge the SDT to reconsider the use of Attachment 2 for reporting events, with due consideration to the actual intent of the standard (as pointed out in our comments under Q1).
No
This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement's and other specialized agencies', including international agencies', role in defining acts of sabotage and not hold the registered entity wholly responsible to do so.
No
If the training and Operation Plan requirements are adopted as proposed, this may not be sufficient time for some entities to comply, particularly those with limited number of staff but perform functions that have multiple event reporting requirements.
No
The standards should be changed to define what a "disturbance" is for reporting in EOP-004. Also, sabotage reporting requirements in CIP-001 should be rescinded as EOP-004 already has such requirements.

## Consideration of Comments on Disturbance and Sabotage Reporting — Project 2009-01

The Disturbance and Sabotage Reporting Drafting Team thanks all commenters who submitted comments on its preliminary draft of EOP-004-2 – Impact Event and Disturbance Assessment, Analysis, and Reporting. This standard was posted for a 30-day informal comment period from September 15, 2010 through October 15, 2010. Stakeholders were asked to provide feedback on the standard through a special Electronic Comment Form. There were 60 sets of comments, including comments from more than 175 different people from approximately 100 companies representing 9 of the 10 Industry Segments as shown in the table on the following pages.

In this report, the comments have been sorted by question number so that it is easier to see where there is consensus. The comments are posted in their original format on the following project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

Based on stakeholder comments, and also on the results of the observations made by the Quality Review team, the drafting team made the following significant changes to the standard following the posting period that ended on October 15, 2011.

**Scope:** A common thread through most of the comments was that the DSR SDT went beyond the reliability intent of the standard (reporting) and concentrated too much on the analysis of the event. The DSR SDT agrees with this response, and revised the purpose as follows:

*Original Purpose:* Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES).

*Revised Purpose:* To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.

### Definitions:

**Impact Event:** The DSR SDT had proposed a working definition for “impact events” to support EOP-004 - Attachment 1 as follows:

“An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

Many stakeholders indicated that the definition should be added to the NERC Glossary and the DSR SDT adopted this suggestion.

The types of Impact Events that are required to be reported are contained within EOP-004 - Attachment 1. Only the events identified in EOP-004 – Attachment 1 are required to be reported under this Standard.

**Sabotage:** FERC Order 693, paragraph 471 states in part: “. . . the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide

guidance as to the triggering events that would cause an entity to report a sabotage event.”

The DSR SDT made a conscious, deliberate decision to exclude a strict definition of sabotage from this standard and sought stakeholder feedback on this issue. Some suggested adopting the NRC definition of the term sabotage, and the DSR SDT did consider adopting the NRC definition shown below but determined that the definition is too narrowly focused.

Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.

Most respondents agreed that in order to be labeled as an act of sabotage, the intent of the perpetrators must be known. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This would result in further ambiguity with respect to reporting events, and the timeline associated with the reporting requirements does not lend itself to the in-depth analysis required to identify a disturbance (or potential disturbance) as sabotage. The SDT felt that a likely consequence of having to meet this criterion, in the time allotted, would be an under-reporting of events. Accordingly, all references to sabotage have been deleted from the standard.

Instead, the SDT concentrated on providing clear guidance on the events that should trigger a report. The SDT believes that this more than adequately meets the reliability intent of the Commission as expressed in paragraph 471 of Order 693 in an equally efficient and effective manner.

**Situational Awareness versus Industry Awareness:** Some commenters correctly pointed out that “situational awareness” is a desirable by-product of an effective event reporting system, and not the driver of that system. Accordingly, all references to “situational awareness” have been deleted from the standard. The more generic “industry awareness” has been substituted where appropriate.

### **Applicability:**

The DSR SDT had protracted discussions on the applicability of this standard to the LSE. Per the Functional Model, the LSE does not own assets and therefore should not be an applicable entity (no equipment that could experience a “disturbance”). However, the Registry Criteria contains language that could imply that the LSE does own assets, or is at least responsible for assets. In addition, the DSR SDT modified Attachment 1 to include reporting of damage or destruction of Critical Cyber Assets per CIP-002. The LSE, as well as the Interchange Authority and Transmission Service Provider are applicable entities under CIP-002 and should be included for Impact Events under EOP-004.

There were several comments that the asset owners (GO/TO) would be less likely than the asset operators (GOP/TOP) to be aware of an impact event. The DSR SDT recognizes that this may be true in some cases, but not all. In order to meet the reliability objectives of this requirement, the applicability for GO/TO will remain as per Attachment 1.

**Requirement R1:**

Based on stakeholder comments, Requirement R1, which assigned the ERO the responsibility for collecting and distributing impact event reports was deleted. There was strong support for a central system for receiving and distributing impact event reports (a/k/a one stop shopping). There was general agreement that NERC was the most likely, logical entity to perform that function. However several respondents expressed their concern that the ERO could not be compelled to do so by a requirement in a Reliability Standard (not a User, Owner or Operator of the BES). In their own comments, NERC did not oppose the concept, but suggested that the more appropriate place to assign this responsibility would be the NERC Rules of Procedure. The DSR SDT concurs. The DSR SDT has removed the requirement from the standard and is proposing to make revisions to the NERC Rules of Procedure as follows:

812. NERC will establish a system to collect impact event reports as established for this section, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, and regulatory agencies as necessary. These reports shall be forwarded to the Federal Energy Regulatory Commission for impact events that occur in the United States. The ERO shall solicit contact information from Registered Entities appropriate governmental, law enforcement and regulatory agencies for distributing reports.

**Requirement R2 (now R1 in the revised standard):**

There were objections to the use of the term “Operating Plan” to describe the procedure to identify and report the occurrence of a disturbance. The DSR SDT believes that the use of a defined term is appropriate and has revised Requirement R1 to include Operating Plan, Operating Process and Operating Procedure.

Many commenters felt that the requirements around updating the Operating Plan were too prescriptive, and impossible to comply with during the time frame allowed. The DSR SDT agrees, and Requirement R2, Parts 2.5 through 2.9 have been eliminated. They have been replaced with Requirement R1, Part 1.4 to require updating the Impact Event Operating Plan within 90 days of any change to content.

**R1.** Each Responsible Entity shall have an Impact Event Operating Plan that includes: *[Violation Risk: Factor Medium] [Time Horizon: Long-term Planning]:*

- 1.1. An Operating Process for identifying Impact Events listed in Attachment 1.
- 1.2. An Operating Procedure for gathering information for Attachment 2 regarding observed Impact Events listed in Attachment 1.
- 1.3. An Operating Process for communicating recognized Impact Events to the following:
  - 1.3.1 Internal company personnel notification(s).

1.3.2. External organizations to notify to include but not limited to the Responsible Entities' Reliability Coordinator, NERC, Responsible Entities' Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.

1.4. Provision(s) for updating the Impact Event Operating Plan within 90 days of any change to its content.

Other requirements reference the Operating Plan as appropriate. The requirements of EOP-004-2 fit precisely into the definition of Operating Plan:

Operating Plan: A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.

**Requirement R3 (now R2 in the revised standard):**

Requirement R3 has been re-written to exclude the requirement to “assess the initial probable cause”. The only remaining reference to “cause” is in the Impact Event Reporting Form (Attachment 2). Here, there is no longer a requirement to assess the probable cause. The probable cause only needs to be identified, and only if it is known at the time of the submittal of the report.

R2. Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B). *[Violation Risk: Factor Medium] [Time Horizon: Real-time Operations and Same-day Operations]*

**Requirement R4 (now R3 in the revised standard):**

The DSR SDT did a full review based on comments that were received. R3 now is stream lined to read:

R3. Each Responsible Entity shall conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 months between such tests. .

The testing of the Operating Process for communicating recognized Impact Events (as stated in R1) is the main component of this requirement. Several commenters provided input that too much “how” was previously within R3 and the DSR DST should only provide the “what”. The DSR SDT did not provide any prescriptive guidance on how to accomplish the required testing within the rewrite. Testing of the entity’s procedure (R1) could be by an actual exercise of the process (testing as stated in FERC Order 693 section 471), a formal review process or real time implementation of the procedure. The DSR SDT reviewed Order 693 and section 465 directs that processes are “verify that they achieve the desired result”. This is the basis of R3, above.

**Requirement R5 (now R4 in the revised standard):**

The DSR SDT did a full review based on comments that were received. The major issues that

were provided by commenters involved the inclusion of Requirement R5, Part 5.3 and Part 5.4.

- 5.3 If the Operating Plan is revised (with the exception of contact information revisions), training shall be conducted within 30 days of the Operating Plan revisions.
- 5.4 For internal personnel added to the Operating Plan or those with revised responsibilities under the Operating Plan, training shall be conducted prior to assuming the responsibilities in the plan.

Upon detailed review the DSR SDT agrees with the majority of comments received regarding Requirement R5, Parts 5.3 and 5.4 and has removed Parts 5.3 and 5.4 completely from the Standard. Training is still the main theme of this requirement (now R4) as it pertains to the personnel required to implement the Impact Event Operating Plan (R1).

R4 now is stream lined to read:

- R4. Each Responsible Entity shall review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan at least annually with no more than 15 calendar months between review sessions

**Requirement R6 (now R5 in the revised standard):**

The DSR SDT did a full review based on comments that were received. Many comments received identified concerns on the reporting time lines within Attachment 1., Several commenters wanted the ability to report impact events to their responsible parties via the DOE Form OE-417. Upon discussions with the DOE and NERC, the DSR SDT has added the ability to use the DOE Form OE-417 when the same or similar items are required to be reported to NERC and the DOE. This will reduce the need to file multiple forms when the same or similar events must be reported to the DOE and NERC. The reliability intent of reporting impact events within prescribed guidelines, to provide industry awareness and to start any required analysis processes can be met without duplicate reporting R5 now is stream lined to read:

- R5. Each Responsible Entity shall report Impact Events in accordance with its Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form.

**Requirements R7 and R8:**

The DSR SDT did a full review based on comments that were received. The DSR SDT has determined that R7 and R8 are not required to be within a NERC Standard since Section 800 of the Rules of Procedure already assigns this responsibility to NERC.

**Attachment 1:**

The DSR SDT did a full review based on comments that were received. The DSR SDT, the Events Analysis Working Group (EAWG), NERC Staff (to include NERC Senior VP and Chief Reliability Officer) had an open discussion involving this topic. The EAWG and the DSR SDT aligned Attachment 1 with the Event Analysis Program category 1 analysis responsibilities. This will assure that impact events in EOP-004-2 reporting requirements are the starting vehicle for any required Event Analysis within the NERC Event Analysis Program. The DSR SDT reviewed the “hierarchy” of reporting within Attachment 1. To reduce multiple entities reporting the same impact event, the DSR SDT has stated that the entity that performs the action or is directly



affected by an action will report per EOP-004-2. As an example, during a system emergency, the TOP or RC may request manual load shedding by a DP or TOP. The DP or TOP would have the responsibility to report the action that it took if it meets or exceeds the bright-line criteria established in Attachment 1. Upon reporting, the NERC Event Analysis Program would be made aware of the impact event and start the Event Analysis Process which is outside the scope of this Standard. Several bright-line criteria were removed from Attachment 1. These criteria (DC converter station, 5 generator outages, and frequency trigger limits) were removed after discussions with the EAWG and NERC staff, who concurred that these items should be removed from a reporting standard and analysis process.

Several respondents expressed concern that the reporting requirements were redundant. The general sentiment was that unclear responsibility to report a disturbance could trigger a flood of event reports. Attachment 1 has been modified to assign clear responsibility for reporting, for each category of Impact Event.

Some commenters indicated a concern that the list of events in Attachment 1 isn't as comprehensive as the existing standard since the existing standard includes bomb threats and observations of suspicious activities. Others commented that the impact event list should include deliberate acts against infrastructure. The DSR SDT believes that "observation of suspicious activity" and "bomb threats" are addressed in Attachment 1 Part B – "Risk to BES equipment from a non-environmental physical threat". The SDT has added the phrase, "and report of suspicious device near BES equipment" to note 3 of the "Attachment 1, Potential Reliability – Part B" for additional clarity.

**Attachment 2:**

The proposed Impact Event Report (Attachment 2) generated comments regarding the duplicative nature of the form when compared to the OE-417. The DSR SDT has added language to the proposed form to clarify that NERC will accept a DOE OE-417 form in lieu of Attachment 2 if the responsible entity is required to submit an OE-417 form.

In collaboration with the NERC Event Analysis Working Group (EAWG) the DSR SDT modified the attachment to eliminate confusion. This revised form will be Attachment 2 of the Standard and collects the only information required to be reported for EOP-004-2. Further information may be requested through the Events Analysis Process (NERC Rules of Procedure), but the collection of this information is outside of the scope of EOP-004.

The DSR SDT has also clarified what the form's purpose with the following addition to the form:

"This form is to be used to report impact events to the ERO."

**Other Standard Issues:**

The DSR SDT proposed that combining EOP-004 and CIP-001 would not introduce a reliability gap between the existing standards and the proposed standard and the industry comments received confirms this.

Several entities expressed their concern with the fact that Attachment 1 contained most of the elements already called for in the OE-417. The DSR SDT agrees, and Attachment 1 part 1 has

been modified to even more closely mirror the Department of Energy’s OE-417 Emergency Incident and Disturbance Report form. Additionally, the standard has been modified to allow for the use of the OE-417.

There was some concern expressed that there could be confusion between the reporting requirements in this standard, and those found in CIP-008. The DSR SDT agrees, and Attachment 1 Part B, has been modified to provide the process for the reporting of a Cyber Security Incident.

The DSR SDT also believes NERC’s additional concern about what data is applicable is addressed by the revisions to Attachment 1, and the inclusion of the OE-417 as an acceptable interim vehicle.

**Implementation Plan:**

The DSR SDT asked stakeholders to provide feedback on the proposed effective date which provided entities at least a year following board approval of the standard. Most stakeholders supported the one year minimum, however based on the revisions made to the requirements, the drafting team is now proposing that this time period be shortened to between six months and nine months. The current CIP-001 plan is adequate for the new EOP-004 and training should be met in the proposed timeline. Note that the Implementation Plan was developed for the revised Requirements, which do not include an electronic “one-stop shopping” tool. The tool for ‘one stop shopping’ will be addressed in the proposed revisions to the NERC Rules of Procedure.

The industry commented on the need for e-mail addresses and fax numbers for back up purposes. These details were added to the standard and the implementation plan.

The proposed ballot in December was incorrect and has been deleted from the future development plan. The plan was updated with the correct project plan dates.

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Herb Schrayshuen, at 609-452-8060 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

Index to Questions, Comments, and Responses

1. ***Do you agree with the purpose statement of the proposed standard? Please explain in the comment box below. .... 19***
2. ***Do you agree with the applicable entities in the Applicability Section as well as assignment of applicable entities noted in Attachment 1? Please explain in the***

---

<sup>1</sup> The appeals process is in the Reliability Standards Development Procedures:

<http://www.nerc.com/standards/newstandardsprocess.html>.

<i>comment box below. ....</i>	<i>35</i>
<i>3. Do you agree with the requirement R1 and measure M1? Please explain in the comment box below. ....</i>	<i>53</i>
<i>4. Do you agree with the requirement R2 and measure M2? Please explain in the comment box below. ....</i>	<i>67</i>
<i>5. Do you agree with the requirement R3 and measure M3? Please explain in the comment box below. ....</i>	<i>90</i>
<i>6. Do you agree with the requirement R4 and measure M4? Please explain in the comment box below. ....</i>	<i>103</i>
<i>7. Do you agree with the requirement R5 and measure M5? Please explain in the comment box below. ....</i>	<i>115</i>
<i>8. Do you agree with the requirement R6 and measure M6? Please explain in the comment box below ....</i>	<i>132</i>
<i>9. Do you agree with the requirements for the ERO (R7-R8) or is this adequately covered in the Rules of Procedure (section 802)? Please explain in the comment box below. ....</i>	<i>143</i>
<i>10. Do you agree with the impact event list in Attachment 1? Please explain in the comment box below and provide suggestions for additions to the list of impact events. ....</i>	<i>155</i>
<i>11. Do you agree with the use of the Preliminary Impact Event Report (Attachment 2)? .....</i>	<i>182</i>
<i>12. The DSR SDT has replaced the terms “disturbance” and “sabotage” with the term “impact events”. Do you agree that the term “impact events” adequately replaces the terms “disturbance” and “sabotage” and addresses the FERC directive to “further define sabotage” in an equally efficient and effective manner? Please explain in the comment box below.....</i>	<i>192</i>
<i>13. The DSR SDT has combined EOP-004 and CIP-001 into one standard (please review the mapping document that shows the translation of requirements from the already approved versions of CIP-001 and EOP-004 to the proposed EOP-004), EOP-004-3 and retiring CIP-001. Do you agree that there is no reliability gap between the existing standards and the proposed standard?.....</i>	<i>201</i>
<i>14. Do you agree with the proposed effective dates? Please explain in the comment box below.....</i>	<i>207</i>

***15. Do you have any other comments that you have not identified above?.....213***

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
1.	Group	Guy Zito	Northeast Power Coordinating Council										X
Additional Member	Additional Organization	Region	Segment Selection										
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10									
2.	Gregory Campoli	New York Independent System Operator	NPCC	2									
3.	Kurtis Chong	Independent Electricity System Operator	NPCC	2									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
4.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1																
5.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1																
6.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10																
7.	Dean Ellis	Dynegy Generation	NPCC	5																
8.	Brian Evans-Mongeon	Utility Services	NPCC	8																
9.	Mike Garton	Dominion Resources Services, Inc.	NPCC	5																
10.	Brian L. Gooder	Ontario Power Generation Incorporated	NPCC	5																
11.	Kathleen Goodman	ISO - New England	NPCC	2																
12.	Chantel Haswell	FPL Group, Inc.	NPCC	5																
13.	David Kiguel	Hydro One Networks Inc.	NPCC	1																
14.	Michael R. Lombardi	Northeast Utilities	NPCC	1																
15.	Randy MacDonald	New Brunswick System Operator	NPCC	2																
16.	Bruce Metruck	New York Power Authority	NPCC	6																
17.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10																
18.	Robert Pellegrini	The United Illuminating Company	NPCC	1																
19.	Si Truc Phan	Hydro-Quebec TransEnergie	NPCC	1																
20.	Saurabh Saksena	National Grid	NPCC	1																
21.	Michael Schiavone	National Grid	NPCC	1																

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
22.		Peter Yost	Consolidated Edison Co. of New York, Inc. NPCC	3									
2.	Group	Jim Case, SERC OC Chair	SERC OC Standards Review Group	X		X							
Additional Member	Additional Organization	Region	Segment Selection										
1.	Mike Garton	Dominion Virginia Power	SERC	1, 3									
2.	Jim Griffith	Southern	SERC	1, 3, 5									
3.	Vicky Budreau	Santee Cooper	SERC	1, 3, 5, 9									
4.	Gerry Beckerle	Ameren	SERC	1, 3									
5.	Eugens Warnecke	Ameren	SERC	1, 3									
6.	Scott McGough	Oglethorpe Power	SERC	5									
7.	John Neagle	AEC I	SERC	1, 3, 5									
8.	Joel Wise	TVA	SERC	1, 3, 5, 9									
9.	Jennifer Weber	TVA	SERC	1, 3, 5, 9									
10.	Robert Thomasson	BREC	SERC	1, 3, 5, 9									
11.	Derek Bleyle	SCE&G	SERC	1, 3, 5									
12.	Gene Delk	SCE&G	SERC	1, 3, 5									
13.	Dave Plauck	Calpine	SERC	5									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
14.	Tom Hanzlik	SCE&G	SERC	1, 3, 5																
15.	Randy Castello	Mississippi Power	SERC	1, 3, 5																
16.	Doug White	NCEMC	SERC	1, 3, 5, 9																
17.	Randy Haynes	Alcoa	SERC	1, 5																
18.	Joel Rogers	SMEPA	SERC	1, 3, 5, 9																
19.	Mike Bryson	PJM	SERC	2																
20.	Rick Meyers	EEI	SERC	1, 5																
21.	Tim Hattaway	PowerSouth	SERC	1, 3, 5, 9																
22.	Barry Warner	EKPC	SERC	1, 3, 5, 9																
23.	Jack Kerr	Dominion Virginia Power. P.	SERC	1, 3																
24.	Wes Davis	SERC Reliability Corp.	SERC	10																
25.	John Troha	SERC Reliability Corp.	SERC	10																
3.	Group	Brad Jones	Luminant Energy								X									
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Kevin Phillips	Luminant Energy	ERCOT	6																
4.	Group	David Grubbs	City of Garland		X															
<b>Additional Member Additional Organization Region Segment</b>																				



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
			<b>Selection</b>										
		1. David Grubbs	ERCOT	1									
		2. Fred Sherman	ERCOT	1									
		3. Steve Zaragoza	ERCOT	1									
		4. Billy Lee	ERCOT	1									
		5. Heather Siemens	ERCOT	1									
		6. Ronnie Hoeinghaus	ERCOT	1									
		7. Matt Carter	ERCOT	1									
5.	Group	Terry L. Blackwell	Santee Cooper		X		X		X	X			
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
		1. S. T. Abrams	Santee Cooper	SERC	1								
		2. Rene' Free	Santee Cooper	SERC	1								
		3. Vicky Budreau	Santee Cooper	SERC	1								
		4. Glenn Stephens	Santee Cooper	SERC	1								
6.	Group	Steve Alexanderson	Pacific Northwest Small Public Power Utility Comment Group				X	X					

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment										
			1	2	3	4	5	6	7	8	9	10	
Additional Member	Additional Organization	Region	Segment Selection										
1.	Russell Noble	Cowlitz County PUD No. 1	WECC	3, 4, 5									
2.	Dave Proebstel	Clallam County PUD	WECC	3									
3.	Ronald Sporseen	Blachly-Lane Electric Cooperative	WECC	3									
4.	Ronald Sporseen	Central Electric Cooperative	WECC	3									
5.	Ronald Sporseen	Clearwater Power Company	WECC	3									
6.	Ronald Sporseen	Douglas Electric Cooperative	WECC	3									
7.	Ronald Sporseen	Consumers Power	WECC	3									
8.	Ronald Sporseen	Fall River Rural Electric Cooperative	WECC	3									
9.	Ronald Sporseen	Northern Lights	WECC	3									
10.	Ronald Sporseen	Lane Electric Cooperative	WECC	3									
11.	Ronald Sporseen	Lincoln Electric Cooperative	WECC	3									
12.	Ronald Sporseen	Raft River Rural Electric Cooperative	WECC	3									
13.	Ronald Sporseen	Lost River Electric Cooperative	WECC	3									
14.	Ronald Sporseen	Salmon River Electric Cooperative	WECC	3									
15.	Ronald Sporseen	Umatilla Electric Cooperative	WECC	3									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization		Registered Ballot Body Segment									
					1	2	3	4	5	6	7	8	9	10
16.		Ronald Sporseen	Coos-Curry Electric Cooperative	WECC	3									
17.		Ronald Sporseen	West Oregon Electric Cooperative	WECC	3									
18.		Ronald Sporseen	Pacific Northwest Generating Cooperative	WECC	5									
19.		Ronald Sporseen	Power Resources Cooperative	WECC	5									
7.	Group	Mallory Huggins	NERC Staff											
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
	1. Earl Shockley	NERC	NA - Not Applicable NA											
	2. Dave Nevius	NERC	NA - Not Applicable NA											
	3. Gerry Adamski	NERC	NA - Not Applicable NA											
	4. Roman Carter	NERC	NA - Not Applicable NA											
8.	Group	Carol Gerou	MRO's Subcommittee	NERC Standards Review										X
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
	1.	Mahmood Safi	Omaha Public Utility District	MRO	1, 3, 5, 6									
	2.	Chuck Lawrence	American Transmission Company	MRO	1									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment												
			1	2	3	4	5	6	7	8	9	10			
3.	Tom Webb	WPS Corporation	MRO	3, 4, 5, 6											
4.	Jodi Jenson	Western Area Power Administration	MRO	1, 6											
5.	Ken Goldsmith	Alliant Energy	MRO	4											
6.	Alice Murdock	Xcel Energy	MRO	1, 3, 5, 6											
7.	Dave Rudolph	Basin Electric Power Cooperative	MRO	1, 3, 5, 6											
8.	Eric Ruskamp	Lincoln Electric System	MRO	1, 3, 5, 6											
9.	Joseph Knight	Great River Energy	MRO	1, 3, 5, 6											
10.	Joe DePoorter	Madison Gas & Electric	MRO	3, 4, 5, 6											
11.	Scott Nickels	Rochester Public Utilities	MRO	4											
12.	Terry Harbour	MidAmerican Energy Company	MRO	1, 3, 5, 6											
9.	Group	Sam Ciccone	FirstEnergy	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>															
1.	Dave Folk	FE	RFC												
2.	Doug Hohlbaugh	FE	RFC												
3.	Andy Hunter	FE	RFC												
4.	Kevin Querry	FE	RFC												
5.	Brian Orians	FE	RFC												

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
6. John Martinez	FE	RFC												
7. John Reed	FE	RFC												
8. Marissa McLean	FE	RFC												
9. Phil Bowers	FE	RFC												
10. Group	Mike Garton	Electric Market Policy	X		X		X	X						
Additional Member	Additional Organization	Region	Segment Selection											
1.	Michael Gildea	Dominion	NPCC	5										
2.	Louis Slade	Dominion	SERC	6										
3.	John Loftis	Dominion Virginia Power	SERC	1										
11. Group	Denise Koehn	Bonneville Power Administration		X		X		X	X					
Additional Member	Additional Organization	Region	Segment Selection											
1.	Jim Burns	BPA, Transmission, Technical Operations	WECC	1										
2.	Russell Funk	BPA, Transmission, DCC Data System Hardware	WECC	1										
3.	John Wylder	BPA, Transmission, CC HW Dsgn/Stdns Montr & Admin	WECC	1										

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
12.	Group	Kenneth D. Brown	PSEG Companies	X		X		X	X				
Additional Member	Additional Organization	Region	Segment Selection										
1.	Ron Wharton	PSE&G System Ops	RFC	1, 3									
2.	Jerzy Slusarz	PSEG Fossil	RFC	5, 6									
3.	James Hebson	PSEG ER&T	ERCOT	5, 6									
4.	Dominick Grasso	PSEG Power Connecticut	NPCC	5, 6									
13.	Group	Steve Rueckert	WECC										X
Additional Member	Additional Organization	Region	Segment Selection										
1.	Tom Schneider	WECC	WECC	10									
2.	John McGee	WECC	WECC	10									
14.	Group	Richard Kafka	Pepco Holdings, Inc - Affiliates	X		X		X	X				
Additional Member	Additional Organization	Region	Segment Selection										
1.	Vic Davis	Delmarva Power & Light Co	RFC	1									
2.	Dave Thorne	Potomac Electric Power Company	RFC	1									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
15.	Group	Howard Rulf	We Energies			X	X	X					
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
	1.	Tom Eells	We Energies RFC	3, 4, 5									
	2.	Fred Hessen	We Energies RFC	3, 4, 5									
	3.	Brian Heimsch	We Energies RFC	3, 4, 5									
16.	Group	Annette M. Bannon	PPL Supply					X					
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
	1.	Mark Heimbach	PPL Martins Creek, LLC RFC	5									
17.	Group	J T Wood	Southern Company - Transmission	X		X							
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
	1.	Marc Butts	Southern Company Services	SERC 1									
	2.	Andy Tillery	Southern Company Services	SERC 1									
	3.	Jim Busbin	Southern Company Services	SERC 1									
	4.	Phil Winston	Southern Company Services	SERC 1									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization		Registered Ballot Body Segment									
					1	2	3	4	5	6	7	8	9	10
5.		Mike Sanders	Southern Company Services	SERC	1									
6.		Bob Canada	Southern Company Services	SERC	1									
7.		Boyd Nation	Southern Company Services	SERC	1									
8.		Phil Whitmer	Georgia Power Company	SERC	3									
9.		Randy Mayfield	Alabama Power Company	SERC	3									
10.		Randy Castello	Mississippi Power Company	SERC	3									
18.	Group	Jason L. Marshall	Midwest ISO Standards Collaborators			X								
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		Jim Cyrulewski	JDRJC Associates, LLC	RFC	8									
2.		Kirit Shah	Ameren	SERC	1									
3.		Robert A. Thomasson Sr.	Big Rivers	SERC	1, 3									
19.	Group	Ben Li	IRC Standards Review Committee			X								
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		Bill Phillips	MISO	MRO	2									
2.		Matt Goldberg	ISO-NE	NPCC	2									



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter		Organization		Registered Ballot Body Segment														
						1	2	3	4	5	6	7	8	9	10					
3.		Charles Yeung	SPP	SPP	2															
4.		Mark Thompson	AESO	WECC	2															
5.		James Castle	NYISO	NPCC	2															
6.		Steve Myers	ERCOT	ERCOT	2															
7.		Greg Van Pelt	CAISO	WECC	2															
8.		Patrick Brown	PJM	RFC	2															
20.	Individual	Brian Pillittere	Tenaska							X										
21.	Individual	Sandra Shaffer	PacifiCorp			X			X		X	X								
22.	Individual	Jana Van Ness, Director Regulatory Compliance	Arizona Public Service Company			X			X		X	X								
23.	Individual	Brent Ingebrigtsen	E.ON U.S. LLC			X			X		X	X								
24.	Individual	Brenda Lyn Truhe	PPL Electric Utilities			X														
25.	Individual	Greg Froehling	Green Country Energy								X									
26.	Individual	TransAlta Centralia Generation, LLC	TransAlta Corporation								X									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
27.	Individual	Doug Smeall	ATCO Electric Ltd.	X									
28.	Individual	Dan Roethemeyer	Dynegy Inc.					X					
29.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X				
30.	Individual	Philip Savage	PacifiCorp	X		X							
31.	Individual	Brian Reich	Idaho Power Company	X		X							
32.	Individual	Chris Hajovsky	RRI Energy, Inc.					X	X				
33.	Individual	Bill Keagle	BGE	X									
34.	Individual	John Brockhan	CenterPoint Energy	X									
35.	Individual	Joylyn Faust	Consumers Energy			X	X	X					
36.	Individual	Doug White	North Carolina Electric Coops			X	X	X					
37.	Individual	Lauri Jones	Pacific Gas and Electric Company	X		X		X					
38.	Individual	Laurie Williams	PNM Resources	X		X							
39.	Individual	Val Lehner	ATC	X									

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
40.	Individual	Martin Bauer	US Bureau of Reclamation					X						
41.	Individual	Wayne Pourciau	Georgia System Operations Corporation			X	X							
42.	Individual	Rex Roehl	Indeck Energy Services					X						
43.	Individual	Jonathan Appelbaum	United Illuminating	X										
44.	Individual	Amir Y Hammad	Constellation Power Generation and Constellation Commodities Group					X	X					
45.	Individual	Carol Bowman	City of Austin dba Austin Energy	X										
46.	Individual	John Bee	Exelon	X		X		X						
47.	Individual	Kirit Shah	Ameren	X		X		X	X					
48.	Individual	Thad Ness	American Electric Power (AEP)	X		X		X	X					
49.	Individual	Joe Knight	Great River Energy	X		X		X	X					
50.	Individual	Greg Rowland	Duke Energy	X		X		X	X					
51.	Individual	Nathan Lovett	Georgia Transmission Corporation	X										

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
52.	Individual	Chris de Graffenried	Consolidated Edison Co. of NY, Inc.	X									
53.	Individual	Kathleen Goodman	ISO New England Inc.		X								
54.	Individual	Amanda Stevenson	E.ON Climate & Renewables					X					
55.	Individual	Christine Hasha	ERCOT ISO		X								
56.	Individual	Terry Harbour	MidAmerican Energy	X									
57.	Individual	Michael Gammon	Kansas City Power & Light	X		X		X	X				
58.	Individual	Ron Gunderson	Nebraska Public Power District	X		X		X					
59.	Individual	Dan Rochester	Independent Electricity System Operator		X								
60.	Individual	Catherine Koch	Puget Sound Energy	X									

**1. Do you agree with the purpose statement of the proposed standard? Please explain in the comment box below.**

**Summary Consideration:** Stakeholders who responded to this question were fairly evenly divided on acceptance of the original purpose statement with about half supporting the purpose and half suggesting revisions to the purpose. A common thread through most of the comments was that the DSR SDT went beyond the intent of the standard (reporting) and concentrated too much on the analysis of the event. Based on these comments, the SDT revised the purpose statement. The new purpose is:

To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.

Several commenters noted that the term, “impact event” is not a formally defined term. The DSR SDT has used a working definition for “impact events” to develop Attachment 1 as follows:

An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.

Many stakeholders indicated that the definition should be added to the NERC Glossary and the DSR SDT adopted this suggestion.

The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard.

Some commenters correctly pointed out that “situational awareness” was a desirable by-product of an effective event reporting system, and not driver of that system. Accordingly, all references to “situational awareness” have been deleted from the standard. The more generic “industry awareness” has been substituted where appropriate.

Many commenters noted that the SDT did not define sabotage. FERC Order 693, paragraph 471 states in part: “. . . the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” The DSR SDT made a conscious, deliberate decision to exclude a strict definition of sabotage from this standard and sought

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

stakeholder feedback on this issue. Some suggested adopting the NRC definition of the term sabotage, and the DSR SDT did consider adopting the NRC definition shown below but determined that the definition is too narrowly focused.

Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.

Most respondents agreed that in order to be labeled as an act of sabotage, the intent of the perpetrators must be known. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This would result in further ambiguity with respect to reporting events, and the timeline associated with the reporting requirements does not lend itself to the in-depth analysis required to identify a disturbance (or potential disturbance) as sabotage. The SDT felt that a likely consequence of having to meet this criterion, in the time allotted, would be an under-reporting of events. Accordingly, all references to sabotage have been deleted from the standard.

Organization	Yes or No	Question 1 Comment
Ameren	No	The purpose talks about reporting impact events and their known causes. We have no problem with this generic intent, but the purpose says nothing about the very burdensome expectation of verbal updates to NERC and Regional Entities (Attachment 1, top of first page), Preliminary Impact Event Reports (Attachment 1, top of first page, are these Attachment 2?), "Actual" Impact Event Reports (Attachment 1 - Part A) and "Potential" Impact Event Reports (Attachment 1 - Part B). These multiple levels of reporting and events need to be greatly reduced.
American Electric Power (AEP)	No	It is unclear what the relationship between this project and the newly revamped NERC Event Analysis Process. We support moving towards one process opposed to separate obligations that may be in conflict.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>In addition, AEP supports the concept of a central clearinghouse such as the RCIS that is shared by the industry. We support fewer punitive requirements and more prompting for using tools to make multiple entities aware of reliability related issues shortly after the fact.</p>
CenterPoint Energy	No	<p>CenterPoint Energy does not agree with the purpose statement of the proposed standard. The directive from the Commission in FERC Order 693 and restated in the Guideline and Technical Basis is "...the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: 1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event." Instead the SDT has introduced another term, impact event, to address concerns regarding different definitions. The term, impact event and its proposed concept is too broad. Specifically the concept that an impact event "...has the potential to impact the reliability of the Bulk Electric System" leaves too much room for an entity and a regulatory body to have a difference of opinion as to whether an event should be reported. Required reporting should be limited to actual events. The reporting to follow could become overwhelming for the Responsible Entities, the ERO, and other various organization and agencies. Furthermore, situational awareness is a term that is associated with aspects of real-time. Given the analysis required before a report can be submitted, the report will not be real-time and will not sustain a purpose of supporting situational awareness. (See also comments on Q10 regarding the "Time to Submit Report".) A purpose that is more aligned with consolidation of the EOP-004 and CIP-001 standards would be as follows: Responsible Entities shall report disturbance events and acts of sabotage to support the reliability of the BES through industry awareness.</p>
Consolidated Edison Co. of NY, Inc.	No	<p>Comments: The purpose is not clear because it uses the term "impact events". This term should be defined in the NERC glossary, and should not include words such as "potential".</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
Duke Energy	No	The Purpose statement says that reporting under this standard supports situational awareness. However this is in conflict with Section 5. Background, where the DSR SDT makes clear that this standard includes no real-time operating notifications, and that this proposed standard deals exclusively with after-the-fact reporting. We also disagree with the stated concept of “impact event”. Including the phrase “or has the potential to impact” in the concept makes it impossibly broad for practical application and compliance.
Electric Market Policy	No	The term “impact events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. As conveyed in Dominion’s comments on NERC Reliability Standards Development Plan 2011 - 2013, Dominion does not see this draft standard as needing to be in the queue while other standards having more impact to bulk electric reliability remain incomplete or unfinished.
ERCOT ISO	No	ERCOT ISO believes that according to the timelines allotted in Attachment 1, it may not be possible for the entity to identify the “known cause” of an event. The requirements list identification of “initial probable cause”. This is more reasonable under the timelines noted in Attachment 1.
Exelon	No	The purpose states that Responsible Entities SHALL report impact events - this implies that ALL impact events need to be reported regardless of magnitude, suggest rewording to say "... shall report applicable impact events ..." to allow for evaluation of each impact for applicability in accordance with Attachment 1).



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
FirstEnergy	No	<p>Since this standard is after-the-fact reporting, the phrase "situational awareness" may not be appropriate since that phrase is attributed by a large part of the industry to real-time, minute-to-minute awareness of the system. We suggest the following rewording of the purpose statement: "To ensure Applicable Entities report impact events and their known causes to enhance and support the reliability of the Bulk Electric System (BES)".</p>
Indeck Energy Services	No	<p>Suggestion: "Functional Entities identified in Section 4 shall support situational awareness of impact events and their known causes."</p>
Independent Electricity System Operator	No	<p>(1) Our understanding of the proposed revision as conveyed in the SAR was to provide clarity and reduce redundancy on reporting the latest and even on-going events on the system that may be caused by system changes and/or sabotage. The intent is to ensure the proper authorities are informed of such events so that they may take appropriate and necessary actions to identify causes and/or mitigate or limit the extent of interruptions. We also supported a suggestion in the SAR to assess the merit of merging CIP-001 and EOP-004 to remove redundancy, although we suggested that this should not be a presumption when revising the standard(s). This posting appears to indicate that only EOP-004 will be revised at this time, and CIP-001 which deals with sabotage reporting will remain in effect. With this assumption, the proposed standard appears to contain a mixture of reporting two types of events of different time frame - the first type being those events that need to be reported soon or immediately after they occur (e.g. impact events that appear to be the result of a sabotage) with an aim to curb/contain these events by the appropriate authorities; the second type being the events that can be reported sometime well after the fact, e.g. system disturbances due to weather or switching or other known causes that are not of malicious nature. Combining the two types of requirement does not appear to be clearly conveyed in the SAR. We therefore suggest the SDT review the main purpose</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>and content in the proposed EOP-004 to ensure consistency with the SAR, and in relation to the purpose and requirements already contained in CIP-004.(2) With respect to disseminating reports and related information after the fact, we wonder if a data collection process, such as RoP 1900, can serve the purpose without having to create a standard or a requirement to achieve this.(3) Most of the requirements appear to be administrative in nature and they stipulate the how but not the what, which in our view does not conform with the Results-based standard concept and does not rise to the level of a reliability standard.(4) A number of requirements proposed in the draft standard are quite vague and cannot be measured. Details of this assessment is provided below.</p>
<p>IRC Standards Review Committee</p>	<p>No</p>	<p>The proposed requirements in the standard are not focused on the core industry concern that current requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, “The existing requirements need to be revised to be more specific - and there needs to be more clarity in what sabotage looks like.” Instead this proposed standard includes requirements that are more focused on “how” to report, rather than “what” to report. The SAR states that: “The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.” The SRC believes the scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seem helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>team seems to be ignored, “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard.</p>
ISO New England Inc.	No	<p>The proposed requirements in the standard are not focused on the core industry concern that current requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, “The existing requirements need to be revised to be more specific - and there needs to be more clarity in what sabotage looks like.” Instead this proposed standard includes requirements that are more focused on “how” to report, rather than “what” to report. The draft 2 SAR has never been balloted for approval prior to standard drafting. In fact, the SAR states, “The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.” The scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seems helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting team seems to be ignored: “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard. The term “impact</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		<p>events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC Glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. This draft standard should not have this high a priority while other standards having a greater impact on Bulk Electric System reliability remain incomplete or unfinished. Regional reporting requirements should be in Regional Standards, and not be included in a NERC Standard.</p>
Manitoba Hydro	No	<p>Though new purpose greatly clarifies the proposed EOP-004-2 and using “situational awareness” is the key to this purpose, further clarification of specific items should be added to the purpose. “Responsible Entities shall report SIGNIFICANT events to support interconnection situational awareness on events that impact the integrity of the Bulk Electric System, such as islanding, generation, transmission and load losses, load shedding, operation errors, IROL/SOL violations, sustained voltage excursions, equipment and protection failures and on suspected or acts of sabotage.”</p>
Nebraska Public Power District	No	<p>The background states there is no real-time reporting requirement in this standard, but the purpose states a purpose is for situational awareness. This implies real-time reporting. The purpose clearly identify the standard is for after the fact reporting to permit analysis of events, trend data, and identify lessons learned.</p>
North Carolina Electric Coops	No	<p>The term “impact event” is not a defined term in the NERC glossary and does not draw a clear boundary or give concise guidance to aid in event recognition.</p>
Northeast Power Coordinating	No	<p>The proposed requirements in the standard are not focused on the core industry concern that current</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
Council		<p>requirements are unclear as to what types of events warrant entities to report. Per draft 2 of the SAR, “The existing requirements need to be revised to be more specific - and there needs to be more clarity in what sabotage looks like.” Instead this proposed standard includes requirements that are more focused on “how” to report, rather than “what” to report. The draft 2 SAR has never been balloted for approval prior to standard drafting. In fact, the SAR states, “The development may include other improvements to the standards deemed appropriate by the drafting team, with consensus on the stakeholders (emphasis added), consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.” The scope of the SAR, and likewise the proposed standard, is inappropriate to the fundamental reliability purpose of what events need to be reported. The proposed administrative requirements are difficult to interpret, implement and measure, and do not clarify what type of sabotage information entities need to report. Although the use of procedures and an understanding by those personnel accountable seems helpful for ensuring reports are made, the fundamental purpose of clarifying what types of events should be reported and more importantly what types do not have to be reported, is lacking in the standard. Also, one of the first issues identified in the SAR for consideration by the drafting team seems to be ignored: “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The requirements for entities to develop Operating Plans and to have training for those plans, further adds uncertainty and increases complexity of how entities, large and small, will have to comply with this standard. The term “impact events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC Glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator. This draft standard should not have this high a priority while other standards having a greater impact</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
		on Bulk Electric System reliability remain incomplete or unfinished.Regional reporting requirements should be in Regional Standards, and not be included in a NERC Standard.
Pacific Gas and Electric Company	No	PG&E recognizes this is an after the fact report, however, the purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. If the future intent is for this report to replace current reporting criteria the purpose statement should be expanded to reflect the true intent of the Standard.
PNM Resources	No	PNM believes the purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. It is misleading and may have many thinking it is duplicative work.
PSEG Companies	No	The following sentence should be added. "This standard is not intended to be for real-time operations reporting."
RRI Energy, Inc.	No	The purpose does not need to mention "and the reliability of the Bulk Electric System." This is the Congressional mandate in FPA Section 215, and could be attached to every Standard, guide, notice and direction issued by FERC, NERC and Regional Entities. In addition, the purpose references "Responsible Entities." However, section 4 on "Applicability" references "Functional Entities." These terms should be consistent. Therefore, the purpose statement of the proposed standard should be corrected to read, "FunctionalEntities identified in Section 4 shall report impact events and their known causes to support situational awareness."CONSIDERATION: Is the phrase "shall report impact events and their known causes" really a purpose of the Proposed Standard, or is it instead merely a means to achieve the purpose of situational awareness? If the latter, the purpose statement can be further shortened to read, "Functional Entities identified in Section 4 shall support situational awareness of impact events and their known causes."

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 1 Comment
Santee Cooper	No	Since this standard is written to report events after-the-fact and not for a System Operator to perform corrective action, we believe the words situational awareness should be removed from the purpose. Situational Awareness is typically used for real-time operations. Also, any events that require reporting should be clearly defined in Attachment 1 and leave no room for interpretation by an entity.
SERC OC Standards Review Group	No	The term “impact events” does not draw a clear boundary around those events that are affected by this standard. Since this is not a defined term, nor is intended to be a defined term in the NERC glossary, this standard lacks clarity and is likely to produce significant conflict as an applicable entity attempts to establish procedures to assure compliance. It appears that situational awareness could not be improved with this standard since it is only dealing with events after-the-fact, not within the time frame to allow corrective action by the system operator.
United Illuminating	No	UI suggests adding the phrase: and the ERO shall provide quarterly reports; Responsible Entities shall report impact events and their known causes, and the ERO shall provide quarterly reports, to support situational awareness and the reliability of the Bulk Electric System (BES).
US Bureau of Reclamation	No	The purpose is more closely related to the concept that "Responsible Entities shall document and analyze impact events and their known causes and disseminate the impact event documentation to support situational awareness". Not all impact events are to be reported. The analysis of the impact events is what is needed to achieve a lessons learned.
We Energies	No	Impact event needs to be clarified first, and DP references in Attachment 1 clarified. Distribution is not BES.
WECC	No	The purpose statement should reflect the fact that this proposed standard is for after-the-fact reporting. It is

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 1 Comment
		misleading and may have many thinking it is duplicative work.
ATC	Yes	ATC agrees with the purpose statement. However, we do not agree with the implied definition of “impact events” as represented in Attachment 1. (See specific comments about what is included in Attachment 1 for the type of events that qualify as an “impact event”.)
Bonneville Power Administration	Yes	Known causes are difficult under 1 hour reporting requirements (Unusual events are even harder to narrow down in 24 hours and may take weeks.) The System Operators and RC’s handle situational awareness and reliability events, this is an extra wide view and learning for reporting only.
Dynergy Inc.	Yes	Statement is broad enough to cover both Standards.
Great River Energy	Yes	Thank you for the clarification of “known causes”, this will allow entities to report what they currently know when submitting an impact report.
MRO's NERC Standards Review Subcommittee	Yes	Thank you for the clarification of “known causes”, this will allow entities to report what they currently know when submitting an impact report.
Puget Sound Energy	Yes	However, further definition of "known causes" would be helpful as sometime the root cause analysis doesn't uncover the actual cause for sometime after the timeframes outlined in Attachment 1.
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
BGE	Yes	
City of Austin dba Austin Energy	Yes	
City of Garland	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
E.ON Climate & Renewables	Yes	
Georgia System Operations Corporation	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Kansas City Power & Light	Yes	
Luminant Energy	Yes	
MidAmerican Energy	Yes	

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 1 Comment
Midwest ISO Standards Collaborators	Yes	
NERC Staff	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Tenaska	Yes	
TransAlta Corporation	Yes	

**2. Do you agree with the applicable entities in the Applicability Section as well as assignment of applicable entities noted in Attachment 1? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question regarding the acceptability of the proposed list of functional entities and the assignment of applicable entities in Attachment 1.

Several respondents replied with their concern that the reporting requirements were redundant. The general sentiment was that unclear responsibility to report a disturbance could trigger a flood of event reports. Attachment 1 has been modified to assign clear responsibility for reporting, for each category of Impact Event. There was some concern expressed that there could be confusion between the reporting requirements in this standard, and those found in CIP-008. The DSR SDT agrees, and Attachment 1 Part B, has been modified to provide the process for the reporting of a Cyber Security Incident.

The DSR SDT had protracted discussions on the applicability of this standard to the LSE. Per the Functional Model the LSE does not own assets and therefore should not be an applicable entity (no equipment that could experience a “disturbance”). However, the Registry Criteria contains language that could imply that the LSE does own assets, or is at least responsible for assets. In addition, the DSR SDT modified Attachment 1 to include reporting of damage or destruction of Critical Cyber Assets per CIP-002. The LSE, as well as the Interchange Authority and Transmission Service Provider are applicable entities under CIP-002 and should be included for Impact Events under EOP-004.

There were several comments that the asset owners (GO/TO) would be less likely than the asset operators (GOP/TOP) to be aware of an impact event. The DSR SDT recognizes that this may be true in some cases, but not all. In order to meet the reliability objectives of this requirement, the applicability for GO/TO will remain as per Attachment 1.

Organization	Yes or No	Question 2 Comment
--------------	-----------	--------------------

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
American Electric Power (AEP)	No	AEP does not agree with the addition of the Generator Owner to the standard. The Generator Owner does not have visibility to the real time operational status of a unit. As a result, the Generator Owner lacks the ability to recognize impact events and report them to the Regional Entity or NERC within the time frames specified in the standard. Reporting requirements for impact events should be the responsibility of the Generator Operator.
Arizona Public Service Company	No	AZPS recommends excluding 4.1.7 Distribution Providers, as Distribution Providers generally operate at levels below 100kV.
ATC	No	The Functional Entities identified in Attachment 1 do not align with the current CIP Standard obligations (e.g. Load Serving Entities are not included).
CenterPoint Energy	No	CenterPoint Energy does not agree with the addition of Transmission Owner and Distribution Provider to the Applicability section. Transmission Owner and Distribution provider are not currently applicable entities for either CIP-001 or EOP-004 and should not be included in the proposed combined standard. However, CenterPoint Energy does agree that LSE should be removed from the Applicability section. CenterPoint Energy appreciates the SDT's efforts in assigning entities to each event in Attachment 1. This is an improvement over the existing EOP-004 standard. It is clear, however, that with multiple entities responsible for reporting each event, there is no need to expand the Applicability Section to include Transmission Owner and Distribution Provider.
Consolidated Edison Co. of NY, Inc.	No	Comments: NERC's role as the Standard enforcement organization for the power industry will be in conflict if NERC is also identified as an applicable entity. What compliance organization will audit NERC's

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
		performance? This is presently not clear.
Constellation Power Generation and Constellation Commodities Group	No	Constellation Power Generation and Constellation Commodities Group disagrees with the inclusion of Generator Owners. Since one of the goals in revising this standard is to streamline impact event reporting obligations, Generator Operators are the appropriate entity to manage event reporting as the entity most aware of events should they arise. At times, the information required to complete a report may warrant input from entities connected to generation, but the operator remains the best entity to fulfill the reporting obligation.
E.ON Climate & Renewables	No	1. Voltage deviation events are too vague for GOP. How does voltage deviations apply to GOP's or specifically renewables i.e., wind farms? 2. Define what an "entity" is. 3. Define what a "generating station" is. 4. Define what a "BES facility" is. 5. Define what a control center is. 6. Renewable energy/generators should be taken into consideration when crafting the events.
E.ON U.S. LLC	No	The proposed standard does not list the Load Serving Entity as an Applicable Entity, but the possible events that the standard addresses are within the scope of the LSE. Some functions of the LSE listed within the Functional Model are addressed in the proposed standard. Existing CIP-001-1a and EOP-004-1 are both applicable to the LSE.
Electric Market Policy	No	Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. Attachment 1 is troublesome. The time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, we believe this subject is more complex than this table reveals and the table needs more clarification. Several of the events require filing a written formal report within one hour. For example, system separation certainly is going to require an “all hands on deck” response to the actual event. We note that the paragraph above the table in attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.</p>
ERCOT ISO	No	<p>ERCOT ISO recommends that the Electric Reliability Organization be removed from the standard. The Electric Reliability Organization should not be responsible for reliability functions and therefore should be excluded from reliability standards.</p>
Exelon	No	<p>Attachment 1, Part B, footnote 1. A GO is unlikely to know if a fuel supply problem would cause a reliability concern because one GO may not know the demand for an entire region. Attachment 1, Part B, footnote 1. What is the definition of an "emergency" related to problems with a fuel supply chain? What time threshold of projected need would constitute a 1 hour report? Attachment 1, Part A - Voltage Deviations - A GOP may not be able to make the determination of a +/- 10% voltage deviation for approximately 15 minutes, this should be a TOP RC function only. Attachment 1, Part A - Generation Loss of approximately 2,000 MW for a GO/GOP does not provide a time threshold. If the 2,000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? Attachment 1, Part A - Damage or destruction of BES equipment o The</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>event criteria is ambiguous and does not provide clear guidance; specifically, the note needs to provide more explicit criteria related to parts (iii) and (iv) to remove the need for interpretation especially since this is a 1 hour reportable occurrence. In addition, determination of the aggregate impact of damage may not be immediately understood - does the 1 hour report time clock start on initiation of event or following confirmation of event?</p> <ul style="list-style-type: none"> <li>o The initiating event needs to explicitly state that it is a physical and not cyber. Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security - Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard.</li> <li>o If the damage or destruction is related to a deliberate act, consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event. Attachment 1, Part B - Loss of off-site power (grid supply) affecting a nuclear generating station - this event classification should be removed from EOP-004. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design and may not result in a loss of generation (i.e., unit trip); furthermore, if a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). The 1 hour notification in EOP-004 on a loss of off-site power (grid supply) to a nuclear generating station should be commensurate with other federal required notifications. Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential transient on the unit.</li> <li>Attachment 1, Part B - Forced intrusion at a BES facility - Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event.</li> <li>Attachment 1, Part B - Risk to BES equipment from a non-environmental physical threat - this event leaves</li> </ul>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		the interpretation of what constitutes a "risk" with the reporting entity. Need more specific criteria for this event. Attachment 1, Part B - Detection of a cyber intrusion to critical cyber assets - Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security - Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard.
FirstEnergy	No	We do not support the ERO as an applicable entity of a reliability standard because they are not a user, owner or operator of the bulk electric system. Any expectation of the ERO should be defined in the Rules of Procedure.
Georgia System Operations Corporation	No	This standard should not apply to distribution systems or Distribution Providers. It should apply only to the BES.
Georgia Transmission Corporation	No	These events generally are Operator Functions and should not apply to a TO.1. Energy Emergency requiring system-wide voltage reduction2. Loss of firm load greater than 15 min.3. Transmission loss (multiple BES transmission elements)4. Damage or destruction to BES equipment ( thru operational error or equipment failure)5. Loss of off-site power affecting a nuclear generating station
Indeck Energy Services	No	---ERO should not be included in this or any other standard! FERC can decide whether NERC is doing a good job without having standards requirements to audit to. If NERC needs to be included in a standard, then it should a stand-alone one so that the RSAW for all of the other audits don't need to include those requirements. ---"Loss of off-site power (grid supply)" is important at control centers and other large generators. The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---"Footnote 1. Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability." is ambiguous. Everything in the



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
		Standards program can "Affecting BES reliability". The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---"Footnote 2. Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES)." is well intentioned but ambiguous. For example, if I know the motivation is to blow up the plant, then by this footnote, I don't have to report. The SDT must use a well-defined standard such as potentially cause a Reportable Disturbance, to differentiate significant events from others. ---All terms should be used from or added to the Glossary.
Independent Electricity System Operator	No	We do not agree with the inclusion of TO and GO. They are not operating entities and do not need to collect or provide information pertaining to impact events, which are the results and phenomena observe under operating conditions in the operation horizon, and such information collection and provision are the responsibility of the TOP and GOP.
IRC Standards Review Committee	No	Entities that have information about possible sabotage events should report these to NERC after the fact and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an EEA for example?
ISO New England Inc.	No	Having the ERO as an applicable entity raises the issue that they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. NERC has also offered the opinion that since NERC is not a "user, owner, or

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>operator” Standards are not enforceable against the ERO. In Attachment 1 the time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to unnecessary and possibly conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, this subject is more complex than this table reveals, and the table needs more clarification. Entities that have information about possible sabotage events should report these to NERC after the fact, and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, it is likely that there is going to be duplicate reporting. Several of the events require filing a written formal report within one hour. For example, system separation is going to require an “all hands on deck” response to the actual event. The paragraph above the table in Attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements through NERC that cross federal agency jurisdictions.</p>
Luminant Energy	No	<p>Inclusion of both GO and GOP will result in duplicate reporting as both are responsible for reporting resource-related events such as Generation Loss, Fuel Supply Emergencies and Loss of Off-site power (grid supply). Recommend including only the GOP as it is critical that the GOP gather and communicate relevant information to the Reliability Coordinator.</p>
Manitoba Hydro	No	<p>Since this Standard is to support situational awareness, more entities should be included such as Load</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
		Serving Entities (which was removed from EOP-004-1).
MidAmerican Energy	No	While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an energy emergency requiring public appeals?
Midwest ISO Standards Collaborators	No	While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, there is likely going to be duplicate reporting. Why should both the RC and BA submit a report for an energy emergency requiring public appeals?
North Carolina Electric Coops	No	There is a conflict between the ERO being listed as an applicable entity and the fact that the ERO is the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that other applicable entities would be required to meet. Attachment 1 has inconsistent time frames listed for similar events. For example, EEA's are either reported within one or 24 hours depending on the nuance. Also, having more than one entity reporting an EEA can lead to conflicting information for the same event. Attachment 1 has the RC and the BA both reporting the same EEA event. Attachment 1 consolidates time frames from other standards for reporting purposes. There should either be a separate standard for "reporting" that encompasses reporting requirements for all standards or leave the time frames and reporting requirements in the original individual standards. Several of the events require filing a written formal report within one hour. For large events like cascading outages or system separation, "all hands on deck" attention will need to be given to the actual event. Although a verbal report would be allowed in certain circumstances, attention to the actual event should take precedence over formal reporting requirements. There is already a

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		DOE requirement to report certain events and no need to develop redundant reporting requirements in the NERC arena when this information is already available at the federal level at other agencies.
Northeast Power Coordinating Council	No	<p>Having the ERO as an applicable entity raises the issue that they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. For example, establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC’s open process. NERC has also offered the opinion that since NERC is not a “user, owner, or operator” Standards are not enforceable against the ERO. In Attachment 1 the time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does a RC have to report an EEA if the BA is going to report it? This will lead to unnecessary and possibly conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, this subject is more complex than this table reveals, and the table needs more clarification. Entities that have information about possible sabotage events should report these to NERC after the fact, and the standard should simply reflect that. While we agree with the list of functional entities identified in the Applicability Section, we do not agree with their application in Attachment 1. As the functional entities are identified in Attachment 1, it is likely that there is going to be duplicate reporting. Several of the events require filing a written formal report within one hour. For example, system separation is going to require an “all hands on deck” response to the actual event. The paragraph above the table in Attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements. There is already a DOE requirement to report certain events. We see no need to develop redundant reporting</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		requirements through NERC that cross federal agency jurisdictions.
Pacific Gas and Electric Company	No	PG&E recognizes the ERO is in R1, however, it does not see where the ERO's applicability is applied in Attachment 1.
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PNM Resources	No	PNM OTS does not see where the ERO's applicability is applied in Attachment 1.
PPL Electric Utilities	No	While we agree with the applicable entities in the Applicability Section of the revised standard, we would like the SDT to reconsider the applicable entities identified on Attachment 1, specifically regarding duplication of reporting e.g. should TO and TOP report?
PPL Supply	No	While we agree with the list of functional entities identified in the Applicability Section, we do not agree with assignment of applicable entities noted in Attachment 1. As the functional entities are identified in Attachment 1, there will likely be duplicate reporting for many impact events. By applying reporting responsibilities to both the Gen Owner and Gen Operator, this will result in duplicate reporting for plants with multiple owners. It also increases the burden on the Gen Operator who is required to report the event to NERC and to other Gen Owners in a timely manner to allow other Gen Owners to meet the NERC reporting timeline. We suggest that the reporting requirements associated with generators be applied to the Gen Operator only.
RRI Energy, Inc.	No	Agree with the "Applicability" section functional categories. Agree with the Attachment 1 lists of "Entity with Reporting Responsibility," with the following exceptions: PART A "Damage or Destruction of BES Equipment" - This item has a footnote 1 listed, but nothing at the bottom of the page for a footnote. Assuming the footnote

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>reference is intended to reference the "Examples" at the bottom of the page, the following concerns exist:(i) "critical asset" - Is this term intended to reference a "Critical Asset" identified pursuant to the CIP-002 risk-based assessment methodology? If so, it should be capitalized. If not, who determines what constitutes a lower case "critical asset"? (ii) "Significantly affects the reliability margin of the system..." - If this is intended to be enforceable, several words need significant clarification and definition, such as "Significantly," "reliability margin," "system" (BES?), "potential," and "emergency action." The combined ambiguity of just two of those phrases would most likely result in a court holding this statement as so vague as to be unenforceable. The combined lack of clarity of all the highlighted words or phrases render this sentence meaningless.(iii) "Damaged or destroyed due to a non-environmental external cause" - "Non-environmental external cause" should be a defined term because, as is the case in item (ii) above, it is vague and subject to broad, random or arbitrary interpretation. Part B provides examples of "non-environmental physical threat" for "Risk to BES equipment." Those examples could be referenced here, or different examples included that are more applicable to the Event.The items highlighted in items (ii) and (iii) above are very similar to the unintended string of CIP-001 violations that Registered Entities experienced in 2007 and 2008 for failing to provide their own definition of "sabotage" under a sabotage reporting standard that failed to provide any guidance to the industry within the standard as to what constituted "sabotage." PART B"Detection of a cyber intrusion to critical cyber assets" - Capitalize "Critical Cyber Asset."</p>
Santee Cooper	No	<p>Standards cannot be applicable to an ERO because they are the compliance enforcement authority, and the ERO is not a user, owner, or operator of the BES. Since we are reporting events that may affect the BES, why does a DP need to be included as an applicable entity for this standard? If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity. If NERC is going</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		<p>to require a separate reporting of events from DOE, then NERC should look at these events closely to determine if any of the defined events should be eliminated or modified from the current DOE form. (For example: Is shedding 100 MW of firm load really a threat to the BES?)Why does Attachment 1 have multiple entities reporting the same event? An RC should not have to report an EEA if the BA is required to report it. This will lead to conflicting reports for the same event.Attachment 1 is just a consolidation of the time frame from other standards. It appears no review was done for consistency of time frames for similar events.</p>
SERC OC Standards Review Group	No	<p>We find it interesting that the ERO is listed as an applicable entity. The ERO can't be an applicable entity because they are the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. NERC seems to be attempting to evade FERC jurisdiction by having a standard that enables it to write new rules that don't pass through the normal standards development process with ultimate approval by FERC.Attachment 1 is troublesome. The time frames listed are not consistent for similar events. For example, EEAs are either reported within one or 24 hours depending on the nuance. Having multiple entities reporting the same event is troublesome, i.e., why does an RC have to report an EEA if the BA is going to report it? This will lead to conflicting reports for the same event. Attachment 1 seems to be consolidating time frames from other standards into one for reporting. However, we believe this subject is more complex than this table reveals and the table needs more clarification or it should be eliminated and leave the time frames in the other standards.Several of the events require filing a written formal report within one hour. For example, system separation certainly is going to require an "all hands on deck" response to the actual event. We note that the paragraph above the table in attachment 1 indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with the event and not the reporting requirements.There is already a DOE requirement to report</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 2 Comment
		certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Southern Company - Transmission	No	We find it interesting that the ERO is listed as an applicable entity. The ERO is responsible for multiple requirements in this standard that shapes the ultimate actual rules that the other applicable entities would be required to meet. Can the NERC/ERO be accountable for a feedback loop to the industry? Feedback is preferable but would NERC/ERO self-report a violation to the requirement?
We Energies	No	The need for a DP to be included needs to be clarified. The Purpose points to BES. A DP does not have BES equipment.
WECC	No	The ERO's applicability is not applied in Attachment 1.
Great River Energy	Yes	We believe that it is important for the ERO to provide valuable Lessons learned to our electrical industry, thus enhancing the reliability of the BES.
Kansas City Power & Light	Yes	Consideration should be given to the need for a preliminary impact event report to be filed by the Reliability Coordinator and the Registered Entity. If two reports should be filed, should they both contain the same information.
MRO's NERC Standards Review Subcommittee	Yes	The NSRS believes it is important for the ERO to provide valuable Lessons learned to our electrical industry, thus enhancing the reliability of the BES.
TransAlta Corporation	Yes	Electrical Reliability Organization (ERO) does not appear to be a defined term in the NERC Glossary of Terms on the NERC website. Last updated April 20, 2010.



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 2 Comment
US Bureau of Reclamation	Yes	The question is focused on a limited area of Attachment A. There other problematic areas of Attachment 1 will be addressed in subsequent comments.
Ameren	Yes	
ATCO Electric Ltd.	Yes	
BGE	Yes	
Bonneville Power Administration	Yes	
City of Austin dba Austin Energy	Yes	
City of Garland	Yes	
Duke Energy	Yes	
Dynegy Inc.	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Nebraska Public Power District	Yes	
NERC Staff	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 2 Comment
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
Puget Sound Energy	Yes	
Tenaska	Yes	
United Illuminating	Yes	

**3. Do you agree with the requirement R1 and measure M1? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question. There was strong support for a central system for receiving and distributing impact event reports (a/k/a one stop shopping). There was general agreement that NERC was the most likely, logical entity to perform that function. However several respondents expressed their concern that the ERO could not be compelled to do so by a requirement in a Reliability Standard (not a User, Owner or Operator of the BES). In their own comments, NERC did not oppose the concept, but suggested that the more appropriate place to assign this responsibility would be the NERC Rules of Procedure. The DSR SDT concurs. The DSR SDT has removed the requirement from the standard and is proposing to make revisions to the NERC Rules of Procedure as follows:

812. NERC will establish a system to collect impact event reports as established for this section, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. These reports shall be forwarded to the Federal Energy Regulatory Commission for impact events that occur in the United States. This can include state, federal, and provincial organizations. The ERO shall solicit contact information from Registered Entities appropriate governmental, law enforcement and regulatory agencies contact information for distributing reports.

The DSR SDT also believes NERC’s additional concern about what data is applicable is addressed by the revisions to Attachment 1, and the inclusion of the OE-417 as an acceptable interim vehicle.

Organization	Yes or No	Question 3 Comment
WECC		R1 is appropriate for after-the-fact reporting. However, as proposed this standard eliminates all real-time notifications, including the CIP-001-1 R3 notice to appropriate parties in the Interconnection. New requirement R2.6 lists external parties to notify but it does not include the Reliability Coordinator. It is

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		important that the RC be notified of suspected sabotage. The RC's wide-area interconnection view and interaction with BAs may help recognize coordinated sabotage actions. Any "impact event" where sabotage is suspected as the root cause should require additional and real-time notifications.
ATC	No	ATC does not agree with R1 for three reasons:1. The ERO cannot be assigned obligations in NERC Standards. The requirements for the ERO should be addressed by a revision to Section 801 of the Rules of Procedure.2. This is a fill-in-the-blank requirement. The requirement, positioned as R1, does not allow for the obligations to be clearly defined. It refers to R6 which refers to R2 and Attachment 1. A clearer structure to the Standard would be to simply state that the Functional Entities have to meet the reporting obligations documented in Attachment 1 and delete the current R1.
BGE	No	R1 With the definition of "Impact Event", are we eliminating the term "Disturbance Reporting"? If we eliminate disturbance reporting, SDT should remove the reference from the Summary of Concepts and from the title, otherwise further definition on the distinction between the two terms is needed.R1. What is the "system" described here? What type of system is anticipated - electronic, programmatic or can it be better described by using "standard reporting form"?M1. Needs to seek evidence that the "system" was used for receiving reports, as well as distributing them.M1. Examples are more appropriately used in guidance documentation than in the standard. Rationale for R1 - Final statement regarding OE-417 needs to be removed. The ERO will establish the requirement in their "system" if the standard remains as is. The Requirement does not require the responsible entities to send OE-417 to DOE.
CenterPoint Energy	No	The ERO does not need to establish a "system for receiving reports" as the "system for receiving reports" is inherent given the requirements for reporting. The requirement also seems to add redundancy versus eliminating redundancy in the distribution of reports to applicable government, provincial or law enforcement

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		agencies on matters already reported by Responsible Entities. If an event is suspected to be an intentional criminal act, i.e. “sabotage”, the Responsible Entity would have contacted appropriate provincial or law enforcement agencies. The ERO is not in a position to add meaningful value to these reports as any information the ERO may provide is second hand. CenterPoint Energy recommends R1 and M1 be deleted.
City of Garland	No	Reason 1Most of this is duplication of existing processes - More “Big Government” and/or “Overhead” is not needed. There are already processes in place to notify “real time” 24 X 7 organizations that take action (RC, BA, TOP, DOE, FBI, Local Law Enforcement, etc) in response to an “impact event”. It is stated in your document on page five (5) “The proposed standard deals exclusively with after-the -fact reporting.” The combining of CIP 001 & EOP 004 should not expand on existing implemented reporting requirements nor should it result in NERC forming a 24 X 7 department to handle 1 hour (near real time) reporting requirements.Reason 2If this should go forward as drafted, NERC should not establish a “clearing house” for reporting requirements for Registered Entities without also taking legal responsibility for distributing those reports to required entities. It states in at least 2 places (Page 6 & Page 22) in the document that Responsible Entities are ultimately responsible for ensuring that OE-417 is received at the DOE. Thus, a Registered Entity could be penalized for violating this new standard if it did not file the reports with NERC or it could still be penalized (both criminal & civil) if they filed the reports with NERC but NERC (for whatever reason) did not follow through with ensuring the report was properly filed at the DOE.
Consolidated Edison Co. of NY, Inc.	No	See response to Question 2.
Duke Energy	No	The requirement again states the intent is to “enhance and support situational awareness”, which doesn’t sync with “after-the-fact reporting”. We question why NERC needs to create this report and system for

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		<p>distributing impact event reports to various organizations and agencies for after-the-fact reporting, when we are still required to make real-time reports under other standards. For example, the Rational specifically recognizes that this standard won't release us from the DOE's OE-417 reporting requirement. We don't see that this provides value, unless NERC can find a way to eliminate redundancy in reporting.</p>
Electric Market Policy	No	<p>Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of "applicable government, provincial or law enforcement agencies" for distribution as defined in R1. The "rationale for R1" states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. It seems like the better approach would be for the entities to complete OE-417 form and this standard simply require a copy.</p>
ERCOT ISO	No	<p>Recommend that requirements for the Electric Reliability Organization be removed. However, if the requirements are retained, ERCOT ISO recommends the following wording change to be consistent with other standards. "R1. The ERO shall create, implement, and maintain a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness."</p>
Exelon	No	<p>This requirement should include explicit communications to the NRC (if applicable) of any reports including a nuclear generating unit as a jurisdictional agency to ensure notifications to other external agencies are</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		<p>coordinated with the NRC. Depending on the event, a nuclear generator operator (NRC licensee) has specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(2)(xi). In general, the DSR SDT should include discussions with the NRC to ensure communications are coordinated or consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator for consistency.</p>
FirstEnergy	No	<p>FirstEnergy proposes that requirement R1 and Measure M1 be deleted. A requirement assignment to the ERO is problematic and should not appear in a reliability standard. The team should keep in mind that all requirements will require VSL assignments that form the basis of sanctions. FE does not believe it is appropriate for the ERO to be exposed to a compliance violation investigation as the ERO is not a functional entity as envisioned by the Functional Model. If this "after-the-fact" reporting is truly needed for reliability then the standard must be written in a manner that does not obligate the ERO to reliability requirements. It would be acceptable and appropriate for a requirement to reference the "ERO Process" desired by R1, however, that process should be reflected in the Rules of Procedure and not a reliability standard.</p>
Indeck Energy Services	No	<p>This standard is an inappropriate place to define this requirement. NERC needs to be held accountable, but it should be independent of the standard. What if NERC fails to do it by the effective date of the standard, all Registered Entities will violate the standard until NERC is done. The effective date needs to be set based on NERC completing the system defined in R1.</p>
Independent Electricity System Operator	No	<p>R1 does not directly convey the need for reporting. The requirement could be written to require the responsible entities to report impact events to the ERO using a process to be described in the standard and according to a set of reporting criteria. Whether or not there is a "system" makes little difference if it complies with the requirement to provide the reports on time. In addition, an ERO established system which, without</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 3 Comment
		being included in the standard and posted for public comment and eventually balloted, may not be acceptable to the entities that are responsible for reporting to the ERO. Further, a reliability standard should not need to bother with how the ERO disseminate this information to applicable government, provincial or law enforcement agencies. This is the obligation of the ERO and if required, can be included in the Rules of Procedure.
ISO New England Inc.	No	Having the ERO as an applicable entity raises a concern because they are also the Compliance Enforcement Authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC’s open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of “applicable government, provincial or law enforcement agencies” for distribution as defined in R1. The “rationale for R1” states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. The better approach would be for the entities to complete OE-417 form and this standard simply require a copy.
MidAmerican Energy	No	
NERC Staff	No	NERC staff is concerned about this requirement’s applicability to the ERO. We feel that such a responsibility needs mentioning in the Rules of Procedure, the Compliance Monitoring and Enforcement Program (CMEP), or in a guideline document rather than in a standard requirement. Further, the requirement specifies “how” to manage the event data, not “what” should be monitored.



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
North Carolina Electric Coops	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority.
Northeast Power Coordinating Council	No	Having the ERO as an applicable entity raises a concern because they are also the Compliance Enforcement Authority. The ERO is responsible for multiple requirements in this standard that shape the ultimate actual rules that the other applicable entities would be required to meet. Establishing and maintaining a system for receiving and distributing impact events, per R1, would be done solely by the ERO, outside of NERC's open process. At this stage it is not clear how the ERO will develop or effectively maintain a list of "applicable government, provincial or law enforcement agencies" for distribution as defined in R1. The "rationale for R1" states that OE-417 could be included as part of the electronic form, but responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at DOE. This requirement needs to be more definitive with respect to OE-417. The better approach would be for the entities to complete OE-417 form and this standard simply require a copy.
Puget Sound Energy	No	The language of R1 and M1 does not support the DSR SDT's goal of having a single form and system for reporting. The standard should specify the form and system rather than deferring that decision to the ERO. The language of R1 and M1 leaves the form and system to the ERO's discretion, which could lead to multiple forms and frequent revisions to them. This would lead to difficulties in tracking the reporting requirements. In addition, it is impossible to comment intelligently regarding the overall impact of the proposed standard and its requirements and measures without the reporting form and system being specified in the standard.
Santee Cooper	No	It cannot apply to the ERO.
SERC OC Standards Review	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority. The

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
Group		governance in this situation appears incomplete.
US Bureau of Reclamation	No	This standard should describe the ERO process of event documentation, analysis, and dissemination. Allowing the ERO to develop a event documentation, analysis, and dissemination process, which becomes a requirement on the Entities, must be derived through the Standards Development Process. The requirement, as it is currently worded, allows the ERO to develop standard requirements. If the intent is to only develop a means of collecting, which does not impose a requirement, the wording should state so. Otherwise, if the ERO wants to require that reports are posted to a specific location by the Entity, then it is a requirement and must go through the Standards Development Process. Secondly, there is already a single reporting form identified. It is not clear why the SDT could not accept that form as the reporting tool.
American Electric Power (AEP)	Yes	Overall we support the concepts; however, it is unclear if the ERO can be held accountable for compliance with NERC Requirements. If this requirement is removed there needs to be some mechanism for the ERO to establish a single clearinghouse.
City of Austin dba Austin Energy	Yes	Austin Energy would like to see OE-417 incorporated into the electronic form This will reduce the callout of EOP-004-2 and OE-417 forms in our checklists / documents and one form can be submitted to NERC and DOE.
E.ON Climate & Renewables	Yes	A generic ERCO approved electronic (form that can be submitted on-line) reporting form will help to add more clarity & consistency to the Impact event reporting process.
Georgia System Operations Corporation	Yes	Yes it would reduce duplication of effort and should ensure that the various entities and agencies all have consistent information. It should be simpler and quicker to file than what is needed to meet the current

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 3 Comment
		<p>standard. However, the system should allow for partial reporting and hierarchical reporting. Entities up the ladder in a reporting hierarchy may fill in additional info (usually from a wider scope of view) than what lower level entities are aware of. It would be better for information to go up a hierarchy than for bits and pieces to go to the ERO from many entities. Terminology may be different in each of the bits and pieces yet the same idea may be intended. The ERO may mistake multiple reports as being different events when they are all related to one event. The system should give an entity the ability to select the entities that should receive the impact event report. If hierarchical reporting is not enabled by the system, then entities should be allowed to work out a reporting hierarchy as a group and entities at lower levels should not be required to report over the NERC system. Some higher level entity would enter the information on the NERC system as coordinated by the entities within a group.</p>
Idaho Power Company	Yes	the SDT must ensure that only a single form is required for compliance (such example OE-417)
IRC Standards Review Committee	Yes	Note that ERCOT does not sign on to this particular comment.
Kansas City Power & Light	Yes	Although we support situational awareness for the other registered entities, impact event reports should be distributed anonymously to communicate the information while protecting the registered entity.
Manitoba Hydro	Yes	Yes, keeping R1 generic and pointing to “government”, “Provincial”, “law” encompasses all entities in all major interconnections.
PacifiCorp	Yes	All efforts need to be made to include OE-417 reporting requirements to safeguard against duplicate reporting and / or delinquent reporting. One report for all events is more preferable than multiple reports for one event.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 3 Comment
RRI Energy, Inc.	Yes	While including the phrase "to enhance and support situational awareness" is a good use of the Results-Based Standards development tools and framework, the phrase is already included in the purpose statement. As such, it is unnecessary in Requirement 1. If it were to be included in Requirement 1, then it would also need to be included in each of the other Requirements 2 through 8. The "Purpose" statement captures this aptly.
Southern Company - Transmission	Yes	We do have one concern in that we are hopeful that NERC will develop a system that will allow a one stop shop of reporting.
Avmeren	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
Bonneville Power Administration	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Dynergy Inc.	Yes	
Great River Energy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 3 Comment
Green Country Energy	Yes	
Luminant Energy	Yes	
Midwest ISO Standards Collaborators	Yes	
MRO's NERC Standards Review Subcommittee	Yes	
Nebraska Public Power District	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 3 Comment
Tenaska	Yes	
TransAlta Corporation	Yes	
United Illuminating	Yes	
We Energies	Yes	

**4. Do you agree with the requirement R2 and measure M2? Please explain in the comment box below.**

**Summary Consideration:** Most stakeholders who responded to this question indicated disagreement with Requirement R2 and M2 as originally proposed. There were objections to the use of the term “Operating Plan” to describe the procedure to identify and report the occurrence of a disturbance. The DSR SDT concurs, and Operating plan has been replaced with the generic term “procedure” where appropriate believe that the use of a defined term is appropriate and has revised Requirement 1 to include Operating Plan, Operating Process and Operating Procedure.

R1. Each Responsible Entity shall have an Impact Event Operating Plan that includes [Violation Risk: Factor Medium] [Time Horizon: Long-term Planning]:

- 1.1. An Operating Process for identifying Impact Events listed in Attachment 1.
- 1.2. An Operating Procedure for gathering information for Attachment 2 regarding observed Impact Events listed in Attachment 1.
- 1.3. An Operating Process for communicating recognized Impact Events to the following:
  - 1.3.1. Internal company personnel notification(s).
  - 1.3.2. External organizations to notify to include but not limited to the Responsible Entities’ Reliability Coordinator, NERC, Responsible Entities’ Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.
- 1.4. Provision(s) for updating the Impact Event Operating Plan within 90 days of any change to its content.

Other requirements reference the Operating Plan as appropriate. The requirements of EOP-004 fit precisely into the definition of Operating Plan:

Operating Plan: A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

entities, etc., is an example of an Operating Plan.

Note R2 has been moved to R1 due to elimination of original R1. Many commenters felt that the requirements around updating the Operating Plan were too prescriptive, and impossible to comply with during the time frame allowed. The DSR SDT agrees, and Requirement R2 Parts 2.5 through 2.9 have been eliminated. They have been replaced with Requirement R1, Part 1.4 to update the Operating Plan within 90 days of any change to content.

Organization	Yes or No	Question 4 Comment
Bonneville Power Administration		As long as the 2.4 list is position based, not based on each individual that fills the position. (There is a concern of listing all 2.4 monitoring/reporting personnel in the company that cover the impact event, since there are different function groups and shift work. Documentation trails are difficult with personnel changes.) Because the CIP is being added, it requires an Operating Plan (instead of procedure) with 30 day revision timelines, so it increases the burden for electrical grid event reporting function. R2.9 language refers to R8 “annual” report; however R8 language is “quarterly” reporting of past year. It appears this standard is going to be in an update status 4 times per year, plus any event modifications plus personnel changes. This could be overly burdensome due to the expanding world of cyber security.
Ameren	No	While we agree with the intent to list certain minimum requirements for the Operating Plan, the draft list is too lengthy and prescriptive. This merely creates opportunities for failure to comply rather than the real purpose of reporting data that can be used to meaningfully increase the reliability of the BES by identifying trends of events that may otherwise be ignored.
American Electric Power (AEP)	No	Component 2.2 “Method(s) of assessing cause(s) of impact events” is very vague. Furthermore, there are concerns whether these methods can be accomplished within one hour as might be required per Attachment



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>1, in addition to operating the system. Component 2.6 - need to add the statement “as appropriate for type of impact event” Components 2.7 through 2.9 - are good concepts to consider for future inclusion, but at this point in time these appear to be overreaching objectives. We recommend the SDT take smaller increments towards future progress at measure and reasonable pace. Furthermore, if Component 2.9 is retained it should only pertain to lessons learned on the reporting of impact events not all recommendations regarding remediation of the impact events themselves. Furthermore, the 30 day window to update the Operating Plans is aggressive considering the other priorities that may be present day to day.</p>
ATC	No	<p>The requirement should be rewritten to simply state that the Functional Entities has to meet the reporting obligations documented in Attachment 1. How the Functional Entity meets the obligations documented in Attachment 1 should be determined by the Functional Entity, not the requirement. The prescriptive nature of this requirement does not support the performance-based Standards that the industry and NERC are striving towards. In addition, requirement 2.9 creates an alternate method for NERC to develop Standards outside of the ANSI process. This requirement dictates that Functional Entities are required to incorporate lessons learned from NERC reports into their Plan, which is a requirement of this Standard.</p>
BGE	No	<p>R2.1 Creates the opportunity for differences in identifying impact events. BGE recommends additional clarity in the statement. Are we to use Attachment 1 as a “bright line” or can we use our Operating Plan to identify what an impact event is? R2.4 - 2.6 Does a standard need to specify both internal and external lists? 2.7 - is “component” defined anywhere? Is it a component of the BES or a component of the Operating Plan or a component of the three lists in 2.4 to 2.6? Rationale --- Parts 3.3 and 3.4?? Do you mean 2.3 and 2.4? Is the Operating Plan under scrutiny (mandatory and compensable) for all items in the last paragraph of the rationale?</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
CenterPoint Energy	No	<p>CenterPoint Energy does not agree with R2 and M2 as they are focused on process and procedure. Compliance with a reporting requirement should be based on a complete and accurate report submitted in a timely manner. The process an entity uses to accomplish that task is of no consequence. CenterPoint Energy recommends R2 and M2 be deleted. However, if the SDT feels it is necessary to include this process based requirement, CenterPoint Energy believes the SDT, in requiring an overly prescriptive Operating Plan, has expanded the requirement beyond the current CIP-001-1 and EOP-004-1 which only require "...procedures for the recognition of and for making operating personnel aware..." (CIP-001-1) and "...shall promptly analyze..." (EOP-004-1). Specifically, R2.2 is not found in the current Standards. "Methods for assessing causes(s) of impact events" would vary greatly depending upon the type and severity of the event. Responsible Entities would have a difficult time cataloging these various methods to any specific degree and if they are not specific then CenterPoint Energy questions their value in a documented method. R2.3 is not found in the current Standards and is an unnecessary requirement as the method of notification is irrelevant so long as the notification is made. R2.7, R2.8, and R2.9 are also unnecessary expansions beyond what is currently in CIP-001-1 and EOP-004-1. CIP-001-1 requires the Responsible Entity review its procedures annually and CenterPoint Energy believes this is sufficient. When taken in total, R2 requires seven (7) different processes, provisions, and methods. CenterPoint Energy recommends R2.2, R2.3, R2.7, R2.8 and R2.9 be deleted and believes this will not result in a reliability gap.</p>
City of Garland	No	<p>There are 4 "methods" and 2 "provision" required for this requirement - in other words, 6 "paperwork" items that auditors will audit and likely penalize entities for. On page 1, the statement is made "...proposed standard in accordance with Results-Based Criteria." Having to have 4 methods and 2 provisions to end with a report (all of which is paperwork) is not a "result based" standard. It is like being required to have a "plan to plan on planning on composing and filing a report". Events need to be analyzed, communicated, and reported and</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		should be audited as such (results based) - not audited on whether they have a book filled with methods and provisions.
Consolidated Edison Co. of NY, Inc.	No	<p>Requirement R2</p> <ul style="list-style-type: none"> <li>o Lead-in paragraph - Following the words "Attachment 1" add a period and the words "The Operating Plans shall" and then delete "that" and make "includes" singular.</li> <li>o R2.1, 2.2, 2.3, 2.7 - Replace the word "Method(s)" with the word "Procedure(s)".</li> <li>o 2.6 - After the word "notify" add a period, then insert the words "For example, external organizations may include" and delete the words "to include but not limited to."</li> <li>o 2.8 - After the words "Operating Plan based on" add the word "applicable".</li> </ul> <p>Rational R2 After the words "Every industry participant that owns or operates," add the words "Bulk Electric System." Then delete the words "on the grid."</p>
Constellation Power Generation and Constellation Commodities Group	No	<p>Constellation Power Generation and Constellation Commodities Group has several issues with this requirement, but in general, this requirement is heavily prescriptive, administrative in nature, and is unclear whether it will positively impact BES reliability. As examples of administrative requirements that have no impact on reliability, please consider the following comments:</p> <ul style="list-style-type: none"> <li>o Listing personnel in R2.4, - merely having a list of personnel does not add to the sufficiency of an Operating Plan, but it does create a burdensome obligation to maintain a list. As well, specifying "personnel" may limit plans from designating job titles or other designations that may more appropriately and consistently carry reporting responsibility in the Operating Plan.</li> <li>o R2.5 is unclear as to the intent of the requirement - what is threshold of notification? Is the list to be those that have a role in the event response or a list of all within the facility who may receive news notification of the event? Also, as explained above for 2.4, a list is not a beneficial to reliability, but is administratively burdensome.</li> <li>o What is the reasoning for the 30 day timeframe in R2.7 R2.8 and R2.9? The timeframe is not based on a specific necessity, and creates an unreasonable time frame for changing the Operating Plan, in</li> </ul>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>particular if lessons learned are either short turn adjustments or comprehensive programmatic changes what warrant more time to properly institute. In addition, coupled with other requirements (R4, R5, R8), the updating requirements of R2.7, R2.8 and R2.8 potentially create a continually updating Operating Plan which could create enough confusion to reduce the effectiveness of the Operating Plan. The updating and time frame requirements do not impact reliability, but again impose significant administrative burden and compliance exposure. oR2.9 is particularly problematic for its connection to R8. R8 requires NERC to create quarterly reports with lessons learned and R2.9 requires the registered entities to amend their Operating Plans? What if NERC doesn't write an annual or quarterly report? Are the registered entities out of compliance? The "summary of concepts" for this latest revision, as written by the SDT, includes the following items: oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements oClear criteria for reporting oConsistent reporting timelines oClarity around of who will receive the information and how it will be usedMany of the sub-requirements in R2 do not address any of these items and do not serve to establish a high quality, enforceable and reliability focused standard. Constellation Power Generation therefore recommends that R2 be amended to read as follows:R2. Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 2.1. Method(s) for identifying impact events listed in Attachment 12.2. Method(s) for assessing cause(s) of impact events listed in Attachment 12.3. Method(s) for making internal and external notifications should an impact event listed in Attachment 1 occur. 2.4. Method(s) for updating the Operating Plan.2.5 Method(s) for making operation personnel aware of changes to the Operating Plan.</p>
Consumers Energy	No	R 2.7, R 2.8 and R 2.9 are creating a requirement to have procedures to update procedures. Having updated

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		procedures should be the requirement, no more.
Duke Energy	No	Sections 2.4 and 2.5 should allow identification of responsible positions/job titles rather than specific people. Section 2.9 only allows 30 days for updates to our plan based upon lessons learned coming out of an annual report. 60-90 days would be more appropriate. Also, Section 2.9 says it's an annual report, while R8 only requires quarterly reports.
Dynergy Inc.	No	For 2.7, 2.8, 2.9, 30 days is too stringent. Some changes may not warrant changes until a cumulative amount of changes occur. Suggest making it no later than an annual review.
E.ON Climate & Renewables	No	Administrative burden to some of the components such as 2.5.
Electric Market Policy	No	This is an overly prescriptive requirement given the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan lacks continuity with the ERO Event Analysis Process that is currently slated to begin industry field testing on October 25, 2010. Suggest the SDT coordinate EOP-004-2 efforts with this process. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate and how will duplicative reporting be addressed (for example, DOE, Nuclear Regulatory Commission)? Also, in the "rationale for R2", please explain the reference to Parts 3.3 and 3.4.
ERCOT ISO	No	ERCOT ISO recommends the use of "Registered Entity" in place of "Applicable Entity". This would provide consistency with other requirements and Attachment 1. Recommend the following changes to the subrequirements. "2.6. List of external organizations to notify to include but not limited to NERC, Regional

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>Entity, relevant entities within the interconnection, Law Enforcement, and Governmental or Provincial Agencies.””2.7. Process for updating the Operating Plan within 30 days of any changes not of an administrative nature. This includes updates to reflect any lessons learned as a result of an exercise or actual event.”Remove requirement 2.8 and move content to requirement 2.7.”2.8. Process for updating the Operating Plan within 30 days of publication the NERC annual report of lessons learned.”Add “2.9. Process to ensure updates are communicated to personnel responsible for under the Operating Plan within 30 days of the change being completed.”</p>
Exelon	No	<p>R.2.4 and 2.5 - should not be required to have a list of internal personnel. If an entity has an Operating Plan that covers internal and external notifications that should be sufficient.R2.2.7, 2.8, 2.9 - R4 requires an annual drill. Updating the plan if required following an annual drill should be sufficientWhy does an entity need to develop a stand alone Operating Plan if there is an existing process to address identification, assessing and reporting certain events?30 day implementation for a component change or lesson learned does not seem reasonable or commensurate with the potential impact to the BES and should not be a required element of EOP-004.What is the communication protocol for lessons learned outside of the annual NERC report? What process will be followed and who will review, evaluate, and disseminate lessons learned that warrant updating the Operating Plan?</p>
FirstEnergy	No	<p>The term Operating Plan(s) is not the appropriate term for this standard. These should be called Reporting Plan(s). Operating Plans are usually designed to be applied during the operating timeframe. Parts 2.2 and 2.6 - We suggest changes to these two subparts as well as a new 2.2.1 and 2.6.1 as follows: 2.2. Method(s) for assessing the initial probable cause(s) of impact events(Add) 2.2.1. Method(s) for assessing the external organizations to be notified.2.6. List of external organizations to notify in accordance with Part 2.2.1. to</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>include but not limited to NERC, Regional Entity, and Governmental Agencies.(Add) 2.6.1. Method(s) for notifying Law Enforcement as determined by Part 2.2.1.Parts 2.4 and 2.6: This should be a list of job titles for ease of maintenance. An entity may choose to use someone in a job position that is a 24 by 7 operation with several personnel that cover that position over the 24 by 7 period. Listing each person by name should not be required as personnel change while the operating responsibility related to the job title can remain constant. We suggest changing the wording to "2.4. List of the job titles of internal company personnel responsible for making initial notification(s) in accordance with Parts 2.5.and 2.6.2.5. List of the job titles of internal company personnel to notify."Part 2.6 - We are under the impression that the phrase "include but not limited to" should not be used according to the NEW SDT guidelines. We suggest changing this to say "List of external organizations to notify that includes at a minimum, NERC, Regional Entity, and Governmental Agencies. (A provincial agency is a governmental agency)."Part 2.7. is overly burdensome. FE suggests the team revise to simply reflect annual updates that should consider component changes and updates from lessons learned. This also permits parts 2.8 and 2.9 to be deleted. FE proposes the following text for Requirement R2.7 "Annual review, not to exceed 15 months between reviews, and update as needed of the Reporting Plan that considers component changes and continuous improvement changes from lessons learned."Parts 2.8 and 2.9 - FE proposes to delete part 2.8 and 2.9. We do not see a need for these changes since the plan must be updated annually and will cover lessons learned.</p>
Great River Energy	No	<p>A. As detailed in R2, the Operating Plan shall contain provisions for "identifying, assessing, and reporting impact events". R2.8, and R2.9 do not have a correlation to R2's Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change. We believe that the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>the components of an entity's Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the words "lessons learned" would be required to be in your Operating Plan. It is solely up to an entity to implement a "Lesson Learned" and not the place for this SDT to require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. B. In R2.8 &amp; R2.9, It may be difficult to implement lessons learned within 30 days. We suggest that lessons learned should be incorporated within 12 calendar months if lessons learned are not deleted from the R2.8 &amp; R2.9.</p>
Green Country Energy	No	<p>Highly administrative version of what could accomplish the same thing. A requirement that the applicable entity shall make appropriate notifications as required by attachment A and B events. I can see the need for review and lessons learned but that needs to be done at a higher level since many entities may be involved in an "event"</p>
Idaho Power Company	No	<p>The SDT needs to clarify Requirement 2.9 references an annual report issued pursuant to requirement R8, however Requirement 8 references a quarterly report. These requirements should have the same time frames.</p>
Indeck Energy Services	No	<p>R2 needs to state that the Operating Plan needs to only those Attachment 1 events applicable to the Registered Entity. The Operating Plan should contain a list of these events so that the other Requirements can reference the Operating Plan and not Attachment 1 for the list of events. For example a GO/GOP &lt;2,000 MW would not need to address this type of event and it wouldn't be listed in its Operating Plan. It would be unnecessarily cumbersome, to describe events which are not covered within the Operating Plan.</p>
Independent Electricity System	No	<p>R2 is not needed. An entity does not need to have an "operating plan" to identify and report on impact events;</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
Operator		it needs only to report on the events listed in Attachment 1 in a form depicted in Attachment 2. How does the entity do this, and whether or not an operating plan is in place, or whether its staff is trained to provide the report should not need to be included in a reliability standard for so long as the responsible entity provides the report in the required form on time. If the responsible entity fails to report the listed events in the depicted format, it will be found non-compliant, and that's it - no more and no less. If the "operating plan" really means an established data collection and reporting procedure, then the requirement should be revised to more clearly convey the intent.
IRC Standards Review Committee	No	The SRC suggests that this is not, in fact, an Operating Plan. At most, it may be a reporting plan or reporting procedure. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure bulk power reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. The Operating Plan requirements as proposed seem only to be suitable for real-time notifications. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Unlike the real-time operating notifications which have relatively short reporting time frames, there is sufficient time for personnel to make appropriate communications within their organizations to make timely after the fact reports under NERC Section 1600 authority. Would it be feasible for NERC to issue a standing requirement for timely after-the-fact reports under NERC Section 1600 authority?
ISO New England Inc.	No	This is an overly prescriptive requirement given that the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan is an unnecessary burden that offers no additional improvements to

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>the reliability of the Bulk Electric System, and this is not, in fact, an Operating Plan. At most, it may be a reporting plan. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure Bulk Electric System reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Stating reporting requirements directly in the standard would produce a more uniform and effective result across the industry, contributing towards a more reliable Bulk Electric System. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate, and how will duplicative reporting be addressed (for example, DOE, Nuclear Regulatory Commission)? Also, in the “rationale for R2”, please explain the reference to Parts 3.3 and 3.4.</p>
Kansas City Power & Light	No	<p>We agree with the rationale for R8 requiring NERC to analyze Impact Events that are reported through R6 and publish a report that includes lessons learned but disagree with R2.9 obligating an entity to update its Operating Plan based on applicable lessons learned from the report. Whether lessons learned are applicable to an entity is subjective. If an update based on lessons learned from an annual NERC report is required, the requirement should clearly state the necessity of the update is determined by the entity and the entity’s Reliability Coordinator or NERC can not make that determination then find the entity in violation of the requirement. In addition, if an update based on lessons learned from a NERC report is required, NERC should publish the year-end report (R8) on approximately the same day annually (i.e. January 31) and allow</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>an entity at least 60 days to analyze the report and incorporate any changes it deems necessary in its Operating Plan. In addition, the language using quarterly and annual as a requirements between R2.9 and R8 is confusing.</p>
MidAmerican Energy	No	<p>R2 and R5 coupled with R8 will drive quarterly updates (in addition to drills, etc) and training to the literally hundreds to thousands of people per company for the proper internal operating personnel and management will actually hurt the development of a culture of compliance by overwhelming personnel with constant plan changes and training. The standards drafting team should remove all 30 day references or provide the technical basis of why revising plans and training to “changes and lessons learned” quarterly all within 30 days is the right use of reliability resources to improve the grid. The addition of the 30 day constraints and new vague criteria in Attachment one such as “damage to a BES element through and external cause” or “transmission loss of multiple BES elements which could mean two or more” is the opposite of clear standards writing or results based standards. We disagree with requiring an Operating Plan for identifying, assessing, and reporting impact events. This is an administrative requirement that has no clear reliability benefit. Furthermore, it is questionable that event reporting even meets the basic definition of an Operating Plan. Per the NERC glossary of terms, Operating Plans contain Operating Procedures or Operating Processes which encompass taking action real-time on the BES not reporting on it. As detailed in R2, the Operating Plan shall contain provisions for “identifying, assessing, and reporting impact events”. R2.8, and R2.9 do not have a correlation to R2’s Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change, the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in the components of an entity’s Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>words “lessons learned” would be required to be in your Operating Plan. It is solely up to an entity to implement a “Lesson Learned” and not the place for this SDT to require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. In R2.8 &amp; R2.9, It may be difficult to implement lessons learned within 30 days. The NSRS recommends to incorporate lessons learned within 12 calendar months if lesson learned are not deleted from the R2.8 &amp; R2.9.</p>
<p>Midwest ISO Standards Collaborators</p>	<p>No</p>	<p>We disagree with requiring an Operating Plan for identifying, assessing, and reporting impact events. This is an administrative requirement that has no clear reliability benefit. Furthermore, it is questionable that event reporting even meets the basic definition of an Operating Plan. Per the NERC glossary of terms, Operating Plans contain Operating Procedures or Operating Processes which encompass taking action real-time on the BES not reporting on it. What is an impact event? It appears that this undefined, ambiguous term was substituted for sabotage which is also undefined and ambiguous. One of the SARs stated goals was to “provide clarity on sabotage events”. This does not provide clarity.</p>
<p>MRO's NERC Standards Review Subcommittee</p>	<p>No</p>	<p>A. As detailed in R2, the Operating Plan shall contain provisions for “identifying, assessing, and reporting impact events”. R2.8, and R2.9 do not have a correlation to R2’s Operating Plan. Where, R2.7 states to update the Operating Plan when there is a component change. The NSRS believes the components of this Operating Plan are only 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. R2.8 and R2.9 are based on Lessons Learned (from internal and external sources) and do not fit in the components of an entity’s Operating Plan. R2.7 requires the Operating Plan to be updated. As written, every memo, simulations, blog, etc that contain the words “lessons learned” would be required to be in your Operating Plan. It is solely up to an entity to implement a “Lesson Learned” and not the place for this SDT to</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		<p>require an Operating Plan to contain Lessons Learned. Recommend that R2.8 and R2.9 be deleted for this requirement. If R2.8 and R2.9 are not removed, R5.3 will be in a constant state of change. B. In R2.8 &amp; R2.9, It may be difficult to implement lessons learned within 30 days. The NSRS recommends to incorporate lessons learned within 12 calendar months if lesson learned are not deleted from the R2.8 &amp; R2.9.</p>
North Carolina Electric Coops	No	<p>This requirement dictates details of documentation of after-the-fact reporting of events which cannot impact reliability of the BES and, as such, should not be a reliability standard. The cost and burden of becoming auditably compliant with this requirement can be extreme for small entities.</p>
Northeast Power Coordinating Council	No	<p>This is an overly prescriptive requirement given that the intent of this standard is after-the-fact reporting. The requirement to create an Operating Plan is an unnecessary burden that offers no additional improvements to the reliability of the Bulk Electric System, and this is not, in fact, an Operating Plan. At most, it may be a reporting plan. Most of these requirements are administrative and procedural in nature and, therefore, do not belong as requirements in a Reliability Standard. Perhaps they could be characterized as a best practice and have an associated set of Guidelines developed and posted on the subject. As proposed, the Operating Plan is not required to ensure Bulk Electric System reliability. As stated in the purpose of this standard, it does not cover any real-time operating notifications for the types of events covered by CIP-001, EOP-004. Since these incidents are meant to be reportable after-the-fact, familiarity with the reporting requirements and time frames is sufficient. Stating reporting requirements directly in the standard would produce a more uniform and effective result across the industry, contributing towards a more reliable Bulk Electric System. R2.6 establishes an external organization list for Applicable Entity reporting, yet R1 suggests that external reporting will be accomplished via submittal of impact event reports. How will the two requirements be coordinated? What governmental agencies are appropriate, and how will duplicative reporting be addressed (for example, DOE,</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
		Nuclear Regulatory Commission)? Also, in the “rationale for R2”, please explain the reference to Parts 3.3 and 3.4.
Pacific Gas and Electric Company	No	PG&E would like clarification on whether the 30 days, is calendar days or business days.
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
Pepco Holdings, Inc - Affiliates	No	For R 2.7, 2.8 and 2.9, 30 days may be too short a time for large entities with multiple subsidiaries to do the necessary notice and coordination. PHI suggests 90 days.
PNM Resources	No	PNM would like clarification on whether the 30 days, is calendar days or business days.
PPL Electric Utilities	No	While we agree with documenting our process, we feel the use of the defined term Operating Plan is not required and possibly a misuse of the term. We would like to suggest using the term ‘procedure’. Additionally, we would like the SDT to confirm/clarify whether Attachment 1 is a complete list of impact events. Also, please confirm that the Proposed R2.1 language ‘Method(s) for identifying impact events’ means identifying impact event occurrence as opposed to identifying list of impact events. i.e. does R2.1 mean recognize impact event occurrence?
PPL Supply	No	While we agree with concept addressed in R2, we don't agree with use of the defined term Operating Plan. Consider working the requirement as follows: "Each Applicable Entity identified in Attachment 1 shall have a documented process or program that includes the following components:..." Also, please consider changing 2.1 to be"Method(s) for recognizing the occurrence of impact events." The current wording could be

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 4 Comment
		interpreted to mean, "create a list of the impact events."
Puget Sound Energy	No	While the concept of an operating plan is reasonable, the requirements for update in sections 2.7, 2.8 and 2.9 will lead to an immense amount of work for the entities subject to the standard. In addition, constant revisions to the operating plan makes it difficult to cement a habit through this procedure. The proposed update schedule does not strike the appropriate balance between the need to respond to lessons learned and the value of plan continuity.
RRI Energy, Inc.	No	1. R2 includes the phrase "for identifying, assessing and reporting," followed by R2.1 which states "identifying," R2.2 which states "assessing" and both R2.3 and R2.6 state "notify" or "making internal and external notifications" (i.e., reporting). The language is unnecessarily redundant. RECOMMENDATION: Reword R2 phrase "for identifying, assessing and reporting," to simply state, "for addressing." 2. Rationale for R2 - The rationale section for R2 references in the third paragraph "Parts 3.3 and 3.4." Was this intended to reference R2.3 and R2.4?
Santee Cooper	No	The words "operating plan" should be removed from the requirement. This standard deals exclusively with after-the-fact reporting. This requirement is also overly prescriptive.
SERC OC Standards Review Group	No	This is an overly prescriptive requirement that dictates details of documentation and, as such, has no place in a reliability standard. NERC needs to trust the RCs to do their jobs; this standard and this requirement in particular seems to be attempting to codify the actions that an RC would take in response to an event. The cost and burden of becoming auditably compliant with this requirement is extreme and unrealistic, especially on small entities

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
Southern Company - Transmission	No	The Operating Plan has a different connotation for different operations folks. We suggest that we call it an Impact Event Reporting Plan.
Tenaska	No	We have adequate compliance procedures already in place for the existing CIP-001-1 and EOP-004-1 Standards. The list of required "Operating Plan" components in the proposed R2 is too specific. Maintaining the "Operating Plan" described in R2 would increase the burden on Registered Entities to comply with the Standard and this type of "laundry list" Requirement would make it more difficult to prove compliance with EOP-004-2 during an audit.
United Illuminating	No	R2.9 requires provisions to update the Operating Plan based on the annual ERO report developed in R8. The ERO report does not appear to be providing lessons learned to be applied to the Operating Plan for impact event reporting, but more focused on trends and threats to the BES. Also 30 days after the report is published by NERC is not enough time for the entity to read, and assess the report, and then to administratively update the Operating Plan. UI agrees that the Operating Plan should be reviewed annually and updated subsequent to the review within 30 days.
US Bureau of Reclamation	No	R2 does not reconcile with Attachment A or the sub paragraphs. As an example, the requirement 2.6 states "List of organizations to notify ...." All sub paragraphs use the term notify. Notify as used in Attachment A is when a report cannot be provided in the time frame listed in Attachment A. Therefore there is no requirement in this standard for the Operating Plan to have a provision for reporting. The subparagraph 2.8 indicates that the Entity must update it plan based on the lessons learned published by NERC. It would be appropriate to require a review and update of the plan based on the lessons learned.



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
We Energies	No	R2.3, R2.4: "Part" is not a defined term or used in the NERC Standard Process Manual.R2: Attachments are not mentioned in the NERC Standard Process Manual. Is this a mandatory or informational part of the standard?R2.6 (and possibly R2.5): There does not seem to be discretion in notifications. Are all people or organizations on the notify lists always contacted for every impact event? Even Law Enforcement?R2.7: What is a "component? A Plan component? A BES component?R2.9: There is no annual NERC report issued pursuant to R8. R8 requires quarterly reporting.
WECC	No	Need clarification on whether the 30 days is calendar days or business days. As noted in the comment to question 3, any impact event where sabotage is suspected should be treated differently from those where sabotage is not suspected.
Arizona Public Service Company	Yes	AZPS agrees with R2, however, the use of the term "Operating Plan" is confusing. A more accurate term would be "Event Reporting Plan."
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Georgia System Operations Corporation	Yes	An entity-developed Operating Plan will allow the flexibility needed to address different entity relationships around the country, e.g., generating companies, cooperatives, munis, large IOUs, small IOUs, RTOs/ISOs, non-independent market area, and so on.However, all applicable entities should not be required to report directly to NERC or the region. The system should allow for partial reporting and hierarchical reporting. Entities within an area should be allowed to coordinate their plans to define reporting procedures within their area. They could have an entity at some wide scope top level that reports to NERC and the region the

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 4 Comment
		information collected from multiple narrow scope lower levels within their wide area. If every small lower level entity directly reported to NERC and the Region, it could create situational confusion rather than situation awareness.
Manitoba Hydro	Yes	R2 - 2.1 to 2.9 detail what is expected of an Operating Plan for Impact Events.The attachment 1 details the event, the threshold parameters and time line. Though the threshold parameters in the attachment may be questioned, this greatly clarifies the expectations of reporting events. Further events should be added to this list:"Detection of suspected or actual or acts or threats of physical sabotage"
Luminant Energy	Yes	
Nebraska Public Power District	Yes	
NERC Staff	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
TransAlta Corporation	Yes	

5. Do you agree with the requirement R3 and measure M3? Please explain in the comment box below.

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question. Requirement R3 has been re-written to exclude the requirement to “assess the initial probable cause”. The only remaining reference to “cause” is in the Impact Event Reporting Form (Attachment 2). Here, there is no longer a requirement to assess the probable cause. The probable cause only needs to be identified, and only if it is known at the time of the submittal of the report.

Organization	Yes or No	Question 5 Comment
Ameren	No	There are too many missing details on how this will be accomplished. As stated before, this Draft requires too much time be invested in verbal reports, "Preliminary" reports, "Final" reports and even "Confidential" reports (Attachment 2). If the goal is to report ASAP details on events which could impact BES reliability, all of these reports will need to be made at the worst possible time - when Operators are trying to collect data, analyze what they find and correct major problems on the system. And if the reports are wrong or not issued fast enough, the Operators will be keenly aware of potential fines and violations.
American Electric Power (AEP)	No	Not clear how this is different from R6 since it relies on the same timetable in Attachment 1.
ATC	No	ATC believes that this requirement should be deleted and that the SDT should coordinate its goal with the EAWG. We believe that the lessons learned process and identification of root cause is better covered under that process than through the NERC Mandatory Standards.
BGE	No	R3. Limits responsibility to Attachment 1 events only and mandates that an “initial probable cause” be identified. Are we at liberty to define “initial probable cause” and define time period for completion in the Operating Plan? BGE believes this could cause wide difference between Operating Plans and the standard

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		should be more prescriptive by relating to a time-table for the life of an impact event, including expected identification time, initial assessment time and analysis time leading to the reporting deadlines. BGE recommends not including examples of evidence in a measure but include it in a Guideline. Including in a measure will be translated as a requirement by an auditor.
CenterPoint Energy	No	CenterPoint Energy does not agree with R3 and M3 as written as the Company does not agree with the requirement to have an Operating Plan (see comments to Q4 above). However, if R2 and M2 were to be deleted, and R3 was revised to read; "Each Applicable Entity shall identify and assess initial probable cause of events listed in Attachment 1.", CenterPoint Energy could agree with this requirement.
City of Garland	No	Should be part of R2 or R6 - this is unnecessary duplication
Constellation Power Generation and Constellation Commodities Group	No	This requirement introduces double jeopardy for registered entities. If an entity does not include methods for identifying impact events and for assessing cause per R2.1 and R2.2 in their Operating Plan, they will be out of compliance with R2. Without the methods in R2 the registered entity is out of compliance with R3 as well for failing to identify and assess. Constellation Power Generation therefore recommends that R3 be amended to be incremental to R2 and read as follows: R3. Each Applicable Entity shall implement their Operating Plan(s) to identify and assess cause of impact events listed in Attachment 1.
Electric Market Policy	No	We think "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build audit ready compliant procedures.
ERCOT ISO	No	ERCOT ISO recommends the use of "Registered Entity" in place of "Applicable Entity". This would provide consistency with other requirements and Attachment 1. The measure for this requirement notes the obligation

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		for “documentation”. This is not addressed in the requirement. The measure also notes “on its Facilities”. This clarification of scope should be addressed in the requirement. R3. Each Registered Entity shall identify, assess, and document initial probable cause of impact events on its Facilities listed in Attachment 1.
Exelon	No	: Agree that Each Applicable Entity shall identify and assess initial probable cause of impact events; disagree with aspects and time requirements in Attachment 1.
FirstEnergy	No	M3 - Power flow analysis would be used to assess the impact of the event on the BES, not to determine initial probable cause. It is more likely that DME would provide the data for the initial probable cause evaluation. We suggest rewording M3 as follows: "To the extent that an Applicable Entity has an impact event on its Facilities, the Applicable Entity shall provide documentation of its assessment or analysis. Such evidence could include, but is not limited to, operator logs, voice recordings, or disturbance monitoring equipment reports. (R3)"
Green Country Energy	No	Actually yes and no... An event may be caused, analyzed and corrected by one entity but most likely it will involve more. Low Voltage or frequency may not be caused by a generator but the generator will see the event and to have the generator assess the probable cause seems inappropriate. I can see reporting the event and duration and making notifications.
Indeck Energy Services	No	R3 should reference the events covered by the Operating Plan, as listed in it, rather than in Attachment 1. If the Plan is deficient, it is a violation of R2 and not every other Requirement that references the Plan.
Independent Electricity System Operator	No	We agree that the responsible entity needs to identify and assess initial probable cause of impact events but not in accordance with any operating plan in R2. Each operating entity (RC, BA, TOP) has an inherent responsibility to identify the cause of any system events to ensure it complies with a number of related

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		operational standards. R3, in fact, could be revised to require the Responsible Entity to include the probable cause of impact events in its report, rather than asking it to “identify and assess” since this is not measurable. Also, the ERO may be removed from the Applicability Section depending on the response to our comments under Q9.
IRC Standards Review Committee	No	Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes quite some time for an actual cause to be determined. The determination process may require a root cause analysis of some complexity. Further, in the case of suspected or potential sabotage, the industry can only say it doesn’t know, but it may be possible. It really is the law enforcement agencies who make the determination of whether sabotage is involved and the info may not be made available until an investigation is completed, if indeed it is ever made available.
ISO New England Inc.	No	We think “impact event” needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditable compliance procedures. Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes a considerable amount of time for an actual cause to be determined. The determination process may require a complex root cause analysis. Further, in the case of suspected or potential sabotage, the industry can only say it doesn’t know, but it may be possible. Law enforcement agencies make the determination of whether sabotage is involved, and the information may not be made available until an investigation is completed, if indeed it is ever made available.
Kansas City Power & Light	No	We believe R3 and M3 are unnecessary as a stand alone requirement and measure and propose combining this requirement and measure with R6 and M6. Identifying and assessing the initial probable cause of an

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
		impact event is the obvious starting point in the reporting process and ultimate completion of the required report. Evidence to support the identification and assessment of the impact event and evidence to support the completion and submittal of the report are really one in the same.
Manitoba Hydro	No	Though each local entity should identify and assess initial probable cause of impact events as per their Operating Plan, the creation of this Operating Plan could be labor intensive and also guidelines for consistency within an RC region should be created. So “NO” is entered simply because a large time line would be needed to properly and efficiently implement R3 and R4.
MidAmerican Energy	No	
Midwest ISO Standards Collaborators	No	While we agree that it makes sense to report on the cause of an event, we disagree with the need for an Operating Plan as identified in R2.
North Carolina Electric Coops	No	The term “impact event” needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditably compliant procedures and give guidance on what is proper to report.
Northeast Power Coordinating Council	No	"Impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditable compliance procedures. Although it is useful for entities to make an initial assessment of a probable cause of an event, this requirement should stand alone and does not need to be tied to requirement R2, Operating Plan. Quite often, it takes a considerable amount of time for an actual cause to be determined. The determination process may require a complex root cause analysis. Further, in the case of suspected or potential sabotage, the industry can only say it doesn't know, but it may be possible. Law enforcement agencies make the determination of whether sabotage is involved, and the information may not be made

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 5 Comment
		available until an investigation is completed, if indeed it is ever made available.
Pacific Northwest Small Public Power Utility Comment Group	No	Comments: When applying R3 to row 11 of attachment 1, the comment group notes that applicable entities are expected to assess probable cause of BES equipment damage, including that which may be the result of criminal behavior. At best this would needlessly duplicate the efforts of law enforcement. A more likely result is that entity involvement would interfere with law enforcement and ultimately hinder prosecution of those responsible. Also See #15
PPL Electric Utilities	No	We believe the rationale for R3 is good and provides value. However, we feel the clarity was lost when the rationale was translated to the standards language. Please consider revising language to refocus on rationale of assess and report per Attachment 1 as opposed to identify. We suggest changing the word "identify" to "recognize" and add the Rationale statement to the requirement as follows: "Each Applicable Entity shall assess the causes of the reportable event and gather available information to the complete the report."
PPL Supply	No	Please consider changing the word "identify" to "recognize" and adding the Rationale statement to the requirement as follows: "Each Applicable Entity shall assess the causes of the reportable event and gather available information to complete the report."
RRI Energy, Inc.	No	"Identify and assess" - Auditors are as much in need of clearly worded, unambiguous Reliability Standards are as Registered Entities. This phrase leaves much too wide a range of interpretations, almost guaranteeing regular and frequent disagreements during an audit between Registered Entity and Regional Entity auditor as to what constitutes "identify and assess" sufficient to meet the intent of this Requirement. Compounding this issue is the Rationale for R3 that states an Applicable Entity (which should probably read "applicable



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 5 Comment
		<p>Functional Entity") should "gather enough information to complete the report that is required to be filed." While Rationale statements are not technically part of the standard, this emphasizes the current wording of the requirement as subject to random and arbitrary interpretation by auditors and Registered Entities. RECOMMENDATION: Change "identify and assess" to "document," so that the Requirement now reads "Each Applicable Entity shall document initial probable cause of impact events..." including an option for "cause not determined".</p>
Santee Cooper	No	<p>Does the initial probable cause have to be reported within the timing associated in Attachment 1? Entities may not have enough information that soon to report the initial probable cause. This should be done with events analysis.</p>
SERC OC Standards Review Group	No	<p>We think "impact event" needs to be defined in the NERC Glossary to provide the clarity the industry needs to build auditably compliant procedures.</p>
Tenaska	No	<p>The probable cause of a reportable event is already required to be submitted on the OE-417 form. This Requirement is redundant.</p>
TransAlta Corporation	No	<p>Clarity required Does an entity have to report on the cause of every "applicable" impact event they witness even though the event did not originate at their plant, system or region and did not adversely affect them? Essentially this would require every entity that witnessed an "applicable" event to report on its cause. In most cases they will not know the cause if they did not create the event. Measure M3 should reference Attachment 1 to indicate the Time to Submit Report'.</p>
We Energies	No	<p>A DP may not have Facilities (a BES element). See NERC Glossary definition of Facility.</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 5 Comment
Bonneville Power Administration	Yes	Known causes are difficult under 1 hour reporting requirements. (Unusual events are even harder to narrow down in 24 hours and may take weeks.)
Consolidated Edison Co. of NY, Inc.	Yes	We agree, however, the term “impact event” must be part of the NERC glossary.
Georgia System Operations Corporation	Yes	It directly supports the purpose of the standard.
Great River Energy	Yes	While we agree that it makes sense to report on the cause of an event, we disagree with the need for an Operating Plan as identified in R2
MRO's NERC Standards Review Subcommittee	Yes	The NSRS thanks the SDT for stating “initial probable cause” as this is in direct correlation to the Purpose which states “known causes”.
Puget Sound Energy	Yes	However, this requirement doesn't address the timing required for this analysis. This may be intentional and appreciated because at times the analysis can take months when the events are complex in nature.
US Bureau of Reclamation	Yes	This is provided that the report submitted in Attachment A does not include the probable cause. It is highly unlikely that a probable cause may be determined within the reporting timelines.
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 5 Comment
City of Austin dba Austin Energy	Yes	
Duke Energy	Yes	
Dynergy Inc.	Yes	
Idaho Power Company	Yes	
Luminant Energy	Yes	
NERC Staff	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
Southern Company - Transmission	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 5 Comment
United Illuminating	Yes	
WECC	Yes	

**6. Do you agree with the requirement R4 and measure M4? Please explain in the comment box below.**

**Summary Consideration:** Note R4 has been moved to R3 due to rearranging of requirements. The DSR SDT did a full review based on comments that were received. R3 now is stream lined to read:

R3. Each Responsible Entity shall conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 months between such tests. The testing of the procedure (as stated in R1) is the main component of this requirement. Several commenters provided input that too much “how” was previously within R3 and the DSR DST should only provide the “what”. The DSR SDT did not provide any prescriptive guidance on how to accomplish the required verification within the rewrite. Testing of the entity’s Operating Process (R1) could be by an actual exercise of the process (testing as stated in FERC Order 693 section 471), a formal review process or real time implementation of the process. The DSR SDT reviewed Order 693 and section 465 directs that processes “verify that they achieve the desired result”. This is the basis of R3, above.

Organization	Yes or No	Question 6 Comment
Ameren	No	Establishing a program with trigger actions expected to require reporting several times a year, combined with adequate initial, and on-going, training should preclude the need for mandatory drills as an added compliance burden.
ATC	No	We do not believe that a drill that exercises a written reporting obligation will add additional reliability to the BES.
BGE	No	M4. BGE recommends not including examples of evidence in a measure but include it in a Guideline. Including in a measure will be translated as a requirement by an auditor.Rationale for R4: If multiple

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 6 Comment
		exercises are performed are all of them subject to the sub-R2 requirements and to audit/audit findings?
Bonneville Power Administration	No	There was no drill required for CIP-001 (a drill was in CIP-008, but the purpose did not list combining CIP-008). A drill is not needed for reporting Electrical Grid events, designate it as excluded in the intent of the requirement.
CenterPoint Energy	No	CenterPoint Energy does not agree with R4 and M4. See comments to Q4 above. In addition to the process vs. results based issue stated above, CenterPoint Energy believes conducting a drill to verify recognition, analysis, and reporting procedures is a waste of valuable resources and time.
City of Garland	No	Existing CIP 001 and EOP 004 are reporting standards - neither currently requires annual drills or exercises. Combining these two (2) should not entail expanding the requirements to include drills or exercises. There are existing drills / exercises that must be performed annually for compliance with CIP 008 & CIP 009 which require the same basic identifying, assessing, developing lessons learned, responding, and reporting skill sets. Requiring additional drills or exercises for this new combined standard will provide additional “business overhead” that results in basically nothing that is not obtained by the CIP 008 / 009 drills as far as securing or making the BES reliable. It does, however, result in additional audit risk at audit time.
Constellation Power Generation and Constellation Commodities Group	No	It is not clear how this requirement to conduct drills and exercises relates to the concepts spelled out by the SDT: a single form to report disturbances and impact events that threaten the reliability of the bulk electric system. Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements. Clear criteria for reporting. Consistent reporting timelines. Clarity around of who will receive the information and how it will be used. R4 does not address any of the above items and should therefore be removed from this standard.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 6 Comment
Consumers Energy	No	NERC should either standardize on a 12 month year or an annual year for reviews.
Dynergy Inc.	No	What is the basis for the drill being annual. This is to stringent. I suggest it be every 3 years.
Electric Market Policy	No	The need for a periodic drill has not been established and appears to be overly restrictive given the intent of the standard is reporting of impact events. Suggest this requirement be eliminated.
ERCOT ISO	No	ERCOT ISO believes that a drill or exercise of its Operating Plan is unnecessary. The intent of the drill can be addressed within the training requirements under R5.
Exelon	No	If drills remain as a component of the standard, an effort to consolidate updating an entities plan with a requirement to drill the plan should be made. . Each entity/utility should be able to dictate/determine if they need a drill for a particular event. Is this document implying a drill for every type of event?
FirstEnergy	No	FE suggests that this requirement be deleted. FE does not see a reliability need for conducting a drill on reporting. This is overly burdensome and should not be included within this reliability standard. Training on the plan and periodic reminder of reporting obligations should suffice.
Great River Energy	No	We disagree with the need to conduct a drill for reporting
Green Country Energy	No	Another training requirement with what benefit? We must train on all of our NERC requirements now anyway to insure compliance and that's not a requirement, thats implied and I think thats enough.
Indeck Energy Services	No	In M4, it is suggested that data from a real event would be evidence. R4 should be satisfied if the Operating

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 6 Comment
		Plan is used for a real event within 15 months of the last drill or event.
Independent Electricity System Operator	No	Along the line of our comments on R2 for an operating plan (whose need we do not agree with), a drill, exercise, or Real-time implementation of the Operating Plan for reporting is also not necessary.
IRC Standards Review Committee	No	Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are really training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in a short time frame as may be required for real-time operating notifications.
ISO New England Inc.	No	The need for a periodic drill has not been established, and appears to be overly restrictive given the intent of the standard is the reporting of impact events. Suggest this requirement be eliminated. Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in as short a time frame as may be required for real-time operating conditions notifications.
Kansas City Power & Light	No	We believe R4 and M4 are clearly unnecessary. Thoughtful preparation of an Operating Plan per R2 that specifically addresses personnel responsibilities and appropriate evidence gathering combined with the training requirement in R5 is sufficient.
Luminant Energy	No	We support the requirements outlined in R2 which create significant obligations to maintain and update the required Operating Plan. However, we believe annual drilling for a reporting process seems unnecessary, particularly given the response horizon of 24 hours for the majority of impact events. If drilling is required, the



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 6 Comment
		standard should allow actual events to fulfill a drilling requirement as stated in the Rationale for R4 and within the text of M4.
Manitoba Hydro	No	Drills and exercise for implementation of the Operating Plan are important and critical, but as in question 5, or Requirement R3, careful and detailed creation of the Operating Plan are crucial to facilitate proper training, drills and exercises. So “NO” is entered simply because a large time line would be needed to properly and efficiently implement R4 and R3.
MidAmerican Energy	No	
Midwest ISO Standards Collaborators	No	We disagree with the need to conduct a drill for reporting.
North Carolina Electric Coops	No	Requiring a drill for “reporting” is unnecessary and burdensome. Reporting is covered in processes and procedures and during the normal training cycle. We recommend the elimination of this requirement.
Northeast Power Coordinating Council	No	The need for a periodic drill has not been established, and appears to be overly restrictive given the intent of the standard is the reporting of impact events. Suggest this requirement be eliminated. Similar to our comments on R2 for an Operating Plan, a drill, exercise, or Real-time implementation of its Operating Plan for reporting is unnecessary. Such things are training practices. There are already existing standards requirements regarding training. There is no imminent threat to reliability that requires these events to be reported in as short a time frame as may be required for real-time operating conditions notifications.
Pacific Gas and Electric	No	PG&E believes the addition of a drill constitutes additional training and should be added to R5. PG&E is

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 6 Comment
Company		concerned as to who the target audience for this annual training would affect.
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PNM Resources	No	PNM feels the addition of a drill or exercise constitutes additional training and believes R4 should be added to R5. The WECC OTS also is interested as to what level does the annual training target, for instance, the field personnel. Will they have to complete the exercise/drill?
RRI Energy, Inc.	No	Every employee in a Registered Entity might potentially have exposure to an impact event, and therefore result in a list of thousands of employees subject to the EOP-004-2 Operating Plan. Does this mean, for example, an applicable Functional Entity with 3,000 employees, each capable of potentially observing an impact event, must include them in the drill, exercise, or Real-Time implementation? Such an expectation would require a hypothetical email notice to be sent to 3,000 employees, advising them "This is a test - You observe a suspicious vehicle driving around the fence of your power plant. Perform the next action you should take." The result in this hypothetical might be 3,000 phone calls and emails to the responsible employee in the applicable Functional Entity, each needing to be documented and retained for the audit period. As stated above in question 5, auditors need guidance as much as Registered Entities. Otherwise, it is observed that they will seek the most stringent approach they observe from the best of the best practices over the first year of implementation and apply that expectation as the base-case, under which all other approaches will be deemed violations.
Santee Cooper	No	There is no need to drill for administrative reporting! This requirement should be deleted.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 6 Comment
SERC OC Standards Review Group	No	We think this requirement is unclear - we think it requires a drill for "reporting", which seems absurd! We recommend the elimination of this requirement.
Tenaska	No	This Requirement is too specific and places additional burdens on Registered Entities.
US Bureau of Reclamation	No	There is no rationale offered on why 15 months was selected. Without a defined basis the time period is arbitrary. It would be appropriate to let the Entity determine and document the time interval. That would allow the time frame to be sensitive to the complexity of the Operating Plan. Some entities are geographically dispersed and a single Operating Plan may be difficult to test at one time or within 15 months. The allowance for real time events or actual use is a good move and may make it easier to define a suitable time frame by the Entity.
WECC	No	The addition of a drill or exercise constitutes additional training and believes R4 should be added to R5. Clarification is needed as to what level does the annual training target, for instance, the field personnel. Will they have to complete the exercise/drill?
American Electric Power (AEP)	Yes	
Arizona Public Service Company	Yes	AZPS agrees with R4, however, the use of the term "Operating Plan" is confusing and leads one to believe an Operating Drill is necessary for a "reporting plan drill." A more accurate term to use would be "Event Reporting Plan."
Georgia System Operations Corporation	Yes	We agree with R4 with "... at least annually, with no more than 15 months ..." replaced with "... at least once per calendar year, with no more than 15 months ..." as in R5.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 6 Comment
MRO's NERC Standards Review Subcommittee	Yes	The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be exercised once per calendar year.
United Illuminating	Yes	Suggest R4 be improved to state that a Registered Entity is only required to conduct a drill or execute real-time implementation of the Operating Pan for one impact event listed in the attachment. In other words the Registered Entity is not required to drill on reporting each type of impact event on an annual basis.
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Duke Energy	Yes	
Idaho Power Company	Yes	
NERC Staff	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 6 Comment
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Puget Sound Energy	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
We Energies	Yes	

**7. Do you agree with the requirement R5 and measure M5? Please explain in the comment box below.**

**Summary Consideration:** Most stakeholders who responded to this question indicated disagreement with the originally proposed Requirement R5 and Measure M5. (Note R5 has been moved to R4 in the revised standard. ) The DSR SDT did a full review based on comments that were received. The major issues that were provided by commenters was R5.3 and R5.4 and their contents. Upon detailed review the DSR SDT agrees with the majority of comments received with R5.3 and R5.4 and have removed them completely from the Standard. Training is still the main theme of this requirement as it pertains to the personnel in the procedure (R1). R4 now is stream lined to read:

R4. Each Responsible Entity shall review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan at least annually with no more than 15 calendar months between review sessions

Organization	Yes or No	Question 7 Comment
Green Country Energy		Same as my comment for question 6
Arizona Public Service Company	No	AZPS believes the required training is too restrictive for minor changes/edits to the Event Reporting Plan.
ATC	No	ATC believes it is an inherent obligation of all Functional Entities to train their appropriate staff to meet all applicable NERC Standards. Including a training requirement in some, but not all, Standards implies that the other Standards do not necessitate training. Although this is an important Standard and one that should be included in a Functional Entities' training program, ATC does not believe that this Standard is more important than the other NERC Standards and, therefore, requires a separate training provision
ATCO Electric Ltd.	No	R5.3 requires an entity to conduct training within 30 days of a revision to the Operating Plan. For an entity

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		that covers a wide area, 30 days may not be sufficient to reach all employees.
BGE	No	Suggested revision to clarify R5:Each Applicable Entity shall provide training to all internal personnel identified in its Operating Plan on the Operating Plan annually. Training is only on Reporting, pursuant to R2, not on the Operating Plan?BGE does not believe the SDT needs to identify sub bullets on this requirement. R5.1 is not logical --- what does it mean?
CenterPoint Energy	No	CenterPoint Energy believes that R5 and M5 are not necessary and should be deleted. CenterPoint Energy supports an entity training its staff in any reporting responsibilities; however, such training should be the responsibility of each entity and such requirements do not belong in a NERC standard. In addition, CenterPoint Energy believes any necessary training requirements are covered in the PER Standards and therefore the addition of this requirement adds redundancy to the Standards.If a majority of the industry supports such a requirement, CenterPoint Energy cannot support R5 and M5 as written as we do not agree with the requirement to develop and maintain an Operating Plan (see comments to Q4 above). CenterPoint Energy offers the following alternate language: “Each Applicable Entity shall provide training concerning reporting requirements contained in this Standard to internal personnel involved in the recognition or analysis of events listed in Attachment 1.
City of Garland	No	This expands beyond the original CIP 001 and EOP 004 - neither explicitly requires training - combining does not mean expanding. In reality, what practical skill are you going to train on? People who perform the analysis on an event are going to have job specific training external to this standard and those same folks will maintain their skill set external to this standard. If it is going to be a results based criteria standard, then let the entities be responsible. Training on methods to fill out and file paper work does not make the BES more reliable. The vast majority of other standards do not have a training requirement section and yet, entities manage to be

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		compliant with those standards. Compared to all the other reliability standards and their requirements, are penalties for training on filling out paper work really making the BES more secure and reliable?
Consolidated Edison Co. of NY, Inc.	No	Requirement 5 - Training should be targeted only at those responsible for implementing the Operating Plan (OP), not all those mentioned in the OP.R5 - After the words "internal personnel" add the words "responsible for implementing." The delete the words "identified in" and "for reporting pursuant to Requirement R2."5.4 - Following the words "For internal personnel" add the words "responsible for implementing the Operation Plan." Between the words "revised responsibilities" add the word "implementation."M5 - After the words "between the people" add the words "responsible for implementing the Operating Plan"
Constellation Power Generation and Constellation Commodities Group	No	Constellation Power Generation questions how R5 relates to the SDT's "summary of concepts":oA single form to report disturbances and impact events that threaten the reliability of the bulk electric systemoOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirementsoClear criteria for reportingoConsistent reporting timelines oClarity around of who will receive the information and how it will be usedHowever, Constellation Power Generation believes that security awareness is an important aspect of personnel security and proposes an annual training similar to what was in the previous standards. Constellation Power Generation therefore recommends two requirement changes that would achieve security awareness without the burdensome administrative aspects. First, as stated earlier, a sub requirement in R2 should be added which reads as follows: R2.5 Method(s) for making operation personnel aware of changes to the Operating Plan.Second, this training requirement should be rewritten as follows: Each Applicable Entity shall provide training to all operation personnel at least annually.
Consumers Energy	No	Again, either 12 month year or annual year, NERC needs to standardize on one or the other. Training should apply only to those that must take action relevant the reliability of the BES. A plan would likely include



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		notification of senior officers, however they don't need to be included in drills and training if they have no active role.
Duke Energy	No	Strike the word "all" in the requirement. All personnel don't need to be trained - for example, the plan may contain references to some personnel as potential sources of the information that will then be reported. Also, Section 5.3 only allows 30 days for training, which may be impossible with rotating shift personnel and training schedules. 60 days is more appropriate.
Dynergy Inc.	No	The annual training seems excessive especially if their have been no changes. You have included one exception for contact information revisions; however, it should be expanded to include exceptions for minor/non-substantial changes. Also, make training requirements (after initial training)be required for substantive changes only.
E.ON Climate & Renewables	No	Redundant with R4.
Electric Market Policy	No	The need for a periodic training has not been established and appears to be overly restrictive given the intent of the standard is reporting of impact events. Suggest this requirement be eliminated.
Exelon	No	Exelon doesn't feel that the 30 day requirement is achievable and recommends an annual review. Training for all participants in a plan should not be required. Many organizations have dozens if not hundreds of procedures that a particular individual must use in the performance of various tasks and roles. Checking a box which states someone read a procedure does not add any value, it is an administrative burden with no contribution to reliability. It is Exelon's opinion that training requirements should be covered in the PER standards and that the audience to be trained should be identified. R5.4 requires internal personnel that

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 7 Comment
		<p>have responsibilities related to the Operating Plan cannot assume the responsibilities unless they have completed training. This requirement places an unnecessary burden on the registered entities to track and maintain a data base of all personnel trained and should not be a requirement for job function. A current procedure and/or operating plan that addresses each threshold for reporting should provide adequate assurance that the notifications will be made per an individual's core job responsibilities.</p>
FirstEnergy	No	<p>Requirement R5 and Part 5.1 - The wording in Part 5.1 is too prescriptive and should not require training on the specific actions of personnel. Also, R5 should not require training for personnel that may only receive the report and are not required to do anything. Therefore we suggest rewording R5 and 5.1 as follows: "R5. Each Applicable Entity identified in Attachment 1 shall have a Reporting Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 5.1 The training includes the personnel required to respond under the Reporting Plan." Part 5.3 - We suggest removing subpart 5.3. This requirement is overly burdensome and not necessary. We believe that the requirements for annual review and update of the plan as well as training sufficiently cover reviews of changes to the plan. Part 5.4 - The last phrase "training shall be conducted prior to assuming the responsibilities in the plan" should account for emergency situations when the entity does not have time to train the replacement before they are to assume a responsibility.</p>
Great River Energy	No	<p>We believe that this task should be incorporated into the Job Task Analysis for the System Operators and that this requirement should be deleted as being redundant.</p>
Idaho Power Company	No	<p>The 30 day Requirement is limited with real time operations. Most entities with real time operations utilize a 5 or 6 week rotating schedule to comply with PER-002. the NERC Continuing Education Program allows up to 60 days to comply, this allows the operating shifts to accommodate training within the operating schedule. The</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		requirement 5.3 should allow 60 days to complete the training.
Indeck Energy Services	No	It is wholly unreasonable to re-train everyone for each change to the Operating Plan. Suggestion: Clarify that upon changes to the Operating Plan, the Registered Entity may either require full training, or instead distribute a summary of the change to affected personnel only.
Independent Electricity System Operator	No	Along the line of our comments on R2 for an Operating Plan (whose need we do not agree with), any training on developing and providing the report is unnecessary. What matters is that the report is provided to the needed organizations or entities on time and in the required format according to established procedure. How this is accomplished goes outside of the purpose of reliability standard requirements.
IRC Standards Review Committee	No	We do not agree with the need for R5. We do not see the need for a standard requirement that stipulates training the personnel on reporting events. What matters is that the reports are provided to the needed organizations or entities on time and in the required format according to established procedure. Stipulating a training requirement to achieve this reporting is micro-managing and overly prescriptive.
ISO New England Inc.	No	The need for a periodic drill has not been established, and appears to be overly restrictive given that the intent of the standard is reporting of impact events. Suggest this requirement be eliminated. There are training standards in place that cover these requirements. We agree the relevant personnel should be “aware” of the reporting requirements. But there is not a need to have a training program with specific time frames for reporting impact events. Awareness of these reporting requirements can be achieved through whatever means are available for entities to employ to train on any of the NERC standards, and need not be dictated by requirements.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
Kansas City Power & Light	No	We agree with the need for the Operating plan and the provision of formal training to impacted personnel. We believe that the personnel references are too open-ended to be productive and measurable. This leaves all applicable entities open to subjectivity in assessment and may produce a large administrative burden to demonstrate compliance with no associated benefit to improved reliability.
Luminant Energy	No	Operating Plan revisions communicated through procedure updates and employee acknowledgements of the same are sufficient when coupled with a procedural training program that occurs according to a programmed schedule.
Manitoba Hydro	No	The comments in Question 6 and 7 encompass the training aspect of this requirement.
MidAmerican Energy	No	: R5.2. The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be trained once per calendar year.R5.3 As detailed in R2, the Operating Plan shall contain provisions for “identifying, assessing, and reporting impact events”. Where, R2.7 states to update the OperatingWe disagree with the need to provide formal training. We could agree with the need to communicate to System Operators and other pertinent personnel the criteria for reporting so that they know when system events need to be reported.
Midwest ISO Standards Collaborators	No	We disagree with the need to provide formal training. We could agree with the need to communicate to System Operators and other pertinent personnel the criteria for reporting so that they know when system events need to be reported.
MRO's NERC Standards Review Subcommittee	No	R5.2. The NSRS agrees that to enhance reliability and situational awareness of the BES, the Operating Plan be trained once per calendar year.R5.3 As detailed in R2, the Operating Plan shall contain provisions for

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		<p>“identifying, assessing, and reporting impact events”. Where, R2.7 states to update the Operating Plan when there is a component change. The NSRS believes the components of this Operating Plan are 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events. These components relate to training when the Operating Plan is revised per, R5.3, only. As written, every memo, simulations, blog, etc that contain the words “lessons learned” would be required to be in your Operating Plan and trained on every time one was issued or heard about internally or externally. Recommend that the Operating Plan be revised and training occurs when a change occurs to the entity’s Operating Plan, consisting of 1) indentifying impact events, 2) assessing impact events, and 3) reporting impact events, only.</p>
North Carolina Electric Coops	No	<p>Requiring training to report of after-the-fact events does not improve the reliability of the BES. We recommend the elimination of this requirement.</p>
Northeast Power Coordinating Council	No	<p>The need for a periodic drill has not been established, and appears to be overly restrictive given that the intent of the standard is reporting of impact events. Suggest this requirement be eliminated. There are training standards in place that cover these requirements. The relevant personnel should be “aware” of the reporting requirements. But there is not a need to have a training program with specific time frames for reporting impact events. Awareness of these reporting requirements can be achieved through whatever means are available for entities to employ to train on any of the NERC standards, and need not be dictated by requirements.</p>
Pacific Gas and Electric Company	No	<p>PG&amp;E believes 30 days is too restrictive due to real-time operations schedule requirements. The schedule is six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Suggest extending to 60 days to meet the training criteria which follows the NERC Continuing Education revised submittal date for the Individual Learning</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		Activities (ILA).
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PacifiCorp	No	Training required within 30 days of a revision to the Operating Plan is not feasible with 5 or 6 week shift rotations. A sixty day requirement would be more realistic.
Pepco Holdings, Inc - Affiliates	No	30 days may be too short a time for large entities with multiple subsidiaries to do the necessary notice and coordination. PHI suggests 90 days.
PNM Resources	No	PNM believes 30 days is too restrictive due to real-time operations schedule requirements. Most work schedules are either five or six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Based on the NERC Continuing Education revised submittal date for the Individual Learning Activities (ILA), PNM would recommend 60 days. Creating an Impact Event Report is duplicative and redundant and the WECC OTS feels this is not necessary.
PPL Electric Utilities	No	We agree with the need for training on one's process. However, we suggest changes to R5.3. Consider expanding the exception criteria to exempt non-substantive changes such as errata changes, minor editorial changes, contact information changes, etc. We also suggest saying '...training shall be conducted, or notification of changes made, within 30 days of the procedure revisions.'
PPL Supply	No	We generally agree with R5 but recommend two changes to 5.3. Consider expanding the exception criteria to exempt non-substantive changes such as errata changes, minor editorial changes, contact information

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		changes, etc. Also, consider changing "training shall be conducted" to "training or communication/notification of changes shall be conducted."
Puget Sound Energy	No	The fact that proposed requirement R2 will require frequent updates to the operating plan means that the training required under this plan will occur quite frequently as well, leading to operator confusion. Even the comment allowing a review and "sign-off" will not completely mitigate this result.
RRI Energy, Inc.	No	<p>1. This Requirement is structured to result in the same heavy-handed, zero-tolerance approach that has made CIP-004 one of the top three violated Reliability Standards. The failure in CIP-004 is that, for example, a seven-year background check or annual training program that is tardy by one day results in a violation. There is no margin of error, proviso, or cure scenario. Likewise, the proposed R5 in EOP-004-2 makes it a violation if someone takes their newly established training on the day after the end of 15 months. Systems configurations are often based on quarterly monitoring for individuals needing to take training. In addition, when dealing with potentially thousands of employees, it is inevitable that any one of hundreds of reasons might result in an employee not being included in the tracking system, and rolling past the 15th month. RECOMMENDATION: To avoid further burden to Regional Entity audit and enforcement personnel as has been the case in CIP-004, develop a cure process that allows the Registered Entity to correct the training or background check tardiness with prompt correction, fill out a notification report to submit to NERC, and proceed with protecting the reliable operation of the BES, rather than tying up Registered Entity and Regional Entity staffs with data requests, enforcement paperwork and administrative actions.</p> <p>2. The proposed R5.3 requires the entire applicable staff to redo the entire training within 30 days of a change to the Operating Plan. These Operating Plans will not be short documents, and formal training will not involve a 5 minute soundbite. However, for such a significant procedure as the Operating Plan, frequent changes and revisions are going to</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 7 Comment
		<p>be very common, especially given the likelihood of frequent clarifications, Compliance Action Notices ("CANs"), and lessons learned issued by NERC and Regional Entities over this very detailed set of new obligations. It is not unreasonable to expect a Registered Entity to make three or more revisions to their Operating Plan in a year, which would require training for thousands of employees three times a year, for what might amount to a single sentence revision. Furthermore, the obligation to retrain on the entire training program is not limited in this requirement to only those individuals impacted by the revision. Where a change or revision only impacts 3 possible employees, this standard would require a company with 1,500 employees subject to the Operating Plan to retake the entire training. RECOMMENDATION: Clarify that upon changes to the Operating Plan, the Registered Entity may either require full training, or instead distribute a summary of the change(s) via email to affected personnel only.</p>
Santee Cooper	No	<p>The concept of requiring training on reporting of after-the-fact events does not support or enhance bulk electric system reliability. We recommend the elimination of this requirement.</p>
SERC OC Standards Review Group	No	<p>While we support training on an annual basis for the operating plan, the concept of requiring training on reporting of after-the-fact events does not support or enhance bulk electric system reliability. We recommend the elimination of this requirement.</p>
Southern Company - Transmission	No	<p>We suggest that the time frame be changed to 60 or 90 days in 5.3. 5.4 needs to have a time frame associated with it; we suggest that it be 60 or 90 days.</p>
Tenaska	No	<p>This Requirement is too specific and places additional burdens on Registered Entities.</p>
TransAlta Corporation	No	<p>Measure M5 states applicable entities shall provide training material presented... This measure is unclear as</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 7 Comment
		to whether the meaning is for internal personnel or to be provided to external entities upon request? Please clarify.
US Bureau of Reclamation	No	The measure is vague and redundant. The Entity is required to provide information to be used to "verify content". The information may be used to demonstrate compliance but who will verify the content is adequate and on what basis. Secondly, the measure requires training information be provided twice, once to demonstrate who participated and then to show who was trained. This is all unnecessary and could be remedied by simply stating that "evidence shall demonstrate that all individuals listed in the plan have received training on their role in the plan"
We Energies	No	Please clarify who is to be trained. As written, R5 requires any internal personnel identified in the plan, including CEO, Vice Presidents, etc., to be trained.
WECC	No	Thirty days is too restrictive due to real-time operations schedule requirements. Most work schedules are either five or six weeks and individuals may be on either long change or vacation and therefore unable to complete the training within 30 days of the identification of the need. Based on the NERC Continuing Education revised submittal date for the Individual Learning Activities (ILA), the requirement should be changed to require training to be conducted within 60 days.
Bonneville Power Administration	Yes	There was no training required for CIP-001 or in CIP-008. (The proposed EOP-008 purpose did not list incorporating CIP-008). Training was not really needed for reporting Electrical Grid events.
ERCOT ISO	Yes	ERCOT ISO believes the content of training can include an exercise or drill.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 7 Comment
United Illuminating	Yes	R5.3 coupled with the rationale provided is a sensible approach. It is important that the rationale is not forgotten.
Ameren	Yes	
American Electric Power (AEP)	Yes	
City of Austin dba Austin Energy	Yes	
Georgia System Operations Corporation	Yes	
NERC Staff	Yes	
PacifiCorp	Yes	

**8. Do you agree with the requirement R6 and measure M6? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst stakeholders who responded to this question regarding agreement with the originally proposed Requirement R6 and Measure M6. (Note R6 been moved to R5 in the revised standard.) The DSR SDT did a full review based on comments that were received. Many comments indicated concerns with the reporting timelines within Attachment 1. (The DSR SDT has addressed those comments in response to Question 10).

Several commenters wanted the ability to report impact events to their responsible parties via the DOE Form OE-417. Following discussions with the DOE and NERC, the DSR SDT has added the ability to use of the DOE Form OE-417 when the same or similar items are required to be reported to NERC and the DOE. This will reduce the need to file multiple forms when like items must be reported to the DOE and NERC for the same impact event. The underlying fact is that impact events are to be reported within prescribed guidelines, thus providing industry awareness and starting of any analysis process. R5 now is stream lined to read:

R5. Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form.

Organization	Yes or No	Question 8 Comment
American Electric Power (AEP)	No	It is not clear how this is different from R3 since it relies on the same timetable in Attachment 1.
CenterPoint Energy	No	CenterPoint Energy does not agree with R6 and M6 as written as we do not agree with the requirement to develop and maintain an Operating Plan (see comments to Q4 above) In addition CenterPoint Energy does not agree with the timelines required in Attachment 1 (see comments on Q10). CenterPoint Energy offers the following alternate language: "Each Applicable Entity shall report events outlined in Attachment 1 to applicable entities including but not limited to; NERC, and appropriate law enforcement agencies."

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 8 Comment
City of Garland	No	<p>1. The reporting requirements should not be expanded beyond CIP 001 and EOP 004-1. The goal for combining the two should be to make the process more efficient - not add on extra requirements for procedures on how to report, drills on reporting, training on reporting, etc. 2. The timelines requiring 1 hour reporting to the ERO are not needed and provide little realtime benefit to the BES. Real time or near real time reporting for “people on the ground” such as the RC, BA, TOP, FBI, Local Law Enforcement, DOE, etc. is necessary. They are in a position to take action in response to an event. On page 5, it states “The proposed standard deals exclusively with after-the-fact reporting. 1 Hour reporting requirements to the ERO in addition to existing reporting are not reasonable “after-the-fact” reporting requirements in the midst of an emergency. Also, there is not a 24X7 ERO center to report events to - why build and staff one when they already exists at the RC, BA, TOP, DOE, FBI, Local Law Enforcement, etc. - An ERO 24X7 center would be extra overhead that would provide no additional benefit in the first hour or hours of an emergency.</p>
Consolidated Edison Co. of NY, Inc.	No	<p>R2 requires applicable entities to have an Operating Plan which are company specific procedures and process required to be compliant with EOP-004. Therefore, R6 should be deleted since it is redundant with R2.</p>
Electric Market Policy	No	<p>Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.</p>
ERCOT ISO	No	<p>ISO recommends the following changes to the language of the requirement.R6. Each Applicable Entity shall report impact events in accordance with Attachment 1.</p>
Exelon	No	<p>The time durations in the attachment are too short, it would be impossible to collect all the data necessary to report out on an impact event in the defined time to report.The SDT should evaluate each event for the most</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
		appropriate entity responsible to ensure there is minimal confusion on who has the responsibility and eliminate duplication of reporting when feasible.
FirstEnergy	No	M6 - NERC's system should be capable of making this evidence available for the entities and provide a "return-receipt" of the reports that we send them. Also, M6 should be revised to state "Applicable Entities" as opposed to "Registered Entities".
Great River Energy	No	We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
Indeck Energy Services	No	---This is the first mention of the time lines in Attachment 1. If they are part of the standard, then they should be incorporated to the Operating Plan in R2 and then need not be mentioned again, only compliance with the plan. ---In M6, the last part, "evidence to support the type of impact event experienced; the date and time of the impact event ; as well as evidence of report submittal that includes date and time" is redundant. All of that should be in the report to NERC. If not, then it's not important to keep.
Independent Electricity System Operator	No	We agree with having a requirement to report impact events in accordance with the timelines outlined in Attachment 1, but not with the requirements indicated in R2.
IRC Standards Review Committee	No	There is not a need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
ISO New England Inc.	No	Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements for NERC that cross other federal agency jurisdictions. There is no need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations which is implied by the label "Operating Plan."
Kansas City Power & Light	No	We believe R3 and M3 are unnecessary as a stand alone requirement and measure and propose combining these requirements with R6 and M6. Identifying and assessing the initial probable cause of an impact event is the obvious starting point in the reporting process and ultimate completion of the required report. Evidence to support the identification and assessment of the impact event and evidence to support the completion and submittal of the report are really one in the same.
MidAmerican Energy	No	We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
Midwest ISO Standards Collaborators	No	We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will particularly difficult when support personnel are not present such as during nights, holidays and weekends.
North Carolina Electric Coops	No	There is already a DOE requirement to report certain events. NERC should not be developing redundant reporting requirements when this information is already available at the federal level from other agencies.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 8 Comment
Northeast Power Coordinating Council	No	Entities are already required by other agencies (e.g., DOE, NRC) to report certain events. We see no need to develop redundant reporting requirements for NERC that cross other federal agency jurisdictions. There is no need for an Operating Plan as proposed. This is not truly an Operating Plan. There are already other standards which create the requirements for an Operating Plan. This is an administrative reporting plan and any associated impact upon reliability is far beyond real-time operations which is implied by the label "Operating Plan".
Pacific Gas and Electric Company	No	PG&E believes that if the standard is intended to be an after the fact report, we question the one and/or twenty-four hour reporting criteria and then the 30 day criteria?
Pacific Northwest Small Public Power Utility Comment Group	No	See #15
PNM Resources	No	PNM believes there seems to be redundancy in reporting based on the time frames in Attachment 1, i.e. OE-417 and other required reports. If this standard is intended to be an after the fact report, why is there one/twenty-four hour reporting criteria?
PPL Electric Utilities	No	We understand the rationale for this standard and support the project to combine EOP-004 and CIP-001 as well as the reporting requirement in CIP-008. We are concerned that it may be difficult to meet Attachment 1 Part B Potential Reliability Impact submittal times as the time to submit is 1 or 24 hour after occurrence. E.g. Risk to BES equipment, the example given is a major event and easy to conclude. Consider forced intrusion, risk to BES equipment (increased violence in remote area), or cyber intrusion - should Attachment 1 state 'report within 24 hours after detection'?

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
PPL Supply	No	It may be difficult to meet Attachment 1 Part B Potential Reliability Impact submittal times as the time to submit is 1 or 24 hours after occurrence. Consider changing the Time to Submit Report for Forced intrusion, Risk to BES equipment, and Detection of a cyber intrusion to be "report within 24 hours after detection".
RRI Energy, Inc.	No	RECOMMENDATION: Clarify that the reporting of impact events shall be to those entities identified in the Operation Plan section developed specifically in Section 2.6. Reference to Attachment 1 indicates reporting to "external" parties is the intent for R6.
Santee Cooper	No	If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity
SERC OC Standards Review Group	No	There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Southern Company - Transmission	No	The time to submit report column needs to be more flexible with time frames.
Tenaska	No	The reporting timelines are currently listed on the OE-417 form. This Requirement is redundant.
TransAlta Corporation	No	R6 should reference Attachment 2 to make it clear that this report form must be used.M6 seems to be requesting evidence that the Confidential Impact Event Report was submitted. TransAlta suggests the submission of the actual report is evidence the report was submitted.Records of this submission can be provided on request.Web Reports Project 2009-01 has indicated online reporting is the direction they are



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 8 Comment
		going.If the impact report becomes an online Web report the entity submitting the report has no way of confirming the report ended up at the Compliance Enforcement Authority office after it is submitted. There needs to be some method that demonstrates the report was submitted and received.
We Energies	No	The proposed definition of “impact event” needs to be clarified.
WECC	No	There seems to be redundancy in reporting based on the time frames in Attachment 1, i.e. OE-417 and other required reports. If this standard is intended to be an after the fact report, why is there one/twenty-four hour reporting criteria?
Arizona Public Service Company	Yes	AZPS believes that Operating Plan should be replaced with "Event Reporting Plan."
ATC	Yes	ATC does agree that applicable entities report on events identified in Attachment 1 (See our comments about Attachment 1), but we do not agree that applicable entities should be required by this standard to have an Operational Plan. Please see our comments to question 4.
BGE	Yes	Comments for clarification:R6. Use of Capital letters in Operating Plan makes it unnecessary to state "created pursuant to Requirement 2
Bonneville Power Administration	Yes	The requirement needs to specify who (ERO) to report to. Attachment 1 doesn't say to report to the ERO either. Clarify or remove the difference between the report submitted and evidence of the type of impact event required in the measurement.
Georgia System Operations Corporation	Yes	It directly supports the purpose of the standard.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 8 Comment
Green Country Energy	Yes	Now this is an excellent example of all that is needed for this requirement!
Manitoba Hydro	Yes	Attachment 1 details the impact events and the thresholds of which they should be reported.
Puget Sound Energy	Yes	It is assumed that for the purposes of M6, NERC and the regions would already have access to these reports.
Ameren	Yes	
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Duke Energy	Yes	
Dynergy Inc.	Yes	
Idaho Power Company	Yes	
Luminant Energy	Yes	
MRO's NERC Standards Review	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 8 Comment
Subcommittee		
NERC Staff	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
United Illuminating	Yes	
US Bureau of Reclamation	Yes	

9. Do you agree with the requirements for the ERO (R7-R8) or is this adequately covered in the Rules of Procedure (section 802)?  
Please explain in the comment box below.

**Summary Consideration:** There was no consensus amongst the commenters who responded to this question. The DSR SDT did a full review based on comments that were received. The DSR SDT has determined that R7 and R8 are not required to be within a NERC Standard since Section 800 of the Rules of Procedure already assigns this responsibility to NERC. The DSR SDT, the Events Analysis Working Group (EAWG), NERC Staff (to include NERC Senior VP and Chief Reliability Officer) had an open discussion with this item being a major topic. The DSR SDT and EAWG are working in coordination with each other to provide NERC Staff with updated language for future inclusion into the Rules of Procedure. NERC Staff, the EAWG and the DSR SDT all supported this new initiative.

Organization	Yes or No	Question 9 Comment
Ameren	No	NERC's current heavy case load should justify reviewing the impact review table only once every 2 years.
ATC	No	ATC feels the ERO obligations should be covered in the Rules of Procedure. We do not agree with the requirements assigned to the ERO, but believe that they should be incorporated into the ERO's Rules of Procedure
BGE	No	R7. Make Impact Event Table all Capital Letters(it is a title). R8. Is the term "reportable impact events" new or is impact event intended to be capitalized? R8. Does a quarterly report of the year's reportable impact events include 12 months of "reportable impact events"? This is confusing. R8. In the Rationale for R8 Impact Events appears with Capital letters - why now? Shouldn't it appear with all Capital letters throughout the document as it is a defined term? R8. There are no previous requirements to report threats (R8.3) or

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		lessons learned (R8.5) or trends (R8.2) to an ERO. Is this information from reports to the ERO or from ERO research?
CenterPoint Energy	No	CenterPoint Energy does not believe this requirement is necessary; however, if the SDT insists on keeping this requirement then CenterPoint Energy believes it should remain as written. Any change to Attachment 1 should go through the Reliability Standards Development Procedure.
Consolidated Edison Co. of NY, Inc.	No	See response to Question 2Requirement 7Delete the words “and propose revisions to”Following the words (Attachment 1) add a period.Following that period add the words “The ERO shall revise the table”Requirement 8RECOMMEND DELETION OF R8 - CONFIDENTIALITY CONCERNS WILL MAKE ESTABLISHING A PUBLICATION REQUIRMENT EXTREMELY CHALLENGING.
Constellation Power Generation and Constellation Commodities Group	No	The impact event table (Attachment #1), as part of a standard, would have to be FERC approved every time it is edited. That would cause it to go through NERC’s Standard Development Process, and would cause a revision to the standard each time. This will also cause revisions to each and every registered entity’s Operating Plan. Overall, this requirement causes a large administrative burden on all entities, and does not improve reliability. As stated earlier, the “summary of concepts” for this latest revision, as written by the SDT, includes the following items: <ul style="list-style-type: none"> <li>oA single form to report disturbances and impact events that threaten the reliability of the bulk electric system</li> <li>oOther opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements</li> <li>oClear criteria for reporting</li> <li>oConsistent reporting timelines</li> <li>oClarity around of who will receive the information and how it will be used</li> </ul> Requirement 7 and 8 do not address any of these items. Furthermore, for R8, it is requiring NERC to send out quarterly reports, yet entities are supposed to amend their Operating Plans based on an annual NERC report. This requirement is confusing and is not consistent with earlier requirements. Constellation Power Generation

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		believes that these two requirements should be removed.
Electric Market Policy	No	Having the ERO as an applicable entity is concerning as they are also the compliance enforcement authority.
ERCOT ISO	No	Recommend that the Electric Reliability Organization be removed. The Electric Reliability Organization should not be responsible for reliability functions and therefore should be excluded from reliability standards.
FirstEnergy	No	FE disagrees with the ERO as an applicable entity within a reliability standard. See our responses to Questions 2 and 3 above. We do not believe the desired ERO process is adequately covered in section 802. Section 802 deals with assessments and not event reporting.
Georgia System Operations Corporation	No	It should not be necessary for the ERO to require itself to do these things. NERC's authority should be sufficient to do these things as part of its mission. With quarterly trending and analysis of threats, vulnerabilities, lessons learned, and recommended actions in R8, R7 (an annual review) should not be necessary. The quarterly activity could include proposing revisions to Attachment 1 if warranted. An alternative would be to perform annual trending and analysis of threats, vulnerabilities, lessons learned, recommended actions, and proposed revisions to Attachment 1 if warranted. Also, the Reliability Standards Development Procedure has been replaced with the Standard Processes Manual.
Indeck Energy Services	No	Reviewing Attachment 1 annually is unnecessary. Events don't change much and if they do, a SAR is needed to consider the changes. NERC should not be included in any standard!
Independent Electricity System Operator	No	We agree with the need to update the list as needed, but it does not have to be the ERO who takes on a reliability standard to do so. It can simply be an annual project in the standards development work plan to review Attachment 1 as part of a standard. The industry will then be provided an opportunity to weigh on the

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		<p>changes. Also, we do not see the reliability results or benefits of R8. The ERO can issue the report quarterly but who are audiences? What reliability purpose does it serve if no further actions are pursued upon receiving the report? Can this be done as a standing item for the ERO at, say, the BoT meeting? Or, can this be a part of the quarterly communication from the ERO to the industry? To make this a reliability standard is an over-kill, and does not conform with the results-based standard concept. From our perspective, both R7 and R8 can be removed, and the ERO can be removed from the Applicability Section as well.</p>
<p>IRC Standards Review Committee</p>	<p>No</p>	<p>We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.</p>
<p>ISO New England Inc.</p>	<p>No</p>	<p>Having the ERO as an applicable entity raises concern as it is also the compliance enforcement authority. Requirement R7 is unnecessary as there are already requirements in place for three year reviews of all Standards. R8 contains requirements to release information that should be protected, such as identification of trends and threats against the Bulk Electric System. This may trigger more threats because it will be published to unwanted persons in the private sector. We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.</p>
<p>Kansas City Power &amp; Light</p>	<p>No</p>	<p>We agree with the rationale for R8 requiring NERC to analyze Impact Events that are reported through R6 and publish a report that includes lessons learned but disagree with R2.9 obligating an entity to update its Operating Plan based on applicable lessons learned from the report. Whether lessons learned are applicable</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		<p>to an entity is subjective. If an update based on lessons learned from an annual NERC report is required, the requirement should clearly state the necessity of the update is determined by the entity and the entity's Reliability Coordinator or NERC can not make that determination then find the entity in violation of the requirement. In addition, if an update based on lessons learned from a NERC report is required, NERC should publish the year-end report (R8) on approximately the same day annually (i.e. January 31) and allow an entity at least 60 days to analyze the report and incorporate any changes it deems necessary in its Operating Plan. Again, the language referencing annual and quarterly in these two requirements is confusing.</p>
Manitoba Hydro	No	<p>Rules of Procedure appear to have a different focus then R7 and R8. Briefing on Rules of Procedure 802 Assess, review and report on:</p> <ul style="list-style-type: none"> <li>1.1 overall electric operation</li> <li>1.2 uncertainties and risks</li> <li>1.3 self assessment of supply and reliability</li> <li>1.4 projects on customer demand</li> <li>1.5 impact of evolving electric market practices that could affect the present and future of the BES</li> </ul> <p>Briefing on R7 and R8</p> <ul style="list-style-type: none"> <li>R7 - ERO shall review and propose revisions to Attachment 1</li> <li>R8- ERO shall publish quarterly reports on trends, threats, vulnerabilities, lessons learned and recommended actions.</li> </ul>
Midwest ISO Standards Collaborators	No	<p>We do not agree with the requirements and we do not believe it is adequately covered in section 802. First, section 802 deals with assessments not event reporting. Secondly, since attachment 1 is part of a standard, it should not be modified outside of the Reliability Standards Development process.</p>
NERC Staff	No	<p>NERC staff believes that requirements R7 and R8 are not needed because they are intrinsic expectations from its Rules of Procedure. Furthermore, these elements are necessary for analysis in support of the Reliability Metrics efforts NERC is leading under its Reliability Assessment and Performance Analysis</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		program.
North Carolina Electric Coops	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority.
Northeast Power Coordinating Council	No	Having the ERO as an applicable entity raises concern as it is also the compliance enforcement authority. Requirement R7 is unnecessary as there are already requirements in place for three year reviews of all Standards. R8 contains requirements to release information that should be protected, such as identification of trends and threats against the Bulk Electric System. This may trigger more threats because it will be published to unwanted persons in the private sector. We do not support an annual time frame to update the events list. The list should be updated as needed through the Reliability Standards Development Process. Any changes to a standard must be made through the standards development process, and may not be done at the direction of the ERO without going through the process.
Puget Sound Energy	No	This is adequately covered by section 802 of the Rules of Procedure. There seems to be some conflict between R2.9 and R8 regarding timeframes and the specific elements required.
Santee Cooper	No	Standards cannot be applicable to an ERO because they are the compliance enforcement authority, and the ERO is not a user, owner, or operator of the BES.
SERC OC Standards Review Group	No	The ERO cannot be subject to a requirement for which it is the compliance enforcement authority. The governance in this situation appears incomplete.
United Illuminating	No	The rules of procedure adequately cover this.
US Bureau of Reclamation	No	Requirements 7 and 8 are covered in the Section 801.801. Objectives of the Reliability Assessment and

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		Performance Analysis Program. The objectives of the NERC reliability assessment and performance analysis program are to: (1) conduct, and report the results of, an independent assessment of the overall reliability and adequacy of the interconnected North American bulk power systems, both as existing and as planned; (2) analyze off-normal events on the bulk power system; (3) identify the root causes of events that may be precursors of potentially more serious events; (4) assess past reliability performance for lessons learned; (5) disseminate findings and lessons learned to the electric industry to improve reliability performance; and (6) develop reliability performance benchmarks. The final reliability assessment reports shall be approved by the board for publication to the electric industry and the general public.
Bonneville Power Administration	Yes	R2.9 language refers to R8 “annual” report; however R8 language is “quarterly” reporting. It appears this standard is going to be in an update status 4 times per year minimum, plus any event modifications plus personnel changes. Overly burdensome.
City of Garland	Yes	R7 - Yes as long as any changes to attachment 1 follow the “Reliability Standards Development Procedure. R8 - Yes as long as R8.6 is strictly “recommended actions.” They should not become “required actions” as this bypasses the standard development process.
Duke Energy	Yes	However, R8 only addresses quarterly reports, and R2 Section 2.9 states that there will be an annual report.
Green Country Energy	Yes	I realize this is another burden for the ERO but the information would be good to know what is going on outside the plant .
Luminant Energy	Yes	Continually refining the Impact Event table to better define which events should be reported would be extremely valuable. Section 802 does not adequately require such refinement, thus R7 and R8 are

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 9 Comment
		appropriate inclusions to this standard.
MRO's NERC Standards Review Subcommittee	Yes	Should read "In accordance with Sections 401(2) and 405 of the Rules of Procedures, the ERO can be set as an applicable entity in a requirement or standard". As stated in the text box.
RRI Energy, Inc.	Yes	We support the concept that Reliability Standard requirements and obligations that are subject to violations and penalties should all be contained in the four-corners of the Reliability Standard. If an obligation exists in the Rules of Procedures that creates a stand-alone responsibility that is subject to violation and penalty, it should be removed from the Rules of Procedure and inserted into the appropriate Reliability Standard.
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Dynergy Inc.	Yes	
Great River Energy	Yes	
Idaho Power Company	Yes	
MidAmerican Energy	Yes	
Pacific Gas and Electric Company	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 9 Comment
PacifiCorp	Yes	
PacifiCorp	Yes	
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
We Energies	Yes	
WECC	Yes	

**10. Do you agree with the impact event list in Attachment 1? Please explain in the comment box below and provide suggestions for additions to the list of impact events.**

**Summary Consideration:** Most commenters who responded to this question disagreed with some aspect of Attachment 1 – most commenters provided specific suggestions for improvement. The DSR SDT did a full review based on comments that were received. The DSR SDT, the Events Analysis Working Group (EAWG), NERC Staff (to include NERC Senior VP and Chief Reliability Officer) had an open discussion with this item being a major topic. The EAWG and the DSR SDT aligned Attachment 1 with the Event Analysis Program category 1 analysis responsibilities. This will assure that impact events in EOP-004-2 reporting requirements are the starting vehicle for any required Event Analysis within the Event Analysis Program. The DSR SDT agrees that there are similar items in the DOE Form OE 417 and EOP-004-2. DOE, NERC and the DSR SDT are in initial talks to try and reduce duplicate reporting requirements. Until such time in the future that a new process is established between the DOE and NERC, the DSR SDT has revised the standard to indicate that the use of either the DOE Form OE 417 or Attachment 2 is an acceptable reporting form for applicable entities. The DSR SDT reviewed the “hierarchy” of reporting within Attachment 1. To reduce multiple entities reporting the same impact event, the DSR SDT has stated that the entity that performs the action or is directly affected by an action will report per EOP-004-2. As an example, during a system emergency, the TOP or RC may request manual load shedding by a DP or TOP. The DP or TOP would have the responsibility to report the action that they took if they meet or exceed the bright-line criteria established in Attachment 1. Upon reporting, NERC Event Analysis Program would be made aware of the impact event and start the EA Process which is outside the scope of this Standard.

Several bright-line criteria were removed from Attachment 1. These criteria (DC converter station, 5 generator outages, and frequency trigger limits) were removed after discussions with the EAWG and NERC staff, who concurred that these items should be removed from a reporting standard and analysis process.

Organization	Yes or No	Question 10 Comment
--------------	-----------	---------------------

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
WECC		For strictly after-the-fact reporting the list of Attachment 1 is appropriate. However, as noted in our earlier comments, actual or suspected sabotage events can have a potentially significant impact on reliability and should be treated differently, with additional real-time reporting requirements. It is important that such events be identified and recognized for reliability purposes and that notices include the RC.
Ameren	No	<p>We have numerous comments about the Attachments. (1) What are the requirements for "verbal" reporting to NERC and Regional entities? (2) What are the requirements for a "Preliminary" Impact Event Report? (3) The Voltage Deviations Event is unclear (a) Are these consecutive minutes? (b) Where is the voltage measured? (generator terminals? Point of Interconnections? Anywhere?) (c) must each Entity report separately? (d) What is the +/- 10% measured against (Generator Voltage Schedule?) (4) For Generation loss events how is an "entity" defined? (a corporate parent? each registered entity? other?) (5) Are the "Examples" in the Attachment 1 - Part A really Examples, or mandatory situations? (6) Can you define "Damage"? (7) Can you define "external cause"? (8) Can you give examples of "non-environmental external causes"? (9) The footnote 1 reference for "Damage or destruction of BES equipment" doesn't match up with the a. and b. footnotes or the 1. footnote of Attachment A - Part B. (10) How is the Operator supposed to determine what Event affects the reliability of the BES fast enough to decide whether or not to report? (11) is the Loss of off-site power (grid supply) event to a nuclear plant already covered by NUC-001?(12) What are "critical cyber assets" since CIP-002-4 will eliminate that term? (13) When is Attachment 2 supposed to be used? (14) What is meant by the word "Confidential" in the title of the Attachment 2 report? How would the SDT propose a GO/GOP handle the reporting for the following situation? A CTG unit is dispatched and the unit is started, synchronized and put on the bus. Immediately the Operator receives a high gas alarm from the GSU. The Operator quickly shuts the unit down and de-energizes the GSU. There are no relay targets and no obvious reason for the problem. After several weeks of analysis it's determined there was an internal fault in the GSU</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		and it must be replaced. How would the SDT recommend all the reporting requirements in this situation be addressed with the current draft?
American Electric Power (AEP)	No	Are the times listed for the initial probable reporting under R3 or the reporting under R6? Many of these items do not constitute emergency conditions. We view many of these as too onerous and would divert operating staff from monitoring and operating the BES. In addition, some terms (i.e. Frequency Trigger Limits) are not currently defined terms. Furthermore, there are existing requirements that have obligations for entities to provide this information to the RC. For example "Detection of a cyber intrusion to critical cyber assets" is already covered under CIP-008. This creates duplicate (and potentially competing) requirements. AEP also contends that some of the timelines are very aggressive and not commensurate with perceived need for the information. Transmission loss of multiple BES transmission elements (simultaneous or common-mode event) within 24 hours after occurrence is overly aggressive and should provide more specific criteria.
Arizona Public Service Company	No	AZPS believes that the list in Attachment 1 would be complete, as long as the text box of examples is included. The examples demonstrate what is necessary.
ATC	No	ATC has several areas of concern regarding Attachment 1.1. The one hour requirement for reporting will take the Functional Entities' focus off of addressing the immediate reliability issues and instead force the FE to devote valuable resources to filling out forms which will potentially reduce reliability. 2. Part A: a. Provide a definition of "system wide" for the Energy Emergency requiring system-wide voltage reduction. b. Add in the clarity that for Energy Emergency requiring firm load shed pertains to a single event, not cumulative events. c. Insert the word "continuous" for Voltage Deviations. d. Take off the TOP for IROL violations. (We believe that an IROL violation should be reported by the RC and not by the TOP based on the nature of the event. Requiring both the RC and TOP to report will only result in multiple reports for a single event. The RC is in

Organization	Yes or No	Question 10 Comment
		<p>the best position to report on an IROL violation for its RC area.)e. Take off the TO, TOP and add the LSE for Loss of Firm Load. (As a transmission only company ATC does not have contracts with end load users. Because of this the Loss of Firm Load should be the reporting obligations of the entity closes to the end load users which is the BA, DP or LSE. Failure to modify this requirement will cause confusion as to which entity has to report Loss of Firm Load. f. Define a timeframe for Generation Loss g. Multiple should be changed to “4 or more” for Transmission Loss.(ATC is concerned that this would require reporting of events that have little or no industry wide benefits but would take up considerable Registered Entity resources.)h. Provide clarity to and tighten the definition of Damage or destruction of BES equipment. The way it is written now would require over-reporting of all damaged or destroyed equipment due to a non-environmental external cause (e.g. broken insulator).3. Part B:a. Take off the TO and TOP for Loss of off-site power. (The GOP has the responsibility to acquire off-site power and we believe it is the GOP’s sole responsibility to report the Loss of off-site power. Failure to correct this would result in multiple reporting for the same event.)b. Take off RC for Risk to BES equipment. (The RC function does not own BES equipment and we believe it is impossible for them to report on risk to BES equipment if they are not the owner or operator of that equipment. This standard should be required of the entity that owns/operates BES equipment. c. Provide guidance to the phrase “reasonably determine” in footnote.d. Examples provided do not provide a clear obligation for an entity to follow. (Question: How close is the train to the substation? (Inches away from the substation fence, ten feet away from the substation fence or 500 feet away from the substation fence.) In addition, this standard is so open to interpretation that no entity can demonstrate compliance with the action. We believe that the only solution is to delete this reporting requirement. Overall:Multiple Functional Entities impacted by the same event are required to report. No lead entity is identified. This will result in multiple reports of the same event. ATC does not believe that this built-in duplicity enhances reliability?</p>



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
ATCO Electric Ltd.	No	Attachment 1: Part A - Transmission Loss: Only sustained outages should be reportable. Also the reporting threshold needs to be quantified for impact events, for example:a) Size of DC converter Station > 200 MW.b) Impact of loss of Multiples BES transmission elements in terms of significant load (> 200 MW for > 15 min).
BGE	No	TOP determines "system-wide" voltage reductions; why place this responsibility on a TO or DP? - Load Shedding is automatic load shedding; why 100MW? Does a DP need to provide a Report when directed by the RC, BA or TOP to shed load or reduce voltage? - No examples should be included in the standard! Need to define a "BES Transmission Element". - Table shows multiple entities in "Entity with Reporting Responsibility"; is it one or is it all entities report? - In an audit who determines "reasonably determined likely motivation" - Is it justified to expect to have "motivation" knowledge within one hour of an event? - Why are the Responsible Entities reporting Interruptible Demand tripped / lost?
Bonneville Power Administration	No	BPA suggests the following:Change loss of multiple BES to 3 or more. Loss of a double circuit configuration due to lightning doesn't need a report (it's a studied contingency). Add qualifier to damage/destruction of BES equipment, since a failed PCB or a system transformer normally doesn't have a MAJOR impact to the grid.Add qualifier to Loss of "ALL" off-site power affecting nuclear...The unplanned evacuation of control center is a busy time for the backup control center, yet this standard requires 1 hour reporting. Suggest changing to 24 hours.
CenterPoint Energy	No	CenterPoint Energy appreciates the efforts of the SDT in identifying the entity with reporting responsibility. This is an improvement to the event table. CenterPoint Energy is concerned with multiple entities being listed as having Reporting Responsibility. CenterPoint Energy recommends the SDT limit this to one entity having responsibility for reporting each event. This would not preclude that entity from coordinating with other entities

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>to gather data necessary to complete the report. In addition, CenterPoint Energy believes there are several events that should be removed from the list. “Transmission Loss” is covered by the TPL standards and does not need to be identified or reported under EOP-004. The loss of a DC converter station or multiple BES transmission elements may or may not disrupt the reliable operation of the BES, i.e. result in blackout, cascading outages, or voltage collapse. Likewise “Damage or destruction of BES equipment” in and of itself should not be the subject of reporting. If the damage or destruction results in true disruption to the reliable operation of the BES, that impact would be reported under one of the other identified events. “Voltage Deviations” is another unnecessary event. CenterPoint Energy believes a voltage event of the proposed magnitude will, more than likely, result in other events identified in Attachment 1 such as; IROL Violation or Generation Loss and would be reported under one of those triggers. Another concern is the threshold trigger of +/- 10% for 15 minutes or more. CenterPoint Energy is unclear as to the starting point to determine the deviation. In other words is the 10% deviation from nominal voltage, such as 138kV or 345kV, or the actual voltage at the time of the event? Additionally, must the deviation occur over a “wide area” or is such a deviation at one buss enough to trigger a report? Based upon these ambiguities and concerns CenterPoint Energy recommends “Voltage Deviations” be deleted from Attachment 1. The examples that follow on page 14 should also be deleted.</p>
City of Garland	No	<p>This report should follow exactly the OE-417 to avoid redundant, possible conflicting, and overall confusion in reporting. Note: The table has entries that are in conflict with the OE-417 and thus can cause confusion in filing multiple reports potentially causing an entity to violate Federal Law due to the confusion. By submitting the same information on different timelines, i.e. one hour reporting under OE-417 and 24 hours under this Standard, the reports may be significantly different causing confusion from differing reports of the same event. Although we prefer the events to match the OE-417 events exactly, if the SDT decides to include a</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>seperate events table we make the following suggestions: Energy Emergency requiring system-wide voltage reduction: should be reportable at 5% not 3% voltage reduction. The standard should clearly state this was applicable for BES energy emergency conditions only, not voltage reductions for other reasons. On voltage deviations: it should be clear that this applies to widespread effects on the BES not a single distribution feeder that has a low voltage. For the Frequency deviation: Did not see a definition for the FTL (frequency trigger limit) Generation loss: the reportable loss of generation should be significantly more than 500 MW. The number of units at the locaton is irrelevant. Ten units at 50 MW each is no more critical than a single 500 MW unit. Under this standard, if the plant with ten 50 MW units trips it is reportable but an 800 MW single unit is not reportable. The trip of the 800 MW unit has much more effect on the sytem reliability. Damage or destruction of BES equipment: Should be limited to specific equipment such as a 765 kV autotransformer not a 138 kV lightning arrestor. This needs to be eliminated or significantly limited as to the equipment type that is reportable.</p>
Consolidated Edison Co. of NY, Inc.	No	<p>It is absolutely essential that the work on EOP-004 and that on the NERC Event Analysis Process (EAP) be fully coordinated. We find that there are a number of inconsistencies between these two documents. The EAP and EOP-004 are not aligned. In order to operate and report effectively entities need consistent requirements. Attachment 1 Frequency Deviations - The term "Frequency Trigger Limit (FTL)" is not defined. Only defined terms should be used, or the term should be defined. If the term is defined in another standard it should be moved to the Glossary of Terms for wider use. Loss of Firm load for 15 Minutes - The text under the rightmost column entitled, Time to Submit Report, appears to be incomplete in our copy. Transmission loss and Damage or destruction of BES equipment - At the end of the wording for both under the column entitled "Threshold for Reporting" add the words "that significantly affects the integrity of interconnected system operations." Examples - Capitalize "Critical Asset" as this is a defined term.</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Constellation Power Generation and Constellation Commodities Group	No	<p>Constellation Power Generation and Constellation Commodities Group questions why the generation loss line item includes generating facilities of 5 or more generators with an aggregate of 500 MW or greater? The number of units makes no difference for reporting, as is evident in the generation thresholds written before this inclusion. The examples of damaged or destroyed BES equipment are confusing, and do not clarify the reporting event. What if a GSU at a small plant (20 MW) were to fail? Is that reportable? Constellation Power Generation believes that equipment failures that are not suspicious do not need to be reported. Finally, Constellation Power Generation and Constellation Commodities Group believes that the “loss of offsite power affecting a nuclear generation station” should be removed for the following reasons:1)The purpose of this reliability standard is stated as being: “Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES). “ While the “situational awareness” portion of the purpose could be interpreted as all-inclusive, the real element deals with BES reliability. Off-site power sources to nuclear units have nothing to do with BES reliability. Why should nuclear units be treated differently?2)The issue of concern for a loss of offsite power at a nuclear station is continued power supply (other than emergency diesels) to power equipment to cool the reactor core. A nuclear unit automatically shuts down when off-site power supply is lost. Availability of off-site power is a reactor safety concern (i.e., NRC regulatory concern and a one-hour report to the NRC) - not a reliability concern that FERC/NERC would have jurisdiction over.3)There is a nuclear-specific reliability standard (NUC-001) that contemplated off-site power availability. That standard contained no reporting requirements outside of those that may be already established in current procedures. Why try to impose one here?4)A loss of offsite power will result in an emergency declaration at the nuclear facility. Notifications will be made to federal (NRC), state, and local authorities. The control room crew is already overly-burdened with notifications - any additional call to NERC/Regional Reliability orgs will add insult-to-injury for no beneficial reason. If NERC is interested, they should obtain info from NRC.5)If all else fails and the item is to remain on the table, it needs</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		to be clarified as a “complete” loss of off-site power lasting greater than X minutes (i.e., would we have to report a complete momentary loss that was rectified in short order by an auto-reclose or quick operator action?).
Duke Energy	No	<p>o General Comment - many timeframes in Attachment 1 are within one hour. This is inconsistent with the stated aim of the standard, which is after-the-fact reporting, as opposed to real-time operating notifications under RCIS and other standards (e.g. TOP). This standard should not be structured to require another layer of real-time reporting.</p> <p>o Voltage Deviation - Plus or minus 10% of what voltage?</p> <p>o Frequency Deviation - this is Interconnection-wide. Do you really want a report from every RC and BA in the Eastern Interconnection??</p> <p>o Transmission Loss - “Multiple BES transmission elements” should be changed to “Three or more BES transmission elements”. Also, the time to submit the report should be based upon 24 hours after the occurrence is identified.</p> <p>o Damage or destruction of BES equipment - need clarity on the “Examples”. Is the intent to report an event that meets any one of the four “part a.” sub-bullets?</p> <p>i. - critical asset should be capitalized. Disagree with the phrase “has the potential to result” in section iii. - it should just say “results”. Section iv. is too wide open. It should instead say “Damaged or destroyed with malicious intent to disrupt or adversely affect the reliability of the electric grid.”</p> <p>o Unplanned Control Center evacuation - see our General Comment above. Clearly in this case the reporting individuals are evacuating and cannot report in one hour. 24 hours should be more than adequate for after-the-fact reporting.</p> <p>o Fuel Supply Emergency, Loss of off-site power, and Loss of all monitoring or voice communication capability - see our General Comment above. Time to report should be 24 hours after occurrence is identified.</p> <p>o Forced intrusion, Risk to BES equipment, Detection of a cyber intrusion to critical cyber assets - time to report should be 24 hours after occurrence is identified, and critical cyber assets should be capitalized.</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Dynergy Inc.	No	A 2000 MW loss needs to be more clearly defined by either the BA, ISO, RC, etc. for the applicable entity. Also, what is the distinction between the "damage or destruction of BES equipment" and the generation loss of $\geq$ 2000 MWs if it is a Critical Asset which is currently drafted as those greater than 1500 MW in current draft of CIP-002-4. This could lead to 2 events with different thresholds (i.e. 1500 MW and 2000 MWs). Possibly get rid of the 2000MW criteria and let the threshold level be the same as the Critical Asset MW level. Or remove the Critical Asset threshold in the footnote to Attachment 1.
E.ON Climate & Renewables	No	1. Voltage deviation events are too vague for GOP. How does voltage deviations apply to GOP's or specifically renewables i.e., wind farms? 2. Define what an "entity" is. 3. Define what a "generating station" is. 4. Define what a "BES facility" is. 6. Define what a control center is.
Electric Market Policy	No	1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would appear to overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004.
ERCOT ISO	No	ERCOT ISO requests the reporting timeframes be changed to reflect a 24 hour requirement for all events in Attachment 1. During an impact event, operating personnel are generally involved in event resolution and not available immediately to submit reports. ERCOT ISO requests that the "Detection of a cyber intrusion to a

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		critical cyber asset” be removed. There are established processes defined for incident response supporting CIP-008. By including this element in Attachment 1, the Operating requirement R2 would also require procedure documents for cyber security incident response. This would be redundant and would remove the responsibility away from the subject matter experts for cyber security incident response.
Exelon	No	The listed Impact Events is lacking specific physical security related events. .In general, all impact events need to be as explicit as possible in threshold criteria to eliminate any interpretation on the part of a reporting entity. Ambiguity in what constitutes an "impact event" and what the definition of "occurrence" is will ultimately lead to confusion and differing interpretations.
FirstEnergy	No	1. The table in Att. 1 and the requirements should alleviate the potential for duplicate reporting. For example, If the RC submits a report regarding a Voltage deviation in its footprint, the report should be submitted by the RC on behalf of the RC, TOP, and GOP, and not require the TOP and GOP to submit duplicate reports.2. Regarding the "Note" before the table - We agree that under certain conditions it is not possible to issue a written report in a given time period. However, the ERO and RE should also be required to confirm receipt of the verbal communication in writing to prove that the entity communicated the event as these verbal notifications may be done by an entity using an unrecorded line.3. Organizations with many registered entities should be permitted to submit one report to cover multiple entities under one parent company name. We suggest this be made clear in the Tables, the reporting form, and in the requirements.4. Voltage Deviations Event - We suggest the team provide more clarity with regard to the types and locations of voltage deviations that constitute an event.5. Examples of BES Equipment in Part A of "Actual Reliability Impact" Table - Is the phrase "critical asset" referring to the CIP defined term? If so, this should be capitalized.6. Under the "Time to Submit Report" column of the table, we suggest that all of the phrases end in "after identification of the

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>occurrence".7. Frequency Trigger Limit (FTL) for the Frequency Deviation event should be replaced with the values the FTL represent. The FTL is part of the BAAL Standards which have not been approved by the industry and are not in effect. It is possible that these terms are not used by those not participating in the field trial of the BAAL standards.</p>
Great River Energy	No	<p>Comments: Please provide a phone number and provision within the Note of EOP-004 - Attachment 1: Impact Events table for an entity to contact NERC if unable to contact NERC within the time described.Voltage Deviations - recommend adding the word "(continuous)" after sustained in Threshold column. This could be interpreted as an aggregate value over any length of time.Frequency deviations - recommend adding the word "(continuous)" after 15 minutes' in Threshold column. This could be interpreted as an aggregate value over any length of time.CIP-008 R1.3 states the entity is to report Cyber Security Incidents to the ES_ISAC. Does the EOP-004 Attachment 2 fulfill this requirement?We request clarification on the Transmission Loss threshold events that constitute reporting. We also want clarification on what constitutes the loss of a DC Converter station and is there a time duration that constitutes the need for reporting or does each trip need to be reported? For example during a commutation spike the DC line could be lost for less than a minute. Does this loss require a report to be submitted? Is the SDT stating that each time a company loses their DC line, they are required to file a report even though it may not have an effect on the bulk system? What is the threshold for this loss?The SDT needs to clarify that duplicative reporting is not required and that only one entity needs to report. For instance, the first three categories regarding energy emergencies could be interpreted to require the BA and RC to both report. The reporting responsibilities in this table should be clarified based on who has primary reporting responsibility for the task per the NERC Functional Model and require only one report. For instance, since balancing load, generation and interchange is the primary function of a BA per the NERC Functional Model, only the BA should be required to provide this report.The</p>



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 10 Comment
		term Frequency Trigger Limit (FTL) is not currently defined in the NERC Glossary. The term FTL needs to be introduced at the beginning of the standard and defined as a new term.
Indeck Energy Services	No	Loss of off-site power is important to more than just nuclear plants--but which ones? Control centers or other large generators. But not small generators! Should there be a common element to Attachment 1, like the potential to cause a Reportable Disturbance, or maybe there need to be multiple criteria like that.
Independent Electricity System Operator	No	We do not support the 1 hour reporting time frames for Emergency Energy, System Separation, unplanned Control Center evacuation, Loss of off-site power, Loss of monitoring or voice communication. Energy emergency is broadcast on the RCIS which also goes to the ERO so its explicit reporting is not necessary (System Operations please verify). During other events listed above, the responsible entities will likely be concentrating its effort in returning the system to a stable and reliable state. Reporting to anyone not having direct actions to control, mitigate and contain the disturbances is secondary to restoring the system to a reliable state. Since these are after the fact reports for awareness and/or analysis and not for real-time responses, these can be reported at a later time, up to 24 hours after the initial occurrence without any detriment to reliability, or at the very earliest: up to 1 hour after the system has returned to a reliable state, or after the backup control centre is fully functional, or after backup power is restored to the nuclear power plant, or after monitoring or voice communication is restored.
IRC Standards Review Committee	No	We do not agree with the requirement to report “detection of a cyber intrusion to critical cyber assets” as this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. We suggest that physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.
ISO New England Inc.	No	1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>entity to report the event. This is duplicative and would overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004. What are the examples at the bottom of page 14 supposed to illustrate? Critical Asset should have the appropriate capitalization as being a defined term. Is Critical Asset what is intended to be used here? Should the “a” list be read as ANDs or Ors? Does “loss of all monitoring communications” mean “loss of all BES monitoring “communications”? Does “loss of all voice communications” mean “loss of all BES voice communications?” Are the blue boxes footnotes or examples? Does “forced intrusion” mean “physical intrusion” (which is different from “cyber intrusion”) ? Regarding “Risk to BES Equipment,” request clarification of “non-environmental”. Regarding the train derailment example, the mixture of BES equipment and facility is confusing. Request clarification for when the clock starts ticking. Regarding “Detection of a cyber intrusion to critical cyber assets”, there is concern that this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. Suggest physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.</p>
Kansas City Power & Light	No	<p>We agree with the event descriptions listed in Attachment 1 and the review and revision of the impact table by the ERO is appropriately addressed in R7 but the time periods allowed to complete the new, longer preliminary report is insufficient. The correlation of this with the timing of the reporting quarterly and annually or pushing information for other entities' situational awareness does not allow the registered entity adequate time to thoughtfully consider the event and proposed root cause.</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Luminant Energy	No	<p>The Impact Events Table might be easier to clarify if organized by Reporting Entity rather than Event Type as events vary substantially based on the affected BES component. For example, a GO or GOP cannot adequately determine if an event will significantly affect the reliability margin of the system or if an event results in an IROL. Examples specific to Reporting Entities would assist in more appropriate report submissions. Additionally, the footnote under examples of Damage or Destruction of BES Equipment, cites “A critical asset”. This term must be clarified to indicate whether this refers to a Critical Asset as defined by CIP 002-1. Finally, the Fuel Supply Emergency item requires additional definitions as neither a GO nor a GOP can reasonably project if an individual fuel supply chain problem will result in the need for emergency actions by the RC or BA.</p>
MidAmerican Energy	No	<p>New vague criteria in Attachment one such as “damage to a BES element through and external cause” or “transmission loss of multiple BES elements which could mean two or more” is the opposite of clear standards writing or results based standards.</p>
Midwest ISO Standards Collaborators	No	<p>Several categories require duplicate reporting. For instance, the first three categories regarding energy emergencies could be interpreted to require the BA and RC to both report. The reporting responsibilities in this table should be clarified based on who has primary reporting responsibility for the task per the NERC Functional Model and require only one report. For instance, since balancing load, generation and interchange is the primary function of a BA per the NERC Functional Model, only the BA should be required to provide this report. As another option, perhaps the registered entity initiating the action should submit the report. If the BA did not take action and the RC had to direct the BA to take action, one could argue that perhaps the RC should submit the report then. However, if the BA takes action appropriately on their own, the BA should submit it. If the TOP reduces voltage for a capacity and energy emergency per a directive of the BA, then the</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		BA should report the event.
MRO's NERC Standards Review Subcommittee	No	Please provide a phone number and provision within the Note of EOP-004 - Attachment 1: Impact Events table for an entity to contact NERC if unable to contact NERC within the time described.Voltage Deviations - recommend adding the word "(continuous)" after sustained in Threshold column. This could be interpreted as an aggregate value over any length of time.Frequency deviations - recommend adding the word "(continuous)" after 15 minutes' in Threshold column. This could be interpreted as an aggregate value over any length of time.CIP-008 R1.3 states the entity is to report Cyber Security Incidents to the ES_ISAC. Does the EOP-004 Attachment 2 fulfill this requirement?
Nebraska Public Power District	No	Since the reporting under this standard is for after the fact reporting, the minimum time to report should be the end of the next business day. The combination of the extremely short time periods to file a report and the amount of detail required in attachment 2 will lead to a reduction in the reliability of the BES. System Operators will be forced to take focus off their primary responsibility to respond to the event in order to complete the report within the required timeframe (within an hour for some events). During non-business hours the only personnel available to complete the reports will be those responsible for real-time operation of the BES. Since the background indicates this standard is only for after the fact reporting, the minimum required time to submit the report should be one business day to permit completion of the report without distracting from the real-time operation of the BES. Real-time reporting requirements are covered in other standards and should be to the Reliability Coordinator and from the Reliability Coordinator to NERC. For after the fact reporting, there is absolutely no reliability benefit for requiring reporting to be completed on such a short timeframe. This is especially true due to the amount of data required by Attachment 2.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
NERC Staff	No	<p>The SDT should clarify its use of the term “critical asset” in the Examples section under Part A of the table. The term or versions of the term are used in different contexts in the NERC Reliability Standards. For instance, in CIP-002-1, Requirement 1, the Critical Asset Identification Method is used to identify its critical assets. In EOP-008-0, Requirement 1.3, the applicable entity is required to list its “critical facilities” in its contingency plan for the loss of control center functionality. The team should confirm what it is referring to in this proposed standard. To avoid confusion, the SDT may want to consider using a different term here or better clarify its meaning. Further, there exists the potential to have disparate reporting criteria in this proposed standard relative to the criteria being proposed by the Events Analysis Working Group as part of the Events Analysis Process document dated October 1, 2010. In particular, the following areas should be reconciled between the drafting team and the EAWG to ensure a consistent set of threshold criteria:</p> <p>Voltage Deviations --EOP-004-2: Greater than or equal to 15 minutes --EAWG Process: Greater than or equal to 5 minutes</p> <p>System Separation (Islanding) --EOP-004-2: Greater than or equal to 100 MW --EAWG Process: Greater than or equal to 1000 MW</p> <p>System Separation (Islanding) --EOP-004-2: Does not address intentional islanding as in the case of Alberta, Florida, New Brunswick--EAWG Process: Addresses intentional islanding as in the case of Alberta, Florida, New Brunswick</p> <p>SPS/RAS --EOP-004-2: Does not expressly address proper SPS/RAS operations or failure, degradation, or misoperation of SPS/RAS --EAWG Process: Expressly addresses proper SPS/RAS operations or failure, degradation, or misoperation of SPS/RAS</p> <p>Transmission Loss --EOP-004-2: Identifies Multiple BES transmission elements --EAWG Process: Provides specificity in Category 1a and 1b regarding transmission events</p> <p>Damage or destruction of BES equipment --EOP-004-2: Through operational error, equipment failure, or external cause but not linked to loss of load--EAWG Process: Identifies in Category 2h equipment failures linked to loss of firm system demands</p> <p>Forced intrusion--EOP-004-2: Addressed --EAWG Process: Not addressed</p> <p>Risk to BES equipment --EOP-004-2: Addressed --EAWG Process: Not addressed</p> <p>Detection of a cyber intrusion to critical cyber assets --EOP-004-2: Addressed --</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		EAWG Process: Not addressed
North Carolina Electric Coops	No	This list is too similar and redundant to the DOE requirements and does not provide any additional clarity on recognition of sabotage.
Northeast Power Coordinating Council	No	<p>1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004. What are the examples at the bottom of page 14 supposed to illustrate? Critical Asset should have the appropriate capitalization as being a defined term. Is Critical Asset what is intended to be used here? Should the “a” list be read as ANDs or Ors? Does “loss of all monitoring communications” mean “loss of all BES monitoring “communications”? Does “loss of all voice communications” mean “loss of all BES voice communications?” Are the blue boxes footnotes or examples? Does “forced intrusion” mean “physical intrusion” (which is different from “cyber intrusion”) ? Regarding “Risk to BES Equipment,” request clarification of “non-environmental”. Regarding the train derailment example, the mixture of BES equipment and facility is confusing. Request clarification for when the clock starts ticking. Regarding “Detection of a cyber intrusion to critical cyber assets”, there is concern that this creates a double jeopardy situation between CIP-008 and EOP-004-2 R2.6. Suggest physical incident reporting be part of EOP-004 and cyber security reporting be part of CIP-008.</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
Pacific Northwest Small Public Power Utility Comment Group	No	Footnote 1 is missing from Part A, although it is referenced in column 1 row 11. Is this the Examples? The purpose of the Examples is unclear. Is it meant to limit the scope to those enumerated? This is not stated, but if not it should be removed since it adds confusion. What is meant by non-environmental? All external causes of damage or destruction come from the environment by definition. Please specify what is intended or remove the word.
PacifiCorp	No	Energy Emergency requiring firm load shedding - An SPS/RAS could operate shedding firm load but no Energy Emergency may exist. This requires clarification. Transmission Loss - Multiple BES transmission elements. Loss of two transmission lines in the same corridor due to a wildfire could qualify for this reporting. Once again clarification needed.
Pepco Holdings, Inc - Affiliates	No	Some items with one hour reporting (such as Unplanned Control Center evacuation) may be so disruptive to operations that one hour is too short. 4 hours suggested.
PPL Electric Utilities	No	While we think providing an impact event list is beneficial, we would like to see Attachment 1 revised and/or clarified. Refer to response to Question 2 considering duplicate reporting. Regarding impact event 'Damage or destruction of BES equipment' and considering the first example in the 'Examples' section, does 'example a. i.' mean if the BES equipment that is damaged is not identified as a critical asset per CIP-002 that no reporting is required? Clarify the Part A and Part B, specifically: Attachment 1 Part A is labeled 'Actual Reliability Impact'. Does this title mean that for all events listed that the 'threshold for reporting' is only met if the event occurs AND there is an actual reliability impact? As opposed to Part B where the threshold for reporting is met when the event occurs and there is a potential for reliability impact? This could be broad for event 'risk to BES equipment'. Providing as much clarity as possible on the 'threshold for reporting' is

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		beneficial to the industry and will help eliminate confusion with the existing CIP-001 standard regarding 'potential sabotage'.
PPL Supply	No	Attachment 1 Part A is labeled "Actual Reliability Impact". Does this title mean that for all events listed the "threshold for reporting" is only met if the event occurs AND there is an actual reliability impact? As opposed to Part B where the threshold for reporting is met when the event occurs and there is a potential for reliability impact? This could be broad for events like "Risk to BES equipment."
PSEG Companies	No	For many items, there are multiple entities listed with reporting obligations. For example, loss of off-site power to a nuclear plant lists RC, BA, TOP, TO, GO and GOP. This appears to result in the potential for the sending of 6 separate reports within the hour for the same event, which in wide area disturbances overload the recipients. The drafting team should consider revising the lists where possible to a single, or absolute minimum number, entity. Those items reportable OE-417 should be removed from Attachment 1. For example, voltage reduction, loss of load for greater than 15 minutes. The trigger for voltage reduction should be the time of issuance of the directive to reduce voltage in an emergency, not when "identified."
Puget Sound Energy	No	The proposed standard does not adequately ensure that the impact events subject to its requirements are limited to those listed in Attachment 1. In order to ensure that this is true, the term "impact event" should be a defined term and that definition should clearly limit impact events to those listed in Attachment 1.
Santee Cooper	No	The SDT should review the list of events closely to determine if the defined events actually impact the BES. (For example: Is shedding 100 MW of firm load really a threat to the BES?)
SERC OC Standards Review	No	Will all reporting requirements be removed from other standards to avoid duplication? And will all future



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 10 Comment
Group		standard revisions include revisions to this standard to incorporate associated reporting requirements?There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
Southern Company - Transmission	No	The time to submit report column needs to be more flexible with time frames. The Entity with Reporting Responsibility column needs to be more descriptive in which there are multiple entitles with hierarchy reporting.
United Illuminating	No	UI agrees but the listing needs to be improved for clarity in certain instances. For example,EOP-004 Attachment 1 Part A - Example iii - uses the phrase “significantly affects the reliability margin of the system.” Significantly is an immeasurable concept and does not provide guidance to the Entity. The phrase “reliability margin” is not defined and is open to interpretation. Perhaps utilize “resource adequacy”, if that is all that intended, or use “adequate level of reliability”.
US Bureau of Reclamation	No	The Attachment is very vague and without modification creates a Pseudo definition of BES equipment in the example provided. The example now indicates that something is BES equipment if it is "Damaged or destroyed due to a non-environmental external cause". Perhaps the example should be reworded to "BES equipment whose operation effects or causes:" and then adjust each of the line items to clarify what was intended. Next, the Attachment A example redefines reportable levels for Risk to BES Equipment - From a non-environmental physical threat as "Report copper theft from BES equipment only if it degrades the ability of equipment to operate correctly". Who makes that determination? Not all events will be known within 24 hours. As example, Risk to BES Equipment - From a non-environmental physical threat may not be known until more thorough examination or investigation takes place. Also the reportable level appears to be defined by the Entity. While agree with that, we will end up with the same criticism from FERC when the level is set to

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>"high" in FERC's mind. The reporting times are unrealistic for complicated events. Notification is reasonable but not reporting. Many organizations's have internal processes the reports must be vetted through before they become public and subject to compliance scrutiny.</p>
We Energies	No	<p>I did not compare this standard to the OE-417 form. Please do not require operators to fill out a second form during an emergency within one hour. Energy Emergency requiring Public appeal...: "Public " is not a defined term. Energy Emergency requiring system-wide voltage...: DP does not control BES voltage. Energy Emergency requiring firm load shed...: TOP does not have load it would shed for an Energy Emergency. Frequency Deviations: Why is a BA reporting? This will be every BA in the Interconnection reporting the same Frequency Deviation. Frequency Deviations: Frequency Trigger Limit is not a defined term, and is not defined in this standard. Loss of Firm Load...: TO and TOP may coordinate or direct load shed, but they do not serve firm load. Damage or destruction of BES... There is no footnote 1 on this page. I assume it is the examples on the page. Are these "examples" of a larger set or are these all that is required? Critical Asset is a defined term. Forced Intrusion: "facility" or Facility? An RC and BA do not have Facilities.</p>
Georgia System Operations Corporation	Yes	<p>We support the concept of Impact Events and listing and describing them in a table. However, we have some concerns. Reporting of impact events should not be applicable to a DP. The timelines outlined in Attachment 1 should be targets to try to meet but it should not be a compliance violation of the reporting requirement if it is not met. Regarding the NOTE before the table, verbal reports and updates should be allowed for other than certain adverse conditions like severe weather as well as adverse conditions. The first priority for all entities should be addressing the effects of the impact event. It may not be possible to assess the damage or the cause of an impact event in the allotted time. All entities should make their best effort to quickly report under any circumstances what they know about the event even if it is not complete. They should be allowed to</p>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 10 Comment
		<p>report up through a hierarchy. The written report should not be issued until adequate information is available. Change "Preliminary Impact Event Report" to "Confidential Impact Event Report."Capitalization throughout this table is inconsistent. Sometimes an event is all capitalized. Sometimes not. It is not in synch with the NERC Glossary. All terms that remain capitalized in the next draft (other than when used as a title or heading) should be defined in the Glossary of Terms Used in NERC Reliability Standards. Examples of inconsistencies: Unplanned Control Center evacuation, Loss of off-site power, Voltage Deviations.-Energy Emergency requiring a public appeal or a system-wide voltage reduction: All The NERC Glossary defines Energy Emergency as a condition when a LSE has exhausted all other options and can no longer provide its customers' expected energy requirements. The events should not be described as an Energy Emergency requiring public appeal or system-wide voltage reductions. If public appeal and system-wide voltage reductions are still an option then all options have not been exhausted, the LSE can still provide its customers' energy requirements, and it is not an Energy Emergency. We suggest using "Energy Emergency Alert" rather than "Energy Emergency."-Energy Emergency requiring firm load shedding: load shedding via automatic UFLS or UVLS would not necessarily be due to an Energy Emergency. Other events could cause frequency or voltage to trigger a load shed. Most likely an entity would be seeing the Energy Emergency coming and would be using manual load shedding. -Forced intrusion and detection of cyber intrusion to critical cyber assets: CIP-008 is not referenced for a forced intrusion. CIP-008 is referenced for a detection of cyber intrusion impact event. Aren't there reportable events per CIP-008 that involve physical intrusion that are not intrusions at a BES facility?-Risk to BES equipment: The threshold states that it is for a non-environmental threat but the examples given are environmental threats. Please clarify.</p>
Manitoba Hydro	Yes	<p>Though R7 indicated Attachment 1 will be reviewed and revised regularly the immediate addition of:"Detection of suspected or actual or acts or threats of physical sabotage"should be added.</p>

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 10 Comment
City of Austin dba Austin Energy	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PNM Resources	Yes	
RRI Energy, Inc.	Yes	
TransAlta Corporation	Yes	

**11. Do you agree with the use of the Preliminary Impact Event Report (Attachment 2)? Please explain in the comment box below.**

**Summary Consideration:** Most commenters who responded to this question disagreed with some aspect of the Preliminary Impact Event Report. The proposed Preliminary Impact Event Report (Attachment 2) generated comments regarding the duplicative nature of the form when compared to the OE-417. The DSR SDT has added language to the proposed form to clarify that NERC will accept a DOE OE-417 form in lieu of Attachment 2 if the responsible entity is required to submit an OE-417 form.

In collaboration with the NERC Event Analysis Working Group (EAWG) the DSR SDT proposes to modify the attachment to eliminate confusion. This revised form will be used as Attachment 2 of the Standard and is the only required information for EOP-004-2 reporting. Further information may be requested through Events Analysis Process (NERC Rules of Procedure), but this information is outside of the scope of EOP-004.

The DSR SDT has also clarified what the form is to be used for with the following language added:

“This form is to be used to report impact events to the ERO.”

Organization	Yes or No	Question 11 Comment
City of Austin dba Austin Energy		Austin Energy would like to see OE-417 incorporated into the electronic form This will reduce the callout of EOP-004-2 and OE-417 forms in our checklists / documents and one form can be submitted to NERC and DOE.
Independent Electricity System Operator		TBD
Ameren	No	It is unclear when this should be used, or why.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
ATC	No	No. NERC does not have the authority to absolve the Functional Entities of the reporting obligations for the DOE Form OE-417. Therefore, there will be duplicate reporting requirements and the one hour timeframes required in Attachment 1 will take valuable resources away from mitigating the event to filling out duplicative paperwork. It is ATC's position that the OE-417 report be used as the main reporting template until NERC and the DOE can develop a single reporting template. Task #14 in the report should be modified to say, "Identify any known protection system misoperation(s)." If this report is to be filed within 24 hrs, there will not be enough time to assess all operations to determine any misoperation. As a case in point, it typically takes at least 24 hrs to receive final lightning data; therefore, not all data is available to make a determination.
ATCO Electric Ltd.	No	Attachment 2 Item 4 implies that an entity is required to analyse and report on an impact event that occurred outside its system. This is not practical as the entity will not have access to the necessary information.
BGE	No	There is considerable difference between this form and OE-417 necessitating that two forms be completed. BGE believes that the purpose of combining the standards was to reduce the number of reporting entities and number of reports to be generated by each entity. BGE believes this fails to accomplish this purpose.
City of Garland	No	The report filed should be the OE-417 ELECTRIC EMERGENCY INCIDENT AND DISTURBANCE REPORT and should be filed only on OE-417 reportable incidents. If this report is implemented as drafted, companies with multiple registration numbers and functions should only have to file one report for all functions and registrations.
Consolidated Edison Co. of NY, Inc.	No	It is not clear why the DOE form cannot be used. NERC should make every effort to minimize paper work for entities responding to system events.
Constellation Power Generation and Constellation Commodities Group	No	It is unclear if an entity has to answer all the questions. In addition, "Preliminary" is not currently included in the report title.
Electric Market Policy	No	There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.
ERCOT ISO	No	ERCOT ISO requests the use of a single report format to meet all requirements from NERC and DOE. There is no value added in requiring different reporting to different agencies.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
Exelon	No	Exelon agrees with the use of the report but feels that # 5 should consist of check boxes. #12, 13, and 14 will take more time then allotted by the reporting requirements to acquire, cannot be accomplished in an hour.Attachment 2 should have a provision for the reporting entity to enter (N/A) based on function (see below)Check box #8 A GO/GOP may not have the information to determine what the frequency was prior to or immediately after an impact event. This information should be the responsibility of a TOP or RC.Check box #9A GO/GOP may not have the information to determine what transmission facilities tripped and locked out. This information should be the responsibility of a TO, TOP or RC.Check box #10A GO/GOP may not have the information to determine the number of affected customers or the demand lost (MW-Minutes). This information should be the responsibility of a TO, TOP, or RC.
Great River Energy	No	NERC and the DOE need to coordinate and decide on which report they want to use and whichever report it is needs to include all information required by both entities. The way this standard is currently written there is the potential that two government entities may need to be reported to is a relatively short period of time. It is not clear what benefit providing the Compliance Registration ID number provides. Many of the registered entities employees that will likely have to submit the report, particularly given the one-hour reporting requirement for some impact events, will not be aware of this registration ID. However, they will know for what functions they are registered. We recommend removing the need to enter this compliance registration ID or extending the time frame for reporting to allow back office personnel to complete the form. For item two, please change “Time/Zone:” with “Time (include time zone)”. As written it is a little confusing.
Idaho Power Company	No	there should only be on report, utilized OE-417
Indeck Energy Services	No	The form needs to identify whether it is a preliminary or final report. An identifier should be created to tie the final to the preliminary one. Some fields, 1,2 3 5 & 6, are required for the preliminary report and should be labeled as such. With the 1 hour reporting deadline for some events, the details may not be known. 12 & 13 should be required for the final report. 13 should designate whether the cause is preliminary or final. 7-11 & 14 are optional, and the form should state this, and based on some types of events. It's confusing to have irrelevant blanks on the form.
IRC Standards Review Committee	No	Attachment 2 is not referenced in the standard requirements. Is it a part of the standard that an entity must use to file the impact event reports to a specific recipient. If so, this needs to be referenced in the standard.We question the need for using a fixed format for reports that vary from “shedding firm load” to “damaging equipment”. The nature of impact events varies from one event to another and hence a fixed format or pre-determined form may not be able to provide the appropriate template that is suitable for use for

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
		all events. We urge the SDT to reconsider the use of Attachment 2 for reporting events, with due consideration to the actual intent of the standard (as pointed out in our comments under Q1).
ISO New England Inc.	No	There is already a DOE requirement to report certain events. There is no need to develop redundant reporting requirements to NERC that cross other federal agency jurisdictions. The heading on page 16 refers to EOP-002, but this is Standard EOP-004. If some questions do not require an answer all of the time, then the form should state that or provide a NA checkbox. While Attachment 1 details some cyber thresholds, Attachment 2 provides no means to report - which is acceptable if cyber incidents are handled by CIP-008 per the comment provided for Question 10. The Event Report Template in Appendix A is different from the most recent version, which is available at: <a href="http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf">http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf</a>
Kansas City Power & Light	No	For easier classification and analysis of events for both external reporting to the ERO and internal reporting for the applicable entity, the form should include Event Type. The DSR SDT should code each event type and include the codes as part of Attachment 1.
Manitoba Hydro	No	Though a “Confidential Impact Event Report” is much needed the Attachment 2 needs refinement. Provide an explanation for each “task”. Isolate and simplify the “Who, When and What” section. Isolate the description of event. Remove items 7 to 10. Modify Attachment 1, add columns to indicate time of event, quantity, restore time, etc as required. The Attachment 1 can be attached to Attachment 2. This could simply and speed the reporting process.
MidAmerican Energy	No	
Midwest ISO Standards Collaborators	No	This form differs from the DOE reporting forms. We do not believe different reporting forms should be required. The DOE form should be sufficient for NERC reporting. It is not clear what benefit providing the Compliance Registration ID number provides. Many of the registered entities employees that will likely have to submit the report, particularly given the one-hour reporting requirement for some impact events, will not be aware of this registration ID. However, they will know for what functions they are registered. We recommend removing the need to enter this compliance registration ID or extending the time frame for reporting to allow back office personnel to complete the form. For item two, please change “Time/Zone:” with “Time (include time zone)”. As written it is a little confusing.



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
MRO's NERC Standards Review Subcommittee	No	Number 4 of the reporting form does not take into consideration of potential impact events. Recommend that "Did the impact event originate in your system?" to "Did the impact event originate or affect your system?". This will provide clarity to entities.
Nebraska Public Power District	No	If the standard requires submission of the report within an hour (which is not appropriate), there must be an abbreviated form that can be quickly filled out by checking boxes and not require substantial narrative. The existing form has too much free form text that takes time to enter and with the short timeframe for reporting will distract the entities responsible for real-time reliability of the BES from that task by forcing them to complete after the fact reports. It is unrealistic to expect entities to staff personnel to complete the reporting 24 x 7 for unlikely events, so the task will fall to System Operators who should be focusing on operating the BES at the time of these events instead of providing after the fact reporting to entities that do not have responsibility for real-time operation of the BES. Real-time reporting to the RC and/or BA is covered under other standards and is necessary for the RC to have situational awareness, but is not covered under this standard. The registered entities may report to the proper law enforcement entities when the situation warrants, but again this form is not the appropriate way to handle that reporting requirement.
NERC Staff	No	Item 15: A one-line diagram should be attached to assist in the understanding and evaluation of the event. Two additional items are recommended:--Ongoing reliability impacts/system vulnerability - this would capture areas where one is not able to meet operating reserves or is in an overload condition, below voltage limits, etc. in real-time--Reliability impacts with next contingency - this would capture potential impacts as outlined above with the next contingency.
North Carolina Electric Coops	No	There is already a DOE requirement to report certain events. NERC should not be developing redundant reporting requirements when this information is already available at the federal level from other agencies.
Northeast Power Coordinating Council	No	There is already a DOE requirement to report certain events. There is no need to develop redundant reporting requirements to NERC that cross other federal agency jurisdictions. The heading on page 16 refers to EOP-002, but this is Standard EOP-004. If some questions do not require an answer all of the time, then the form should state that or provide a NA checkbox. While Attachment 1 details some cyber thresholds, Attachment 2 provides no means to report - which is acceptable if cyber incidents are handled by CIP-008 per the comment provided for Question 10. The Event Report Template in Appendix A is different from the most recent version, which is available at: <a href="http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf">http://www.nerc.com/docs/eawg/Event_Analysis_Process_WORKINGDRAFT_100110-Clean.pdf</a>

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
Pacific Gas and Electric Company	No	PG&E believes the report is duplicative to the OE-417 reporting criteria.
Pacific Northwest Small Public Power Utility Comment Group	No	We found no "Preliminary Impact Event Report" in the posted draft standard, so we assume the question is regarding the "Confidential Impact Report" (Attachment 2). It is unclear what role the form plays, since no requirement refers to it. If this is the form to report impact events per R6, then R6 should reference it. The comment group cautions that the use of the word "confidential" should be carefully considered, since many filled out forms that originally contained the word are now posted on the NERC website for all to see. If there are limits to the extent and/or duration of the confidentiality this should be clearly stated in the form, or the word should be avoided. Protection System misoperation reporting is already covered by PRC-004. Including it here is redundant, and doubly jeopardizes an entity for the same event.
PacifiCorp	No	As previously mentioned all effort should be made to ensure duplicate reporting is not required. OE-417 requirements should be covered by this one form.
Pepco Holdings, Inc - Affiliates	No	The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
PNM Resources	No	PNM believes the report is duplicative to the OE-417 reporting criteria.
PSEG Companies	No	The top of this form should have the following statement added: "This form is not required if OE-417 is required to be filed."
Puget Sound Energy	No	Attachment 2 is not referenced in the requirements of the proposed standard. As a result, it is not clear when its submission would be required.
Santee Cooper	No	If the DOE form is going to continue to be required by DOE, then NERC should accept this form. Entities do not have time to fill out duplicate forms within the time limits allowed for an event. This is burdensome on an entity.
SERC OC Standards Review Group	No	There is already a DOE requirement to report certain events. We see no need to develop redundant reporting requirements in the NERC arena that cross other federal agency jurisdictions.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 11 Comment
TransAlta Corporation	No	We recommend the ‘time to Submit Report’ to start when the event is recognized verses when it occurred.
United Illuminating	No	The standard does not appear to require the use of Attachment 2. Placing the form within the Standard may require the use of the Standards Development Process to modify the form. UI suggests the form is maintained outside the Standard to allow it to be adjusted. UI would prefer NERC to establish an internet based reporting tool to convey the initial reports.
US Bureau of Reclamation	No	There is already a reporting form for disturbances. The SDT should reconcile this standard with all the other reporting that is being requested and not add more.
We Energies	No	The data required to assess an impact event thoroughly will often not be available or apparent. Immediate reporting should fall to the RE with assistance/information from the affected entities. There do not seem to be provisions for when it is impossible to take the time to fill out a form or when it is impossible to send a form. I did not compare this standard to the OE-417 form. Please do not require operators to fill out a second form during an emergency within one hour.
WECC	No	The report is duplicative to the OE-417 reporting criteria.
Bonneville Power Administration	Yes	Item 8: list Hz minimum on the second line prior to Hz max since that is the typical frequency excursion order. The Operating Plan is going to have to include the Compliance Registration ID number, since Operating Personnel don't carry that information around and it is not readily available.
Duke Energy	Yes	However, Attachment 2 is titled “Impact Event Reporting Form”.
E.ON Climate & Renewables	Yes	Suggestions on the form: if an entity has not had time to fully determine the cause of an Impact Event such as for “Question # 4: Did the impact event originate in your system, yes or no?”, perhaps more time is needed that 24 hours to determine the cause.
FirstEnergy	Yes	Although we agree with the report, it should be clear that organizations with many registered entities can submit one report to cover multiple entities under one parent company.
Georgia System Operations	Yes	We support having one form for reporting however every applicable entity should not be required to fill it out and send it to NERC. See previous comments about hierarchical reporting. The title of the report is

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 11 Comment
Corporation		"Confidential Impact Event Report." Some suggested modifications: The form could have a blank added to enter the event "description" as described in the first column of Attachment 1. The first seven lines contain information that would most likely be filled out every time. The other lines except line 13 may or may not be applicable every time. It is required (R3) for an entity to access the initial probable cause of all impact events so line 13 will most likely be filled out every time. Please move the probable cause line up to line 7 or 8 (depending on if the event description line is added).
PPL Electric Utilities	Yes	For ease, timeliness, and accuracy of reporting an application with an easy to use interface would be preferred. If the reporting is done via an application, the ability to enter partial data, save and add additional info prior to submission would be helpful. Additionally, an application with drop downs to select from for impact event, NERC function, etc would be helpful. #1 - Is the 'Compliance Registration ID number' the same as the NCR number? If this is required, include as separate entry. #2 - is this the date of occurrence or detection?
Arizona Public Service Company	Yes	
Dynergy Inc.	Yes	
Green Country Energy	Yes	
Luminant Energy	Yes	
PacifiCorp	Yes	
PPL Supply	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

---

Organization	Yes or No	Question 11 Comment
RRI Energy, Inc.	Yes	
Southern Company - Transmission	Yes	

**12. The DSR SDT has replaced the terms “disturbance” and “sabotage” with the term “impact events”. Do you agree that the term “impact events” adequately replaces the terms “disturbance” and “sabotage” and addresses the FERC directive to “further define sabotage” in an equally efficient and effective manner? Please explain in the comment box below.**

**Summary Consideration:** There was no consensus amongst commenters who responded to this question. Several commenters expressed concern that the definition should be added to the glossary. The DSR SDT has proposed a definition for “Impact Events” to support Attachment 1 as follows:

“An Impact Event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

The DSR SDT has proposed this definition for inclusion in the NERC Glossary for “Impact Event”. The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard.

Several commenters expressed concern that the team did not define ‘Sabotage’ and FERC directed that the modifications to this standard include a definition of sabotage. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This will result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The Impact Events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

Some commenters were concerned that some of the events that require reporting that were specifically listed in the previous version of the standard are not included in the revised standard. Attachment 1, Part A is to be used for those actions that have impacted the electric system and in particular the section “Damage or destruction to equipment” clearly defines that all equipment that intentional or non intentional human error be reported. Attachment 1, Part B covers the similar items but the action has not fully occurred but may cause a risk to the electric system and is required to be reported.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
Bonneville Power Administration		The definition of an impact event in EOP-004-2 seems clear, however the term "mis-operation" still may imply intent in the action of an individual. The SDT should consider further defining that term.
Independent Electricity System Operator		We do not have a view on what name is assigned to the reportable events for so long they are listed in Attachment 1. However, the heading of the Table contains the words "Actual Reliability Impact", which does not accurately reflect the content inside the table and which may introduce confusion with the term "impact event". We suggest to change them to "Reportable Impact Events".As we read the Summary of Concept and Assumption, there appears to be a slightly different lists at the bottom of P. 21. With these events included, the meaning of "impact event" would seem to be too broad. Rather than calling those events listed in Attachment 1 "impact events", why not simply call them "reportable events"?
CenterPoint Energy	No	CenterPoint Energy does not agree that the term "impact event" adequately replaces "disturbances" and "sabotage". CenterPoint Energy suggests that just as the SDT has come to consensus on a concept for impact event, a definition could be derived for sabotage. "Potential", as used in the SDT's concept, is a vague term and indicates an occurrence that hasn't happened. Required reporting should be limited to actual events. CenterPoint Energy offers the following definition of "sabotage": "An actual or attempted act that intentionally disrupts the reliable operation of the BES or results in damage to, destruction or misuse of BES facilities that result in large scale customer outages (i.e. 300MW or more)."
City of Garland	No	<p>1 In keeping with a Results Based Standard, the impact event should be a trigger for filing a report. At the time of the event, one may not know if the event was caused by sabotage. Sabotage that does not affect the BES should not be a reportable event.</p> <p>2. To comply with the Commissioners request to define sabotage, Impact Event does not adequately replace "sabotage". If someone reports sabotage, people universally have a concept that someone(s) have taken some type of action to purposely harm, disable, cripple, etc something. Impact Event does not convey that same concept.</p> <p>3. If Sabotage is left as a "trigger," it should not include minor acts of vandalism but only acts that impact reliability of the BES</p>
Consolidated Edison Co. of NY, Inc.	No	The definition is open for interpretation beyond events identified in Attachment 1. In addition, all Standards are supposed to have Rationales. In the Draft Standard, the Rationales do not address the concept of Potential, and how it relates to an actual system event. Additional work needs to be done addressing the

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
		meaning of “potential”.
Duke Energy	No	We disagree with the stated concept of “impact event”. Including the phrase “or has the potential to significantly impact” in the concept makes it impossibly broad for practical application and compliance. By not attempting to define “sabotage”, the standard creates a broad reporting requirement. “Disturbance” is already adequately defined. “Sabotage” should be defined as “the malicious destruction of, or damage to assets of the electric industry, with the intention of disrupting or adversely affecting the reliability of the electric grid for the purposes of weakening the critical infrastructure of our nation.”
Dynergy Inc.	No	The term is fine but FERC wants more specific examples. GO/GOP can't determine the effect on the BES.
E.ON Climate & Renewables	No	Acts of Sabotage is still not defined and if the registered entities are required to reports acts of sabotage, NERC still needs to define this further.
ERCOT ISO	No	
Exelon	No	Need to better define sabotage and provide examples, the term “impact events” create confusions as to what constitutes an event. The definition of impact event is vague and needs to be quantified or qualified with a term such as “significant”. Otherwise, almost any event could be deemed to be an impact event. Attachment 1 needs to clearly define that damage or destruction of BES equipment does not include cyber sabotage. Events related to cyber sabotage are reported in accordance with CIP-008, "Cyber Security - Incident Reporting and Response Planning," and therefore any type of event that is cyber initiated should be removed from this Standard. In general, all impact events need to be as explicit as possible in threshold criteria to eliminate any interpretation on the part of a reporting entity. Ambiguity in what constitutes an "impact event" and what the definition of "occurrence" is will ultimately lead to confusion and differing interpretations.
FirstEnergy	No	For the most part we support this definition of impact events. However, we have the following suggestions:1. We believe that it warrants an official NERC glossary definition. 2. The term "potential" in the definition should point to the specific events detailed in Attachment 1 Part B.3. Since the standard does not cover environmental events, the phrase "environmental conditions" in the definition is not an impact event in the context of this standard.



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
Great River Energy	No	We believe the SAR scope regarding addressing sabotage has not been addressed at all. It appears that impact event essentially replaces sabotage. This standard needs to make it clear that sabotage, in some cases, cannot be identified until an investigation is performed by the appropriate policing agencies such as the FBI. Intent plays an important role in determining sabotage and only these agencies are equipped to make these assessments.
Green Country Energy	No	Yes and no ... Yes impact events is an adequate term however since it is restrained by the tables it may be helpful to define the term and scope of the term to be more inclusive of sabotage events.
Indeck Energy Services	No	Impact Events is OK. It needs to be balloted as a definition for the Glossary like Protection System.
IRC Standards Review Committee	No	This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement's and other specialized agencies', including international agencies', role in defining acts of sabotage and not hold the registered entity wholly responsible to do so.
ISO New England Inc.	No	The use of the term "impact events" has simply replaced the terms "disturbance" and "sabotage", and has not further defined sabotage as directed by FERC. We do feel that "impact events" needs to be a defined term. While we agree with the SDT's new direction, the FERC directive has not been met. This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement and other specialized agencies, including international agencies roles in defining acts of sabotage, and not hold the registered entity wholly responsible to do so.
Luminant Energy	No	The term "Impact Event" does not adequately replace the term "Sabotage" The Impact Events table seems to provide the definition of the term "Impact Event". This table does not include sufficient definition for actual sabotage events. Additionally, it does not include any provision for suspected sabotage events. Assuming the Damage or Destruction of BES Equipment event type is intended to cover actual sabotage, the Threshold for Reporting column should include specific levels of materiality that are specific to Functional Entity. For instance, a GO and GOP could have a MW level to define materiality as a GO or GOP cannot assess impact to an IROL or system reliability margin due to equipment damage. A threshold value consistent with "Generation Loss" in the proposed EOP-004 Attachment 1 would be appropriate.
Manitoba Hydro	No	The majority of the items listed in Attachment 1 are typically and historically operating events. Yes these are all "impact events". Sabotage, cyber and security are typically viewed as separate events. These events are

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
		not part of “a typical day of BES operations”. These are outside event and though qualify as “impact events” should still be treated separately.
Midwest ISO Standards Collaborators	No	We believe the SAR scope regarding addressing sabotage has not been addressed at all. It appears that impact event essentially replaces sabotage. This standard needs to make it clear that sabotage, in some cases, cannot be identified until an investigation is performed by the appropriate policing agencies such as the FBI. Intent plays an important role in determining sabotage and only these agencies are equipped to make these assessments.
NERC Staff	No	NERC staff is concerned with the ambiguity of the term “impact event.” The definition of the term is not clear, in part because it includes using the words “impact” and “event” (and thus violates the frowned-up practice of using a word to define the word itself). NERC staff recommends the SDT consider using the term “Event.” The following definition (modified from the one used the INPO Human Performance Fundamentals Desk Reference, P. 11) would apply: Event: “An unwanted, undesirable change in the state of plants, systems or components that leads to undesirable consequences to the safe and reliable operation of the Bulk Electric System. ”Supporting statement following the definition: “An event is often driven by deficiencies in barriers and defenses, latent organizational weaknesses and conditions, errors in human performance and factors, and equipment design or maintenance issues.” Further, if this is intended for use in this standard, it should be presented as an addition to Glossary to avoid confusion with the use of the term event in other standards. Of course, this would require an analysis of how the term “Event” as defined herein would affect the other standards to which the term is used. In the end, this is the cleanest manner for the standards.
Northeast Power Coordinating Council	No	The use of the term “impact events” has simply replaced the terms “disturbance” and “sabotage”, and has not further defined sabotage as directed by FERC. We do feel that “impact events” needs to be a defined term. While we agree with the SDT’s new direction, the FERC directive has not been met. This term and the FERC directive do not recognize limitations in what a registered entity can do to determine whether an act of sabotage has been committed. This term should recognize law enforcement and other specialized agencies, including international agencies roles in defining acts of sabotage, and not hold the registered entity wholly responsible to do so.
Pacific Gas and Electric Company	No	PG&E believes Attachment 1 Part A or B do not clearly specify “sabotage” events, other than “forced entry” and the proposed definition of “impact event” does not meet FERC’s directive to “further define sabotage” nor does it take into consideration their request to address the applicability to smaller entities.
Pacific Northwest Small Public	No	The comment group fails to see how changing the words meet the directive. Sabotage implies an organized

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
Power Utility Comment Group		intentional attack that may or may not result in an electrical disturbance. The distinction between sabotage and vandalism is important since sabotage on a small system may be the first wave of an attack on many entities. The proposed standard asks us to treat insulator damage caused by a frustrated hunter (an act of vandalism) the same as attack by an unfriendly foreign government (an act of sabotage). The comment group does not agree that these should be treated equally.
Pepco Holdings, Inc - Affiliates	No	The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
PNM Resources	No	PNM believes the proposed definition of “impact event” does not meet FERC’s directive to “further define sabotage” nor does it take into consideration their request to address the applicability to smaller entities. Attachment 1 Part A or B do not clearing specify “sabotage” events, other than “forced entry”.
Puget Sound Energy	No	With some of the tight timeframes for reporting, it is reasonable to focus on impact rather than motivation. Requiring further analysis of the event in order to assess the possibility that the event was caused by sabotage, however, may be necessary to address FERC’s concerns with respect to sabotage.
Santee Cooper	No	The term "impact events" needs to be more clearly defined.
US Bureau of Reclamation	No	The two are distinctly different. Disturbances are what happened, sabotage is why. We can easily tell what happened. Determining why it happened (e.g. sabotage) takes time.
We Energies	No	Impact Event could replace disturbance and sabotage but not in its present form. The proposed definition of impact event “An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.” Is too vague. The “potential to impact the reliability” is too broad and open to interpretation. It needs to be specific so entities know what is and is not an impact event and so an auditor clearly knows what it is. Define “impact event” as the items listed in Attachment 1.As you have done, focusing on an event’s impact on reliability is more important than determining an individuals intent (sabotage v.s. theft).
WECC	No	The proposed definition of “impact event” does not meet FERC’s directive to “further define sabotage” nor does it take into consideration their request to address the applicability to smaller entities. Attachment 1 Part A or B do not clearing specify “sabotage” events, other than “forced entry”. The purpose of CIP-001-1 and its requirements is to address the specific issue of possible sabotage of BES facilities. This is entirely different

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 12 Comment
		than a “disturbance” or an “event” on the BES. The proposed definition for “impact events” is essentially any event that has either impacted the BES or has the potential to impact the BES, caused only by three specific things; equipment failure or misoperation, environmental conditions, or human action. Several of these “impact events could be a result of sabotage. Actual or potential sabotage clearly poses a risk to the reliability of the BES. It is important that the risks related to sabotage be reflected in either EOP or CIP
Ameren	Yes	However, the term Impact Event should be a new defined term. When the SDT determines this, it should use the term consistently on both pages 5 and 21 of the SDT document.
ATC	Yes	Yes, if ATC’s recommended changes are made to Attachment 1 and the Standard.
BGE	Yes	The defined term “impact events” should be capitalized throughout the document to identify it as a defined term. Additionally, BGE has noted in several comments that another term is used instead of “impact events”. These terms should be eliminated and use “impact events” instead.
Electric Market Policy	Yes	The use of the term “impact events’ has simply replaced the terms “disturbance” and “sabotage” and has not further defined sabotage as directed by FERC. We do feel that impact events needs to be a defined term.
Georgia System Operations Corporation	Yes	The new term is much more clear than those two terms. This will improve uncertainty and confusion regarding whether or not something should be reported.
Kansas City Power & Light	Yes	Should the word disturbance be removed from the title of EOP004-2 to avoid confusion and simply be called Impact Event and Assessment, Analysis and Reporting.
MRO's NERC Standards Review Subcommittee	Yes	As an industry we have looked at sabotage as a sub component of a disturbance. Sabotage is hard to measure since it is based on a perpetrator's intent and thus very hard to determine.
Nebraska Public Power District	Yes	I agree there is a lot of interpretation and confusion as to what sabotage or a Cyber Incident is, so would welcome better clarity. Whether “impact events” can more effectively clarify, is yet to be seen. “it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.” “An impact event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences.” I do know that Cyber Sabotage may take time or days to become aware so not sure

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 12 Comment
		how that might expedite reporting and awareness.
PPL Electric Utilities	Yes	Refer to clarification requested in question 10 comments.
RRI Energy, Inc.	Yes	Agree. However, strongly encourage this to be made into a defined term in the Glossary of Terms.
SERC OC Standards Review Group	Yes	We do feel that this needs to be a defined term
United Illuminating	Yes	The term impact event can substitute for sabotage and disturbance. The use of Forced Intrusion is a bright line for reporting.
American Electric Power (AEP)	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
City of Austin dba Austin Energy	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Idaho Power Company	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 12 Comment
MidAmerican Energy	Yes	
North Carolina Electric Coops	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
PPL Supply	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	

13. The DSR SDT has combined EOP-004 and CIP-001 into one standard (please review the mapping document that shows the translation of requirements from the already approved versions of CIP-001 and EOP-004 to the proposed EOP-004), EOP-004-3 and retiring CIP-001. Do you agree that there is no reliability gap between the existing standards and the proposed standard? Please explain in the comment box below.

**Summary Consideration:** While a majority of commenters who responded to this question support combining the two standards, some commenters suggested that in combining the standards, the team left some gaps in coverage with respect to the types of events that must be reported. The DSR SDT believes that combining EOP-004 and CIP-001 does not introduce a reliability gap between the existing standards and the proposed standard and the industry comments received confirms this. Some events that were specifically identified in the original standard (such as a bomb threat) are covered more generically in the revised standard. This modification encourages entities to focus on the ‘types’ of events that may be impactful rather than having a finite list that may omit an event that couldn’t be anticipated when drafting the requirements.

The decision to eliminate the term sabotage from the standard and the retirement of CIP-001 should alleviate all concerns regarding the term sabotage and its definition. The DSR SDT believes that “observation of suspicious activity” and “bomb threat” is considered to be included in Part B – “Risk to BES equipment from a non-environmental physical threat”. We have added “and report of suspicious device near BES equipment” to note 3 of the “Attachment 1, Potential Reliability – Part B”.

Organization	Yes or No	Question 13 Comment
WECC		A potential gap may exist. Attacks on BES facilities, via either vandalism or sabotage, are very different events than impact events on the system. From a Compliance standpoint, a revised standard to address the FERC directive on sabotage should be developed as an EOP standard (that is grouped with 693 Standards) rather than as a CIP Standard (CIP-001-1).
Ameren	No	It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
		in the existing standards.
Bonneville Power Administration	No	BPA supports the concept behind the revisions to EOP-004-2. Creating a single reporting methodology will improve the processes and lead to more consistency. BPA recommends that the Standards Drafting Team (SDT) coordinate any revisions in the reporting requirements with those found in CIP-008-3 to ensure that there are no conflicts. BPA asks the SDT to consider the impact of these changes on CIP-008-3 and work with the CIP SDT to ensure that the wording of the two requirements is similar and clear. Based on Attachment 1 part A of EOP-004-2, certain cyber security events, intrusions for example, would have to be reported under both EOP-004-2 and CIP-008-3. That puts a burden on a Registered Entity to take additional steps to coordinate reporting or face potential compliance risk for correctly reporting an event under one standard and failing to report it under the other standard. The mapping document had errors: a. CIP-001 R1 to EOP-004 R2.9 (annual vs quarterly). b. EOP-004-1 R2 was translated to R2 & R3 of version 2. c. EOP-004-1 R3 was translated to R6 of version 2 (which doesn't say to whom to report).
City of Garland	No	EOP-004-1 R2 did not get translated to EOP-004-2 R2 - table states it is mapped to R1
E.ON U.S. LLC	No	The Version History contained with EOP-004-2 indicates that CIP-001-1 and EOP-004-1 are "Merged", however, the actions do not reflect the retirement of CIP-001-1a and therefore, it is unclear if there will be remaining redundancies or potential gaps with the new version EOP-004-2 and CIP-001-1a.
Electric Market Policy	No	Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity.
Exelon	No	Reporting form doesn't allow for investigations which result in no impact events found or identified.
Georgia Transmission Corporation	No	The only two events that apply to a TO are the ones related to CIP:1. Forced intrusion (report if motivation cannot be determined, i.e. to steal copper)2. Detection of a cyber intrusion to critical cyber assets ( criteria of CIP-008)Everything in this standard applies to a TOP and therefore E-004-2 and CIP-001 should not be combined



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
Great River Energy	No	It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than in the existing standards.
Indeck Energy Services	No	Bomb threat has totally been lost.
Independent Electricity System Operator	No	We do not agree with the mapping. The proposed mapping attempts to merge the reporting in CIP-001-1 which has more of an on-going awareness nature to alert operating and government authorities of suspected sabotage to prompt investigation with a possible aim to identify the cause and develop remedies to curb the sabotage/events. The proposed EOP-004-2 appears to be more of a post-event reporting for need-to-know purpose only. This is not consistent with the purpose of the SAR.
ISO New England Inc.	No	Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by the NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity. EOP-004-3 should be EOP-004-2.
Luminant Energy	No	CIP-001-1 R3.1 includes instructions associated with the DOE OE-417 form. EOP-004-2 R2.6 should include the DOE as an example of an external organization requiring notification. Additionally, the Rationale for R1 discusses the possibility of one electronic form satisfying US entities with related disturbance reporting requirements but does not include any information about the likelihood of this outcome. Please elaborate on the process required to combine these reports.
Midwest ISO Standards Collaborators	No	It appears that all requirements have been addressed from the existing standards. However, we believe there is a reliability gap that continues from the existing standards because sabotage is not defined any better than in the existing standards.
North Carolina Electric Coops	No	
Northeast Power Coordinating Council	No	Per the mapping document, some of the existing requirements are awaiting a new reporting procedure being developed by the NERC EAWG. For those requirements that were transferred over, the resulting standard seems overly complex and lacks clarity. EOP-004-3 should be EOP-004-2.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
Pepco Holdings, Inc - Affiliates	No	The list of events misses many items considered as suspicious or potential sabotage, such as suspicious observation of critical facilities.
Santee Cooper	No	It is very difficult to assess this question with the standard as currently written.
SERC OC Standards Review Group	No	
US Bureau of Reclamation	No	The two could be combined with no reliability gap based on the concept rather than the proposed standard. As the standard is currently written, there is a reliability gap. Consider that after the fact reporting of a sabotage event (other than criminal acts which may have been witnessed) usually take some time to investigate and analyze.
ATC	Yes	ATC agrees with this effort and does not currently see a reliability gap
BGE	Yes	None.
CenterPoint Energy	Yes	CenterPoint Energy agrees that there is no reliability gap between the existing standards and the proposed standard. However, CenterPoint Energy believes that the SDT went too far in developing the proposed EOP-004-2 and added additional unnecessary requirements. If the comments made above to Q1 - Q12 were to be incorporated into the proposed Standard, CenterPoint Energy believes the product would be closer to a results based Standard with no reliability gap.
City of Austin dba Austin Energy	Yes	If we can use OE 417 for NERC and DOE we do not perceive a reliability gap.
Georgia System Operations Corporation	Yes	The new single standard will cover all necessary reporting requirements that are in the current two standards. They are being combined into EOP-004-2 not EOP-004-3.

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 13 Comment
Green Country Energy	Yes	With the provision that definition and scope of "impact event" are developed and tables adjusted as needed to address FERCs concerns specifically ."(1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event."
MRO's NERC Standards Review Subcommittee	Yes	Within the above question, the SDT is asking about EOP-004-2 not -3.
Nebraska Public Power District	Yes	Appears they only changed R1 for CIP-001 and moving R2-R4 directly over to EOP-004-2. R1 adds much more detail on our part for a company operating plan but would definitely help some of the present confusion.
RRI Energy, Inc.	Yes	Assume reference to EOP-004-3 in the question 13 was meant to reference version 2 (EOP-004-2).
American Electric Power (AEP)	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Constellation Power Generation and Constellation Commodities Group	Yes	
Duke Energy	Yes	
Dynegy Inc.	Yes	
ERCOT ISO	Yes	
FirstEnergy	Yes	

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 13 Comment
Idaho Power Company	Yes	
Kansas City Power & Light	Yes	
MidAmerican Energy	Yes	
NERC Staff	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
Puget Sound Energy	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
United Illuminating	Yes	
We Energies	Yes	

**14. Do you agree with the proposed effective dates? Please explain in the comment box below.**

**Summary Consideration:** While most stakeholders who responded to this question supported the 12 months originally proposed for entities to become compliant, the drafting team has revised this to 6 months. The DSR SDT feels that six months and not more than nine months is an adequate time frame. The current CIP-001 plan is adequate for the new EOP-004 and training should be met in the proposed timeline.

The Implementation Plan was developed for the revised Requirements, which do not include an electronic “one-stop shopping” tool. This topic is to be addressed in the proposed revisions to the NERC Rules of Procedure.

Organization	Yes or No	Question 14 Comment
Independent Electricity System Operator		We do not agree with the proposed standard. We therefore are unable to agree on any implementation plan.
City of Garland	No	Do not agree with this proposed draft - instead of combining 2 standards to gain efficiency, this expands the standard with unnecessary paperwork, drills, training, etc.
Constellation Power Generation and Constellation Commodities Group	No	Based on the drastic differences between the previous revisions to these standards, and this proposed revision, 24 months would be a more reasonable timeframe for an effective date.
IRC Standards Review Committee	No	If the training and Operation Plan requirements are adopted as proposed, this may not be sufficient time for some entities to comply, particularly those with limited number of staff but perform functions that have multiple event reporting requirements.
ISO New England Inc.	No	If the training and Operation Plan requirements are adopted as proposed, this may not allow sufficient time for some entities to comply, particularly those with limited number of staff, but perform functions that have multiple event reporting requirements.
Kansas City Power & Light	No	April 2011 is too soon for considerations applicable to the creation of an Operating Plan.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 14 Comment
Manitoba Hydro	No	Though CIP-001-1a already contained provisions for sabotage response guidelines, the new EOP-004-2 R2 (2.1 to 2.9) will require reexamination of existing policies to remain compliant. Upon the approval of Attachment 1, the existing disturbance guidelines will also have to be reexamined. With the addition of R3 (Identify and assess), R4 (Drills) and R5 (Training), will also require redevelopment of existing processes.
NERC Staff	No	In order to provide explicit dates, the language should be modified to state: "First calendar day of the first calendar quarter one year after the date of the order providing applicable regulatory authority approval for all requirements."
Northeast Power Coordinating Council	No	The effective dates in Canada need to be defined. The first bullet should be sufficient. If the training and Operation Plan requirements are adopted as proposed, this may not allow sufficient time for some entities to comply, particularly those with limited number of staff, but perform functions that have multiple event reporting requirements.
Puget Sound Energy	No	There are no effective dates listed in the proposed standard. The proposed effective date should allow at least one year for entities to implement the requirements of the standard. In addition, if requirement R1 remains, then the requirement to implement an operating plan should only be triggered by the ERO's finalization of the form and system for reporting impact events and should provide at least six months for the implementation of the operating plan.
Santee Cooper	No	With the proposed training and drill requirements in the current written standard, one year is not enough time.
United Illuminating	No	UI believes the implementation should be staged. For R1 and R2: First calendar day of the first calendar quarter one year after applicable regulatory authority approval for all. This provides sufficient time to draft a procedure Then time needs to be provided to provide training prior to implementation of R3 and R6. UI believes two calendar quarters should be provided to complete training; therefore R3and R6 is effective six calendar quarters following regulatory approval. Implementation for R4 should state that the initial calendar year begins on the date R2 is effective and entities have 12 months following that date to complete their first drill. R5 requires training once per calendar year. Implementation for R5 should state that the initial calendar year begins on the date R2 is effective and entities have 12 months following that date to complete their first drill.

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 14 Comment
US Bureau of Reclamation	No	There is a 15 month training requirement. If the standard goes into effect in one year, most entities will not have had an opportunity to develop their new Operating Plans and train their staff. The effective date should recognize Operating Plans need to be revised and then training needs to be implemented. The most aggressive schedule is 18 months. Two years would be more appropriate. The implementation date could recognize the Operating Plan development as one phase and the training as the second.
ATC	Yes	Yes, if ATC's recommended changes are made to the Standard. However, if the changes are not supported then ATC recommends that the implantation time be changed to two years. Entities will need time to develop both the plan called for in this standard and to train the personnel identified in the plan.
BGE	Yes	None.
Exelon	Yes	Agree with the proposed implementation date. A 12 month implementation will provide adequate time to generate, implement and provide any necessary training by a registered entity.
Ameren	Yes	
Arizona Public Service Company	Yes	
ATCO Electric Ltd.	Yes	
Bonneville Power Administration	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Duke Energy	Yes	
Dynergy Inc.	Yes	
E.ON Climate & Renewables	Yes	
Electric Market Policy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 14 Comment
ERCOT ISO	Yes	
FirstEnergy	Yes	
Georgia System Operations Corporation	Yes	
Great River Energy	Yes	
Green Country Energy	Yes	
Idaho Power Company	Yes	
Indeck Energy Services	Yes	
Luminant Energy	Yes	
MidAmerican Energy	Yes	
Midwest ISO Standards Collaborators	Yes	
MRO's NERC Standards Review Subcommittee	Yes	
North Carolina Electric Coops	Yes	
Pacific Gas and Electric Company	Yes	
PacifiCorp	Yes	
PacifiCorp	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 14 Comment
Pepco Holdings, Inc - Affiliates	Yes	
PNM Resources	Yes	
PPL Electric Utilities	Yes	
PPL Supply	Yes	
RRI Energy, Inc.	Yes	
SERC OC Standards Review Group	Yes	
Southern Company - Transmission	Yes	
TransAlta Corporation	Yes	
We Energies	Yes	
WECC	Yes	

**15. Do you have any other comments that you have not identified above?**

**Summary Consideration:** The DSR SDT has met with the EAWG and has put in place a process to ensure the cooperation and coordination between the DSR SDT and the EAWG. The impact event list is comprehensive and addresses the needs of the EAWG and EOP-004.

There were concerns expressed that the impact event list should include deliberate acts against infrastructure. The impact list includes “Risk to BES equipment from a non-environmental physical threat” the DSR SDT feels that this is inclusive of deliberate acts against infrastructure.

During discussions around the use and definition of the term sabotage, the DSR SDT considered the NRC definition and decided to eliminate the use of the term sabotage from EOP-004 and replaced it with impact events. The DSR SDT has developed a definition for “Impact Events” to support Attachment 1 as follows:

“An Impact Event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

The DSR SDT has proposed this definition for inclusion in the NERC Glossary for “Impact Event”. The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This will result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The Impact Events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive. Attachment 1, Part A is to be used for those actions that have impacted the electric system and in particular the section “Damage or destruction to equipment” clearly defines that all equipment that intentional or non intentional human error be reported. Attachment 1, Part B

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

covers the similar items but the action has not fully occurred but may cause a risk to the electric system and is required to be reported.

The industry commented on the need for e-mail addresses and fax numbers for back up purposes. These details were added to the standard and will also be covered in the implementation plan.

The proposed ballot in December was incorrect and has been deleted from the future development plan. The plan was updated with the correct project plan dates.

Organization	Yes or No	Question 15 Comment
Indeck Energy Services		Good start on a unified event reporting standard!
IRC Standards Review Committee	No	The standards should be changed to define what a “disturbance” is for reporting in EOP-004. Also, sabotage reporting requirements in CIP-001 should be rescinded as EOP-004 already has such requirements.
PSEG Companies		
Arizona Public Service Company	No	
ATCO Electric Ltd.	No	
Duke Energy	No	
Electric Market Policy	No	
FirstEnergy	No	
Independent Electricity System Operator	No	
Luminant Energy	No	

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
Manitoba Hydro	No	
PacifiCorp	No	
PPL Supply	No	
RRI Energy, Inc.	No	
United Illuminating	No	
Ameren	Yes	We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting.
American Electric Power (AEP)	Yes	The standard needs to be modified to allow the ability for one entity to report on behalf of other entities. For example the loss of Generation over the threshold could be reported by the RC opposed to the GO individually, if mutually agreed upon before the fact.
ATC	Yes	ATC believes that it is not evident in this draft that the SDT has worked collaboratively with the Events Analysis working group to leverage their work. ATC believes that NERC must coordinate this project and the EAWG efforts. The EAWG is proposing to modify NERC Rules of Procedure but the SDT is suggesting requirement for the ERO be build within the standard. We believe that the Rules of Procedure is the proper course to take to for identifying NERC obligations, but what is clear is that NERC itself does not seem to have an overall plan for event reporting and analysis. Lastly, ATC would like to see the SDT expand the mapping document to include the work of the EAWG. The industry needs to be presented with a clear picture as to how all these things will work together along with their reporting obligations. The definition of an “impact event” needs to be revised. First, if these events are to include any equipment failure or mis-operation that impacts the BES, the standard is requiring more than is intended based upon the reading of the requirements. PRC-004 already covers the reporting of protection system mis-operations, and if reading this definition verbatim, it would lead one to conclude that those same mis-operations reported under PRC-004 shall also be reported under EOP-004. The definition should be revised to something like: “An impact event is a system disturbance affecting the Bulk Electric System beyond loss of a single element under normal operating conditions and does not include events normally reported under PRC-004. Such events may be caused by...”

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
BGE	Yes	One item that is properly addressed is the removal of Load Serving Entity from the Applicable Functional Entities. There may be a need to provide some guidance to Functional Entities when there are separate Transmission Owners and Transmission Operators or Generation Owners and Generation Operators. If they are separate, there may be redundancy in reporting. From the documentation, it doesn't seem like the SDT are combining all reports into one form as we would like to see. In the rationale for R1 section, it talks of getting both forms (NERC and OE-417) together in one document (however it sounds like the forms within the document are still separate), available electronically, which only seems like a step forward. However, it does not take away the confusing process for the operators of which part of the form would need to be filled, who should be set this form depending on what part is filled, if one part of the form is filled out do the other parts need to be filled, etc. If the forms cannot be consolidated, BGE would rather the forms be separate to reduce confusion. BGE believes all these reports should require one form with one set of recipients, period. This may mean that NERC needs to get DOE to modify their OE-417 form.
Bonneville Power Administration	Yes	The document retention times in EOP-004-3 should be spelled out more clearly. The Compliance summary does so (but needs some punctuation clarification regarding investigation), the SDT should consider making that part of the requirements or clarifying the wording in the requirements.
CenterPoint Energy	Yes	CenterPoint Energy appreciates the efforts of the SDT in removing outdated and unnecessary language from the existing EOP-004 standard. Additionally, CenterPoint Energy urges the SDT to also remove the proposed "how to" prescriptive requirements. CenterPoint Energy believes the SDT team's focus should be on drafting a results-based standard for reporting actual system disturbances and acts of sabotage that disrupt the reliable operation of the BES. The SDT should not delve into trying to identify a list of events that have a potential reliability impact. As stated in response to Q10, CenterPoint Energy strongly believes that cyber-related events should not be in the scope of this standard since they are already required to be identified and reported to appropriate entities under CIP-008. Excluding cyber events from this standard further supports the elimination of redundancies within the body of standards.
City of Garland	Yes	Do not agree with this proposed draft - instead of combining 2 standards to gain efficiency, this expands the standard with unnecessary paperwork, drills, training, etc. For reports required under this standard, companies with multiple registration numbers and functions should only have to file one report for all functions and registrations.
Consolidated Edison Co. of NY, Inc.	Yes	Overriding Comment and Concern: It is absolutely essential that the work on EOP-004 and that on the NERC Event Analysis Process (EAP) be fully coordinated. We find that there are a number of inconsistencies between these two documents. The EAP and EOP-004 are not aligned. In order to operate and report

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		effectively entities need consistent requirements.
Constellation Power Generation and Constellation Commodities Group	Yes	As stated earlier, the “summary of concepts” for this latest revision, as written by the SDT, includes the following items: o A single form to report disturbances and impact events that threaten the reliability of the bulk electric system o Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements o Clear criteria for reporting o Consistent reporting timelines o Clarity around of who will receive the information and how it will be used. Each and every requirement should be mapped to one of these 5 items; otherwise, it should not be included in this standard. Summarizing all of the comments above, Constellation Power Generation proposes the following revision to EOP-004-2:1. Title: Impact Event and Disturbance Assessment, Analysis, and Reporting 2. Number: EOP-004-2 3. Purpose: Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES). 4. Applicability 4.1. Functional Entities:4.1.1. Reliability Coordinator 4.1.2. Balancing Authority 4.1.3. Transmission Operator 4.1.4. Generator Operator 4.1.5. Distribution Provider 4.1.6. Electric Reliability Organization. Requirements and Measures R1. The ERO shall establish, maintain and utilize a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness.R2. Each Applicable Entity identified in Attachment 1 shall have an Operating Plan(s) for identifying, assessing and reporting impact events listed in Attachment 1 that includes the following components: 2.1. Method(s) for identifying impact events listed in Attachment 2.2. Method(s) for assessing cause(s) of impact events listed in Attachment 12.3. Method(s) for making internal and external notifications should an impact event listed in Attachment 1 occur. 2.4. Method(s) for updating the Operating Plan.2.5 Method(s) for making operation personnel aware of changes to the Operating Plan.R3. Each Applicable Entity shall implement their Operating Plan(s) to identify and assess cause of impact events listed in Attachment 1.R4. Each Applicable Entity shall provide training to all operation personnel at least annually.R5. Each Applicable Entity shall report impact events in accordance with its Operating Plan created pursuant to Requirement 2 and the timelines outlined in Attachment 1.
Dynergy Inc.	Yes	This does not address the inability of a GO/GOP to determine effects on the BES. Surrounding BES knowledge is limited for a GO/GOP.
E.ON Climate & Renewables	Yes	Refrain from having redundant reporting forms if at all possible. This can create confusion and lead to unnecessary penalty amounts and violations for registered entities. Potential” impacts of an event on the BES need to be clearly defined in the standard.
E.ON U.S. LLC	Yes	The new standard should incorporate all other disturbance, sabotage, or “impact event” reporting standards, such as CIP-008-3. At the very least it should reference those other standards that have within their scope

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		same/similar events in order to ensure complete reporting and full compliance. Suggesting that one standard provides the single reporting procedure, when in actuality it does not, is counterproductive. The discussion of "impact event" clearly indicates the SDT's intent to include sabotage events in the proposed standard EOP-004-2.
ERCOT ISO	Yes	ERCOT ISO supports the comments provided by the SRC. However, if the standard is to be established, ERCOT ISO has offered the comments contained herein as improvements to the requirements proposed. The requirements listed do not take into consideration the hierarchical reporting necessary for events (i.e.: GO to GOP to BA). The current structure will lead to redundant and conflicting reporting from multiple entities. This will lead to confusion in the analysis of the event. Any system developed and used to report impact events must include notification to the other relevant entities (i.e.: Reliability Coordinator, Balancing Authority, Transmission Operator, and Generator Operator). The proposed standard should not rely on a centralized system that does not follow the established hierarchy of dissemination of information.
Exelon	Yes	The standard is lacking guidance for DOE Form OE-417 reporting as outlined in the current version of EOP-004 and doesn't contain any non-BES related reporting. What is the governing process for OE-417 reporting?. Need clarification if one entity can respond on behalf to all entities in one company. Need a provision for entities to provide one report for all entities. Radiological sabotage is a defined term within the NRC glossary of terms. It would seem that a deliberate act directed towards a plant would also constitute an "impact event." In general, the DSR SDT should include discussions with the NRC to ensure communications are coordinated or consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator for consistency. The definition of sabotage is defined by NRC is as follows: Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.
Georgia System Operations Corporation	Yes	Light years better than the current CIP-001-1 and EOP-004-1! With some changes from this comment period, we should have a clearer set of realistic requirements which could likely pass the ballot. Thanks go out to the drafting team for bringing clarity to this topic. Capitalization throughout this document is inconsistent. It is not in synch with the NERC Glossary. All terms that remain capitalized in the next draft (other than when used as a title or heading) should be defined in the Glossary of Terms Used in NERC Reliability Standards. Examples of not in synch with the Glossary: Registered Entity, Responsible Entity, Law Enforcement. These are not defined in the Glossary. The requirements that apply to entities should not use the word "analysis." "Assessment" should be used. Analysis is a different process (an ERO process) and is being addressed by

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		another group within NERC (Dave Nevius). This EOP-004 drafting team and the NERC analysis group should closely coordinate such that there are no conflicts and the combined requirements/processes are realistic (mainly regarding timelines).
Great River Energy	Yes	We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting. Please provide an e-mail address for the submittal of the report to NERC (and any other parties above a Regional Entity) within this Standard and a fax number as a backup to electronic submittal.
Green Country Energy	Yes	I think the drafting team has done a wonderful job of beginning the task of combining two related standards. I ask them to keep in mind the small generators, and others who do not have the wide view capability, that more than likely react to events that occur wih no knowledge of why they occured, and limited staff to address administrative standard requirements. Many times the KISS approach is the best approach.
Idaho Power Company	Yes	By including training requirements in each standard, creates confusion and compliance or failure to comply potential. PER standards are in place for personel training, these standards should be utilized for adding requirements that require training for NERC Standards.
ISO New England Inc.	Yes	Request clarification on how RCIS is part of this Standard. The form should be filled out in two stages. First stage would be the immediately available information. The second stage would be the additional information such as one line diagrams. There is concern with burdening the reporting operator on filling out forms instead of operating the Bulk Electric System. Most of the draft requirements are written as administrative in nature, and this is not most effective. Changes need to be made to (or possibly elimination of) R1, R2, R3. The standards should be changed to define what a “disturbance” is for reporting in EOP-004. Sabotage reporting as per CIP-001 should be rescinded as EOP-004 already has such a requirement.
Kansas City Power & Light	Yes	The standard addressed a preliminary report it should also address the requirements of a final report.
MidAmerican Energy	Yes	This entire standard needs to be revised to consider a results based standard.
Midwest ISO Standards Collaborators	Yes	We are concerned with the Future Development Plan. It shows an initial ballot period starting in December. This standard has significant issues and will need another distinct comment period (and not the formal comment period in parallel with balloting) prior to balloting.



Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
MRO's NERC Standards Review Subcommittee	Yes	Please provide an e-mail address for the submittal of the report to NERC (and any other parties above a Regional Entity) within this Standard and a fax number as a backup to electronic submittal. EOP-004 Attachment 2: Impact Event Reporting Form (note in the proposed standards it states EOP-002) seems to be written for Actual Impact Events only. Perhaps another section could be added for "Potential" Impact Events.
NERC Staff	Yes	NERC staff commends the SDT on its work so far. Merging CIP-001 and EOP-004 is a significant improvement and eliminates some current redundancies for reporting events. NERC staff believes opportunities to improve the proposed standard still exist. In particular, the team should consider possible redundancies with the Reliability Coordinator Working Group (RCWG) reporting guidelines, the Electricity Sector - Information Sharing and Analysis Center (ES-ISAC) reporting requirements for sharing information across sectors, and the Events Analysis Working Group (EAWG) efforts to develop event reporting processes. Ideally, the SDT and the EAWG should work together to develop a single consistent set of reporting criteria that can be utilized in both the EAWG event reporting process and in the requirements of the EOP-004-2 Reliability Standard.
North Carolina Electric Coops	Yes	Keep in mind that redundancy in reporting requirements from the DOE does not improve or enhance bulk electric system reliability but rather creates more work for the reporting entity.
Northeast Power Coordinating Council	Yes	Request clarification on how RCIS is part of this Standard. The form should be filled out in two stages. First stage would be the immediately available information. The second stage would be the additional information such as one line diagrams. There is concern with burdening the reporting operator on filling out forms instead of operating the Bulk Electric System. Most of the draft requirements are written as administrative in nature, and this is not most effective. Changes need to be made to (or possibly elimination of) R1, R2, R3. The standards should be changed to define what a "disturbance" is for reporting in EOP-004. Sabotage reporting as per CIP-001 should be rescinded as EOP-004 already has such a requirement.
Pacific Gas and Electric Company	Yes	PG&E believes as the training requirements continue to expand, having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues.
Pacific Northwest Small Public Power Utility Comment Group	Yes	The proposed standard has a huge impact on small DPs. DPs that presently do not maintain 24/7 dispatch centers will need to begin doing so to meet the reporting deadlines such as 1 hour after an occurrence is identified (possibly identified by a third party) or 24 hour after an occurrence (regardless of when it was discovered by the DP). The planning, assessing, drilling, training, and reporting requirements (R2-R6), as well as documentation (M2-M6) by small entities will cause utility rates to rise, will reduce local level of service,

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

Organization	Yes or No	Question 15 Comment
		and will not represent a corresponding increase to the reliability of the BES. The SDT concept of clear criteria for reporting has not been met, since R2 effectively directs the applicable entities to develop their own criteria. The decision of which types of events will be reported to which external organizations has been left up to the applicable entity. The comment group notes that there is no coordination of effort required between the applicable entities and the RCs or TOs that issue reliability directives. Energy Emergencies requiring voltage reduction or load shedding are likely to be communicated to applicable entities via directives. The likely result of this lack of coordination is that entities will plan, drill, and train for an event, but when the directive comes it will not be the one planned, drilled, and trained for. Coordination between those sending and receiving directives would ensure the probable events and directed responses are the ones planned, drilled, and trained for.
PacifiCorp	Yes	This is yet another standard with training requirements not covered under any PER standards. Having different training requirements spread throughout the standards makes it increasingly difficult to ensure all training requirements are met. Developing a "Training Standard" that lists ALL required training would streamline the process and aid greatly in compliance monitoring.
Pepco Holdings, Inc - Affiliates	Yes	The EAWG is developing processes that will be enforced through the Rules of Procedure. It may be inappropriate to reference the EAWG process in the Mapping Document.
PNM Resources	Yes	PNM believes that having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues. This will become even more of an issue as training requirements continue to expand.
PPL Electric Utilities	Yes	Combining EOP-004, CIP-001 and CIP-008's reporting requirements reduces redundancy and will add clarity to the compliance activities.
Puget Sound Energy	Yes	The DSR SDT's concepts for implementing a new structure for reporting are appropriate. Proper implementation of those concepts is likely to result in a very much improved standard. However, the proposed standard falls well short of implementing the concepts and is not much of an improvement on the current standard.
Santee Cooper	Yes	We don't believe that entities should be subjected to duplicate reporting to existing DOE requirements. How does redundancy in reporting requirements improve or enhance bulk electric system reliability?
SERC OC Standards Review	Yes	We find it disturbing that NERC is headed down a path of codifying requirements that are redundant to

**Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01**

Organization	Yes or No	Question 15 Comment
Group		existing DOE requirements. How does redundancy in reporting requirements improve or enhance bulk electric system reliability? Disclaimer:” The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers.”
Southern Company - Transmission	Yes	The only concern that we have with the proposed standard is that it feels like it is creating dual, not quite redundant, reporting requirements for cyber intrusions in concert with CIP-008. Hopefully, there will not have to be a redundant reporting requirement if we continue to merge efforts with the CIP Drafting Team. Since we will no longer use the word SABOTAGE in the new EOP-004, we are hoping the industry and the CIP Drafting Team will give us the criteria they wish for us to use in order to report CIP-008 incidents. We will then achieve a “ONE STOP SHOP” reporting standard.
Tenaska	Yes	Since the proposed EOP-004-2 Standard does not eliminate the OE-417 reporting requirement, it does not streamline the existing CIP-001-1 and EOP-004-1 reporting requirements for GO/GOP’s. The "laundry list" of components required in the Operating Plan described in R2 is too specific and would make it more difficult to prove compliance during an audit. We prefer that the existing CIP-001-1 and EOP-004-1 Standards remain unchanged.
TransAlta Corporation	Yes	A Confidential Impact Event Report form is included in attachment 2 but nowhere in the standard does it say to use this form. This form appears to be similar to the “Preliminary Disturbance Report” form used in EOP-004-1. Clarity is required.
US Bureau of Reclamation	Yes	The SDT should consider that in reality it would be more streamlined to require immediate notification of an event for situational awareness, and then give adequate time for analysis of the cause. Reports that have an arbitrary rush will be diseased with low quality information and not much value in the long run to the BES. The Attachment A should be constructed around notification of situational awareness. The reporting timeline should be constructed around the different levels severity. The more severe the event, usually the more complicated the event is to analyze. Simple events usually do not have a significant impact.
We Energies	Yes	Please be careful to capitalize defined terms. If the intent is to not use the defined term, use another word."Forced intrusion" (cutting a fence, breaking in a door) may not be discovered for quite some time after it occurs. Should it be reported as soon as discovered? Even if there was no impact event (disturbance)? "Destruction of a Bulk Electric System Component" seems pretty specific. However, if a transformer kicks off line due to criminal damage, yet is considered repairable, is the event reportable?

Consideration of Comments on Disturbance & Sabotage Reporting— Project 2009-01

---

Organization	Yes or No	Question 15 Comment
WECC	Yes	<p>Having one training standard that captures all the training required within the NERC standards will allow for better clarity for the training departments in providing and meeting all NERC Standard compliance issues. This will become even more of an issue as training requirements continue to expand. CIP-001-1 has surprisingly been one of the most violated standards during the initial period. However, most entities have now developed and demonstrated a decent compliance process. Unless a revised standard to address the FERC directive on sabotage is developed (as suggested in 13 above) this proposed standard appears to eliminate sabotage reporting as a reliability standard to the potential detriment of BES reliability.</p>

## Standard Development Timeline

---

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 2010)

### Proposed Action Plan and Description of Current Draft

This is the first posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a 30-day formal comment period.

### Future Development Plan

Anticipated Actions	Anticipated Date
Drafting team considers comments, makes conforming changes, and proceed to second comment	October 2010 – February 2011
Second Comment Period	March – May 2011
Third Comment/Ballot period	June- July 2011
Recirculation Ballot period	July-August 2011
Receive BOT approval	September 2011

### Effective Dates

1. The standard shall become effective on the first calendar day of the third calendar quarter after the date of the order providing applicable regulatory approval.
2. In those jurisdictions where no regulatory approval is required, the standard shall become effective on the first calendar day of the third calendar quarter after Board of Trustees adoption.

### Version History

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
2		Merged CIP-001-1 Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Impact Event Reporting; Retire CIP-001-1a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting.	Revision to entire standard (Project 2009-01)

## Definitions of Terms Used in Standard

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

**Impact Event:** Any event which has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

### Introduction

1. **Title:** Impact Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.
4. **Applicability**
  - 4.1. **Functional Entities: Within the context of EOP-004-2, the term “Responsible Entity” shall mean:**
    - 4.1.1. Reliability Coordinator
    - 4.1.2. Balancing Authority
    - 4.1.3. Interchange Authority
    - 4.1.4. Transmission Service Provider
    - 4.1.5. Transmission Owner
    - 4.1.6. Transmission Operator
    - 4.1.7. Generator Owner
    - 4.1.8. Generator Operator
    - 4.1.9. Distribution Provider
    - 4.1.10 Load Serving Entity

### 5. Background:

NERC established a SAR Team in 2009 to investigate revisions to the CIP-001 and EOP-004 Reliability Standards.

1. CIP-001 may be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 has some ‘fill-in-the-blank’ components to eliminate.

The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information).



The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009. A “concepts paper” was designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The concept paper sought comments from stakeholders on the “road map” that will be used by the SDR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the SDR SDT.

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives in order to determine a prudent course of action with respect to these standards.

The DSR SDT has used a working definition for “Impact Events” to develop Attachment 1 as follows:

“An Impact Event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

The DSR SDT has proposed this definition for inclusion in the NERC Glossary for “Impact Event”. The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This will result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The Impact Events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive. Attachment 1, Part A is to be used for those actions that have impacted the electric system and in particular the section “Damage or destruction to equipment” clearly defines that all equipment that intentional or non intentional human error be reported. Attachment 1, Part B covers the similar items but the action has not fully occurred but may cause a risk to the electric system and is required to be reported.

To support this concept, the DSR SDT has provided specific event for reporting including types of Impact Events and timing thresholds pertaining to the different types of Impact Events and who’s responsibility for reporting under the different Impact Events. This information is outlined in Attachment 1 to the proposed standard.

The DSR SDT wishes to make clear that the proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001, EOP-004. This is achieved

through the RCIS and is covered in other standards (e.g. TOP). The proposed standard deals exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and Impact Event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

### **Summary of Concepts**

- A single form to report disturbances and Impact Events that threaten the reliability of the bulk electric system
- Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Clear criteria for reporting
- Consistent reporting timelines
- Clarity around of who will receive the information and how it will be used

### **Law Enforcement Reporting**

The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting Impact Events. Certain outages, such as those due to vandalism and terrorism, are not preventable. Entities rely upon law enforcement agencies to respond and investigate those Impact Events which have the potential of wider area affect upon the industry which enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading involving Impact Events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### **Stakeholders in the Reporting Process**

- Industry
- NERC (ERO)
- FERC
- DOE
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State Law Enforcement
- FBI

The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The present CIP-001-1 standard requires a liaison relationship on behalf of the industry and FBI. Annual requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate the liaison is in place and effective. FBI offices have been asked to confirm, on FBI letterhead, the existence of a working relationship to report acts of sabotage to include references to years the liaison has been in existence and confirming telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, passionately committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.


### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**

A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Impact Event EOP-004-2). Essentially, reporting an Impact Event to law enforcement agencies will only require the industry to notify the state or provincial level law enforcement agency. The state or provincial level law enforcement agency will coordinate with local law enforcement to investigate. If the state or provincial level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Reporting Hierachy for Impact Event EOP-004-2



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

## Requirements and Measures

**R1.** Each Responsible Entity shall have an Impact Event Operating Plan that includes: *[Violation Risk: Factor Medium] [Time Horizon: Long-term Planning]*

- 1.1. An Operating Process for identifying Impact Events listed in Attachment 1.
- 1.2. An Operating Procedure for gathering information for Attachment 2 regarding observed Impact Events listed in Attachment 1.
- 1.3. An Operating Process for communicating recognized Impact Events to the following:
  - 1.3.1. Internal company personnel notification(s).
  - 1.3.2. External organizations to notify to include but not limited to the Responsible Entities' Reliability Coordinator, NERC, Responsible Entities' Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.
- 1.4. Provision(s) for updating the Impact Event Operating Plan within 90 days of any change to its content.

**M1.** Each Responsible Entity shall provide the current in force Impact Event Operating Plan to the Compliance Enforcement Authority.

**R2.** Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B). *[Violation Risk: Factor Medium] [Time Horizon: Real-time Operations and Same-day Operations]*

**M2.** To the extent that an Responsible Entity has an Impact Event on its Facilities, the Responsible Entity shall provide documentation of the implementation of its Impact Event Operating Plans. Such evidence could include, but is not limited to, operator logs, voice

### Rationale for R1

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened and why it happened when Impact Events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized.

For the Impact Event Operating Plan, the DSR SDT envisions that Part 1.2 includes performing sufficient analysis and information gathering to be able to complete the report for reportable Impact Events. The main issue is to make sure an entity can a) identify when an Impact Event has occurred and b) be able to gather enough information to complete the report.

Part 1.3 could include a process flowchart, identification of internal positions to be notified and to make notifications, or a list of personnel by name as well as telephone numbers.

The Impact Event Operating Plan may include, but not be limited to, the following: how the entity is notified of event's occurrence, person(s) initially tasked with the overseeing the assessment or analytical study, investigatory steps typically taken, and documentation of the assessment / remedial action plan.

recordings, or other notations and documents retained by the Registered Entity for each Impact Event.

**R3.** Each Responsible Entity shall conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 calendar months between tests.  
*[Violation Risk: Factor Medium]*  
*[Time Horizon: Long-term Planning]*

**M3.** In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or documentation. (R3)

### **Rationale for R3**

The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized Impact Events is correct so that the entity can respond appropriately in the case of an actual Impact Event. The Responsible Entity may conduct a drill or exercise of its Operating Process for communicating recognized Impact Events as often as it desires but the time period between such drill or exercise can be no longer than 15 months from the previous drill/exercise or actual Impact Event (i.e., if you conducted an exercise/drill/actual employment of the Operating Process in January of one year, there would be another exercise/drill/actual employment by March 31 of the next calendar year)). Multiple exercises in a 15 month period are not a violation of the requirement and would be encouraged to improve reliability.

**R4.** Each Responsible Entity shall review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan at least annually with no more than 15 calendar months between review sessions*[Violation Risk: Factor Medium]* *[Time Horizon: Long-term Planning ]*.

**M4.** Responsible Entities shall provide the materials presented to verify content and the association between the people listed in the plan and those who participated in the review, documentation showing who was present and when internal personnel were trained on the responsibilities in the plan.

**R5.** Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form. *[Violation Risk: Factor: Medium]*  
*[Time Horizon: Real-time Operations and Same-day Operations]*.

**M5.** Responsible Entities shall provide evidence demonstrating the submission of reports using the plan created pursuant to Requirement R1 and Attachment 1 using either the form in

Attachment 2 or the DOE OE-417 report. Such evidence will include a copy of the Attachment 2 form or OE-417 report submitted, evidence to support the type of Impact Event experienced; the date and time of the Impact Event; as well as evidence of report submittal that includes date and time.

### Compliance

#### Compliance Enforcement Authority

- Regional Entity; or
- If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement.

#### Compliance Monitoring and Enforcement Processes:

- Compliance Audits
- Self-Certifications
- Spot Checking
- Compliance Violation Investigations
- Self-Reporting
- Complaints

#### Evidence Retention

Each Responsible Entity shall retain data or evidence for three calendar years or for the duration of any regional or Compliance Enforcement Authority investigation; whichever is longer.

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

**Additional Compliance Information**

None

**Table of Compliance Elements**

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
<b>R1</b>	Long-term Planning	Medium	The Responsible Entity has an Impact Event Operating Plan but failed to include one of Parts 1.1 through 1.4.	The Responsible Entity has a Impact Event Operating Plan but failed to include two of Parts 1.1 through 1.4.	The Responsible Entity has an Impact Event Operating Plan but failed to include three of Parts 1.1 through 1.4.	The Responsible Entity failed to include all of Parts 1.1 through 1.4.
<b>R2</b>	Real-time Operations and Same-day Operations	Medium	N/A	N/A	N/A	The Responsible Entity failed to implement its Impact Event Operating Plan for an Impact Event listed in Attachment 1.
<b>R3</b>	Long-term Planning	Medium	The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part	The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part	The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part	The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part



**EOP-004-2 — Impact Event Reporting**

			1.3 in more than 15 months but less than 18 months.	1.3 in more than 18 months but less than 21 months.	1.3 in more than 21 months but less than 24 months.	1.3 in more than 24 months
<b>R4</b>	Long-term Planning	Medium	The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 15 months but less than 18 months.	The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 18 months but less than 21 months.	The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 21 months but less than 24 months.	The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 24 months
<b>R5</b>	Real-time Operations and Same-day Operations	Medium	The Responsible Entity failed to submit a report in less than 36 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.	The Responsible Entity failed to submit a report in more than 36 hours but less than or equal to 48 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.	The Responsible Entity failed to submit a report in more than 48 hours but less than or equal to 60 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.  OR The Responsible Entity failed to submit a report in more than 1 hour but less than 2 hours for an Impact Event requiring reporting within 1 hour in Attachment 1.	The Responsible Entity failed to submit a report in more than 60 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.  OR The Responsible Entity failed to submit a report in more than 2 hours for an Impact Event requiring reporting within 1 hour in Attachment 1.  OR The responsible entity failed to submit a

## EOP-004-2 — Impact Event Reporting

---

						report for an Impact Event in Attachment 1.
--	--	--	--	--	--	---

### **Variations**

None

### **Interpretations**

None

**EOP-004 - Attachment 1: Impact Events Table**

NOTE: Under certain adverse conditions, e.g. severe weather, it may not be possible to report the damage caused by an Impact Event and issue a written Impact Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify its Regional Entity(ies) and NERC, (e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, Voice: 609-452-1422) and provide as much information as is available. The affected Responsible Entity shall then provide periodic verbal updates until adequate information is available to issue a written Impact Event report.

EOP-004 – Attachment 1 - Actual Reliability Impact – Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
Energy Emergency requiring Public appeal for load reduction	Initiating entity is responsible for reporting	Each public appeal for load reduction	Within 1 hour of issuing a public appeal
Energy Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more	Within 1 hour after event is initiated
Energy Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq$ 100 MW	Within 1 hour after event is initiated
Energy Emergency resulting in automatic firm load shedding	Each DP or TOP that experiences the Impact Event	Firm load shedding $\geq$ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)	Within 1 hour after event is initiated
Voltage Deviations on BES Facilities	Each RC, TOP, GOP that experiences the Impact Event	$\pm$ 10% sustained for $\geq$ 15 continuous minutes	Within 24 hours after 15 minute threshold
IROL Violation	Each RC, TOP that experiences the Impact Event	Operate outside the IROL for time greater than IROL $T_v$	Within 24 hours after $T_v$ threshold
Loss of Firm load for $\geq$ 15 Minutes	Each RC, BA, TOP, DP that experiences the Impact Event	<ul style="list-style-type: none"> <li>• <math>\geq</math> 300 MW for entities with previous year's demand <math>\geq</math> 3000 MW</li> <li>• <math>\geq</math> 200 MW for all other entities</li> </ul>	Within 1 hour after 15 minute threshold
System Separation	Each RC, BA, TOP, DP that	Each separation resulting in an island of	Within 1 hour after occurrence is

**EOP-004-2 — Impact Event Reporting**

EOP-004 – Attachment 1 - Actual Reliability Impact – Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
(Islanding)	experiences the Impact Event	generation and load $\geq$ 100 MW	identified
Generation loss	Each RC, BA, GOP that experiences the Impact Event	<ul style="list-style-type: none"> <li><math>\geq</math> 2,000 MW for entities in the Eastern or Western Interconnection</li> <li><math>\geq</math> 1000 MW for entities in the ERCOT or Quebec Interconnection</li> </ul>	Within 24 hours after occurrence
Loss of Off-site power to a nuclear generating plant (grid supply)	Each RC, BA, TO, TOP, GO, GOP that experiences the Impact Event	Affecting a nuclear generating station per the Nuclear Plant Interface Requirement	Report within 24 hours after occurrence
Transmission loss	Each RC, TOP that experiences the Impact Event	Three or more BES Transmission Elements	Within 24 hours after occurrence
Damage or destruction of BES equipment <sup>1</sup>	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the Impact Event	Through operational error, equipment failure, external cause, or intentional or unintentional human action.	Within 1 hour after occurrence is identified
Damage or destruction of Critical Asset	Applicable Entities under CIP-002 or its successor.	Through operational error, equipment failure, external cause, or intentional or unintentional human action.	Within 1 hour after occurrence is identified
Damage or destruction of a Critical Cyber Asset	Applicable Entities under CIP-002 or its successor.	Through intentional or unintentional human action.	Within 1 hour after occurrence is identified

<sup>1</sup>BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action; or iv) Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly e.g., removal of grounding straps rendering protective relaying inoperative.

**EOP-004-2 — Impact Event Reporting**

<b>EOP-004 – Attachment 1 - Potential Reliability Impact – Part B</b>			
<b>Event</b>	<b>Entity with Reporting Responsibility</b>	<b>Threshold for Reporting</b>	<b>Time to Submit Report</b>
Unplanned Control Center evacuation	Each RC, BA, TOP that experiences the potential Impact Event	Unplanned evacuation from BES control center facility	Report within 24 hour after occurrence
Fuel supply emergency	Each RC, BA, GO, GOP that experiences the potential Impact Event	Affecting BES reliability <sup>2</sup>	Report within 1 hour after occurrence
Loss of all monitoring or voice communication capability	Each RC, BA, TOP that experiences the potential Impact Event	Affecting a BES control center for $\geq 30$ continuous minutes	Report within 24 hours after occurrence
Forced intrusion <sup>3</sup>	Each RC, BA, TO, TOP, GO, GOP that experiences the potential Impact Event	At a BES facility	Report within 1 hour after verification of intrusion

<sup>2</sup> Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability.

<sup>3</sup> Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).

## EOP-004-2 — Impact Event Reporting

---

Risk to BES equipment <sup>4</sup>	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the potential Impact Event	From a non-environmental physical threat	Report within 1 hour after identification
Detection of a reportable Cyber Security Incident.	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the potential Impact Event	That meets the criteria in CIP-008 (or its successor)	Report within 1 hour after detection

---

<sup>4</sup> Examples include a train derailment adjacent to BES equipment, that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment).

## EOP-004-2 — Impact Event Reporting

---

### EOP-004 - Attachment 2: Impact Event Reporting Form

This form is to be used to report Impact Events to the ERO. NERC will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550

Impact Event Reporting for EOP-004-2		
	Task	Comments
1.	Entity filing the report (include company name and Compliance Registration ID number):	
2.	Date and Time of Impact Event. Date: (mm/dd/yyyy) Time/Zone:	
3.	Name of contact person: Email address: Telephone Number:	
4.	Did the actual or potential Impact Event originate in your system?	Actual Impact Event <input type="checkbox"/> Potential Impact Event <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
5.	Under which NERC function are you reporting? (RC, TOP, BA, other)	

**EOP-004-2 — Impact Event Reporting**

Impact Event Reporting for EOP-004-2			
	Task	Comments	
6.	Brief Description of actual or potential Impact Event: (More detail should be provided in the Sequence of Events section below.)		
7.	Generation tripped off-line*.  MW Total List units tripped		
8.	Frequency*.  Just prior to Impact Event (Hz): Immediately after Impact Event (Hz max): Immediately after Impact Event (Hz min):		
9.	List transmission facilities (lines, transformers, buses, etc.) tripped and locked-out*. (Specify voltage level of each facility listed).		
10.	Demand tripped (MW)*: Number of affected customers*:	FIRM	INTERRUPTIBLE



Impact Event Reporting for EOP-004-2			
	Task	Comments	
	Demand lost (MW-Minutes)*:		
11.	Restoration Time*.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		
12.	Sequence of Events of actual or potential Impact Event (if potential Impact Event, please describe your assessment of potential impact to BES) :		

Impact Event Reporting for EOP-004-2	
Task	Comments
13.	Identify the initial probable cause or known root cause of the actual or potential Impact Event if known at time of submittal of Part I of this report:
14.	Identify any protection system misoperation(s) <sup>1</sup> :
15.	Additional Information that helps to further explain the actual or potential Impact Event if needed.

<sup>1</sup> Only applicable if it is part of the impact event the responsible entity is reporting on

## Guideline and Technical Basis

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and is progressing toward developing standards based on the SAR. This concepts paper is designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The DSR SDT also proposed to investigate incorporation of the cyber incident reporting aspects of CIP-008 under this project. This will be coordinated with the Cyber Security - Order 706 SDT (Project 2008-06).

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives to determine a prudent course of action with respect to these standards.

This concept paper provides stakeholders with a proposed “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. This concept paper provides the background information and thought process of the DSR SDT.

The proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). The proposed standards deal exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

### Summary of Concepts and Assumptions:

***The Standard Will:*** Require use of a single form to report disturbances and “Impact Events” that threaten the reliability of the bulk electric system

- Provide clear criteria for reporting
- Include consistent reporting timelines
- Identify appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provide clarity around of who will receive the information

The drafting team will explore other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements

### **Discussion of Disturbance Reporting**

Disturbance reporting requirements currently exist in EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of Impact Events that are to be reported under this standard (attachment 1).

### **Discussion of “Impact Event” Reporting**

There are situations worthy of reporting because they have the potential to impact reliability. The DSR SDT proposes calling such incidents ‘Impact Events’ with the following concept:

An Impact Event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences.

Impact Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate the reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of Impact Events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008 or its successor standard
- Forced intrusion attempt at a substation
- Train derailment near a transmission right-of-way
- Destruction of Bulk Electrical System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that reporting material risks to the Bulk Electrical System using the Impact Event categorization, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

The DST SDT discussed the reliability needs for Impact Event reporting and will consider guidance found in the document “[NERC Guideline: Threat and Incident Reporting](#)” in the development of requirements, which will include clear criteria for reporting.

Certain types of Impact Events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of Impact Events may have different reporting requirements. For example, an Impact Event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. As envisioned, the standard will only require Functional entities to report the incidents and provide information or data necessary for these analyses. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The goal of the DSR SDT is to have one reporting form for all functional entities (US, Canada, Mexico) to submit to NERC. Ultimately, it may make sense to develop an electronic version to expedite completion, sharing and storage. Ideally, entities would complete a single form which could then be distributed to jurisdictional agencies and functional entities as appropriate. Specific reporting forms<sup>6</sup> that exist today (i.e. - OE-417, etc) could be included as part of the

---

<sup>6</sup> The DOE Reporting Form, OE-417 is currently a part of the EOP-004 standard. If this report is removed from the standard, it should be noted that this form is still required by law as noted on the form: NOTICE: This report is mandatory under Public Law 93-275. Failure to comply may result in criminal fines, civil penalties and other sanctions as provided by law. For the sanctions and the provisions concerning the confidentiality of information submitted on this form, see General Information portion of the instructions. Title 18 USC 1001 makes it a criminal

electronic form to accommodate US entities with a requirement to submit the form, or may be removed (but still be mandatory for US entities under Public Law 93-275) to streamline the proposed consolidated reliability standard for all North American entities (US, Canada, Mexico). Jurisdictional agencies may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE. Functional entities may include the RC, TOP, and BA for industry awareness. Applicability of the standard will be determined based on the specific requirements.

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT is planning to update the listing of reportable events from discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences may still exist.

The reporting proposed by the DSR SDT is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information is not necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

---

offense for any person knowingly and willingly to make to any Agency or Department of the United States any false, fictitious, or fraudulent statements as to any matter within its jurisdiction.

## Standard Development Timeline

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).

### 5. Initial Informal Comment Period (September 2010)

### Proposed Action Plan and Description of Current Draft

This is the first posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a 30-day formal comment period.

### Future Development Plan

Anticipated Actions	Anticipated Date
<del>Initial Comment Period</del> <u>Drafting team considers comments, makes conforming changes, and proceed to second comment</u>	<del>September</del> <u>October</u> 2010 – <u>February</u> <u>2011</u>
<del>Drafting team considers comments, makes conforming changes, and proceed to second comment</del> <u>Second Comment Period</u>	<del>October—December</del> 2010 <u>March – May</u> <u>2011</u>
<u>Third Comment</u> <del>Period/Initial/Ballot period</del>	<del>December 2010-</del> <u>January</u> <u>June- July</u> 2011
<del>Successive Comment/Recirculation</del> Ballot period	<del>February—</del> <u>March</u> <u>July-August</u> 2011
Receive BOT approval	<del>April</del> <u>September</u> 2011

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

Effective Dates

- 1. ~~USA: The standard shall become effective on the first~~ calendar day of the ~~first~~third calendar quarter ~~one year~~ after ~~the date of the order providing~~ applicable regulatory ~~authority~~ approval. ~~for all requirements~~
- 2. ~~Canada and Mexico: First calendar day of~~ Concurrent with the ~~first calendar quarter~~ one year following Board of Trustees adoption unless governmental authority withholds approval. ~~Effective Date for the USA: In those jurisdictions where no regulatory approval is required, the standard shall become effective on the first calendar day of the third calendar quarter after Board of Trustees adoption.~~

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Font: 12 pt

Formatted: Normal

Version History

Version	Date	Action	Change Tracking
2		Merged CIP-001-1 <u>Sabotage Reporting</u> and EOP-004-1 <u>Disturbance Reporting</u> into EOP-004-2; <u>Impact Event Reporting; Retire CIP-001-1a Sabotage Reporting and</u> Retired EOP-004-1, <u>R1, R3.2, R3.3, R3.4, R4, R5</u> and associated measures, evidence retention and VSLs <u>Disturbance Reporting</u> . <u>Added new requirements for ERO—R1, R7, R8.</u>	Revision to entire standard (Project 2009-01)



### Definitions of Terms Used in Standard

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved.*

*When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

**None**

**Impact Event: Any event which has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.**

## EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

### Introduction

1. **Title:** Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting
2. **Number:** EOP-004-2
3. **Purpose:** ~~Responsible Entities shall report impact events and their known causes to support situational~~ To improve industry awareness and the reliability of the Bulk Electric System (BES) by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.
4. **Applicability**
  - 4.1. **Functional Entities:** Within the context of EOP-004-2, the term “Responsible Entity” shall mean:
    - 4.1.1. Reliability Coordinator
    - 4.1.2. Balancing Authority
    - 4.1.3. Interchange Authority
    - 4.1.4. Transmission Service Provider
    - ~~4.1.3~~4.1.5. Transmission Owner
    - ~~4.1.4~~4.1.6. Transmission Operator
    - ~~4.1.5~~4.1.7. Generator Owner
    - ~~4.1.6~~4.1.8. Generator Operator
    - ~~4.1.7~~4.1.9. Distribution Provider
    - ~~4.1.8. Electric Reliability Organization~~
    - 4.1.10 Load Serving Entity
5. **Background:**

NERC established a SAR Team in 2009 to investigate revisions to the CIP-001 and EOP-004 Reliability Standards.

1. CIP-001 may be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 has some ‘fill-in-the-blank’ components to eliminate.

The development may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality,

## EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and Reporting~~

enforceable and technically sufficient bulk power system reliability standards (see tables for each standard at the end of this SAR for more detailed information).

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009. A “concepts paper” was designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The concept paper sought comments from stakeholders on the “road map” that will be used by the SDR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the SDR SDT.

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives in order to determine a prudent course of action with respect to these standards.

The DSR SDT has ~~proposed the following concept for *impact event*~~ used a working definition for “Impact Events” to develop Attachment 1 as follows:

“An ~~*impact event*~~*Impact Event* is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

The DSR SDT has proposed this definition for inclusion in the NERC Glossary for “Impact Event”. The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This will result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The Impact Events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive. Attachment 1, Part A is to be used for those actions that have impacted the electric system and in particular the section “Damage or destruction to equipment” clearly defines that all equipment that intentional or non intentional human error be reported. Attachment 1, Part B covers the similar items but the action has not fully occurred but may cause a risk to the electric system and is required to be reported.

To support this concept, the DSR SDT has provided specific event for reporting including types of ~~*impact events*~~*Impact Events* and timing thresholds pertaining to the different types of ~~*impact events*~~*Impact Events* and who’s responsibility for reporting under the different ~~*impact events*~~*Impact Events*. This information is outlined in Attachment 1 to the proposed standard.

## EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

The DSR SDT wishes to make clear that the proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001, EOP-004. This is achieved through the RCIS and is covered in other standards (e.g. TOP). The proposed standard deals exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and ~~impact event~~Impact Event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

### Summary of Concepts

- A single form to report disturbances and ~~impact events~~Impact Events that threaten the reliability of the bulk electric system
- Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Clear criteria for reporting
- Consistent reporting timelines
- Clarity around of who will receive the information and how it will be used

### Law Enforcement Reporting

The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting Impact Events. Certain outages, such as those due to vandalism and terrorism, are not preventable. Entities rely upon law enforcement agencies to respond and investigate those Impact Events which have the potential of wider area affect upon the industry which enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading involving Impact Events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### Stakeholders in the Reporting Process

- Industry

Draft 1: ~~September 10, 2010~~; March 7,

### **Rationale for R4**

~~The goal of the DSR SDT is to have a generic reporting form and a system for all functional entities (US, Canada, Mexico) to submit impact event reports to NERC and other entities. Ultimately, it may make sense to develop an electronic version of the form to expedite completion, sharing and storage. Ideally, entities would complete a single electronic form on-line which could then be electronically forwarded or distributed to jurisdictional agencies and functional entities as appropriate using check boxes or other coding within the electronic form. Specific reporting forms that exist today (i.e. OE 417, etc) could be included as part of the electronic form to accommodate US entities with a requirement to submit the form or may be removed (but still be mandatory for US entities under Public Law 93-275) to streamline the proposed consolidated reliability standard for all North American entities (US, Canada, Mexico). Jurisdictional agencies may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE. Functional entities may include the RC, TOP, and BA for situational awareness. Applicability of the standard will be determined based on the specific requirements.~~

~~The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT is planning to update the listing of reportable events from discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences may still exist.~~

~~Responsible entities will ultimately be responsible for ensuring that OE-417 reports are received at the DOE.~~

- NERC (ERO)
- FERC
- DOE
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State Law Enforcement
- FBI

The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

#### **Present expectations of the industry under CIP-001:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The present CIP-001-1 standard requires a liaison relationship on behalf of the industry and FBI. Annual requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate the liaison is in place and effective. FBI offices have been asked to confirm, on FBI letterhead, the existence of a working relationship to report acts of sabotage to include references to years the liaison has been in existence and confirming telephone numbers for the FBI.

#### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, passionately committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

#### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**

A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial

## EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting


---

law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Impact Event EOP-004-2). Essentially, reporting an Impact Event to law enforcement agencies will only require the industry to notify the state or provincial level law enforcement agency. The state or provincial level law enforcement agency will coordinate with local law enforcement to investigate. If the state or provincial level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Reporting Hierarchy for Impact Event EOP-004-2



\*Canadian entities will follow law enforcement protocols applicable in their jurisdictions

## Requirements and Measures

~~R1. The ERO shall establish, maintain and utilize a system for receiving and distributing impact event reports, received pursuant to Requirement R6, to applicable government, provincial or law enforcement agencies and Registered Entities to enhance and support situational awareness.~~

~~M1. The ERO shall provide evidence that it established, maintained and utilized a system for the distribution of the reports it receives to the various organizations or agencies. Such evidence could include, but is not limited to, dated records indicating that reports were distributed as shown on the submitted report or electronic logs indicating distribution of reports. (R1)~~

### Rationale for R1

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened and why it happened when Impact Events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized.

For the Impact Event Operating Plan, the DSR SDT envisions that Part 1.2 includes performing sufficient analysis and information gathering to be able to complete the report for reportable Impact Events. The main issue is to make sure an entity can a) identify when an Impact Event has occurred and b) be able to gather enough information to complete the report.

Part 1.3 could include a process flowchart, identification of internal positions to be notified and to make notifications, or a list of personnel by name as well as telephone numbers.

The Impact Event Operating Plan may include, but not be limited to, the following: how the entity is notified of event's occurrence, person(s) initially tasked with the overseeing the assessment or analytical study, investigatory steps typically taken, and documentation of the assessment / remedial action plan.



**R2.**— Each ~~Applicable~~ Responsible Entity ~~identified in Attachment 1~~ shall have an Impact Event Operating Plan(s) that includes: *[Violation Risk: Factor Medium] [Time Horizon: Long-term Planning]*

~~1.1. An Operating Process for identifying, assessing and reporting impact events~~ Impact Events listed in Attachment 1 ~~that includes,~~

~~1.2. An Operating Procedure for gathering information for Attachment 2 regarding observed~~ Impact Events listed in Attachment 1.

~~1.1.1.3.~~ An Operating Process for communicating recognized Impact Events to the following components:

~~1.2. Method(s) for identifying impact events~~

~~1.3. Method(s) for assessing cause(s) of impact events~~

~~1.4. Method(s) for making internal and external notifications pursuant to Parts 2.5 and 2.6~~

~~1.4.1.1.3.1.~~ List of internal ~~Internal~~ company personnel responsible for making initial notification(s) pursuant to Parts 2.5 and 2.6.

~~1.5. List of internal company personnel to notify~~

~~1.5.1.1.3.2.~~ List of external ~~External~~ organizations to notify to include but not limited to NERC, the Responsible Entities' Reliability Coordinator, NERC, Responsible Entities' Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.

~~1.6.1.4.~~ Method ~~Provision~~ (s) for updating the Impact Event Operating Plan ~~when there is a component change within 30~~ 90 days of the notification of the any change: to its content.

~~1.7. A provision for updating the Operating Plan based on lessons learned from an exercise or implementation of the Operating Plan within 30 days of identifying the lessons learned.~~

~~1.8. A provision for updating the Operating Plan based on applicable lessons learned from the annual NERC report issued pursuant to Requirement R8 within 30 days of NERC publishing lessons learned.~~

#### **Rationale for R2**

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to assess what happened and why it happened when impact events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized.

For the Operating Plan, the DSR SDT envisions that "assessing" includes performing sufficient analysis to be able to complete the report for reportable impact events. The main issue is to make sure an entity can a) identify when an impact event has occurred and b) be able to gather enough information to complete the report.

Parts 3.3 and 3.4 include, but not limited to, operating personnel who could be involved with any aspect of the operating plan.

The Operating Plan may include, but not be limited to, the following: how the entity is notified of event's occurrence, person(s) initially tasked with the overseeing the assessment or analytical study, investigatory steps typically taken, and documentation of the assessment / remedial action plan.

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

---

~~M2~~

M1. Each ~~Applicable~~ Responsible Entity shall provide the current in force Impact Event Operating Plan to the Compliance Enforcement Authority ~~upon request. (R2)~~.

**R3**

**R2.** Each Applicable Responsible Entity shall ~~identify and assess initial probable cause of impact events listed in Attachment 1 in accordance with its~~ implement its Impact Event Operating Plan documented in Requirement R2-R1 for Impact Events listed in Attachment 1 (Parts A and B). [Violation Risk: Factor Medium] [Time Horizon: Real-time Operations and Same-day Operations]

**Rationale for R3**

The DSR-SDT intends for each Applicable Entity to assess the causes of the reportable impact event and gather enough information to complete the report that is required to be filed.

**M3M2.** To the extent that an Applicable Responsible Entity has an ~~impact event~~ Impact Event on its Facilities, the Applicable Responsible Entity shall provide documentation of ~~its assessment or analysis~~ the implementation of its Impact Event Operating Plans. Such evidence could include, but is not limited to, operator logs, voice recordings, or ~~power flow analysis cases. (R3)~~ other notations and documents retained by the Registered Entity for each Impact Event.

**R4**

**R3.** Each Applicable Responsible Entity shall conduct a ~~drill, exercise, or Real-time implementation~~ test of its Operating ~~Plan~~ Process for ~~reporting~~ communicating recognized Impact Events created pursuant to Requirement R2R1, Part 1.3 at least annually, with no more than 15 calendar months between ~~exercises or tests.~~ [Violation Risk: Factor Medium] [Time Horizon: Long-term Planning]

**Ratic**  
The Entity  
comm  
correc  
appro  
Event  
a drill  
comm  
often  
such a  
15 mc  
actual  
exerci  
Opera  
there:

**Rationale for R4**

The DSR-SDT intends for each Applicable Entity to conduct a drill or exercise of its Operating Plan as often as merited but no longer than 15 months from the previous exercise to prevent a long cycle of exercises (i.e., conducting an exercise in January of one year and then December of the next year). Multiple exercises in a 15 month period is not a violation of the requirement and would be encouraged to improve reliability. A drill or exercise may be a table-top exercise, a simulation or an actual implementation of the Operating Plan.

**M3.** In the absence of an ~~actual use-~~ Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or documentation. (R3)

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

---

~~M4. The Applicable~~**R4.** Each Responsible Entity shall ~~provide evidence that it conducted a drill, exercise or Real-time implementation of the~~review its Impact Event Operating Plan for reporting as specified in the requirement. Such evidence could include, but is not limited to, a dated, exercise scenario with notes on the exercise or operator logs, voice recordings, or power flow analysis cases for an actual implementation of the Operating Plan. (R4)

~~R5.~~ Each Applicable Entity shall provide training to all internal ~~those~~ personnel ~~who have~~ responsibilities identified in its Operating Plan for reporting pursuant to Requirement R2 subject to the following:

~~5.1~~ The training includes the personnel required to respond and their required actions under the Operating Plan.

~~Training conducted that plan~~ at least ~~once per~~ ~~calendar year~~ annually with no more than 15 ~~calendar~~ months between ~~training review~~ sessions for personnel with existing responsibilities. ~~[Violation Risk: Factor Medium] [Time Horizon: Long-term Planning].~~

~~5.2~~ If the Operating Plan is revised (with the exception of contact information revisions), training shall be conducted within 30 days of the Operating Plan revisions.

~~5.3~~ For internal personnel added to the Operating Plan or those with revised responsibilities under the Operating Plan, training shall be conducted prior to assuming the responsibilities in the plan.

~~M5.~~ Applicable

~~M4.~~ Responsible Entities shall provide the ~~actual training material~~ materials presented to verify content and the association between the people listed in the plan and those who participated in the ~~training review~~, documentation showing who was ~~trained~~ present and when internal personnel were trained on the responsibilities in the ~~Operating Plan as well as dates for personnel changes and evidence that the training was conducted following personnel changes.~~ (R5) plan.

~~R6~~R5. Each ~~Applicable~~ Responsible Entity shall report ~~impact events~~ Impact Events in accordance with ~~its the Impact Event~~ Operating Plan ~~created~~ pursuant to Requirement ~~R2~~ R1 and Attachment 1 using the ~~timelines outlined~~ form in Attachment ~~1-2~~ or the DOE OE-417 reporting form. ~~[Violation Risk: Factor: Medium] [Time Horizon: Real-time Operations and Same-day Operations].~~

~~M6.~~ ~~Registered~~ M5. Responsible Entities shall provide evidence demonstrating the submission of reports using the ~~Operating Plan~~ plan created pursuant to Requirement ~~R2~~ for impact events R1 and Attachment 1 using either the form in Attachment 2 or the DOE OE-417 report. Such evidence will include a copy of the ~~original impact event~~ Attachment 2 form or OE-417 report submitted, evidence to support the type of ~~impact event~~ Impact Event

#### Rationale for R5

The SDT is not prescribing how training is to be conducted and leaves that decision to each Applicable Entity as they best know how to conduct such activities. Conduct of an exercise constitutes training for compliance with this requirement.

For changes to the Operating Plan (5.3), the training may simply consist of a review of the revised responsibilities and a “sign-off” that personnel have reviewed the revisions.

**EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting**

---

experienced; the date and time of the ~~impact event~~ Impact Event; as well as evidence of report submittal that includes date and time. ~~(R6)~~

~~R7.~~ The ERO shall annually review and propose revisions to the impact event table (Attachment 1) if warranted based on its analysis of reported impact events. Revisions to Attachment 1 shall follow the Reliability Standards Development Procedure.

~~M7.~~ The ERO shall provide evidence that it reviewed the impact event table. If applicable, the ERO shall provide evidence that it followed the Reliability Standards Development Procedure to propose and implement revisions to Attachment 1. Such evidence may include, but not be limited to, documentation that compares or assesses the list of impact events (Attachment 1) against the analysis of reported impact events. (R7)

~~R8.~~ The ERO shall publish a quarterly report of the year's reportable impact events subject to the following:

- ~~8.1~~ Issued no later than 30 days following the end of the calendar quarter
- ~~8.2~~ Identifies trends on the BES
- ~~8.3~~ Identifies threats to the BES
- ~~8.4~~ Identifies other vulnerabilities to the BES
- ~~8.5~~ Documents lessons learned
- ~~8.6~~ Includes recommended actions.

~~M8.~~ The ERO shall provide evidence that it issued a report identifying trends, threats, or other vulnerabilities on the bulk electric system at least quarterly. Such evidence will include a copy of the report as well as dated evidence of the report's issuance. (R8)

#### Rationale for R7-R8

Some of the concepts contained in Requirements R7 and R8 are contained in the NERC Rules of Procedure, section 800. The DSR SDT felt that, in order to have a complete standard for reporting impact events that improved reliability, there needed to be feedback to industry on a regular basis as well as when issues are discovered. The analysis of impact events is crucial and the subsequent dissemination of the results of that analysis must be performed.

In accordance with Sections 401(2) and 405 of the Rules of Procedures, the ERO can be set as an applicable entity in a requirement or standard. After careful consideration, the DSR SDT believes that these requirements (R7-8) are best applicable to the ERO.

#### Rationale for R8

The ERO will analyze Impact Events that are reported through requirement R6. The DSR SDT envisions the ERO issuing reports identifying trends, threats or other vulnerabilities when available or at least quarterly. The report will include lessons learned and recommended actions (such as mitigation plans) to improve reliability as applicable.

## Compliance

### Compliance Enforcement Authority

- Regional Entity; or
- ~~For requirements applicable to the ERO, an entity contracted to perform an audit.~~
- If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement.

**Compliance Monitoring and Enforcement Processes:**

- Compliance Audits
- Self-Certifications
- Spot Checking
- Compliance Violation Investigations
- Self-Reporting
- Complaints

**Evidence Retention**

Each ~~Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator and Distribution Provider~~ Responsible Entity shall ~~keep~~ retain data or evidence ~~to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:~~

~~The ERO shall retain evidence of Requirements 1, 7 and 8, Measures 1, 7, and 8 for three calendar years.~~

~~Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator and Distribution Provider shall retain data or evidence of Requirements 2, 3, 4, and 5 and Measures 2, 3, 4, and 5 for three calendar years for the duration of any regional or Compliance Enforcement Authority investigation; whichever is longer to show compliance unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.~~

~~Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator and Distribution Provider shall retain data or evidence of Requirement 6 and Measure 6 for three calendar years for the duration of any regional investigation, whichever is longer to show compliance unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation.~~

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.



**Additional Compliance Information**

~~To be determined.~~

None

**Table of Compliance Elements**

<u>R #</u>	<u>Time Horizon</u>	<u>VRF</u>	<u>Violation Severity Levels</u>			
			<u>Lower VSL</u>	<u>Moderate VSL</u>	<u>High VSL</u>	<u>Severe VSL</u>
<u>R1</u>	<u>Long-term Planning</u>	<u>Medium</u>	<u>The Responsible Entity has an Impact Event Operating Plan but failed to include one of Parts 1.1 through 1.4.</u>	<u>The Responsible Entity has a Impact Event Operating Plan but failed to include two of Parts 1.1 through 1.4.</u>	<u>The Responsible Entity has an Impact Event Operating Plan but failed to include three of Parts 1.1 through 1.4.</u>	<u>The Responsible Entity failed to include all of Parts 1.1 through 1.4.</u>
<u>R2</u>	<u>Real-time Operations and Same-day Operations</u>	<u>Medium</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>The Responsible Entity failed to implement its Impact Event Operating Plan for an Impact Event listed in Attachment 1.</u>
<u>R3</u>	<u>Long-term Planning</u>	<u>Medium</u>	<u>The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to</u>	<u>The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to</u>	<u>The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to</u>	<u>The Responsible Entity failed to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to</u>

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

			<u>Requirement R1, Part 1.3 in more than 15 months but less than 18 months.</u>	<u>Requirement R1, Part 1.3 in more than 18 months but less than 21 months.</u>	<u>Requirement R1, Part 1.3 in more than 21 months but less than 24 months.</u>	<u>Requirement R1, Part 1.3 in more than 24 months</u>
<u>R4</u>	<u>Long-term Planning</u>	<u>Medium</u>	<u>The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan 1 in more than 15 months but less than 18 months.</u>	<u>The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 18 months but less than 21 months.</u>	<u>The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 21 months but less than 24 months.</u>	<u>The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 24 months</u>
<u>R5</u>	<u>Real-time Operations and Same-day Operations</u>	<u>Medium</u>	<u>The Responsible Entity failed to submit a report in less than 36 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.</u>	<u>The Responsible Entity failed to submit a report in more than 36 hours but less than or equal to 48 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.</u>	<u>The Responsible Entity failed to submit a report in more than 48 hours but less than or equal to 60 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.</u> <u>OR</u> <u>The Responsible Entity failed to submit a report in more than 1 hour but less than 2 hours for an Impact Event requiring reporting within 1 hour</u>	<u>The Responsible Entity failed to submit a report in more than 60 hours for an Impact Event requiring reporting within 24 hours in Attachment 1.</u> <u>OR</u> <u>The Responsible Entity failed to submit a report in more than 2 hours for an Impact Event requiring reporting within 1 hour in Attachment 1.</u> <u>OR</u> <u>The responsible entity</u>

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

---

					<a href="#">in Attachment 1.</a>	<a href="#">failed to submit a report for an Impact Event in Attachment 1.</a>
--	--	--	--	--	----------------------------------	--

**Variances**

None

**Interpretations**

None

EOP-004 - Attachment 1: Impact Events Table

NOTE: Under certain adverse conditions, e.g., severe weather, it may not be possible to ~~assess/report~~ the damage caused by an ~~impact event~~ **Impact Event** and issue a written Impact Event Report within the timing in the table below. In such cases, the affected ~~Applicable/Responsible~~ Entity shall notify its Regional Entity(ies) and NERC, ~~and verbally (e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422) and~~ provide as much information as is available ~~at that time.~~ The affected ~~Applicable/Responsible~~ Entity shall then provide periodic verbal updates until adequate information is available to issue a written ~~Preliminary~~ **Impact Event Report**.

EOP-004 – Attachment 1 - Actual Reliability Impact – Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
Energy Emergency requiring Public appeal for load reduction	<del>RC, BA</del> <u>Initiating entity is responsible for reporting</u>	<del>To reduce consumption in order to maintain the continuity of the BES</del> Each public appeal for load reduction	Within 1 hour of issuing a public appeal
Energy Emergency requiring system-wide voltage reduction	<del>RC, TO, TOP, DP</del> <u>Initiating entity is responsible for reporting</u>	System wide voltage reduction of 3% or more	Within 1 hour after <del>occurrence</del> <u>event is identified/initiated</u>
<u>Energy Emergency requiring manual firm load shedding</u>	<u>Initiating entity is responsible for reporting</u>	<u>Manual firm load shedding ≥ 100 MW</u>	<u>Within 1 hour after event is initiated</u>
Energy Emergency <del>requiring</del> <u>resulting in automatic</u> firm load shedding	<del>RC, BA, TOP, DP</del> <u>Each DP or TOP that experiences the Impact Event</u>	Firm load shedding ≥ 100 MW ( <del>manually or</del> via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)	Within <del>24 hours</del> <u>1 hour</u> after <del>occurrence</del> <u>event is initiated</u>
Voltage Deviations <u>on BES Facilities</u>	<u>Each RC, TOP, GOP that experiences the Impact Event</u>	± 10% sustained for ≥ 15 <u>continuous</u> minutes	Within 24 hours after 15 minute threshold
<del>Frequency Deviations</del>	<del>RC, BA</del>	<del>± Deviations ≥ than Frequency Trigger Limit (FTL) more than 15 minutes</del>	<del>Within 24 hours after 15 minute threshold</del>
IROL Violation	<u>Each RC, TOP that experiences the Impact Event</u>	Operate outside the IROL for time greater than IROL Tv	Within 24 hours after Tv threshold

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

EOP-004 – Attachment 1 - Actual Reliability Impact – Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
Loss of Firm load for ≥ 15 Minutes	<u>Each RC, BA, <del>TO</del>, TOP, DP that experiences the Impact Event</u>	<ul style="list-style-type: none"> <li>≥ 300 MW for entities with previous year's demand ≥ 3000 MW</li> <li>≥ 200 MW for all other entities</li> </ul>	Within <del>24 hours</del> <u>1 hour</u> after 15 minute threshold
System Separation (Islanding)	<u>Each RC, BA, TOP, DP that experiences the Impact Event</u>	Each separation resulting in an island of generation and load ≥ 100 MW	Within 1 hour after occurrence is identified
Generation loss	<u>Each RC, BA, <del>GO</del>, GOP that experiences the Impact Event</u>	<ul style="list-style-type: none"> <li>≥ 2,000 MW for entities in the Eastern or Western Interconnection</li> <li><del>≥ 1000 MW for entities in the ERCOT or Quebec Interconnection</del></li> <li><del>An entire generating station of ≥ 5 generators with aggregate capacity of ≥ 500 MW</del></li> </ul>	Within 24 hours after occurrence
<u>Loss of Off-site power to a nuclear generating plant (grid supply)</u>	<u>Each RC, BA, TO, TOP, GO, GOP that experiences the Impact Event</u>	<u>Affecting a nuclear generating station per the Nuclear Plant Interface Requirement</u>	<u>Report within 24 hours after occurrence</u>
Transmission loss	<u>Each RC, <del>TO</del>, TOP that experiences the Impact Event</u>	<ul style="list-style-type: none"> <li><del>An entire DC converter station</del></li> <li><del>Multiple BES transmission elements (simultaneous or common mode event)</del></li> <li><del>Three or more BES Transmission Elements</del></li> </ul>	Within 24 hours after occurrence
Damage or destruction of BES <del>equipment</del> <sup>1</sup> <u>equipment</u> <sup>1</sup>	<u>Each RC, BA, TO, TOP, GO, GOP, DP that experiences the Impact Event</u>	Through operational error, equipment failure, <del>or</del> external cause, <u>or intentional or unintentional human action.</u>	Within 1 hour after occurrence is identified

<sup>1</sup>BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action; or iv) Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly e.g., removal of grounding straps rendering protective relaying inoperative.

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

EOP-004 – Attachment 1 - Actual Reliability Impact – Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
<u>Damage or destruction of Critical Asset</u>	<u>Applicable Entities under CIP-002 or its successor.</u>	<u>Through operational error, equipment failure, external cause, or intentional or unintentional human action.</u>	<u>Within 1 hour after occurrence is identified</u>
<u>Damage or destruction of a Critical Cyber Asset</u>	<u>Applicable Entities under CIP-002 or its successor.</u>	<u>Through intentional or unintentional human action.</u>	<u>Within 1 hour after occurrence is identified</u>

**Examples:**

- a. ~~BES equipment that is:~~
    - i. ~~A critical asset~~
    - ii. ~~Affects an IROL~~
    - iii. ~~Significantly affects the reliability margin of the system e.g., has the potential to result in the need for emergency actions~~
    - iv. ~~Damaged or destroyed due to a non-environmental external cause~~
- ~~Report copper theft from BES equipment only if it degrades the ability of equipment to operate correctly e.g., removal of grounding straps rendering protective relaying ineffective~~

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

EOP-004 – Attachment 1 - Potential Reliability Impact – Part B			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
Unplanned Control Center evacuation	<del>Each</del> RC, BA, TOP <del>that experiences the potential Impact Event</del>	Unplanned evacuation from BES control center facility	<del>report</del> Report within <del>+24</del> hour after occurrence
Fuel supply emergency	<del>Each</del> RC, BA, GO, GOP <del>that experiences the potential Impact Event</del>	Affecting BES <del>reliability</del> <sup>2</sup> <del>reliability</del> <sup>2</sup>	<del>report</del> Report within 1 hour after occurrence
<del>Loss of off-site power (grid supply)</del>	<del>RC, BA, TO, TOP, GO, GOP</del>	<del>Affecting a nuclear generating station</del>	<del>report</del> within <del>1 hour</del> after occurrence
Loss of all monitoring or voice communication capability	<del>Each</del> RC, BA, TOP <del>that experiences the potential Impact Event</del>	Affecting a BES control center for ≥ 30 <del>continuous</del> minutes	<del>report</del> Report within <del>1 hour</del> <sup>24 hours</sup> after occurrence
Forced <del>intrusion</del> <sup>2</sup> <del>intrusion</del> <sup>3</sup>	<del>Each</del> RC, BA, TO, TOP, GO, GOP <del>that experiences the</del>	At a BES facility	<del>report</del> Report within <del>24 hours</del> <sup>1 hour</sup> after <del>occurrence</del> <sup>verification of intrusion</sup>

<sup>2</sup> Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability.

<sup>3</sup> Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).

EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

	<u>potential Impact Event</u>		
Risk to BES <del>equipment<sup>3</sup>equipment<sup>4</sup></del>	<u>Each RC, BA, TO, TOP, GO, GOP, DP that experiences the potential Impact Event</u>	From a non-environmental physical threat	<del>report</del> <u>Report</u> within <del>24 hours</del> <u>1 hour</u> after <del>occurrence</del> <u>identification</u>
Detection of a <del>cyber intrusion to critical cyber assets</del> <u>reportable Cyber Security Incident.</u>	<u>Each RC, BA, TO, TOP, GO, GOP, DP that experiences the potential Impact Event</u>	That meets the criteria in CIP-008 (or its successor)	<del>report</del> <u>Report</u> within <del>24 hours</del> <u>1 hour</u> after <del>occurrence</del> <u>detection</u>

- ~~1. Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability.~~
- ~~2. Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).~~

~~Examples include a train derailment adjacent to BES equipment, that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center).~~

<sup>4</sup> ~~Examples include a train derailment adjacent to BES equipment, that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment).~~



EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and~~ Reporting

EOP-~~002~~004 - Attachment 2: Impact Event Reporting Form

This form is to be used to report Impact Events to the ERO. NERC will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: [609-452-9550](tel:609-452-9550)

EOP-004—Confidential Impact Event <del>Report</del> Reporting for EOP-004-2		
	Task	Comments
1.	Entity filing the report (include <u>company name and</u> Compliance Registration ID number):	
2.	Date and Time of <del>impact event</del> Impact Event. Date: (mm/dd/ <u>yyyyyy</u> ) Time/Zone:	
3.	Name of contact person: Email address: Telephone Number:	
4.	Did the <del>impact event</del> actual or potential Impact Event originate in your system?	<u>Actual Impact Event</u> <input type="checkbox"/> <u>Potential Impact Event</u> <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> <u>Unknown</u> <input type="checkbox"/>
5.	Under which NERC function are you reporting? ( <u>RC, TOP, BA, other</u> )	

Formatted Table

EOP-004— Confidential Impact Event <del>Report</del> Reporting for EOP-004-2			
	Task	Comments	
6.	Brief Description of <del>impact event</del> <u>actual or potential Impact Event</u> : (More detail should be provided in the Sequence of Events section below.)		
7.	Generation tripped off-line: MW Total List units tripped		
8.	Frequency: Just prior to <del>impact event</del> <u>Impact Event</u> (Hz): Immediately after <del>impact event</del> <u>Impact Event</u> (Hz max): Immediately after <del>impact event</del> <u>Impact Event</u> (Hz min):		
9.	List transmission facilities (lines, transformers, buses, etc.) tripped and locked-out: (Specify voltage level of each facility listed).		
10.	Demand tripped (MW):	FIRM	INTERRUPTIBLE

Formatted Table

EOP-004— Confidential Impact Event <del>Report</del> Reporting for EOP-004-2			
	Task	Comments	
	Number of affected customers: <del>*</del> Demand lost (MW-Minutes) <del>*)</del> <del>*</del> :		
11.	Restoration Time: <del>*</del>	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		
12.	<u>Sequence of Events:</u> <u>Sequence of Events of actual or potential Impact Event (if potential Impact Event, please describe your assessment of potential impact to BES):</u>		

Formatted Table

EOP-004— Confidential Impact Event <del>Report</del> Reporting for EOP-004-2	
Task	Comments
13.	Identify the initial probable cause or known root cause of the <del>impact event</del> <u>actual or potential Impact Event if known at time of submittal of Part I of this report:</u>
14.	Identify any protection system misoperation(s) <del>);</del> <sup>1</sup> :
15.	Additional Information that <del>the</del> helps to further explain the <del>event</del> <u>actual or potential Impact Event</u> if needed. <del>A one-line diagram may be attached, if readily available, to assist in the evaluation of the event.:</del>

Formatted Table

<sup>1</sup> Only applicable if it is part of the impact event the responsible entity is reporting on

EOP-004—Confidential Impact Event <del>Report</del> Reporting for EOP-004-2		
	Task	Comments

Formatted Table

## Guideline and Technical Basis

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and is progressing toward developing standards based on the SAR. This concepts paper is designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The DSR SDT also proposed to investigate incorporation of the cyber incident reporting aspects of CIP-008 under this project. This will be coordinated with the Cyber Security - Order 706 SDT (Project 2008-06).

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives to determine a prudent course of action with respect to these standards.

This concept paper provides stakeholders with a proposed “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. This concept paper provides the background information and thought process of the DSR SDT.

The proposed changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). The proposed standards deal exclusively with after-the-fact reporting.

The DSR SDT is proposing to consolidate disturbance and event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

## EOP-004-2 — ~~Impact Event and Disturbance Assessment, Analysis, and Reporting~~

Summary of Concepts and Assumptions:

**The Standard Will:** Require use of a single form to report disturbances and “~~impact events~~Impact Events” that threaten the reliability of the bulk electric system

- Provide clear criteria for reporting
- Include consistent reporting timelines
- Identify appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provide clarity around of who will receive the information

The drafting team will explore other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements

### Discussion of Disturbance Reporting

Disturbance reporting requirements currently exist in EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria are in the existing EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of ~~impact events~~Impact Events that are to be reported under this standard (attachment 1).

### Discussion of “~~impact event~~Impact Event” Reporting

There are situations worthy of reporting because they have the potential to impact reliability. The DSR SDT proposes calling such incidents ‘~~impact events~~Impact Events’ with the following concept:

An ~~impact event~~Impact Event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences.

Impact ~~event~~Event reporting facilitates ~~situational~~industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate the reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of ~~impact events~~Impact Events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008 or its successor standard
- Forced intrusion attempt at a substation

## EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and Reporting~~

- Train derailment near a transmission right-of-way
- Destruction of Bulk Electrical System equipment

### **What about sabotage?**

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that reporting material risks to the Bulk Electrical System using the ~~impact event~~Impact Event categorization, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

The DST SDT discussed the reliability needs for ~~impact event~~Impact Event reporting and will consider guidance found in the document “[NERC Guideline: Threat and Incident Reporting](#)” in the development of requirements, which will include clear criteria for reporting.

Certain types of ~~impact events~~Impact Events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of ~~impact events~~Impact Events may have different reporting requirements. For example, an ~~impact event~~Impact Event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### **Potential Uses of Reportable Information**

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. As envisioned, the standard will only require Functional entities to report the incidents and provide information or data necessary for these analyses. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The goal of the DSR SDT is to have one reporting form for all functional entities (US, Canada, Mexico) to submit to NERC. Ultimately, it may make sense to develop an electronic version to expedite completion, sharing and storage. Ideally, entities would complete a single form which could then be distributed to jurisdictional agencies and functional entities as appropriate. Specific reporting forms<sup>6</sup> that exist today (i.e. - OE-417, etc) could be included as part of the

<sup>6</sup> The DOE Reporting Form, OE-417 is currently a part of the EOP-004 standard. If this report is removed from the standard, it should be noted that this form is still required by law as noted on the form: NOTICE: This report is mandatory under Public Law 93-275. Failure to comply may result in criminal fines, civil penalties and other



## EOP-004-2 — Impact Event ~~and Disturbance Assessment, Analysis, and Reporting~~

---

electronic form to accommodate US entities with a requirement to submit the form, or may be removed (but still be mandatory for US entities under Public Law 93-275) to streamline the proposed consolidated reliability standard for all North American entities (US, Canada, Mexico). Jurisdictional agencies may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE. Functional entities may include the RC, TOP, and BA for ~~situational~~industry awareness. Applicability of the standard will be determined based on the specific requirements.

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT is planning to update the listing of reportable events from discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences may still exist.

The reporting proposed by the DSR SDT is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information is not necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

---

sanctions as provided by law. For the sanctions and the provisions concerning the confidentiality of information submitted on this form, see General Information portion of the instructions. Title 18 USC 1001 makes it a criminal offense for any person knowingly and willingly to make to any Agency or Department of the United States any false, fictitious, or fraudulent statements as to any matter within its jurisdiction.

## Unofficial Comment Form for Disturbance and Sabotage Reporting (Project 2009-01)

Please **DO NOT** use this form to submit comments. Please use the electronic comment form located at the link below to submit comments on the Second Posting of EOP-004-2, Impact Event Reporting (Project 2009-01). The electronic comment form must be completed by **April 8, 2011**.

[Project 2009-01 Disturbance and Sabotage Reporting](#)

If you have questions please contact Stephen Crutchfield at [Stephen.Crutchfield@nerc.net](mailto:Stephen.Crutchfield@nerc.net) or by telephone at 609-651-9455.

### Background Information

The Disturbance and Sabotage Reporting Drafting Team posted the first draft of EOP-004-2 – Impact Event Reporting for a 30-day informal comment period from September 15, 2010 through October 15, 2010. Based on stakeholder comments, and also on the results of the observations made by the Quality Review team, the drafting team made the following significant changes to the standard following the posting period that ended on October 15, 2011.

**Scope:** A common thread through most of the comments was that the DSR SDT went beyond the reliability intent of the standard (reporting) and concentrated too much on the analysis of the event. The DSR SDT agrees with this response, and revised the purpose as follows:

*Original Purpose:* Responsible Entities shall report impact events and their known causes to support situational awareness and the reliability of the Bulk Electric System (BES).

*Revised Purpose:* To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.

### Definitions:

**Impact Event:** The DSR SDT had proposed a working definition for “impact events” to support EOP-004 - Attachment 1 as follows:

“An impact event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

Many stakeholders indicated that the definition should be added to the NERC Glossary and the DSR SDT adopted this suggestion. The types of Impact Events that are required to be reported are contained within EOP-004 - Attachment 1. *Only the events identified in EOP-004 – Attachment 1 are required to be reported under this Standard.*

### Sabotage:

FERC Order 693, paragraph 471 states in part: “. . . the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.” The DSR SDT made a conscious, deliberate decision to exclude a strict definition of sabotage from this standard and sought stakeholder feedback on this issue. Some suggested adopting the NRC

definition of the term sabotage, and the DSR SDT did consider adopting the NRC definition shown below but determined that the definition is too narrowly focused.

Any deliberate act directed against a plant or transport in which an activity licensed pursuant to 10 CFR Part 73 of NRC's regulations is conducted or against a component of such a plant or transport that could directly or indirectly endanger the public health and safety by exposure to radiation.

Most respondents agreed that in order to be labeled as an act of sabotage, the intent of the perpetrators must be known. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This would result in further ambiguity with respect to reporting events, and the timeline associated with the reporting requirements does not lend itself to the in-depth analysis required to identify a disturbance (or potential disturbance) as sabotage. The SDT felt that a likely consequence of having to meet this criterion, in the time allotted, would be an under-reporting of events. Accordingly, all references to sabotage have been deleted from the standard. Instead, the SDT concentrated on providing clear guidance on the events that should trigger a report. The SDT believes that this more than adequately meets the reliability intent of the Commission as expressed in paragraph 471 of Order 693 in an equally efficient and effective manner.

**Situational Awareness versus Industry Awareness:** Some commenters correctly pointed out that "situational awareness" is a desirable by-product of an effective event reporting system, and not the driver of that system. Accordingly, all references to "situational awareness" have been deleted from the standard. The more generic "industry awareness" has been substituted where appropriate.

**Applicability:** The DSR SDT had protracted discussions on the applicability of this standard to the LSE. Per the Functional Model, the LSE does not own assets and therefore should not be an applicable entity (no equipment that could experience a "disturbance"). However, the Registry Criteria contains language that could imply that the LSE does own assets, or is at least responsible for assets. In addition, the DSR SDT modified Attachment 1 to include reporting of damage or destruction of Critical Cyber Assets per CIP-002. The LSE, as well as the Interchange Authority and Transmission Service Provider are applicable entities under CIP-002 and should be included for Impact Events under EOP-004.

There were several comments that the asset owners (GO/TO) would be less likely than the asset operators (GOP/TOP) to be aware of an impact event. The DSR SDT recognizes that this may be true in some cases, but not all. In order to meet the reliability objectives of this requirement, the applicability for GO/TO will remain as per Attachment 1.

**Requirement R1:** Based on stakeholder comments, Requirement R1, which assigned the ERO the responsibility for collecting and distributing impact event reports was deleted. There was strong support for a central system for receiving and distributing impact event reports ("one stop shopping"). There was general agreement that NERC was the most likely, logical entity to perform that function. However several respondents expressed their concern that the ERO could not be compelled to do so by a requirement in a Reliability Standard (not a User, Owner or Operator of the BES). In their own comments, NERC did not oppose the concept, but suggested that the more appropriate place to assign this responsibility would be the NERC Rules of Procedure. The DSR SDT concurs. The DSR SDT has removed the requirement from the standard and is proposing to make revisions to the NERC Rules of Procedure as follows:

812. NERC will establish a system to collect impact event reports as established for this section, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, and regulatory agencies as necessary. These reports shall be forwarded to the Federal Energy Regulatory Commission for impact events that occur in the United States. The ERO shall solicit contact information from Registered Entities appropriate governmental, law enforcement and regulatory agencies for distributing reports.

**Requirement R2 (now R1 in the revised standard)**

There were objections to the use of the term "Operating Plan" to describe the procedure to identify and report the occurrence of a disturbance. The DSR SDT believes that the use of a defined term is appropriate and has revised Requirement R1 to include Operating Plan, Operating Process and Operating Procedure.

Many commenters felt that the requirements around updating the Operating Plan were too prescriptive, and impossible to comply with during the time frame allowed. The DSR SDT agrees, and Requirement R2, Parts 2.5 through 2.9 have been eliminated. They have been replaced with Requirement R1, Part 1.4 to require updating the Impact Event Operating Plan within 90 days of any change to content.

**R1.** Each Responsible Entity shall have an Impact Event Operating Plan that includes: [*Violation Risk: Factor Medium*] [*Time Horizon: Long-term Planning*]:

- 1.1. An Operating Process for identifying Impact Events listed in Attachment 1.
- 1.2. An Operating Procedure for gathering information for Attachment 2 regarding observed Impact Events listed in Attachment 1.
- 1.3. An Operating Process for communicating recognized Impact Events to the following:
  - 1.3.1 Internal company personnel notification(s).
  - 1.3.2. External organizations to notify to include but not limited to the Responsible Entities' Reliability Coordinator, NERC, Responsible Entities' Regional Entity, Law Enforcement, and Governmental or Provincial Agencies.
- 1.4. Provision(s) for updating the Impact Event Operating Plan within 90 days of any change to its content.

Other requirements reference the Operating Plan as appropriate. The requirements of EOP-004-2 fit precisely into the definition of Operating Plan:

Operating Plan: A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.

**Requirement R3:** Requirement R3 (now R2 in the revised standard) has been re-written to exclude the requirement to "assess the initial probable cause". The only remaining reference to "cause" is in the Impact Event Reporting Form (Attachment 2). Here, there is no longer a requirement to assess the probable cause. The probable cause only needs to be identified, and only if it is known at the time of the submittal of the report.

- R2. Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B).

**Requirement R4:** (Now R3 in the revised standard.) The DSR SDT did a full review based on comments that were received. R3 now is stream lined to read:

- R3. Each Responsible Entity shall conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 months between such tests.

The testing of the Operating Process for communicating recognized Impact Events (as stated in R1) is the main component of this requirement. Several commenters provided input that too much "how" was previously within R3 and the DSR DST should only provide the "what". The DSR SDT did not provide any prescriptive guidance on how to accomplish the required testing within the rewrite. Testing of the entity's procedure (R1) could be by an actual exercise of the process (testing as stated in FERC Order 693 section 471), a formal review process or real time implementation of the procedure. The DSR SDT reviewed Order 693 and section 465 directs, with respect to processes, that entities "verify that they achieve the desired result". This is the basis of R3, above.

**Requirement R5:** Note R5 has been moved to R4 due to rearranging of requirements. The DSR SDT did a full review based on comments that were received. The major issues that were provided by commenters involved the inclusion of Requirement R5, Part 5.3 and Part 5.4.

- 5.3 If the Operating Plan is revised (with the exception of contact information revisions), training shall be conducted within 30 days of the Operating Plan revisions.
- 5.4 For internal personnel added to the Operating Plan or those with revised responsibilities under the Operating Plan, training shall be conducted prior to assuming the responsibilities in the plan.

Upon detailed review the DSR SDT agrees with the majority of comments received regarding Requirement R5, Parts 5.3 and 5.4 and has removed Parts 5.3 and 5.4 completely from the Standard. Training is still the main theme of this requirement (now R4) as it pertains to the personnel required to implement the Impact Event Operating Plan (R1). R4 now is stream lined to read:

- R4. Each Responsible Entity shall review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan at least annually with no more than 15 calendar months between review sessions.

**Requirement R6:** Note R6 been moved to R5 due to rearranging of requirements. The DSR SDT did a full review based on comments that were received. Many comments received identified concerns on the reporting time lines within Attachment 1. Several commenters wanted the ability to report impact events to their responsible parties via the DOE Form OE-417. Upon discussions with the DOE and NERC, the DSR SDT has added the ability to use the DOE Form OE-417 when the same or similar items are required to be reported to NERC and the DOE. This will reduce the need to file multiple forms when the same or similar events must be reported to the DOE and NERC. The reliability intent of reporting impact events within prescribed guidelines, to provide industry awareness and to

start any required analysis processes can be met without duplicate reporting. R5 now is stream lined to read:

R5. Each Responsible Entity shall report Impact Events in accordance with its Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form.

**Requirements R7 and R8:** The DSR SDT did a full review based on comments that were received. The DSR SDT has determined that R7 and R8 are not required to be within a NERC Standard since Section 800 of the Rules of Procedure already assigns this responsibility to NERC.

**Attachment 1:** The DSR SDT did a full review based on comments that were received. The DSR SDT, the Events Analysis Working Group (EAWG), NERC Staff (to include NERC Senior VP and Chief Reliability Officer) had an open discussion involving this topic. The EAWG and the DSR SDT aligned Attachment 1 with the Event Analysis Program category 1 analysis responsibilities. This will assure that impact events in EOP-004-2 reporting requirements are the starting vehicle for any required Event Analysis within the NERC Event Analysis Program. The DSR SDT reviewed the “hierarchy” of reporting within Attachment 1. To reduce multiple entities reporting the same impact event, the DSR SDT has stated that the entity that performs the action or is directly affected by an action will report per EOP-004-2. As an example, during a system emergency, the TOP or RC may request manual load shedding by a DP or TOP. The DP or TOP would have the responsibility to report the action that it took if it meets or exceeds the bright-line criteria established in Attachment 1. Upon reporting, the NERC Event Analysis Program would be made aware of the impact event and start the Event Analysis Process which is outside the scope of this Standard. Several bright-line criteria were removed from Attachment 1. These criteria (DC converter station, 5 generator outages, and frequency trigger limits) were removed after discussions with the EAWG and NERC staff, who concurred that these items should be removed from a reporting standard and analysis process.

Several respondents expressed concern that the reporting requirements were redundant. The general sentiment was that unclear responsibility to report a disturbance could trigger a flood of event reports. Attachment 1 has been modified to assign clear responsibility for reporting, for each category of Impact Event.

Some commenters indicated a concern that the list of events in Attachment 1 isn't as comprehensive as the existing standard since the existing standard includes bomb threats and observations of suspicious activities. Others commented that the impact event list should include deliberate acts against infrastructure. The DSR SDT believes that “observation of suspicious activity” and “bomb threats” are addressed in Attachment 1 Part B – “Risk to BES equipment from a non-environmental physical threat”. The SDT has added the phrase, “and report of suspicious device near BES equipment” to note 3 of the “Attachment 1, Potential Reliability – Part B” for additional clarity.

**Attachment 2:** The proposed Impact Event Report (Attachment 2) generated comments regarding the duplicative nature of the form when compared to the OE-417. The DSR SDT has added language to the proposed form to clarify that NERC will accept a DOE OE-417 form in lieu of Attachment 2 if the responsible entity is required to submit an OE-417 form. In collaboration with the NERC Event Analysis Working Group (EAWG) the DSR SDT modified the attachment to eliminate confusion. This revised form will be Attachment 2 of the Standard and collects the only information required to be reported for EOP-004-2.

Further information may be requested through the Events Analysis Process (NERC Rules of Procedure), but the collection of this information is outside of the scope of EOP-004.

The DSR SDT has also clarified the form's purpose with the following addition to the form:

"This form is to be used to report impact events to the ERO."

**Other Standard Issues:**

The DSR SDT proposed that combining EOP-004 and CIP-001 would not introduce a reliability gap between the existing standards and the proposed standard and the industry comments received confirms this.

Several entities expressed their concern with the fact that Attachment 1 contained most of the elements already called for in the OE-417. The DSR SDT agrees, and Attachment 1 part 1 has been modified to even more closely mirror the Department of Energy's OE-417 Emergency Incident and Disturbance Report form. Additionally, the standard has been modified to allow for the use of the OE-417.

There was some concern expressed that there could be confusion between the reporting requirements in this standard, and those found in CIP-008. The DSR SDT agrees, and Attachment 1 Part B, has been modified to provide the process for reporting a Cyber Security Incident.

The DSR SDT also believes NERC's additional concern about what data is applicable is addressed by the revisions to Attachment 1, and the inclusion of the OE-417 as an acceptable interim vehicle.

**Implementation Plan:**

The DSR SDT asked stakeholders to provide feedback on the proposed effective date which provided entities at least a year following board approval of the standard. Most stakeholders supported the one year minimum, however based on the revisions made to the requirements, the drafting team is now proposing that this time period be shortened to between six months and nine months. The current CIP-001 plan is adequate for the new EOP-004 and training should be met in the proposed timeline. Note that the Implementation Plan was developed for the revised Requirements, which do not include an electronic "one-stop shopping" tool. The tool for "one stop shopping" will be addressed in the proposed revisions to the NERC Rules of Procedure.

**You do not have to answer all questions. Enter All Comments in Simple Text Format.**

*Insert a "check" mark in the appropriate boxes by double-clicking the gray areas.*

1. Do you agree with the revised Purpose Statement of EOP-004-2, Impact Event Reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

2. Do you agree with the proposed definition of Impact Event? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

3. Do you agree that the DSR SDT has provided an equally efficient and effective solution to the FERC Order 693 directive to "further define sabotage"? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

4. Do you agree with the proposed applicability of EOP-004-2 shown in Section 4 and Attachment 1 of the standard? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

5. Stakeholders suggested removing original Requirements 1, 7 and 8 from the standard and addressing the reliability concepts in the NERC Rules of Procedure. Do you agree with the removal of original requirements 1, 7 and 8 (which were assigned to the ERO) and the proposed language for the Rules of Procedure (Paragraph 812)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

6. Do you agree with the proposed revisions to Requirement 2 (now R1) including the use of defined terms Operating Plan, Operating Process and Operating Procedure? If not,



please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

7. Do you agree with the proposed revisions to Requirement 3 (now R2)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

8. Do you agree with the proposed revisions to Requirement 4 (now R3)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

9. Do you agree with the proposed revisions to Requirement 5 (now R4)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

10. Do you agree with the proposed revisions to Requirement 6 (now R5) and the use of either Attachment 2 or the DOE-OE-417 form for reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

11. Do you agree with the proposed revisions to Attachment 1? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

12. Do you agree with the proposed measures for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

13. Do you agree with the proposed Violation Risk Factors for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

14. Do you agree with the proposed Violation Severity Levels for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

15. Do you agree with the proposed Time Horizons for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

16. Do you agree with the proposed Implementation Plan for EOP-004-2? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

Yes

No

Comments:

17. If you have any other comments you have not already provided in response to the questions above, please provide them here.

Comments:

## Project 2009-01 Disturbance and Sabotage Reporting Implementation Plan

### Implementation Plan for EOP-004-2 - Impact Event Assessment, Analysis, and Reporting

#### Prerequisite Approvals

None

#### Revisions to Approved Standards and Definitions

Retire all requirements of EOP-004-1 and CIP-001-1.

#### Compliance with the Standard

**The following entities are responsible for being compliant with all requirements of EOP-004-2:**

- Reliability Coordinator
- Balancing Authority
- Load-serving Entity
- Interchange Authority
- Transmission Service Provider
- Transmission Owner
- Transmission Operator
- Generator Owner
- Generator Operator
- Distribution Provider

#### Effective Date

The standard shall become effective on the first calendar day of the third calendar quarter after the date of the order providing applicable regulatory approval. In those jurisdictions where no regulatory approval is required, the standard shall become effective on the first calendar day of the third calendar quarter after Board of Trustees adoption.

**A. Introduction**

- 1. Title:** **Sabotage Reporting**
- 2. Number:** CIP-001-1
- 3. Purpose:** Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.
- 4. Applicability**
  - 4.1.** Reliability Coordinators.
  - 4.2.** Balancing Authorities.
  - 4.3.** Transmission Operators.
  - 4.4.** Generator Operators.
  - 4.5.** Load Serving Entities.
- 5. Effective Date:** January 1, 2007

**B. Requirements**

- R1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- R2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- R3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- R4.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

**C. Measures**

- M1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

Regional Reliability Organizations shall be responsible for compliance monitoring.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to verify compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Reliability Coordinator, Transmission Operator, Generator Operator, Distribution Provider, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

#### **1.4. Additional Compliance Information**

None.

**2. Levels of Non-Compliance:**

**2.1. Level 1:** There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

**2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).

**2.1.2** Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).

**2.1.3** Has not established communications contacts, as specified in R4.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).

**2.4. Level 4:** Not applicable.

**E. Regional Differences**

None indicated.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Amended

## A. Introduction

1. **Title:** **Disturbance Reporting**
2. **Number:** EOP-004-1
3. **Purpose:** Disturbances or unusual occurrences that jeopardize the operation of the Bulk Electric System, or result in system equipment damage or customer interruptions, need to be studied and understood to minimize the likelihood of similar events in the future.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Regional Reliability Organizations.
5. **Effective Date:** January 1, 2007

## B. Requirements

- R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.
- R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.
- R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.
  - R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until some time after they occur shall be reported within 24 hours of being recognized.
  - R3.2. Applicable reporting forms are provided in Attachments 1-EOP-004 and 2-EOP-004.
  - R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that

time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.

- R3.4.** If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.
- R4.** When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.
- R5.** The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.

### C. Measures

- M1.** The Regional Reliability Organization shall have and provide upon request as evidence, its current regional reporting procedure that is used to facilitate preparation of preliminary and final disturbance reports. (Requirement 1)
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, the preliminary report, computer printouts, operator logs, or other equivalent evidence that will be used to confirm that it prepared and delivered the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1.
- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to confirm that it provided information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours. (Requirement 3.3)



## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

NERC shall be responsible for compliance monitoring of the Regional Reliability Organizations.

Regional Reliability Organizations shall be responsible for compliance monitoring of Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load-serving Entities.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Regional Reliability Organization shall have its current, in-force, regional reporting procedure as evidence of compliance. (Measure 1)

Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that is either involved in a Bulk Electric System disturbance or has a reportable incident shall keep data related to the incident for a year from the event or for the duration of any regional investigation, whichever is longer. (Measures 2 through 4)

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**1.4. Additional Compliance Information**

See Attachments:

- EOP-004 Disturbance Reporting Form
- Table 1 EOP-004

**2. Levels of Non-Compliance for a Regional Reliability Organization**

**2.1. Level 1:** Not applicable.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Not applicable.

**2.4. Level 4:** No current procedure to facilitate preparation of preliminary and final disturbance reports as specified in R1.

**3. Levels of Non-Compliance for a Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load- Serving Entity:**

**3.1. Level 1:** There shall be a level one non-compliance if any of the following conditions exist:

**3.1.1** Failed to prepare and deliver the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1

**3.1.2** Failed to provide disturbance information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours as specified in R3.3

**3.1.3** Failed to prepare a final report within 60 days as specified in R3.4

**3.2. Level 2:** Not applicable.

**3.3. Level 3:** Not applicable

**3.4. Level 4:** Not applicable.

**E. Regional Differences**

None identified.

**Version History**

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	May 23, 2005	Fixed reference to attachments 1-EOP-004-0 and 2-EOP-004-0, Changed chart title 1-FAC-004-0 to 1-EOP-004-0, Fixed title of Table 1 to read 1-EOP-004-0, and fixed font.	Errata
0	July 6, 2005	Fixed email in Attachment 1-EOP-004-0 from <a href="mailto:info@nerc.com">info@nerc.com</a> to <a href="mailto:esisac@nerc.com">esisac@nerc.com</a> .	Errata

0	July 26, 2005	Fixed Header on page 8 to read EOP-004-0	Errata
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised

## **Attachment 1-EOP-004 NERC Disturbance Report Form**

### **Introduction**

These disturbance reporting requirements apply to all Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load Serving Entities, and provide a common basis for all NERC disturbance reporting. The entity on whose system a reportable disturbance occurs shall notify NERC and its Regional Reliability Organization of the disturbance using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. Reports can be sent to NERC via email ([esisac@nerc.com](mailto:esisac@nerc.com)) by facsimile (609-452-9550) using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. If a disturbance is to be reported to the U.S. Department of Energy also, the responding entity may use the DOE reporting form when reporting to NERC. Note: All Emergency Incident and Disturbance Reports (Schedules 1 and 2) sent to DOE shall be simultaneously sent to NERC, preferably electronically at [esisac@nerc.com](mailto:esisac@nerc.com).

The NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports are to be made for any of the following events:

1. The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:
  - a. Modification of operating procedures.
  - b. Modification of equipment (e.g. control systems or special protection systems) to prevent reoccurrence of the event.
  - c. Identification of valuable lessons learned.
  - d. Identification of non-compliance with NERC standards or policies.
  - e. Identification of a disturbance that is beyond recognized criteria, i.e. three-phase fault with breaker failure, etc.
  - f. Frequency or voltage going below the under-frequency or under-voltage load shed points.
2. The occurrence of an interconnected system separation or system islanding or both.
3. Loss of generation by a Generator Operator, Balancing Authority, or Load-Serving Entity — 2,000 MW or more in the Eastern Interconnection or Western Interconnection and 1,000 MW or more in the ERCOT Interconnection.
4. Equipment failures/system operational actions which result in the loss of firm system demands for more than 15 minutes, as described below:
  - a. Entities with a previous year recorded peak demand of more than 3,000 MW are required to report all such losses of firm demands totaling more than 300 MW.
  - b. All other entities are required to report all such losses of firm demands totaling more than 200 MW or 50% of the total customers being supplied immediately prior to the incident, whichever is less.
5. Firm load shedding of 100 MW or more to maintain the continuity of the bulk electric system.

6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in:
  - a. Sustained voltage excursions equal to or greater than  $\pm 10\%$ , or
  - b. Major damage to power system components, or
  - c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance as defined by steps 1 through 5 above.
7. An Interconnection Reliability Operating Limit (IROL) violation as required in reliability standard TOP-007.
8. Any event that the Operating Committee requests to be submitted to Disturbance Analysis Working Group (DAWG) for review because of the nature of the disturbance and the insight and lessons the electricity supply and delivery industry could learn.

## NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report

Check here if this is an Interconnection Reliability Operating Limit (IROL) violation report.

1.	Organization filing report.		
2.	Name of person filing report.		
3.	Telephone number.		
4.	Date and time of disturbance. Date:(mm/dd/yy) Time/Zone:		
5.	Did the disturbance originate in your system?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
6.	Describe disturbance including: cause, equipment damage, critical services interrupted, system separation, key scheduled and actual flows prior to disturbance and in the case of a disturbance involving a special protection or remedial action scheme, what action is being taken to prevent recurrence.		
7.	Generation tripped.  MW Total List generation tripped		
8.	Frequency. Just prior to disturbance (Hz): Immediately after disturbance (Hz max.): Immediately after disturbance (Hz min.):		
9.	List transmission lines tripped (specify voltage level of each line).		
10.	Demand tripped (MW): Number of affected Customers:	FIRM	INTERRUPTIBLE

	Demand lost (MW-Minutes):		
11.	Restoration time.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		

## **Attachment 2-EOP-004**

### **U.S. Department of Energy Disturbance Reporting Requirements**

#### **Introduction**

The U.S. Department of Energy (DOE), under its relevant authorities, has established mandatory reporting requirements for electric emergency incidents and disturbances in the United States. DOE collects this information from the electric power industry on Form EIA-417 to meet its overall national security and Federal Energy Management Agency's Federal Response Plan (FRP) responsibilities. DOE will use the data from this form to obtain current information regarding emergency situations on U.S. electric energy supply systems. DOE's Energy Information Administration (EIA) will use the data for reporting on electric power emergency incidents and disturbances in monthly EIA reports. In addition, the data may be used to develop legislative recommendations, reports to the Congress and as a basis for DOE investigations following severe, prolonged, or repeated electric power reliability problems.

Every Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity must use this form to submit mandatory reports of electric power system incidents or disturbances to the DOE Operations Center, which operates on a 24-hour basis, seven days a week. All other entities operating electric systems have filing responsibilities to provide information to the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity when necessary for their reporting obligations and to file form EIA-417 in cases where these entities will not be involved. EIA requests that it be notified of those that plan to file jointly and of those electric entities that want to file separately.

Special reporting provisions exist for those electric utilities located within the United States, but for whom Reliability Coordinator oversight responsibilities are handled by electrical systems located across an international border. A foreign utility handling U.S. Balancing Authority responsibilities, may wish to file this information voluntarily to the DOE. Any U.S.-based utility in this international situation needs to inform DOE that these filings will come from a foreign-based electric system or file the required reports themselves.

Form EIA-417 must be submitted to the DOE Operations Center if any one of the following applies (see Table 1-EOP-004-0 — Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies):

1. Uncontrolled loss of 300 MW or more of firm system load for more than 15 minutes from a single incident.
2. Load shedding of 100 MW or more implemented under emergency operational policy.
3. System-wide voltage reductions of 3 percent or more.
4. Public appeal to reduce the use of electricity for purposes of maintaining the continuity of the electric power system.
5. Actual or suspected physical attacks that could impact electric power system adequacy or reliability; or vandalism, which target components of any security system. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.



6. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.
7. Fuel supply emergencies that could impact electric power system adequacy or reliability.
8. Loss of electric service to more than 50,000 customers for one hour or more.
9. Complete operational failure or shut-down of the transmission and/or distribution electrical system.

The initial DOE Emergency Incident and Disturbance Report (form EIA-417 – Schedule 1) shall be submitted to the DOE Operations Center within 60 minutes of the time of the system disruption. Complete information may not be available at the time of the disruption. However, provide as much information as is known or suspected at the time of the initial filing. If the incident is having a critical impact on operations, a telephone notification to the DOE Operations Center (202-586-8100) is acceptable, pending submission of the completed form EIA-417. Electronic submission via an on-line web-based form is the preferred method of notification. However, electronic submission by facsimile or email is acceptable.

An updated form EIA-417 (Schedule 1 and 2) is due within 48 hours of the event to provide complete disruption information. Electronic submission via facsimile or email is the preferred method of notification. Detailed DOE Incident and Disturbance reporting requirements can be found at: [http://www.eia.doe.gov/cneaf/electricity/page/form\\_417.html](http://www.eia.doe.gov/cneaf/electricity/page/form_417.html).

<b>Table 1-EOP-004-0</b>				
<b>Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies</b>				
<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Uncontrolled loss of Firm System Load	$\geq 300$ MW – 15 minutes or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>2</b>	Load Shedding	$\geq 100$ MW under emergency operational policy	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>3</b>	Voltage Reductions	3% or more – applied system-wide	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>4</b>	Public Appeals	Emergency conditions to reduce demand	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>5</b>	Physical sabotage, terrorism or vandalism	On physical security systems – suspected or real	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>6</b>	Cyber sabotage, terrorism or vandalism	If the attempt is believed to have or did happen	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>7</b>	Fuel supply emergencies	Fuel inventory or hydro storage levels $\leq 50\%$ of normal	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>8</b>	Loss of electric service	$\geq 50,000$ for 1 hour or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>9</b>	Complete operation failure of electrical system	If isolated or interconnected electrical systems suffer total electrical system collapse	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
All DOE EIA-417 Schedule 1 reports are to be filed within 60-minutes after the start of an incident or disturbance				
All DOE EIA-417 Schedule 2 reports are to be filed within 48-hours after the start of an incident or disturbance				

***All entities required to file a DOE EIA-417 report (Schedule 1 & 2) shall send a copy of these reports to NERC simultaneously, but no later than 24 hours after the start of the incident or disturbance.***

<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Loss of major system component	Significantly affects integrity of interconnected system operations	NERC Prelim Final report	24 hour 60 day
<b>2</b>	Interconnected system separation or system islanding	Total system shutdown Partial shutdown, separation, or islanding	NERC Prelim Final report	24 hour 60 day
<b>3</b>	Loss of generation	$\geq 2,000$ – Eastern Interconnection $\geq 2,000$ – Western Interconnection $\geq 1,000$ – ERCOT Interconnection	NERC Prelim Final report	24 hour 60 day
<b>4</b>	Loss of firm load $\geq 15$ -minutes	Entities with peak demand $\geq 3,000$ : loss $\geq 300$ MW All others $\geq 200$ MW or 50% of total demand	NERC Prelim Final report	24 hour 60 day
<b>5</b>	Firm load shedding	$\geq 100$ MW to maintain continuity of bulk system	NERC Prelim Final report	24 hour 60 day
<b>6</b>	System operation or operation actions resulting in:	<ul style="list-style-type: none"> <li>• Voltage excursions <math>\geq 10\%</math></li> <li>• Major damage to system components</li> <li>• Failure, degradation, or misoperation of SPS</li> </ul>	NERC Prelim Final report	24 hour 60 day
<b>7</b>	IROL violation	Reliability standard TOP-007.	NERC Prelim Final report	72 hour 60 day
<b>8</b>	As requested by ORS Chairman	Due to nature of disturbance & usefulness to industry (lessons learned)	NERC Prelim Final report	24 hour 60 day

All NERC Operating Security Limit and Preliminary Disturbance reports will be filed within 24 hours after the start of the incident. If an entity must file a DOE EIA-417 report on an incident, which requires a NERC Preliminary report, the Entity may use the DOE EIA-417 form for both DOE and NERC reports.

***Any entity reporting a DOE or NERC incident or disturbance has the responsibility to also notify its Regional Reliability Organization.***



NORTH AMERICAN ELECTRIC  
RELIABILITY CORPORATION

## Standards Announcement

Project 2009-01 Disturbance and Sabotage Reporting  
Formal Comment Period Open March 9 – April 8, 2011

**Now available at:** [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Formal 30-day Comment Period Open through 8 p.m. on April 8, 2011**

The Disturbance and Sabotage Reporting SDT has posted a revised draft of EOP-004-2 — Impact Event Reporting, along with the associated implementation plan and a redline of EOP-004-2 showing changes made since an informal comment period for this project concluded in October 2010. These documents are posted for a 30-day formal comment period.

The drafting team proposes to retire CIP-001-1 and incorporate its requirements into EOP-004-2. As a result, the changes to EOP-004 are so extensive that a redline showing changes against the last approved version would be impractical. For reference, the last approved versions of EOP-004 and CIP-001 have been posted.

### **Instructions**

Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the project page: [http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

### **Next Steps**

The drafting team will consider all comments and determine whether to make additional changes to the standard. The team will post its response to comments and, if changes are made to the standard and supporting documents, submit the revised documents for quality review prior to ballot.

### **Project Background**

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

## Standards Process

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
116-390 Village Blvd.  
Princeton, NJ 08540  
609.452.8060 | [www.nerc.com](http://www.nerc.com)



**Individual or group. (60 Responses)**  
**Name (39 Responses)**  
**Organization (39 Responses)**  
**Registered Ballot body segment (check all industry segments in which your company is registered) (39 Responses)**  
**Group Name (21 Responses)**  
**Lead Contact (21 Responses)**  
**Question 1 (56 Responses)**  
**Question 1 Comments (60 Responses)**  
**Question 2 (57 Responses)**  
**Question 2 Comments (60 Responses)**  
**Question 3 (55 Responses)**  
**Question 3 Comments (60 Responses)**  
**Question 4 (53 Responses)**  
**Question 4 Comments (60 Responses)**  
**Question 5 (53 Responses)**  
**Question 5 Comments (60 Responses)**  
**Question 6 (55 Responses)**  
**Question 6 Comments (60 Responses)**  
**Question 7 (54 Responses)**  
**Question 7 Comments (60 Responses)**  
**Question 8 (54 Responses)**  
**Question 8 Comments (60 Responses)**  
**Question 9 (53 Responses)**  
**Question 9 Comments (60 Responses)**  
**Question 10 (55 Responses)**  
**Question 10 Comments (60 Responses)**  
**Question 11 (57 Responses)**  
**Question 11 Comments (60 Responses)**  
**Question 12 (54 Responses)**  
**Question 12 Comments (60 Responses)**  
**Question 13 (45 Responses)**  
**Question 13 Comments (60 Responses)**  
**Question 14 (41 Responses)**  
**Question 14 Comments (60 Responses)**  
**Question 15 (42 Responses)**  
**Question 15 Comments (60 Responses)**  
**Question 16 (48 Responses)**  
**Question 16 Comments (60 Responses)**  
**Question 17 (0 Responses)**  
**Question 17 Comments (60 Responses)**

-
Group
Progress Energy
Jim Eckelkamp
No
Progress Energy appreciates the Standard Drafting Team's work on this project. "Any potential impact" is too vague and impossible to measure. Progress is unsure of how the ERO or Regional Entity measure impact. Potential is very subjective.
Yes

Yes
Yes
Yes
Yes
Do all individuals who are assigned roles and responsibilities in the Impact Event Operating Plan have to be involved with the test each time? Since there are multiple different types of Impact Events, it seems likely that only a subset of those Impact Events would be tested during an annual test, and therefore only a subset of individuals with responsibilities in the Impact Event Operating Plan would participate. For example, one test may exercise the Operating Process for properly reporting damage to a power plant that is a Critical Asset, and personnel from the Distribution Provider would not be involved in that test. Would such a scenario meet the requirement for the annual test? If so, it seems that some aspects of the Plan may never actually be required to be tested. This is ok, since R4 requires an annual review with personnel with responsibilities in the Impact Event Operating Plan. It must be made clear what is required in the annual test.
Yes
No
Progress Energy appreciates the effort of the Standard Drafting Team, but we do have some issues with the content of Attachment 1. The loss of three Transmission Elements can occur with a single transmission line outage. Progress is concerned that the possible frequency of this type of reporting could be an extreme burden. Under the column "Entity with Reporting Responsibility," why do all related entities have to report the same event? (i.e. do the RC and the TOP in the RC footprint both have to report an event, or is it either/or? The word 'Each' implies separate reports. What is the Reliability-based need for both an RC and the BA/TOP/GO within the footprint to file the same report for the same event?) For vertically integrated companies it should be clear that only one report is required per Impact Event that will cover the reporting requirements for all registered entities within that company. The "damage or destruction of BES equipment" footnote contains the language "Significantly affects the reliability margin..." The word significantly should not be used in a Standard because it is subjective. Reliability margin is also undefined. System Operators must be trained on how to comply with the Standard, and thus objective criteria must be developed for reporting. "1 hour after occurrence" places a burden on System Operators for reporting when response to and information gathering dealing with the Impact Event may still be occurring. There is a note that states that the timing guidelines may not be met "under certain conditions..." but then requires a call to both its Regional Entity and notification to NERC. The focus should be on the event response and this type of reporting should occur "within an hour or as soon as practical." It is unclear what the voltage deviations of +-10% based on (i.e. is that +-10% of nominal voltage? This may require new alarm set-points to be placed in service in Energy Management Systems in order for entities to be able to prove in an audit that they reported all occurrences of voltage exceeding the 10% limit for 15 minutes or more. It has been stated by Regional Entity audit and enforcement personnel that attestations cannot be used to "prove the positive.") The word "potential" should be removed from Attachment 1 and from the definition of Impact Event. An event is either an Impact Event or not. If an entity has to evacuate its control center facility temporarily for a small fire, or any other such minor occurrence, then it activates its EOP-008 compliant backup control center, and there is no impact to reliability, then why does there need to be a report generated? The "Forced Intrusion" category is problematic. The footnote 3 states: "Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects (sic) the reliability of the BES)." "Reasonably determine likely motivation" makes this subjective. If someone breaks into a BES substation fence to steal copper, is interrupted and leaves, then entity personnel determine someone tried to break into the substation, but cannot determine why, then this table requires a report to be filed within an hour. It is unclear what the purpose of such a report would be. Progress agrees that multiple reports in a short time across multiple entities may indicate a larger issue.
No
M3 states that "In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event..." Does this mean that, if an entity experiences an Impact Event that is reportable, then the entity does not have to perform its annual test? If so, this should be made clear in the Requirement.
No
No
Progress disagrees with the High and Severe VSLs listed for R5. If an entity experiences an Impact Event and fails to submit a report within an hour as required, it may be that there are multiple mitigating circumstances. It is not reasonable to require reporting within an hour since identifying a reportable event often takes longer than this time period.

Progress thanks the Standard Drafting Team for their efforts on this project. The BES definition is still being revised under "Project 2010-17: Proposed Definition of Bulk Electric System." "BES equipment" is mentioned several times in this Standard. A better definition of BES is important to the effectiveness of this Standard and integral to entities ability to comply with the Standard requirements. In Attachment 2, on the Impact Event Reporting form, item 10 is "Demand Tripped" and the categories include "FIRM" and "INTERRUPTIBLE." It is unclear why interruptible load is included on the reporting form.
Individual
John Bee
Exelon
1 - Transmission Owners, 5 - Electric Generators
No
Although Exelon agrees that the proposed revision to the purpose statement of EOP-004-2 is better than the original draft; the DSR SDT should consider aligning the definition with the existing OE-417 terms. "Impact Events" are not clearly defined as reportable criteria in the DOE forms and may create confusion. Suggest rewording the purpose statement to simply "Incident Reporting" to align with existing terminology in OE-417 and removing the addition of a new term. A Purpose Statement is defined as "The reliability outcome achieved through compliance with the requirements of the standard." Propose that the purpose should be, " To require a review, assessment and report of events that could have an adverse material impact on the Bulk Electric System".
No
The definition of impact events should be reworded to align with OE-417 and to explicitly reference that only events identified in EOP-004 – Attachment 1 are to be reported. Suggest the following: "An incident that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action as defined in EOP-004 Attachment 1." Propose the definition be changed to include "material" impact and read as follows; "Any event which has either caused or has the potential to cause an adverse material impact to the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action"
Yes
Exelon agrees with the DSR SDT in that the currently proposed solution effectively addresses the intent of FERC Order 693 directive to both clarify the triggering event for an entity to take action and by deleting all references to "sabotage" in effect removes the very term that had no clear definition.
No
Remove LSE. As has been determined in previous filings, FERC has ruled that asset owning DP's must be registered as LSE's. The standard as proposed is applicable to DP's. This addresses any concern with a "reliability gap" for reporting events that could have an adverse material impact to the BES. See FERC Docket RC-07-4-003, -6-003, -7-003 paragraphs 24 and 25. "The Commission approves ... revisions to the Registry Criteria to have registered distribution providers also register as the LSE for all load directly connected to their distribution facilities... The registration of the distribution provider as the LSE for all load directly connected to its distribution facilities is for the purpose of compliance with the Reliability Standards. As NERC explains, distribution providers have both the infrastructure and access to information to enable them to comply with the Reliability Standards that apply to LSEs... The Commission finds that, based on these facts, NERC acted reasonably in determining that the distribution provider is the most appropriate entity to register as the LSE for the load directly connected to its distribution facilities." Attachment 1, Part A – Energy Emergency requiring Public appeal for load reduction – In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity". As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency". Suggest revising back to specific entities that would be likely responsible for this action (e.g., RC, BA, TOP). Attachment 1, Part A – Energy Emergency requiring system-wide voltage reduction – In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity". As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency" related to system-wide voltage reduction. Suggest revising back to specific entities that would be likely responsible for this action. Attachment 1, Part A – Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 continuous minutes, this should be a TOP RC function only. Attachment 1, Part A – Loss of off-site power (grid supply) affecting a nuclear generating station – this event applicability should be removed in its entirety for a Nuclear Plant Generator Operator. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design, if it is a partial loss of off-site power (per the plant specific NPIRs) and may not result in a loss of generation (i.e., unit trip). If a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a Nuclear Plant Generator Operator during a potential transient on the unit. In addition, if the loss of off-site power were to result in a unit trip, if the impact to the BES were ≥2,000 MW, then required notifications would be made



in accordance with the threshold for reporting for Attachment 1, Part A – Generation Loss. However, to align with the importance of ensuring nuclear plant safe operation and shutdown as implemented in NERC Standard NUC-001, if a transmission entity experiences an event that causes an unplanned loss of off-site power (source) as defined in the applicable Nuclear Plant Interface Requirements, then the responsible transmission entity should report the event within 24 hours after occurrence. In addition, replace the words "grid supply" to "source" to ensure that notification occurs on an unplanned loss of one or multiple sources to a nuclear power plant. Suggest rewording as follows (including replacing the words "grid supply" to "source" and adding in the word "unplanned" to eliminate unnecessary reporting of planned maintenance activities in the table below): Event Entity with Reporting Responsibility Threshold for Reporting Time to Submit Report Unplanned loss of off-site power to a Nuclear generating plant (source) as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) Each transmission entity responsible for providing services related to NPIRs (e.g., RC, BA, TO, TOP, TO, GO, GOP) that experiences the event causing an unplanned loss of off-site power (source) Unplanned loss of off-site power (source) to a Nuclear Power Plant as defined in the applicable NPIRs. Within 24 hours after occurrence

Yes

No

• R.1 Does an entity need to develop a stand alone Operating Plan if there is an existing process to address identification, assessing and reporting certain events? Suggest rewording to state "Each Responsible Entity shall have an Impact Event Operating Plan or equivalent implementing process that includes:" Disagree these new terms are required. Commonly accepted descriptions of programs, processes and procedures exist in registrar entities that would suffice. For example, R1 could use "Impact Event evaluation and reporting process" as a generic term to describe what is required. This would allow an entity to utilize any existing protocols or management guidelines and naming conventions in effect in their organization.

No

Agree that each Responsible Entity shall implement the [Impact] Events listed in Attachment 1 (Parts A and B); however, disagree with certain events, reporting responsibilities, threshold for reporting and time to submit reports as currently outlined in Attachment 1 (Parts A and B). Also suggest that R.2 be reworded to state for applicable [Impact] Events listed in Attachment 1 (Parts A and B). This requirement should only be applied to those events applicable to the registered entity. R2 is redundant to R1. No entity could claim to have met R1 if their plan / process was not operational and approved in the manner consistent with any other approved program, process, guideline etc. within their company.

No

• Each entity should be able to determine if they need a drill for a particular event. Is this document implying that the annual drill covering all applicable [Impact] Events? • A provision should be added to be able to take credit for an existing drill/exercise that could incorporate the required communications to meet the intent of R.3 to alleviate the burden on conducting a stand alone annual drill. The DSR SDT needs to provide more guidance on the objectives and format of the drill expected (e.g., table top, simulator, mock drill). • A provision should be added to R.3 to allow for an actual event to be used as credit for the annual requirement. It would seem that the intent is as such based on the wording in M.3; however, it needs to be explicit in the Requirement. • Must a test include communicating to NERC or the Region?

No

• Need more guidance on what personnel are expected to participate in the annual review. Training for all participants in a plan should not be required. Many organizations have dozens if not hundreds of procedures that a particular individual must use in the performance of various tasks and roles. Checking a box that states someone read a procedure does not add any value. This is an administrative burden with no contribution to reliability. • If the intention is that internal personnel who have responsibilities related to the Operating Plan cannot assume the responsibilities unless they have completed training. This requirement places an unnecessary burden on the registered entities to track and maintain a database of all personnel trained and should not be a requirement for job function. A current procedure and/or operating plan that addresses each threshold for reporting should provide adequate assurance that the notifications will be made per an individual's core job responsibilities.

No

Agree that each Responsible Entity should be able to use either Attachment 2 or the DOE OE-417 form for reporting; however, a GO/GOP will not have the ability to respond to Attachment 2 Task numbers 8, 9, 10, 11, and 12. Suggest that the DSR SDT either evaluate a shortened form version, provide a note or provision for "N/A" based on registration, or revise form to be submitted by the most knowledgeable functional entity (e.g., TOP or RC). Need clear guidance as to which form is to be used for which Impact Event, we feel that one and only one form should be used to eliminate confusion. Attachment 2 has an asterisk on #s 7, 8, 9, 10 and 11 there is no reference corresponding to it.

No

Attachment 1, Part A – Energy Emergency requiring Public appeal for load reduction – In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity". As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency". Suggest revising back to specific entities that would be likely responsible for this action (e.g., RC, BA, TOP). Attachment 1, Part

A – Energy Emergency requiring system-wide voltage reduction – In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity". As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency" related to system-wide voltage reduction. Suggest revising back to specific entities that would be likely responsible for this action. Attachment 1, Part A – Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 continuous minutes, this should be a TOP RC function only. Attachment 1, Part A – Generation Loss of ≥ 2, 000 MW for a GOP does not provide a time threshold. If the 2, 000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? Suggest that a time threshold be added for clarity. Attachment 1, Part A – Loss of off-site power (grid supply) affecting a nuclear generating station – this event applicability should be removed in its entirety for a Nuclear Plant Generator Operator. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design, if it is a partial loss of off-site power (per the plant specific NPIRs) and may not result in a loss of generation (i.e., unit trip). If a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a Nuclear Plant Generator Operator during a potential transient on the unit. In addition, if the loss of off-site power were to result in a unit trip, if the impact to the BES were ≥2,000 MW, then required notifications would be made in accordance with the threshold for reporting for Attachment 1, Part A – Generation Loss. However, to align with the importance of ensuring nuclear plant safe operation and shutdown as implemented in NERC Standard NUC-001, if a transmission entity experiences an event that causes an unplanned loss of off-site power (source) as defined in the applicable Nuclear Plant Interface Requirements, then the responsible transmission entity should report the event within 24 hours after occurrence. In addition, replace the words "grid supply" to "source" to ensure that notification occurs on an unplanned loss of one or multiple sources to a nuclear power plant. Suggest rewording as follows (including replacing the words "grid supply" to "source" and adding in the word "unplanned" to eliminate unnecessary reporting of planned maintenance activities in the table below): Event Entity with Reporting Responsibility Threshold for Reporting Time to Submit Report Unplanned loss of off-site power to a Nuclear generating plant (source) as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) Each transmission entity responsible for providing services related to NPIRs (e.g., RC, BA, TO, TOP, TO, GO, GOP) that experiences the event causing an unplanned loss of off-site power (source) Unplanned loss of off-site power (source) to a Nuclear Power Plant as defined in the applicable NPIRs. Within 24 hours after occurrence Attachment 1, Part A – Damage or destruction of BES equipment • The event criteria is still ambiguous and does not provide clear guidance; specifically, the determination of the aggregate impact of damage may not be immediately understood – it does not seem reasonable to expect that the 1 hour report time clock starts on identification of an occurrence. Suggest that the 1 hour report time clock begins following confirmation of event. • The initiating event needs to explicitly state that it is a physical and not cyber. • If the damage or destruction is related to a deliberate act, consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event (see additional comments in response to item 17 below). Attachment 1, Part A – Damage or destruction of Critical Cyber Asset The events that are associated with Critical Cyber Assets should be removed from this Standard. Critical Cyber Asset related events are better addressed in the reporting of Cyber Security Incidents which is already included in Attachment 1, Part B and the CIP standards currently require details about Critical Cyber Assets to be protected with access to that information restricted to only specifically authorized personnel. Attachment 1, Part A – Damage or destruction of Critical Asset The events that are associated with Critical Assets should be removed from this Standard. Critical Assets are typically whole control centers, substations or generation plants and the damage or destruction of individual pieces of equipment at one of these locations will usually not have much impact to the BES. Any important impacts located at these sites are already addressed in the other existing [Impact] Event types or would be addressed in the Cyber Security Incident event which is already included in Attachment 1, Part B. The CIP standards also currently require that details about Critical Assets and Critical Cyber Assets must be protected with access to that information restricted to only specifically authorized personnel. The identification of Critical Asset is also only an interim step used to identify the Critical Cyber Assets that need to have cyber security protections and the NERC Project 2008-06 CSO706 Standards Drafting Team is currently expecting to eliminate the requirement to identify Critical Assets in the draft revisions they are currently working on. Attachment 1, Part B – Forced intrusion at a BES facility – Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event (see additional comments in response to item 17 below). Attachment 1, Part B – Risk to BES equipment from a non-environmental physical threat – this event leaves the interpretation of what constitutes a "risk" with the reporting entity. Although the DSR SDT has provided some examples, there needs to be more specific criteria for this event as this threshold still remains ambiguous and will lead to difficulty in determining within 1 hour if a report is necessary. Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event (see additional comments in response to item 17 below). Attachment 1, Part B – Detection of a reportable Cyber Security Incident Although the DSR SDT agreed that there may be confusion between reporting requirements in this draft and the current CIP-008, "Cyber Security – Incident Reporting and Response Planning", Part B now requires a 1 hour report after occurrence. The DSR SDT should verify the timing and reporting required for these Cyber Security Incident events is coordinated with the NERC Project 2008-06 CSO706 Standards Drafting Team.

No
<ul style="list-style-type: none"> <li>• M1 - Suggest rewording to state "Each Responsible Entity shall provide the current revision of the Impact Event Operating Plan or equivalent implementing process"</li> <li>• M3 – Need to provide more guidance on evidence of compliance to meet R.3 The DSR SDT needs to provide more guidance on the objectives and format of the drill expected (e.g., table top, simulator, mock drill) and what evidence will be required to illustrate compliance.</li> <li>• M5 - Suggest that the DSR SDT provide a note or provision to allow for the DOE OE-417 reporting form be submitted by the most knowledgeable functional entity (e.g., the TOP or RC) experiencing the event.</li> </ul>
No
R.4 should be a low risk factor, this is an administrative requirement with no contribution to reliability.
No
Suggest rewording the 1 hour reporting for High and Severe to state "communicate or submit" a report within ... depending on the severity of the event, an actual report may not be feasible. Similar to an NRC event report, a provision should be made for verbal notifications in lieu of an actual submitted report. An entity should not be penalized for failing to submit a written report within 1 hour if the communications were completed within the 1 hour time period meeting the intent of the Standard.
No
The DSR SDT reduced the implementation from one year to between six and nine months based on the revised standard requirements. Exelon disagrees with the proposed shortened implementation timeframe. The current revision to EOP-004 still requires an entity to generate, implement and provide any necessary training for the "Impact Event Operating Plan" by a registered entity. Commenters previously supported a one year minimum; but the requirements for implementation have not changed measurably - six to nine months is not adequate to implement as written.
The DSR SDT makes reference to comments that were previously provided that suggested adopting the NRC definition of "sabotage." Respectfully, this commenter believes the DSR SDT did not understand the intent of the original comment. The comment made by Exelon in the October 15, 2009 submittal was to ensure that the DSR SDT made an effort to include the Nuclear Regulatory Commission (NRC) as a key Stakeholder in the Reporting Process and to consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator. Depending on the event, a nuclear generator operator (NRC licensee) also has specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72, "Immediate notification requirements for operating nuclear power reactors," paragraph (b)(2)(xi). The one hour notification requirement for an intrusion event would also meet an emergency event classification at a nuclear power plant. If an operations crew is responsible for the one hour notification and if separate notifications must be completed within the Emergency Plan event response, then an evaluation in accordance with 10 CFR 50.54, "Conditions of licensees," paragraph (q), would need to be performed to ensure that this notification requirement would not impact the ability to implement the Emergency Plan. At a minimum the DSR SDT should communicate this project to the NRC to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. Note that existing reporting/communication requirements are already established with the FBI, DHS, NORAD, FAA, State Police, LLEA and the NRC depending on the event. There are existing nuclear plant specific memorandums of understanding between the NRC and the FBI and each nuclear generating site licensee must have a NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan. The proposed "Reporting Hierarchy for Impact Event EOP-004-2," needs to be communicated and coordinated with the NRC to ensure that the flow chart does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans. Propose allowing for verbal reporting via telephone, for 1 hr. reporting with a follow up using the forms. With the revised standard EOP-004-2 it eliminates the #8; loss of electric service >= 50K, however, that requirement is still required for the DOE-OE-417 form. The question is do we still have to send it to NERC / Region if NERC/ Region does not specifically still have that as a requirement? Also, with that requirement, on the current EOP-004-1 it says that schedule 1 has to be filled out within 1 hour? This does not coincide with DOE-OE-417 form. The bottom line, it looks like there is inconsistency as to what is reportable per EOP-004-2 and DOE-OE-417 form, some of the items are redundant, some are not, but better guidance is needed as to which form to use when. The SDT should have a Webinar with the industry to create an understanding as to who is responsible to report what and at what time.
Individual
Jennifer Wright
SDG&E
1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators
No
SDG&E does not agree with the revised Purpose Statement because it does not reflect the standard's purpose of identifying reporting requirements for impact events. SDG&E recommends the following revised Purpose Statement: "To identify the reporting requirements for events considered to have an impact on the reliability of the Bulk Electric System and to allow an awareness of these Impact Events to be understood by the industry in recognizing potential

enhancements that may be made to the reliability of the BES.”
Yes
Yes
No
SDG&E recommends that “Load Serving Entity,” “Transmission Service Provider,” and “Interchange Authority” be removed from the proposed applicability shown in Section 4. These entities do not own assets that could have an impact on the Bulk Electric System. Additionally, none of these entities is listed as an “Entity with Reporting Responsibility” in Attachment 1. Finally, “Transmission Service Provider” is covered by either “Transmission Owner” or “Balancing Authority,” which are entities also listed in the proposed Applicability section, and “Load Service Entity” and “Interchange Authority” are covered by “Balancing Authority.”
No
SDG&E agrees with removing original Requirements 1, 7, 8 from the standard. In addition, SDG&E recommends that the standard reference Section 812 of the Rules of Procedure.
Yes
Yes
Yes
Yes
Yes
No
For “Detection of a reportable Cyber Security Incident,” Attachment 1 identifies the threshold for reporting as: “that meets the criteria in CIP-008 (or its successor)”; however, CIP-008 has no specified criteria, so this is an unusable threshold. Additionally, SDG&E recommends that the timing of any follow-up and/or final reports required by the standard be listed in the Attachment 1 table.
Yes
Yes
No
This Reliability Standard provides a list of reporting requirements that are applicable to registered entities, thus it is a paperwork exercise; therefore, SDG&E recommends that none of the requirements should exceed a “Moderate” Violation Severity Level. Failure on the part of an applicable Registered Entity to provide an event report will have no immediate impact on the Bulk Electric System.
No
SDG&E recommends a 9 month minimum timeframe for implementation.
Individual
Alan Gale
City of Tallahassee (TAL)
3 - Load-serving Entities, 5 - Electric Generators
Yes
No
While I agree with the overall concept, I am concerned with “or has the potential to impact”. While the standard makes reference to Attachment 1 Parts A and B, the inclusion of the attachment is not in the definition. This leaves ambiguity in the definition that could enable second guessing by auditors. Proposed: “An impact event is any event that has either impacted or has the potential to impact (above the thresholds described in EOP-004-2 Attachment 1) the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”

Yes
Yes
Yes
Yes
Yes
No
Comments: The verbiage "at least annually, with no more than 15 months between such tests" is an attempt to define annually. If you want every 15 months say "at least every 15 months". Otherwise just say annual and let the entities decide what that is, as is being done with other "annual" requirements. Additionally, while the Measure (M3) implies that an actual event would suffice it is not stated in the requirement, and the entire plan should be tested, not just a component. Proposed: Each Responsible Entity shall conduct a test of its Impact Event Operating Plan at least annually. A test of the Impact Event Operating Plan can range from a paper drill, to the response to an actual event.
No
The verbiage "at least annually, with no more than 15 months between review sessions" is an attempt to define annually. If you want every 15 months say "at least every 15 months". Otherwise just say annual and let the entities decide what that is, as is being done with other "annual" requirements.
Yes
No
One hour should be expanded. While I realize the importance of getting information to NERC/ESISAC/whoever, most of the 1-hour requirements are tied to events that may not be resolved within one hour. This will result in stopping restoration efforts or monitoring to submit paperwork. Calling in additional assistance, while certainly a possibility, may not be feasible to accomplish in sufficient time to meet the one-hour deadline. If any of these events were to truly have a detrimental effect on the BES, the effects would have already been felt. Recommend all 1-hour reports be extended to 4-hours. This should also be placed on the list to modify the OE-417 report time lines.
No
M3 & M4 should be modified if comments above (#8 and #9) are incorporated. M4 - Providing the "materials presented" is beyond the scope of compliance. This constitutes a review of the training program which is beyond the scope of the standard. Review of attendance sheets should be sufficient. The personnel will be listed in the Plan/Process/Procedure. Modify M4: Responsible Entities shall provide evidence of those who participated in the review, showing who was present and when internal personnel were trained on their responsibilities in the plan.
No
R1 is administrative in nature (must have a document) and should be Lower.
Yes
Yes
Yes
Attachment 2 (Impact Event Reporting Form) items 8, 9, 10, and 11 have an asterisk but no identification as to what the asterisks refer to.
Individual
Mace Hunter
Lakeland Electric
1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators
Yes
Yes
Yes



Yes
Yes
Yes
Group
PJM Interconnection LLC
Srinivas Kappagantula
Yes
No
The term "Impact Event" has been too broadly defined. According to the current definition, any event (including routine operations) can have the potential to impact the reliability of the Bulk Electric System and hence can be an Impact Event. The definition should only include unplanned events. Attachment 1 lists the events that are reportable. It seems that the definition of Impact Event refers to the events in Attachment 1 as opposed to defining "Impact Event". As such, it is best that the SDT not define "Impact Event" but use words to the effect that requires an entity to have a plan and implement it for reporting unplanned events outlined in Attachment 1. If "Impact Event" were to be defined, we suggest the following definition would be a better option: "An Impact Event is any unplanned event listed in Attachment I that has either adversely impacted or has the potential to adversely impact the reliability of the Bulk Electric System."
Yes
Yes
1. We agree that the entities listed should be responsible for ensuring events are reported, provided they own BES assets, but more guidance should be provided on which entity in Attachment 1 should actually file the report to avoid multiple entities reporting a single event. Current Attachment 1 results in significant duplicate reporting. 2. Although the applicable entities listed in Section 4 capture all entities that are assigned a reporting responsibility in Attachment 1, some events in Attachment 1 refer to entities applicable under a different standard (e.g CIP-002) as the responsible entities for reporting. This results in IA, TSP, and LSE (none of which, generally own Critical Assets and hence not likely own CCAs) as being responsible for reporting an event. We urge the SDT review the need to include IA, TSP, and LSE in applicable entities. Also, why is NERC an applicable entity in CIP-002-3 but not in this standard?
No
We agree that the standard should not have requirements applicable to the ERO, but disagree with revising the NERC Rules of Procedure (RoP) to include suggested Section 812. The reporting responsibility should not be solely given to NERC. Other learning organizations must also be considered for performing this responsibility. Additionally, the proposed wording of Section 812 appears to imply that NERC will notify the appropriate law enforcement agencies as opposed to the local responsible entity.
No
1. This is an "after-the-fact" reporting requirement and should not be confused with Operating Plans that have specific operating actions and goals. Each entity should prepare its own impact event operating guideline that addresses impact events, identification of impact events, information gathering, and communication without specifying a specific format such as Operating Plans, Operating Process, and Operating Procedures. In fact, all three documents mentioned can all be a single document. 2. 1.3.2 requires notification of law enforcement agencies for all events listed in Attachment 1. This is essentially not true. For example, firm load is shed requires notification to law enforcement but an IROL violation, generation loss, or voltage deviation do not.
No
We agree with the concept but disagree with the use of the term "Operating Plan" as a defined term in line with our comments in Question 6 above.
No
1. This is an "after-the-fact" reporting requirement (administrative in nature). Annual testing of such a requirement does not add to the reliability of the BES. 2. R3 attempts to define "Annual" for the Registered Entity to test its Operating Process. We believe R3 should follow the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) – CAN-0010 – Definition of Annual as opposed to creating a new definition of Annual – or – refer to an entity's defined use of the term annual.
Yes
1. We agree with the concept but disagree with the use of the term "Operating Plan" as a defined term in line with our comments to Question 6 above. 3. R4 attempts to define "Annual" for the Registered Entity to review its Impact

Operating Plan. We believe R4 should follow the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) – CAN-0010 – Definition of Annual as opposed to creating a new definition of Annual – or – refer to an entity’s defined use of the term annual.
No
R5 seems redundant as R2 already requires an entity to report any Impact Events by executing/implementing its Impact Event Operating Plan. R5 merely stipulates the use of Attachment 2 or DOE-417, which an entity automatically would use for reporting purposes while implementing its Impact Event Operating Plan.
No
There is still a significant amount of duplicate reporting involved in Attachment 1, which needs to be cleared. See comments to Question 4.
No
1. We disagree with M4 as it seems to indicate that all training needs to be in person and precludes any form of Computer Based Training (CBT). 2. As indicated in 10, R5 is redundant as R2 already required an entity to report any Impact Events by executing/implementing its Impact Event Operating plan. If R5 is to remain as is, then M5 goes beyond the requirement by requiring the entity to produce evidence of compliance for the type of Impact Event experienced. It is not clear as to what additional evidence is needed to “support the type of Impact Event experienced”.
No
All VRFs should be lower as Requirements 1-5 are all administrative in nature. A violation of any of these requirements does not directly or indirectly affect the reliability of the BES.
No
VSLs should reflect the comments on the VRFs above.
No
R2 and R5 should be in Operations Assessment Time Horizon as they deal with “after-the-fact” reporting.
Yes
In the Compliance Enforcement Authority Section on Page 11, the second bullet says “If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement”. We are not sure what this exactly implies or means. Additional clarification is required.
Individual
Brian Pillittere
Tenaska
5 - Electric Generators
No
We already have adequate procedures in place to address sabotage and other significant events, pursuant to the existing CIP-001-1 and EOP-004-1 Standards. The requirement to develop a new Impact Event Operating Plan would increase the administrative burden on Registered Entities to comply with the proposed Standard, without providing a foreseeable improvement in system reliability. The “laundry list” of required Impact Event Operating Plan components is too specific and would make it more difficult to prove compliance with EOP-004-2 during an audit. A revised version of the proposed R5 is the only Requirement that is necessary to achieve the stated purpose of Project 2009-01.
No
The proposed Impact Event Operating Plan should not be required.
No
The proposed Impact Event Operating Plan should not be required, therefore any tests of the Operating Process should not be required.
No
The proposed Impact Event Operating Plan should not be required.
No
R5 should be changed to “Each Responsible Entity shall report Impact Events listed in Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form”. This revised version of the proposed R5 is the only Requirement that is necessary to achieve the stated purpose of Project 2009-01. The proposed R1 through R4 should be deleted and R5 should be changed to R1.



No

The proposed R1 through R4 should be deleted and a revised version of R5 should become R1. The proposed measures for the new R1 should be revised accordingly.

Individual

Michael Johnson

APX Power Markets

8 - Small End Users

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

The reporting of Impact Events needs to be clear spelled out and if moving some of that to State Agencies it needs to be consistent in all States at the same time and which State it should be reported to. We have a 24-hour Desk in one state that handles facilites in many other States. If there is an Impact Event that needs to be reported, where is that report sent to. The State the facility resides in or the State where our 24-hour Desk resides in.

Individual

Jonathan Appelbaum

United Illuminating Co

1 - Transmission Owners

No

UI agrees with the idea but believes the statement can be improved to remove ambiguities. For example: "if known" can be modifying the word causes, or the word Impact events. To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of identified Impact Events and if known their causes, if known, by the Responsible Entities.
Yes
Yes
No
Will an entity be required to develop an Operating Process for every Impact Event in Attachment 1, or only those events that apply to its Registration. For example, does a DP require evidence of an Operating Process/Procedure for Voltage Deviations on a BES Facility? Some items in Attachment 1 state "Each RC, BA, TOP, DP that experiences the Impact Event" (such as Loss of Firm Load). DP's may have arranged with TOP and RC to communicate the event to TOP who then will file the NERC report and OE-417. The requirements in the Standard would allow for this as long as the Operating Plan documents it. Attachment 1 though can be interpreted that this arrangement would not be allowed and each entity shall file its own and separate report. UI suggests that Attachment 1 be modified to allow for an Entities Operating Plan to rely on another Entity making the final communication to NERC. "Each RC, BA, TOP, DP that experiences the Impact Event, either individually or combined on a single filing"
Yes
No
Does R1.1 require an Operating Process for each Impact Event in attachment 1 or an Operating Process that in general applies to all Impact Events?
Yes
Yes
: FERC did state in Order 693 that the reporting procedure requires testing. UI is concerned that the scope of the requirement is unspecified. Does the exercise require only one type of Impact Event to be exercised per period, or is an entity required to simulate each Impact Event and notification
Yes
As written it is a training burden. Certain persons will have only one step in one operating procedure to perform. There is no necessity to review the entire Operating Plan with them. For example, Field Personnel need to know that if they see something not right to report it immediately. In this instance there is no benefit to review the Operating Procedure/Process for firm load shedding with them.
Yes
Put "its" before Impact Event Operating Plan.
No
R3 should be Low. It is a test of the communication Plan which is use of telephone and email.
Yes
Yes
No
The SDT should be specific that on the effective date an Entity will have the Operating documented and approved. The SDT should be specific that the first simulation is required to occur 15 months following the effective date. The SDT should be specific that the first annual review shall occur with in 15 months after the effective date.
Group
Georgia Transmission Corporation & Oglethorpe Power Corporation
David Revill
Yes
We find it unnecessary to state that the purpose of a Reliability Standard is to "improve...the reliability of the Bulk Electric System."
No
We do not think that Impact Event should be defined using a recursive definition. i.e. that the word "impact" should be

used in the definition of the term "Impact Event." Instead, we suggest using an enumerative definition in that the tables included in Attachment 1 are themselves used to define "Impact Event." If this definition is not acceptable, we suggest replacing the word "impact" in the definition with the word reduce, reduced, or ...potential to reduce the reliability of the BES.

Yes

We agree with the approach taken by the SDT.

No

We do not believe that GO, TO, TSP, DP, or LSE should be included in the applicability of this standard. It is our opinion that the reporting requirements lie primarily with the applicable operator and should be limited as such. We recommend modifications as discussed in our response to question 6 to clearly define what types of events each Responsible Entity needs to prepare for. Currently, it seems that multiple entities are being required to report the same event for some events where only one entity should have a reporting responsibility. However, NERC should not decide which one entity should report a given event. The entities should have the flexibility to create a process which allows for coordination and communication at a local level and to work out with neighboring entities who might ultimately report events to the applicable organizations.

No

The terms "Operating Procedure, Operating Plan, and Operating Process," while included in the NERC glossary, are not consistently used throughout the body of NERC standards as they are used in R1 of EOP-004-2. As such, we do not see a reliability benefit in using the defined terms over the more commonly used terms of simply "plans, processes, and procedures." In part 1.1 of R1, we think that the requirement should clearly indicate that a particular Responsible Entity's Impact Event Plan should only be required to include those particular Impact Events for which the Responsible Entity has the reporting obligation. Therefore, we suggest the following modification to R1: "1.1 An Operating Process for identifying Impact Events listed in Attachment 1 for those Impact Events where the Responsible Entity is identified as having the reporting responsibility." Additionally, in part 1.3 of R1, we believe the language to be vague and will introduce the need for further clarification either through an interpretation or the CAN process in part because the verb tenses of the sub-sub-requirements do not agree and it appears to require notification to all listed parties for every Impact Event instead of only those that make sense for a particular event. As such, we suggest adding a column to the tables in Attachment 1 that identifies precisely which organizations should be notified in the case of a particular Impact Event and modifying part 1.3.2 to read: "1.3.2 External organizations to notify as specified in Attachment 1." Currently, as written, the standard could be interpreted to require notification to law enforcement for an IROL violation, for instance. Furthermore, we are concerned that as written, the standard may require that the same event must be reported by multiple responsible entities. Our current process uses notification between Responsible Entities (i.e. from a TO to a TOP and then from the TOP to NERC) to allow for a centralized and coordinated notification to law enforcement, NERC, etc. We are concerned that the requirement as written does not appear to allow this flexibility and may require both the TO and TOP to report the same event in order to prove compliance with the Standard.

No

We are concerned with having a separate requirement to implement the Plan. Is this requirement necessary on its own? Should R1 instead require a Responsible Entity to "document and implement" an Impact Event Operating Plan? More specifically, if an Entity does not have an Impact Event, are they in violation of this requirement? If merging this requirement with R1 is not acceptable we suggest moving the language from the measure to the requirement as such: "To the extent that a Responsible Entity has an Impact Event on its Facilities, Each Responsible Entity shall implement..." Additionally, R1 uses the phrase "recognized Impact Event" where as R2 simply uses the term "Impact Event." The phrase "recognized Impact Event" should be used consistently in R2 as well.

No

With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between tests" is necessary. If instead the team believes that, in order to support the reliability of the BES, tests should be performed at least every 15 months, then the requirement should be to perform a test at least every 15 calendar months and remove the annual component.

No

We do not believe that the requirement should specify that the plan must be reviewed with those personnel who have responsibilities identified in that plan as there is no requirement in R1 that the plan must identify any specific personnel responsibilities. Additionally, we seek clarification on whether review in this instance means train as indicated in the measure.

No

As stated above in response to question 6, we believe that a column should be added to the tables to explicitly indicate what external organizations should receive the communications of a particular Impact Event type. Additionally we have concerns with the following table items: Threshold for reporting Transmission Loss: As stated, this will require the reporting of almost all transmission outages. This is particularly true taking into consideration the current work of the drafting team to define the Bulk Electric System. The loss of a single 115kV network line could meet the threshold for

reporting as the definition of Element includes both the line itself and the circuit breakers. Instead, we recommend the following threshold "Three or more BES Transmission lines." This threshold has consistency with CIP-002-4 and draft PRC-002-2. This threshold also needs additional clarification as to the timeframe involved. Is the intent the reporting of the loss of 3 or more BES Transmission Elements anytime within a 24 hour period or must they be lost simultaneously? Also, we recommend that these three losses be the result of a related event to require reporting. Entity with Reporting Responsibility for Loss of Off-site power to a nuclear generating plant (grid supply): The reporting responsibility should clarify that this is only entities included in the Nuclear Plan Interface Requirements.
No
Several of the measures appear to introduce items that are not required by the standard. For instance, R3 requires that a test of the communications process be performed, however Measure 3 indicates that a mock impact event be performed. Measure 4 indicates that personnel be listed in the plan and be trained on the plan, however there is no requirement to include people in the plan or to train them.
In the discussion and related flowchart described as "A Reporting Process Solution - EOP-004," the discussion suggests that Industry should notify the state law enforcement agency and then allow the state agency to coordinate with local law enforcement. It has been our experience that we receive very good response from local law enforcement and they have existing processes to notify state or federal agencies as necessary. It appears the recommendation is to bypass the local law enforcement, but it is not clear that representatives from state or local law enforcement were included in this discussion (see proposal discussed with "FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair"). It would be helpful to see some additional clarification to understand why the state agency was chosen over local or federal agencies. Finally, we would like to express our gratitude to the DSR SDT for their hard work in making improvements to the NERC standards for event reporting.
Group
Northeast Power Coordinating Council
Guy Zito
Yes
No
Is there a need for this definition? By itself the term is not specific on the types of events that are regarded as having an "impact". The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. The events that are to be reported can be called anything. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not used anywhere else in the NERC Reliability Standards. For a complete definition of Impact Event, all the elements in Attachment A must be a part of it. Suggest consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A.
Yes
It is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
No
Disagree with the following inclusion/exclusion of several entities: a. The applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. NERC should be included in the Applicability Section as it is an applicable entity identified in CIP-002-3. b. If the above approach was not strictly followed, then suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.
Yes
Agree with the proposed removal, but have not assessed the proposed language for RoP para. 812 because unable to access it (not on the RoP page).
Yes
Yes
No
The annual testing requirement is too frequent for a reporting, and not an operational process. The testing interval

should be extended to five years.
Yes
No
R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the "how" part, not the "what". The vehicle for reporting can easily be included in R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event. Suggest combining R2 with R5.
No
As indicated under Question 4, we question the need to include IA, TSP and LSE in the responsible entities for reporting.
No
Concerns with M5: a. As suggested in the response to Question 10 above, R5 should be combined with R2; b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to "support the type of Impact Event experienced". Also, the date and time of the Impact Event is provided in the reporting form. Why the need to provide additional evidence on the date and time of the Impact Event?
No
If R5 is to remain as is, then the VRF should be a Lower, not a Medium. R5 stipulates the form to be used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form does not lead to unreliability.
No
No major issues with the proposed VSLs. However, because of the preceding comments, want to see the next revision of the draft.
No
For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. Consistent with other plans such as system restoration plans which need to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. Suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning.
Yes
Individual
Kevin Koloini
American Municipal Power
3 - Load-serving Entities, 4 - Transmission-dependent Utilities, 5 - Electric Generators
Yes
The purpose is acceptable. I think it could be improved and simplified. There were not any questions on the title. Consider changing the title to Reportable Events. There were not any questions on the category. I suggest changing the category from Emergency Operations to Communications. Reporting events can trigger and be more than just Emergency Operations. I feel the reporting function performed by entities should be under the Communications category. Title: Reportable Events Purpose: To improve reliability by communicating timely information about an event or events.
Yes
The definition of Impact Event is acceptable and an improvement. I feel it could be improved and simplified further. Consider changing Impact Event to a "reportable event".
Yes
Well done.
No
No, I do not agree. The DP and LSE functions should be removed.
Yes
A software solution may provide an easy expansion for reporting EOP-004, CIP-001, and additional standards.
No
No, remove R1. R1 is not an acceptable requirement nor should this be an operation. Focusing on a plan and procedure is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.

No
No, remove R2. R2 is not an acceptable requirement nor should this be an operation. Focusing on a plan is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
No
No, remove R3. R3 is not an acceptable requirement nor should this be an operation. Focusing on a test is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
No
No, remove R4. R4 is not an acceptable requirement nor should this be an operation. Focusing on a plan and personnel tracking is overly prescriptive. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
No
R5 is not an acceptable requirement, but it can be improved. Each Responsible Entity shall report "Impact Events" to _____ (address specified in attachment 1, website, entity, email address, or fax, etc.) Focusing on a plan and procedure is overly prescriptive. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
Yes
No
M1-M4 should be eliminated and M5 should be revised to incorporate a simplified R5. M5 - Date and time of submitted report
No
No, this is not acceptable. Eliminate R1-R4. Change R5 to Lower.
No, this is not acceptable. Eliminate R1-R4 and change R5. Severe: n/a High VSL: n/a Medium VSL: No report for a reportable event Low VSL: Late report for a reportable event
No
Yes
Individual
Daniel Duff
Liberty Electric Power LLC
5 - Electric Generators
Yes
Yes
I am interpreting the phrase "has the potential" to exclude events which had the potential, but did not impact the BES. An example would be a generation trip - if the trip had happened during a system emergency it could have affected the BES, but since it happened under normal conditions there is no reporting responsibility. Some assurance on this interpretation would be appreciated.
Yes
Yes
Yes
Yes
Yes
No
It is not the proper role of the standards to dictate how an entity conducts training. Large utilities with backup control rooms and enough personnel can conduct routine drills without disturbing operations, but this is not always the case for small entities. Further, classroom training where emergency responses are discussed can be a better tool at times for

assuring compliance with operating procedures. I would suggest R3 read "Each entity shall assure that personnel are aware of the requirements of EOP-004 and capable of responding as required".
No
Again, the entity should determine the need for review of any procedure. Changing circumstances may dictate a shorter cycle, but no changes could dictate a longer review. I will note that spill prevention plans are required to be reviewed every five years, so I question the need for an 18-month review of the EOP plan.
Yes
Yes
A qualified yes here - please clarify footnote 1 to the table. Are the listed qualifications "and" or "or" statements -IOW, if destruction of BES equipment through human error does not have the potential to result in the need for emergency actions, is it still reportable? If a 18-240 KV step-up transformer suffers minor damage because a conservator tank was valved out, is this reportable under this definition?
No
Due to disagreement with R3 and R4.
No
See Q 12.
No
See Q 12.
Yes
Yes
Individual
Philip Huff
Arkansas Electric Cooperative Corporation
3 - Load-serving Entities, 4 - Transmission-dependent Utilities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators
No
The purpose statement reads "To improve industry awareness...of the BES". We suggest the purpose should state "To improve industry awareness and effectiveness in addressing risks to the BES". We feel the remaining purpose statement is unnecessary.
Yes
Yes
Yes
Yes
No
We appreciate the effort the team has taken in improving the requirements since the last posting. For 1.3, it appears to suggest the communication must always include communicating to internal personnel and ALL external organizations. We suggest removing the reference to 1.3.1 and 1.3.2 and move 1.3.1 and 1.3.2 to 1.4 and 1.5 respectively. For 1.3.2, modify to state "Internal company personnel notification(s) deemed necessary by the Responsible Entity". For 1.4, we feel the term "content" is too broad as used here. For example, if the FBI changes the contact info for the JTTF, the Responsible Entity may not find out until an incident or annual exercise. Or if the contact person for the state agency changes position without notifying us, it would require us to then change the plan within 90 days. We suggest an annual review of the plan is sufficient for the objective of this requirement.
Yes
Yes
No
We appreciate the effort the team has taken in improving the requirements since the last posting. We request the team

clarify if this also includes personnel observing and reporting the requirements or only those specifically listed in the plan. The measure seems to indicate it only includes those listed in the plan, but this is not clear in the requirement. If it includes those personnel involved in observing and notifying management, then this might include a significant portion of the organization. In either case, we feel the requirement should be modified as "...review applicable portions of its Impact Event Operating Plan...".
No
We appreciate the effort the team has taken in improving the requirements since the last posting. For R5, we suggest including the reporting form as part of the plan in R1. Otherwise, a violation of R5 would also indicate a violation of R2.
No
We appreciate the effort the team has taken in improving the requirements since the last posting. Event Forced Intrusion: The timeframe is very small given the possibly minimal risk to the BES. It often takes much longer than 1 hour after verification of intrusion to determine the intrusion was only for copper theft. We suggest a 24 hour time frame or tie the timeframe to the "verification of forced intrusion".
No
We applaud the drafting team's effort in crafting more meaningful measures. However, we have concerns with the measures reading like requirements in stating Responsible Entities "shall" do something. We suggest crafting the measures to provide acceptable, but not all exclusive, forms of evidence by stating something similar to "Acceptable forms of evidence may include..."
Yes
Yes
Yes
Yes
We appreciate the added context through the use of extended background information, rationale statements, and corresponding guideline and hope this context will remain in line with the Standards through the ballot and approval process. We have a few suggestions and questions related to this context. Our comments for this question relate to the contextual information. First of all, in the diagram on page 8, we suggest the appropriate question to ask is "Is event associated with potential criminal activity?" rather than "Report to Law Enforcement?" Also, it would be helpful to make clear the communication flow associated with the State Agency is the responsibility of the State Agency and not the Responsible Entity. This could be shown with a different colored background that calls this process out separately. In the rationale box for R3, it states "The DSR SDT intends..." We propose this should read similar to "The objective of this requirement is..." Overall, we suggest the SDT review the guidance document to make sure any changes made to the requirements are consistent with the guidance.
Individual
Joe Petaski
Manitoba Hydro
1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators
No
"Situational Awareness" was replaced by the generic "Industry awareness". Justification for this was that "Situational Awareness" was a "by product" of a successful event reporting system and not a "driver". Using "Industry awareness" clouds the clarity of the purpose. If personal are properly trained and conscious of their responsibilities, then they are in fact "situationally aware", and will therefore drive the reporting process on the detection an "Impact Event". "Industry awareness" falsely labels this Standard as unique to the electrical industry when clearly many outside and international agencies will be notified and involved. "Situational Awareness" seems much more appropriate and encompassing. Other then that the Purpose is a large improvement from the original.
Yes
"Disturbance" has a unique and traditional meaning in the electrical industry, basically meaning "a notable electrical event causing in imbalance of load and generation". Attempting to include the many scenarios can that can affect reliability blurred the current vision of "Disturbance" and the addition of "unusual occurrences" just added to the confusion. It never seemed appropriate to submit an "unusual occurrence" on a "Disturbance Report". "Impact Event" is very encompassing and then detailed specifically in Attachment 1.
Yes
"Impact event", The DSR SDT reasoning for this "A sabotage event can only be typically determined by law enforcement after the fact" is very creative and concise!
Yes
All registered entities are included. This means all field and office personal involved will create a 360 degree view of the



BES, and fulfill "Situational awareness of the industry". In Attachment 1, the "Entity with Reporting Responsibility" entities vary. It might be clearer to leave all impact levels "Entity with Reporting Responsibility" as the RC, BA and TOP, as these are likely the only parties that will report as required. All other entities must report to the RC, BA and TOP.
Yes
Agree with R1, a central system for receiving and distributing reports. There is limited time and resources for control operators to follow up and ensure ALL required entities have received all information required in a timely manner. Agree with R7 and R8.
No
Plan, Process and Procedure are all too interchangeable with each other and have no value being used in "one paragraph" as they do not differentiate from one or other. The terms "identify", "gather" and "communicate" better describe "Process, plan or procedure" so simplify to: 1.4. Identification of Impact Events as listed in Attachment 1. 1.5. Gathering information for inclusion into Attachment 2 regarding observed Impact Events listed in Attachment 1. 1.6. Communicate recognized Impact Events to the following:
Yes
Removing "assess the initial probable cause" from the statement removes the ambiguity in the same way as replacing sabotage with impact level. Let the staff trained in this field determine probable cause after the fact.
Yes
This requirement appears to be written so as to leave how each entity tests this procedure is up to them and not how. The testing of this procedure could vary vastly from entity to entity, meaning there is no set protocol on this procedure. As long as this requirement remains open, it is fair.
Yes
Removing the extreme details "within 30 days of revision" and "train before given responsibility" and giving leeway to when this training is necessary, will allow training to be integrated into other existing training schedules. Inclusion of 5.3 and 5.4 would require unique set of time lines and additional resources to monitor and implement.
Yes
The DOE-OE-417 appears more intuitive and descriptive (and on line ability), but having the either or option is fine. DOE-OE-417 Form is mentioned several time in this Standard, but no link to this document.
No
Reporting for CCA's should be limited to damage associated with a detected cyber security incident.
Yes
No
Reduce the Long Term Planning items to Lower VRF. The planning items will not have the same impact on the reliability of the system as real time operations.
Yes
Yes
Yes
Individual
Mike Albosta
Sweeny Cogeneration LP
5 - Electric Generators
Yes
Yes
No
The threshold for reporting what could be sabotage still leaves the door open for second guessing after-the-fact. For example, if graffiti is sprayed on a BES asset, the entity is to assume that the event is not to be reported. However, intent to harm the BES may be discovered at a later point – with ramifications to the entity who did not report it. A solution may be to strengthen footnote 3 to both reporting tables, which makes an allowance to report "if you cannot reasonably determine likely motivation" of sabotage. If acceptable methods to provide justifiable evidence that reporting was NOT required, then this loophole may be corrected.
No

In Attachment 1, Generator Operators who experience a  $\pm 10\%$  sustained voltage deviation for  $\geq 15$  continuous must issue a report For externally driven events, the GOP will have little if any knowledge of the cause or remedies taken to address it. We believe the language presently in EOP-004-1 is satisfactory that any "action taken by a Generator Operator" that results in a voltage deviation has to be reported by the GOP.

Yes

We agree that these requirements appropriately belong in the NERC Rules of Procedure. However, we are concerned with the multiple reporting requirements being driven by EOP-004-2, CIP-008-3, the ERO Events Analysis Team, the Reliability Assessment and Performance Analysis Group (RAPA). It is imperative that these efforts be consolidated into a single procedure using a single reporting template.

Yes

Yes

No

We do not see a reliability benefit in the planning and execution of tests or drills to ensure that regulatory reporting is performed in a timely fashion. It is sufficient that penalties can be assessed against entities that do not properly respond in accordance with EOP-004-2, leaving it to us to determine how to avoid them.

Yes

Yes

No

In Attachment 1, Part A, Generator Operators who experience a  $\pm 10\%$  sustained voltage deviation for  $\geq 15$  continuous must issue a report For externally driven events, the GOP will have little if any knowledge of the cause or remedies taken to address it. We believe the language presently in EOP-004-1 is satisfactory that any "action taken by a Generator Operator" that results in a voltage deviation has to be reported by the GOP.

Yes

Yes

Yes

Yes

Yes

Individual

Thad Ness

American Electric Power

1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators

Yes

No

The definition is too broad and vague. The text in the comment form has the following sentence "Only the events identified in EOP-004 – Attachment 1 are required to be reported under this Standard." The definition should contain that caveat or something similar.

Yes

Yes

AEP agrees, but it further supports the notion that this standard should not apply to the IA, TSP, and LSE functions.

Yes

No

Even best developed plans, processes and procedures do not always lend themselves to address the issues at hand. There needs to be flexibility to allow entities to first address the reliability concern and second report correspondingly.

Currently, this requirement is overly prescriptive and places unnecessary emphasis on the means to an end and not the outcome. The outcome for this requirement is to report Impact Events.
No
Requirement 5 and Requirement 2 are redundant. We recommend Requirement 2 be replaced with the language in Requirement 5. "Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417."
No
It is unclear if actual events would qualify for a test in the requirement; however, the associated measure and rationale appear to support this. We suggest the requirement be restated to allow for actual events to count for this requirement.
Yes
No
This should be one step covered by the implementation in requirement 2. We like the ability to use one form (i.e. NERC Attachment 2 or the DOE-417); however, we would prefer to have this information only be reported once.
No
The time to submit a report for the inclusion of the damage or destruction of BES equipment, critical asset, or critical cyber asset is too aggressive. The critical cyber asset reporting is redundant with CIP-008. Furthermore, reporting equipment failures within an hour for Critical Assets is going to overwhelm operators that need to focus on the restoration efforts. Self-evident equipment failures at a Critical Asset (such as a tube leak at a generator which is a Critical Asset) should not be required to be reported. Maybe the wording should be stated as an "abnormal occurrence" rather than "equipment failure." It would be helpful if there was a defining or a footnote that defines the nature and/or duration for loss of some equipment. For example, is a transmission loss for sustain or momentary outages?
Yes
No
With the scope of applicable functions expanding, more time will be required to develop broader processes and training. This will need to be extended for 18 months to get the process implemented and everyone trained.
We still do not agree that LSE, TSP and IA should be included in the applicability of this standard. Having processes to report to local or federal law enforcement agencies is "legislating the obvious". The focus on this standard should only be on Impact Event reporting to reliability entities.
Group
Southern Company
Cindy Martin
Yes
Yes
There is concern that the proposed definition for Impact Event does not allow for prudent judgment and preliminary situational assessment by the entity to declare a Potential Impact Event (especially threats) as non-credible. The thresholds for reporting established in Attachment 1 – Part A provide a somewhat definitive bright line with regard to those events identified in Part A, but for some of the events in Part B there should be allowance for an assessment by the entity to reasonably determine whether the event poses a credible threat to the reliability of the BES. This is attempted in the footnote to the "Forced Intrusion" event in Attachment 1 – Part B, but we think this allowance for entity assessment and prudent judgment needs to apply more pervasively, perhaps by including the term "credible" in the definition of Impact Event or at least by adding the term "credible" wherever the term "physical threat" is used.
Yes
Yes
This will cause the duplication of reporting for some events. Reference EOP-004 Attachment 1: Impact Events Table; Event - Loss of Firm Load for ≥ 15 minutes (page 15 of standard) This requires the RC, BA, TOP, and DP to report. So if a storm front goes through our system and takes out 400MW of load in Alabama and Georgia the PCC would have to report as the RC, BA, and TOP. Alabama Power and Georgia Power would also have to report as DPs. The way it is now the PCC reports for any of these events.
Yes
Yes



No
The "Potential Reliability Impact" table should be taken out. Referred to previous comment on our position on potential impacts.
Yes
Yes
Yes
No
Yes
Individual
Nathaniel Larson
New Harquahala Generating Co.
1 - Transmission Owners, 5 - Electric Generators
Yes
Yes
Yes
Yes
Yes
Yes
Yes
No
M3. In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or documentation. (R3). The measure for R3 needs to make it clear that "exercise/drill/actual employment" can be a classroom exercise, utilizing scenarios for discussion. It should not be necessary to fully test the plan by making actual phone calls, notifications etc.
Yes
Yes
Yes
No
See R3 comments
Yes
Yes
Yes
Yes
Yes

Group
Bonneville Power Administration
Denise Koehn
Yes
Yes
Agree, but note that this will add many more situations to reporting and it will require more staff time to accomplish this.
Yes
Yes
Yes
Ensure distribution of trends.
No
Not sure that a 90-day update is needed to be sent to CEF.
No
Minimize the number of requirements. Not sure what the new R2 intends that is different than having a valid plan (signed?). Why can't R1 have develop and implement? R5 is the reporting. Implement should be with R1 or R5 depending on the interpretation.
No
Too burdensome to go through EACH and ALL individual Impacts and report each one on a drill basis with outside entities. One or two scenarios may be OK.
Yes
Yes
Reporting form OK. Note that the Frequency Maximum/Minimum Section should be clarified. A Gen Loss doesn't usually experience a high (maximum) frequency, just the low immediately following the event.
No
Generally OK, but there are too many events to report. The loss of 3 BES elements for a large geographic entity for a (5 county?) windstorm that has little impact to the system is not needed. 3 elements within the same minute could be acceptable and 6? elements still out within an hour ... or something to that affect could work.
Yes
No
R2, R3 and R4 should be lower VRFs than R5 and R1.
No
For R5 VSL's: suggest moving the 1-2 hours down one level to Moderate and move the >2 hours down to High with a range of 2-8 hours. Leave the "Failed to Submit" in the Severe category.
No
Depends on the answer to #7. If implementation means a signed and valid Plan, then it should be with Long Term. If reporting the events, then it should be Real-Time/Same Day Operations.
Yes
Work needed on Part A Damage or Destruction of BES equipment. The Note 1 is OK, but the Threshold doesn't match well. If a PCB is damaged by lightning or an earthquake, Note 1 (human action) doesn't require Reporting (proper interpretation), but the Threshold still requires "equipment damage".
Group
Midwest Reliability Organization
Carol Gerou
Yes
The addition of "industry awareness" adds to the scope of this Standard. Whereby an entity is required to inform the RC and others of actual and potential Impact Events.
No

The proposed definition is not supported by any of the established "bright line" criteria's that are contained within attachment 1. This Results Based Standard should close any loop-holes that could be read into any section, especially the definition. According to rules of writing a definition, a definition should not contain part of the word that is being defined. Recommend the definition be enhanced to read: "Impact Event: Any Contingency which has either effected or has the potential to effect the Stability of the BES as outlined per attachment 1. Within this enhanced recommendation, presently defined NERC terms are used (Contingency and Stability), thus supporting what is current used within our industry. There is also a quantifiable aspect of "as outlined per attachment 1" that clearly defines Impact Events.

Yes

Sabotage is usually associated with a "malicious" attack. Entities have always lacked the clinical expertise to determine if an event was malicious or not. The Impact Event bright line criteria clearly states what the minimum reporting requirements are.

Yes

Yes

The ERO is not a user, owner or operator of the BES and the best place to contain their responsibilities, is in the Rules of Procedure.

Yes

This is a NERC defined term and will assist entities in maintaining compliance with this (proposed) Standard.

Yes

This clearly states that an entity's Operating Plan is to be used for reporting of Impact Events.

Yes

Yes

Yes

This will reduce any double reporting to the ERO and FERC.

No

1) Section 9 of the Impact Reporting Form states: "List transmission facilities (lines, transformers, busses, etc.) tripped and locked out". But Part A of Attachment 1 states: "Three or more BES Transmission Elements". a. Should section 9 state: "List transmission facilities (lines, transformers, busses, etc.) tripped or locked out"? b. Should section 9 state: "List transmission elements (lines, transformers, busses, etc.) tripped or locked out"? This will align the reporting criteria with the actual reporting form. 2) Section 13 of the Impact Reporting Form states: "Identify the initial probable cause or known root cause of the actual or potential Impact Event if know at the time of submittal of Part I of this report:". Recommend that "of Part I" be removed since there is no Part 2. 3) Every Threshold in attachment 1 gives a clear measurable bright line, except: "Transmission Loss". As presently written "Three or more BES Transmission Elements" could imply that a Report will be required to be submitted if a BES transmission substation is removed from service to perform maintenance. Or there could be three separate elements within a large substation that are out of service (and don't effect each other) that will require a Report. Upon review of the TPL standards, there are normally planned items that our industry plans for. It is recommended that the Threshold for Reporting of Transmission Loss be enhanced to read: "Two or more BES Transmission Elements that exceed TPL Category D operating criteria or its successor". This threshold now is based on a actively enforced NERC Standard, and each RC and TOP are aware of what this bright line is.

Yes

Yes

Yes

Yes

Yes

On the Impact Reporting Form, number 7,8,9,10, and 11 have an astrict (\*) but nothing describes what the astrict means. Recommend a foot note be added to state: \* If applicable to the reported Impact Event.

Group

SRP

Cynthia Oder

Yes
No
Suggest that definition include reference to the fact that this is non-desired occurrence, as the word 'impact' has neither a positive nor negative implication. This is not a well formed definition as it contains circular references to 'impacted' and 'event' within the definition.
Yes
No
The threshold for Reporting is broad, vague and repetitive. "Three or more BES Transmission Elements" is vague and could be interpreted as 3 breakers in a large system.
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Individual
Eric Salsbury
Consumers Energy
3 - Load-serving Entities, 4 - Transmission-dependent Utilities, 5 - Electric Generators
No
The definition of "Impact Event" seems very vague and nebulous. This definition should be modified to be clear and concise, such that entities clearly understand what is included within the definition.
No
EOP-004 does not appear to address a reliability need. Reporting "after-the-fact" information such as that described in "Impact Events" does not do anything to improve Bulk Electric System reliability. Therefore, we recommend that CIP-001 be updated to address sabotage events, and that NERC otherwise rely on the statutory reporting to the DOE that is represented by OE-417 for any "after-the fact" information. The remainder of our comments reflects detailed comments on the posted draft, presuming that our objection represented above will be disregarded.
No
Requirement R1, "Have a plan ..." with all of the listed criteria, seems to present a serious compliance risk to applicable entities without a direct reliability benefit, as long as entities still identify and report relevant events. Ad-hoc



procedures, as discussed within the R1 "Rationale" have been acknowledged within the rationale to be working effectively, and should remain sufficient without having a documented and by inference, signed, approved, dated document with revision history (as is being demanded today by compliance auditors wherever a "documented plan" is specified within the requirements).

No

We understand that DOE is migrating to an on-line reporting facility rather than the email-submitted OE-417. If they do so, the OE-417 will not be available for providing to NERC, and the reporting specified by EOP-004 will be duplicative of that for DOE. We recommend that NERC, RFC and the DOE work cooperatively to enable a single reporting system in which on-line reports are made available to all appropriate parties.

No

1. In reference to the Impact Event addressing "Loss of Firm load for greater than or equal to 15 minutes", this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to "Within 1 hour after detection of exceeding 15-minute threshold". Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES. 2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting "Within 1 hour after occurrence is identified" possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the "time to submit" 3. Referring to the "Transmission Loss" Impact Event, please provide more specificity. Is this intended to address : - anytime that three or more BES Transmission Elements are out of service, - only when three or more BES Transmission Elements are concurrently out-of-service due to unscheduled events, - only when three or more BES Transmission Elements are simultaneously automatically forced out-of-service, or - only when three or more BES Transmission Elements are forced from service in some proximity to each other? It is not unusual, for a large transmission system, that this many elements may be concurrently forced out-of-service at widely-separated locations for independent reasons. 4. Referring to the "Fuel Supply Emergency" Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417. 5. For that matter, the SDT should carefully compare the Impact Event Table with OE-417. Where similar Impact Events are listed, consistent terminology should be used, and identical reporting periods specified. Where the Impact Event Table contains additional events, they should be clarified as being distinct from OE-417 to assist entities in implementation. Further, since OE-417 must be reviewed and updated every three years, EOP-004 should defer to the reporting time constraints within OE-417 wherever listed in order to assure that conflicting reporting requirements are not imposed.

No

We understand that DOE is migrating to an on-line reporting facility rather than the email-submitted OE-417. If they do so, the OE-417 will not be available for providing to NERC, and the reporting specified by EOP-004 will be duplicative of that for DOE. We recommend that NERC, RFC and the DOE work cooperatively to enable a single reporting system in which on-line reports are made available to all appropriate parties.

No

1. In reference to the Impact Event addressing "Loss of Firm load for greater than or equal to 15 minutes", this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to "Within 1 hour after detection of exceeding 15-minute threshold". Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES. 2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting "Within 1 hour after occurrence is identified" possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the "time to submit". 3. Referring to the "Fuel Supply Emergency" Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.

No

1. In reference to the Impact Event addressing "Loss of Firm load for greater than or equal to 15 minutes", this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities)

has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to "Within 1 hour after detection of exceeding 15-minute threshold". Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES. 2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting "Within 1 hour after occurrence is identified" possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the "time to submit". 3. Referring to the "Fuel Supply Emergency" Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.

No

1. We appreciate the aggregation of redundant standards on this subject, but have some concerns about the content of the aggregated standard as listed below and in reference to previous questions on this comment form. 2. It is not clear whether an event that meets OE-417 reporting criteria but is not defined within EOP-004-2 is an Impact Event; for example, "loss of 50,000 or more customers for 1 hour or more" is required to be reported to DOE as a OE-417 type 11 event but it is not clear whether EOP-004-2 requires that such events be also reported to NERC. The "Reporting Hierarchy" flow chart seems to suggest that any OE-417 must still be filed with NERC/RE. If the flow chart is not consistent with the intent of the Requirements, it must be clarified. 3. NERC implies active involvement of law enforcement. This assumes that law enforcement has the resources to be involved in an Impact Event investigation and fulfill the standard reporting requirements. This is an unrealistic expectation as we have experienced first-hand, a lack of response by law enforcement agencies as their resources shrink due to economic issues. Additionally, NERC is asking that we place credence in law enforcement, on our behalf, to make a definitive decision about the reporting of events. Refer to page 6 of EOP-004-2 under "Law Enforcement Reporting": "...Entities rely upon law enforcement agencies to respond and investigate those Impact Events which have the potential of wider area affect..." In many cases, the internal security function must work with system operations personnel to thoroughly understand the system and the effects of certain events. It is unrealistic to think law enforcement would be in a position to make BES decisions within the timeframe given without having system operations experience. It is our experience that external agencies do not understand the integration / inter-connectivity, resiliency, or implications of our energy infrastructure. 4. Within Michigan, a "Michigan Fusion Center: Michigan Intelligence Operations Center (MIOC)" has been established. - Today, we share information such as substation issues and identity theft (not internal issues) to the MIOC. The MIOC is trending incidents on critical infrastructure assets and sectors around the state. The private sector is encouraged to report to the Fusion Center. If NERC is collecting this type of information for future studies and trending / analysis, they should coordinate with each state's Fusion Center.

Individual

Michael Falvo

Independent Electricity System Operator

2 - RTOs and ISOs

Yes

Yes

We do not have any issue with the wording of the definition, but question the need for this definition since by itself the term is not specific on the types of events that are regarded as having an "impact". The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. For that matter, these events that are to be reported can be called anything. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not used anywhere else in the NERC reliability standards. In fact, for the term Impact Event to be fully defined, all the elements in Attachment A must become a part of it. We therefore suggest the SDT to consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A.

Yes

We agree since it is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.

No

We disagree with the following inclusion/exclusion of several entities: a. We assess that the applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. If our reasoning is correct, we question why NERC was dropped from the Applicability Section as it is an applicable entity identified in CIP-002-3. b. If the above approach was not strictly followed, then we'd suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.

Yes
Yes
Yes
Yes
Yes
No
R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the “how” part, not the “what”. The vehicle for reporting can easily be included in R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event. We suggest the SDT combine R2 with R5.
No
As indicated under Q4, we question the need to include IA, TSP and LSE in the responsible entities for reporting.
No
We do not have any issues with Measures M1, M2 and M4, but have a concern with M3 and a couple of concerns with M5: M3: This Measure contains a requirement for the Responsible Entities to conduct a mock Impact Event. We disagree to have this included in the Measure. R3 requires the Responsible Entity to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The Measure should adhere to this condition only. We suggest to change the wording to: The Responsible Entity shall provide evidence that it conducted a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, documentation or a report on an actual Impact Event. M5: a. As suggested above, R5 should be combined with R2; b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to “support the type of Impact Event experienced”. Also, the date and time of the Impact Event is provided in the reporting from. Why do we need to provide additional evidence on the date and time of the Impact Event?
No
If R5 were to remain as is, then the VRF should be a Lower, not a Medium since R5 stipulates the form to be used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form does not give rise to unreliability.
We do not have any major issues with the proposed VSLs. However, in view of our comments on some of the Questions, above, we reserve our comments upon seeing a revised draft.
No
For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. And consistent with other plans such as system restoration plan which needs to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. We suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning.
Yes
Group
Western Electricity Coordinating Council
Steve Rueckert
Yes
No
We question the need for a defined term. It appears that an Impact Event is any event identified in Attachment 1. The use of the defined term combined with the language of Requirement 2 to implement the Impact Event Operating Plan for Impact Events listed in Attachment 1 may be confusing. Is an Impact Event any event described by the proposed definition or is an Impact Event any event listed in Attachment 1?
Yes



Yes
Reporting consistency and timelines may need to reviewed for example: Fuel Supply Emergency - OE-417 requires reporting within 6 hours / Attachment 1 Part B requires reporting within 1 hour.
No
Recommendation: Add a column in Attachment 1 to acknowledge the events that require a OE-417 Report and list the number under Schedule 1 that required the OE-417 Report. This would add accuracy and consistency among reporting entities.
Yes
Yes
Individual
Kirit Shah
Ameren
1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators
No
The original Purpose wording was clear, concise and understandable.
No
The documentation from the SDT included the reliability objective for EOP-004-2 which should be included in the definition of Impact Event. Our suggested alternate definition for Impact Event: "An Impact Event is any event that has either caused, or has the likely potential to cause, an outage which could lead to Cascading. Such events will be identified as being caused by, to the best of the reporting entity's information: (1) equipment failure or equipment mis-operation, (2) environmental conditions, and/or (3) human actions." This alternate wording includes the reliability objective and clarifies the three known, or likely, causes of the Impact Event.
No
The SDT did not further define sabotage as directed by FERC, but instead created a new term that does not address the order. The Term Impact Event has no clarity or quantitative qualities by which an entity can determine what should be reported. the use of the phrase "has the potential to impact reliability" has such a vague scope, an auditor can interpret to mean any "off-normal" condition, which makes this standard impossible to comply with. The SDT should use the DOE definition of sabotage as follows: Sabotage – Defined by Department of Energy (DOE) as: • An actual or suspected physical or Cyber attack that could impact electric power system adequacy or reliability • Vandalism that targets components of any security system on the Bulk Electric System • Actual or suspected Cyber or communications attacks that could impact electric power system adequacy or vulnerability, including ancillary systems which support networks (e.g. batteries) • Any other event which needs to be reported by the Balancing Authority (Transmission Operations) to the Department of Energy. Sabotage can be the work of a single saboteur, a disgruntled employee or a group of individuals.
No
The 1 hour reporting requirement, as reference in Attachment 1 is inappropriate. In the event an "Impact Event" were to be discovered the Responsible Entity should focus on public and personnel safety. The reporting requirement should read "Within 1 hour or as soon as conditions are deemed to be safe." This statement would be applicable to "Damage or destruction of Critical Asset" The SDT should not put personnel in the position of choosing to either comply with NERC or address public or co-worker safety. The Time to Submit Report states "within 1 hour after occurrence is identified" This gives an auditor a wide area to question. If personnel report the occurrence 1 hour after identified, but 24 hours after it occurred, we are subject to the personal beliefs of the auditor that the event was not identified 24 hours ago, and reported 24 hours late. This will also be difficult to measure as the operator will have to document in the plant log the time the event was identified, while possibly dealing with Emergency Conditions. In the Note above the Actual Reliability Impact Table, the SDT identifies that under certain conditions, NERC / RRO staff may not be available for continuous 24 hour reporting. The SDT should consider the same stipulations apply to operating personnel and they should not be held to a higher standard than NERC / RRO.

No
The "Responsible Entity" should be limited to those functions with the most oversight such as the BA, RC, or TOP. Otherwise there will be multiple DOE OE-417 reports sent by multiple entities.
No
See response to question 4.
Yes
The following is a list of our greatest concerns. (1) We are concerned about the lack of definitions and use of critical non-capitalized terms. As an example, there is a reportable Impact Event if there is a +/- 10% Voltage Deviation for 15 minutes or more on BES Facilities. As a first example, why is the term Voltage Deviation capitalized when it is not in the NERC Glossary and not proposed to be added? Where is the deviation measured - at any BES metering device? What is the deviation to be reported - the nominal voltage? the high-side of the Voltage Schedule? the low-side of the Voltage Schedule? the generator terminals? when a unit is starting up? All of these are possible interpretations, but < 1% of them would ever result in a Cascading outage - which is the reliability objective of this Standard. A second example is a Generation loss. The threshold for reporting is 2,000 MW, or more, for the Eastern or Western Interconnection. Is this simultaneous loss of capacity over the entire Interconnection? Or, cumulative loss within 1 hour? Or, cumulative loss within 24 hours? How many individual GOPs have responsibility for > 2,000 MW? It seems this would more effectively apply only to an RC and/or BA. The likelihood that one GOP would lose that much generation at once is probably remote. A third example would be the damage or destruction of BES equipment event. The term "equipment" was left lower case with a footnote explanation that includes "...due to intentional or unintentional human action...". This is likely to require the determination of intent by the human involved, which will almost certainly be impossible to determine within the 1 hour reporting time. Also, what is the definition of the terms "damage" and "destruction"? Once again, if the reliability intent is to ONLY report Events that have a likely chance of leading to Cascading, this will greatly reduce the potentially enormous reporting burden. that could result without this type of clarification. (2) Without a very thorough understanding of the definitions of the terms requiring reporting, the 1 hour reporting constraint on most events will likely require that we frequently overreport events to minimize any chance of non-compliance. A webinar explaining expected reporting requirements would very useful and valuable. It is also unclear why so many Impact Events require such a short reporting time period. There will almost certainly be many times at 2:00 AM on a weekend when experts and the appropriate personnel will be available to quickly analyze an event and decide, within 1 hour, if a report is necessary. (3) Have all the new Impact Event reporting requirements been checked against reporting requirements from other Standards? For example, the Voltage Deviation Event would appear to potentially overlap/conflict with instructions from a TOP for VAR-002 compliance. Since VAR-002-2 is now in draft, has the SDT worked with that Team to determine if the requirements dovetail?
Individual
Kathleen Goodman
ISO New England, Inc
2 - RTOs and ISOs
No
The proposed states "To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities." Awareness by who in the industry?
No
We question the need for this definition since by itself the term is not specific on the types of events that are regarded as having an "impact". The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. For that matter, these events that are to be reported can be called anything, or just simply be titled "Event to be Reported" without having to define them. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not used anywhere else in the NERC reliability standards. In fact, for the term Impact Event to be fully defined, all the elements in Attachment A must become a part of it. We therefore suggest the SDT to consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A. If the SDT still wishes to retain a definition despite our reservations noted above, we strongly suggest an improvement. The proposed definition of Impact Event is overly broad because of the use of "potential to impact" and the "Such as" list. Consider that routine switching has the potential to result in a mis-operation. In that regard most routine switching could be interpreted as an impact event. The "Such as" list should be struck and "potential" language should be struck. An alternative definition to consider: An Impact Event is any deliberate action designed to reduce

BES reliability; unintended accident that could result in an Adverse Reliability Impact; or an unusual natural event that causes or could cause an Adverse Reliability Impact.
Yes
We agree since it is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
No
We disagree with the following inclusion/exclusion of several entities: a. We acknowledge that the applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. If our reasoning is correct, we question why NERC was dropped from the Applicability Section as it is an applicable entity identified in CIP-002-3. b. If the above approach was not strictly followed, then we'd suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets. c. There is still significant duplicate reporting included. For instance, why do both the RC and TOP to report voltage deviations? As written, a voltage deviation on the BES would require both to report. The same would hold true for IROLs. Perhaps IROLs should only be reported by the RC to be consistent with the recently FERC approved Interconnection Reliability Operating Limit standards.
Yes
No
We do not believe that the use of the Operating Process, Operating Procedure, and Operating Plan for a reporting requirement is consistent with their definitions nor with the intent of the definitions. For instance, an Operating Process is intended to meet an operating goal. What operating goal does this requirement meet? An Operating Procedure includes tasks that must be completed by "specific operating positions". This reporting requirement could be met by back office personnel. We suggest that R1.3.2 delete the list of entities to notify. The terms used to identify who to notify are not defined terms and can lead to subjective interpretations. As written, the requirement does not aid the Applicable entity or the Compliance enforcers in clearly including or excluding who to notify. We also believe that parts 1.3 and 1.3.2 under Requirement 1 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. While some should require notification to law enforcement such as when there has been destruction to BES equipment, others certainly would not. For instance, law enforcement does not need to know that an IROL violation, generation loss or voltage deviation occurred. We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will be particularly difficult when support personnel are not present such as during nights, holidays and weekends. We further suggest that as explicit statement that "reliable operations must ALWAYS take precedence to reporting times" be included in the standard.
No
Fuel Supply Emergency is not a defined condition. We suggest that the SDT poll the ballot body regarding the reporting of Fuel Supply Emergencies. Fuel Supply is an economic consideration and the concept of Fuel Supply Emergency is subjective. A resource that uses coal or oil may vary its supplies based on economic considerations (the price of the fuel). For a conservative BA a fuel-on-demand supply line can be viewed as a fuel supply emergency whereas the resource owner sees the matter as good business. Moreover, the release of such reports to the public can have unintended consequences. Fuel disruptions caused by contract negotiations when reported to the public can result in non-union transportation employees being physically harmed by fuel supply organizers thus resulting in the loss of non-contract fuel. Further, this information may aggravate the situation by causing the cost of fuel to be inflated by suppliers when demand is great. If this event is not deleted, then we would suggest that the definition be constrained to "declared" fuel supply emergencies. Suggest the deletion of category: Risk to BES equipment. Because of the broad definition of BES, the risk to BES equipment is overly broad and can be applied to any risk to any "part of" any BES asset. The footnote helps identify what the SDT was intending, however, the words themselves can result in overly broad findings by compliance enforcement people.
No
We appreciate and agree with the drafting team recognizes that actual implementation of the plan for a real event should qualify as a "test". However, we are concerned that review of this requirement in isolation and without the benefit of the background material and information provided by the drafting team may cause a compliance auditor to believe that a test cannot be met by actual implementation. Furthermore, we do not believe testing a reporting procedure is necessary. Periodic reminders to personnel responsible for implementing the procedure make sense but testing it does not add to reliability. If they don't report an event, it will become obvious to compliance auditors. Recommend using language similar to CIP-009. "Each Responsible Entity shall conduct a an exercise of its operating process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 calendar months between exercises. An exercise can range from a paper drill, to a full operational exercise, to reporting of actual incident Also, we question the need to conduct a test annually. Since this is only a reporting Standard and, as such, has no direct impact on reliability, we suggest modifying the testing

requirement to once every three years.
Yes
No
R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the “how” part, not the “what”. The vehicle for reporting can easily be included in R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event. We suggest the SDT combine R2 with R5.
No
As indicated under Q4, we question the need to include IA, TSP and LSE in the responsible entities for reporting. There is still significant duplicate reporting included. For instance, why do both the RC and TOP to report voltage deviations? As written, a voltage deviation on the BES would require both to report. The same would hold true for IROLs. Perhaps IROLs should only be reported by the RC to be consistent with the recently FERC approved Interconnection Reliability Operating Limit standards. Also, the CIP reporting requirements duplicate was is already contained in the CIP Standards, specifically CIP-008. Also, we are required to intentionally destroy Critical Cyber Assets when they are retired, why would we be required to report this?
No
We do not have any issues with Measures M1, M2 and M4, but have a comment on M3 and a couple of concerns with M5: M3: This Measure contains a requirement for the Responsible Entities to conduct a mock Impact Event. We disagree to have this included in the Measure. R3 requires the Responsible Entity to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The Measure should adhere to this condition only. We suggest to change the wording to: The Responsible Entity shall provide evidence that it conducted a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, documentation or a report on an actual Impact Event. M5: a. As suggested above, R5 should be combined with R2; b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to “support the type of Impact Event experienced”. Also, the date and time of the Impact Event is provided in the reporting from. Why do we need to provide additional evidence on the date and time of the Impact Event? c. We disagree with Measurement 4. It implies that the review must be conducted in person. Why couldn't other means such as web training or a reminder memo not satisfy the requirement?
No
If R5 is to remain as is, then the VRF should be a Lower, not a Medium since R5 stipulates the form to be used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form has no impact on reliability. All violation risk factors should be Lower. All requirements are administrative in nature. While they are necessary because a certain amount of regulatory reporting will always be required, a violation will not in any direct or indirect affect reliability.
We do not have any major issues with the proposed VSLs. However, in view of our comments on some of the Questions, above, we reserve our comments upon seeing a revised draft.
No
For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. And consistent with other plans such as system restoration plan which needs to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. We suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning. The Time Horizon for R2 and R5 should be changed to Operations Assessment since they both deal with after the fact reporting.
Yes
Under the “Law Enforcement Reporting” it is stated “The Standard is intended to reduce the risk of Cascading involving Impact Events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.” We question whether a reporting standard can “reduce the risk of cascading” and wonder if the reference to the threat “around them” refers to law enforcement? We would expect that the appropriate operating personnel are the only entities that would be able to mitigate the potential risk to the BES. As it currently stands there is a potential duplication between the reporting requirements under EOP-004-2 (i.e. Attachment 2 Form) and the ERO Event Analysis Process that is undergoing field test (i.e. Event Report Form). This will result in entities (potentially multiple) reporting same event under two separate processes using two very similar forms. Is this the intent or will information requirements be coordinated further prior to adoption in order to meet the declared objective that the impact event reporting under EOP-004 be “the starting vehicle for any required Event Analysis within the NERC Event Analysis Program?”
Individual
Deborah Schaneman



Platte River Power Authority
1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Yes
Group
Pacific Northwest Small Public Power Utility Comment Group
Steve Alexanderson
Yes
No
We believe that facilities used in the local distribution of electric energy should be excluded from these requirements due the language of 16 U.S.C. § 824o(a)(1) and 16 U.S.C. § 824o(i)(1).
Yes
No
1.4 makes no sense. The operating plan update and the change to its content occur simultaneously. Perhaps the SDT meant to say "Provision(s) for updating the Impact Event Operating Plan within 90 days of identification of a needed change to its content. This would be consistent with the "lessons learned" language of the prior version.
Yes

Yes
Yes
Yes
No
The comment group is composed of smaller entities that do not all maintain 24/7 administrative support. While many of the 1 hour reporting thresholds do not affect us, some do. Others may come into play as standards are revised, such as the CIPs. We ask the SDT to consider the identification or verification that starts the clock on these may come at inopportune times for meeting a one hour deadline for these entities. Restoration may be delayed in an attempt to meet these time limits. Safety should always be the number one priority, and restoration and continuity of service second. We see reporting of these events much further down the list. We note that FERC order 693, paragraph 471 does not dictate a specific reporting time period and therefore we suggest timing requirements that promote situational awareness but allow smaller entities needed flexibility. FERC order 693, paragraph 470 directed the ERO to consider "APPA's concerns regarding events at unstaffed or remote facilities, and triggering events occurring outside staffed hours at small entities." Our comment group does not believe the SDT has adequately responded to APPA's concerns but rather took the 1 hour Homeland security requirement referenced in paragraph 470 verbatim. While a report within an hour might be ideal, it is not always practicable. We suggest: 1) as soon as possible after service has been restored to critical services within the service territory, or 2) By the COB the first business day after discovery. Our comment group realizes the difficulty in wording standards/requirements that lump small entities in with larger ones and we believe our suggestion achieves some balance. Expecting smaller entities to achieve timing requirements that can only be normally met under ideal conditions at large entities is not feasible or fair.
No
It is unclear when reporting to the Compliance Enforcement Authority is required. Does the registered entity report initially, and then anytime a change to the plan is made, or a drill is performed. Or is the information only provided following a request of the Compliance Enforcement Authority, and if so what is the acceptable time limit to respond?
All five requirements refer to Attachment 1 Part A either directly, or indirectly by referring to R1 plans. Attachment 1 Part A, though, only provides the thresholds required for reporting (R5). No thresholds are provided for planning (R1) or the requirements referencing the plan (R2-R4). Strictly interpreted, an entity would be required to plan for any amount of firm load loss exceeding 15 minutes (for example), implement the plan for any amount and then report only those events that exceeded the applicable 200 or 300 MW level. An entity that had a peak load of less than 200 MW would still need to meet R1-R4 regarding load loss. We believe the SDT intended to use common thresholds for all the requirements. Suggest relabeling the Attachment 1 Part A column header from "Threshold for Reporting" to "Threshold." We also fail to see how an entity's size in MWh affects the threshold for reporting firm load loss.
Group
PSEG Companies
Patricia Hervochon
Yes
Yes
Yes
No
The PSEG Companies believe the defining language, roles and responsibilities outlined in Attachment 1 are unclear and inconsistent. For example fuel supply emergency reporting footnote 2 "Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability" attempts to clarify the condition for reporting but does not. Whose "emergency actions" are being referred to in the footnote? It is not clear if those actions would be related to the specific station or the overall Bulk Electric System (BES). Can this be interpreted to imply a gas supply issue to one generating station as the result of pipeline maintenance, or local pressure issues would also requiring reporting? The PSEG Companies believe the definition of a fuel supply emergency needs to be more specific and less open to broad interpretation. In addition, the "Time to Submit Report" section of attachment 1 has a significant number of changes from the previous version. Accelerating the twenty four (24) hour to one (1) hour requirement for submitting the reports for several of the events takes resources away from managing the actual event. For the above

comments failure to submit a report within 1 hour is a high or severe VSL for a fuel supply emergency. This approach seems inconsistent with ensuring the operation and reliability of the BES. One (1) hour reporting, in most cases, is not adequate time to compile the needed information, prepare report, ensure the accuracy, submit, and simultaneously manage the actual event. We recommend 24 hour reporting for: Damage or destruction to BES, Fuel Supply Emergency, Forced Intrusion, and Risk to BES equipment sections of Attachment 1.

Yes

No

The PSEG Companies believe that sections 1.3 and 1.3.2 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. This is appropriate for some events if there has been destruction to BES equipment, for example, but not in certain operational events. It should not be necessary to notify law enforcement that a non sabotage event like an IROL violation, generation loss or voltage deviation has occurred.

No

Fuel supply emergency, as discussed in response to question 4 above, is not a defined condition. This event should be removed.

Yes

Yes

Yes

No

For the reasons cited in response to question 4 above the language roles and responsibilities remain inconsistent and unclear. The Time to Report changes are unreasonable and there is significant duplicate reporting required.

Yes

No

If Requirements 1-5 remain intact the Violation Risk Factor should be reduced to a Lower not a Medium since this is an administrative requirement and does not impact the reliability of the BES.

Individual

Phil Porter

Calpine Corp

5 - Electric Generators

No

The purpose has moved significantly from the originally approved SAR. The purpose should focus on reporting requirements for reporting electrical disturbances to the Bulk Electric System that exceed specific thresholds. Sabotage/vandalism/theft are a subset of the reportable events that could have or do cause a Bulk Electric System Electrical Disturbance. The Standard's content should focus on setting requirements to report specific types of electrical disturbance events and providing guidance for performing that reporting. Alternative language: Purpose: To establish reporting requirements for events that either cause, or have the potential to cause, significant disturbances on the Bulk Electric System.

No

Adding a definition for "Impact Event" is unnecessary and does not provide useful clarification of the actual reporting requirement for events that either impact the Bulk Electric System or have the potential to impact the Bulk Electric System. The all-encompassing nature of the proposed definition seems to conflict with the finite listing of events that actually require reporting. Although FERC specifically requested additional clarification of the term "sabotage" to clarify reporting requirements, the Drafting Team is correct in noting that "sabotage" implies intent and that the intent of human acts is not always easily determined. The fact that intent is not always determinable within the reporting timeframe can be dealt with more simply by requiring (in attachment 1) that human intrusions that have not been identified within the reporting timeframe as theft or vandalism should be reported as potential sabotage pending further clarification. This approach negates the need for an additional definition that may cause confusion regarding which events are reportable and eliminates the potential for under-reporting based on the assumption that the cause might be theft or vandalism.

No

The additional definition for "Impact Event" is unnecessary and does not provide useful clarification regarding actual reporting requirements. Sabotage, whatever the exact definition used, implies intent to damage or disrupt. The committee correctly notes that determination of actual intent is not always readily available. However, adding a general expansive definition encompasses all events that might disrupt the Bulk Electric System does not add clarity to the types of events that require reporting – which are listed in detail in Attachment 1. The issue can be more simply addressed by replacing the item "Human Intrusion" on Attachment 1, as follows: Event: Sabotage (note 3) Entity with Reporting Responsibility: All affected Responsible Entities listed in the Applicability Section of this Standard. Threshold for Reporting: Forced Intrusions at a BES facility that have not been determined within the reporting period to be theft or vandalism that does not affect the operability of BES equipment. Note 3 For purposes of reporting under Attachment 1, reportable sabotage includes all forced intrusions at BES facilities that have potential to cause, or cause, any of the disturbance events listed in Attachment 1 and have not been determined to be theft or vandalism that did not result in any event listed in Attachment 1. Responsible Entities are not required to report incidents of theft or vandalism that do not result in disturbance events. This approach also eliminates the need to reference copper theft as a particular type of theft that does not require reporting.

No

Expanding the current applicability of CIP-001-1 and EOP-004-1 to the GO function is unnecessary and will result in numerous duplicate reports, self-certifications, spot checks, and audits reviews, with no benefit to the reliability of the Bulk Electric System. The GOP is the appropriate applicable entity for generation facilities.

Yes

No

In the "Rationale for R1", the draft states "Every industry participant that owns or operates elements or devices on the grid has formal or informal process, procedure, or steps it takes to gather information regarding what happened and why it happened when Impact Events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized." Absent substantial evidence that the proposed requirement addresses an actual systemic problem with the "formal or informal process, procedure, or steps it takes" for internal and external evaluation and notification of items listed in Attachment 1, there is no obvious need for this additional paperwork burden, which in most cases will result in a written procedure that documents another existing written procedure or procedures, that will be maintained for the sole purpose of demonstrating compliance with the requirement. Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Adding a requirement to implement an "Impact Event Operating Plan", "Operating Procedure", and "Operating Process" is unnecessary. However, if the requirement is maintained, the related Measure M1 should state in plain language exactly what elements are required for compliance. Statements such as "The Impact Event Operating Plan may include, but not be limited to, the following..." begs the question regarding what other elements are required to demonstrate compliance. As written, M1 requires that entities provide an "Impact Event Operating Plan", but does not specify the required elements of the plan. In the absence of much more detailed instruction on exactly what elements must be included in the various documents, the proposed requirement will create confusion with both compliance and enforcement of the requirement. An example of each of the various required documents would be helpful. Any difficulty in developing such an example would be instructive of the probable compliance issues that would ensue from the necessarily varying approaches taken by disparate entities attempting to meet the requirement.

No

Requirement R2 is unnecessary for the same reasons listed above in answer to question 6 regarding Requirement R1. A new Reliability Standard requirement is not needed to verify that internal notifications are made within Registered Entities or to ensure that Registered Entities notify local law enforcement of suspicious activity, sabotage, theft, or vandalism. Such notifications are made by any company, and this requirement does not clearly enhance the reliability of the Bulk Electric System. Requirement R5 provides sanction in the event that events listed in Attachment 1 are not made appropriately. However, if the requirement is maintained, the related Measure M2 should state in plain language exactly what elements are required for compliance. In the absence of much more detailed instruction on exactly what elements must be included in the various documents, the proposed requirement will create confusion with both compliance and enforcement of the requirement. A detailed example of example documentation would be helpful. Any difficulty in developing such an example would be instructive of the probable compliance issues that would ensue from the necessarily varying approaches that would be taken by disparate entities attempting to meet the requirement.

No

Absent substantial evidence that the proposed requirement addresses an actual systemic problem with actual submittal of reports of electrical disturbances, Requirement R4 should be removed. Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Entities are capable of implementing procedures appropriate to ensure compliance with the actual reporting requirements without the addition of this "test". Alternately, if this requirement for annual tests is retained, it should be supplemented with a detailed example of an acceptable test and acceptable documentation of the test to avoid future compliance and enforcement issues. Stating "evidence may include, but is not limited to..." provides broad and unnecessary opportunity for future compliance and enforcement issues. Any difficulty the committee might encounter in developing such a detailed example would be instructive of the probable compliance and issues that would ensue from

implementation of the requirement.
No
Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Entities are capable of implementing procedures appropriate to ensure compliance with the actual reporting requirements without the addition a formal requirement to annually review their internal procedures with personnel. In the unlikely event that an entity cannot attain this level of operating competence without implementation of a new requirement, such Entities would be subject to enforcement under Requirement R5. Absent substantial evidence of systemic problems by Entities in contacting local law enforcement properly or failures to complete event reports to appropriate agencies when provided with clear guidance on the events to be reported, this requirement is unnecessary.
No
The use of DOE OE-417 is acceptable, but the language of Requirement R5 should be modified. The disturbance event form must be filled out correctly, irrespective of the requirements of an Entity's "Impact Event Operating Plan". Reference to that Plan does not add clarity to the requirement to report events. The requirement should delete the reference to the "Impact Event Operating Plan" and simply state: Each Responsible Entity shall report events listed in Attachment 1 using the provided form, or where also required to complete the current version of DOE OE-417, that form. Although one of the primary stated purposes of the original SAR was to simplify the reporting process by creating a single form, the fact that some entities are already required to report substantially identical information to DOE argues for retention of the use of the DOE form.
No
1. Additional clarity on the nature of reportable "Fuel Emergencies" is needed. Does loss of interruptible gas transportation require reporting? 2. Additional clarity on the threshold for "damage or destruction of BES equipment" is needed. Footnote 1 on page 16 states, in part "Significantly affects the reliability margin of the system (e.g. has the potential to result the need for emergency actions". For generating facilities, does this statement refer specifically to the parallel requirement to report any loss of generation $\geq$ 2,000 in the Eastern or Western Connection or $\geq$ 1,000 in the ERCOT or Quebec Interconnection" If not, exactly what level of damage at a generating plant requires reporting? Use of imprecise terms such as "significantly" sets the stage for future compliance and enforcement confusion. 3. Additional clarity is required for "Detection of reportable Cyber Security Incident". Is this item intended to apply only to Critical Cyber Assets, or is it an extension of the requirement to all applicable entities irrespective of their Critical Asset status? If it applies only to Critical Cyber Assets, does this reporting requirement create redundant reporting (as reporting is already required under CIP-008-4)? CIP-008-4 requires reporting only of events affecting Critical Cyber Assets. If a more expansive application is intended, what equipment or systems are to be included in the reporting requirement?
No
Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. The measure for Requirement R5 should focus on the need to report accurately and promptly, not on a Responsible Entity's "Operating Plan". If the Requirements are retained, the measures should state in much greater detail what actions and documentation are required for compliance.
No
Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. If retained, the violation risk factors should be low for those Requirements, as they all simply support the requirement to actually report correctly stated in Requirement R5.
No
Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. If retained, the violation risk factors should be low for those requirements, as they all simply support the requirement to actually report correctly stated in Requirement R5.
Focusing on reporting of actual disturbance events as listed in Attachment 1 based on potential or actual impact to the Bulk Electric System will provide maximum benefit to system reliability without adding needless levels of new documentation generated to demonstrate compliance. Absent significant evidence of systemic problems in the industry with past reporting attributable to causes other than a lack of clear guidance on the types events that require reporting, the proposed Standard should focus on the single issue of correct reporting, without attempting to micromanage how Entities internally manage such reporting.
Group
Dominion
Louis Slade
No
It is not evident how Impact Event reporting will "improve industry awareness" as suggested in the Purpose Statement. The transfer of Requirement R8 (ERO quarterly report) to the Rules of Procedure (paragraph 812) invalidates that claim within the context of this standard. Suggest removing this phrase from the Purpose Statement.

Yes
Dominion agrees with the proposed definition of Impact Events, but notes the use of the phrase "has the potential to impact" is somewhat subjective. The concern being a Responsible Entity makes a judgment on an event's potential impact that is viewed differently after-the-fact by an auditor.
Yes
No
1) Several of the events require filing a written Impact Event report within one hour. System Separation, for example, is going to require an "all hands on deck" response to the actual event. We note that the paragraph above Attachment 1, Part A indicates that a verbal report would be allowed in certain circumstances, but this is the same issue with the formal report in that the system operators are concerned with managing the event and not the reporting requirements. Another example would be the Loss of Off-site power to a nuclear generating plant. Suggest reconsideration of one hour reporting requirement for events requiring extensive operator actions to mitigate; 2) Several events seem to have the "Threshold for Reporting" contained in footnotes rather than in the table. For example, Damage or destruction of BES equipment – Footnote 1, Fuel supply emergency – Footnote 2, etc.) Suggest moving the actual threshold into the table; 3) If one hour reporting remains as indicated in Attachment 1; align/rename events similar to that of the 'criteria for filing' events listed in DOE OE-417 for consistency.
Yes
No
The requirement for Responsible Entities to establish an Impact Event Operating Plan, Operating Process, and Operating Procedure seems overly cumbersome and prescriptive. The use of these NERC defined terms create additional compliance burden for little, if any, improvement to reliability. Suggest simplification by requiring the Responsible Entities to have a procedure to report Impact Events, to the appropriate parties, pursuant to EOP-004. In addition, we request clarification of R1.4. It seems circular to us in that it requires the plan to be updated within 90 days of when it changes. Is the intent that any necessary changes identified in the annual review required by R4 be incorporated in a revision to the plan within 90 days of the review? If so, R1.4 belongs under R4. If not, we do not understand the requirement. What starts the 90 day count down?
Yes
Dominion agrees subject to the comments provided in Question #6. In addition, Requirement R2 appears duplicative of Requirement R5. Suggest R2 be clarified relative to the intent.
No
: The need to conduct a test of its Operating Process has not been established and is overly restrictive given that the purpose of the standard is to report Impact Events.
No
The need to periodically review its Impact Event Operating Plan has not been established and is overly restrictive (annually) given that the purpose of the standard is to report Impact Events. Suggest removing this requirement
No
Dominion does not agree because the Requirement is too restrictive giving the Responsible Entity the choice on reporting forms as either Attachment 2 or DOE OE-417. The use of Attachment 2 or DOE OE-417 may be appropriate when reporting to NERC, however, Requirement R 1.3.2 requires the Responsible Entities Impact Event Operating Plan to address notifications to non-NERC entities such as Law Enforcement or Governmental Agencies. It is likely that these organizations have specific reporting requirements or forms that will not line up the options prescribed in Requirement R5. Suggest revising Requirement R5 to not require the use of these two forms as the only options. If these 2 forms are used; suggest aligning the Event names in Attachment 1 to be similar to the 'criteria for filing' event names in the DOE OE-417 to allow for consistency. Also suggest aligning the 'time to submit' for similar event names in each form.
No
1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would appear to overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004.
No
1) M1 is open ended. Suggest adding "on request" to the end of the sentence as written; 2) M4 requires evidence of "when internal personnel were trained; however, Requirement R4 does not require training.
No
All the VRFs are "Medium". Since the requirements deal with after-the-fact reporting and the administration of reporting

plans, procedures, and processes; all VRFs should be "Lower".
Yes
Yes
Dominion agrees with the Implementation Plan; however, notes that the title for EOP-004-2 is inconsistent with the actual proposed standard.
The following comments are provided on the Reporting Hierarchy for Impact Events EOP-004-2: 1) A reference to sabotage still exists in a "decision block"; 2) The "entry block" only specifies "actual Impact Events" and does not address "potential"; 3) Hierarchy is misspelled in the title. Attachment 2: Impact Event Reporting Form; in questions 7, 8, 9, 10, 11 what is the purpose of the *(asterisk) behind each Task that is named?
Individual
Bill Keagle
BGE
1 - Transmission Owners
No
BGE believes that using the term "Impact Events" as currently defined is too vague. An alternative statement would be "... requiring the reporting of events listed in Attachment 1 and their causes, if known ..." and making the definition change as noted in question 2.
No
Change the definition of "Impact Event", to add the following phrase to the definition "Any event (listed in Attachment 1) which has either...". Also, the phrase "... or has the potential to impact the reliability..." is too vague and broad. Such broad statement is unhelpful in clarifying entities' compliance obligation and potentially creates conflicted reporting between entities. A clear statement of how the reliability is affected should be used, i.e., results in contingency emergency situation or IROL.
Yes
No comments.
Yes
No comments.
Yes
No comments.
No
This seems overly restrictive in its use. Requirement is now telling entities how to resolve situations, not giving them a requirement to resolve the situation.
Yes
No comments.
No
Requirement 3 (formerly R4) should be removed altogether because it is covered by the new R4. The topic of Disturbance Reporting is covered several times each year during operator training classes and the operators are tested on the material. Actual issued Disturbance Reports throughout the year are also covered during training class.
Yes
No comments.
No
Language needs to be more specific on when to use Attachment 2 or DOE-OE-417.
No
For the following Events (Damage or destruction of BES equipment, Damage or destruction of Critical Asset, and Damage or destruction of a Critical Cyber Asset), submitting a report within 1 hour after occurrence is identified is too short of a time frame. Generally, the initial time period is spent in recovering from the situation and restoring either electric service or restoring computer services to assure proper operations. To distract from the restoration to normal activities to focus on a report would be detrimental to reliability. Notification of an event may perhaps be made by phone call within 1 hour but completing a report should be required no less than 6 or 12 hours. Determining a cause (especially external or intentional) could take longer than 1 hour to determine and complete a report. It is important to consider the imposition created by a compliance obligation and weigh it against the other demands before the operator at that time. A compliance obligation should avoid becoming a distraction from reliability related work. Under impact event type scenarios, in the first hour of the event, the primary concern should be coping with/resolving the event.
No position or comments.
Yes

No comments.
Yes
No comments.
No position or comments.
Yes
No comments.
Please provide a Mapping Document which shows where the four CIP-001 requirements map to in the new EOP-004-2, and note if any of the CIP-001 requirements have been eliminated. A Mapping Document was provided during the first Comment Period, but not during the second Comment Period. A Mapping Document will be very helpful to companies in aligning standard owners in reviewing this proposal and in transitioning compliance programs when the revised standard is approved.
Group
We Energies
Howard Rulf
Yes
No
From an on-line dictionary, an event is "something that happens". Combined with the phrase "has the potential to impact" and the definition of Impact Event would include every routine operation performed by any entity. Taking a generator on or off line, switching a transmission line in or out, traffic driving past a substation, all have the "potential to impact" the BES. The Impact Event definition is overly broad and needs to be significantly narrowed.
Yes
No
Attachment 1: From the NERC Glossary, an Energy Emergency: A condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements. The first four events listed can only apply to an LSE. Loss of Firm Load for >15 Minutes: By the NERC Glossary definitions of DP and LSE, the LSE would seem to be more appropriate than the DP. With the proposed one-hour reporting requirement, the industry would be undertaking significant regulatory risk with respect to timely reporting. The requirement to report the crime-based events in the field within one hour, as shown in Attachment 1 Part A or Part B will be difficult. We could even discover a theft in progress with the suspect trapped inside the substation fence and the police attempting to make a safe arrest. We need more reporting time, especially when they have not even resulted in an outage. The industry is keenly interested in understanding the benefit of taking on the risk. What analysis, insight, warnings or recommendations would the ES-ISAC provide to the reporting entity, the industry or to law enforcement agencies in the hours after such an incident is reported? Note too that DOE requires reporting of a physical attack within one hour only when it "causes a major interruption or major negative impact on critical infrastructure facilities or to operations." In lesser cases, the entity gets up to six hours if it "impacts electric power system reliability". DOE has said that it is not interested in copper theft unless it causes one of these events. If the SDT is working to ensure consistency of reporting requirements, please consider DOE requirements too. Meeting the reporting deadline will mean that available resources in the control center will be devoted to ensuring the report is filed on time instead of making the site safe and arranging for prompt repair. It may even mean that law enforcement won't be contacted until the forms are filed with the ES-ISAC. The exception contained in footnote #1 of Attachment 1 with respect to copper theft is not an exception at all. The majority of copper theft from substations is, in fact, such grounding connectors which may or may not render the protective relaying inoperative. You could end up receiving reports from all over the USA, Canada and Mexico, mostly on Monday mornings as weekend copper thefts are discovered. Attachment 1 Part A table also contains redundancies. One of the cells reads, "Damage or Destruction of Critical Asset". One cannot destroy something without damaging it first. Consequently, it is sufficient to simply say, "Damage to a Critical Asset". Apply to all cells with the same phrase.
Yes
No
R1.2: By its NERC Glossary definition, an Operating Procedure is too prescriptive for data collection. An Operating Procedure requires specific steps to be taken by specific people in a specific order. We would have to predict every event that could happen to have every step in proper order to collect the data. It will be impossible to comply with this requirement. R1.3: Change "Impact Event" to "Impact Event listed in Attachment 1".
Yes
No
A test of the Operating Process for communication would be placing telephone calls. This requirement would have virtually every entity in North America calling NERC, Regional Entities, FERC/Provincial Agency, Public Service



Commission, FBI/RCMP, local Police, etc. annually. Every entity will probably be asking for a confirmation letter from each telephone call for proof of compliance. This is an unnecessary requirement. Delete it.
No
Include that this is for internal personnel as stated in the associated measure.
Yes
No
It appears that the footnotes only apply one place in the table. Place the footnote in the table where it applies. Voltage Deviations on BES Facilities: 10% compared to what? Rated? Forced Intrusion: "At a BES facility" facility or Facility?
No
M1 contains a redundancy: It currently reads, "Each Responsible Entity shall provide the current in force Impact Event Operating Plan to the Compliance Enforcement Authority." ("In force" is the same as "current".) M2: Change "Impact Event" to "Impact Event listed in Attachment 1". M3: This is an additional requirement. R3 does not require a mock Impact Event. R3 requires a test of the communicating Operating Process. As stated above, R3 and M3 should be deleted. M4: This is written assuming classroom training. R4 does not require formal training much less classroom training. R4 requires that those (internal) personnel who have responsibilities in the plan review the Impact Event Operating Plan. M5: When we report, how do we show to an auditor that we reported "using the plan"? Delete the reference to "the plan".
No
All VRFs should be Lower. They are all administrative and will not affect BES Reliability.
No
Change the VRFs as indicated above and the Time Horizons as indicated below.
No
R2 and R5 should be Operations Assessment.
Yes
Attachment 2: What do the asterisks refer to? I didn't see a comment or description related to them. #7 & #10: What is "tripped"? Automatic or manual or both. #13: This report has no Part 1. Flowchart: By the flowchart, the only time an OE-417 is filed is when I do not need to contact Law Enforcement. The Reporting Hierarchy flow chart should be modified. In the lower right corner it indicates that if sabotage is not confirmed, the state law enforcement agency investigates. Law enforcement agencies will not investigate an incident that is not a crime. Note too that state law enforcement agencies do not even investigate these kinds of events unless and until requested by local law enforcement. The local law enforcement agency always has initial jurisdiction until surrendered or seized by a superior agency's authority. Evidence Retention is incomplete. From the NERC Standards Process Manual: "Evidence Retention: Identification, for each requirement in the standard, of the entity that is responsible for retaining evidence to demonstrate compliance, and the duration for retention of that evidence."
Individual
Kenneth A Goldsmith
Alliant Energy
4 - Transmission-dependent Utilities
Yes
No
The proposed definition is not supported by any of the established "bright line" criteria that are contained within attachment 1. This Results Based Standard should close any loop-holes that could be read into any section, especially the definition. We recommend the definition be enhanced to read: "Impact Event: Any Contingency which has either effected or has the potential to effect the Stability of the BES as outlined per attachment 1. Within this enhanced recommendation, presently defined NERC terms are used (Contingency and Stability), thus supporting what is current used within our industry. There is also a quantifiable aspect of "as outlined per attachment 1" that clearly defines Impact Events. If the above definition is not adopted, we believe it should be rephrased to narrow the scope to "those events that result from malicious intent or human negligence/error." We are concerned that by using phrases like "unintentional or intentional human action" in combination with "damage or destruction" basically means everything except copper theft becomes a reportable impact event (including planned actions we must perform to comply with CIP-007 R7).
Yes
Yes

Yes
Yes
This is a NERC defined term and will assist entities in maintaining compliance with this (proposed) Standard. We believe the reference to Attachment 2 in R1.2 should be revised to the DOE Form and utilize only one reporting form, if at all possible.
Yes
Yes
Yes
No
We believe Attachment 2 should be deleted, and NERC should work with the DOE to have one form for all events, if possible. It makes the reporting procedure much simpler, only having to use one form.
No
The item relating to Loss of Firm Load for > 15 minutes should be revised to 500 MW and 300 MW. For many companies, a storm moving across their system could cause more than 300 MW of firm load to be lost, but there is no impact on the BES, so why does the detailed reporting need to be done? The items relating to "damage or destruction" need to be revised to not be so wide. As currently written, a plan by a company to raze a facility could be considered a violation and must be reported. We believe it needs to be tightened to malicious intent or human negligence/error.
Yes
Yes
Yes
Yes
Yes
Group
Pepco Holdings Inc and Affiliates
David Thorne
Yes
No
The two sentence definition will not be adequate to serve well over the course of time. People will have to read and understand the standard without benefit of the detailed information, explanations and interpretations available during the standards development process. Without additional explanation as provided in the background and the guideline and technical basis sections, to support the definition, the standard will be subject to confusion and interpretations. Consider adding a lot of the information and explanation that is in those sections to the standard. Any event could be an impact event. However, only a subset is reportable. What is really being addressed are reportable events. More specifically after the fact reporting of unplanned events.
No
See #2. With out the explanation contained in background information, over time those that have not been involved with this standard development will struggle with how to interpret the code words of non environmental and intentional human action.
Yes
More guidance is needed for which entity in Attachment 1 actually files the report to avoid duplicate filing.
Yes
Agree that NERC should not have requirements applicable to them.
No
An Operating Plan, Operating Process or Operating Procedure implies something different than an after the fact reporting activity.

Yes
Yes
Yes
Yes
No
The entity responsible for reporting is not clear. Is the initiating entity the same as requesting entity or implementing entity? In the paper it indicates the DT intent is for the entity that performs the action or is directly affected will report. It seems that the proposal would result in a significant amount of duplicate reporting.
Yes
No
This standard involves after the fact reporting of events. Other standards deal with the real time notifications. How do the risk factors between the two line up? A VRF of Low would seem appropriate, since a violation would not affect the reliability of the BES.
No
This standard involves after the fact reporting of events. Other standards deal with the real time notifications. How do the severity level between the two line up? See above VRF comments.
Yes
However, do they line up with the corresponding real time reporting procedures as mentioned above, #13 and #14?
No
The proposed time line is too short. It is easy to revise procedures. However developing training and integrating the training into the schedule takes time. Shorter time frame takes away adequate time to integrate into the training plan and disrupts operator schedules. Since notifications already exist and after the fact reporting does not impact BES reliability, why the need to expedite? There are many other training activities that must be coordinated with this.
IRO-000-1, Sec D1.5 and TOP-007, Sec D1.1 there are "after the fact" reporting requirements for IROL violations. Since IROL violations are included in this standard, should those standards be modified? Should the standard include a specific statement that this standard deals only with after the fact and other standards deal with real time reporting? Since this standard deals with after the fact reporting, consideration should be given to extending the time to report as defined in Attachment 1. One hour does not seem to be reasonable.
Individual
John Brockhan
CenterPoint Energy
1 - Transmission Owners
Yes
No
CenterPoint Energy suggests that the phrase "...or has the potential to impact..." be deleted as it makes the definition vague and broad. Similar issues encountered in trying to define sabotage may resurface, such as varying definitions or interpretations of "potential". If this standard is to support after-the-fact reporting, the focus should be on actual events, not potential situations or events. Effective and efficient prevention would come from analysis of actual events. Resources and reporting could become overwhelmed upon having to consider "potential". All references to "potential" should be removed from the standard, guidance, and attachments.
No
CenterPoint Energy would agree if the definition for Impact Event was changed as suggested in the response to Question 2.
Yes
Yes
No
CenterPoint Energy recommends deleting the current R2 as it is an inherent part of the current R5. For an entity to

“report Impact Events in accordance with the Impact Event Operating Plan pursuant to R1” (see R5), the entity must “implement its Impact Operating Plan documented in Requirement 1...” (see R2). Including both requirements is unnecessary and duplicative. Likewise, M2 should be deleted.

Yes

Yes

Yes

CenterPoint Energy agrees with the idea of streamlining the reporting process through the use of existing report forms. However, as noted in the response to Question 11, the Company has concerns about the DOE OE-417 Form, specifically the timeframes in which to submit reports. CenterPoint Energy will be making the same recommendation to extend reporting timeframes during the DOE OE-417 report revision process when the current form expires on 12/31/11. Any future changes to the DOE Form could also impact reporting for this requirement.

No

(1) CenterPoint Energy believes that the “Entity with Reporting Responsibility” for the first three events in Part A should be clarified. There could still be confusion regarding the “initiating entity” for events where one entity directs another to take action. From the text on page 5 of the Unofficial Comment Form, it appears that the SDT intended for the “initiating entity” to be the entity that takes action. To make this clear in Attachment 1, CenterPoint Energy recommends replacing “initiating entity” with “Each (insert applicable entities) that (insert action). For example, for “Energy Emergency requiring a Public appeal” the Entity with Reporting Responsibility should be “Each...that issues a public appeal for load reduction”. (2) Part A: The threshold for reporting “System Separation” should not be fixed at greater than or equal to 100 MW for all entities, but rather should be scaled to previous year’s demand as in “Loss of Firm load for greater than or equal to 15 minutes”, so that for entities with demand greater than or equal to 3000 MW, the island would be greater than or equal to 300MW. (3) Part A: The one hour reporting requirements are unreasonable and burdensome. The Background text indicates that “proposed changes do not include any real-time operating notifications...” CenterPoint Energy believes all one hour reporting requirements could potentially divert resources away from responding to the event. In many instances the event may still be developing within one hour. Likewise, the 24 hour reporting requirements are also burdensome. CenterPoint Energy recommends changing all reporting requirements to 48 hours. CenterPoint Energy acknowledges that the DOE OE-417 report requires certain one hour and 6 hour reporting. Those requirements should also be extended, and CenterPoint Energy will be making the same recommendation during the DOE OE-417 report revision process when the current form expires on 12/31/11. (4) Part B: CenterPoint Energy is very concerned with the “events” listed under Attachment 1 – Potential Reliability Impact – Part B and believes Part B should be deleted. These arbitrary “events” with “potential reliability impact” and reporting times place unnecessary burden on entities to report “situations” that would rarely impact the reliability of the BES. Entities should be aware of developing situations; however, this standard should not require reporting of such occurrences. (5) Part B: Of particular concern is the overly broad “Risk to BES equipment” and the example provided in the footnote. CenterPoint Energy believes the SDT has already identified the events with the greatest risk to impact the BES in Part A. Also including “potential reliability impact” situations in Part B inappropriately dilutes attention away from the truly important events. The industry, NERC and FERC should not lose sight of the forest for the trees.

No

M1: CenterPoint Energy recommends that the phrase “current in force” be updated to “current” or “currently effective”. Additionally, CenterPoint Energy suggests clarifying M1 by adding “within 30 days upon request”, which would be consistent with language found in measures in other standards. The revised measure would read, “Each Responsible Entity shall provide the currently effective Impact Event Operating Plan to the Compliance Enforcement Authority within 30 days upon request.” M2: If R2 is deleted (as recommended in response to Question 7), then M2 should be deleted.

No

CenterPoint Energy believes that the Severe VSL for R5 (Reporting) in the current draft incorrectly equates 2X reporting with failure to submit a report. CenterPoint Energy believes the VSLs for R5 should all reflect a factor increase in time. For example, the lower VSL should be 1.5X the reporting time frame. The Moderate VSL should be 2x the reporting time frame. The High VSL should be 3x the reporting time frame. The Severe VSL should be failure to report.

Yes

No

CenterPoint Energy prefers the previously accepted timeline of 1 year.

CenterPoint Energy believes the flowchart found on page 8 identifying the reporting hierarchy for EOP-004 is helpful. CenterPoint Energy believes the DOE reporting items should also be included on the right side of the chart. Some of the issues with CIP-001 were a result of law enforcement’s preference and procedures for notification. Law enforcement’s preferences and procedures should be considered for this draft. (Reference: <http://www.fbi.gov/contact-us/when>)

Individual
Martin Kaufman
ExxonMobil Research and Engineering
1 - Transmission Owners, 5 - Electric Generators, 7 - Large Electricity End Users
Yes
No
The use of the word potential is ominous.
Yes
Yes
No
Obstain from commenting on this question.
No
The requirement to notify State Law Enforcement deviates from existing government security requirements that Petrochemical Facilities (Cogenerators) are required to follow. Per the Maritime Transportation Security Act of 2002 (MTSA) and the Chemical Facility Anti-Terrorism Standard (CFATS), Petrochemical Facilities are required to report the security incidents identified in EOP-004 Revision 2 to the National Response Center which is staffed by the United States Coast Guard. The National Response Center coordinates incident reporting to both the Department of Homeland Security and Federal Bureau of Investigation. Requiring Petrochemical Facilities to report security incidences to State Law Enforcement agencies duplicates their reporting of incidences to the appropriate law enforcement agencies. EOP-004 Revision 2 should be modified to synergize with existing federal security regulations so that those facilities that are required to comply with the MTSA and CFATS are, by default, compliant with EOP-004 Revision 2 when they comply with these existing federal security regulations. It is unclear, from the documentation provided in this revision of EOP-004, which entities a Responsible Entity is required to notify when certain types of Impact Events occur. Previously, CIP-001 included a similarly vague instruction that required notifications to the 'appropriate parties in the interconnection' and the FBI/RCMP. The Standard Drafting Team should identify which NERC Functional Entities should be notified when each of the Impact Events identified in Attachment 1 occurs. Current revisions of CIP-001 Revision 1 or EOP-004 Revision 1 do not include corresponding requirements to update procedures within a certain time frame. It's difficult to foresee a situation where an Entity would initiate a change to its response plan without being required to update the formal response plan documentation per their management of change process. Additionally, failure to update the procedure would result in the entity deviating from the procedure any time an impact event occurred, which would automatically force a violation of EOP-004-2 R2 for failure to properly implement their Operating Process. Furthermore, the only changes occurring between review cycles should be revisions to the contact information for third parties. It is beyond an entity's power to require third parties to notify the entity when the third party changes their contact information, and, as such, this requirement burdens registered facilities with responsibility for compliance for items that are beyond their realm of control.
No
The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notifications windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of the situation and determine the extent of the problem. The existing standard's requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].
No

The annual (15 month) time window for conducting annual performance tests appears to be reasonable. However, the required scope of the test is vague. The Standard Drafting Team should modify the testing requirement to include boundary criteria such as whether notifications to third parties and law enforcement are required or if the test is limited to internal notifications and response processes. Furthermore, the current measure associated with this requirement, EOP-004 Revision 2 Measure 3, implies, that if an Impact Event occurs, the registered entity can count the activation of its Impact Event Operating Plan as a test and extend the test window 15 months from the date of activation. The Standard Drafting Team should revise the requirement to clarify that the test window resets when a site initiates its Impact Event Operating Plan in response to a real Impact Event as requirement criteria should not be included in a measure.

No

It's unclear whether R4 is a training requirement to train all individuals who may be required to implement its Impact Event Operating Plan on an annual basis or a requirement for an Entity to review the Impact Event Operating Plan with at least one person from each position that has a role in the Impact Event Operating Plan in order to complete a quality review of the Impact Event Operating Plan. The SDT should clarify the intent of the requirement. If the intent is that both of the aforementioned interpretations is expected to occur, the SDT should break R4 into two requirements so that an entity is not violation of Requirement R4 when the entity fails to comply with one of the two imbedded requirements (e.g. if the quality review is not performed but all individuals were trained).

No

The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notifications windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of the situation and determine the extent of the problem. The existing standard's requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].

No

The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notifications windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of the situation and determine the extent of the problem. The existing standard's requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].

No

Measure M3 introduces a pseudo-requirement by implying you are able to reset the testing clock if you implement our

Impact Event Operating Plan in response to an Impact Event. This should be covered in Requirement R3. Measure M4 should refer to positions and evidence that people occupying those positions participated in the annual review of the Impact Event Operating Plan. Given the number of individuals involved in operations and the cycle of promotions and reassignments, it's unreasonable to expect an entity to identify specific individuals in their Impact Event Operating Plan. As the one hour time window is not long enough for entities to report all types of events when responding to the impact the Impact Event had on its facility, Measure M5 should be modified to include voice recordings and log book entries to capture verbal information reported to required parties.
No
VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more appropriate for this requirements of this standard.
No
VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more appropriate for this requirements of this standard.
No
VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more appropriate for this requirements of this standard.
Recommend 4th calendar quarter instead of 3rd.
Group
SPP Standards Review Group
Robert Rhodes
No
We would suggest changing the purpose to read 'To improve industry awareness and effectiveness in addressing risk to the BES by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.'
Yes
Yes
No
While the SDT has recognized the issue of applicability to GO/TO in its background information with the Unofficial Comment Form, we still do not feel comfortable with the GO/TO being listed as a responsible entity when in fact it may be days before they become aware of an event worthy of reporting. If the GOP/TOP makes the report, are the GO/TO still responsible for filing a report? If the GOP/TOP do not file the report, would the GO/TO then be non-compliant? This issue appears to put additional risk on the GO/TO over which they have no control. We need some mechanism to eliminate unnecessary risk while at the same time ensuring that we have coverage for the BES. Perhaps this could be done through delegation agreements between the entities involved or through allowances within the standard itself. For example, could the phrase 'appropriate parties in the Interconnection' as currently contained in CIP-001-1, R2 be incorporated into the standard to basically replace GO/TO?
Yes
No
We would suggest rewording Part 1.3.2 to read 'External organizations to notify may include but are not limited to the Responsible Entity's Reliability Coordinator, NERC, Responsible Entity's Regional Entity, Law Enforcement and Governmental or Provincial Agencies. We would also suggest the following for Part 1.4: 'Provision(s) for updating the Impact Event Operating Plan within 90 days of any known changes to its content.' Would also suggest adding 'as requested' at the end of M1.
Yes
No
The SDT included a formal review process in the discussion of R4 in the Background Information in the Unofficial Comment Form as one of three options for demonstrating compliance with the testing requirements of R4, yet M3 only contains two of those options – a mock Impact Event exercise and a real-time implementation of its Operating Process. The third option, a formal review process, is missing from M3 and needs to be added. We would suggest the following for M3: 'In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 or conducted a formal review of its Operating Process. The time period between tests, actual Impact Events or formal reviews shall be no more than 15 calendar months. Evidence may include, but is not limited to, operator logs, voice recordings or documentation.
No

There is confusion surrounding the use of the term 'review' in R3 and R4. In R3 and the suggested revision to M3 in Question 8, review is an analysis of the plan by a specific group tasked to determine if the plan requires updating or modifying to remain viable. Review in R4 has training connotations for all personnel who have responsibilities identified in the plan. Although we understand the use of 'review' in R4 is new to this version of EOP-004-2, we believe it may be more appropriate to use training rather than review in R4. And further, we feel the training should be focused on those specific portions of the plan that apply to specific job functions.

No

We feel there is redundancy between R2 and R5. To eliminate this redundancy, we propose to take the phrase '...using the form in Attachment 2 or the DOE OE-417 reporting form' and adding it at the end of R2. Then what's left of R5 could be deleted. The new R2 would read 'Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B) using the form in Attachment 2 or the DOE OE-417 reporting form.'

No

Threshold for Reporting – Some of the thresholds used to trigger event reporting seem arbitrary. For example, why were three BES Transmission Elements selected for the transmission loss trigger? What's significant with three? There may be situations where one element can impact reliability more than other situations where three or more lines may be lost. The defining line should be impact to reliability, not a simple count of elements. Also, timing of the loss of these elements is important. If the three elements are lost over a 3-day span, does this trigger an event report? We would think not and would like to see that clarification in the standard. Public appeals – Some entities may utilize load reduction (Demand Response, interruptible loads, etc) in the normal course of daily operation in lieu of committing additional generation resources. Because this is not an Energy Emergency as defined in the NERC Glossary, would such an event trigger the filing of an Impact Event report under EOP-004-2? We would like clarification on this issue. Multiple entity reporting responsibility – Several of the triggering events in Attachment 1 list multiple entity reporting responsibility. The SDT needs to clarify precisely who has the actual reporting responsibility for those events. For example, if a DP loses  $\geq 300$  MW (or  $\geq 200$  MW depending on size) of load who files the report? Is it the DP, TOP, BA or RC? Attachment 1 would lead us to believe all four are required to file reports. This redundancy is unnecessary and creates unneeded paperwork. Surely this redundancy is not the intent of the SDT. Reporting timeframe – The timeframes for reporting these after-the-fact reports need to be thoroughly reviewed and, we believe, realigned. Which is more important to the reliability of the BES, operating and controlling the BES following an Impact Event or filing a report describing that event? Most operating desks are staffed by a single operator at nights and on weekends. Their focus should be on operating the system, not filing a report with NERC or DOE within one hour. There appears to be inconsistency in the reporting times among the triggering events. There doesn't appear to be any logic regarding how the times were selected. Shouldn't impact to the reliability of the BES be that basis? Why is a BA with 50 MW of load who makes a public appeal to customers for load reduction required to report within 1 hour while an IROL violation doesn't need to be reported for 24 hours? Clearly the IROL violation has a greater impact on the reliability of the BES. Therefore, shouldn't these types of reports be filed sooner than those events with less impact on BES reliability? Risk to BES equipment – The Threshold for Reporting this event indicates that only those events associated with a non-environmental physical threat should be reported. The train derailment example in the footnote then conversely describes just such an environmental threat with flammable or toxic cargo. Which should it be? Additionally, how does one determine the applicability of a potential threat? Is this time dependent, is it threat dependent, how do we factor all this in?

No

The measures are written as if they are adding requirements to the standards. Using wording such as 'shall provide' gives this implication. We would suggest wording such as 'examples of acceptable evidence to demonstrate compliance may be...' See Question 6 for comments regarding M1. See Question 8 for comments regarding M3.

No

These are reporting requirements and therefore do not deserve the 'medium' VRF. We suggest making the VRFs for all requirements for EOP-004-2 'low'.

No

Requirement 4: We would suggest the following: Low – The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 15 calendar months but less than 18 calendar months since the last review. Moderate - The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 18 calendar months but less than 21 calendar months since the last review. High - The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 21 calendar months but less than 24 calendar months since the last review. Severe - The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan within 24 calendar months since the last review. Requirement 5: With our suggested deletion of Requirement 5, we further suggest deleting the VSLs associated with Requirement 5.

No

Based on our previous comments in response to Question 11, we feel that the Time Horizon for R2 should be lengthened. Assigning it a Real-time Operations and Same-day Operations timeframe has too much of an impact on



real-time operations. Pushing it back will allow support personnel to do the after-the-fact reporting and keep this burden off of the operators.

Yes

In Attachment 2 just before the table, the statement is made that 'NERC will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report.' But the last sentence in the Guideline and Technical Basis white paper, it is stated that ' For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.' These are in conflict with each other. Which is correct? We prefer the former over the latter. In Attachment 2 in Tasks 7-11 an asterisk appears in those tasks. To what does this asterisk refer?

Individual

Brenda Truhe

PPL Electric Utilities

1 - Transmission Owners

Yes

Yes

PPL EU agrees with the definition. We would like to point out that our interpretation of the definition excludes maintenance work. Our interpretation also concludes that maintenance work that does not go as planned or goes awry and impacts the reliability of the BES would be an impact event and reported as required per Attachment 1.

Yes

Yes

Yes

Yes

Yes

Yes

Yes

Yes

We would like to suggest the language be changed such that 'submission via a NERC system' would be acceptable in addition to the use of the Attachment 2 Form or the DOE OE-417 form. The standard would then accommodate the proposed revision to NERC Rules of Procedure 812. '...NERC will establish a system to collect impact events reports...'

No

We very much appreciate the work performed by SDT and consideration of all the comments received. While we agree with the majority of the Attachment 1 changes, we suggest the SDT add further clarification to Attachment 1, Part A, Event 'Transmission Loss'. Does this mean permanent loss? Do two lines and a pole constitute a loss of three elements? E.g. Consider the loss of a 230 kV line with two tapped transformers. This does not have a significant effect on the BES, yet would it be reportable? We would prefer Attachment 1, Part A, 'Threshold Reporting' be clarified. E.g. 'Three or more "unrelated" pieces of equipment for a single event'.

Yes

Yes

Yes

We thank the SDT for addressing so many Industry concerns with the 2010 draft of EOP-004-2. We feel the current draft version of EOP-004-2 is a significant improvement over current EOP-004-1 and CIP-001-1 standard and the

previous draft. Thank you for your time.
Individual
Tim Soles
Occidental Power Marketing
3 - Load-serving Entities
Yes
No
The SDT includes in the definition the "potential to impact the reliability of the BES." This seems vague, although Attachment 1 clarifies what actually has to be reported. An LSE may have limited or no knowledge of "potential to impact." The SDT may want to refine the definition, e.g., "to the extent the entities' knowledge could reasonably reveal the impact."
Yes
No
Load Serving Entities that do not own or operate BES assets (or assets that support the BES) should not be included in the Applicability. The SDT includes LSEs based on CIP-002; however, if the LSE does not have any BES assets (or assets that support the BES), CIP-002 should also not be applicable because the LSE could not have any Critical Assets or Critical Cyber Assets. It is understood that the SDT is trying to comply with FERC Order 693, Sections 460 and 461; however, Section 461 also states: "Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns." A qualifier in the Applicability of EOP-004-2 that would include only LSEs that own, operate or control BES assets (or assets that support the BES) would seem appropriate and acceptable to FERC.
Yes
Yes
However, only LSEs with BES assets (or assets that support the BES) should be included in the Applicability section of the standard.
Yes
However, only LSEs with BES assets (or assets that directly support the BES) should be included in the Applicability section of the standard.
No
We understand that this requirement is meant to comply with FERC Order 693, Section 466; however, there needs to be more specificity concerning what sort of "test" would be accepted for auditing purposes. Also, only LSEs with BES assets should be included in the Applicability section of the standard.
Yes
However, only LSEs with BES assets (or assets that directly support the BES) should be included in the Applicability section of the standard.
Yes
Yes
There does not appear to be any reportable events for LSEs that do not own, operate, or control BES assets (or assets that directly support the BES) in Attachment 1. This would support removing such entities from the Applicability.
Yes
In general, the measures are okay. However, as mentioned above for R3, there needs to be more specificity as to what is acceptable as a "mock Impact Event" for auditing purposes--especially for small entities such as LSEs that do not own, operate, or control BES assets.
Yes
Yes
Yes
Yes
Occidental Power Marketing appreciates the extensive work accomplished by the SDT and their responsiveness to

comments. Also, the presentation of this draft with its extensive explanation of the SDT's considerations during development of the draft were very helpful in preparing our comments.

Individual

Eric Ruskamp

Lincoln Electric System

1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators

Yes

No

As currently drafted, the proposed definition of "Impact Event" appears vague and provides entities minimal clarity in terms of distinguishing events of significance. Recommend the drafting team reference "Attachment 1: Impact Events Tables" within the definition to direct industry towards more specific criteria.

Yes

Yes

Yes

Yes

Yes

No

As currently drafted, requirement R3 states one must "conduct a test" whereas the associated Measure requests evidence that one "conducted a mock Impact Event". The Rationale box lends to further confusion by referencing a "drill or exercise" as a process to verify one's Operating Process. To avoid potential confusion between R3 and M3, as well as to maintain consistency with the Rationale box, recommend the drafting team replace the word "test" with "drill or exercise" within R3 and the associated Measure.

Yes

Yes

No

While LES supports the bright line criteria listed in Attachment 1 for reporting Impact Events, we have concerns regarding the reporting threshold for "Transmission loss". For Transmission loss of three or more Transmission Elements, LES supports the MRO NSRS' suggested wording of "Two or more BES Transmission Elements that exceed TPL Category D operating criteria or its successor."

Yes

Yes

Yes

Yes

Yes

Individual

Linda Jacobson

Farmington Electric Utility System

3 - Load-serving Entities

Yes

Yes

Yes
Yes
Yes
No
consider rewording 1.4; the wording implies a change to content already occurred, so it would be updated concurrently – consider, updating the plan within 90 days of discovery of content requiring a change?
Yes
No
The measure for R3 indicates an actual Impact Event would count as a test, consider aligning the requirement with the measure to clarify an Impact Event could be considered a test.
Yes
A review of the Impact Event Operating Plan can be interrupted as an informal examination of the plan. The measure for R4 indicates evidence of a review, parties conducting the review AND when internal training occurred. It should be clarified in R4 training is expected as part of the review for personnel with responsibilities. This is an improvement from the previous 5.3 and 5.4; however, the team should consider adding back, 'review/training shall be conducted prior to assuming the responsibility in the plan.'
Yes
Yes
No
See comments in requirements for R3 and R4
Yes
Yes
Yes
Yes
Yes
Nine months would be preferred
Individual
Andrew Z Pusztai
American Transmission Company
1 - Transmission Owners
Yes
No
ATC does not agree with the proposed definition and further disagrees whether a definition is needed at all. Proposed Definition: The definition, read outside of the proposed standard, does not provide Registered Entities with a clear meaning of the purpose of the definition. It is ATC's opinion that the SDT is using the term "Impact Event" as an introduction phrase to Attachment 1. ATC would be more comfortable if the definition was dropped and the team would re-write the requirement to specifically point to Attachment 1. It is our opinion that this type of structure would achieve the goal of the team to get Registered Entities to report on events identified in Attachment 1. The other option is for the team to write into the definition that the events being discussed are limited to those identified in Attachment 1. Also the language currently being used in the definition includes "potential" and "such as". These terms should be struck from the definition.
Yes
No
First, under Part A, the reporting requirement for three or more BES Transmission Elements will create confusion. The NERC definition for an Element is: "Any electrical device with terminals that may be connected to other electrical

devices such as a generator, transformer, circuit breaker, bus section, or transmission line. An element may be comprised of one or more components.” This could be interpreted to be three potential transformers on a bus section; therefore, any bus section would require a report. It is suggested that this be reworded to indicate three or more BES transmission lines, bus sections, or transformers. Second, under Part A, the reporting requirement for “Damage or destruction of BES equipment” is too broad and needs to be modified. For example, an output contact on a relay could be damaged unintentionally during routine testing resulting in a reportable event. It is suggested that the list of BES equipment and full intent of this be further defined in the footnote. The intent needs to be clarified, such as “events that have an immediate and significant impact to the stability or reliability of the BES.” Third, under Part A, the reporting requirement for “Damage or destruction of a Critical Cyber Asset” is too broad and needs to be modified. For example, an output contact on a relay could be damaged unintentionally during routine testing resulting in a reportable event.

Yes

Yes

No

ATC does not agree with the proposed language in Requirement 3. ATC is concerned that, in order to demonstrate compliance, an entity will have to show that each step in the plan was followed which will likely leave entities facing the choice of choosing between different compliance violations. If the plan is not followed, but the report is made within the time given, then an entity is in violations of their plan. If the plan is followed, but the report does not get filed within the time allotted, then they face a possible violation of the time to report. ATC believes that the team should enforce the position that the report being filed in the time allotted is key, not that they necessarily follow and document that their plan was followed. Depending on the situation, the internal reporting will vary; however, based on the purpose of the Standard, the key is to get a report to NERC.

Yes

Yes

No

Attachment 2, Task #14 in the report should be modified to read, “Identify any known protection system misoperation(s).” If this report is filed quickly, there is not enough time to assess all operations to determine any misoperation. As a case in point, it typically takes at least 24 hrs. to receive final lightning data; therefore, not all data is available to make a proper determination of a misoperation

No

Energy Emergency requiring Public Appeal ATC believes that the phrase “initiating entity” is unclear and could be interpreted in multiple ways. 1) the entity has the authority to call for public appeals, 2) the entity has the authority to declare an Energy Emergency, or 3) the entity determines and identifies the need for the Energy Emergency Typically the BA’s call for public appeals, so does every BA that calls for the public appeal have to make a filing? The RC declares the need for an Energy Emergency, so are they the initiating entity? A TOP could also identify the need for public appeals and notify the RC about the request. In this case, is the TOP the initiating entity? Given the above examples, ATC believes that the SDT needs to clarify who is required to make the filing. Voltage Deviations on BES Facilities ATC believes that this should be clarified because one may assume that a loss of a single bus in which voltage goes to zero for more than 15 minutes is reportable. It is ATC understands that what the SDT means is a voltage dip, not an outage to a BES facility. However, given the brief description, ATC is not 100% sure whether there is a clear understanding of the standard’s intent. Energy Emergency resulting in automatic firm load shedding Please provide additional clarify. ATC believes that the SDT should not use the term “Impact Event” when identifying the entity with reporting responsibility. The term “Impact Event” is identified in the standard and points to Attachment 1 but now is being used outside of that context and requires entities to interpret what qualifies as an Impact Event. The above observation also applies to those other events that use the term “Impact Event” to describe Reporting Responsibility. Footnote 1: ATC would like the phrase “as determined by the equipment owner” added to the footnote. This simple phrase will allow entities to be sure that they are responsible for determining if the damage significantly affects the reliability margin of the system. Without this phrase, entities could be subject to non-compliance actions based on differences of opinions to the extent of the damage on the system. The other option the SDT has is to provide additional clarity on what qualifies as a significant affect. Time to Submit Report: ATC strongly disagrees with the 1 hour time to submit a report because it does not fit with the purpose of this standard. The purpose of this standard is to increase awareness, however, requiring a one-hour reporting window following the event provides little to no benefit. ATC believes that these events should have a 24 hour reporting window which allows for a reasonable amount of time to gather information and report the issue. If the SDT disagrees with this observation, ATC believes a complete explanation should be provided on why knowledge of an event within an hour is significantly better than having the knowledge of the event in a 24 hour time period. ATC strongly believes that NERC will gain as much or more knowledge of the event by giving entities time to understand the event and report.

Yes

Yes
Yes
Yes
Yes
Group
LG&E and KU Energy LLC
Brent Ingebrigtsen
No
In Attachment 1, the existing EOP-004-1 Attachment 1, point 6 includes an "Or" for the entities (RC, TOP, GOP) for a, b and c. The way the SDT has pulled this apart, they have included the GOP as having an impact on the Voltage Deviations on BES Facilities. The TOP monitors the transmission system and directs GOPs when they need to change in order to protect the system reliability. This is not something the GOP is responsible for monitoring. The GOP is required to be at the TOP assigned voltage schedule and that actually falls under VAR-002 already. Please remove the GOP from the line of "Voltage Deviations on BES Equipment." The way EOP-004-1 Attachment 1 point 6 is currently written, the GOP is an "or" and does fall into parts b or c, where part 6b is similar to the proposed line "Damage or destruction of BES equipment" identified in the proposed EOP-004-2 Attachment 1. However, currently the GO/GOP reports "Loss of Major System Components" on EOP-004-1 within 24 hours of determining damage to the equipment. The proposed "One hour" is too tight of a window as the GO/GOP often do not know the extent of damage that soon. Typically the OEM is called upon to come and do a thorough inspection and assess the extent of damage, of if there even is any damage; once the "loss of major system components" is determined, then the 24 hour clock begins today.
Individual
Michelle D'Antuono
Ingleside Cogeneration LP
5 - Electric Generators
Yes
The addition of the modifier "if known" to reporting the cause of an Impact Event is appropriate. It often proves counter-productive to speculate – as initial conjectures of the cause of an event are easy to come up with, but difficult to back out of later.
No
The SDT includes in the definition the "potential to impact the reliability of the BES". This seems vague, although ultimately the events which meet the threshold of a reportable Impact Event are governed by the tables under Attachment 1. We believe that there should be close, if not perfect, synchronization between the ERO's Event Analysis Process and Attachment 1 since they share the same ultimate goal as EOP-004-2 to improve industry awareness and BES reliability.

Yes
Sabotage cannot be confirmed until after the fact, so we support this initiative.
No
Owners and operators of facilities whose total removal from the BES would not meet any reportable threshold under Attachment 1, should not have to create and maintain Operating documents. The same would be true of any LSE, TSP, or IA that does not oversee any Critical Cyber Assets as identified under CIP-002. A statement to that effect could be made in Section 4 of EOP-004-2.
Yes
Ingleside Cogeneration agrees that the NERC Rules of Procedure are the appropriate location for ERO assigned activities. However, we would like to get a solid commitment from NERC that the Events Analysis Process and the Reliability Assessment and Performance Analysis Group (RAPA) data analysis requirements for Protection System Misoperations is coordinated through a single process. Their unique data needs are understandable, but should not require the downstream entity to evaluate what is required by each sub-committee – and which reporting template to use.
Yes
Yes
No
Since the reporting of event data to regulatory agencies does not support a front-line operations capability to mitigate or restore a BES impairment, regular simulations are not needed. Those notification items which test coordination between operating entities can be addressed in emergency operations exercises.
Yes
Yearly refresher training on the reporting process is appropriate. Ingleside Cogeneration also agrees that a “review” with those individuals with assigned responsibilities under the Operating Plan is a better way to frame the requirement.
Yes
Although our preference would be to have a single form, Ingleside Cogeneration realizes that is not likely in the near term. We would like to see that remain as a goal of the project team or the ERO.
Yes
We believe that there should be close, if not perfect, synchronization between the ERO’s Event Analysis Process and Attachment 1 since they share the same ultimate goal as EOP-004-2 to improve industry awareness and BES reliability.
Yes
Yes
Yes
Yes
Yes
Group
Midwest ISO Standards Collaborators
Marie Knox
Yes
No
The definition of Impact Event is overly broad because of the use of “potential to impact” and the “Such as” list. Consider routine switching has the potential to result in a mis-operation. This means all routine switching is an impact event. The “Such as” list should be struck and “potential” language should be struck.
No
In general, we agree that the standard drafting team has provided an equally efficient and effective alternative, but we wonder if the SDT has not in essence already defined sabotage in their description for why they can’t define sabotage. It seems that sabotage involves willful intent to destroy equipment. In general, intent would have to be determined by

an investigation of law enforcement. This could be part of the definition. There might be some obvious acts that could be included without investigation such as detonation of a bomb. Is it possible for the SDT to use the DOE definition for sabotage? We encourage the SDT to provide a definition for sabotage.

Yes

No

We see no issue with imposing requirements on NERC. However, we are not opposed to making these changes in the Rules of Procedure either.

No

We do not believe that the use of the Operating Process, Operating Procedure, and Operating Plan for a reporting requirement is consistent with their definitions and certainly not with the intent of the definitions. For instance, an Operating Process is intended to meet an operating goal. What operating goal does this requirement meet? An Operating Procedure includes tasks that must be completed by "specific operating positions". This reporting requirement could be met by back office personnel. We also believe that parts 1.3 and 1.3.2 under Requirement 1 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. While some should require notification to law enforcement such as when firm load is shed, others certainly would not. For instance, law enforcement does not need to know that an IROL violation, generation loss or voltage deviation occurred.

Yes

No

We appreciate the drafting team recognizes that actual implementation of the plan for a real event should qualify as a "test". However, we are concerned that review of this requirement in isolation of the background material and information provided by the drafting team may cause a compliance auditor to believe that a test cannot be met by actual implementation. Furthermore, we do not believe testing a reporting procedure is necessary. Periodic reminders to personnel responsible for implementing the procedure make sense but testing it does not add to reliability. If they don't report an event, it will become obvious with all the tools (SAFNR project) the regulators have to observe system operations.

Yes

No

Requirement 2 and Requirement 5 appear to be very similar. Requirement 2 requires implementation of the Operating Plan, Operating Process and/or Operating Procedure in Requirement 1. The Operating Procedure requires gathering and reporting of information for the form in Attachment 2. What does Requirement 5 add that is not already covered in Requirement 2 except the ability to use the DOE OE-417 reporting form which could be included in Requirement 2?

Yes

No

We disagree with Measurement 4. It implies that the review must be conducted in person. Why could other means such as a web training or a reminder memo not satisfy the requirement? Because Requirement 1 does not require submittal of the Operating Plan, Operating Process and/or the Operating Procedure, Measurement 1 should only require submittal to the Compliance Enforcement Authority upon its request.

No

All violation risk factors should be Lower. All requirements are administrative in nature. While they are necessary because a certain amount of regulatory reporting will always be required, a violation will not in any direct or indirect way lead to reliability problem on the Bulk Electric System

Yes

No

R2 and R5 should be Operations Assessment since it deals with after the fact reporting. R3 should included Operations Assessment since an actual event could be used as the test.

Yes

We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing with the event. This will be particularly difficult when support personnel are not present such as during nights, holidays, and weekends.

Individual

Greg Rowland

Duke Energy



1 - Transmission Owners, 3 - Load-serving Entities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators
Yes
However, as we have noted previously, the DSR SDT statement that the proposed changes do not include any real-time operating notifications is inconsistent with requiring notification within one hour for thirteen of the twenty listed Events in Attachment 1 "Impact Event Table". Also, in the Background discussion, under Law Enforcement, the DSR SDT states that the objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting Impact Events. As we have previously commented, we are still required to make real-time reports under other standards. Requiring duplicate real-time reporting under EOP-004-2 is a waste of resources which could otherwise be used to improve reliability.
No
The phrase "or has the potential to impact" makes this an impossibly broad definition, and demonstrating compliance will not be straightforward.
No
Sabotage is still identified on the flowchart. Timeframes for reporting on Attachment 1 should be made consistent with DOE OE-417 reporting. Also on Attachment 1, the Threshold for Reporting on a Forced Intrusion Event should be "Affecting BES reliability" instead of "At a BES facility".
No
Section 4 is fine, but on Attachment 1, Entity with Reporting Responsibility should just identify "Initiating entity" for every Event, as was done with the first three Events. That way you avoid errors in leaving an entity off, or including an entity incorrectly (as was done with the GOP on Voltage Deviations).
No
Proposed language for Section 812 is very confusing. Is the NERC "system" really going to perform all notifications: "applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, and regulatory agencies as necessary"? Is it intended that the NERC "system" will relieve registered entities of the obligation to make these other reports? Is there an implementation plan to achieve that objective? It appears that this current version of EOP-004-2 has the potential for significantly creating redundant reporting. Will the NERC reports be protected from FOIA disclosure? How will FERC Order 630 be followed (CEII disclosure)?
Yes
Yes
Yes
We understand that the objective of this requirement is to test the Operating Process for communicating Impact Events; and that such test could be an actual exercise, a formal review, or a real-time implementation. But given that R1.4 requires updating the Operating Plan within 90 days of any changes, we believe the VRF for R3 should be LOW instead of MEDIUM.
Yes
Yes
There is so much overlap between Attachment 2 and the DOE OE-417 that we believe the DOE OE-417 should be revised to include the additional items that must be reported to NERC, so that there is only one form to submit to NERC and DOE.
No
<ul style="list-style-type: none"> <li>Attachment 1 contains three reportable events (Damage or destruction of Critical Asset, Damage or destruction of a Critical Cyber Asset, and Detection of a reportable Cyber Security Incident) that overlap with CIP-008-3 Cyber Security Incident Reporting and Response Planning and could result in redundant or conflicting content between the two standards. We propose either of the following options: 1. Remove the requirement for reporting these events from EOP-004-2 and add the timing and reporting requirements into CIP-008-3, R1.3. "Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary." OR 2. Replace the reporting requirement in CIP-008-3, R1.3. with a reference to report as required in EOP-004-2.</li> <li>Also, as noted in our comment to Question #4 above, the Attachment 1 Section "Entity with Reporting Responsibility" should just identify "Initiating entity" for every Event, as was done with the first three Events. That way you avoid errors in leaving an entity off, or including an entity incorrectly (as was done with the GOP on Voltage Deviations). We note that LSE is listed in the standard as an Applicable entity, and should be included in Attachment 1. Our suggestion would handle this oversight. We also note that CIP-001 does not include Distribution Provider in the list of applicable entities, but EOP-004-2 does include the DP.</li> <li>We reiterate our comment to Question #1 above that the DSR SDT statement that the proposed changes do not include any real-time operating notifications is inconsistent with requiring notification within one hour for thirteen of the twenty listed Events in Attachment 1.</li> <li>The last six events refer to the entity that experiences the potential Impact Event. We believe that the word "potential" should be struck, as this</li> </ul>

creates an impossibly broad reporting requirement. • Footnote 1 should be revised to strike the phrase “has the potential to” from the parenthetical, as this creates an impossibly broad reporting requirement. • The Impact Event “Risk to BES equipment” should be revised to “Risk to BES equipment that results in the need for emergency actions”. The accompanying footnote 4 should be revised to read as follows: Examples could include a train derailment adjacent to BES equipment (e.g. flammable or toxic cargo that would cause the evacuation of a BES facility control center), or a report of a suspicious device near BES equipment.

Yes

Yes

Yes

Yes

Yes

Individual

Amir Hammad

Constellation Power Generation

5 - Electric Generators

Yes

While CPG generally agrees with the purpose statement, we believe that the term Impact Events should be removed. Please see CPG’s response to Question 2 discussing the term Impact Events.

No

The currently proposed definition is vague and can be easily misinterpreted. Coining a term to define the events that the DSR SDT hopes to capture in EOP-004-2 is a difficult task, one that may not be necessary. Replacing the term “Impact Events” with “events in Attachment 1,” would eliminate the need to define such a term. In addition, the phrase “... or has the potential to impact the reliability...” is too vague and broad. Such broad statement is unhelpful in clarifying entities’ compliance obligation and potentially creates conflicted reporting between entities. The language in the reporting requirements should be limited to real impact events, while information sharing on “near miss” or “deficiency” incidents should be handled as good industry practices and not subject to onerous compliance obligations. The drafting team should also give careful consideration to the existing reporting and information sharing currently in place in the industry. When an event occurs, partners in the electric sector are notified as part of existing requirements outside of NERC compliance.

Yes

No

As stated in comments to earlier versions of EOP-004-2, CPG disagrees with the inclusion of Generator Owners. Since one of the goals in revising this standard is to streamline impact event reporting obligations, Generator Operators are the appropriate entity to manage event reporting as the entity most aware of events should they arise. At times, the information required to complete a report may warrant input from entities connected to generation, but the generator operator remains the best entity to fulfill the reporting obligation.

Yes

No

Per NERC’s glossary of terms, an Operating Plan can include Operating Process documents and Operating Procedures. An Operating Process identifies general tasks while an Operating Procedure identifies specific tasks. CPG is unclear as to why R1.1 and R1.3 require the use of an Operating Process while R1.2 requires an Operating Procedure. CPG believes that R1.2 should be changed to require the use of an Operating Process instead of Operating Procedure. R1.2 is merely requiring an entity to fill out the necessary forms should an event occur, so requiring a clear and concise step by step procedure for filling out a form only adds a compliance burden to an entity instead of improving the reliability of the BES. CPG does agree with the DSR SDT that an entity should have a process in place mandating that the proper paperwork be completed in a timely manner should an event occur.

Yes

Although CPG agrees with the wording of Requirement 2, CPG has several comments and suggested changes regarding the Attachments, to which this requirement points. Please see those comments below.

No

As CPG stated in comments to earlier versions of EOP-004-2, this requirement adds a substantial compliance burden with little to no reliability improvement to the BES. Numerous entities in the NERC footprint have created fleet wide compliance programs for their facilities, instead of overseeing multiple stand alone compliance programs. This was done not just for the ease of administration, but it also greatly improves the reliability of the BES by ensuring consistency across multiple facilities. By requiring each responsible entity to test the Operating Process, those under a fleet wide compliance program will end up testing the same Operating Process numerous times. This would be inefficient, ineffective and unnecessarily costly. If the testing requirement remains, then the Responsible Entity should be able to take credit for testing of the Operating Process regardless of which entity in the fleet tested it. Alternatively, the drafting team should consider removing Requirement 3 (formerly R4) because in practice it is covered by the new R4. As discussed below R4 needs refinement, but the topic of Disturbance Reporting is covered during annual training.

No

The purpose of this requirement as currently worded is unclear. It seems to insinuate that a formal review of the Operating Plan takes place annually, and that any and all personnel identified in the plan are part of the review. If that is correct, than CPG believes this requirement is echoing Requirement 3. These two requirements can be incorporated into one. Furthermore, the Measure for R4 is too prescriptive, going so far as to specifically describe how this formal review should take place. It even states that the Responsible Entity needs to present documentation showing that the personnel in the plan were trained, yet there is no requirement for training. CPG would like the DSR SDT to revisit the purpose and intent of this requirement, alone and in concert with R3. If there are indeed similar then consolidate them into one requirement.

No

The requirements for filling out the DOE-OE-417 form are not necessarily the same as the requirements prescribed in Attachment 1. CPG suggests that the drafting team create a new requirement, spelling out when an entity is required to complete the DOE-OE-417 form.

No

CPG has the following concerns regarding Attachment 1:

- Real-Time - On page 5 of the proposed standard, the team noted that “the proposed changes do not include any real-time operating notifications.” However, several events in Attachment 1 require that documentation be completed and submitted to the ERO within 1 hour. For generation sites that are unmanned, or only have 1 to 2 operators on site at all times, a 1 hour requirement is not only onerous but is essentially “real time.”
- Response within 1 hour - It is important to consider the imposition created by a compliance obligation and weigh it against the other demands before the operator at that time. A compliance obligation should avoid becoming a distraction from reliability related work. Under impact event type scenarios, in the first hour of the event, the primary concern should be coping with/resolving the event. Other notification requirements exists based on required agency response relative to the concern at hand (e.g. public evacuations, fire assistance, etc.) Notification within an hour under EOP-004 does not appear to represent a relevant benefit to resolving the situation and the potential cost would be borne by reliability and recovery efforts. Anything performed within the first hour of the event must be to benefit the public or benefit the restoration of power.
- Damage or destruction of BES equipment – the reporting requirement of 1 hour is extremely onerous. A good example is the failure of a major piece of equipment at a remote combustion turbine generation site. Combustion turbine generation sites are not usually manned with many people. If a failure of a major piece of equipment were to occur, the few people on site need to complete communications to affected entities, communications to their management, as well as emergency switching and ensuring that no other pieces of equipment are effected or harmed. There is little time to complete a form in 1 hour. This should be changed to 48 hours. The form is also inadequate for this type of event.
- o Using the example above of a failure of a major piece of equipment, CPG is not sure if it’s reportable per Attachment 1, which further proves that Attachment 1 is not clear. Per the footnote regarding damage to BES equipment, the failure would not be reportable, as it does not affect IROL, given the information at the plant it does not significantly affect the reliability margin of the system, and was not damaged or destroyed due to intentional or unintentional human action. However, it would be reportable per the table as the table states “equipment failure” and “external cause.” Clarification is needed.
- Damage or destruction of Critical Asset – This item should be removed or significantly refined. For generation assets, a critical asset is essentially the entire plant, so in many cases the information reported at this level would not be useful if the valuable details reside at the equipment level. If it is not removed, then see the notes above on the 1 hour requirement for the completion of the form.
- Fuel supply emergency – 1 hour for reporting the document is unreasonable. See the earlier notes.
- Risk to BES equipment – “From a non-environmental physical threat” This item is too vague and subjective. A catch all category to capture a broad list of potential risks is problematic for entities to manage in their compliance programs and to audit. This should be removed.

No

See CPG’s earlier comments regarding the Requirements and Measures.

CPG has the following comments regarding Attachment 2:

- Generally, this attachment is inadequate for all events. The real-life experience with the recent SW cold snap demonstrated that the questions inadequately capture what may be

of greatest concern in the situation. •Question 4 – this question is vague. It should be removed. •Question 7 – the role of generation in an event may not always be related to a trip. As experienced with the recent SW cold snap, this question may inadequately capture information relevant to the situation at hand. The drafting team should reassess how best to gather information relevant to the event and useful for evaluation. •Question 8 – generation is not required to monitor frequency during events, so this would not be answered. This question also assumes that frequency had been impacted, which is not always the case (i.e., the plant could not come online). •The asterisk on some questions in Attachment 2 is not defined.

Group

FirstEnergy

Sam Ciccone

Yes

No

Although we agree with the definition of Impact Event, we believe that it should be clear that this term is specific to the events listed in Attachment 1 of the standard. Therefore, we suggest adding the phrase "(as detailed in Attachment 1 of EOP-004-2)" in the definition.

Yes

No

Attachment 1, Part A – Energy Emergency requiring Public appeal for load reduction – In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity". We can't see where the GO/GOP would ever make this determination. Needs to be clarified. Attachment 1, Part A – Energy Emergency requiring system-wide voltage reduction – In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity". We can't see where the GO/GOP would ever make this determination. Needs to be clarified.

Attachment 1, Part A – Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 continuous minutes, this should be a TOP RC function only. Attachment 1, Part A - Loss of offsite power (LOOP) classification should not apply to nuclear generators. The impact of a LOOP is dependent on the design of the specific nuclear unit and may not necessarily result in a unit trip. If a LOOP did result in a unit trip, the NRC requires notification by the nuclear GO/GOP via the Emergency Notification System (ENS), and time allowed for that notification (1 hour, 4 hours, 8 hour, or none at all) is, as mentioned above, dependent on the design of the plant. We believe it would be beneficial if consideration were given to coordinating reporting requirements for nuclear units with existing required notifications to the NRC to avoid duplication of effort. Attachment 1 should align NERC Standard NUC-001 concerning the importance of ensuring nuclear plant safe operation and shutdown. If a transmission entity experiences an event that causes a loss of off-site power as defined in the nuclear generator's Nuclear Plant Interface Requirements, then the responsible transmission entity should report the event within 24 hours after occurrence. Also, for clarity "grid supply" should be replaced with "source" to ensure that notification occurs on a loss of one or multiple sources to a nuclear power plant. Attachment 1, Part A – Damage or destruction of BES equipment. See Nuclear comments on question 17 below. Attachment 1, Part B – Forced intrusion at a BES facility. See Nuclear comments on question 17 below. Attachment 1, Part B – Risk to BES equipment from a non-environmental physical threat. What constitutes a "risk" to the reporting entity is still somewhat ambiguous, and although the DSR SDT has provided some examples, without more specific criteria for this event the affected entity will have difficulty in determining within 1 hour if a report is necessary. Also, see Nuclear comments on question 17 below.

Yes

No

1. We believe that the use of stringent definitions for an entity's process requires too much of the "how" instead of the "what". As long as the entity has a process, procedure (or whatever they want to call it) that includes the necessary information detailed in sub-parts 1.1 through 1.4 then that should suffice. 2. In sub-part 1.3, we suggest adding the phrase "as applicable" to clarify that not every event will require a notification to, for example, law enforcement. 3. In sub-part 1.4, we suggest adding clarification that the 90-day framework is only required for substantive changes and that all other minor editorial changes can be updated within a year.

Yes

No

We believe that a separate requirement for testing the reporting process is unnecessary. The FERC directive that required periodic testing was directed at sabotage events per CIP-001. Since the proposed standard moves the responsibility for classifying an event as sabotage from the entity to the applicable law enforcement authority, the need for a periodic drill is no longer necessary. We believe that Requirement R4 should suffice in ensuring that the individuals involved in the process are aware of their responsibilities.

No

We believe that Requirement 4 does not warrant a "Medium" risk factor. For example, a simple review of the process does not have the same impact on the Bulk Electric System as the implementation of the Operating Plan per R2. Therefore, we believe R4 is at best a "Low" risk to the BES.
No
We believe that Requirement 5 does not warrant a "Medium" risk factor. Not using a particular form is strictly administrative in nature and the VRF should be "Low".
No
Nuclear facilities should be explicitly excluded from the events which have CIP standards as the threshold for reporting since they are exempt from the CIP standards.
No
Measure M4 includes the phrase "when internal personnel were trained on the responsibilities in the plan" implies the Requirement R4 requires training. R4 is only requiring the review of a document of the necessary personnel and that the rest of the measure covers the needed evidence for R4. This phrase in the measure should be removed. We suggest the following for M4: M4. Responsible Entities shall provide the materials presented to verify content and the association between the people listed in the plan and those who participated in the review, documentation showing who was present.
No
1. We believe that Requirement 5 does not warrant a "Medium" risk factor. Not using a particular form is strictly administrative in nature and the VRF should be "Low". 2. We believe that Requirement 4 does not warrant a "Medium" risk factor. For example, a simple review of the process does not have the same impact on the Bulk Electric System as the implementation of the Operating Plan per R2. Therefore, we believe R4 is at best a "Low" risk to the BES.
Yes
No
We believe the previous proposal for a 12 month implementation was more appropriate and suggest the team revert back to that timeframe.
FE offers the following additional comments and suggestions: 1. In the Background section of EOP-004-2, on page 6 under Stakeholders in the Reporting Process, we suggest adding "Regional Entity" and "Nuclear Regulatory Commission". 2. The DSR SDT makes reference to comments that Exelon provided that suggested adopting the NRC definition of "sabotage." We feel the comment made by Exelon in their previous submittal was to ensure that the DSR SDT included the Nuclear Regulatory Commission (NRC) as a key Stakeholder in the Reporting Process and FE agrees with this suggestion. Nuclear generator operators already have specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(s)(xi). We ask that the DSR SDT contact the NRC about this project to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. We believe this is a similar situation as what was recently resolved between NERC and the NRC concerning the applicability of CIPs 002 – 009 for nuclear plants. Each nuclear generating site licensee must have an NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan (E-Plan). We ask that the proposed "Reporting Hierarchy for Impact Event EOP-004-2," flow chart be coordinated with the NRC to ensure it does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans.
Individual
Scott Barfield-McGinnis
Georgia System Operations Corporation
3 - Load-serving Entities, 4 - Transmission-dependent Utilities
Yes
We agree with the purpose. However, we do not agree that the purpose will be achieved as this standard is currently drafted or that the standard is ready for balloting.
No
It is not clear for the purposes of complying with this standard what it means to "impact reliability." Impact in what way? To what degree? Do not define this term. An alternative would be to define it as those events listed in Appendix 1.
Yes
None.
No
We do not agree that this standard assigns clear responsibility for reporting. It seems that multiple entities are being required to report the same event for some events. Only one entity should report. See comments later regarding

Attachment 1. NERC should not decide which ONE entity should report. The entities should be allowed to decide this (and include it in the Impact Event Operating Plan) and to let NERC or the region know who will report (or give them a copy of the plan).

Yes

None.

No

-R1.3.2: "Law Enforcement", "Governmental Agencies", and "Provincial Agencies" are not proper nouns/names and are not defined in the NERC Glossary. They should not be capitalized. -R1.4: Keeping documents current and in force should be a matter of an entity's compliance program and not of a NERC requirement. It is not clear what the difference is between "updating the Impact Event Operating Plan" and changing "its content." How is compliance with this measured? Delete R1.4.

No

-We suggest moving the language from the measure to the requirement as such: "To the extent that a Responsible Entity has an Impact Event on its Facilities, each Responsible Entity shall implement..." Additionally, R1 uses the phrase "recognized Impact Event" where as R2 simply uses the term "Impact Event." The phrase "recognized Impact Event" should be used consistently in R2 as well.

No

-With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between tests" is necessary. Although we understand the additional qualification is used in the VSL matrix, we recommend removing "with no more that 15 calendar months between tests" and rely on the Responsible Entity's definition of annual and not to exceed timeframes. -We suggest moving the language from the measure to the requirement as such: "In the absense of an acutal Impact Event, each Responsible Entity shall ..."

No

-With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between reviews" is necessary. Remove "with no more that 15 calendar months between reviews". -R3 requires testing the process. R4 requires reviewing the plan. Testing a process and reviewing a plan both seem to imply verifying the process/plan is correct and the appropriate actions will take place. Training implies making personnel aware of and providing them an understanding of what the process/plan involves and not verifying whether or not it is correct or appropriate. It is not clear what is being required in R4. -The measure says that documentation showing when personnel were trained is required. R4 does not require training. The requirement and the measure should be made clear and consistent.

No

R5: This standard should not require all Responsible Entities to report the same event. Entities should be allowed to report in a hierarchical manner. They should be allowed to coordinate impact event plans and include in their plans the entity that has the responsibility for reporting various events. Flexibility should be allowed to provide different reporting entities depending on the type of event. In R5, does "Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan ..." allow this hierarchical reporting and flexibility? An entity should be allowed to report to another operating entity by whatever reporting form or mechanism works and then the other entity reports to NERC using the required NERC or DOE form. Add "To the extent that a Responsible Entity had an Impact Event," at the beginning of R5 and M5.

No

Energy Emergency requiring public appeal for load reduction: -The NERC Glossary defines "Energy Emergency" as a "condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements." Per EOP-002, an Energy Emergency Alert may be initiated by the RC upon RC sole discretion, upon BA request, or upon LSE request. -Question: Is it intended that the LSE reports the event if the LSE requests an alert, the BA reports the event if the BA requests an alert, and the RC reports it if it is a RC sole discretion decision? What if an alert is not initiated? Is it an Energy Emergency? Is it an impact event? Who must initiate the public appeal? Since it must be reported within a certain time after the issuance of the public appeal, is it not an impact event until after the initiation of the public appeal (which should be after the initiation of the alert)? Shouldn't the reporting of the impact event be done by the initiator of the public appeal? The event should probably be the public appeal and not the Energy Emergency. -"Public" should not be capitalized. -The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. • Energy Emergency requiring system-wide voltage reduction: See Energy Emergency requiring public appeal for load reduction above regarding requesting Energy Emergency Alerts. If this event is to be reported within a certain time after "the event", at what time is the event marked? Or is it within a certain time after the initiation of the voltage reduction and, if so, shouldn't the reporting of the impact event be done by the initiator of the voltage reduction? The event should probably be the system-wide voltage reduction and not the Energy Emergency. The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and NERC does not need to know this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Energy Emergency requiring manual firm load shedding: -See Energy Emergency requiring public appeal for load reduction above regarding requesting

Energy Emergency Alerts. If this event is to be reported within a certain time after "the event", at what time is the event marked? Or is it a certain time after the initiation of the shedding of load, if so, shouldn't the reporting of the impact event be done by the initiator of the shedding of the load? If the RC directs a BA to shed load, then the BA directs a DP to do it, then the DP sheds the load, who is the initiator of the load shedding? The event should probably be the firm load shedding and not the Energy Emergency. -The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Energy Emergency resulting in automatic firm load shedding: Whenever load is automatically shed both the DP and the TOP "experience" the event. So does the BA and the LSE. This event includes "or" between "DP" and "TOP." Is that intentional? Other events in the table do not include either an "and" or an "or." The entities are separated only by commas. NERC should not require multiple entities to report the same event. See comment for R5 above. If a DP "experiences" an automatic load shedding doesn't the TOP also experience it? Both should not report the same event. -The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Voltage deviations on BES Facilities: -Should GOs/GOPs be required instead to report to BAs when this condition exists with the BA then reporting to NERC? The idea of a deviation "on BES Facilities" is not clear. On any one Facility? On all Facilities in an area? How wide of an area? -"Voltage Deviation" is not proper noun/name and is not defined in the NERC Glossary. It should not be capitalized. IROL violation: Multiple entities should not report the same event. Please define "IROL Violation" or use lowercase. It is assumed that "IROL Violation" means operation "outside the IROL for a time greater than IROL TV." Loss of firm load for  $\geq 15$  minutes: -Multiple entities should not report the same event. The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. "Firm Demand" is defined but not "Firm load." System separation (islanding): -Multiple entities should not report the same event. A DP separating from the transmission system should not be a reportable event for a DP in and of itself. If it leads to a sufficient loss of load, it is reportable as above. -The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. The words "separation" and "islanding" should not be capitalized. Generation loss: -Should GOs/GOPs be required instead to report to BAs when their generation is lost with the BA then reporting to NERC when the total is  $\geq 2,000$  MW? A "loss" of generation should be clarified. Is the discovery of damaged equipment in an offline plant which makes the plant unavailable for an extended period of time a "loss" of generation? -It should be clarified if this event means the concurrent loss of the generation or losing the generation non-concurrently but they are concurrently unavailable. What is the time window for losing the generation? Lost within seconds of each other? Minutes? Hours? Loss of off-site power to a nuclear generating plant (grid supply): -Multiple entities should not report the same event. -"Off" should be lowercase. Transmission loss: -RCs should not be required to report the loss of transmission elements to NERC. A "loss" of a BES Transmission Element should be clarified. It should be clarified if this event means the concurrent loss of elements or the non-concurrent loss of the elements but they are concurrently unavailable. What is the time window for losing the elements? When elements are lost, it will be difficult to differentiate if they are BES Transmission Elements or not. Alarms don't immediately identify this. It could lead to gross over-reporting if no distinction is made by a TOP and the TOP reports all losses of 3 elements. It may still be over-reporting (from a reasonableness/practicality basis) even if the differentiation could be easily made and only BES Transmission Elements are reported. Threshold for reporting Transmission Loss: As stated, this will require the reporting of almost all transmission outages. This is particularly true taking into consideration the current work of the drafting team to define the Bulk Electric System. The loss of a single 115kV network line could meet the threshold for reporting as the definition of Element includes both the line itself and the circuit breakers. Instead, we recommend the following threshold "Three or more BES Transmission lines." This threshold has consistency with CIP-002-4 and draft PRC-002-2. This threshold also needs additional clarification as to the timeframe involved. Is the intent the reporting of the loss of 3 or more BES Transmission Elements anytime within a 24 hour period or must they be lost simultaneously? Also, we recommend that the three losses be the result of a related event to require reporting. Damage or destruction of BES equipment that i. affects an IROL; ii. significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); or iii. damaged or destroyed due to intentional or unintentional human action (Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly, e.g., removal of grounding straps rendering protective relaying inoperative.): -What is "BES equipment?" Would an operator know which equipment is BES equipment and which is not or which BES equipment affects an IROL (if we had one) or which does not? It is a judgment call as to whether the effect was significant or not or if it has the potential or not. Multiple entities should not report the same event. Unplanned control center evacuation: -"Control Center" should be lowercase. -The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Fuel supply emergency: Multiple entities should not report the same event. Should GOs/GOPs be required instead to report to BAs when they have a fuel supply emergency with the BA then reporting to NERC if the situation is projected to require emergency action at the BA level? -The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Loss of all monitoring or voice communication capability (affecting a BES control center for  $\geq 30$  minutes): -Does this event mean that ALL capability at both the primary and backup control centers or just one? Forced intrusion at a BES facility (report if you cannot reasonably determine likely motivation, i.e., intrusion to steal copper or spray graffiti is not reportable unless it affects (affects – not effects) the reliability of the BES): -What is a "BES facility?" It is not clear for the purposes of complying

with this standard what it means to affect the reliability of the BES. Deferred for ECMS review and additional comments. Risk to BES equipment (examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment, e.g., flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center, and report of suspicious device near BES equipment.): -In the footnote, delete "could have" from "...either could have damaged..." Something that could cause evacuation of a control center does not pose a risk to damaging BES equipment. The threshold is "from a non-environmental physical threat" but the example (toxic cargo) IS an environmental threat.

No

There are a lot of inconsistencies between the requirements and the measures. The measures add requirements that are not stated in the requirements. The measures need to be made consistent with the requirements and to not add to them. Also see comments on requirements earlier for language to move from the measures into the requirements. M2: Remove "on its Facilities." The word "its" leads to a lot of confusion regarding who reports what. Attachment 1 should make clear "what" needs to be reported. The entities' operating plan should make it clear as to who should report each "what." Furthermore, not all Impact Events are "on Facilities." M3: Replace "that it conducted a mock Impact Event" with "that it conducted a test of its Operating Process". Delete "The time period between actual and or mock Impact Events shall be nor more than 15 months." M4: The measure says that documentation showing when personnel were trained is required. R4 does not require training. The requirement and the measure should be made clear and consistent.

No

Failing to report to NERC any of many of the listed events does not present a reliability risk. The exception to this would be those threat events where the ES-ISAC needs to be notified. The object of the standard is to prevent or reduce the risk of Cascading. Reporting system situations to appropriate operating entities who can take some mitigating action (e.g., a LSE reporting to its BA or a BA reporting to its RC) and reporting threats to law enforcement officials could prevent or reduce the risk of Cascading but reporting to NERC (except for events where the ES-ISAC needs to know) is unlikely to do that. Reporting of most of the listed events to NERC does not meet the objective of this standard and should be removed from this standard. Such events should be reported to NERC through some other (than a Reliability Standard) requirement for reporting to NERC so that NERC can accomplish its mission of analyzing events. Analyzing events may lead to an understanding that could reduce the future risk of Cascading but analyzing events cannot be performed in time to reduce any impending risks.

No

None.

Yes

None.

No

There is nothing about the revisions that were made to the requirements that shortens the time needed by the industry to get prepared for this revision. The removal of requirements for NERC does not shorten the requirements for the industry. Eighteen months (or 12 months minimum) should be allotted to prepare for this revision.

Attachment 2: Impact Event Reporting Form -Instructions for filling out this form are needed. -Line 7, Generation tripped off-line: What is the asterisk for after this task and after the many others following? This should only be reported by a BA. Does generation "tripped off-line" mean the same as generation "lost?" -Line 9, List of transmission facilities (lines, transformers, buses, etc.) tripped and locked-out: Does this mean the same as BES Transmission Elements lost? -Line 10: The column headings in white text on lighter blue background at the top do not seem to apply from this line on. -Line 11, Restoration Time: Restoration of what? Initial/Final clock time? Transmission? What about transmission? Generation/Demand? -Line 13, Identify the initial probable cause or known root cause of the actual or potential Impact Event if known at time of submittal of Part I of this report: "At the time of submittal of Part I of this report"?? Where is Part II? Did you mean Part A? Is Part B to be submitted at a different time? Background -Page 5, last sentence which is continued on page 6: This standard does not recognize the various "versions" of companies in the industry. The standard is made applicable to a long list of registered entity types. In many cases, many of these entities are wrapped into one company. A company may be responsible for "everything" in a geographic area. It may be almost every registered entity type with no other registered entities within its geographic area. There should be no conflicts or need for coordination with others for this company. Everything would be coordinated internally within that one company before being reported to NERC and no one else would be reporting to NERC. However, sometimes one company is only a LSE. When an LSE-only is having a LSE impact event, the LSE should report to some higher operating entity like its BA and should not report to NERC. Reporting should be done in a hierarchical manner within appropriate operating entities and then reported to NERC at the RC (or BA) level or as agreed among entities in any coordinated impact event reporting plans. The RC, BA, TOP, and LSE should not all be held accountable for reporting the same event. This standard does not deal exclusively with after-the-fact reporting. Some events deal with the condition of the system (risk of possible future events) or condition of an entity's ability to operate (supplying fuel, covering load, etc.) or with a threat to the BES. -Page 6, Summary of Concepts: A single form may have been an objective but it is obviously not a concept being implemented by the standard. There are two forms. -Page 6, Law Enforcement Reporting: The object of the standard may be to prevent or reduce the risk of Cascading. Reporting system situations to appropriate operating entities who can take some mitigating action (e.g., a LSE reporting to its BA



or a BA reporting to its RC) and reporting threats to law enforcement officials could prevent or reduce the risk of Cascading but reporting to NERC is unlikely to do that. Reporting of most of the listed events to NERC does not meet the objective of this standard and should be removed from this standard. Such events should be reported to NERC through some other (than a Reliability Standard) requirement for reporting to NERC so that NERC can accomplish its mission of analyzing events. Analyzing events may lead to an understanding that could reduce the future risk of Cascading but not any impending risks. -Page 6, Stakeholders: What is "Homeland Security – State?" We know what the Department of Homeland Security and the State Department are but this term is not clear. -Page 6, "State Regulators", "Local Law Enforcement", and State Law Enforcement": These are not proper nouns/names and are not defined in the NERC Glossary. They should not be capitalized. -Pages 7 & 8, Law enforcement: Is each entity required to determine procedures for reporting to law enforcement and work it out with the state law enforcement agency? Do the state law enforcement agencies know this? Or is there a pre-determine procedure that is already worked out with the state law enforcement agency that entities are to follow?

Individual

Max Emrick

City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power

1 - Transmission Owners, 3 - Load-serving Entities, 4 - Transmission-dependent Utilities, 5 - Electric Generators, 6 - Electricity Brokers, Aggregators

No

"To improve industry awareness and the reliability for the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known by the Responsible Entities" The revised purpose statement includes the phrase, "if known". This seems like a huge loophole. They should change it to "when discovered" or "when notified".

Yes

Yes

Yes

Yes

Yes

However, there needs to be some clarity on which government agencies (if not the FBI) are responsible for reporting these type of events.

No

There are generally several events during the year. If the process is well documented, a drill or exercise is excessive. It should be sufficient to say "provide training".

Yes

Yes

Yes

No

The one hour reporting timeline is unrealistic for this event. In general it looks like other events requiring the 1 hour reporting timeline are for event that are 'initiated' by the system operator. (ie load shedding, public load reduction, EEP...). Loss of BES equipment is in general 24 hour reporting timeline. It should be, "as soon as possible but within 24 hours".

No

M3 -The testing of the Plan by drill or mock impact event is unnecessary and burdensome.

No

Yes

No

Why shorten the normal process?

No

The implementation Plan was to move up the timeline and we do not see why this needs to be pushed forward on a shortened timeline. It should remain at the one year implementation schedule especially if annual exercises are not

removed from the standard requirements as this take some time to prepare.
We like the option to use the OE_417 as the reporting form for these events.
Group
Compliance & Responsibility Organization
Silvia Parada Mitchell
No
See comments set forth in number 2.
No
<p>NextEra Energy Inc. (NextEra) appreciates the drafting team providing valuable ideas and a framework on how to improve and consolidate CIP-001 and EOP-004. However, NextEra also believes that the currently drafted EOP-004-2 needs to be revised and enhanced to more clearly explain the Responsible Entities' duties, the definition of sabotage and address FERC directives and concerns. For example, NextEra is not in favor using the term "Impact Event" which seems to add considerable confusion of what is or is not sabotage. In Order No. 693, FERC stated its interest in NERC revising CIP-001 to better define sabotage and requiring notification to the certain appropriate federal authorities, such as the Department of Homeland Security. FERC Order 693 at PP 461, 462, 467, 468, 471. NextEra has provided an approach that accomplishes FERC's objectives and remains within the framework of the drafting team, but also focuses the process of determining and reporting only those sabotage acts that could impact other BES systems. Today, there are too many events that are being reported as sabotage to all parties in the Interconnection, when in reality these acts have no material affect or potential impact to other BES systems other than the one that experienced it. For example, while the drafting team notes the issue of copper theft is a localized act, there are other localized acts of sabotage that are committed by an individual, and these acts pose little, if any, impact or threat to other BES systems other than the one experiencing the sabotage event. Reporting sabotage that has no need to sent of everyone does not necessary add to the security or reliability of the BES. Related, there is a need to clarify some of the current industry confusion on who should (and has the capabilities to) be reporting to a boarder audience of entities. Hence, NextEra approach provides a clear definition of sabotage, as well as the process for determining and reporting sabotage. NextEra further believes that some of the requirements can be consolidated and more clearly stated, and NextEra has attempted to do that in the approach presented below. Lastly, NextEra comments on Attachment 1 are submitted in response to question 17. NextEra Approach Delete definition of Impact Event and its use in the requirements and in Attachment 1 Delete 13, 14, 15 and 19 in Attachment 1 Delete and replace R1 through R5 with the following: New Definition Attempted or Actual Sabotage: an intentional act that attempts to or does destroy or damage BES equipment or a Critical Cyber Asset for the purpose of disrupting the operations of BES equipment, Critical Cyber Asset or the BES, and has a potential to materially threaten or impact the reliability of one or more BES systems (i.e., is one act in a larger conspiracy to threaten the reliability of the Interconnection or other BES systems). R1. Each Responsible Entity shall document and implement a procedure (either individually or jointly with other Responsible Entities) to accomplish the reporting requirements, including the time frames, assigned to the Responsible Entity as set forth in Attachment 1 items 1 through 12, 16, 17 and 18 for reporting from the Responsible Entity to its Regional Entity and NERC, using the form in Attachment 2 or the DOE OE-417 reporting form. R2. Each Responsible Entity shall document and implement a procedure (either individually or jointly with other Responsible Entities) to report to its internal personnel with a need to know and its Reliability Coordinator an act of Attempted or Actual Sabotage, using the form in Attachment 2 or the DOE OE-417 reporting form, within one hour after a determination has been made that an act Attempted or Actual Sabotage has occurred. To make a determination that an act of Attempted or Actual Sabotage has occurred, the Responsible Entity shall document and implement a procedure that requires it, as soon as practicable after the discovering an act appearing to be Attempted or Actual Sabotage, to engage local law enforcement or the Federal Bureau of Investigation or Royal Canadian Mounted Police, as deemed appropriate, to assist the Registered Entity make such a determination. Upon receiving a report of Attempted or Actual Sabotage from a Responsible Entity, the Reliability Coordinator shall within one hour forward the report to other impacted Reliability Coordinators, Responsible Entities, Regional Entities, NERC, Department of Homeland Security, and the Federal Bureau of Investigation or the Royal Canadian Mounted Police. R3. Each Responsible Entity shall review (and conduct a test for sabotage only) of its documented procedure required in R1 and R2 with no more than 15 calendar months between tests for sabotage reporting. If, based on the review or test, the Responsible Entity determines there is a need to update its documented procedure, it shall update the procedures within 90 calendar days of the review or test.</p>
No
See comments set forth in number 2.
Yes
No
See comments to 2. Also, although NextEra agrees that a documented procedure is appropriate, NextEra does not favor the current approach of pre-defined layers of processes and documentation that seem to overly complicate, and, possibly contradict, already established internal methods by which a company implements policies, procedures and processes. Thus, NextEra's options suggest using a more generic approach that allows entities more flexibility to establish documents and processes. and demonstrate compliance. Such a generic approach was used in NextEra's

proposed options set forth in response to number 2.
No
See comments set forth in number 2.
No
See comments set forth in number 2. Also, while NextEra understands the need to have a testing requirement for sabotage (Order 693 at P 446), it does not find it necessary to have a testing requirement for the other events. At this time in the process, additional requirements for the sake of having a requirement are likely to detract from reliability. Thus, NextEra requests that the testing requirement be limited to sabotage related events.
No
See comments set forth in number 2
Yes
No
See comments set forth in number 2
No
See comments set forth in number 2.
No
See comments set forth in number 2.
No
See comments set forth in number 2.
No
See comments set forth in number 2.
Yes
Nuclear power plants (a need for a revised approach) With respect to sabotage, damage or destruction of BES equipment, damage or destruction of a Critical Asset, damage or destruction of a Critical Cyber Asset, forced intrusion, etc., nuclear plants already have a responsibility to report the events to the FBI and the Nuclear Regulatory Commission (NRC). Performing another report to NERC, with potentially different requirements, within 60 minutes of an event does not seem necessary or practical. It would also be difficult, during an event, to report to external organizations, including but not limited to the Responsible Entities' Reliability Coordinator, NERC, Responsible Entities' Regional Entity, Law Enforcement, and Governmental or Provincial Agencies when operations personnel are pre-occupied with an abnormal or emergency situation. Further, nuclear plants already have an obligation to report the loss of off site power to NRC. Similarly, now that cyber assets will be regulated by the NRC, these reporting requirements should not be applicable to a nuclear power plant. Thus, there is a need to exempt nuclear power plants from these requirements or provide more flexibility to such plants, given its pre-existing NRC reporting requirements. Attachment 1. There is no explanation for why a report must be submitted within one hour of a event. As stated with respect to nuclear, an entity should not be prioritizing between stabilizing the system and reporting. One approach that would help balance conflicting priorities is to start the time frame after "all is clear." Another approach could involve the use of target times, with an allowance for exceptions during emergencies or situations in which it is impracticable. Another alternative is to have two times: an earlier "target reporting time" and second later "mandatory reporting time." Further, the current wording suggests that a generator owner or generator operator will be able to determine the impact or potential impact on the BES. This is not realistic, given that impacts to the BES are generally only understood at a transmission operator or reliability coordinator level. Thus, the concept of relying on generators to determine impacts on the BES needs to be eliminated. Also, as written, for a generator, Attachment 1 appears to require a report when a lightning arrester fails at a Critical Asset. NextEra cannot see any justification for reporting such an event, and this is another reason why Attachment 1 needs more review and revision prior to the next draft of EOP-004-2. This one reason why NextEra has suggested a materiality test for reporting in a definition of Attempted or Actual Sabotage.
Individual
Rex Roehl
Indeck Energy Services
5 - Electric Generators
No
The reporting of events does not improve the reliability of the BES. If someone takes action based on the reporting, there might be an improvement. Because many of these events are not preventable, such as sabotage or weather, reporting them won't improve reliability. The original Purpose was satisfactory.
No
It's not a definition. It needs some quantification, such as, a Reportable Disturbance (NERC glossary), a reportable event under DOE OE-417, sabotage or bomb threat. Defining it as having or potentially having an impact is no definition. What is an impact? It needs to be quantified or auditors will have license to define it any way that they want. It shouldn't be a NERC Glossary definition if its only use is in EOP-004. Within EOP-004, it can be defined as anything

in Attachment 1.
No
The SDT hasn't defined sabotage. Attachment 1 does not do justice to the concept of sabotage. Sabotage should be defined as any intentional damage to BES facilities the causes a Reportable Disturbance, reportable event under DOE OE-417 or involves a bomb or bomb threat.
No
Voltage Deviations should not be reportable by GOP. That's why we have TOP's. Damage or destruction of BES equipment should be reportable only if it causes or could cause a Reportable Disturbance, reportable DOE OE-417 event or sabotage (as defined above). Otherwise, an auditor could require reporting of a relay failure caused by human error even though the relay was in test mode and no BES impact was experienced. This category could be dropped in favor of the next one, damage to Critical Asset. Fuel Supply Emergency needs a definition. For natural gas, various conditions could be referred to as emergencies, but unless they actually affect generation, they should not need to be reported. Fuel Supply Emergencies that cause a Reportable Disturbance or reportable DOE OE-417 event should be reported. It is unclear why Forced Intrusion should be reportable under EOP-004. If it causes a problem, it will be reportable as another category and is one more unpreventable event. Forced Intrusion isn't, in many cases, as the exceptions try to define, an impact event at all, but could be a cause, which would be reported as the cause of an impact event. Risk to BES Equipment is not well defined. It should be expanded to Risk to BES Equipment from a non-environmental physical threat within a reasonable distance of the Equipment. A train derailment on the line past the plant would likely be known, whereas one that was 1/2 mile or more away with flammable materials might not be known about unless a public warning was made.
Yes
No
The terms are not important and many plans or procedures already exist and restructuring them to match the terms is wasteful. R1 is too prescriptive. R1 should state that a written document should show how the entity will comply with EOP-004. R1.2 is superfluous and should be deleted. The data must be gathered and the process will vary with the event. Trying to define the multitude of possibilities for the collection process is not productive and leaves open the possibility of missing something for an auditor to nit pick. R1.3 should just be a written communications plan/process/procedure for external notifications. R1.4 is redundant because it can't be changed within 90 days until the content has already been changed. R1.4 should be deleted. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
No
R2 is direct and to the point. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
No
For smaller entities, for which few of the Attachment 1 events apply (eg a 75 MW wind farm), a drill is overkill. Reviewing the procedure during training should be sufficient. The solution is to require a drill for any entity for which any of the Attachment 1 events would cause a Reportable Disturbance or reportable DOE OE-417 event and training review for any other entities. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
R4 is redundant with R3 and should be deleted. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
No
The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
No
Comments were included in previous comments.
No
M1 is OK. M2 should be about implementation, not about any particular events--M5 is about events. Implementation would include distribution and training. M3 should be modified to reflect a training review by entities that cannot cause a Reportable Disturbance or reportable DOE OE-417 event and for the others documentation of an actual event (which is not included in the present M3) or a drill or mock event. M4 is OK. M5 should only include the reports submitted and the date of submission. Further evidence of the event is redundant.
No
If there are any, they should all be Low because this is reporting of historical events. There is no direct effect on BES reliability. Some effect could occur if someone reacts to the reports, but many are concerning unpreventable events.
No
There should be only Lower VSL's. This is reporting of historical events and there is no direct effect on BES reliability. How does missing 3 parts of R1 compare to tripping a 4,000 MW generating station because vegetation was not properly managed? Just because there are 4 levels. doesn't mean that all Standards need to use them all. If you step

back, and think about causes of cascading outages, reporting events 1 hour or 24 hours later has no significance. There is no direct preventative causation either.
No
These requirements have no time horizon. There about history and not about the future.
Yes
This revision seriously missed the mark.
Group
SERC OC Standards Review Group
Gerald Beckerle
Yes
No
We believe the definition is too broad even considering Attachment 1, footnote1, which, for example, uses the term significantly and other ambiguous terms. Consideration should be given to limiting the definition to unplanned events.
Yes
No
We agree that all of the entities listed should be responsible for reporting an event, provided they own BES assets, but guidance should be given for which entity in Attachment 1 actually files the report to avoid duplication for a single event.
No
We agree that the ERO should not have requirements applicable to them, but disagree with changing or revising the Rules of Procedure (ROP) giving this reporting responsibility solely to NERC. This responsibility may be performed by NERC but other learning organizations should also be considered for performing this responsibility. In addition, the proposed wording of the revision to the ROP appears to place the responsibility of notifying the appropriate law enforcement with NERC rather than with the local responsible entity.
No
This is a reporting requirement and should not be confused with Operating Plans that have specific operating actions and goals. Each entity should prepare its own event reporting guideline that address impact events, identification, information gathering, and communication without specifying a specific format such as Operating Plans, Operating Process and Operating Procedures.
No
We agree with the concept, but disagree with the use of the term "Operating Plan" as a defined term in line with our comments in question 6 above.
No
Annual testing of an "after-the-fact" reporting procedure does not add to the reliability of the BES!
Yes
We agree with the concept, but disagree with the use of the term "Operating Plan" as a defined term in line with our comments in question 6 above.
Yes
We agree with the concept, but disagree with the use of the term "Operating Plan" as a defined term in line with our comments in question 6 above.
No
While we agree with the changes made, we do not believe the goal of eliminating duplicate reporting has been accomplished. In addition, the threshold for transmission loss does not adequately translate to previous "loss of major system components" which had a threshold of "significantly affects the integrity of interconnected system operations".
No
The measures should be revised to match the general nature of the comments we have made on each requirement.
No
How can an after-the-fact report require a VRF greater than low?
No
The VSLs should reflect the comments on the requirements above.
No
R2 and R5 should be in the Operations Assessment time horizon.
Yes

In Attachment 1, the reporting timeline should be no less than the end of the next business day for after-the-fact reporting of events. If reporting in a time frame less than this is required for reliability, the groups or organizations receiving the reports should be included in the functional model. The emphasis should be on giving the operators the time to respond to events and not to reporting requirements. "The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers."
Individual
Patricia Robertson
BC Hydro
1 - Transmission Owners, 2 - RTOs and ISOs, 3 - Load-serving Entities, 5 - Electric Generators
Yes
Yes
For the change from 24hr to 1hr reporting for events, 1 hour goes extremely quickly in these types of events and it will be difficult to report anything meaningful. As the RC is kept informed during the event why is the report required within 1hr?
Individual
Tony Kroskey
Brazos Electric Power Cooperative
1 - Transmission Owners
No
Instead of Impact Event could simply call it Event Information Reporting.
No
Yes
No
Inclusion of LSE and DP is questionable.
No
Yes
Yes
Yes
Yes

No
Question applicability to DP.
No
M2 and M5 appear to duplicate each other.
No
A one year implementation is needed to develop and implement formal documents to meet requirements.

## Stakeholders in the Reporting Process

- Industry
  - NERC (ERO)
  - FERC
  - DOE
  - DHS – Federal
  - Homeland Security- State
  - State Regulators
  - Local Law Enforcement
  - State Law Enforcement
  - FBI
  - **Royal Canadian Mounted Police (RCMP) (addition)**
  - **Provincial Law Enforcement (addition)**
  - **Municipal Law Enforcement (addition)**

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**

A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

The above should read as follows;

### **Coordination of Municipal and Provincial Law Enforcement Agencies with the RCMP**

A similar law enforcement coordination hierarchy exists in Canada. Municipal and provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. Municipal and provincial law enforcement agencies have a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Impact Event EOP-004-2). Essentially, reporting an Impact Event to law enforcement agencies will only require the industry to notify the state or provincial level law enforcement agency. The state or provincial level law enforcement agency will coordinate with local law enforcement to investigate. If the state or provincial level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial level law enforcement agency will notify and coordinate with the FBI or the RCMP.

The above should read as follows; (red reflects suggested changes)

### **A Reporting Process Solution – EOP-004**

A proposal discussed with FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Impact Event EOP-004-2). Essentially, reporting an Impact Event to law enforcement agencies will only require the industry to notify the state **or provincial or local or municipal law enforcement agency**. The state **or provincial or local or municipal law enforcement agency will coordinate with law enforcement of jurisdiction to investigate**. If the state **or provincial or local or municipal law enforcement agency decides federal agency law enforcement should respond and investigate**, the state **or provincial or local or municipal law enforcement agency will notify and coordinate with the FBI or the RCMP**.



## Compliance

### Compliance Enforcement Authority

- Regional Entity; or
- If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement.

The above needs to reflect Canadian compliance authorities as they do not include FERC therefore I suggest the following (red reflects suggested changes/additions)

- Regional Entity; **and or applicable Canadian provincial authority; or**
- If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity), **or applicable Canadian Provincial authority**, responsible for compliance enforcement.

## Consideration of Comments on Disturbance & Sabotage Reporting – Project 2009-01

The Disturbance & Sabotage Reporting Drafting Team (DSR SDT) thanks all commenters who submitted comments on the Second Posting of EOP-004-2, Impact Event Reporting (Project 2009-01).

This standard was posted for a 30-day public comment period from March 9, 2011 through April 8, 2011. The stakeholders were asked to provide feedback on the standard through a special Electronic Comment Form. There were 60 sets of comments, including comments from 188 different people from approximately 132 companies representing 10 of the 10 Industry Segments as shown in the table on the following pages.

In this report, comments have been organized by question to make it easier to see where there is consensus. Comments may be reviewed in their original format on the project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Herb Schrayshuen, at 404-446-2560 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

**Summary Consideration:** The DSR SDT received many comments regarding the proposed definition of “Impact Event,” the requirements, and event reporting in Attachment 1. The main stakeholder concerns were addressed as follows:

- Many stakeholders disagreed with the need for the definition of “Impact Event” and felt that the definition was ambiguous and created confusion. The DSR SDT agrees and has deleted the proposed definition from the standard. The list of events in Attachment 1 is all-inclusive and no further attempts to define “Impact Event” are necessary.
- Many stakeholders raised concerns with the 1 hour reporting requirement for certain types of events. The commenters believed that the restoration of service or the return to a stable bulk power system state may be jeopardized by having to report certain events within one hour. The DSR SDT agreed and revised the reporting time to 24 hours for most events, with the exception of damage or destruction of BES equipment, forced intrusion or cyber related incidents.
- Many stakeholders suggested that the reporting of events after the fact only justified a VRF of “lower” for each requirement. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF, as this requirement deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all “lower” with the exception of Requirement R2 which is a requirement to analyze

---

<sup>1</sup> The appeals process is in the [Standard Processes Manual](#).

events. This standard relates only to reporting events. Analysis of reported events is addressed through the NERC Events Analysis Program. Proposed changes to the Electric Reliability Organization Events Analysis Process Field Trial documents that clarify the role of the Events Analysis program in analyzing reported events will be posted for stakeholder comment separately.

- The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events to the appropriate entities in accordance with the Operating Plan based on Attachment 1. Requirement R3 makes sure that an entity can communicate information about events. Some of these events are dealing with potential sabotage events, and part of the reason to communicate these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 are consistent with the existing approved VRFs for both EOP-004 and CIP-001.
- Several commenters wanted more clarity regarding which entities report and to whom they report. Many stakeholders were confused regarding law enforcement notifications and questioned whether certain types of events (IROL, Public Appeal, etc.) needed to be reported to law enforcement. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:
  - “The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”
- Some commenters also questioned whether or not the existing applicability would result in multiple reports being submitted by different entities for the same event. NERC staff has indicated that this is acceptable and that having multiple types of entities report the same event may provide different types of information about the event.

Commenters also had concerns about the applicability of the standard to Load Serving Entities who may not own physical assets as well as to the ERO and Regional Entity. The DSR SDT agrees that the Distribution Provider owns the assets per the Functional Model; however the LSE is an applicable entity under CIP-002. Events relating the CIP-002 assets are to be reported by the LSE. These are envisioned to be cyber assets. The DSR SDT also include the ERO or the RE as applicable entities based on the applicability of CIP-002

Some commenters identified issues with the footnotes in Attachment 1. These were revised as suggested. There were a few instances where the word “sabotage” remained in the standard or the flowchart. The DSR SDT has removed all instance of “sabotage” and replaced them with “event,” and revised the flowchart to remove references to sabotage.

Several commenters were concerned that the DSR SDT and the NERC Events Analysis Working Group (EAWG) may not be in alignment. The DSR SDT is working in close coordination with the EAWG and will continue to develop the standard and will make the EAWG aware of the DSR SDT’s efforts.

The issue of the FERC directives relating to this project was broached by several commenters. The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure. This process is being revised by the EAWG. Discussions with FERC staff indicate that the current efforts of the DSR SDT and the EAWG are sufficient to address the intent of the directive.

After the drafting team completed its consideration of stakeholder comments, the standards and implementation plan were submitted for quality review. Based on feedback from the quality review, the drafting team has made two significant revisions to the standard. The first revision is to add a requirement for implementation of the Operating Plan listed in Requirement R1. There was only a requirement to report events, but no requirement specifically calling for updates to the Operating Plan or the annual review. This was accomplished by having two requirements. The first is Requirement R2 which specifies that an entity must implement the Operating Plan per Requirement R1, Parts 1.1, 1.2, 1.4 and 1.5:

R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.

The second Requirement is R3 which addresses Part 1.3:

R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

The second revision based on the quality review pertains to Requirement R4. The quality review suggested revising the requirement to more closely match the language in the Rationale box that the drafting team developed. This would provide better guidance for responsible entities as well as provide more clear direction to auditors. The revised requirement is:

R4. Each Responsible Entity shall verify (through actual implementation for an event, or through a drill or exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification or actual implementation.

## Index to Questions, Comments, and Responses

1. Do you agree with the revised Purpose Statement of EOP-004-2, Impact Event Reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	15
2. Do you agree with the proposed definition of Impact Event? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	23
3. Do you agree that the DSR SDT has provided an equally efficient and effective solution to the FERC Order 693 directive to “further define sabotage”? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	38
4. Do you agree with the proposed applicability of EOP-004-2 shown in Section 4 and Attachment 1 of the standard? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	46
5. Stakeholders suggested removing original Requirements 1, 7 and 8 from the standard and addressing the reliability concepts in the NERC Rules of Procedure. Do you agree with the removal of original requirements 1, 7 and 8 (which were assigned to the ERO) and the proposed language for the Rules of Procedure (Paragraph 812)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	64
6. Do you agree with the proposed revisions to Requirement 2 (now R1) including the use of defined terms Operating Plan, Operating Process and Operating Procedure? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	70
7. Do you agree with the proposed revisions to Requirement 3 (now R2)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	87
8. Do you agree with the proposed revisions to Requirement 4 (now R3)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	98
9. Do you agree with the proposed revisions to Requirement 5 (now R4)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	113
10. Do you agree with the proposed revisions to Requirement 6 (now R5) and the use of either Attachment 2 or the DOE-OE-417 form for reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	123
11. Do you agree with the proposed revisions to Attachment 1? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	134
12. Do you agree with the proposed measures for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	159
13. Do you agree with the proposed Violation Risk Factors for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	<b>Error! Bookmark n</b>
14. Do you agree with the proposed Violation Severity Levels for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	<b>Error! Bookmark n</b>
15. Do you agree with the proposed Time Horizons for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	189
16. Do you agree with the proposed Implementation Plan for EOP-004-2? If not, please explain why not and if possible, provide an alternative that would be acceptable to you. ....	195
17. If you have any other comments you have not already provided in response to the questions above, please provide them here. ....	201

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

The Industry Segments are:

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
1.	Group	David Revill	Georgia Transmission Corporation & Oglethorpe Power Corporation			X	X	X					
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	John Miller	Georgia Transmission Corporation	SERC	1									
2.	Greg Davis	Georgia Transmission Corporation	SERC	1									
3.	Jason Snodgrass	Georgia Transmission Corporation	SERC	1									
4.	Scott McGough	Oglethorpe Power Corporation	SERC	5									
2.	Group	Guy Zito	Northeast Power Coordinating Council					X					
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10									
2.	Gregory Campoli	New York Independent System Operator	NPCC	2									
3.	Kurtis Chong	Independent Electricity System Operator	NPCC	2									
4.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1									
5.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1									
6.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10									
7.	Si Truc Phan	Hydro-Quebec TransEnergie	NPCC	1									

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual	Commenter	Organization			Registered Ballot Body Segment															
					1	2	3	4	5	6	7	8	9	10						
8. Mike Garton	Dominion Resources Services, Inc.	NPCC	5																	
9. Brian L. Gooder	Ontario Power Generation Incorporated	NPCC	5																	
10. Kathleen Goodman	ISO - New England	NPCC	2																	
11. David Kiguel	Hydro One Networks Inc.	NPCC	1																	
12. Michael R. Lombardi	Northeast Utilities	NPCC	1																	
13. Randy MacDonald	New Brunswick Power Transmission	NPCC	1																	
14. Bruce Metruck	New York Power Authority	NPCC	6																	
15. Chantel Haswell	FPL Group, Inc.	NPCC	5																	
16. Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10																	
17. Robert Pellegrini	The United Illuminating Company	NPCC	1																	
18. Saurabh Saksena	National Grid	NPCC	1																	
19. Michael Schiavone	National Grid	NPCC	1																	
20. Wayne Sipperly	New York Power Authority	NPCC	5																	
21. Donald Weaver	New Brunswick System Operator	NPCC	1																	
22. Ben Wu	Orange and Rockland Utilities	NPCC	1																	
23. Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC	3																	
3.	Group	Denise Koehn	Bonneville Power Administration					X	X	X	X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region Segment Selection</b>																
1.	Jim Burns	BPA, Transmission, Technical Operations		WECC	1															
4.	Group	Carol Gerou	Midwest Reliability Organization			X		X		X	X									
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region Segment Selection</b>																
1.	Mahmood Safi	Omaha Public Utility District		MRO	1, 3, 5, 6															
2.	Chuck Lawrence	American Transmission Company		MRO	1															
3.	Tom Webb	Wisconsin Public Service Corporation		MRO	3, 4, 5, 6															
4.	Jodi Jenson	Western Area Power Administration		MRO	1, 6															
5.	Ken Goldsmith	Alliant Energy		MRO	4															
6.	Alice Ireland	Xcel Energy		MRO	1, 3, 5, 6															
7.	Dave Rudolph	Basin Electric Power Cooperative		MRO	1, 3, 5, 6															

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual	Commenter	Organization		Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
8.	Eric Ruskamp	Lincoln Electric System	MRO	1, 3, 5, 6											
9.	Joseph Knight	Great River Energy	MRO	1, 3, 5, 6											
10.	Joe DePoorter	Madison Gas & Electric	MRO	3, 4, 5, 6											
11.	Scott Nickels	Rochester Public Utilities	MRO	4											
12.	Terry Harbour	MidAmerican Energy Company	MRO	1, 3, 5, 6											
13.	Richard Burt	Minnkota Power Cooperative, Inc.	MRO	1, 3, 5, 6											
5.	Group	Steve Rueckert	Western Electricity Coordinating Council						X						
<b>Additional Member Additional Organization Region Segment Selection</b>															
1.	Don Pape	WECC	WECC	10											
2.	Phil O'Donnell	WECC	WECC	10											
6.	Group	Annette Bannon	PPL Supply		X		X		X	X					
<b>Additional Member Additional Organization Region Segment Selection</b>															
1.	Mark Heimbach	PPL Martins Creek, LLC	RFC	5, 6											
7.	Group	Steve Alexanderson	Pacific Northwest Small Public Power Utility Comment Group						X					X	
<b>Additional Member Additional Organization Region Segment Selection</b>															
1.	Dave Proebstel	Clallam County PUD No.1	WECC	3											
2.	Russell A. Noble	Cowlitz County PUD No. 1	WECC	3, 4, 5											
3.	Ronald Sporseen	Blachly-Lane Electric Cooperative	WECC	3											
4.	Ronald Sporseen	Central Electric Cooperative	WECC	3											
5.	Ronald Sporseen	Clearwater Power Company	WECC	3											
6.	Ronald Sporseen	Douglas Electric Cooperative	WECC	3											
7.	Ronald Sporseen	Fall River Rural Electric Cooperative	WECC	3											
8.	Ronald Sporseen	Northern Lights	WECC	3											
9.	Ronald Sporseen	Lane Electric Cooperative	WECC	3											
10.	Ronald Sporseen	Lincoln Electric Cooperative	WECC	3											
11.	Ronald Sporseen	Raft River Rural Electric Cooperative	WECC	3											



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
12. Ronald Sporseen	Lost River Electric Cooperative	WECC 3												
13. Ronald Sporseen	Salmon River Electric Cooperative	WECC 3												
14. Ronald Sporseen	Umatilla Electric Cooperative	WECC 3												
15. Ronald Sporseen	Coos-Curry Electric Cooperative	WECC 3												
16. Ronald Sporseen	West Oregon Electric Cooperative	WECC 3												
17. Ronald Sporseen	Pacific Northwest Generating Cooperative	WECC 3, 4, 8												
18. Ronald Sporseen	Power Resources Cooperative	WECC 5												
19. Ronald Sporseen	Consumers Power	WECC 1, 3												
20. Steven J. Grega	Public Utility District #1 of Lewis County	WECC 5												
8.	Group	Patricia Hervocho	PSEG Companies	X					X					
<b>Additional Member</b>			<b>Additional Organization</b>	<b>Region</b>	<b>Segment</b>	<b>Selection</b>								
1.	Jeffrey Mueller	PSE&G			3									
2.	Kenneth Brown	PSE&G			1									
3.	Peter Dolan	PSEG ER&T			6									
4.	Eric Schmidt	PSEG ER&T			6									
5.	Clint Bogan	PSEG Fossil			5									
6.	Dominic Grasso	PSEG Fossil			5									
7.	Kenneth Petroff	PSEG Nuclear			5									
8.	Patricia Hervocho	PSEG NERC Compliance			NA									
9.	Group	Louis Slade	Dominion			X	X	X						
<b>Additional Member</b>			<b>Additional Organization</b>	<b>Region</b>	<b>Segment</b>	<b>Selection</b>								
1.	Lou Roeder	Electric Transmission	SERC		1, 3									
2.	Mike Garton	Electric Market Policy	NPCC		5, 6									
3.	Connie Lowe	Electric Market Policy	RFC		5, 6									
4.	Jack Kerr	Electric Transmission	SERC		3, 1									
5.	Len Sandberg	Electric Transmission	SERC		3, 1									
10.	Group	David Thorne	Pepco Holdings Inc and Affiliates			X								

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		Mark Godfrey	RFC	1, 3										
11.	Group	Robert Rhodes	SPP Standards Review Group	X		X		X	X					
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		John Allen	City Utilities of Springfield, MO	SPP	1, 4									
2.		George Allan	Sunflower Electric Power Corporation	SPP	1									
3.		Michelle Corley	CLECO	SPP	1, 3, 5, 6									
4.		Robert Cox	Lea County Electric Cooperative	SPP	1, 3									
5.		Kevin Emery	Carthage Water and Electric	SPP	3									
6.		Denney Fales	Kansas City Power & Light	SPP	1, 3, 5, 6									
7.		Louis Guidry	CLECO	SPP	1, 3, 5, 6									
8.		Jonathan Hayes	SPP	SPP	2									
9.		Philip Huff	Arkansas Electric Cooperative Corporation	SPP	3, 4, 5, 6									
10.		Gregory McAuley	Oklahoma Gas & Electric	SPP	1, 3, 5									
11.		Terri Pyle	Oklahoma Municipal Power Authority	SPP	4									
12.		Sean Simpson	Board of Public Utilities, City of McPherson, KS	SPP	1, 3, 5									
13.		Tay Sing	Oklahoma Municipal Power Authority	SPP	4									
14.		Chad Wasinger	Sunflower Electric Power Corporation	SPP	1									
15.		Mark Wurm	Board of Public Utilities, City of McPherson, KS	SPP	1, 3, 5									
16.		Ron Gunderson	Nebraska Public Power District	MRO	1, 3, 5									
17.		Bruce Schutte	Nebraska Public Power District	MRO	1, 3, 5									
18.		Jeff Elting	Nebraska Public Power District	MRO	1, 3, 5									
12.	Group	Marie Knox	Midwest ISO Standards Collaborators		X									
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.		Bob Thomas	Illinois Municipal Electric Agency	RFC	4									
2.		Jim Cyrulewski	JDRJC Associates, LLC	RFC	8									
3.		Terry Harbour	MidAmerican	MRO	1									
4.		Joe O'Brien	NIPSCO	RFC	6									

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
5. Robert Thomasson		Big Rivers Electric Corp.	SERC	1, 3									
13.	Group	Sam Ciccone	FirstEnergy	X		X		X	X				
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	Doug Hohlbaugh	FE	RFC	1, 3, 4, 5, 6									
2.	Bill Duge	FE	RFC	5									
3.	John Reed	FE	RFC	1									
4.	Jim Eckels	FE	RFC	1									
5.	Kevin Querry	FE	RFC	5									
6.	Ken Dresner	FE	RFC	5									
14.	Group	Gerald Beckerle	SERC OC Standards Review Group					X					
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	David Trego	Fayetteville PWC	SERC	1, 3, 4, 9									
2.	Melinda Montgomery	Entergy	SERC	1, 3									
3.	Andy Burch	EEL	SERC	1, 5									
4.	Eugene Warnecke	Ameren	SERC	1, 3									
5.	Chuck Feagans	TVA	SERC	1, 3, 5, 9									
6.	Larry Rodriquez	Entegra Power	SERC	5, 6									
7.	Gary Hutson	SMEPA	SERC	1, 3, 5, 9									
8.	Jennifer Weber	TVA	SERC	1, 3, 5, 9									
9.	Doug White	NCEMC	SERC	1, 3, 5, 9									
10.	Shaun Anders	CWLP	SERC	1, 3, 5, 9									
11.	Jake Miller	Dynegy	SERC	5, 6									
12.	Reggie Wallace	Fayette PWC	SERC	1, 3, 4, 9									
13.	Dan Roethemeyer	Dynegy	SERC	5, 6									
14.	Alvis Lanton	SIPC	SERC	1, 3, 5, 9									
15.	Marc Butts	Southern	SERC	1, 3, 5									
16.	Robert Thomasson	BREC	SERC	1, 3, 5, 9									
17.	Srinivas kappagantula	PJM	SERC	2									

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment																
				1	2	3	4	5	6	7	8	9	10							
18.	Barry Hardy	OMU	SERC	1, 3, 5, 9																
19.	Rene' Free	Santee Cooper	SERC	1, 3, 5, 9																
20.	Greg Matejka	CWLP	SERC	1, 3, 5, 9																
21.	John Troha	SERC Reliability Corp.	SERC	10																
15.	Individual	Srinivas Kappagantula	PJM Interconnection LLC		X															
16.	Individual	Cindy Martin	Southern Company					X												
17.	Individual	Cynthia Oder	SRP		X															
18.	Individual	Howard Rulf	We Energies		X				X		X									
19.	Individual	Brent Ingebrigtsen	LG&E and KU Energy LLC		X															
20.	Individual	Silvia Parada Mitchell	Compliance & Responsibility Organization				X													
21.	Individual	John Bee	Exelon		X		X		X	X										
22.	Individual	Jennifer Wright	SDG&E				X													
23.	Individual	Alan Gale	City of Tallahassee (TAL)		X															
24.	Individual	Mace Hunter	Lakeland Electric						X											
25.	Individual	Nathaniel Larson	New Harquahala Generating Co.		X		X		X	X										
26.	Individual	Brian Pillittere	Tenaska						X											
27.	Individual	Michael Johnson	APX Power Markets				X	X												

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
28.	Individual	Jonathan Appelbaum	United Illuminating Co	X		X	X	X	X				
29.	Individual	Kevin Koloini	American Municipal Power					X					
30.	Individual	Daniel Duff	Liberty Electric Power LLC	X	X	X		X					
31.	Individual	Philip Huff	Arkansas Electric Cooperative Corporation	X									
32.	Individual	Joe Petaski	Manitoba Hydro	X									
33.	Individual	Mike Albosta	Sweeny Cogeneration LP			X	X	X					
34.	Individual	Thad Ness	American Electric Power					X					
35.	Individual	Andres Lopez	USACE			X	X	X	X				
36.	Individual	Nathaniel Larson	New Harquahala Generating Co.	X		X		X	X				
37.	Individual	Eric Salsbury	Consumers Energy					X					
38.	Individual	Michael Falvo	Independent Electricity System Operator	X		X		X	X				
39.	Individual	Kirit Shah	Ameren					X				X	
40.	Individual	Kathleen Goodman	ISO New England, Inc	X				X					
41.	Individual	Deborah Schaneman	Platte River Power Authority			X	X	X					
42.	Individual	Phil Porter	Calpine Corp		X								
43.	Individual	Bill Keagle	BGE	X		X		X	X				

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
44.	Individual	Kenneth A Goldsmith	Alliant Energy		X									
45.	Individual	John Brockhan	CenterPoint Energy	X		X		X	X					
46.	Individual	Martin Kaufman	ExxonMobil Research and Engineering					X						
47.	Individual	Brenda Truhe	PPL Electric Utilities	X										
48.	Individual	Tim Soles	Occidental Power Marketing				X							
49.	Individual	Eric Ruskamp	Lincoln Electric System	X										
50.	Individual	Linda Jacobson	Farmington Electric Utility System	X				X		X				
51.	Individual	Andrew Z Puszta	American Transmission Company	X										
52.	Individual	Michelle D'Antuono	Ingleside Cogeneration LP			X								
53.	Individual	Greg Rowland	Duke Energy	X		X		X						
54.	Individual	Amir Hammad	Constellation Power Generation			X								
55.	Individual	Scott Barfield-McGinnis	Georgia System Operations Corporation	X										
56.	Individual	Max Emrick	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power					X						
57.	Individual	Rex Roehl	Indeck Energy Services	X		X		X	X					
58.	Individual	Patricia Robertson	BC Hydro					X						

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
59.	Individual	Tony Kroskey	Brazos Electric Power Cooperative			X	X							
60.	Individual	Jim Eckelkamp	Progress Energy	X										

**1. Do you agree with the revised Purpose Statement of EOP-004-2, Impact Event Reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of stakeholders agree with the purpose statement. Some commenters had concerns with the use of the words "if known" and "industry awareness" and statements on requiring information from an analysis in the report which may not be known at the time of the report. Comments on this being an "after the fact" report and not real-time reporting have been addressed by a significant revision to the change in reporting times reflected in Attachment 1.

A number of commenters offered suggestions on the use of terms "situational awareness" versus "industry awareness." The DSR SDT used "industry awareness" to address concerns about real-time reporting (which this standard does not cover) and to avoid confusion with the NERC Situational Awareness organization.

The purpose statement was slightly revised to remove the defined term "Impact Event" and replace with the phrase "events with the potential to impact reliability". No other revisions were made.

"To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities."

Organization	Yes or No	Question 1 Comment
Exelon	No	<p>Although Exelon agrees that the proposed revision to the purpose statement of EOP-004-2 is better than the original draft; the DSR SDT should consider aligning the definition with the existing OE-417 terms. "Impact Events" are not clearly defined as reportable criteria in the DOE forms and may create confusion. Suggest rewording the purpose statement to simply "Incident Reporting" to align with existing terminology in OE-417 and removing the addition of a new term.</p> <p>A Purpose Statement is defined as "The reliability outcome achieved through compliance with the requirements of the standard." Propose that the purpose should be, "To require a review, assessment and report of events that could have an adverse material impact on the Bulk Electric System."</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. Form OE-417 report is a DOE report that is not specifically related to BES reliability and is not applicable outside of the United States. The standard only requires reporting of events. Analysis occurs through the NERC Events Analysis Program.</p>		
SDG&E	No	<p>SDG&amp;E does not agree with the revised Purpose Statement because it does not reflect the standard's purpose of identifying reporting requirements for impact events. SDG&amp;E recommends the following revised Purpose Statement:</p> <p>"To identify the reporting requirements for events considered to have an impact on the reliability of the Bulk</p>



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 1 Comment
		Electric System and to allow an awareness of these Impact Events to be understood by the industry in recognizing potential enhancements that may be made to the reliability of the BES.”
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the existing purpose statement addresses most of your suggested rewording. The last phrase “recognizing potential enhancements that may be made to the reliability of the BES” is not in the scope of the standard or this project.</p>		
Dominion	No	It is not evident how Impact Event reporting will “improve industry awareness“ as suggested in the Purpose Statement. The transfer of Requirement R8 (ERO quarterly report) to the Rules of Procedure (paragraph 812) invalidates that claim within the context of this standard. Suggest removing this phrase from the Purpose Statement.
<p><b>Response:</b> The DSR DT thanks you for your comment. The ERO will issue reports for industry awareness purposes under the Rules of Procedure. If entities do not report events to the ERO, then these reports will not be issued.</p>		
SPP Standards Review Group	No	We would suggest changing the purpose to read “To improve industry awareness and effectiveness in addressing risk to the BES by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities.”
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT contends that the phrase “addressing risk to the BES” applies to the analysis of events which is not covered under the standard.</p>		
United Illuminating Co	No	UI agrees with the idea but believes the statement can be improved to remove ambiguities. For example: “if known” can be modifying the word causes, or the word Impact events. To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of identified Impact Events and if known their causes, if known, by the Responsible Entities.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The words “if known” are intended to modify the word ‘causes.’ The DSR SDT has revised the existing wording (from the clean version of the standard) to: <i>To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities.</i></p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 1 Comment
Arkansas Electric Cooperative Corporation	No	The purpose statement reads "To improve industry awareness of the BES." We suggest the purpose should state "To improve industry awareness and effectiveness in addressing risks to the BES." We feel the remaining purpose statement is unnecessary.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT contends that the phrase "addressing risk to the BES" applies to the analysis of events which is not covered under the standard.</p>		
Manitoba Hydro	No	<p>Situational Awareness was replaced by the generic "Industry awareness." Justification for this was that Situational Awareness was a byproduct of a successful event reporting system and not a driver.</p> <p>Using Industry awareness clouds the clarity of the purpose. If personal are properly trained and conscious of their responsibilities, then they are in fact situationally aware, and will therefore drive the reporting process on the detection an Impact Event. Industry awareness falsely labels this Standard as unique to the electrical industry when clearly many outside and international agencies will be notified and involved. Situational Awareness seems much more appropriate and encompassing. Other then that the Purpose is a large improvement from the original.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT changed "situational awareness" to "industry awareness" to address concerns about real-time reporting (which this standard does not cover) and to avoid confusion with the NERC Situational Awareness organization.</p>		
Ameren	No	The original Purpose wording was clear, concise and understandable.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The original purpose statement was in the form of a requirement and not a purpose statement.</p>		
ISO New England, Inc	No	The purposed states To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known, by the Responsible Entities. Awareness by who in the industry?
<p><b>Response:</b> The DSR SDT thanks you for your comment. The requirements of this standard require that events be reported after-the-fact. The NERC Events Analysis Program will take certain events reported under this standard and analyze them to provide information to the entire body of users, owners and operators of the BES.</p>		
Calpine Corp	No	The purpose has moved significantly from the originally approved SAR. The purpose should focus on reporting requirements for reporting electrical disturbances to the Bulk Electric System that exceed specific thresholds. Sabotage/vandalism/theft are a subset of the reportable events that could have or do cause a Bulk Electric System Electrical Disturbance. The Standards content should focus on setting requirements to

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 1 Comment
		report specific types of electrical disturbance events and providing guidance for performing that reporting. Alternative language: Purpose: To establish reporting requirements for events that either cause, or have the potential to cause, significant disturbances on the Bulk Electric System.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The purpose covers the EOP-004 and CIP-001 standards which include disturbance and sabotage. The use of the word 'events' and the definition of the specific events to be reported (see Attachment 1) is a result of combining these two standards as well as the drafting team's efforts to address FERC Order 693 Directives. The proposed purpose statement does not adequately address these items.</p>		
BGE	No	BGE believes that using the term Impact Events as currently defined is too vague. An alternative statement would be requiring the reporting of events listed in Attachment 1 and their causes, if known and making the definition change as noted in question 2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated the defined term "Impact Events" and uses the generic term "events: in the purpose statement.</p> <p><i>To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities.</i></p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	"To improve industry awareness and the reliability fo the Bulk Electric System by requiring the reporting of Impact Events and their causes, if known by the Responsible Entities." The revised purpose statement includes the phrase, if known. This seems like a huge loophole. They should change it to when discovered or when notified.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of "if known" was to make sure that events were reported regardless of whether the cause was known. It is important for entities to report events and to return the BES to a reliable operating state. Investigation of causes can occur at a later time.</p>		
Indeck Energy Services	No	The reporting of events does not improve the reliability of the BES. If someone takes action based on the reporting, there might be an improvement. Because many of these events are not preventable, such as sabotage or weather, reporting them won't improve reliability. The original Purpose was satisfactory.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The requirements of this standard require that events be reported after-the-fact. The NERC Events Analysis Program will take certain events reported under this standard and analyze them to provide information that will lead to improvements in BES reliability.</p>		
Brazos Electric Power Cooperative	No	Instead of Impact Event could simply call it Event Information Reporting.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 1 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event."</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
Georgia Transmission Corporation & Oglethorpe Power Corporation	Yes	We find it unnecessary to state that the purpose of a Reliability Standard is to "improve the reliability of the Bulk Electric System."
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT disagrees. This is an integral part of the purpose of reporting events.</p>		
Midwest Reliability Organization	Yes	The addition of "industry awareness" adds to the scope of this Standard. Whereby an entity is required to inform the RC and others of actual and potential Impact Events.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has streamlined Attachment 1 to ensure that the proper reporting is accomplished.</p>		
American Municipal Power	Yes	The purpose is acceptable. I think it could be improved and simplified. There were not any questions on the title. Consider changing the title to Reportable Events. There were not any questions on the category. I suggest changing the category from Emergency Operations to Communications. Reporting events can trigger and be more than just Emergency Operations. I feel the reporting function performed by entities should be under the Communications category. Title: Reportable Events Purpose: To improve reliability by communicating timely information about an event or events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT revised the existing title of the standard to conform to the intended purpose of reporting events. The team discussed making this a COM standard during the initial DT discussions but decided to retain the existing EOP-004 standard category and number. This is not a real-time reporting standard but requires after the fact reporting.</p>		
Ingleside Cogeneration LP	Yes	The addition of the modifier if known to reporting the cause of an Impact Event is appropriate. It often proves counter-productive to speculate as initial conjectures of the cause of an event are easy to come up with, but difficult to back out of later.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
Duke Energy	Yes	However, as we have noted previously, the DSR SDT statement that the proposed changes do not include any real-time operating notifications is inconsistent with requiring notification within one hour for thirteen of the

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 1 Comment
		<p>twenty listed Events in Attachment 1 Impact Event Table. Also, in the Background discussion, under Law Enforcement, the DSR SDT states that the objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting Impact Events. As we have previously commented, we are still required to make real-time reports under other standards. Requiring duplicate real-time reporting under EOP-004-2 is a waste of resources which could otherwise be used to improve reliability.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have made significant revisions to Attachment 1 and the reporting time requirements to address the real-time reporting concern.</p>		
Constellation Power Generation	Yes	<p>While CPG generally agrees with the purpose statement, we believe that the term Impact Events should be removed. Please see CPGs response to Question 2 discussing the term Impact Events.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Please see responses to comments on question 2.</p>		
Georgia System Operations Corporation	Yes	<p>We agree with the purpose. However, we do not agree that the purpose will be achieved as this standard is currently drafted or that the standard is ready for balloting.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have made significant revisions to the body of the standard and Attachment 1.</p>		
Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Western Electricity Coordinating Council	Yes	
PPL Supply	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 1 Comment
Pepco Holdings Inc and Affiliates	Yes	
Midwest ISO Standards Collaborators	Yes	
FirstEnergy	Yes	
SERC OC Standards Review Group	Yes	
PJM Interconnection LLC	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	
City of Tallahassee (TAL)	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Liberty Electric Power LLC	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	
USACE	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 1 Comment
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
Platte River Power Authority	Yes	
Alliant Energy	Yes	
CenterPoint Energy	Yes	
ExxonMobil Research and Engineering	Yes	
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
BC Hydro	Yes	

**2. Do you agree with the proposed definition of Impact Event? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of the commenters do not agree with the definition and thought the definition as overly broad, too subjective and confusing. Many commenters questioned whether there was a need for a definition of Impact Event at all. The DSR SDT discussed the comments and suggestions and decided to incorporate commenters’ suggestion to delete the definition and rely on the Attachment 1 to stand on its own.

The DSR SDT has deleted the Impact Event definition.

Organization	Yes or No	Question 2 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	We do not think that Impact Event should be defined using a recursive definition, i.e. that the word "impact" should be used in the definition of the term "Impact Event." Instead, we suggest using an enumerative definition in that the tables included in Attachment 1 are themselves used to define "Impact Event." If this definition is not acceptable, we suggest replacing the word "impact" in the definition with the word reduce, reduced, or potential to reduce the reliability of the BES.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Northeast Power Coordinating Council	No	<p>Is there a need for this definition? By itself the term is not specific on the types of events that are regarded as having an impact. The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. The events that are to be reported can be called anything. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not used anywhere else in the NERC Reliability Standards. For a complete definition of Impact Event, all the elements in Attachment A must be a part of it.</p> <p>Suggest consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
Bonneville Power Administration	Yes	Agree, but note that this will add many more situations to reporting and it will require more staff time to accomplish this.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Midwest Reliability Organization	No	The proposed definition is not supported by any of the established bright line criterias that are contained within attachment 1. This Results Based Standard should close any loop-holes that could be read into any section, especially the definition. According to rules of writing a definition, a definition should not contain part of the word that is being defined. Recommend the definition be enhanced to read: Impact Event: Any Contingency which has either effected or has the potential to effect the Stability of the BES as outlined per attachment 1. Within this enhanced recommendation, presently defined NERC terms are used (Contingency and Stability), thus supporting what is current used within our industry. There is also a quantifiable aspect of as outlined per attachment 1 that clearly defines Impact Events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes the definition is embodied in Attachment 1 criteria and needs no further clarification. We have deleted the proposed defined term "Impact Events" and will use the generic term "event."</p>		
Western Electricity Coordinating Council	No	We question the need for a defined term. It appears that an Impact Event is any event identified in Attachment 1. The use of the defined term combined with the language of Requirement 2 to implement the Impact Event Operating Plan for Impact Events listed in Attachment 1 may be confusing. Is an Impact Event any event described by the proposed definition or is an Impact Event any event listed in Attachment 1?
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT agrees the definition could be confusing. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Dominion	Yes	Dominion agrees with the proposed definition of Impact Events, but notes the use of the phrase has the potential to impact is somewhat subjective. The concern being a Responsible Entity makes a judgment on an events potential impact that is viewed differently after-the-fact by an auditor.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Pepco Holdings Inc and Affiliates	No	The two sentence definition will not be adequate to serve well over the course of time. People will have to read and understand the standard without benefit of the detailed information, explanations and interpretations

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		available during the standards development process. Without additional explanation as provided in the background and the guideline and technical basis sections, to support the definition, the standard will be subject to confusion and interpretations. Consider adding a lot of the information and explanation that is in those sections to the standard. Any event could be an impact event. However, only a subset is reportable. What is really being addressed are reportable events. More specifically after the fact reporting of unplanned events.
<p><b>Response:</b> Thank you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events for the given thresholds listed in Attachment 1.</p>		
Midwest ISO Standards Collaborators	No	The definition of Impact Event is overly broad because of the use of potential to impact and the Such as list. Consider routine switching has the potential to result in a mis-operation. This means all routine switching is an impact event. The Such as list should be struck and potential language should be struck.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term "Impact Events" and will use the generic term "event."</p>		
FirstEnergy	No	Although we agree with the definition of Impact Event, we believe that it should be clear that this term is specific to the events listed in Attachment 1 of the standard. Therefore, we suggest adding the phrase (as detailed in Attachment 1 of EOP-004-2) in the definition.
<p><b>Response:</b> Thank you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
SERC OC Standards Review Group	No	We believe the definition is too broad even considering Attachment 1, footnote1, which, for example, uses the term significantly and other ambiguous terms. Consideration should be given to limiting the definition to unplanned events.
<p><b>Response:</b> Thank you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event."</p>		
PJM Interconnection LLC	No	The term "Impact Event" has been too broadly defined. According to the current definition, any event (including routine operations) can have the potential to impact the reliability of the Bulk Electric System and hence can be an Impact Event. The definition should only include unplanned events. Attachment 1 lists the events that are reportable. It seems that the definition of Impact Event refers to the events in Attachment 1 as opposed to defining Impact Event. As such, it is best that the SDT not define Impact Event but use words to the effect that requires an entity to have a plan and implement it for reporting unplanned events outlined in Attachment 1. If Impact Event were to be defined, we suggest the following definition would be a better

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		option:"An Impact Event is any unplanned event listed in Attachment I that has either adversely impacted or has the potential to adversely impact the reliability of the Bulk Electric System."
<b>Response:</b> Thank you for your comment. We have deleted the proposed defined term "Impact Events" and will use the generic term "event."		
SRP	No	Suggest that definition include reference to the fact that this is non-desired occurrence, as the word 'impact' has neither a positive nor negative implication. This is not a well formed definition as it contains circular references to 'impacted' and 'event' within the definition.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term "Impact Events" and will use the generic term "event."		
We Energies	No	From an on-line dictionary, an event is something that happens. Combined with the phrase has the potential to impact and the definition of Impact Event would include every routine operation performed by any entity. Taking a generator on or off line, switching a transmission line in or out, traffic driving past a substation, all have the potential to impact the BES. The Impact Event definition is overly broad and needs to be significantly narrowed.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term "Impact Events" and will use the generic term "event."		
Compliance & Responsibility Organization	No	<p>NextEra Energy Inc. (NextEra) appreciates the drafting team providing valuable ideas and a framework on how to improve and consolidate CIP-001 and EOP-004. However, NextEra also believes that the currently drafted EOP-004-2 needs to be revised and enhanced to more clearly explain the Responsible Entities' duties, the definition of sabotage and address FERC directives and concerns.</p> <p>For example, NextEra is not in favor using the term "Impact Event" which seems to add considerable confusion of what is or is not sabotage. In Order No. 693, FERC stated its interest in NERC revising CIP-001 to better define sabotage and requiring notification to the certain appropriate federal authorities, such as the Department of Homeland Security. FERC Order 693 at PP 461, 462, 467, 468, 471.</p> <p>NextEra has provided an approach that accomplishes FERC's objectives and remains within the framework of the drafting team, but also focuses the process of determining and reporting only those sabotage acts that could impact other BES systems. Today, there are too many events that are being reported as sabotage to all parties in the Interconnection, when in reality these acts have no material affect or potential impact to other BES systems other than the one that experienced it.</p> <p>For example, while the drafting team notes the issue of copper theft is a localized act, there are other localized acts of sabotage that are committed by an individual, and these acts pose little, if any, impact or threat to other BES systems other than the one experiencing the sabotage event. Reporting sabotage that</p>

Organization	Yes or No	Question 2 Comment
		<p>has no need to sent of everyone does not necessary add to the security or reliability of the BES. Related, there is a need to clarify some of the current industry confusion on who should (and has the capabilities to) be reporting to a boarder audience of entities.</p> <p>Hence, NextEra approach provides a clear definition of sabotage, as well as the process for determining and reporting sabotage. NextEra further believes that some of the requirements can be consolidated and more clearly stated, and NextEra has attempted to do that in the approach presented below.</p> <p>Lastly, NextEra comments on Attachment 1 are submitted in response to question 17. NextEra Approach Delete definition of Impact Event and its use in the requirements and in Attachment 1 Delete 13, 14, 15 and 19 in Attachment 1 Delete and replace R1 through R5 with the following: New Definition Attempted or Actual Sabotage: an intentional act that attempts to or does destroy or damage BES equipment or a Critical Cyber Asset for the purpose of disrupting the operations of BES equipment, Critical Cyber Asset or the BES, and has a potential to materially threaten or impact the reliability of one or more BES systems (i.e., is one act in a larger conspiracy to threaten the reliability of the Interconnection or other BES systems).</p> <p>R1. Each Responsible Entity shall document and implement a procedure (either individually or jointly with other Responsible Entities) to accomplish the reporting requirements, including the time frames, assigned to the Responsible Entity as set forth in Attachment 1 items 1 through 12, 16, 17 and 18 for reporting from the Responsible Entity to its Regional Entity and NERC, using the form in Attachment 2 or the DOE OE-417 reporting form.</p> <p>R2. Each Responsible Entity shall document and implement a procedure (either individually or jointly with other Responsible Entities) to report to its internal personnel with a need to know and its Reliability Coordinator an act of Attempted or Actual Sabotage, using the form in Attachment 2 or the DOE OE-417 reporting form, within one hour after a determination has been made that an act Attempted or Actual Sabotage has occurred. To make a determination that an act of Attempted or Actual Sabotage has occurred, the Responsible Entity shall document and implement a procedure that requires it, as soon as practicable after the discovering an act appearing to be Attempted or Actual Sabotage, to engage local law enforcement or the Federal Bureau of Investigation or Royal Canadian Mounted Police, as deemed appropriate, to assist the Registered Entity make such a determination. Upon receiving a report of Attempted or Actual Sabotage from a Responsible Entity, the Reliability Coordinator shall within one hour forward the report to other impacted Reliability Coordinators, Responsible Entities, Regional Entities, NERC, Department of Homeland Security, and the Federal Bureau of Investigation or the Royal Canadian Mounted Police.</p> <p>R3. Each Responsible Entity shall review (and conduct a test for sabotage only) of its documented procedure required in R1 and R2 with no more than 15 calendar months between tests for sabotage reporting. If, based on the review or test, the Responsible Entity determines there is a need to update its documented procedure, it shall update the procedures within 90 calendar days of the review or test.</p>

Organization	Yes or No	Question 2 Comment
<p><b>Response:</b> Thank you for your comments and suggestions. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Other revisions were made to the standard based on comments received on specific requirements. The DSR SDT believes that these revisions clarify the requirements and has provided additional details in response to comments from questions Q3, Q6, Q7, Q8, Q11, Q12, Q13, Q14 and Q17. Please see the revised standard.</p> <p>In regards to sabotage, the DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability.</p> <p>The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <p>“The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
Exelon	No	<p>The definition of impact events should be reworded to align with OE-417 and to explicitly reference that only events identified in EOP-004 ? Attachment 1 are to be reported. Suggest the following: “An incident that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action as defined in EOP-004 Attachment 1.” Propose the definition be changed to include material impact and read as follows; Any event which has either caused or has the potential to cause an adverse material impact to the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action?</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
City of Tallahassee (TAL)	No	<p>While I agree with the overall concept, I am concerned with “or has the potential to impact.” While the standard makes reference to Attachment 1 Parts A and B, the inclusion of the attachment is not in the definition. This leaves ambiguity in the definition that could enable second guessing by auditors.</p> <p>Proposed: “An impact event is any event that has either impacted or has the potential to impact (above the</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		thresholds described in EOP-004-2 Attachment 1) the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”
<b>Response:</b> Thank you for your comments. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.”		
American Electric Power	No	The definition is too broad and vague. The text in the comment form has the following sentence Only the events identified in EOP-004 Attachment 1 are required to be reported under this Standard. The definition should contain that caveat or something similar.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.		
USACE	No	<p>1) You cannot use the terms impact and event to define impact event.</p> <p>2) The phrase “has the potential to impact” makes the definition too vague. Every action taken to modify the system or its components has the potential to impact the Bulk Electric System.</p> <p>3) Recommend to change the definition to “Any occurrence which has adversely affected the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”</p>
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.		
Consumers Energy	No	The definition of Impact Event seems very vague and nebulous. This definition should be modified to be clear and concise, such that entities clearly understand what is included within the definition.
<b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.		
Ameren	No	<p>The documentation from the SDT included the reliability objective for EOP-004-2 which should be included in the definition of Impact Event. Our suggested alternate definition for Impact Event:</p> <p>“An Impact Event is any event that has either caused, or has the likely potential to cause, an outage which could lead to Cascading. Such events will be identified as being caused by, to the best of the reporting entity's information: (1) equipment failure or equipment mis-operation, (2) environmental conditions, and/or (3) human actions.”</p>

Organization	Yes or No	Question 2 Comment
		This alternate wording includes the reliability objective and clarifies the three known, or likely, causes of the Impact Event.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
ISO New England, Inc	No	<p>We question the need for this definition since by itself the term is not specific on the types of events that are regarded as having an impact. The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. For that matter, these events that are to be reported can be called anything, or just simply be titled “Event to be Reported” without having to define them. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not used anywhere else in the NERC reliability standards. In fact, for the term Impact Event to be fully defined, all the elements in Attachment A must become a part of it.</p> <p>We therefore suggest the SDT to consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A. If the SDT still wishes to retain a definition despite our reservations noted above, we strongly suggest an improvement. The proposed definition of Impact Event is overly broad because of the use of “potential to impact” and the “Such as” list. Consider that routine switching has the potential to result in a mis-operation. In that regard most routine switching could be interpreted as an impact event. The “Such as” list should be struck and “potential” language should be struck.</p> <p>An alternative definition to consider:</p> <p>An Impact Event is any deliberate action designed to reduce BES reliability; unintended accident that could result in an Adverse Reliability Impact; or an unusual natural event that causes or could cause an Adverse Reliability Impact.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Calpine Corp	No	<p>Adding a definition for Impact Event is unnecessary and does not provide useful clarification of the actual reporting requirement for events that either impact the Bulk Electric System or have the potential to impact the Bulk Electric System. The all-encompassing nature of the proposed definition seems to conflict with the finite listing of events that actually require reporting. Although FERC specifically requested additional clarification of the term sabotage to clarify reporting requirements, the Drafting Team is correct in noting that sabotage implies intent and that the intent of human acts is not always easily determined. The fact that intent is not always determinable within the reporting timeframe can be dealt with more simply by requiring (in attachment</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		1) that human intrusions that have not been identified within the reporting timeframe as theft or vandalism should be reported as potential sabotage pending further clarification. This approach negates the need for an additional definition that may cause confusion regarding which events are reportable and eliminates the potential for under-reporting based on the assumption that the cause might be theft or vandalism.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
BGE	No	Change the definition of “Impact Event”, to add the following phrase to the definition “Any event (listed in Attachment 1) which has either...” Also, the phrase “...or has the potential to impact the reliability...” is too vague and broad. Such broad statement is unhelpful in clarifying entities’ compliance obligation and potentially creates conflicted reporting between entities. A clear statement of how the reliability is affected should be used, i.e., results in contingency emergency situation or IROL.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Alliant Energy	No	<p>The proposed definition is not supported by any of the established bright line criteria that are contained within attachment 1. This Results Based Standard should close any loop-holes that could be read into any section, especially the definition. We recommend the definition be enhanced to read: Impact Event: Any Contingency which has either effected or has the potential to effect the Stability of the BES as outlined per attachment 1. Within this enhanced recommendation, presently defined NERC terms are used (Contingency and Stability), thus supporting what is current used within our industry. There is also a quantifiable aspect of as outlined per attachment 1 that clearly defines Impact Events.</p> <p>If the above definition is not adopted, we believe it should be rephrased to narrow the scope to those events that result from malicious intent or human negligence/error.</p> <p>We are concerned that by using phrases like unintentional or intentional human action in combination with damage or destruction basically means everything except copper theft becomes a reportable impact event (including planned actions we must perform to comply with CIP-007 R7).</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
CenterPoint Energy	No	CenterPoint Energy suggests that the phrase “...or has the potential to impact...” be deleted as it makes the definition vague and broad. Similar issues encountered in trying to define sabotage may resurface, such as



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		<p>varying definitions or interpretations of “potential.” If this standard is to support after-the-fact reporting, the focus should be on actual events, not potential situations or events. Effective and efficient prevention would come from analysis of actual events. Resources and reporting could become overwhelmed upon having to consider “potential.” All references to “potential” should be removed from the standard, guidance, and attachments.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
ExxonMobil Research and Engineering	No	The use of the word potential is ominous.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Occidental Power Marketing	No	<p>The SDT includes in the definition the "potential to impact the reliability of the BES." This seems vague, although Attachment 1 clarifies what actually has to be reported. An LSE may have limited or no knowledge of "potential to impact." The SDT may want to refine the definition, e.g., "to the extent the entities' knowledge could reasonably reveal the impact."</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Lincoln Electric System	No	<p>As currently drafted, the proposed definition of Impact Event appears vague and provides entities minimal clarity in terms of distinguishing events of significance. Recommend the drafting team reference Attachment 1: Impact Events Tables within the definition to direct industry towards more specific criteria.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
American Transmission Company	No	<p>ATC does not agree with the proposed definition and further disagrees whether a definition is needed at all. Proposed Definition: The definition, read outside of the proposed standard, does not provide Registered Entities with a clear meaning of the purpose of the definition. It is ATCs opinion that the SDT is using the term Impact Event as an introduction phrase to Attachment 1. ATC would be more comfortable if the</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		<p>definition was dropped and the team would re-write the requirement to specifically point to Attachment 1. It is our opinion that this type of structure would achieve the goal of the team to get Registered Entities to report on events identified in Attachment 1. The other option is for the team to write into the definition that the events being discussed are limited to those identified in Attachment 1. Also the language currently being used in the definition includes potential and such as. These terms should be struck from the definition.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Ingleside Cogeneration LP	No	<p>The SDT includes in the definition the potential to impact the reliability of the BES. This seems vague, although ultimately the events which meet the threshold of a reportable Impact Event are governed by the tables under Attachment 1. We believe that there should be close, if not perfect, synchronization between the EROs Event Analysis Process and Attachment 1 since they share the same ultimate goal as EOP-004-2 to improve industry awareness and BES reliability.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Duke Energy	No	<p>The phrase “...or has the potential to impact...” makes this an impossibly broad definition, and demonstrating compliance will not be straightforward.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Constellation Power Generation	No	<p>The currently proposed definition is vague and can be easily misinterpreted. Coining a term to define the events that the DSR SDT hopes to capture in EOP-004-2 is a difficult task, one that may not be necessary. Replacing the term Impact Events with events in Attachment 1, would eliminate the need to define such a term.</p> <p>In addition, the phrase or has the potential to impact the reliability is too vague and broad. Such broad statement is unhelpful in clarifying entities compliance obligation and potentially creates conflicted reporting between entities. The language in the reporting requirements should be limited to real impact events, while information sharing on near miss or deficiency incidents should be handled as good industry practices and not subject to onerous compliance obligations.</p> <p>The drafting team should also give careful consideration to the existing reporting and information sharing currently in place in the industry. When an event occurs, partners in the electric sector are notified as part of</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		existing requirements outside of NERC compliance.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Georgia System Operations Corporation	No	It is not clear for the purposes of complying with this standard what it means to impact reliability. Impact in what way. To what degree. Do not define this term. An alternative would be to define it as those events listed in Appendix 1.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Indeck Energy Services	No	It's not a definition. It needs some quantification, such as, a Reportable Disturbance (NERC glossary), a reportable event under DOE OE-417, sabotage or bomb threat. Defining it as having or potentially having an impact is no definition. What is an impact? It needs to be quantified or auditors will have license to define it any way that they want. It shouldn't be a NERC Glossary definition if its only use is in EOP-004. Within EOP-004, it can be defined as anything in Attachment 1.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Progress Energy	No	Progress Energy appreciates the Standard Drafting Teams work on this project. Any potential impact is too vague and impossible to measure. Progress is unsure of how the ERO or Regional Entity measure impact. Potential is very subjective.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Brazos Electric Power Cooperative	No	
Southern Company	Yes	There is concern that the proposed definition for Impact Event does not allow for prudent judgment and preliminary situational assessment by the entity to declare a Potential Impact Event (especially threats) as non-credible. The thresholds for reporting established in Attachment 1 ? Part A provide a somewhat definitive bright line with regard to those events identified in Part A, but for some of the events in Part B there should be allowance for an assessment by the entity to reasonably determine whether the event poses a credible threat

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		to the reliability of the BES. This is attempted in the footnote to the Forced Intrusion event in Attachment 1 ? Part B, but we think this allowance for entity assessment and prudent judgment needs to apply more pervasively, perhaps by including the term credible in the definition of Impact Event or at least by adding the term credible wherever the term physical threat is used.
<p><b>Response:</b> Thank you for your comments. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” The word “credible” could lead to many interpretations as well. Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
American Municipal Power	Yes	The definition of Impact Event is acceptable and an improvement. I feel it could be improved and simplified further. Consider changing Impact Event to a "reportable event."
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Liberty Electric Power LLC	Yes	I am interpreting the phrase "has the potential" to exclude events which had the potential, but did not impact the BES. An example would be a generation trip - if the trip had happened during a system emergency it could have affected the BES, but since it happened under normal conditions there is no reporting responsibility. Some assurance on this interpretation would be appreciated.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Manitoba Hydro	Yes	“Disturbance” has a unique and traditional meaning in the electrical industry, basically meaning “a notable electrical event causing in imbalance of load and generation.” Attempting to include the many scenarios can that can affect reliability blurred the current vision of “Disturbance” and the addition of “unusual occurrences” just added to the confusion. It never seemed appropriate to submit an unusual occurrence on a “Disturbance Report.” “Impact Event” is very encompassing and then detailed specifically in Attachment 1.
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
Independent Electricity System Operator	Yes	We do not have any issue with the wording of the definition, but question the need for this definition since by itself the term is not specific on the types of events that are regarded as having an “impact.” The detailed listing of events that fall into a reportable event category, hence the basis for the Impact Event, is provided in Attachment A. For that matter, these events that are to be reported can be called anything. Defining the term Impact Event does not serve the purpose of replacing the details in Attachment A, and such a term is not

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 2 Comment
		<p>used anywhere else in the NERC reliability standards. In fact, for the term Impact Event to be fully defined, all the elements in Attachment A must become a part of it.</p> <p>We therefore suggest the SDT to consider not defining the term Impact Event, but rather use words to stipulate the need to have a plan, to implement the plan and to report to the appropriate entities those events listed in Attachment A.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
PPL Electric Utilities	Yes	<p>PPL EU agrees with the definition. We would like to point out that our interpretation of the definition excludes maintenance work. Our interpretation also concludes that maintenance work that does not go as planned or goes awry and impacts the reliability of the BES would be an impact event and reported as required per Attachment 1.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.” Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		
SDG&E	Yes	
PPL Supply	Yes	
PSEG Companies	Yes	
SPP Standards Review Group	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
Arkansas Electric Cooperative	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 2 Comment
Corporation		
Sweeny Cogeneration LP	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
Farmington Electric Utility System	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
BC Hydro	Yes	
<p><b>Response:</b> Thank you for your response. Most commenters who responded to this question disagreed with the proposed definition and some suggested that the definition is not needed. In response, the drafting team has deleted the proposed defined term "Impact Events" and will use the generic term "event." Reporting is only required for those events and for the given thresholds listed in Attachment 1.</p>		

**3. Do you agree that the DSR SDT has provided an equally efficient and effective solution to the FERC Order 693 directive to “further define sabotage”? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Most stakeholders agreed that the drafting team addressed the directive to further define sabotage. Commenters generally agreed that the DSR SDT approach in the currently proposed solution effectively addresses FERC Order 693 directive. The approach clarifies the triggering event for an entity to take action and, by deleting all references to "sabotage," in effect removes the very term that had no clear definition.

Organization	Yes or No	Question 3 Comment
Pepco Holdings Inc and Affiliates	No	See #2. With out the explanation contained in background information, over time those that have not been involved with this standard development will struggle with how to interpret the code words of non environmental and intentional human action.
<p><b>Response:</b> The DSR DT thanks you for your comment. This is a Results-based standard and the format includes all of the information, with the exception of the Rationale boxes, through the ballot and filing of the standard. The background section of the proposed standard will be retained with the standard for future reference.</p>		
Midwest ISO Standards Collaborators	No	In general, we agree that the standard drafting team has provided an equally efficient and effective alternative, but we wonder if the SDT has not in essence already defined sabotage in their description for why they cant define sabotage. It seems that sabotage involves willful intent to destroy equipment. In general, intent would have to be determined by an investigation of law enforcement. This could be part of the definition. There might be some obvious acts that could be included without investigation such as detonation of a bomb. Is it possible for the SDT to use the DOE definition for sabotage? We encourage the SDT to provide a definition for sabotage.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that sabotage may be one aspect of a single event. The intent is to report (per Thresholds of Reporting in Attachment 1) events that have an impact on BES reliability. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <ul style="list-style-type: none"> <li>o “The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely</li> </ul>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 3 Comment
<p>upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p><b>Response:</b> The DSR DT thanks you for your comment. Please see the DSR DT response above for question number 2.</p>		
Sweeny Cogeneration LP	No	<p>The threshold for reporting what could be sabotage still leaves the door open for second guessing after-the-fact. For example, if graffiti is sprayed on a BES asset, the entity is to assume that the event is not to be reported. However, intent to harm the BES may be discovered at a later point with ramifications to the entity who did not report it.</p> <p>A solution may be to strengthen footnote 3 to both reporting tables, which makes an allowance to report if you cannot reasonably determine likely motivation of sabotage. If acceptable methods to provide justifiable evidence that reporting was NOT required, then this loophole may be corrected.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Attachment 1 has been updated per comments received.</p>		
USACE	No	The DSR SDT should have defined sabotage since it helps the SDT working on CIP standards further define its action. Sabotage can be defined as the deliberate act of destruction, disruption, or damage of assets to impact the reliability of the BES.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (in Attachment 1) that have an impact on BES reliability. Attachment 1 has been updated per comments received.</p>		
Consumers Energy	No	EOP-004 does not appear to address a reliability need. Reporting after-the-fact information such as that described in Impact Events does not do anything to improve Bulk Electric System reliability. Therefore, we recommend that CIP-001 be updated to address sabotage events, and that NERC otherwise rely on the statutory reporting to the DOE that is represented by OE-417 for any after-the fact information. The remainder of our comments reflects detailed comments on the posted draft, presuming that our objection



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 3 Comment
		represented above will be disregarded.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Providing event reporting information will start the event analysis process done by the current NERC Event Analysis Program. EOP-004-2 is the reporting vehicle to the ERO that will support the analysis phase of any event.</p>		
Ameren	No	<p>The SDT did not further define sabotage as directed by FERC, but instead created a new term that does not address the order. The Term Impact Event has no clarity or quantitative qualities by which an entity can determine what should be reported. The use of the phrase "has the potential to impact reliability" has such a vague scope, an auditor can interpret to mean any "off-normal" condition, which makes this standard impossible to comply with. The SDT should use the DOE definition of sabotage as follows:</p> <p>Sabotage - Defined by Department of Energy (DOE) as:</p> <ul style="list-style-type: none"> <li>An actual or suspected physical or Cyber attack that could impact electric power system adequacy or reliability</li> <li>Vandalism that targets components of any security system on the Bulk Electric System</li> <li>Actual or suspected Cyber or communications attacks that could impact electric power system adequacy or vulnerability, including ancillary systems which support networks (e.g. batteries)</li> <li>Any other event which needs to be reported by the Balancing Authority (Transmission Operations) to the Department of Energy. Sabotage can be the work of a single saboteur, a disgruntled employee or a group of individuals.</li> </ul>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Attachment 1 has been updated per comments received. EOP-004-2 sets the minimum reporting requirements for events.</p>		
Calpine Corp	No	<p>The additional definition for "Impact Event" is unnecessary and does not provide useful clarification regarding actual reporting requirements. Sabotage, whatever the exact definition used, implies intent to damage or disrupt. The committee correctly notes that determination of actual intent is not always readily available. However, adding a general expansive definition encompasses all events that might disrupt the Bulk Electric System does not add clarity to the types of events that require reporting - which are listed in detail in Attachment 1. The issue can be more simply addressed by replacing the item "Human Intrusion" on Attachment 1, as follows:</p> <p>Event: Sabotage (note 3) Entity with Reporting Responsibility: All affected Responsible Entities listed</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 3 Comment
		<p>in the Applicability Section of this Standard.</p> <p>Threshold for Reporting: Forced Intrusions at a BES facility that have not been determined within the reporting period to be theft or vandalism that does not affect the operability of BES equipment.</p> <p>Note 3 For purposes of reporting under Attachment 1, reportable sabotage includes all forced intrusions at BES facilities that have potential to cause, or cause, any of the disturbance events listed in Attachment 1 and have not been determined to be theft or vandalism that did not result in any event listed in Attachment 1.</p> <p>Responsible Entities are not required to report incidents of theft or vandalism that do not result in disturbance events. This approach also eliminates the need to reference copper theft as a particular type of theft that does not require reporting.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.”. Attachment 1 has been updated per comments received. The DSR SDT believes that the reporting of events supports the reliability of the BES. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Footnotes have been updated per comments received.</p>		
CenterPoint Energy	No	CenterPoint Energy would agree if the definition for Impact Event was changed as suggested in the response to Question 2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event.”. Attachment 1 has been updated per comments received. The DSR SDT believes that the reporting of events supports the reliability of the BES.</p>		
Duke Energy	No	Sabotage is still identified on the flowchart. Timeframes for reporting on Attachment 1 should be made consistent with DOE OE-417 reporting. Also on Attachment 1, the Threshold for Reporting on a Forced Intrusion Event should be Affecting BES reliability instead of At a BES facility.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has updated the flowchart. The DOE Form OE-417 is reviewed biennially by the DOE and can be updated or changed without NERC’s involvement. The DSR SDT has taken into consideration the possible use of Form OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2’s reporting requirements. The DSR SDT has removed sabotage from the flowchart and has replaced it with: “Criminal act under federal jurisdiction.”</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 3 Comment
Indeck Energy Services	No	The SDT hasn't defined sabotage. Attachment 1 does not do justice to the concept of sabotage. Sabotage should be defined as any intentional damage to BES facilities the causes a Reportable Disturbance, reportable event under DOE OE-417 or involves a bomb or bomb threat.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the reporting of events supports the reliability of the BES. The intent is to report events (per Thresholds of Reporting in Attachment 1) that have an impact on BES reliability. Sabotage usually is determined after the event is investigated and that Sabotage may be one aspect of a single event. The DOE Form OE-417 is reviewed biennially by the DOE and can be updated or changed without NERC's involvement. The DSR SDT has taken into consideration the possible use of Form OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2's reporting requirements.</p>		
Exelon	Yes	Exelon agrees with the DSR SDT in that the currently proposed solution effectively addresses the intent of FERC Order 693 directive to both clarify the triggering event for an entity to take action and by deleting all references to "sabotage" in effect removes the very term that had no clear definition.
<p><b>Response:</b> Thank you for your comment.</p>		
Georgia Transmission Corporation & Oglethorpe Power Corporation	Yes	We agree with the approach taken by the SDT.
Northeast Power Coordinating Council	Yes	It is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
Midwest Reliability Organization	Yes	Sabotage is usually associated with a malicious attack. Entities have always lacked the clinical expertise to determine if an event was malicious or not. The Impact Event bright line criteria clearly states what the minimum reporting requirements are.
Manitoba Hydro	Yes	"Impact event", The DSR SDT reasoning for this. 'A sabotage event can only be typically determined by law enforcement after the fact' is very creative and concise!
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 3 Comment
Independent Electricity System Operator	Yes	We agree since it is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
<b>Response:</b> The DSR SDT thanks you for your comment.		
ISO New England, Inc	Yes	We agree since it is more important to report suspicious events than to determine if an event is caused by sabotage before it gets reported.
Ingleside Cogeneration LP	Yes	Sabotage cannot be confirmed until after the fact, so we support this initiative.
Bonneville Power Administration	Yes	
Western Electricity Coordinating Council	Yes	
PPL Supply	Yes	
PSEG Companies	Yes	
Dominion	Yes	
SPP Standards Review Group	Yes	
FirstEnergy	Yes	
SERC OC Standards Review Group	Yes	
PJM Interconnection LLC	Yes	
Southern Company	Yes	
SRP	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 3 Comment
We Energies	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
American Municipal Power	Yes	Well done.
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
American Electric Power	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
ExxonMobil Research and Engineering	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 3 Comment
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Constellation Power Generation	Yes	
Georgia System Operations Corporation	Yes	None.
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Brazos Electric Power Cooperative	Yes	
<p><b>Response:</b> The DSR SDT thanks you for your response. Several commenters proposed revisions to the definition, and after deliberation the SDT has deleted the proposed defined term “Impact Events” and will use the generic term “event”. Attachment 1 has been updated per comments received. The DSR SDT believes that the reporting of events supports the reliability of the BES.</p>		

**4. Do you agree with the proposed applicability of EOP-004-2 shown in Section 4 and Attachment 1 of the standard? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. The SDT believes that the industry will gain valuable information from having different perspectives of a single event. Differing viewpoints on the same event will provide for better clarity to all parties on the actual impact to the bulk electric system. The SDT would like to point out that reporting of events is from the time of identification not the time of the event. In response to the comments received, the SDT has made numerous enhancements to Attachment 1. **These revisions include:**

- **Added new column “Submit Attachment 2 or DOE OE-417 Report to:” which references Part 1.3 and provide the time required to submit the report.**
- **Combined Parts A and B into one table and reorganized it so that the events are listed in order of reporting times (either one hour or 24 hours)**
- **Removed references to “Impact Event” and replaced with the specific language for the event type in the “Entity with Reporting Responsibility”. For example, replaced “Impact Event” with “automatic load shedding”.**

**The ERO and the RE were added as applicable entities to reflect CIP-002 applicability to this standard.**

Organization	Yes or No	Question 4 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	<p>We do not believe that GO, TO, TSP, DP, or LSE should be included in the applicability of this standard. It is our opinion that the reporting requirements lie primarily with the applicable operator and should be limited as such. We recommend modifications as discussed in our response to question 6 to clearly define what types of events each Responsible Entity needs to prepare for. Currently, it seems that multiple entities are being required to report the same event for some events where only one entity should have a reporting responsibility. However, NERC should not decide which one entity should report a given event.</p> <p>The entities should have the flexibility to create a process which allows for coordination and communication at a local level and to work out with neighboring entities who might ultimately report events to the applicable</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		organizations.
<p><b>Response:</b> Thank you for your comments. The SDT disagrees that the operators are the only entities with obligations to report; owners and users may have very credible and valuable information relating to events. Such information may be extremely beneficial in developing lessons learned and analyzing events. Your suggestion to allow for local coordination and communication is a practical suggestion and the standard allows for it.</p>		
Northeast Power Coordinating Council	No	<p>Disagree with the following inclusion/exclusion of several entities:</p> <p>a. The applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. NERC should be included in the Applicability Section as it is an applicable entity identified in CIP-002-3.</p> <p>b. If the above approach was not strictly followed, then suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard. The SDT has reviewed the CIP-002-3 standard and has included the ERO and the RE in this standard.</p>		
Pacific Northwest Small Public Power Utility Comment Group	No	We believe that facilities used in the local distribution of electric energy should be excluded from these requirements due the language of 16 U.S.C. ? 824o(a)(1) and 16 U.S.C. ? 824o(i)(1).
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT constructed Attachment 1 based upon the existing requirements in the various reliability standards and established reporting obligations. The information about events and the analysis of those events will be useful to all owners, operators, and users of the bulk power system. The SDT has clarified the reporting requirement such that only those affected by the event are required to submit a report.</p>		
PSEG Companies	No	The PSEG Companies believe the defining language, roles and responsibilities outlined in Attachment 1 are unclear and inconsistent. For example fuel supply emergency reporting footnote 2 “Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability” attempts to clarify the condition for reporting but does not. Whose “emergency actions” are being referred to in the footnote? It is not clear if those actions would be related to the specific station or the overall Bulk Electric



Organization	Yes or No	Question 4 Comment
		<p>System (BES). Can this be interpreted to imply a gas supply issue to one generating station as the result of pipeline maintenance, or local pressure issues would also requiring reporting? The PSEG Companies believe the definition of a fuel supply emergency needs to be more specific and less open to broad interpretation.</p> <p>In addition, the “Time to Submit Report” section of attachment 1 has a significant number of changes from the previous version. Accelerating the twenty four (24) hour to one (1) hour requirement for submitting the reports for several of the events takes resources away from managing the actual event. For the above comments failure to submit a report within 1 hour is a high or severe VSL for a fuel supply emergency. This approach seems inconsistent with ensuring the operation and reliability of the BES. One (1) hour reporting, in most cases, is not adequate time to compile the needed information, prepare report, ensure the accuracy, submit, and simultaneously manage the actual event. We recommend 24 hour reporting for: Damage or destruction to BES, Fuel Supply Emergency, Forced Intrusion, and Risk to BES equipment sections of Attachment 1.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT appreciates the observation on Fuel Supply Emergency and has adjusted Attachment 1 to address it. Reporting under the standard requires that the Registered Entity provide what information it has at the time of the report. The report may not provide the entire record or identification of the event. If the Registered Entity desires to submit an updated report, it may choose to do so; but there is no obligation to do so.</p> <p>The DSR SDT has significantly revised Attachment 1. We have removed the timing column and replaced it with more specific information regarding which form to submit and to whom the report is to be submitted. All events are now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events, Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident. These events are to be reported within 1 hour. Notification of law enforcement (per Requirement R1, Part 1.3.2) is only required for these events. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <p>o “The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
Dominion	No	<p>1) Several of the events require filing a written Impact Event report within one hour. System Separation, for example, is going to require an “all hands on deck” response to the actual event. We note that the paragraph above Attachment 1, Part A indicates that a verbal report would be allowed in certain circumstances, but this</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
		<p>is the same issue with the formal report in that the system operators are concerned with managing the event and not the reporting requirements. Another example would be the Loss of Off-site power to a nuclear generating plant. Suggest reconsideration of one hour reporting requirement for events requiring extensive operator actions to mitigate;</p> <p>2) Several events seem to have the “Threshold for Reporting” contained in footnotes rather than in the table. For example, Damage or destruction of BES equipment - Footnote 1, Fuel supply emergency - Footnote 2, etc.) Suggest moving the actual threshold into the table;</p> <p>3) If one hour reporting remains as indicated in Attachment 1; align/rename events similar to that of the ‘criteria for filing’ events listed in DOE OE-417 for consistency.</p>
<p><b>Response:</b> Thank you for your comment. Reporting under the standard requires that the Registered Entity provide what information it has at the time of the report. The report may not provide the entire record or identification of the event. If the Registered Entity desires to submit an updated report, it may choose to do so; but there is no obligation to do so. Based upon comments received, the SDT has updated the time reporting requirements in Attachment 1. Most events are to be reported within 24 hours. The DSR SDT has retained a one-hour reporting requirement for those events the DSR SDT believes are the types of event that would be typically reported to law enforcement and are of a more urgent nature.</p>		
SPP Standards Review Group	No	<p>While the SDT has recognized the issue of applicability to GO/TO in its background information with the Unofficial Comment Form, we still do not feel comfortable with the GO/TO being listed as a responsible entity when in fact it may be days before they become aware of an event worthy of reporting. If the GOP/TOP makes the report, are the GO/TO still responsible for filing a report? If the GOP/TOP do not file the report, would the GO/TO then be non-compliant? This issue appears to put additional risk on the GO/TO over which they have no control. We need some mechanism to eliminate unnecessary risk while at the same time ensuring that we have coverage for the BES. Perhaps this could be done through delegation agreements between the entities involved or through allowances within the standard itself. For example, could the phrase “appropriate parties in the Interconnection” as currently contained in CIP-001-1, R2 be incorporated into the standard to basically replace GO/TO?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from different entities for the same event may provide a more complete understanding of the event.</p>		
FirstEnergy	No	<p>1. Attachment 1, Part A - Energy Emergency requiring Public appeal for load reduction - In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity." We can't see where the GO/GOP would ever make this determination. Needs to be clarified.</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		<ol style="list-style-type: none"> <li>2. Attachment 1, Part A - Energy Emergency requiring system-wide voltage reduction - In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity." We can't see where the GO/GOP would ever make this determination. Needs to be clarified.</li> <li>3. Attachment 1, Part A - Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 continuous minutes, this should be a TOP RC function only.</li> <li>4. Attachment 1, Part A - Loss of offsite power (LOOP) classification should not apply to nuclear generators. The impact of a LOOP is dependent on the design of the specific nuclear unit and may not necessarily result in a unit trip. If a LOOP did result in a unit trip, the NRC requires notification by the nuclear GO/GOP via the Emergency Notification System (ENS), and time allowed for that notification (1 hour, 4 hours, 8 hour, or none at all) is, as mentioned above, dependent on the design of the plant. We believe it would be beneficial if consideration were given to coordinating reporting requirements for nuclear units with existing required notifications to the NRC to avoid duplication of effort.</li> <li>5. Attachment 1 should align NERC Standard NUC-001 concerning the importance of ensuring nuclear plant safe operation and shutdown. If a transmission entity experiences an event that causes a loss of off-site power as defined in the nuclear generator's Nuclear Plant Interface Requirements, then the responsible transmission entity should report the event within 24 hours after occurrence. Also, for clarity "grid supply" should be replaced with "source" to ensure that notification occurs on a loss of one or multiple sources to a nuclear power plant.</li> <li>6. Attachment 1, Part A - Damage or destruction of BES equipment. See Nuclear comments on question 17 below.</li> <li>7. Attachment 1, Part B - Forced intrusion at a BES facility. See Nuclear comments on question 17 below.</li> <li>8. Attachment 1, Part B - Risk to BES equipment from a non-environmental physical threat. What constitutes a "risk" to the reporting entity is still somewhat ambiguous, and although the DSR SDT has provided some examples, without more specific criteria for this event the affected entity will have difficulty in determining within 1 hour if a report is necessary. Also, see Nuclear comments on question 17 below.</li> </ol>
<p><b>Response:</b> The DSR SDT thanks you for your comment. As a general note, the Applicability section of the standard includes each entity that will be responsible for reporting an event. Attachment 1 has a column "Entity with Reporting Responsibility" to indicate the appropriate entity that is required to report under this standard. For items 1-3 above, the GO or GOP will not be the likely deficient or initiating entity. This will most likely be the BA, TOP or the RC. For item 4, the LOOP event is to be reported by the TO and TOP, not the nuclear plant. For item 5, the TO and TOP are to report within 24 hours. The DSR discussed using "source", however this indicates a single source whereas "supply" encompasses all sources. For items 6, 7 and 8, please see response to Question 17 comments.</p>		
SERC OC Standards Review Group	No	We agree that all of the entities listed should be responsible for reporting an event, provided they own BES assets, but guidance should be given for which entity in Attachment 1 actually files the report to avoid duplication for a single event.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities may provide valuable information on understanding the event.</p>		
PJM Interconnection LLC	Yes	<p>1. We agree that the entities listed should be responsible for ensuring events are reported, provided they own BES assets, but more guidance should be provided on which entity in Attachment 1 should actually file the report to avoid multiple entities reporting a single event. Current Attachment 1 results in significant duplicate reporting.</p> <p>2. Although the applicable entities listed in Section 4 capture all entities that are assigned a reporting responsibility in Attachment 1, some events in Attachment 1 refer to entities applicable under a different standard (e.g CIP-002) as the responsible entities for reporting. This results in IA, TSP, and LSE (none of which, generally own Critical Assets and hence not likely own CCAs) as being responsible for reporting an event. We urge the SDT review the need to include IA, TSP, and LSE in applicable entities. Also, why is NERC an applicable entity in CIP-002-3 but not in this standard?</p>
<p><b>Response:</b> Thank you for your comments. 1. The "Entity with Reporting Responsibility" column of Attachment 1 indicates who is responsible for submitting reports for each event type. It is expected that multiple reports will be received for the same event. Each entity experiencing the event may see something different. This reporting will allow for a more robust analysis process after the fact. 2. The IA, TSP and LSE are included as applicable entities for EOP-004 only because they are applicable under CIP-002. The only events that these entities are required to report are related to cyber assets. The ERO and the RE were added as applicable entities for consistency with CIP-002.</p>		
SRP	No	<p>The threshold for Reporting is broad, vague and repetitive. "Three or more BES Transmission Elements" is vague and could be interpreted as 3 breakers in a large system.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Based upon comments received, the SDT has modified Attachment 1 accordingly.</p>		
We Energies	No	<p>Attachment 1: From the NERC Glossary, an Energy Emergency: A condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements. The first four events listed can only apply to an LSE.</p> <p>Loss of Firm Load for &gt;15 Minutes: By the NERC Glossary definitions of DP and LSE, the LSE would seem to be more appropriate than the DP.</p> <p>With the proposed one-hour reporting requirement, the industry would be undertaking significant regulatory risk with respect to timely reporting. The requirement to report the crime-based events in the field within one</p>

Organization	Yes or No	Question 4 Comment
		<p>hour, as shown in Attachment 1 Part A or Part B will be difficult. We could even discover a theft in progress with the suspect trapped inside the substation fence and the police attempting to make a safe arrest. We need more reporting time, especially when they have not even resulted in an outage.</p> <p>The industry is keenly interested in understanding the benefit of taking on the risk. What analysis, insight, warnings or recommendations would the ES-ISAC provide to the reporting entity, the industry or to law enforcement agencies in the hours after such an incident is reported? Note too that DOE requires reporting of a physical attack within one hour only when it “causes a major interruption or major negative impact on critical infrastructure facilities or to operations.” In lesser cases, the entity gets up to six hours if it “impacts electric power system reliability.” DOE has said that it is not interested in copper theft unless it causes one of these events. If the SDT is working to ensure consistency of reporting requirements, please consider DOE requirements too. Meeting the reporting deadline will mean that available resources in the control center will be devoted to ensuring the report is filed on time instead of making the site safe and arranging for prompt repair. It may even mean that law enforcement won’t be contacted until the forms are filed with the ES-ISAC. The exception contained in footnote #1 of Attachment 1 with respect to copper theft is not an exception at all. The majority of copper theft from substations is, in fact, such grounding connectors which may or may not render the protective relaying inoperative. You could end up receiving reports from all over the USA, Canada and Mexico, mostly on Monday mornings as weekend copper thefts are discovered. Attachment 1 Part A table also contains redundancies. One of the cells reads, “Damage or Destruction of Critical Asset.” One cannot destroy something without damaging it first. Consequently, it is sufficient to simply say, “Damage to a Critical Asset.” Apply to all cells with the same phrase.</p>
<p><b>Response:</b> Thank you for your comments. Only Registered Entities affected by the event have to submit a report. Entities that were not affected by the event are under no obligation to submit a report. Registered Entities are to report what information they have at the submission timeline. The SDT recognizes that a final report may not be possible at the submission time. The reporting requirements are consistent with the current reporting requirements of the various authorities. The one hour reporting times are listed as “one hour within recognition of an event”. This should be sufficient to allow the reporting entity time to submit the report after the event has been recognized. Based upon comments received from many stakeholders, the SDT has modified Attachment 1. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading “Law Enforcement Reporting”: “These are the types of events that should be reported to law enforcement.” The entire paragraph is:</p> <p>o “The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		

Organization	Yes or No	Question 4 Comment
Exelon	No	<p>Remove LSE. As has been determined in previous filings, FERC has ruled that asset owning DP's must be registered as LSE's. The standard as proposed is applicable to DP's. This addresses any concern with a "reliability gap" for reporting events that could have an adverse material impact to the BES. See FERC Docket RC-07-4-003, -6-003, -7-003 paragraphs 24 and 25. "The Commission approves ... revisions to the Registry Criteria to have registered distribution providers also register as the LSE for all load directly connected to their distribution facilities... The registration of the distribution provider as the LSE for all load directly connected to its distribution facilities is for the purpose of compliance with the Reliability Standards. As NERC explains, distribution providers have both the infrastructure and access to information to enable them to comply with the Reliability Standards that apply to LSEs... The Commission finds that, based on these facts, NERC acted reasonably in determining that the distribution provider is the most appropriate entity to register as the LSE for the load directly connected to its distribution facilities."</p> <p>Attachment 1, Part A – Energy Emergency requiring Public appeal for load reduction – In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency." Suggest revising back to specific entities that would be likely responsible for this action (e.g., RC, BA, TOP). Attachment 1, Part A – Energy Emergency requiring system-wide voltage reduction – In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency" related to system-wide voltage reduction. Suggest revising back to specific entities that would be likely responsible for this action. Attachment 1, Part A – Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ≥ 15 continuous minutes, this should be a TOP RC function only. Attachment 1,</p> <p>Part A – Loss of off-site power (grid supply) affecting a nuclear generating station – this event applicability should be removed in its entirety for a Nuclear Plant Generator Operator. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design, if it is a partial loss of off-site power (per the plant specific NPIRs) and may not result in a loss of generation (i.e., unit trip). If a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a Nuclear Plant Generator Operator during a potential transient on the unit. In addition, if the loss of off-site power were to result in a unit trip, if the impact to the BES were ≥2,000 MW, then required notifications would be made in accordance with the threshold for reporting for Attachment 1, Part A – Generation Loss. However, to align with the importance of ensuring nuclear plant safe operation and shutdown as implemented in NERC Standard NUC-001, if a transmission entity experiences an event that causes an unplanned loss of off-site power (source) as defined in the applicable Nuclear Plant Interface Requirements, then the responsible</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		<p>transmission entity should report the event within 24 hours after occurrence. In addition, replace the words "grid supply" to "source" to ensure that notification occurs on an unplanned loss of one or multiple sources to a nuclear power plant. Suggest rewording as follows (including replacing the words "grid supply" to "source" and adding in the word "unplanned" to eliminate unnecessary reporting of planned maintenance activities in the table below): Event Entity with Reporting Responsibility Threshold for Reporting Time to Submit Report Unplanned loss of off-site power to a Nuclear generating plant (source) as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) Each transmission entity responsible for providing services related to NPIRs (e.g., RC, BA, TO, TOP, TO, GO, GOP) that experiences the event causing an unplanned loss of off-site power (source) Unplanned loss of off-site power (source) to a Nuclear Power Plant as defined in the applicable NPIRs. Within 24 hours after occurrence</p>
<p><b>Response:</b> Thank you for your comments. The SDT constructed Attachment 1 based upon the existing requirements in the various reliability standards and established reporting obligations. The LSE is an applicable entity under CIP-002 and CIP-008. The types of events that you list are not applicable to a GO/GOP. The Applicability section of the standard lists each entity that is applicable for some portion of the standard. The information in Attachment 1 specifies which entity must report for which type of event. The loss of off-site power is only applicable to the TO and TOP and not the nuclear plant operator.</p>		
SDG&E	No	<p>SDG&amp;E recommends that "Load Serving Entity," "Transmission Service Provider," and "Interchange Authority" be removed from the proposed applicability shown in Section 4. These entities do not own assets that could have an impact on the Bulk Electric System. Additionally, none of these entities is listed as an "Entity with Reporting Responsibility" in Attachment 1. Finally, "Transmission Service Provider" is covered by either "Transmission Owner" or "Balancing Authority," which are entities also listed in the proposed Applicability section, and "Load Service Entity" and "Interchange Authority" are covered by "Balancing Authority."</p>
<p><b>Response:</b> Thank you for your comments. The SDT constructed Attachment 1 based upon the existing requirements in the various reliability standards and established reporting obligations. The LSE, TSP and IC are applicable entities under CIP-002 and CIP-008.</p>		
United Illuminating Co	No	<p>Will an entity be required to develop an Operating Process for every Impact Event in Attachment 1, or only those events that apply to its Registration. For example, does a DP require evidence of an Operating Process/Procedure for Voltage Deviations on a BES Facility? Some items in Attachment 1 state "Each RC, BA, TOP, DP that experiences the Impact Event" (such as Loss of Firm Load). DP's may have arranged with TOP and RC to communicate the event to TOP who then will file the NERC report and OE-417. The requirements in the Standard would allow for this as long as the Operating Plan documents it. Attachment 1 though can be interpreted that this arrangement would not be allowed and each entity shall file its own and separate report. UI suggests that Attachment 1 be modified to allow for an Entities Operating Plan to rely on another Entity making the final communication to NERC. "Each RC, BA, TOP, DP that experiences the Impact Event, either individually or combined on a single filing"</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it is not necessary to develop a separate Operating Process for each event, unless the company requires it. The SDT feels that any Registered Entity affected by an event needs to submit a report. The SDT believes that the Registered Entity can utilize any resource it has available to complete the reporting obligations and does not believe that Attachment 1 inhibits any options from being used. Based upon comments received, the SDT has decided to remove the definition of Impact Event from the standard and leave as identified through Attachment 1.</p>		
American Municipal Power	No	No, I do not agree. The DP and LSE functions should be removed.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT constructed Attachment based upon the existing requirements in the various reliability standards and established reporting obligations. This information will be useful to all owners, operators, and users of the bulk power system. The DP and LSE are applicable entities under CIP-002 and CIP-008.</p>		
Sweeny Cogeneration LP	No	In Attachment 1, Generator Operators who experience a ± 10% sustained voltage deviation for ≥ 15 continuous must issue a report For externally driven events, the GOP will have little if any knowledge of the cause or remedies taken to address it. We believe the language presently in EOP-004-1 is satisfactory that any “action taken by a Generator Operator” that results in a voltage deviation has to be reported by the GOP.
<p><b>Response:</b> Thank you for your comment. Reporting of events is an obligation of affected Registered Entities. Registered Entities who do not experience an event do not have any reporting obligations.</p>		
Independent Electricity System Operator	No	<p>We disagree with the following inclusion/exclusion of several entities:</p> <p>a. We assess that the applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. If our reasoning is correct, we question why NERC was dropped from the Applicability Section as it is an applicable entity identified in CIP-002-3.</p> <p>b. If the above approach was not strictly followed, then we’d suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, they will be subject to reporting. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard. The SDT has reviewed the CIP-002-3</p>		



Organization	Yes or No	Question 4 Comment
<p>standard and have added the ERO and the RE as applicable entities. If an IA, TSP or LSE does not own Critical Assets nor Critical Cyber Assets, then they will have nothing to report under this standard.</p>		
Ameren	No	<p>The 1 hour reporting requirement, as reference in Attachment 1 is inappropriate. In the event an "Impact Event" were to be discovered the Responsible Entity should focus on public and personnel safety. The reporting requirement should read "Within 1 hour or as soon as conditions are deemed to be safe." This statement would be applicable to "Damage or destruction of Critical Asset" The SDT should not put personnel in the position of choosing to either comply with NERC or address public or co-worker safety. The Time to Submit Report states "within 1 hour after occurrence is identified" This gives an auditor a wide area to question. If personnel report the occurrence 1 hour after identified, but 24 hours after it occurred, we are subject to the personal beliefs of the auditor that the event was not identified 24 hours ago, and reported 24 hours late. This will also be difficult to measure as the operator will have to document in the plant log the time the event was identified, while possibly dealing with Emergency Conditions. In the Note above the Actual Reliability Impact Table, the SDT identifies that under certain conditions, NERC / RRO staff may not be available for continuous 24 hour reporting. The SDT should consider the same stipulations apply to operating personnel and they should not be held to a higher standard than NERC / RRO.</p>
<p><b>Response:</b> Thank you for your comment. The reporting timelines for most events have been changed from 1 hour to 24 hours. The events that retain the one hour requirement are those that are more closely related to sabotage type events. The DSR SDT chose the wording "upon identification of an event" to allow for cases where an event may not be recognized for some time due to an asset being in a remote location for example. It is expected that an auditor will follow what is written in the standard rather than their personal preference. In the note above Attachment 1, it does not state that the ERO may not be available. This note is related to R3.3 of EOP_004-1 and provides for delayed reporting by an entity during storms or other such instances.</p>		
ISO New England, Inc	No	<p>We disagree with the following inclusion/exclusion of several entities:</p> <ol style="list-style-type: none"> <li>a. We acknowledge that the applicable entities listed in Section 4 capture all the entities that are assigned a reporting responsibility in Attachment 1 of the standard. While some events in Attachment 1 have specific entities identified as responsible for reporting, certain events refer to the entities listed in specific standards (e.g. CIP-002) as the responsible entities for reporting. The latter results in IA, TSP and LSE (none of which being specifically identified as having a reporting responsibility) being included in the Applicability Section. If our reasoning is correct, we question why NERC was dropped from the Applicability Section as it is an applicable entity identified in CIP-002-3.</li> <li>b. If the above approach was not strictly followed, then we'd suggest the SDT review the need to include IA, TSP and LSE since they generally do not own any Critical Assets and hence will likely not own any Critical Cyber Assets.</li> <li>c. There is still significant duplicate reporting included. For instance, why do both the RC and TOP to report</li> </ol>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
		voltage deviations? As written, a voltage deviation on the BES would require both to report. The same would hold true for IROLs. Perhaps IROLs should only be reported by the RC to be consistent with the recently FERC approved Interconnection Reliability Operating Limit standards.
<p><b>Response:</b> The DSR SDT thanks you for your comment. (a) The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard. The SDT has reviewed the CIP-002-3 standard and have added the ERO and the RE as applicable entities. (b) The IA, TSP and LSE are included in the Applicability only as it relates to CIP-002 events listed in the table. (c) The DSR SDT has removed the RC from "Voltage Deviations" and the TOP from the IROL to address the comment.</p>		
Calpine Corp	No	Expanding the current applicability of CIP-001-1 and EOP-004-1 to the GO function is unnecessary and will result in numerous duplicate reports, self-certifications, spot checks, and audits reviews, with no benefit to the reliability of the Bulk Electric System. The GOP is the appropriate applicable entity for generation facilities.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities may provide valuable information on understanding the event. The SDT would like to point out that reporting of events is from the time of identification not the time of the event.</p>		
Occidental Power Marketing	No	Load Serving Entities that do not own or operate BES assets (or assets that support the BES) should not be included in the Applicability. The SDT includes LSEs based on CIP-002; however, if the LSE does not have any BES assets (or assets that support the BES), CIP-002 should also not be applicable because the LSE could not have any Critical Assets or Critical Cyber Assets. It is understood that the SDT is trying to comply with FERC Order 693, Sections 460 and 461; however, Section 461 also states: "Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns." A qualifier in the Applicability of EOP-004-2 that would include only LSEs that own, operate or control BES assets (or assets that support the BES) would seem appropriate and acceptable to FERC.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. The LSE is an applicable entity under CIP-002 and CIP-008. If those standards are modified to remove the applicability to these functional registrations, then the appropriate SDT can modify the applicability of this standard.</p>		

Organization	Yes or No	Question 4 Comment
American Transmission Company	No	<p>First, under Part A, the reporting requirement for three or more BES Transmission Elements will create confusion. The NERC definition for an Element is: “Any electrical device with terminals that may be connected to other electrical devices such as a generator, transformer, circuit breaker, bus section, or transmission line. An element may be comprised of one or more components.” This could be interpreted to be three potential transformers on a bus section; therefore, any bus section would require a report. It is suggested that this be reworded to indicate three or more BES transmission lines, bus sections, or transformers.</p> <p>Second, under Part A, the reporting requirement for “Damage or destruction of BES equipment” is too broad and needs to be modified. For example, an output contact on a relay could be damaged unintentionally during routine testing resulting in a reportable event. It is suggested that the list of BES equipment and full intent of this be further defined in the footnote. The intent needs to be clarified, such as “events that have an immediate and significant impact to the stability or reliability of the BES.”</p> <p>Third, under Part A, the reporting requirement for “Damage or destruction of a Critical Cyber Asset” is too broad and needs to be modified. For example, an output contact on a relay could be damaged unintentionally during routine testing resulting in a reportable event.</p>
<p><b>Response:</b> Thank you for your comments. (1) The event “Transmission Loss” has been modified to remove the word Element. This now refers to Facilities. 2. If damage to a contact on a relay poses a reliability threat, then it should be reported. There is a footnote for this the type of event that helps clarify what is expected to be reported. It states:</p> <p>1 BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service. Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).</p> <p>3. This relates only to Critical Cyber Assets identified under CIP-002. If a relay contact is identified under CIP-002 as a Critical Cyber Asset, then its damage or destruction should be reported.</p>		
Ingleside Cogeneration LP	No	<p>Owners and operators of facilities whose total removal from the BES would not meet any reportable threshold under Attachment 1 should not have to create and maintain Operating documents. The same would be true of any LSE, TSP, or IA that does not oversee any Critical Cyber Assets as identified under CIP-002. A statement to that effect could be made in Section 4 of EOP-004-2.</p>
<p><b>Response:</b> Thank you for your comments. Requirements under Standards can only be enforced against Registered Entities, not whether or not they own or operate certain types of assets. The SDT believes it needs to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, then they will be subject to reporting. If those standards are modified to remove the applicability to these</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
functional registrations, then the appropriate SDT can modify the applicability of this standard.		
Duke Energy	No	Section 4 is fine, but on Attachment 1, Entity with Reporting Responsibility should just identify “Initiating entity” for every Event, as was done with the first three Events. That way you avoid errors in leaving an entity off, or including an entity incorrectly (as was done with the GOP on Voltage Deviations).
<b>Response:</b> Thank you for comment. The SDT considered your comment in the development of Attachment 1 decided against including the Initiating Entity designation as it was not appropriate in those cases. Based upon comments received, the SDT has modified Attachment 1 accordingly.		
Constellation Power Generation	No	As stated in comments to earlier versions of EOP-004-2, CPG disagrees with the inclusion of Generator Owners. Since one of the goals in revising this standard is to streamline impact event reporting obligations, Generator Operators are the appropriate entity to manage event reporting as the entity most aware of events should they arise. At times, the information required to complete a report may warrant input from entities connected to generation, but the generator operator remains the best entity to fulfill the reporting obligation.
<b>Response:</b> Thank you for your comment. The SDT has chosen not to distinguish between Registered Entities as far as reporting. Instead the SDT has included Registered Entities which are involved or potentially involved in the types of events. Registered Entities need to recognize that only entities that are affected by the event have the reporting obligation.		
Georgia System Operations Corporation	No	We do not agree that this standard assigns clear responsibility for reporting. It seems that multiple entities are being required to report the same event for some events. Only one entity should report. See comments later regarding Attachment 1. NERC should not decide which ONE entity should report. The entities should be allowed to decide this (and include it in the Impact Event Operating Plan) and to let NERC or the region know who will report (or give them a copy of the plan).
<b>Response:</b> Thank you for your comment. The SDT has chosen not to distinguish between Registered Entities as far as reporting. Instead the SDT has included Registered Entities which are involved or potentially involved in the types of events. Registered Entities need to recognize that only entities that are affected by the event have the reporting obligation.		
Indeck Energy Services	No	Voltage Deviations should not be reportable by GOP. That's why we have TOP's.  Damage or destruction of BES equipment should be reportable only if it causes or could cause a Reportable Disturbance, reportable DOE OE-417 event or sabotage (as defined above). Otherwise, an auditor could require reporting of a relay failure caused by human error even though the relay was in test mode and no BES impact was experienced. This category could be dropped in favor of the next one, damage to Critical Asset.  Fuel Supply Emergency needs a definition. For natural gas, various conditions could be referred to as

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 4 Comment
		<p>emergencies, but unless they actually affect generation, they should not need to be reported. Fuel Supply Emergencies that cause a Reportable Disturbance or reportable DOE OE-417 event should be reported.</p> <p>It is unclear why Forced Intrusion should be reportable under EOP-004. If it causes a problem, it will be reportable as another category and is one more unpreventable event. Forced Intrusion isn't, in many cases, as the exceptions try to define, an impact event at all, but could be a cause, which would be reported as the cause of an impact event.</p> <p>Risk to BES Equipment is not well defined. It should be expanded to Risk to BES Equipment from a non-environmental physical threat within a reasonable distance of the Equipment. A train derailment on the line past the plant would likely be known, whereas one that was 1/2 mile or more away with flammable materials might not be known about unless a public warning was made.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Voltage Deviation reporting no longer applies to the GOP. There is a footnote on Damage or Destruction to BES equipment that addresses your comment. It states:</p> <p><sup>1</sup>BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service. Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).</p> <p>Fuel Supply Emergency has been removed from Attachment 1. Forced Intrusion is an event could be related to sabotage. Identification and reporting of such events may help identify trends. The footnote associated with Risk TO BES Equipment addresses your comment:</p> <p>Examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment.</p>		
Brazos Electric Power Cooperative	No	Inclusion of LSE and DP is questionable.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. The LSE and DP are applicable entities under CIP-002 and CIP-008. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities may provide valuable information on understanding the event. The SDT would like to point out that reporting of events is from the time of identification not the time of the event.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
Manitoba Hydro	Yes	All registered entities are included. This means all field and office personal involved will create a 360 degree view of the BES, and fulfill “Situational awareness of the industry.” In Attachment 1, the “Entity with Reporting Responsibility” entities vary. It might be clearer to leave all impact levels “Entity with Reporting Responsibility” as the RC, BA and TOP, as these are likely the only parties that will report as required. All other entities must report to the RC, BA and TOP.
<p><b>Response:</b> Thank you for your comment. The SDT had previously considered a hierarchal approach to report; however, this concept was rejected by the industry.</p>		
American Electric Power	Yes	AEP agrees, but it further supports the notion that this standard should not apply to the IA, TSP, and LSE functions.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT constructed Attachment based upon the existing requirements in the various reliability standards and established reporting obligations. The LSE, TSP and IC are applicable entities under CIP-002 and CIP-008. The information about an event will be useful to all owners, operators, and users of the bulk power system.</p>		
Southern Company	Yes	<p>This will cause the duplication of reporting for some events.</p> <p>Reference EOP-004 Attachment 1: Impact Events Table; Event - Loss of Firm Load for ≥ 15 minutes (page 15 of standard)</p> <p>This requires the RC, BA, TOP, and DP to report. So if a storm front goes through our system and takes out 400MW of load in Alabama and Georgia the PCC would have to report as the RC, BA, and TOP. Alabama Power and Georgia Power would also have to report as DPs. The way it is now the PCC reports for any of these events.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports from the different entities for the same event may provide a more complete understanding of the event.</p>		
Pepco Holdings Inc and Affiliates	Yes	More guidance is needed for which entity in Attachment 1 actually files the report to avoid duplicate filing.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT believes that it has properly identified registered entities that may potentially have events and the appropriate types of events. A Registered Entity is only required to submit an events report for events listed in Attachment 1 if the registered entity was affected by the event. If an event occurs, only affected Registered Entities listed in Attachment 1 are required to submit a report on the event. Having reports</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 4 Comment
from different entities for the same event may provide a more complete understanding of the event.		
Midwest ISO Standards Collaborators	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
Western Electricity Coordinating Council	Yes	
PPL Supply	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 4 Comment
ExxonMobil Research and Engineering	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Progress Energy	Yes	
<p><b>Response:</b> The DSR SDT thanks you for your comment. Several commenters provided suggestions that led to modifications of Attachment 1.</p>		



5. Stakeholders suggested removing original Requirements 1, 7 and 8 from the standard and addressing the reliability concepts in the NERC Rules of Procedure. Do you agree with the removal of original requirements 1, 7 and 8 (which were assigned to the ERO) and the proposed language for the Rules of Procedure (Paragraph 812)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

**Summary Consideration:** Most commenters agreed with the removal of R1, R7 and R8. The SDT has provided suggested language to NERC for inclusion into the Rules of Procedure.

Organization	Yes or No	Question 5 Comment
Midwest ISO Standards Collaborators	No	We see no issue with imposing requirements on NERC. However, we are not opposed to making these changes in the Rules of Procedure either.
<b>Response:</b> Thank you for your comments. We are pursuing changes to the Rules of Procedure.		
SERC OC Standards Review Group	No	We agree that the ERO should not have requirements applicable to them, but disagree with changing or revising the Rules of Procedure (ROP) giving this reporting responsibility solely to NERC. This responsibility may be performed by NERC but other learning organizations should also be considered for performing this responsibility. In addition, the proposed wording of the revision to the ROP appears to place the responsibility of notifying the appropriate law enforcement with NERC rather than with the local responsible entity.
<b>Response:</b> Thank you for your comments. The responsibility for notifying law enforcement remains with the entity and has been clarified in Attachment 1.		
PJM Interconnection LLC	No	We agree that the standard should not have requirements applicable to the ERO, but disagree with revising the NERC Rules of Procedure (RoP) to include suggested Section 812. The reporting responsibility should not be solely given to NERC. Other learning organizations must also be considered for performing this responsibility. Additionally, the proposed wording of Section 812 appears to imply that NERC will notify the appropriate law enforcement agencies as opposed to the local responsible entity.
<b>Response:</b> Thank you for your comments. The responsibility for notifying law enforcement remains with the entity and has been clarified in Attachment 1.		
SDG&E	No	SDG&E agrees with removing original Requirements 1, 7, 8 from the standard. In addition, SDG&E recommends that the standard reference Section 812 of the Rules of Procedure.

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 5 Comment
<b>Response:</b> Thank you for your comments.		
Duke Energy	No	Proposed language for Section 812 is very confusing. Is the NERC “system” really going to perform all notifications: “applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, and regulatory agencies as necessary?” Is it intended that the NERC “system” will relieve registered entities of the obligation to make these other reports? Is there an implementation plan to achieve that objective? It appears that this current version of EOP-004-2 has the potential for significantly creating redundant reporting. Will the NERC reports be protected from FOIA disclosure? How will FERC Order 630 be followed (CEII disclosure)?
<b>Response:</b> Thank you for your comments. The SDT expects any system would facilitate the reporting to organizations specified in the submitted report. Until such time that the system can be established, the Registered Entity will be obligated to make the notifications as specified in its Operating Plan(s). The SDT has proposed an amendment to the NERC Rules of Procedure to assist in the development of a single reporting process for all three obligations.		
ExxonMobil Research and Engineering	No	Abstain from commenting on this question.
Brazos Electric Power Cooperative	No	
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration agrees that the NERC Rules of Procedure are the appropriate location for ERO assigned activities. However, we would like to get a solid commitment from NERC that the Events Analysis Process and the Reliability Assessment and Performance Analysis Group (RAPA) data analysis requirements for Protection System Misoperations is coordinated through a single process. Their unique data needs are understandable, but should not require the downstream entity to evaluate what is required by each sub-committee - and which reporting template to use.
<b>Response:</b> Thank you for your comments. Your comment addresses a concern that is beyond the scope of this project and cannot be addressed here. The SDT has communicated with the NERC Events Analysis Working Group and DOE in efforts to develop a single reporting process. The SDT will continue to work with those organizations to complete this task.		
Northeast Power Coordinating Council	Yes	Agree with the proposed removal, but have not assessed the proposed language for RoP para. 812 because unable to access it (not on the RoP page).
<b>Response:</b> Thank you for your comments.		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 5 Comment
Bonneville Power Administration	Yes	Ensure distribution of trends.
<b>Response:</b> Thank you for your comments.		
Midwest Reliability Organization	Yes	The ERO is not a user, owner or operator of the BES and the best place to contain their responsibilities, is in the Rules of Procedure.
<b>Response:</b> Thank you for your comments.		
Pepco Holdings Inc and Affiliates	Yes	Agree that NERC should not have requirements applicable to them.
<b>Response:</b> Thank you for your comments.		
American Municipal Power	Yes	A software solution may provide an easy expansion for reporting EOP-004, CIP-001, and additional standards.
<b>Response:</b> Thank you for your comments.		
Manitoba Hydro	Yes	Agree with R1, a central system for receiving and distributing reports. There is limited time and resources for control operators to follow up and ensure ALL required entities have received all information required in a timely manner. Agree with R7 and R8.
<b>Response:</b> Thank you for your comments.		
Sweeny Cogeneration LP	Yes	We agree that these requirements appropriately belong in the NERC Rules of Procedure. However, we are concerned with the multiple reporting requirements being driven by EOP-004-2, CIP-008-3, the ERO Events Analysis Team, the Reliability Assessment and Performance Analysis Group (RAPA). It is imperative that these efforts be consolidated into a single procedure using a single reporting template.
<b>Response:</b> Thank you for your comments. The DSR SDT agrees with the concept of the single reporting template and is working with other agencies to see if the single form would be achievable.		
Western Electricity Coordinating Council	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 5 Comment
PPL Supply	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Dominion	Yes	
SPP Standards Review Group	Yes	
FirstEnergy	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	
Compliance & Responsibility Organization	Yes	
Exelon	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
Liberty Electric Power LLC	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 5 Comment
Arkansas Electric Cooperative Corporation	Yes	
American Electric Power	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
ISO New England, Inc	Yes	
Platte River Power Authority	Yes	
Calpine Corp	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 5 Comment
Constellation Power Generation	Yes	
Georgia System Operations Corporation	Yes	None.
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Indeck Energy Services	Yes	
Progress Energy	Yes	

**6. Do you agree with the proposed revisions to Requirement 2 (now R1) including the use of defined terms Operating Plan, Operating Process and Operating Procedure? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Stakeholders were fairly evenly divided on this question. Overall, there appears to be a misconception on what is and isn't included in the Operating Plan(s). The SDT believes that current Sabotage Reporting substantially meets the requirements outlined in the standard, albeit there may be some needed alterations to accommodate the new standard. The updated subrequirement is a result of a FERC directive in Order No. 693. The DSR SDT removed references to Operating Process and Operating Procedure and revised the Requirement to:

R1. Each Responsible Entity shall have an Operating Plan that includes: [Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]

1.1. A process for identifying events listed in Attachment 1.

1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.

1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate:

- Internal company personnel
- The Responsible Entity's Regional Entity
- Law enforcement
- Governmental or provincial agencies

1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to R3.

1.5. A Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.

Organization	Yes or No	Question 6 Comment
Georgia Transmission Corporation & Oglethorpe Power	No	The terms "Operating Procedure, Operating Plan, and Operating Process," while included in the NERC glossary, are not consistently used throughout the body of NERC standards as they are used in R1 of EOP-

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
Corporation		<p>004-2. As such, we do not see a reliability benefit in using the defined terms over the more commonly used terms of simply "plans, processes, and procedures." In part 1.1 of R1, we think that the requirement should clearly indicate that a particular Responsible Entity's Impact Event Plan should only be required to include those particular Impact Events for which the Responsible Entity has the reporting obligation. Therefore, we suggest the following modification to R1:</p> <p>"1.1 An Operating Process for identifying Impact Events listed in Attachment 1 for those Impact Events where the Responsible Entity is identified as having the reporting responsibility."</p> <p>Additionally, in part 1.3 of R1, we believe the language to be vague and will introduce the need for further clarification either through an interpretation or the CAN process in part because the verb tenses of the sub-sub-requirements do not agree and it appears to require notification to all listed parties for every Impact Event instead of only those that make sense for a particular event.</p> <p>As such, we suggest adding a column to the tables in Attachment 1 that identifies precisely which organizations should be notified in the case of a particular Impact Event and modifying part 1.3.2 to read:</p> <p>"1.3.2 External organizations to notify as specified in Attachment 1."</p> <p>Currently, as written, the standard could be interpreted to require notification to law enforcement for an IROL violation, for instance. Furthermore, we are concerned that as written, the standard may require that the same event must be reported by multiple responsible entities. Our current process uses notification between Responsible Entities (i.e. from a TO to a TOP and then from the TOP to NERC) to allow for a centralized and coordinated notification to law enforcement, NERC, etc. We are concerned that the requirement as written does not appear to allow this flexibility and may require both the TO and TOP to report the same event in order to prove compliance with the Standard.</p>
<p><b>Response:</b> Thank you for your comments. The SDT believes that in order for a term to become consistent with the body of the reliability standards, each SDT will have to incorporate the terms as the opportunity to revise each standard arises. The SDT envisions that each Registered Entity will develop Operating Plan(s) appropriate to meet its obligations as outlined in the standard. Part 1.3 has been revised to indicate that each report must be sent to the ERO and the Registered Entity's Reliability Coordinator and the remaining entities as appropriate. Law Enforcement would certainly not be interested in an IROL violation, but they would be interested in Forced Intrusion.</p>		
Bonneville Power Administration	No	Not sure that a 90-day update is needed to be sent to CEF.
<p><b>Response:</b> Thank you for your comments. That is not required in the standard. The SDT believes that it is unnecessary to forward any update to any organization outside of the Registered Entity. Updates should be used to inform internal personnel of any Operating Plan changes.</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Pacific Northwest Small Public Power Utility Comment Group	No	1.4 makes no sense. The operating plan update and the change to its content occur simultaneously. Perhaps the SDT meant to say “Provision(s) for updating the Impact Event Operating Plan within 90 days of identification of a needed change to its content. This would be consistent with the “lessons learned” language of the prior version.
<p><b>Response:</b> Thank you for your comment. The DSR SDT added additional detail to Part 1.4 to address the broader term “content.”</p>		
PSEG Companies	No	The PSEG Companies believe that sections 1.3 and 1.3.2 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. This is appropriate for some events if there has been destruction to BES equipment, for example, but not in certain operational events. It should not be necessary to notify law enforcement that a non sabotage event like an IROL violation, generation loss or voltage deviation has occurred.
<p><b>Response:</b> Thank you for your comments. The DSR SDT feels that the Registered Entity will establish Operating Plan(s) appropriate for its needs including the specification of how and when law enforcement agencies are contacted. Part 1.3 has been revised to indicate that each report must be sent to the ERO and the Registered Entity's Reliability Coordinator and the remaining entities as appropriate. Law Enforcement would certainly not be interested in an IROL violation, but they would be interested in Forced Intrusion. Attachment 1 language has been updated to say “The parties identified...” which should be included in the entity's Operating Plan(s).</p>		
Dominion	No	<p>The requirement for Responsible Entities to establish an Impact Event Operating Plan, Operating Process, and Operating Procedure seems overly cumbersome and prescriptive. The use of these NERC defined terms create additional compliance burden for little, if any, improvement to reliability. Suggest simplification by requiring the Responsible Entities to have a procedure to report Impact Events, to the appropriate parties, pursuant to EOP-004.</p> <p>In addition, we request clarification of R1.4. It seems circular to us in that it requires the plan to be updated within 90 days of when it changes. Is the intent that any necessary changes identified in the annual review required by R4 be incorporated in a revision to the plan within 90 days of the review? If so, R1.4 belongs under R4. If not, we do not understand the requirement.</p> <p>What starts the 90 day count down?</p>
<p><b>Response:</b> Thank you for your comment. The language in Requirement R1, Part 1.4 was inserted in response to a directive in FERC Order 693. The SDT feels that the directive requires Registered Entities to update their Operating Plan(s) within 90 days of the time the entity identified the need for the change, such as a new telephone number, personnel staff name/title, or addition/deletion of person or organization. The DSR SDT has made changes to better clarify “content.”</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
Pepco Holdings Inc and Affiliates	No	An Operating Plan, Operating Process or Operating Procedure implies something different than an after the fact reporting activity.
<p><b>Response:</b> Thank you for your comment. An Operating Plan is more than an after the fact reporting activity. The Operating Plan(s) incorporates the tasks or steps involved in the identification of events, establishing which internal personnel are to be involved in the communications and or reporting, and establishing the list of outside organizations to be contacted when an event happens.</p>		
SPP Standards Review Group	No	<p>We would suggest rewording Part 1.3.2 to read “External organizations to notify may include but are not limited to the Responsible Entity’s Reliability Coordinator, NERC, Responsible Entity’s Regional Entity, Law Enforcement and Governmental or Provincial Agencies.”</p> <p>We would also suggest the following for Part 1.4: “Provision(s) for updating the Impact Event Operating Plan within 90 days of any known changes to its content.”</p> <p>Would also suggest adding “as requested” at the end of M1.</p>
<p><b>Response:</b> Thank you for your comments. (1) Requirement R1, Part 1.3 has been updated to “as appropriate” to address the parties to communicate event to. (2) The SDT agrees with your suggestions and has made similar word changes. 3) Agreed.</p>		
Midwest ISO Standards Collaborators	No	<p>We do not believe that the use of the Operating Process, Operating Procedure, and Operating Plan for a reporting requirement is consistent with their definitions and certainly not with the intent of the definitions. For instance, an Operating Process is intended to meet an operating goal. What operating goal does this requirement meet?</p> <p>An Operating Procedure includes tasks that must be completed by “specific operating positions.” This reporting requirement could be met by back office personnel. We also believe that parts 1.3 and 1.3.2 under Requirement 1 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. While some should require notification to law enforcement such as when firm load is shed, others certainly would not. For instance, law enforcement does not need to know that an IROL violation, generation loss or voltage deviation occurred.</p>
<p><b>Response:</b> Thank you for your comments. The Glossary Definition of Operating Plan is:</p> <p>A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.</p> <p>The definition uses “goal” rather than “operating goal”. The goal of the Operating Plan is to ensure that entities know how to identify the events listed in</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
<p>Attachment 1 and report them to the appropriate parties. The SDT disagrees with your views on Operating Process, Operating Procedure, and Operating Plan. The SDT appropriately describes the task at hand. The SDT feels that the Operating Plan can identify when law enforcement agencies need to be notified without specification from the SDT. The Background section of the standard contains a heading for “Law Enforcement” and provides clarification regarding the types of events that should be reported to law enforcement.</p>		
FirstEnergy	No	<ol style="list-style-type: none"> <li>1. We believe that the use of stringent definitions for an entity’s process requires too much of the “how” instead of the “what.” As long as the entity has a process, procedure (or whatever they want to call it) that includes the necessary information detailed in sub-parts 1.1 through 1.4 then that should suffice.</li> <li>2. In sub-part 1.3, we suggest adding the phrase “as applicable” to clarify that not every event will require a notification to, for example, law enforcement.</li> <li>3. In sub-part 1.4, we suggest adding clarification that the 90-day framework is only required for substantive changes and that all other minor editorial changes can be updated within a year.</li> </ol>
<p><b>Response:</b> Thank you for your comments. (1) The SDT agrees with your suggestion that the entity can best determine what is included in its Operating Plan. The SDT does not envision instructing an entity on what or how of the Operating Plan(s). (2) The SDT feels that the Operating Plan can identify when law enforcement agencies need to be notified without specification from the SDT. (3) The update requirement comes from a FERC directive in Order No. 693. The SDT has validated the intent of the directive and has included that intent in the requirement. The SDT feels that the directive requires Registered Entities to update their Operating Plan(s) within 90 days of the time the entity identified the need for the change, such as a new telephone number, personnel staff name/title, or addition/deletion of person or organization. The DSR SDT has made changes to better clarify “content.”</p>		
SERC OC Standards Review Group	No	<p>This is a reporting requirement and should not be confused with Operating Plans that have specific operating actions and goals. Each entity should prepare its own event reporting guideline that address impact events, identification, information gathering, and communication without specifying a specific format such as Operating Plans, Operating Process and Operating Procedures.</p>
<p><b>Response:</b> Thank you for your comment. The SDT agrees with your viewpoint and believes that your statement is consistent with the intent of the requirement.</p>		
PJM Interconnection LLC	No	<ol style="list-style-type: none"> <li>1. This is an “after-the-fact” reporting requirement and should not be confused with Operating Plans that have specific operating actions and goals. Each entity should prepare its own impact event operating guideline that addresses impact events, identification of impact events, information gathering, and communication without specifying a specific format such as Operating Plans, Operating Process, and Operating Procedures. In fact, all three documents mentioned can all be a single document.</li> <li>2. 1.3.2 requires notification of law enforcement agencies for all events listed in Attachment 1. This is essentially not true. For example, firm load is shed requires notification to law enforcement but an IROL</li> </ol>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
		violation, generation loss, or voltage deviation do not.
<p><b>Response:</b> Thank you for your comment. (1) The SDT disagrees with your viewpoint that this requirement specifies after-the-fact reporting. The reporting requirement is later in the standard. The SDT agrees with your viewpoint on the operating guideline you provide and believes that your statement is consistent with the intent of the requirement. (2) The SDT believes that the Registered Entity’s Operating Plan(s) can establish when and how law enforcement agencies are notified.</p>		
We Energies	No	<p>R1.2: By its NERC Glossary definition, an Operating Procedure is too prescriptive for data collection. An Operating Procedure requires specific steps to be taken by specific people in a specific order. We would have to predict every event that could happen to have every step in proper order to collect the data. It will be impossible to comply with this requirement.</p> <p>R1.3: Change “Impact Event” to “Impact Event listed in Attachment 1.”</p>
<p><b>Response:</b> Thank you for your comment. The SDT has changed R1 to simply “Operating Plan. The term “Impact Event” has been removed from the standard and R1 and its Parts refer to Attachment 1 as appropriate.</p>		
Compliance & Responsibility Organization	No	<p>See comments to 2. Also, although NextEra agrees that a documented procedure is appropriate, NextEra does not favor the current approach of pre-defined layers of processes and documentation that seem to overly complicate, and, possibly contradict, already established internal methods by which a company implements policies, procedures and processes. Thus, NextEra’s options suggest using a more generic approach that allows entities more flexibility to establish documents and processes, and demonstrate compliance. Such a generic approach was used in NextEra’s proposed options set forth in response to number 2.</p>
<p><b>Response:</b> Thank you for your comments. The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2.</p>		
Exelon	No	<p>R.1 Does an entity need to develop a standalone Operating Plan if there is an existing process to address identification, assessing and reporting certain events?</p> <p>Suggest rewording to state "Each Responsible Entity shall have an Impact Event Operating Plan or equivalent implementing process that includes:"</p> <p>Disagree these new terms are required. Commonly accepted descriptions of programs, processes and procedures exist in registrar entities that would suffice. For example, R1 could use “Impact Event evaluation</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
		and reporting process” as a generic term to describe what is required. This would allow an entity to utilize any existing protocols or management guidelines and naming conventions in effect in their organization.
<p><b>Response:</b> Thank you for your comments. The SDT The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2. The Registered Entity will need to examine its current processes to ensure that all aspects of the new requirements are addressed. Thank you for the suggested re-wording. The SDT revised “Impact Event Operating Plan” to just “Operating Plan”, thus allowing the entity to implement the requirements as needed.</p>		
Tenaska	No	<p>We already have adequate procedures in place to address sabotage and other significant events, pursuant to the existing CIP-001-1 and EOP-004-1 Standards. The requirement to develop a new Impact Event Operating Plan would increase the administrative burden on Registered Entities to comply with the proposed Standard, without providing a foreseeable improvement in system reliability.</p> <p>The “laundry list” of required Impact Event Operating Plan components is too specific and would make it more difficult to prove compliance with EOP-004-2 during an audit.</p> <p>A revised version of the proposed R5 is the only Requirement that is necessary to achieve the stated purpose of Project 2009-01.</p>
<p><b>Response:</b> Thank you for your comments. The SDT The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2 and these should mostly meet the intent of EOP-004. The Registered Entity will need to examine its current processes to ensure that all aspects of the new requirements are addressed. The Parts of R1 are not prescriptive and only provide the minimum information that is required to be in the Operating Plan. The SDT has removed R2 and revised R5 (now R2) to eliminate any duplication.</p>		
United Illuminating Co	No	Does R1.1 require an Operating Process for each Impact Event in attachment 1 or an Operating Process that in general applies to all Impact Events?
<p><b>Response:</b> Thank you for question. The SDT feels that the Registered Entity can have an Operating Plan that in general applies to all events.</p>		
American Municipal Power	No	No, remove R1. R1 is not an acceptable requirement nor should this be an operation. Focusing on a plan and procedure is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> Thank you for your comment. The SDT agrees that the Registered Entity can decide on the how to implement the reporting; however, this requirement mandates that the Registered Entity document its process.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Arkansas Electric Cooperative Corporation	No	<p>We appreciate the effort the team has taken in improving the requirements since the last posting. For 1.3, it appears to suggest the communication must always include communicating to internal personnel and ALL external organizations. We suggest removing the reference to 1.3.1 and 1.3.2 and move 1.3.1 and 1.3.2 to 1.4 and 1.5 respectively. For 1.3.2, modify to state "Internal company personnel notification(s) deemed necessary by the Responsible Entity." For 1.4, we feel the term "content" is too broad as used here. For example, if the FBI changes the contact info for the JTTF, the Responsible Entity may not find out until an incident or annual exercise. Or if the contact person for the state agency changes position without notifying us, it would require us to then change the plan within 90 days. We suggest an annual review of the plan is sufficient for the objective of this requirement.</p>
<p><b>Response:</b> Thank you for your comments. The SDT has added language "as appropriate" to allow the entity to make its own determination who to contact. The term "content" has been removed and replaced with more detail. The requirement for updates requires changes within 90-days. The SDT believes that the timeline for updating can only be based upon the notification to the Registered Entity. The SDT believes that 90-days from the date the Registered Entity is notified or made aware of the change is a suitable time period to update the document.</p>		
Manitoba Hydro	No	<p>Plan, Process and Procedure are all too interchangeable with each other and have no value being used in "one paragraph" as they do not differentiate from one or other.</p> <p>The terms "identify", "gather" and "communicate" better describe "Process, plan or procedure" so simplify to: 1.4. Identification of Impact Events as listed in Attachment 1.1.5. Gathering information for inclusion into Attachment 2 regarding observed Impact Events listed in Attachment 1.1.6. Communicate recognized Impact Events to the following:</p>
<p><b>Response:</b> Thank you for your comments. The SDT has revised R1 to only include an Operating Plan. Part 1.2 has been revised to "A process for gathering information..."</p>		
American Electric Power	No	<p>Even best developed plans, processes and procedures do not always lend themselves to address the issues at hand. There needs to be flexibility to allow entities to first address the reliability concern and second report correspondingly. Currently, this requirement is overly prescriptive and places unnecessary emphasis on the means to an end and not the outcome. The outcome for this requirement is to report Impact Events.</p>
<p><b>Response:</b> Thank you for your comments. While the SDT appreciates your views, it disagrees with your assessment. The outcome of this requirement is not to report events; the outcome is to ensure that the Registered Entity has Operating Plan(s) for the identification of events, establishing which internal personnel are involved, identification of outside agencies to be notified, and having a provision for updating the plan(s). Reporting of events is a requirement later in the standard.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Consumers Energy	No	Requirement R1, "Have a plan..." with all of the listed criteria, seems to present a serious compliance risk to applicable entities without a direct reliability benefit, as long as entities still identify and report relevant events. Ad-hoc procedures, as discussed within the R1 "Rationale" have been acknowledged within the rationale to be working effectively, and should remain sufficient without having a documented and by inference, signed, approved, dated document with revision history (as is being demanded today by compliance auditors wherever a "documented plan" is specified within the requirements).
<p><b>Response:</b> Thank you for your comments. While the SDT appreciates your views, it disagrees with your assessment. The SDT believes that most entities already have plans to mostly satisfy the requirements of EOP-004. These would be the procedures that are required under existing CIP-001, R1 and R2. The measure calls for a current, dated, in force Operating Plan to be provided.</p>		
ISO New England, Inc	No	<p>We do not believe that the use of the Operating Process, Operating Procedure, and Operating Plan for a reporting requirement is consistent with their definitions nor with the intent of the definitions. For instance, an Operating Process is intended to meet an operating goal. What operating goal does this requirement meet? An Operating Procedure includes tasks that must be completed by "specific operating positions." This reporting requirement could be met by back office personnel. We suggest that R1.3.2 delete the list of entities to notify. The terms used to identify who to notify are not defined terms and can lead to subjective interpretations. As written, the requirement does not aid the Applicable entity or the Compliance enforcers in clearly including or excluding who to notify.</p> <p>We also believe that parts 1.3 and 1.3.2 under Requirement 1 will require notification of law enforcement agencies for all Impact Events defined in Attachment 1. While some should require notification to law enforcement such as when there has been destruction to BES equipment, others certainly would not. For instance, law enforcement does not need to know that an IROL violation, generation loss or voltage deviation occurred.</p> <p>We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing the event. This will be particularly difficult when support personnel are not present such as during nights, holidays and weekends.</p> <p>We further suggest that as explicit statement that "reliable operations must ALWAYS take precedence to reporting times" be included in the standard.</p>
<p><b>Response:</b> Thank you for your comments. While the SDT appreciates your views, it disagrees with your assessment.</p> <p>(P1) The outcome of this requirement is not to report events; the outcome is to ensure that the Registered Entity has Operating Plan(s) for the identification of events, establishing which internal personnel are involved, identification of outside agencies to be notified, and having a provision for updating the plan(s). The</p>		

Organization	Yes or No	Question 6 Comment
<p>SDT feels that current Sabotage Reporting guides already provides much of the information needed in the new R1.</p> <p>(P2) We have revised Requirement R1, Part 1.3 to “A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:” This should address your concern regarding law enforcement notification.</p> <p>(P3) We have revised most reporting times to 24 hours. Events of a “sabotage” type nature remain at one hour.</p> <p>(P4) While the DSR SDT sees the point you are trying to make, we do not believe that reporting the events in Attachment 1, under the times listed, is burdensome. At the least, this can be accomplished by back office personnel who are not involved in restoration or other reliability efforts.</p>		
<p>Calpine Corp</p>	<p>No</p>	<p>In the “Rationale for R1”, the draft states:</p> <p>“Every industry participant that owns or operates elements or devices on the grid has formal or informal process, procedure, or steps it takes to gather information regarding what happened and why it happened when Impact Events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized.”</p> <p>Absent substantial evidence that the proposed requirement addresses an actual systemic problem with the “formal or informal process, procedure, or steps it takes” for internal and external evaluation and notification of items listed in Attachment 1, there is no obvious need for this additional paperwork burden, which in most cases will result in a written procedure that documents another existing written procedure or procedures, that will be maintained for the sole purpose of demonstrating compliance with the requirement. Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Adding a requirement to implement an “Impact Event Operating Plan”, “Operating Procedure”, and “Operating Process” is unnecessary.</p> <p>However, if the requirement is maintained, the related Measure M1 should state in plain language exactly what elements are required for compliance. Statements such as “The Impact Event Operating Plan may include, but not be limited to, the following?” begs the question regarding what other elements are required to demonstrate compliance. As written, M1 requires that entities provide an “Impact Event Operating Plan”, but does specify the required elements of the plan.</p> <p>In the absence of much more detailed instruction on exactly what elements must be included in the various documents, the proposed requirement will create confusion with both compliance and enforcement of the requirement. An example of each of the various required documents would be helpful. Any difficulty in developing such an example would be instructive of the probable compliance issues that would ensue from the necessarily varying approaches taken by disparate entities attempting to meet the requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Requirement R1 comes from existing CIP-001, R1. The SDT believes it has addressed these concerns by removing the terms “Operating Procedure” and “Operating Process” and has generically referred to them in the elements of the Operating Plan outlined in</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

---

Organization	Yes or No	Question 6 Comment
Parts 1.1-1.5 of the requirement.		
BGE	No	This seems overly restrictive in its use. Requirement is now telling entities how to resolve situations, not giving them a requirement to resolve the situation.
<b>Response:</b> Thank you for your comments. The requirement is written so that an entity has an Operating Plan that contains certain items. The SDT does not specify in the standard how the entity meets these obligations nor does it specify the form nor format of these items.		

Organization	Yes or No	Question 6 Comment
ExxonMobil Research and Engineering	No	<p>The requirement to notify State Law Enforcement deviates from existing government security requirements that Petrochemical Facilities (Cogenerators) are required to follow. Per the Maritime Transportation Security Act of 2002 (MTSA) and the Chemical Facility Anti-Terrorism Standard (CFATS), Petrochemical Facilities are required to report the security incidents identified in EOP-004 Revision 2 to the National Response Center which is staffed by the United States Coast Guard. The National Response Center coordinates incident reporting to both the Department of Homeland Security and Federal Bureau of Investigation. Requiring Petrochemical Facilities to report security incidences to State Law Enforcement agencies duplicates their reporting of incidences to the appropriate law enforcement agencies. EOP-004 Revision 2 should be modified to synergize with existing federal security regulations so that those facilities that are required to comply with the MTSA and CFATS are, by default, compliant with EOP-004 Revision 2 when they comply with these existing federal security regulations.</p> <p>It is unclear, from the documentation provided in this revision of EOP-004, which entities a Responsible Entity is required to notify when certain types of Impact Events occur. Previously, CIP-001 included a similarly vague instruction that required notifications to the 'appropriate parties in the interconnection' and the FBI/RCMP. The Standard Drafting Team should identify which NERC Functional Entities should be notified when each of the Impact Events identified in Attachment 1 occurs.</p> <p>Current revisions of CIP-001 Revision 1 or EOP-004 Revision 1 do not include corresponding requirements to update procedures within a certain time frame. It's difficult to foresee a situation where an Entity would initiate a change to its response plan without being required to update the formal response plan documentation per their management of change process. Additionally, failure to update the procedure would result in the entity deviating from the procedure any time an impact event occurred, which would automatically force a violation of EOP-004-2 R2 for failure to properly implement their Operating Process. Furthermore, the only changes occurring between review cycles should be revisions to the contact information for third parties. It is beyond an entity's power to require third parties to notify the entity when the third party changes their contact information, and, as such, this requirement burdens registered facilities with responsibility for compliance for items that are beyond their realm of control.</p>
<p><b>Response:</b> Thank you for your comments. (P1) The SDT believes that the requirement does not mandate contact to State Law Enforcement agencies; but merely to include them if appropriate. While we have tried to coordinate with the US DOE, Federal security regulations are outside the scope of this project. (P2) We have revised Requirement R1, Part 1.3 to “A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:” Each type of event should be assessed by the entity to determine whether or not law enforcement needs to be notified,</p> <p>(P3)The subrequirement for updating comes from a FERC directive in Order No. 693. If the Registered Entity’s Operating Plan(s) have a provision for updating, then the entity only needs to verify that the updating does not exceed 90 days from the date of being aware.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 6 Comment
Farmington Electric Utility System	No	consider rewording 1.4; the wording implies a change to content already occurred, so it would be updated concurrently ? consider, updating the plan within 90 days of discovery of content requiring a change?
<p><b>Response:</b> Thank you for your comment. The SDT agrees with your suggestion and has revised Requirement R1, Part 1.4 to: Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to R3.</p>		
Constellation Power Generation	No	<p>Per NERC’s glossary of terms, an Operating Plan can include Operating Process documents and Operating Procedures. An Operating Process identifies general tasks while an Operating Procedure identifies specific tasks.</p> <p>CPG is unclear as to why R1.1 and R1.3 require the use of an Operating Process while R1.2 requires an Operating Procedure.</p> <p>CPG believes that R1.2 should be changed to require the use of an Operating Process instead of Operating Procedure. R1.2 is merely requiring an entity to fill out the necessary forms should an event occur, so requiring a clear and concise step by step procedure for filling out a form only adds a compliance burden to an entity instead of improving the reliability of the BES.</p> <p>CPG does agree with the DSR SDT that an entity should have a process in place mandating that the proper paperwork be completed in a timely manner should an event occur.</p>
<p><b>Response:</b> Thank you for your comments. The SDT has modified Requirement R1, Part 1.1 and Part 1.3 to a “process” as part of the elements of the referenced “Operating Plan” in R1. The SDT has also changed “Operating Procedure” to a “process” in R1.2. This sub-requirement provides for establishing the list of internal personnel to be notified in the case of an event, not the reporting of the event.</p>		
Georgia System Operations Corporation	No	<p>-R1.3.2: “Law Enforcement”, “Governmental Agencies”, and “Provincial Agencies” are not proper nouns/names and are not defined in the NERC Glossary. They should not be capitalized.</p> <p>-R1.4: Keeping documents current and in force should be a matter of an entit</p>
<p><b>Response:</b> Thank you for your comments. The SDT agrees with your suggestions on capitalization and has made the corrections. The update provision comes from a FERC directive in Order No. 693.</p>		
Indeck Energy Services	No	The terms are not important and many plans or procedures already exist and restructuring them to match the

Organization	Yes or No	Question 6 Comment
		<p>terms is wasteful. R1 is too prescriptive.</p> <p>R1 should state that a written document should show how the entity will comply with EOP-004.</p> <p>R1.2 is superfluous and should be deleted. The data must be gathered and the process will vary with the event. Trying to define the multitude of possibilities for the collection process is not productive and leaves open the possibility of missing something for an auditor to nit pick.</p> <p>R1.3 should just be a written communications plan/process/procedure for external notifications.</p> <p>R1.4 is redundant because it can't be changed within 90 days until the content has already been changed. R1.4 should be deleted. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.</p>
<p><b>Response:</b> The SDT disagrees with your viewpoints associated with R1 because the requirement only specifies the elements required, now how to implement them. The SDT believes that many Registered Entities will be able to use their current Sabotage Reporting processes, with some slight modification to address the new sub-requirements. Requirement R1, Part 1.2: The requirement is written so that it is not prescriptive and allows the entity to identify the steps it will take to gather information for filing the report. The DSR SDT does not envision this as being a tome that contains specific data gathering protocol for each event type. Requirement R1, Part 1.3: Has been revised to: "1.3. A process for communicating recognized impact events listed in EOP-004 - Attachment 1 that includes to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and , but is not limited to the following as appropriate :” For Requirement R1, Part 1.4, the update provision comes from a FERC directive in Order No. 693. In addition, the SDT believes that the update is required within 90 days from the date of being notified of the change or update. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Midwest Reliability Organization	Yes	This is a NERC defined term and will assist entities in maintaining compliance with this (proposed) Standard.
<p><b>Response:</b> Thank you for your comment.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 6 Comment
Western Electricity Coordinating Council	Yes	<p>Are "Law Enforcement" considered a "Governmental Agency" (they are listed separately and both required) If not, is there any qualifiers on whether Law Enforcement or Governmental Agency refers to municipal, county, state or federal or any combination"</p> <p>Since the term "Provincial" is associated with "Governmental" it tends to indicate State level. As it is written now an auditor would require documentation of "some" Law Enforcement (other than company security) and an additional communication to at least "some" Agency which could be considered Governmental. Municipal or higher.</p> <p>Contact with City police or Sheriff and either city or county government rep would satisfy.</p> <p>Additional clarity would help from a compliance enforcement perspective.</p>
<p><b>Response:</b> Thank you for your comments. The SDT expects that Registered Entities will identify the proper outside organizations needed for their organization. The SDT feels that law enforcement agencies include federal, state, provincial, or local law agencies and these are not the same as governmental or regulatory agencies. Please refer to the Background section of the standard for further clarification on law enforcement notifications.</p>		
Alliant Energy	Yes	<p>This is a NERC defined term and will assist entities in maintaining compliance with this (proposed) Standard. We believe the reference to Attachment 2 in R1.2 should be revised to the DOE Form and utilize only one reporting form, if at all possible.</p>
<p><b>Response:</b> Thank you for your comments. The DSR SDT continues to work with the DOE to develop a single reporting form that is acceptable to both.</p>		
Occidental Power Marketing	Yes	<p>However, only LSEs with BES assets (or assets that support the BES) should be included in the Applicability section of the standard.</p>
<p><b>Response:</b> Thank you for your comment. LSE applicability is related to their applicability under CIP-002 and CIP-008.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	<p>However, there needs to be some clarity on which government agencies (if not the FBI) are responsible for reporting these type of events.</p>
<p><b>Response:</b> Thank you for your comments. Each Registered Entity should be aware of any reporting obligations it may have to various government agencies (federal, state/provincial, local). To the extent they exist, the notification needs to be included in the entity's Operating Plan(s).</p>		
Northeast Power Coordinating	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 6 Comment
Council		
PPL Supply	Yes	
Southern Company	Yes	
SRP	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
Liberty Electric Power LLC	Yes	
APX Power Markets	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
Platte River Power Authority	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 6 Comment
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	
Progress Energy	Yes	

**7. Do you agree with the proposed revisions to Requirement 3 (now R2)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The slight majority of commenters agreed with the language of Requirement R2. A significant minority opinion exists where commenters suggest revisiting R2 and R5 to eliminate potential redundancy and confusion. Similar comments were received pertaining to Requirement 5 (question 10 below). The DSR SDT has revised Attachment 1 to indicate that entities must submit Attachment 2 or the DOE OE-417 form. This information was contained in Requirement R5. The intent of the two requirements is to have entities make appropriate notifications and report impact events contained in Attachment 1. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements while eliminating potential confusion and redundancy. The revised requirements are shown below:

~~R2. Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B). [Violation Risk: Factor Medium] [Time Horizon: Real-time Operations and Same-day Operations]~~

Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].

Organization	Yes or No	Question 7 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	<p>We are concerned with having a separate requirement to implement the Plan.</p> <p>Is this requirement necessary on its own? Should R1 instead require a Responsible Entity to "document and implement" an Impact Event Operating Plan? More specifically, if an Entity does not have an Impact Event, are they in violation of this requirement?</p> <p>If merging this requirement with R1 is not acceptable we suggest moving the language from the measure to the requirement as such: "To the extent that a Responsible Entity has an Impact Event on its Facilities, Each Responsible Entity shall implement?"</p> <p>Additionally, R1 uses the phrase "recognized Impact Event" where as R2 simply uses the term "Impact Event." The phrase "recognized Impact Event" should be used consistently in R2 as well.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted requirement 2 and revised requirements 1 and 5 to address your concern. The DSR SDT believes that the requirement should remain separate to eliminate the possibility of double jeopardy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		



Organization	Yes or No	Question 7 Comment
Bonneville Power Administration	No	Minimize the number of requirements. Not sure what the new R2 intends that is different than having a valid plan (signed?). Why can't R1 have develop and implement? R5 is the reporting. Implement should be with R1 or R5 depending on the interpretation.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT has deleted requirement 2 and revised requirements 1 and 5 to address your concern. The DSR SDT believes that the requirement should remain separate to eliminate the possibility of double jeopardy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
PSEG Companies	No	Fuel supply emergency, as discussed in response to question 4 above, is not a defined condition. This event should be removed.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Fuel Supply Emergency from Attachment 1. This item was removed in coordination with the NERC Events Analysis Working Group and the proposed Events Analysis Program.</p>		
SERC OC Standards Review Group	No	We agree with the concept, but disagree with the use of the term “Operating Plan” as a defined term in line with our comments in question 6 above.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see response to comments in Question 6 The DSR SDT has revised R1 to eliminate the use of Operating Process and Operating Procedure and have used more generic terms.</p>		
PJM Interconnection LLC	No	We agree with the concept but disagree with the use of the term “Operating Plan” as a defined term in line with our comments in Question 6 above.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
<p><a href="#">Response: The DSR SDT thanks you for your comment. Please see response to comments in Question 6</a></p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p><a href="#">Response: The DSR SDT thanks you for your comment. Please see response to question 2.</a></p>		
Exelon	No	<p>Agree that each Responsible Entity shall implement the [Impact] Events listed in Attachment 1 (Parts A and B); however, disagree with certain events, reporting responsibilities, threshold for reporting and time to submit reports as currently outlined in Attachment 1 (Parts A and B).</p> <p>Also suggest that R.2 be reworded to state for applicable [Impact] Events listed in Attachment 1 (Parts A and B). This requirement should only be applied to those events applicable to the registered entity. R2 is redundant to R1. No entity could claim to have met R1 if their plan / process was not operational and approved in the manner consistent with any other approved program, process, guideline etc. within their company.</p>
<p><a href="#">Response: The DSR SDT thanks you for your comment.</a></p> <p>The DSR SDT has significantly revised Attachment 1. We have removed the timing column and replaced it with more specific information regarding which form to submit and to whom to submit the report. All events are now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events, Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident. These events are to be reported within 1 hour. Notification of law enforcement per Part 1.3.2 is also required for these events only.</p> <p>The DSR SDT has also eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. The DSR SDT believes that the requirement should remain separate to eliminate the possibility of double jeopardy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
Tenaska	No	The proposed Impact Event Operating Plan should not be required.
<p><a href="#">Response: The DSR SDT thanks you for your comment.</a></p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
		<p>The DSR SDT has revised R1 to only include development of an Operating Plan that includes the Parts of R1. This Operating Plan is required so that the entity's personnel will know what to do in the event of an event, how to report the event and to whom the report should be sent.</p>
American Municipal Power	No	<p>No, remove R2. R2 is not an acceptable requirement nor should this be an operation. Focusing on a plan is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>
American Electric Power	No	<p>Requirement 5 and Requirement 2 are redundant. We recommend Requirement 2 be replaced with the language in Requirement 5. "Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417."</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. The old Requirement R5 has been revised as the new Requirement R2, which reads: Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>
ISO New England, Inc	No	<p>Fuel Supply Emergency is not a defined condition. We suggest that the SDT poll the ballot body regarding the reporting of Fuel Supply Emergencies. Fuel Supply is an economic consideration and the concept of Fuel Supply Emergency is subjective. A resource that uses coal or oil may vary its supplies based on economic considerations (the price of the fuel). For a conservative BA a fuel-on-demand supply line can be viewed as a fuel supply emergency whereas the resource owner sees the matter as good business. Moreover, the release of such reports to the public can have unintended consequences. Fuel disruptions caused by contract negotiations when reported to the public can result in non-union transportation employees being physically</p>

Organization	Yes or No	Question 7 Comment
		<p>harmd by fuel supply organizers thus resulting in the loss of non-contract fuel. Further, this information may aggravate the situation by causing the cost of fuel to be inflated by suppliers when demand is great.</p> <p>If this event is not deleted, then we would suggest that the definition be constrained to “declared” fuel supply emergencies. Suggest the deletion of category: Risk to BES equipment. Because of the broad definition of BES, the risk to BES equipment is overly broad and can be applied to any risk to any “part of” any BES asset. The footnote helps identify what the SDT was intending, however, the words themselves can result in overly broad findings by compliance enforcement people.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Fuel Supply Emergency from Attachment 1. This item was removed in coordination with the NERC Events Analysis Working Group and the proposed Events Analysis Program.</p>		
Calpine Corp	No	<p>Requirement R2 is unnecessary for the same reasons listed above in answer to question 6 regarding Requirement R1. A new Reliability Standard requirement is not needed to verify that internal notifications are made within Registered Entities or to ensure that Registered Entities notify local law enforcement of suspicious activity, sabotage, theft, or vandalism. Such notifications are made by any company, and this requirement does not clearly enhance the reliability of the Bulk Electric System. Requirement R5 provides sanction in the event that events listed in Attachment 1 are not made appropriately. However, if the requirement is maintained, the related Measure M2 should state in plain language exactly what elements are required for compliance. In the absence of much more detailed instruction on exactly what elements must be included in the various documents, the proposed requirement will create confusion with both compliance and enforcement of the requirement. A detailed example of example documentation would be helpful. Any difficulty in developing such an example would be instructive of the probable compliance issues that would ensure from the necessarily varying approaches that would be taken by disparate entities attempting to meet the requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
CenterPoint Energy	No	<p>CenterPoint Energy recommends deleting the current R2 as it is an inherent part of the current R5. For an entity to “report Impact Events in accordance with the Impact Event Operating Plan pursuant to R1” (see R5), the entity must “implement its Impact Operating Plan documented in Requirement 1?” (see R2). Including</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
		both requirements is unnecessary and duplicative. Likewise, M2 should be deleted.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
ExxonMobil Research and Engineering	No	<p>The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notifications windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of of the situation and determine the extent of the problem. The existing standard's requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
<p>The DSR SDT has significantly revised Attachment 1. We have removed the timing column and replaced it with more specific information regarding which form to submit and to whom to submit the report. All events are now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events in Part A and Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident in Part B. These events are to be reported within 1 hour. Notification of law enforcement per Part 1.3.2 is also required for</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
these events only.		
American Transmission Company	No	ATC does not agree with the proposed language in Requirement 3. ATC is concerned that, in order to demonstrate compliance, an entity will have to show that each step in the plan was followed which will likely leave entities facing the choice of choosing between different compliance violations. If the plan is not followed, but the report is made within the time given, then an entity is in violations of their plan. If the plan is followed, but the report does not get filed within the time allotted, then they face a possible violation of the time to report. ATC believes that the team should enforce the position that the report being filed in the time allotted is key, not that they necessarily follow and document that their plan was followed. Depending on the situation, the internal reporting will vary; however, based on the purpose of the Standard, the key is to get a report to NERC.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 for clarity and to eliminate potential redundancy. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		
Georgia System Operations Corporation	No	-We suggest moving the language from the measure to the requirement as such:"To the extent that a Responsible Entity has an Impact Event on its Facilities, each Responsible Entity shall implement?"Additionally, R1 uses the phrase "recognized Impact Event"
<p><b>Response:</b> The DSR SDT thanks you for your comment. Requirement 2 has been deleted along with its associated Measure M2. R1 no longer references "recognized" events.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	There are generally several events during the year. If the process is well documented, a drill or exercise is excessive. It should be sufficient to say "provide training."
<p><b>Response:</b> The DSR SDT thanks you for your comment. This appears to be related to R3 in question 8. If an event occurs during the year, additional testing is not required.</p>		
Indeck Energy Services	No	R2 is direct and to the point. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Midwest Reliability Organization	Yes	This clearly states that an entity’s Operating Plan is to be used for reporting of Impact Events.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
Dominion	Yes	Dominion agrees subject to the comments provided in Question #6. In addition, Requirement R2 appears duplicative of Requirement R5. Suggest R2 be clarified relative to the intent.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see responses to comments in Question 6. R2 was deleted and R5 was revised. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment]. The DSR SDT has revised R1 to eliminate the use of Operating Process and Operating Procedure and have used more generic terms.</p>		
Manitoba Hydro	Yes	Removing “assess the initial probable cause” from the statement removes the ambiguity in the same way as replacing sabotage with impact level. Let the staff trained in this field determine probable cause after the fact.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
Occidental Power Marketing	Yes	However, only LSEs with BES assets (or assets that directly support the BES) should be included in the Applicability section of the standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Attachment 1 specifies which types of events are required to be reported by each entity.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 7 Comment
Constellation Power Generation	Yes	Although CPG agrees with the wording of Requirement 2, CPG has several comments and suggested changes regarding the Attachments, to which this requirement points. Please see those comments below.
<b>Response:</b> The DSR SDT thanks you for your comment. Please see responses below.		
Northeast Power Coordinating Council	Yes	
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
Pepco Holdings Inc and Affiliates	Yes	
SPP Standards Review Group	Yes	
Midwest ISO Standards Collaborators	Yes	
FirstEnergy	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 7 Comment
APX Power Markets	Yes	
United Illuminating Co	Yes	
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 7 Comment
Brazos Electric Power Cooperative	Yes	
Progress Energy	Yes	
<p><b>Response:</b> The DSR SDT thanks you for your comment. Based on stakeholder comments, Requirement R2 was deleted and R5 was revised. Old R5, New R2. Each Responsible Entity shall report impact events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p>		

**8. Do you agree with the proposed revisions to Requirement 4 (now R3)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** There were several issues that commenters raised regarding removing the requirement. Below is a summary:

- 1) Review annual component CAN0010 states: Regardless of the registered entity’s documented definition of annual, it will not supersede any requirement stated in the standard. The DSR SDT is defining “annual” within this Standard (and only for this Standard).
- 2) Remove R3-requirement – Several stakeholders believed the testing to be onerous. The language of the requirement was revised to indicate that only the communications portion of the Operating Plan is required to be tested. Each Responsible Entity shall conduct a test of the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between tests.
- 3) Unclear if actual events would qualify for a test in the requirement – The language in the measure was revised to add “Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement. “
- 4) VRF is too high on R3 – With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.

Organization	Yes or No	Question 8 Comment
--------------	-----------	--------------------

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between tests" is necessary. If instead the team believes that, in order to support the reliability of the BES, tests should be performed at least every 15 months, then the requirement should be to perform a test at least every 15 calendar months and remove the annual component.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. Per the CAN, "Regardless of the registered entity's documented definition of annual, it will not supersede any requirement stated in the standard." The team believes the requirement is specifying what the team believes to be appropriate.</p>		
Northeast Power Coordinating Council	No	The annual testing requirement is too frequent for a reporting, and not an operational process. The testing interval should be extended to five years.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. We feel that five years is too long of an interval between tests as contact information contained in the plan may change more often. A one year test is more likely to catch problems with the Operating Plan. If an entity has an event, then they do not need to test the plan during the annual cycle.</p>		
Bonneville Power Administration	No	Too burdensome to go through EACH and ALL individual Impacts and report each one on a drill basis with outside entities. One or two scenarios may be OK.
<p><b>Response:</b> The DSR SDT thanks you for your comment. It is not intended to perform a test for each type of event listed in Attachment 1. The entity is free to choose any single event to test its operating plan. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The test under R3 Operating Plan is to test the communication aspect of your Operating Plan.</p>		
Dominion	No	: The need to conduct a test of its Operating Process has not been established and is overly restrictive given that the purpose of the standard is to report Impact Events.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
<p>respond appropriately in the case of an actual event. The SDT thinks it is critical to test the Operating Plan to verify that employees know the appropriate actions to take and that there are no issues with the reporting procedures. Not testing the Operating Plan could result in employees being unprepared to communicate and report for an actual event.</p>		
SPP Standards Review Group	No	<p>The SDT included a formal review process in the discussion of R4 in the Background Information in the Unofficial Comment Form as one of three options for demonstrating compliance with the testing requirements of R4, yet M3 only contains two of those options ? a mock Impact Event exercise and a real-time implementation of its Operating Process. The third option, a formal review process, is missing from M3 and needs to be added. We would suggest the following for M3: ?In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 or conducted a formal review of its Operating Process. The time period between tests, actual Impact Events or formal reviews shall be no more than 15 calendar months. Evidence may include, but is not limited to, operator logs, voice recordings or documentation.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. The team feels that a formal review will not be able to identify any of these errors unless the communications process is tested.</p>		
Midwest ISO Standards Collaborators	No	<p>We appreciate the drafting team recognizes that actual implementation of the plan for a real event should qualify as a ?test?. However, we are concerned that review of this requirement in isolation of the background material and information provided by the drafting team may cause a compliance auditor to believe that a test cannot be met by actual implementation. Furthermore, we do not believe testing a reporting procedure is necessary. Periodic reminders to personnel responsible for implementing the procedure make sense but testing it does not add to reliability. If they don?t report an event, it will become obvious with all the tools (SAFNR project) the regulators have to observe system operations.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. We have added the following to the measure: "Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement."</p>		
FirstEnergy	No	<p>We believe that a separate requirement for testing the reporting process is unnecessary. The FERC directive that required periodic testing was directed at sabotage events per CIP-001. Since the proposed standard</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
		<p>moves the responsibility for classifying an event as sabotage from the entity to the applicable law enforcement authority, the need for a periodic drill is no longer necessary. We believe that Requirement R4 should suffice in ensuring that the individuals involved in the process are aware of their responsibilities.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified.</p>		
SERC OC Standards Review Group	No	<p>Annual testing of an "after-the-fact" reporting procedure does not add to the reliability of the BES!</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p>		
PJM Interconnection LLC	No	<p>1. This is an "after-the-fact" reporting requirement (administrative in nature). Annual testing of such a requirement does not add to the reliability of the BES.</p> <p>2. R3 attempts to define "Annual" for the Registered Entity to test its Operating Process. We believe R3 should follow the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) ? CAN-0010 ? Definition of Annual as opposed to creating a new definition of Annual ? or ? refer to an entity?s defined use of the term annual.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. Per the CAN, "Regardless of the registered entity's documented definition of annual, it will not supersede any</p>		

Organization	Yes or No	Question 8 Comment
<p>requirement stated in the standard.” The team believes the requirement is specifying what the team believes to be appropriate.</p>		
<p>We Energies</p>	<p>No</p>	<p>A test of the Operating Process for communication would be placing telephone calls. This requirement would have virtually every entity in North America calling NERC, Regional Entities, FERC/Provincial Agency, Public Service Commission, FBI/RCMP, local Police, etc. annually. Every entity will probably be asking for a confirmation letter from each telephone call for proof of compliance. This is an unnecessary requirement. Delete it.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p>		
<p>Compliance &amp; Responsibility Organization</p>	<p>No</p>	<p>See comments set forth in number 2.</p> <p>Also, while NextEra understands the need to have a testing requirement for sabotage (Order 693 at P 446), it does not find it necessary to have a testing requirement for the other events. At this time in the process, additional requirements for the sake of having a requirement are likely to detract from reliability. Thus, NextEra requests that the testing requirement be limited to sabotage related events.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see responses to Question 2 above. Each entity may choose an event type for which to perform the communications process test. It need not be performed for each and every event type listed in Attachment 1. The test must include all aspects of the communications process, including NERC and the RE. The measure for R3 was revised to make it explicit that evidence for compliance for R3 includes an actual event.</p> <p>M3. The Responsible Entity shall provide evidence that it conducted a test of the communication process as documented in its Operating Plan impact events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual impact event may be used as evidence to meet this requirement. The time period between an actual impact event or test shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a test. (R3)</p>		
<p>Exelon</p>	<p>No</p>	<p>- Each entity should be able to determine if they need a drill for a particular event. Is this document implying that the annual drill covering all applicable [Impact] Events?</p>

Organization	Yes or No	Question 8 Comment
		<p>- A provision should be added to be able to take credit for an existing drill/exercise that could incorporate the required communications to meet the intent of R.3 to alleviate the burden on conducting a standalone annual drill. The DSR SDT needs to provide more guidance on the objectives and format of the drill expected (e.g., table top, simulator, mock drill).</p> <p>- A provision should be added to R.3 to allow for an actual event to be used as credit for the annual requirement. It would seem that the intent is as such based on the wording in M.3; however, it needs to be explicit in the Requirement.</p> <p>- Must a test include communicating to NERC or the Region?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each entity may choose an event type for which to perform the communications process test. It need not be performed for each and every event type listed in Attachment 1. The test must include all aspects of the communications process, including NERC and the RE. The measure for R3 was revised to make it explicit that evidence for compliance for R3 includes an actual event.</p> <p>M3. The Responsible Entity shall provide evidence that it conducted a test of the communication process as documented in its Operating Plan impact events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual impact event may be used as evidence to meet this requirement. The time period between an actual impact event or test shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a test. (R3)</p>		
City of Tallahassee (TAL)	No	<p>Comments: The verbiage “at least annually, with no more than 15 months between such tests” is an attempt to define annually. If you want every 15 months say “at least every 15 months.” Otherwise just say annual and let the entities decide what that is, as is being done with other “annual” requirements.</p> <p>Additionally, while the Measure (M3) implies that an actual event would suffice it is not stated in the requirement, and the entire plan should be tested, not just a component. Proposed: Each Responsible Entity shall conduct a test of its Impact Event Operating Plan at least annually. A test of the Impact Event Operating Plan can range from a paper drill, to the response to an actual event.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The language now reads: “annually (once per calendar year), with no more than 15 calendar months between tests”. This comports with the intent and with the recent CAN from NERC on the use of “Annual”. The intent of the requirement is to verify that an entity’s personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test. R3 reads:</p> <p>“Each Responsible Entity shall conduct a test of the communication process as documented in its Operating Plan, created pursuant to Requirement 1, Part 1.3, impact events at least annually, (once per calendar year), with no more than 15 calendar months between tests.”</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 8 Comment
Tenaska	No	The proposed Impact Event Operating Plan should not be required, therefore any tests of the Operating Process should not be required.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Stakeholder consensus indicates that the majority of stakeholders agree with the Operating Plan requirement.</p>		
American Municipal Power	No	No, remove R3. R3 is not an acceptable requirement nor should this be an operation. Focusing on a test is overly prescriptive and costly. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test. This should not be a costly nor burdensome requirement.</p>		
Liberty Electric Power LLC	No	It is not the proper role of the standards to dictate how an entity conducts training. Large utilities with backup control rooms and enough personnel can conduct routine drills without disturbing operations, but this is not always the case for small entities. Further, classroom training where emergency responses are discussed can be a better tool at times for assuring compliance with operating procedures. I would suggest R3 read "Each entity shall assure that personnel are aware of the requirements of EOP-004 and capable of responding as required."
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT agrees and has removed the training Requirement, R4.</p>		
Sweeny Cogeneration LP	No	We do not see a reliability benefit in the planning and execution of tests or drills to ensure that regulatory reporting is performed in a timely fashion. It is sufficient that penalties can be assessed against entities that do not properly respond in accordance with EOP-004-2, leaving it to us to determine how to avoid them.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
American Electric Power	No	It is unclear if actual events would qualify for a test in the requirement; however, the associated measure and rationale appear to support this. We suggest the requirement be restated to allow for actual events to count for this requirement.

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 8 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
New Harquahala Generating Co.	No	<p>M3. In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event and followed its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or documentation. (R3). The measure for R3 needs to make it clear that "exercise/drill/actual employment" can be a classroom exercise, utilizing scenarios for discussion. It should not be necessary to fully test the plan by making actual phone calls, notifications etc.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process including making actual phone calls, etc. The measure was revised to clarify that an actual event can be used in lieu of a test. The purpose of the requirement is to ensure that the communications process works.</p>		
ISO New England, Inc	No	<p>We appreciate and agree with the drafting team recognizes that actual implementation of the plan for a real event should qualify as a "test." However, we are concerned that review of this requirement in isolation and without the benefit of the background material and information provided by the drafting team may cause a compliance auditor to believe that a test cannot be met by actual implementation. Furthermore, we do not believe testing a reporting procedure is necessary. Periodic reminders to personnel responsible for implementing the procedure make sense but testing it does not add to reliability. If they don't report an event, it will become obvious to compliance auditors. Recommend using language similar to CIP-009. "Each Responsible Entity shall conduct a an exercise of its operating process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 at least annually, with no more than 15 calendar months between exercises." An exercise can range from a paper drill, to a full operational exercise, to reporting of actual incident Also, we question the need to conduct a test annually. Since this is only a reporting Standard and, as such, has no direct impact on reliability, we suggest modifying the testing requirement to once every three years.</p> <p><b>CIP-009-3</b></p> <p><b>R.2 Exercises</b> —The recovery plan(s) shall be exercised at least annually. An exercise of the recovery plan(s) can range from a paper drill, to a full operational exercise, to recovery from an actual incident.</p> <p><b>M2.</b> The Responsible Entity shall make available its records documenting required exercises as specified in</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 8 Comment
		<b>Requirement R2.</b>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the requirement is to verify that an entity's personnel can communicate with other entities when a real event occurs. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
Calpine Corp	No	<p>Absent substantial evidence that the proposed requirement addresses an actual systemic problem with actual submittal of reports of electrical disturbances, Requirement R4 should be removed. Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Entities are capable of implementing procedures appropriate to ensure compliance with the actual reporting requirements without the addition of this "test."</p> <p>Alternately, if this requirement for annual tests is retained, it should be supplemented with a detailed example of an acceptable test and acceptable documentation of the test to avoid future compliance and enforcement issues. Stating "evidence may include, but is not limited to..." provides broad and unnecessary opportunity for future compliance and enforcement issues. Any difficulty the committee might encounter in developing such a detailed example would be instructive of the probable compliance and issues that would ensure from implementation of the requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
BGE	No	<p>Requirement 3 (formerly R4) should be removed altogether because it is covered by the new R4. The topic of Disturbance Reporting is covered several times each year during operator training classes and the operators are tested on the material. Actual issued Disturbance Reports throughout the year are also covered during training class.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. R4 was a training requirement which has been revised and incorporated into Requirement R1, Part 1.5. This now calls for an annual review of the Operating Plan rather than training. The intent of the review is to ensure that the plan is up to date.</p>		
Georgia System Operations Corporation	No	<p>-With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between tests" is necessary. Although we understand the additional qualification</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The CAN language defers to the standard drafting team for any qualifications on “annual.” The DSR SDT prefers the existing language.</p>		
Indeck Energy Services	No	<p>For smaller entities, for which few of the Attachment 1 events apply (eg a 75 MW wind farm), a drill is overkill. Reviewing the procedure during training should be sufficient. The solution is to require a drill for any entity for which any of the Attachment 1 events would cause a Reportable Disturbance or reportable DOE OE-417 event and training review for any other entities. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. Any drill or exercise that meets the intent of the requirement is acceptable.</p> <p><b>VRF:</b> With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
ExxonMobil Research and Engineering	No	<p>The annual (15 month) time window for conducting annual performance tests appears to be reasonable. However, the required scope of the test is vague. The Standard Drafting Team should modify the testing requirement to include boundary criteria such as whether notifications to third parties and law enforcement are required or if the test is limited to internal notifications and response processes. Furthermore, the current measure associated with this requirement, EOP-004 Revision 2 Measure 3, implies, that if an Impact Event occurs, the registered entity can count the activation of its Impact Event Operating Plan as a test and extend the test window 15 months from the date of activation. The Standard Drafting Team should revise the requirement to clarify that the test window resets when a site initiates its Impact Event Operating Plan in response to a real Impact Event as requirement criteria should not be included in a measure.</p>

Organization	Yes or No	Question 8 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. It is expected that such a test will include all aspects of the communications process. The measure was revised to clarify that an actual event can be used in lieu of a test.</p>		
Occidental Power Marketing	No	We understand that this requirement is meant to comply with FERC Order 693, Section 466; however, there needs to be more specificity concerning what sort of "test" would be accepted for auditing purposes. Also, only LSEs with BES assets should be included in the Applicability section of the standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p> <p>The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
Lincoln Electric System	No	As currently drafted, requirement R3 states one must "conduct a test" whereas the associated Measure requests evidence that one "conducted a mock Impact Event." The Rationale box lends to further confusion by referencing a "drill or exercise" as a process to verify one's Operating Process. To avoid potential confusion between R3 and M3, as well as to maintain consistency with the Rationale box, recommend the drafting team replace the word "test" with "drill or exercise" within R3 and the associated Measure.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. It is not a common practice to include explanatory text in a requirement. The Results-based standards format allows the Rationale boxes to serve this role. The Rationale box includes language that indicates that an actual implementation of the plan counts as a test.</p>		
Farmington Electric Utility System	No	The measure for R3 indicates an actual Impact Event would count as a test, consider aligning the requirement with the measure to clarify an Impact Event could be considered a test.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. It is not a common practice to include explanatory text in a requirement. The Results-based standards format allows the Rationale boxes to serve this role. The Rationale box includes language that indicates that an actual implementation of the plan counts as a test.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
Ingleside Cogeneration LP	No	Since the reporting of event data to regulatory agencies does not support a front-line operations capability to mitigate or restore a BES impairment, regular simulations are not needed. Those notification items which test coordination between operating entities can be addressed in emergency operations exercises.
<p><b>Response:</b> The DSR SDT thanks you for your comment. We concur with your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event.</p>		
Constellation Power Generation	No	As CPG stated in comments to earlier versions of EOP-004-2, this requirement adds a substantial compliance burden with little to no reliability improvement to the BES. Numerous entities in the NERC footprint have created fleet wide compliance programs for their facilities, instead of overseeing multiple stand alone compliance programs. This was done not just for the ease of administration, but it also greatly improves the reliability of the BES by ensuring consistency across multiple facilities. By requiring each responsible entity to test the Operating Process, those under a fleet wide compliance program will end up testing the same Operating Process numerous times. This would be inefficient, ineffective and unnecessarily costly. If the testing requirement remains, then the Responsible Entity should be able to take credit for testing of the Operating Process regardless of which entity in the fleet tested it. Alternatively, the drafting team should consider removing Requirement 3 (formerly R4) because in practice it is covered by the new R4. As discussed below R4 needs refinement, but the topic of Disturbance Reporting is covered during annual training.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. If the intent of this requirement is fulfilled by another exercise or drill conducted by the responsible entity, then that will meet the requirement.</p>		
Duke Energy	Yes	We understand that the objective of this requirement is to test the Operating Process for communicating Impact Events; and that such test could be an actual exercise, a formal review, or a real-time implementation. But given that R1.4 requires updating the Operating Plan within 90 days of any changes, we believe the VRF for R3 should be LOW instead of MEDIUM.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
<p>responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Progress Energy	Yes	<p>Do all individuals who are assigned roles and responsibilities in the Impact Event Operating Plan have to be involved with the test each time? Since there are multiple different types of Impact Events, it seems likely that only a subset of those Impact Events would be tested during an annual test, and therefore only a subset of individuals with responsibilities in the Impact Event Operating Plan would participate. For example, one test may exercise the Operating Process for properly reporting damage to a power plant that is a Critical Asset, and personnel from the Distribution Provider would not be involved in that test. Would such a scenario meet the requirement for the annual test? If so, it seems that some aspects of the Plan may never actually be required to be tested. This is ok, since R4 requires an annual review with personnel with responsibilities in the Impact Event Operating Plan. It must be made clear what is required in the annual test.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
Manitoba Hydro	Yes	<p>This requirement appears to be written so as to leave how each entity tests this procedure is up to them and not how. The testing of this procedure could vary vastly from entity to entity, meaning there is no set protocol on this procedure. As long as this requirement remains open, it is fair.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment.</p>		
United Illuminating Co	Yes	<p>: FERC did state in Order 693 that the reporting procedure requires testing. UI is concerned that the scope of the requirement is unspecified. Does the exercise require only one type of Impact Event to be exercised per period, or is an entity required to simulate each Impact Event and notification</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. If your communications process differs by event type, then all communications should be tested.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 8 Comment
Southern Company	Yes	This will cause all of the entities listed in R1.3.2 to receive test communications from all of the applicable entities annually.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The standard now has only three requirements. The requirement to test the communications process is important so that any issues or errors in the Operating Plan can be identified. This will allow for reporting to the appropriate entities in the case of an actual event.</p>		
SRP	Yes	
SDG&E	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Platte River Power Authority	Yes	
Alliant Energy	Yes	
CenterPoint Energy	Yes	
USACE	Yes	
Independent Electricity System Operator	Yes	
PPL Electric Utilities	Yes	
American Transmission Company	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 8 Comment
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Brazos Electric Power Cooperative	Yes	
Midwest Reliability Organization	Yes	
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	

**9. Do you agree with the proposed revisions to Requirement 5 (now R4)? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** A significant number of commenters indicated that there was confusion surrounding the use of the term “review” in Requirements R3 and R4. Similar comments suggested that the measure for Requirement R4 has a training connotation, which is inconsistent with the language in the requirement, which uses the term “review.” The DSR SDT has eliminated Requirement R4 and added a part to Requirement 1, Part 1.5, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. Eliminating R4 and adding Part 1.5 maintains the intent while eliminating potential confusion and redundancy.

Other commenters suggested revisions to the use of the term annual. The DSR SDT reviewed the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) CAN-0010, which provides drafting teams latitude to define the term within a requirement as they intend it to be used.

Organization	Yes or No	Question 9 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	We do not believe that the requirement should specify that the plan must be reviewed with those personnel who have responsibilities identified in that plan as there is no requirement in R1 that the plan must identify any specific personnel responsibilities. Additionally, we seek clarification on whether review in this instance means train as indicated in the measure.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated requirement R4 and added a Part under Requirement R1, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. By adding this Part to Requirement R1, the SDT has eliminated confusion and redundancy around the use of the term “review” and the training connotation in the Measure.</p>		
Dominion	No	The need to periodically review its Impact Event Operating Plan has not been established and is overly restrictive (annually) given that the purpose of the standard is to report Impact Events. Suggest removing this requirement
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated requirement R4 and added a Part under Requirement R1, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. The DSR SDT</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
		<p>'s intent is to ensure that there is no gap in the review of the Operating Plan even though the plan has provision(s) for updating the event Operating Plan within 90 days of any change to its content. By adding this Part to Requirement R1, the SDT has eliminated confusion and redundancy around the use of the term "review" and the training connotation in the Measure.</p>
SPP Standards Review Group	No	<p>There is confusion surrounding the use of the term review in R3 and R4. In R3 and the suggested revision to M3 in Question 8, review is an analysis of the plan by a specific group tasked to determine if the plan requires updating or modifying to remain viable. Review in R4 has training connotations for all personnel who have responsibilities identified in the plan. Although we understand the use of review in R4 is new to this version of EOP-004-2, we believe it may be more appropriate to use training rather than review in R4. And further, we feel the training should be focused on those specific portions of the plan that apply to specific job functions.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated Requirement R4 and added a Part under Requirement R1, to require a process for ensuring that the event Operating Plan is reviewed at least annually, with no more than 15 calendar months between review sessions. By adding this Part to Requirement R1, the SDT has eliminated confusion and redundancy around the use of the term "review" and the training connotation in the Measure.</p>		
FirstEnergy	No	<p>We believe that Requirement 4 does not warrant a Medium risk factor. For example, a simple review of the process does not have the same impact on the Bulk Electric System as the implementation of the Operating Plan per R2. Therefore, we believe R4 is at best a Low risk to the BES.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated Requirement R4 and has re-evaluated the Violation Risk Factors for each requirement. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
We Energies	No	<p>Include that this is for internal personnel as stated in the associated measure.</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated Requirement R4 and the associated Measure.</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2
<p><b>Response:</b> Thank you for your comments and suggestions. Please see responses to question 2.</p>		
Exelon	No	<p>Need more guidance on what personnel are expected to participate in the annual review.</p> <p>Training for all participants in a plan should not be required. Many organizations have dozens if not hundreds of procedures that a particular individual must use in the performance of various tasks and roles. Checking a box that states someone read a procedure does not add any value. This is an administrative burden with no contribution to reliability. If the intention is that internal personnel who have responsibilities related to the Operating Plan cannot assume the responsibilities unless they have completed training. This requirement places an unnecessary burden on the registered entities to track and maintain a database of all personnel trained and should not be a requirement for job function. A current procedure and/or operating plan that addresses each threshold for reporting should provide adequate assurance that the notifications will be made per an individual's core job responsibilities.</p>
<p><b>Response:</b> Thank you for your comments. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The requirement is written so that it is not prescriptive and allows the entity flexibility in how it tests its communications process.</p>		
City of Tallahassee (TAL)	No	<p>The verbiage at least annually, with no more than 15 months between review sessions is an attempt to define annually. If you want every 15 months say at least every 15 months. Otherwise just say annual and let the entities decide what that is, as is being done with other annual requirements.</p>
<p><b>Response:</b> Thank you for your comment. The DSR SDT took into consideration the CAN on the definition of 'Annual' and wrote the requirement to meet the intent of the team.</p>		
Tenaska	No	The proposed Impact Event Operating Plan should not be required.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT considers the proposed event Operating Plan a document that identifies the activities to achieve the purpose to improve industry awareness and the reliability of the Bulk Electric System. The DSR SDT has revised R1 to only include development of an Operating Plan that includes the sub-requirements of R1.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
American Municipal Power	No	No, remove R4. R4 is not an acceptable requirement nor should this be an operation. Focusing on a plan and personnel tracking is overly prescriptive. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has taken into consideration your comment, eliminated Requirement R4, and added Requirement R1, Part 1.5. The SDT agrees that the Registered Entity can decide on the how to implement the reporting; however, this requirement mandates that the Registered Entity document its process.</p>		
Liberty Electric Power LLC	No	Again, the entity should determine the need for review of any procedure. Changing circumstances may dictate a shorter cycle, but no changes could dictate a longer review. I will note that spill prevention plans are required to be reviewed every five years, so I question the need for an 18-month review of the EOP plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The review provisions are designed to ensure that contact information for internal and external organizations are correct and up to date.</p>		
Arkansas Electric Cooperative Corporation	No	We appreciate the effort the team has taken in improving the requirements since the last posting. We request the team clarify if this also includes personnel observing and reporting the requirements or only those specifically listed in the plan. The measure seems to indicate it only includes those listed in the plan, but this is not clear in the requirement. If it includes those personnel involved in observing and notifying management, then this might include a significant portion of the organization. In either case, we feel the requirement should be modified as "review applicable portions of its Impact Event Operating Plan...."
<p><b>Response:</b> The DSR SDT thanks you for your comment. The training provisions of the standard have been removed. The DSR SDT intent is to ensure that the Registered Entity has Operating Plan(s) for the identification of events, establishing which internal personnel are involved, identification of outside agencies to be notified, and having a provision for updating the plan(s). The SDT feels that current Sabotage Reporting guidelines already provide much of the information needed in the new R1.</p>		
Calpine Corp	No	Failure to properly report events is currently sanctionable under CIP-001-1 and EOP-004-1 and will continue to be sanctionable under proposed EOP-004-2. Entities are capable of implementing procedures appropriate to ensure compliance with the actual reporting requirements without the addition a formal requirement to annually review their internal procedures with personnel. In the unlikely event that an entity cannot attain this level of operating competence without implementation of a new requirement, such Entities would be subject to enforcement under Requirement R5. Absent substantial evidence of systemic problems by Entities in contacting local law enforcement properly or failures to complete event reports to appropriate agencies when provided with clear guidance on the events to be reported, this requirement is unnecessary.

Organization	Yes or No	Question 9 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R2 and revised Requirements R1 and R5 to address your concern. Requirement R5 (now R2) reads:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
ExxonMobil Research and Engineering	No	<p>Its unclear whether R4 is a training requirement to train all individuals who may be required to implement its Impact Event Operating Plan on an annual basis or a requirement for an Entity to review the Impact Event Operating Plan with at least one person from each position that has a role in the Impact Event Operating Plan in order to complete a quality review of the Impact Event Operating Plan. The SDT should clarify the intent of the requirement. If the intent is that both of the aforementioned interpretations is expected to occur, the SDT should break R4 into two requirements so that an entity is not violation of Requirement R4 when the entity fails to comply with one of the two imbedded requirements (e.g. if the quality review is not performed but all individuals were trained).</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Constellation Power Generation	No	<p>The purpose of this requirement as currently worded is unclear. It seems to insinuate that a formal review of the Operating Plan takes place annually, and that any and all personnel identified in the plant are part of the review. If that is correct, than CPG believes this requirement is echoing Requirement 3. These two requirements can be incorporated into one. Furthermore, the Measure for R4 is too prescriptive, going so far as to specifically describe how this formal review should take place. It even states that the Responsible Entity needs to present documentation showing that the personnel in the plan were trained, yet there is no requirement for training. CPG would like the DSR SDT to revisit the purpose and intent of this requirement, alone and in concert with R3. If there are indeed similar then consolidate them into one requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Georgia System Operations Corporation	No	<p>With the current CAN on the definition of annual, we do not believe that the additional qualification that the test shall be conducted "with no more that 15 calendar months between reviews" is necessary. Remove "with no more that 15 calendar months between reviews.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT has revised the term annual to align with the definition in the NERC Compliance Application</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
Notice (CAN) CAN-0010.		
SERC OC Standards Review Group	Yes	We agree with the concept, but disagree with the use of the term Operating Plan as a defined term in line with our comments in question 6 above.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT believes that the use of a defined term “Operating Plan” to describe the procedure to identify and report the occurrence of a disturbance is appropriate and has revised Requirement R1 to remove the terms Operating Process and Operating Procedure to eliminate confusion.</p>		
PJM Interconnection LLC	Yes	<p>1. We agree with the concept but disagree with the use of the term Operating Plan as a defined term in line with our comments to Question 6 above.</p> <p>2. R4 attempts to define Annual for the Registered Entity to review its Impact Operating Plan. We believe R4 should follow the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) CAN-0010 Definition of Annual as opposed to creating a new definition of Annual or refer to an entities defined use of the term annual.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see responses to question 6 above. The DSR SDT reviewed the NERC definition of Annual as defined in the NERC Compliance Application Notice (CAN) CAN-0010. The NERC CAN provides drafting teams latitude to define annual within a Requirement as they believe is appropriate in the context of a particular standard.</p>		
United Illuminating Co	Yes	As written it is a training burden. Certain persons will have only one step in one operating procedure to perform. There is no necessity to review the entire Operating Plan with them. For example, Field Personnel need to know that if they see something not right to report it immediately. In this instance there is no benefit to review the Operating Procedure/Process for firm load shedding with them.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The training requirement has been removed. The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized events is correct so that the entity can respond appropriately in the case of an actual event. The DSR SDT has removed R4 to eliminate potential confusion and redundancy around the training connotation.</p>		
Manitoba Hydro	Yes	Removing the extreme details within 30 days of revision and train before given responsibility and giving leeway to when this training is necessary, will allow training to be integrated into other existing training schedules. Inclusion of 5.3 and 5.4 would require unique set of time lines and additional resources to monitor and implement.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The training provisions of the standard have been removed.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 9 Comment
Occidental Power Marketing	Yes	However, only LSEs with BES assets (or assets that directly support the BES) should be included in the Applicability section of the standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Attachment 1 specifies which types of events are required to be reported by each entity. LSE is included here due to CIP-002-3 applicability.</p>		
Farmington Electric Utility System	Yes	A review of the Impact Event Operating Plan can be interrupted as an informal examination of the plan. The measure for R4 indicates evidence of a review, parties conducting the review AND when internal training occurred. It should be clarified in R4 training is expected as part of the review for personnel with responsibilities. This is an improvement from the previous 5.3 and 5.4, however, the team should consider adding back, and review/training shall be conducted prior to assuming the responsibility in the plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Ingleside Cogeneration LP	Yes	Yearly refresher training on the reporting process is appropriate. Ingleside Cogeneration also agrees that a review with those individuals with assigned responsibilities under the Operating Plan is a better way to frame the requirement.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and added a new Part 1.5 under R1 to address your concern. Part 1.5 calls for an annual review of the plan.</p>		
Indeck Energy Services		R4 is redundant with R3 and should be deleted. The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has deleted Requirement R4 and revised R3. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.		
Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	
Midwest ISO Standards Collaborators	Yes	
Southern Company	Yes	
SRP	Yes	
SDG&E	Yes	
New Harquahala Generating Co.	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 9 Comment
APX Power Markets	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
ISO New England, Inc	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
American Transmission Company	Yes	
Duke Energy	Yes	
City of Tacoma, Department	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

<b>Organization</b>	<b>Yes or No</b>	<b>Question 9 Comment</b>
of Public Utilities, Light Division, dba Tacoma Power		
Brazos Electric Power Cooperative	Yes	
Progress Energy	Yes	

10. Do you agree with the proposed revisions to Requirement 6 (now R5) and the use of either Attachment 2 or the DOE-OE-417 form for reporting? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.

**Summary Consideration:** The slight majority of commenters suggested revisiting R2 and R5 to eliminate potential redundancy and confusion. The intent of the two requirements is to have entities utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, it does not have to transcribe the same information onto Attachment 2 but may be required to submit the form to the DOE and NERC. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements.

R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

Organization	Yes or No	Question 10 Comment
Northeast Power Coordinating Council	No	R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the how part, not the what. The vehicle for reporting can easily be included in <b>R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event</b> . Suggest combining R2 with R5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Dominion	No	Dominion does not agree because the Requirement is too restrictive giving the Responsible Entity the choice on reporting forms as either Attachment 2 or DOE OE-417. The use of Attachment 2 or DOE OE-417 may be appropriate when reporting to NERC, however, Requirement R 1.3.2 requires the Responsible Entities Impact Event Operating Plan to address notifications to non-NERC entities such as Law Enforcement or Governmental Agencies. It is likely that these organizations have specific reporting requirements or forms that will not line up the options prescribed in Requirement R5. Suggest revising Requirement R5 to not require the use of these two forms as the only options. If these 2 forms are used, suggest aligning the Event names in Attachment 1 to be similar to the criteria for filing event names in the DOE OE-417 to allow for consistency.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
		Also suggest aligning the time to submit for similar event names in each form.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has revised Attachment 1 to indicate that entities must submit Attachment 2 or the DOE OE-417 form. This information was contained in Requirement 5. The intent of the two requirements is to have entities make appropriate notifications and report events contained in Attachment 1. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements while eliminating potential confusion and redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p> <p>The DSR SDT has enhanced Attachment 1 and clarified the intent of each event, threshold and reporting time limits. The DSR SDT removed the column, Time to Submit Report and replaced it with Submit Attachment 2 or DOE OE-417 Report.</p>		
SPP Standards Review Group	No	We feel there is redundancy between R2 and R5. To eliminate this redundancy, we propose to take the phrase using the form in Attachment 2 or the DOE OE-417 reporting form and adding it at the end of R2. Then what is left of R5 could be deleted. The new R2 would read Each Responsible Entity shall implement its Impact Event Operating Plan documented in Requirement R1 for Impact Events listed in Attachment 1 (Parts A and B) using the form in Attachment 2 or the DOE OE-417 reporting form.?
<p><b>Response:</b> The DSR SDT has revised Attachment 1 to indicate that entities must submit Attachment 2 or the DOE OE-417 form. This information was contained in Requirement 5. The intent of the two requirements is to have entities make appropriate notifications and report events contained in Attachment 1. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements while eliminating potential confusion and redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Midwest ISO Standards Collaborators	No	Requirement 2 and Requirement 5 appear to be very similar. Requirement 2 requires implementation of the Operating Plan, Operating Process and/or Operating Procedure in Requirement 1. The Operating Procedure requires gathering and reporting of information for the form in Attachment 2. What does Requirement 5 add that is not already covered in Requirement 2 except the ability to use the DOE OE-417 reporting form which
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the two requirements is to have entities utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
FirstEnergy	No	We believe that Requirement 5 does not warrant a Medium risk factor. Not using a particular form is strictly

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
		administrative in nature and the VRF should be Low.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
PJM Interconnection LLC	No	R5 seems redundant as R2 already requires an entity to report any Impact Events by executing/implementing its Impact Event Operating Plan. R5 merely stipulates the use of Attachment 2 or DOE-417, which an entity automatically would use for reporting purposes while implementing its Impact Event Operating Plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The intent of the two requirements is to have entities utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC. By eliminating R2 and revising R5 (now R2), the DSR SDT has maintained the intent of the requirements.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Exelon	No	Agree that each Responsible Entity should be able to use either Attachment 2 or the DOE OE-417 form for reporting; however, a GO/GOP will not have the ability to respond to Attachment 2 Task numbers 8, 9, 10, 11, and 12. Suggest that the DSR SDT either evaluate a shortened form version, provide a note or provision for "N/A" based on registration, or revise form to be submitted by the most knowledgeable functional entity (e.g., TOP or RC).Need clear guidance as to which form is to be used for which Impact Event, we feel that one and only one form should be used to eliminate confusion. Attachment 2 has an asterisk on #s 7, 8, 9, 10 and 11 there is not reference corresponding to it.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has updated Attachment 2 to per comments received.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
Tenaska	No	R5 should be changed to Each Responsible Entity shall report Impact Events listed in Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form. This revised version of the proposed R5 is the only Requirement that is necessary to achieve the stated purpose of Project 2009-01. The proposed R1 through R4 should be deleted and R5 should be changed to R1.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT agrees the reporting is a fundamental aspect, but the operation plans are integral piece of the BES. The DSR SDT believes that the revisions created will provide clarity for the requirements. Please see the revised standard.</p>		
American Municipal Power	No	R5 is not an acceptable requirement, but it can be improved. Each Responsible Entity shall report "Impact Events" to _____ (address specified in attachment 1, website, entity, email address, or fax, etc.) Focusing on a plan and procedure is overly prescriptive. The only requirement should be to have an entity submit a report. Let the entity decide how they want to implement the reporting.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy. The SDT agrees that the Registered Entity can decide on the how to implement the reporting; however, this requirement mandates that the Registered Entity document its process.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Arkansas Electric Cooperative Corporation	No	We appreciate the effort the team has taken in improving the requirements since the last posting. For R5, we suggest including the reporting form as part of the plan in R1. Otherwise, a violation of R5 would also indicate a violation of R2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
American Electric Power	No	This should be one-step covered by the implementation in requirement 2. We like the ability to use one form (i.e. NERC Attachment 2 or the DOE-417); however, we would prefer to have this information only be reported once.
<p><b>Response:</b> The DSR SDT thanks you for your comment. EOP-004-2 allows entities to utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
Consumers Energy	No	We understand that DOE is migrating to an on-line reporting facility rather than the email-submitted OE-417. If they do so, Form OE-417 will not be available for providing to NERC, and the reporting specified by EOP-004 will be duplicative of that for DOE. We recommend that NERC, RFC and the DOE work cooperatively to enable a single reporting system in which on-line reports are made available to all appropriate parties.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT agrees with the concept of the single reporting template and is working with other agencies to see if the single form would be achievable.</p>		
Independent Electricity System Operator	No	R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the how part, not the what. The vehicle for reporting can easily be included in R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event. We suggest the SDT combine R2 with R5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.</p>		
Ameren	No	The "Responsible Entity" should be limited to those functions with the most oversight such as the BA, RC, or TOP. Otherwise there will be multiple DOE OE-417 reports sent by multiple entities.
<p><b>Response:</b> Thank you for your comments. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
ISO New England, Inc	No	R5 stipulates the use of Attachment 2 or the DOE-417, which is the vehicle for reporting only. This is the how part, not the what. The vehicle for reporting can easily be included in R2 where an entity is required to implement (execute) the Operating Plan upon detection of an Impact Event. We suggest the SDT combine R2 with R5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p>		
Calpine Corp	No	The use of DOE OE-417 is acceptable, but the language of Requirement R5 should be modified. The disturbance event form must be filled out correctly, irrespective of the requirements of an Entities Impact Event Operating Plan. Reference to that Plan does not add clarity to the requirement to report events. The



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 10 Comment
		<p>requirement should delete the reference to the Impact Event Operating Plan? and simply state: Each Responsible Entity shall report events listed in Attachment 1 using the provided form, or where also required to complete the current version of DOE OE-417, that form. Although one of the primary stated purposes of the original SAR was to simplify the reporting process by creating a single form, the fact that some entities are already required to report substantially identical information to DOE argues for retention of the use of the DOE form.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. DSR SDT has deleted requirement 2 and revised requirements R1 and R5 (now R2) to address your concern. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
BGE	No	<p>Language needs to be more specific on when to use Attachment 2 or DOE-OE-417.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Attachment 2 should be the normal reporting vehicle unless the entity is required to submit an OE-417 to the DOE. This keeps the entity from having to file two distinctly different reports for the same event.</p>		
Alliant Energy	No	<p>We believe Attachment 2 should be deleted, and NERC should work with the DOE to have one form for all events, if possible. It makes the reporting procedure much simpler, only having to use one form.</p>
<p><b>Response</b> The DSR SDT thanks you for your comment. EOP-004-2 allows entities to utilize the DOE Form OE-417 to report events listed on Attachment 1. If the entity completes DOE Form OE-417 to report an event, they do not have to transcribe onto attachment 2 but may be required to submit it to the U.S. Department of Energy (DOE) and NERC. The DSR SDT is currently working with the DOE to make revisions to Form OE-417 that would achieve the objective of your comment. We will continue to pursue this.</p>		
ExxonMobil Research and Engineering	No	<p>The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notification windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 10 Comment
		<p>purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of the situation and determine the extent of the problem. The existing standards requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT envisions that each Registered Entity will develop Operating Plan(s) appropriate to meet its obligations as outlined in the standard. The SDT doesn't feel it necessary to prescribe to the Registered Entity any particular interpretation on how to achieve compliance, including who the information should be reported to. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
American Transmission Company	No	<p>Attachment 2, Task #14 in the report should be modified to read, Identify any known protection system misoperation(s). If this report is filed quickly, there is not enough time to assess all operations to determine any misoperation. As a case in point, it typically takes at least 24 hrs. to receive final lightning data; therefore, not all data is available to make a proper determination of a misoperation</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. The entire Attachment 1 has been updated to reflect your comment.</p>		
Constellation Power Generation	No	<p>The requirements for filling out the DOE-OE-417 form are not necessarily the same as the requirements prescribed in Attachment 1. CPG suggests that the drafting team create a new requirement, spelling out when an entity is required to complete the DOE-OE-417 form.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Any entity that is obligated to submit Form OE-417 may submit that completed form to NERC in lieu of Attachment 2.</p>		
Georgia System Operations Corporation	No	<p>R5: This standard should not require all Responsible Entities to report the same event. Entities should be allowed to report in a hierarchical manner. They should be allowed to coordinate impact event plans and include in their plans the entity that has the responsibility for reporting various events. Flexibility should be allowed to provide different reporting entities depending on the type of event. In R5, does each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan? Allow this hierarchical reporting and flexibility? An entity should be allowed to report to another operating entity by whatever reporting form or mechanism works and then the other entity reports to NERC using the required NERC or DOE form. Add "To the extent that a Responsible Entity had an Impact Event," at the beginning of R5 and</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
		M5.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each entity is required to report their portion of the event, however they can coordinate. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, will be able to provide the ERO and others with a different views of what has happened. The DSR SDT understands that there may be multiple reports (for certain events) that are required by different government agencies. NERC will continue to streamline the reporting process as we move into the future. The DSR SDT has also eliminated R2 and revised R5 (now R2) for clarity and to eliminate potential redundancy.</p>		
Indeck Energy Services	No	The Violation Risk Factor should be Low, if any, because this is historical reporting, with little or no reliability consequence.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Bonneville Power Administration	Yes	Reporting form OK. Note that the Frequency Maximum/Minimum Section should be clarified. A Gen Loss doesn't usually experience a high (maximum) frequency, just the low immediately following the event.
<p><b>Response:</b> The DSR SDT thanks you for your comment</p>		
Midwest Reliability Organization	Yes	This will reduce any double reporting to the ERO and FERC.
PPL Supply	Yes	Reporting consistency and timelines may need to be reviewed for example: Fuel Supply Emergency - OE-417 requires reporting within 6 hours / Attachment 1 Part B requires reporting within 1 hour.
<p><b>Response:</b> The DSR SDT thanks you for your comment The DSR SDT has significantly revised Attachment 1 and deleted Fuel Supply Emergency from Attachment 1. This item was removed in coordination with the NERC Events Analysis Working Group and the proposed Events Analysis Program. All events are</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
<p>now to be reported within 24 hours with the exception of Destruction of BES equipment, Damage or destruction of Critical Assets and Damage or destruction of Critical Cyber Asset events in Part A and Forced Intrusion, Risk to BES equipment and Detection of a reportable Cyber Security Incident in Part B.</p>		
SERC OC Standards Review Group	Yes	We agree with the concept, but disagree with the use of the term Operating Plan as a defined term in line with our comments in question 6 above.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT agrees with your viewpoint and believes that your statement is consistent with the intent of the requirement. (refer to question 6)</p>		
United Illuminating Co	Yes	Put it's before Impact Event Operating Plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see the revised standard.</p>		
Manitoba Hydro	Yes	The DOE-OE-417 appears more intuitive and descriptive (and on line ability), but having the either or option is fine. DOE-OE-417 Form is mentioned several time in this Standard, but no link to this document.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see the revised standard.</p>		
CenterPoint Energy	Yes	CenterPoint Energy agrees with the idea of streamlining the reporting process through the use of existing report forms. However, as noted in the response to Question 11, the Company has concerns about the DOE OE-417 Form, specifically the timeframes in which to submit reports. CenterPoint Energy will be making the same recommendation to extend reporting timeframes during the DOE OE-417 report revision process when the current form expires on 12/31/11. Any future changes to the DOE Form could also impact reporting for this requirement.
<p><b>Response:</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. The DOE Form OE-417 is under review by the U.S. Department of Energy (DOE) and can be updated or changed without NERC's involvement. The DSR SDT has taken into consideration the use of OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2's reporting requirements.</p>		
PPL Electric Utilities	Yes	We would like to suggest the language be changed such that submission via a NERC system would be acceptable in addition to the use of the Attachment 2 Form or the DOE OE-417 form. The standard would then accommodate the proposed revision to NERC Rules of Procedure 812. NERC will establish a system to collect impact events reports??

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 10 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The SDT expects any system would facilitate the reporting to organizations specified in the submitted report. Until such time that the system can be established, the Registered Entity will be obligated to make the notifications as specified in its Operating Plan(s). The DSR SDT is currently working with the U.S. Department of Energy (DOE) to make revisions to Form OE-417 that would achieve the objective of your comment, and will continue to pursue this.</p>		
Ingleside Cogeneration LP	Yes	Although our preference would be to have a single form, Ingleside Cogeneration realizes that is not likely in the near term. We would like to see that remain as a goal of the project team or the ERO.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT is currently working with the DOE to make revisions to Form Form OE-417 that would achieve the objective of your comment, and will continue to pursue this.</p>		
Duke Energy	Yes	There is so much overlap between Attachment 2 and the DOE OE-417 that we believe the DOE OE-417 should be revised to include the additional items that must be reported to NERC, so that there is only one form to submit to NERC and DOE.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT is currently working with the DOE to make revisions to Form OE-417 that would achieve the objective of your comment, and will continue to pursue this.</p>		
Western Electricity Coordinating Council	Yes	
Pacific Northwest Small Public Power Utility Comment Group	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	
Southern Company	Yes	
SRP	Yes	
We Energies	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 10 Comment
Compliance & Responsibility Organization	Yes	
SDG&E	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Liberty Electric Power LLC	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	
Brazos Electric Power Cooperative	Yes	

**11. Do you agree with the proposed revisions to Attachment 1? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Most commenters expressed concerns with the reporting times listed in Attachment 1. Upon review of comments received concerning Attachment 1, the DSR SDT did a thorough review and updated the entire document, along with all Footnotes. The DSR SDT removed the column, Time to Submit Report and replaced it with Submit Attachment 2 or DOE OE-417 Report. There were many noted comments that a one hour reporting time frame does not coincide with an after the fact reporting Standard. The DSR SDT reviewed each time frame to report and has extended most of the time frames to 24 hours. There are a few events that have a one hour reporting requirement that was not changed because these are events that would generally be reported to law enforcement authorities and prompt reporting is in the interest of BES reliability. Duplicate reporting of events was minimized where possible. There are several events that will require reporting by multiple entities to achieve a complete enough picture to facilitate industry awareness.

Organization	Yes or No	Question 11 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	As stated above in response to question 6, we believe that a column should be added to the tables to explicitly indicate what external organizations should receive the communications of a particular Impact Event type. Additionally we have concerns with the following table items: Threshold for reporting Transmission Loss: As stated, this will require the reporting of almost all transmission outages. This is particularly true taking into consideration the current work of the drafting team to define the Bulk Electric System. The loss of a single 115kV network line could meet the threshold for reporting as the definition of Element includes both the line itself and the circuit breakers. Instead, we recommend the following threshold "Three or more BES Transmission lines." This threshold has consistency with CIP-002-4 and draft PRC-002-2. This threshold also needs additional clarification as to the timeframe involved. Is the intent the reporting of the loss of 3 or more BES Transmission Elements anytime within a 24 hour period or must they be lost simultaneously? Also, we recommend that these three losses be the result of a related event to require reporting. Entity with Reporting Responsibility for Loss of Off-site power to a nuclear generating plant (grid supply): The reporting responsibility should clarify that this is only entities included in the Nuclear Plan Interface Requirements.
<p><b>Response:</b> The DSR DT thanks you for your comment. Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received.</p>		
Northeast Power Coordinating	No	As indicated under Question 4, we question the need to include IA, TSP and LSE in the responsible entities

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
Council		for reporting.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has established that CIP-002 and CIP-008 are applicable to an IA, TSP, and LSE. These entities will report a Cyber Security Incident per Attachment 2 (or OE-417) as the vehicle to inform the ERO, their Regional Entity and their Reliability Coordinator.</p>		
Bonneville Power Administration	No	Generally OK, but there are too many events to report. The loss of 3 BES elements for a large geographic entity for a (5 county?) windstorm that has little impact to the system is not needed. 3 elements within the same minute could be acceptable and 6? elements still out within an hour ... or something to that affect could work.
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received.</p>		
Midwest Reliability Organization	No	<p>1) Section 9 of the Impact Reporting Form states: "List transmission facilities (lines, transformers, busses, etc.) tripped and locked out." But Part A of Attachment 1 states: "Three or more BES Transmission Elements." a. Should section 9 state: "List transmission facilities (lines, transformers, busses, etc.) tripped or locked out"? b. Should section 9 state: "List transmission elements (lines, transformers, busses, etc.) tripped or locked out"? This will align the reporting criteria with the actual reporting form.2) Section 13 of the Impact Reporting Form states: "Identify the initial probable cause or known root cause of the actual or potential Impact Event if know at the time of submittal of Part I of this report:." Recommend that "of Part I" be removed since there is no Part 2.3) Every Threshold in attachment 1 gives a clear measurable bright line, except: ?Transmission Loss?. As presently written ?Three or more BES Transmission Elements? could imply that a Report will be required to be submitted if a BES transmission substation is removed from service to perform maintenance. Or there could be three separate elements within a large substation that are out of service (and don?t effect each other) that will require a Report. Upon review of the TPL standards, there are normally planned items that our industry plans for. It is recommended that the Threshold for Reporting of Transmission Loss be enhanced to read: ?Two or more BES Transmission Elements that exceed TPL Category D operating criteria or its successor?. This threshold now is based on a actively enforced NERC Standard, and each RC and TOP are aware of what this bright line is.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received. Attachment 2 has been updated to reflect the changes noted in your comments and changes per the received comments.</p>		
PPL Supply	No	Recommendation: Add a column in Attachment 1 to acknowledge the events that require a OE-417 Report



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		and list the number under Schedule 1 that required Form OE-417Report. This would add accuracy and consistency among reporting entities.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DOE Form OE-417 is under review by the DOE and can be updated or changed without NERC’s involvement. The DSR SDT has taken into consideration the use of OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2’s reporting requirements.</p>		
Pacific Northwest Small Public Power Utility Comment Group	No	<p>The comment group is composed of smaller entities that do not all maintain 24/7 administrative support. While many of the 1 hour reporting thresholds do not affect us, some do. Others may come into play as standards are revised, such as the CIPs. We ask the SDT to consider the identification or verification that starts the clock on these may come at inopportune times for meeting a one hour deadline for these entities. Restoration may be delayed in an attempt to meet these time limits. Safety should always be the number one priority, and restoration and continuity of service second. We see reporting of these events much further down the list. We note that FERC order 693, paragraph 471 does not dictate a specific reporting time period and therefore we suggest timing requirements that promote situational awareness but allow smaller entities needed flexibility. FERC order 693, paragraph 470 directed the ERO to consider ?APPA?s concerns regarding events at unstaffed or remote facilities, and triggering events occurring outside staffed hours at small entities.? Our comment group does not believe the SDT has adequately responded to APPA?s concerns but rather took the 1 hour Homeland security requirement referenced in paragraph 470 verbatim. While a report within an hour might be ideal, it is not always practicable. We suggest: 1) as soon as possible after service has been restored to critical services within the service territory, or 2) By the COB the first business day after discovery. Our comment group realizes the difficulty in wording standards/requirements that lump small entities in with larger ones and we believe our suggestion achieves some balance. Expecting smaller entities to achieve timing requirements that can only be normally met under ideal conditions at large entities is not feasible or fair.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity’s notification. The Threshold for Reporting has been updated to reflect comments that have been received. EOP-004-2 requires an entity to “push” information to certain parties for industry awareness. Since this Standard is an after the fact reporting Standard, reporting times for a majority of event types reporting times for a majority of event types have been extended to allow the impacted entity to recover from the event and then report. The starting time to report is upon an entity’s recognized the event, per Submit Report column of Attachment 1.</p>		
PSEG Companies	No	For the reasons cited in response to question 4 above the language roles and responsibilities remain inconsistent and unclear. The Time to Report changes are unreasonable and there is significant duplicate reporting required.

Organization	Yes or No	Question 11 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> Upon review the DSR SDT has included a column to indicate the minimum parties who are required to receive the entity's notification. The Threshold for Reporting has been updated to reflect comments that have been received. EOP-004-2 requires an entity to "push" information to certain parties for industry awareness. Since this Standard is an after the fact reporting Standard, reporting times for a majority of event types have been extended to allow the impacted entity to recover from the event and then report.</p>		
Dominion	No	<p>1) A particular Event could be applicable to multiple entities and Attachment 1 would require each applicable entity to report the event. This is duplicative and would appear to overburden the reporting system. 2) Loss of off-site power (grid supply) reporting for nuclear plants is duplicative of reporting done to satisfy NRC requirements. Given the activity at a nuclear plant during this event, this additional reporting is not desired. 3) Cyber intrusion remains an event that would need to be reported multiple times (e.g., this standard, OE-417, NRC requirements, etc.). 4) Since external reporting for other regulators (e.g., DOE, NRC, etc.) remains an obligation of the Applicable Entity, suggest that Attachment 1 only contain impact events as defined in the current version of EOP-004.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the functional entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The DSR SDT understands that there may be multiple reports (for certain events) that are required by different governing agencies. NERC will continue to streamline the reporting process in the future.</p>		
Pepco Holdings Inc and Affiliates	No	<p>The entity responsible for reporting is not clear. Is the initiating entity the same as requesting entity or implementing entity? In the paper it indicates the DT intent is for the entity that performs the action or is directly affected will report. It seems that the proposal would result in a significant amount of duplicate reporting.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT believes it is clear that the reporting entity is the entity that experiences an event or initiates the event (per Threshold for Reporting in Attachment 1). The DSR SDT will ensure that the supporting guideline clearly states this. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view to what has happened.</p>		
SPP Standards Review Group	No	<p>Threshold for Reporting ? Some of the thresholds used to trigger event reporting seem arbitrary. For example, why were three BES Transmission Elements selected for the transmission loss trigger? What's significant with three? There may be situations where one element can impact reliability more than other situations where three or more lines may be lost. The defining line should be impact to reliability, not a simple count of elements. Also, timing of the loss of these elements is important. If the three elements are lost over a 3-day span, does this trigger an event report? We would think not and would like to see that clarification in the</p>

Organization	Yes or No	Question 11 Comment
		<p>standard.Public appeals ? Some entities may utilize load reduction (Demand Response, interruptible loads, etc) in the normal course of daily operation in lieu of committing additional generation resources. Because this is not an Energy Emergency as defined in the NERC Glossary, would such an event trigger the filing of an Impact Event report under EOP-004-2? We would like clarification on this issue.Multiple entity reporting responsibility ? Several of the triggering events in Attachment 1 list multiple entity reporting responsibility. The SDT needs to clarify precisely who has the actual reporting responsibility for those events. For example, if a DP loses ? 300 MW (or ? 200 MW depending on size) of load who files the report? Is it the DP, TOP, BA or RC? Attachment 1 would lead us to believe all four are required to file reports. This redundancy is unnecessary and creates unneeded paperwork. Surely this redundancy is not the intent of the SDT.Reporting timeframe ? The timeframes for reporting these after-the-fact reports need to be thoroughly reviewed and, we believe, realigned. Which is more important to the reliability of the BES, operating and controlling the BES following an Impact Event or filing a report describing that event? Most operating desks are staffed by a single operator at nights and on weekends. Their focus should be on operating the system, not filing a report with NERC or DOE within one hour.There appears to be inconsistency in the reporting times among the triggering events. There doesn't appear to be any logic regarding how the times were selected. Shouldn't impact to the reliability of the BES be that basis? Why is a BA with 50 MW of load who makes a public appeal to customers for load reduction required to report within 1 hour while an IROL violation doesn't need to be reported for 24 hours? Clearly the IROL violation has a greater impact on the reliability of the BES. Therefore, shouldn't these types of reports be filed sooner than those events with less impact on BES reliability?Risk to BES equipment ? The Threshold for Reporting this event indicates that only those events associated with a non-environmental physical threat should be reported. The train derailment example in the footnote then conversely describes just such an environmental threat with flammable or toxic cargo. Which should it be? Additionally, how does one determine the applicability of a potential threat? Is this time dependent, is it threat dependent, how do we factor all this in?</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT believes it is clear that the reporting entity is the entity that experiences an event or initiates the event (per Threshold for Reporting in Attachment 1). The DSR SDT will ensure that the supporting guideline clearly states this. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view to what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
FirstEnergy	No	Nuclear facilities should be explicitly excluded from the events which have CIP standards as the threshold for reporting since they are exempt from the CIP standards.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT understands that nuclear facilities are exempt from CIP Standards but the Loss of Off Site Power to a nuclear generating plant is a Transmission Owner's and Transmission Operator's responsibility and needs to be reported to the ERO and their</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
Regional Entity for the follow up as described by the Event Analysis Program.		
SERC OC Standards Review Group	No	While we agree with the changes made, we do not believe the goal of eliminating duplicate reporting has been accomplished. In addition, the threshold for transmission loss does not adequately translate to previous ?loss of major system components? which had a threshold of ?significantly affects the integrity of interconnected system operations?.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
PJM Interconnection LLC	No	There is still a significant amount of duplicate reporting involved in Attachment 1, which needs to be cleared. See comments to Question 4.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
We Energies	No	It appears that the footnotes only apply one place in the table. Place the footnote in the table where it applies.Voltage Deviations on BES Facilities: 10% compared to what? Rated?Forced Intrusion: ?At a BES facility? facility or Facility?
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. The Footnotes have been reviewed and updated per comments received.</p>		
LG&E and KU Energy LLC	No	In Attachment 1, the existing EOP-004-1 Attachment 1, point 6 includes an ?Or? for the entities (RC, TOP, GOP) for a, b and c. The way the SDT has pulled this apart, they have included the GOP as having an impact on the Voltage Deviations on BES Facilities. The TOP monitors the transmission system and directs GOPs when they need to change in order to protect the system reliability. This is not something the GOP is responsible for monitoring. The GOP is required to be at the TOP assigned voltage schedule and that actually falls under VAR-002 already. Please remove the GOP from the line of ?Voltage Deviations on BES Equipment.? The way EOP-004-1 Attachment 1 point 6 is currently written, the GOP is an ?or? and does fall into parts b or c, where part 6b is similar to the proposed line ?Damage or destruction of BES equipment? identified in the proposed EOP-004-2 Attachment 1. However, currently the GO/GOP reports ?Loss of Major System Components? on EOP-004-1 within 24 hours of determining damage to the equipment. The proposed ?One hour? is too tight of a window as the GO/GOP often do not know the extent of damage that

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		soon. Typically the OEM is called upon to come and do a thorough inspection and assess the extent of damage, of if there even is any damage; once the ?loss of major system components? is determined, then the 24 hour clock begins today.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2
Exelon	No	<p>Attachment 1, Part A ? Energy Emergency requiring Public appeal for load reduction ? In the current draft Standard, the applicability has been revised from an RC and BA to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency." Suggest revising back to specific entities that would be likely responsible for this action (e.g., RC, BA, TOP). Attachment 1, Part A ? Energy Emergency requiring system-wide voltage reduction ? In the current draft Standard, the applicability has been revised from an RC, TO, TOP, and DP to "initiating entity." As a GO/GOP, I cannot see any event where a GO/GOP would be the responsible "initiating entity" or have the ability to determine an "Energy Emergency" related to system-wide voltage reduction. Suggest revising back to specific entities that would be likely responsible for this action.</p> <p>Attachment 1, Part A ? Voltage Deviations on BES facilities - A GOP may not be able to make the determination of a +/- 10% voltage deviation for ? 15 continuous minutes, this should be a TOP RC function only. Attachment 1, Part A ? Generation Loss of ? 2, 000 MW for a GOP does not provide a time threshold. If the 2, 000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? Suggest that a time threshold be added for clarity.</p> <p>Attachment 1, Part A ? Loss of off-site power (grid supply) affecting a nuclear generating station ? this event applicability should be removed in its entirety for a Nuclear Plant Generator Operator. The impact of loss of off-site power on a nuclear generation unit is dependent on the specific plant design, if it is a partial loss of off-site power (per the plant specific NPIRs) and may not result in a loss of generation (i.e., unit trip). If a loss of off-site power were to result in a unit trip, an Emergency Notification System (ENS) would be required to the Nuclear Regulatory Commission (NRC). Depending on the unit design, the notification to the NRC may be 1 hour, 8 hours or none at all. Consideration should be given to coordinating such reporting with existing required notifications to the NRC as to not duplicate effort or add unnecessary burden on the part of a Nuclear Plant Generator Operator during a potential transient on the unit. In addition, if the loss of off-site power were to result in a unit trip, if the impact to the BES were ?2,000 MW, then required notifications would be made in accordance with the threshold for reporting for Attachment 1, Part A ? Generation Loss. However, to align with the importance of ensuring nuclear plant safe operation and shutdown as implemented in NERC Standard NUC-001, if a transmission entity experiences an event</p>

Organization	Yes or No	Question 11 Comment
		<p>that causes an unplanned loss of off-site power (source) as defined in the applicable Nuclear Plant Interface Requirements, then the responsible transmission entity should report the event within 24 hours after occurrence. In addition, replace the words "grid supply" to "source" to ensure that notification occurs on an unplanned loss of one or multiple sources to a nuclear power plant. Suggest rewording as follows (including replacing the words "grid supply" to "source" and adding in the word "unplanned" to eliminate unnecessary reporting of planned maintenance activities in the table below):</p> <p>Event Entity with Reporting Responsibility Threshold for Reporting Time to Submit Report            Unplanned loss of off-site power to a Nuclear generating plant (source) as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) Each transmission entity responsible for providing services related to NPIRs (e.g., RC, BA, TO, TOP, TO, GO, GOP) that experiences the event causing an unplanned loss of off-site power (source) Unplanned loss of off-site power (source) to a Nuclear Power Plant as defined in the applicable NPIRs. Within 24 hours after occurrence</p> <p>Attachment 1, Part A ? Damage or destruction of BES equipment ? The event criteria is still ambiguous and does not provide clear guidance; specifically, the determination of the aggregate impact of damage may not be immediately understood ? it does not seem reasonable to expect that the 1 hour report time clock starts on identification of an occurrence. Suggest that the 1 hour report time clock begins following confirmation of event. ? The initiating event needs to explicitly state that it is a physical and not cyber. ? If the damage or destruction is related to a deliberate act, consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event (see additional comments in response to item 17 below).</p> <p>Attachment 1, Part A ? Damage or destruction of Critical Cyber Asset The events that are associated with Critical Cyber Assets should be removed from this Standard. Critical Cyber Asset related events are better addressed in the reporting of Cyber Security Incidents which is already included in Attachment 1, Part B and the CIP standards currently require details about Critical Cyber Assets to be protected with access to that information restricted to only specifically authorized personnel.</p> <p>Attachment 1, Part A ? Damage or destruction of Critical Asset The events that are associated with Critical Assets should be removed from this Standard. Critical Assets are typically whole control centers, substations or generation plants and the damage or destruction of individual pieces of equipment at one of these locations will usually not have much impact to the BES. Any important impacts located at these sites are already addressed in the other existing [Impact] Event types or would be addressed in the Cyber Security Incident event which is already included in Attachment 1, Part B. The CIP standards also currently require that details about Critical Assets and Critical Cyber Assets must be protected with access to that information restricted to only specifically authorized personnel. The identification of Critical Asset is also only an interim step used to identify the Critical Cyber Assets that need to have cyber security protections and the NERC Project 2008-06 CSO706 Standards Drafting Team is currently expecting to eliminate the requirement to identify Critical Assets in the draft revisions they are currently working on.</p> <p>Attachment 1, Part B ? Forced intrusion at a BES facility ? Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>potential security event (see additional comments in response to item 17 below).Attachment 1, Part B ? Risk to BES equipment from a non-environmental physical threat ? this event leaves the interpretation of what constitutes a "risk" with the reporting entity. Although the DSR SDT has provided some examples, there needs to be more specific criteria for this event as this threshold still remains ambiguous and will lead to difficulty in determining within 1 hour if a report is necessary. Consideration should also be given to coordinating such reporting with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security event (see additional comments in response to item 17 below).Attachment 1, Part B ? Detection of a reportable Cyber Security IncidentAlthough the DSR SDT agreed that there may be confusion between reporting requirements in this draft and the current CIP-008, "Cyber Security ? Incident Reporting and Response Planning", Part B now requires a 1 hour report after occurrence. The DSR SDT should verify the timing and reporting required for these Cyber Security Incident events is coordinated with the NERC Project 2008-06 CSO706 Standards Drafting Team.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received. The DSR SDT has worked closely with NERC Staff, the Event Analysis Working Group, Project 2008-06 and the U.S. Department of Energy to ensure that EOP-004-2 captures what FERC has directed and will improve the reliability of the BES.</p>		
SDG&E	No	<p>For ?Detection of a reportable Cyber Security Incident,? Attachment 1 identifies the threshold for reporting as: ?that meets the criteria in CIP-008 (or its successor)?; however, CIP-008 has no specified criteria, so this is an unusable threshold. Additionally, SDG&amp;E recommends that the timing of any follow-up and/or final reports required by the standard be listed in the Attachment 1 table.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> CIP-008 states that an entity will report a Cyber Security Incident to the ES-ISAC. EOP-004-2, Attachment 2 is the vehicle to report a Cyber Security Incident. It is also required to be sent to their RC which will give them the industry awareness of a single event or is it a multiple event within their area.</p>		
City of Tallahassee (TAL)	No	<p>One hour should be expanded. While I realize the importance of getting information to NERC/ESISAC/whoever, most of the 1-hour requirements are tied to events that may not be resolved within one hour. This will result in stopping restoration efforts or monitoring to submit paperwork. Calling in additional assistance, while certainly a possibility, may not be feasible to accomplish in sufficient time to meet the one-hour deadline. If any of these events were to truly have a detrimental effect on the BES, the effects would have already been felt.Recommend all 1-hour reports be extended to 4-hours. This should also be placed on the list to modify Form OE-417report time lines.</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received. The DOE Form OE-417 is not governed by NERC but the DSR SDT is proposing to allow an entity to use it to report an event in lieu of Attachment 2.</p>		
Lakeland Electric	No	<p>Event ? Transmission lossThreshold for Reporting ? Revise to ?Loss of three or more BES Transmission elements within a 15 minute period?. This change would capture a sequence of transmission element losses and remove the question if timing that will arise if other transmission elements trip, cascade, due to loss of the first element. There may also be a need for a footnote to clarify that a transmission element that is removed from service by a transmission operator to prevent uncontrolled cascading would be classified as a loss (something for the SDT to consider). Event ? Energy Emergency requiring Public appeal for load reductionThreshold for Reporting ? Add a footnote: Repeated public appeals for the same initiating Impact Event shall be reported as one Public Appeal Event. The initiation and release to the media of the Public appeal(s) should be the reportable event. Question: would an internal request to large industrial customers for voluntary load reductions be reportable under this Event?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received. Demand responsive load is not covered within this proposed Standard unless it fulfills a Threshold of Reporting within Attachment 1. Footnotes have been update to reflect comments received.</p>		
Arkansas Electric Cooperative Corporation	No	<p>We appreciate the effort the team has taken in improving the requirements since the last posting. Event Forced Intrusion: The timeframe is very small given the possibly minimal risk to the BES. It often takes much longer than 1 hour after verification of intrusion to determine the intrusion was only for copper theft. We suggest a 24 hour time frame or tie the timeframe to the "verification of forced intrusion."</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Manitoba Hydro	No	<p>Reporting for CCA's should be limited to damage associated with a detected cyber security incident.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Damage or destruction of Critical Cyber Assets s is per CIP-002 and may not fall into the category of Cyber Security Response as outlined by an entity.</p>		
Sweeny Cogeneration LP	No	<p>In Attachment 1, Part A, Generator Operators who experience a ? 10% sustained voltage deviation for ? 15</p>



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		continuous must issue a report For externally driven events, the GOP will have little if any knowledge of the cause or remedies taken to address it. We believe the language presently in EOP-004-1 is satisfactory that any ?action taken by a Generator Operator? that results in a voltage deviation has to be reported by the GOP.
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
American Electric Power	No	<p>The time to submit a report for the inclusion of the damage or destruction of BES equipment, critical asset, or critical cyber asset is too aggressive. The critical cyber asset reporting is redundant with CIP-008. Furthermore, reporting equipment failures within an hour for Critical Assets is going to overwhelm operators that need to focus on the restoration efforts. Self-evident equipment failures at a Critical Asset (such as a tube leak at a generator which is a Critical Asset) should not be required to be reported. Maybe the wording should be stated as an ?abnormal occurrence? rather than ?equipment failure.?It would be helpful if there was a defining or a footnote that defines the nature and/or duration for loss of some equipment. For example, is a transmission loss for sustain or momentary outages?</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The Implementation Plan for this project now includes a provision to retire the requirement in CIP-008 for reporting (Requirement 1, Part 1.3). The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
USACE	No	The "Potential Reliability Impact" table should be taken out. Referred to previous comment on our position on potential impacts.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT believes that potential events are required to be reported to provide industry awareness.</p>		
Consumers Energy	No	<p>1. In reference to the Impact Event addressing ?Loss of Firm load for greater than or equal to 15 minutes?, this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to ?Within 1 hour after detection of exceeding 15-minute threshold?. Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES.2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting ?Within 1 hour after occurrence is identified? possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the ?time to submit?3. Referring to the</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>?Transmission Loss? Impact Event, please provide more specificity. Is this intended to address :- anytime that three or more BES Transmission Elements are out of service, - only when three or more BES Transmission Elements are concurrently out-of-service due to unscheduled events, - only when three or more BES Transmission Elements are simultaneously automatically forced out-of-service, or- only when three or more BES Transmission Elements are forced from service in some proximity to each other? It is not unusual, for a large transmission system, that this many elements may be concurrently forced out-of-service at widely-separated locations for independent reasons.4. Referring to the ?Fuel Supply Emergency? Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.5. For that matter, the SDT should carefully compare the Impact Event Table with OE-417. Where similar Impact Events are listed, consistent terminology should be used, and identical reporting periods specified. Where the Impact Event Table contains additional events, they should be clarified as being distinct from OE-417 to assist entities in implementation. Further, since OE-417 must be reviewed and updated every three years, EOP-004 should defer to the reporting time constraints within OE-417 wherever listed in order to assure that conflicting reporting requirements are not imposed.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed ' Loss of Firm Load' as a reporting event, and believe the reporting requirement currently approved in EOP-004-1 should remain in EOP-004-2. The DSR SDT has removed the 'Fuel Supply Emergencies' event after considering comments the DSR SDT received on this event. The DOE Form OE-417 is reviewed biennially by the DOE and can be updated or changed without NERC's involvement. The DSR SDT has taken into consideration the use of Form O- 417 to report events to NERC and agrees that this will fulfill EOP-004-2's reporting requirements. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Independent Electricity System Operator	No	As indicated under Q4, we question the need to include IA, TSP and LSE in the responsible entities for reporting.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has established that CIP-002-4 and CIP-008-3 are applicable to an IA, TSP, and LSE. These entities will report a Cyber Security Incident per Attachment 2 (or OE-417) as the vehicle to inform the ERO, their Regional Entity and their Reliability Coordinator.</p>		
Ameren	No	See response to question 4.
<p><b>Response: The DSR DT thanks you for your comment.</b> Please see question 4 response.</p>		
ISO New England, Inc	No	As indicated under Q4, we question the need to include IA, TSP and LSE in the responsible entities for reporting. There is still significant duplicate reporting included. For instance, why do both the RC and TOP to report voltage deviations? As written, a voltage deviation on the BES would require both to report. The same

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>would hold true for IROLs. Perhaps IROLs should only be reported by the RC to be consistent with the recently FERC approved Interconnection Reliability Operating Limit standards. Also, the CIP reporting requirements duplicate was is already contained in the CIP Standards, specifically CIP-008. Also, we are required to intentionally destroy Critical Cyber Assets when they are retired, why would we be required to report this?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has established that CIP-002-3 and CIP-008-3 are applicable to an IA, TSP, and LSE. These entities will report a Cyber Security Incident per Attachment 2 (or OE-417) as the vehicle to inform the ERO, their Regional Entity and their Reliability Coordinator. If a Critical Cyber Asset (CCA) was to be retired, the entity would declassify it as a CCA and therefore it would not be required to be reported. The Implementation Plan for this project now includes a provision to retire the requirement in CIP-008 for reporting (Requirement 1, Part 1.3)</p>		
Calpine Corp	No	<p>1. Additional clarity on the nature of reportable ?Fuel Emergencies? is needed. Does loss of interruptible gas transportation require reporting? 2. Additional clarity on the threshold for ?damage or destruction of BES equipment? is needed. Footnote 1 on page 16 states, in part ?Significantly affects the reliability margin of the system (e.g. has the potential to result the need for emergency actions?. For generating facilities, does this statement refer specifically to the parallel requirement to report any loss of generation &gt;= 2,000 in the Eastern or Western Connection or &gt;= 1,000 in the ERCOT or Quebec Interconnection? If not, exactly what level of damage at a generating plant requires reporting? Use of imprecise terms such as ?significantly? sets the stage for future compliance and enforcement confusion.3. Additional clarity is required for ?Detection of reportable Cyber Security Incident.” Is this item intended to apply only to Critical Cyber Assets, or is it an extension of the requirement to all applicable entities irrespective of their Critical Asset status? If it applies only to Critical Cyber Assets, does this reporting requirement create redundant reporting (as reporting is already required under CIP-008-4)? CIP-008-4 requires reporting only of events affecting Critical Cyber Assets. If a more expansive application is intended, what equipment or systems are to be included in the reporting requirement?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The event of Fuel Supply Emergencies has been removed per comments the DSR SDT received. The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. Damage to BES equipment’s foot note has been enhanced to mean that the BES piece of equipment is required to be removed from service. CIP-008 states that an entity will report a Cyber Security Incident to the ES-ISAC. EOP-004-2, Attachment 2 is the vehicle to report a Cyber Security Incident.</p>		
BGE	No	<p>For the following Events (Damage or destruction of BES equipment, Damage of destruction of Critical Asset, and Damage or destruction of a Critical Cyber Asset), submitting a report within 1 hour after occurrence is identified is too short of a time frame. Generally, the initial time period is spent in recovering from the situation and restoring either electric service or restoring computer services to assure proper operations. To</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>distract from the restoration to normal activities to focus on a report would be detrimental to reliability. Notification of an event may perhaps be made by phone call within 1 hour but completing a report should be required no less than 6 or 12 hours. Determining a cause (especially external or intentional) could take longer than 1 hour to determine and complete a report. It is important to consider the imposition created by a compliance obligation and weigh it against the other demands before the operator at that time. A compliance obligation should avoid becoming a distraction from reliability related work. Under impact event type scenarios, in the first hour of the event, the primary concern should be coping with/resolving the event.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. Damage to BES equipment's foot note has been enhanced to mean that the BES piece of equipment is required to be removed from service.</p>		
Alliant Energy	No	<p>The item relating to Loss of Firm Load for &gt; 15 minutes should be revised to 500 MW and 300 MW. For many companies, a storm moving across their system could cause more than 300 MW of firm load to be lost, but there is no impact on the BES, so why does the detailed reporting need to be done? The items relating to ?damage or destruction? need to be revised to not be so wide. As currently written, a plan by a company to raze a facility could be considered a violation and must be reported. We believe it needs to be tightened to malicious intent or human negligence/error.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed Loss of Firm load and believe the reporting requirement presented approved in EOP-004-1 is substantial and should remain within EOP-004-2. If a Critical Cyber Asset (CCA) was to be retired, the entity would declassify it as a CCA and therefore it would not be required to be reported.</p>		
CenterPoint Energy	No	<p>(1) CenterPoint Energy believes that the ?Entity with Reporting Responsibility? for the first three events in Part A should be clarified. There could still be confusion regarding the ?initiating entity? for events where one entity directs another to take action. From the text on page 5 of the Unofficial Comment Form, it appears that the SDT intended for the ?initiating entity? to be the entity that takes action. To make this clear in Attachment 1, CenterPoint Energy recommends replacing ?initiating entity? with ?Each (insert applicable entities) that (insert action). For example, for ?Energy Emergency requiring a Public appeal? the Entity with Reporting Responsibility should be ?Each?that issues a public appeal for load reduction?. (2) Part A: The threshold for reporting ?System Separation? should not be fixed at greater than or equal to 100 MW for all entities, but rather should be scaled to previous year's demand as in ?Loss of Firm load for greater than or equal to 15 minutes?, so that for entities with demand greater than or equal to 3000 MW, the island would be greater than or equal to 300MW. (3) Part A: The one hour reporting requirements are unreasonable and burdensome. The Background text indicates that ?proposed changes do not include any real-time operating notifications?? CenterPoint Energy believes all one hour reporting requirements could potentially divert resources away from</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>responding to the event. In many instances the event may still be developing within one hour. Likewise, the 24 hour reporting requirements are also burdensome. CenterPoint Energy recommends changing all reporting requirements to 48 hours. CenterPoint Energy acknowledges that the DOE OE-417 report requires certain one hour and 6 hour reporting. Those requirements should also be extended, and CenterPoint Energy will be making the same recommendation during the DOE OE-417 report revision process when the current form expires on 12/31/11.(4) Part B: CenterPoint Energy is very concerned with the ?events? listed under Attachment 1 ? Potential Reliability Impact ? Part B and believes Part B should be deleted. These arbitrary ?events? with ?potential reliability impact? and reporting times place unnecessary burden on entities to report ?situations? that would rarely impact the reliability of the BES. Entities should be aware of developing situations; however, this standard should not require reporting of such occurrences.(5) Part B: Of particular concern is the overly broad ?Risk to BES equipment? and the example provided in the footnote. CenterPoint Energy believes the SDT has already identified the events with the greatest risk to impact the BES in Part A. Also including ?potential reliability impact? situations in Part B inappropriately dilutes attention away from the truly important events. The industry, NERC and FERC should not lose sight of the forest for the trees.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received. The DOE Form OE-417 is under review by the DOE and can be updated or changed without NERC’s involvement. The DSR SDT has taken into consideration the use of OE-417 to report events to NERC and agrees that this will fulfill EOP-004-2’s reporting requirements.</p>		
ExxonMobil Research and Engineering	No	<p>The notification requirement and documentation in Attachment 1 do not clearly identify which entities need to be notified for each type of event detailed in Attachment 1. While it makes sense to notify the Reliability Coordinator, NERC, Regional Entity, Law Enforcement and other Governmental Agencies for sabotage type events, it does not seem proper to notify Law Enforcement agencies of a system disturbance that is unrelated to improper human intervention. Furthermore, it is our belief that a time frame of 1 hour is a short window for making a verbal notification to third parties, and an impossibly short window for requiring the submittal of a completed form regardless of the simplicity. When a Petrochemical Facility experiences an impact event, the initial focus should emphasize safe control of the chemical process. For those cases where registered entities are required to submit a form within 1 hour, the Standard Drafting Team should alter the requirement to allow for verbal notification during the first few hours following the initiation of an Impact Event (i.e. allow the facility time to appropriately respond to and gain control of the situation prior to making a notification which may take several hours) and provide separate notifications windows for those parties that will need to respond to an Impact Event immediately and those entities that need to be informed that one occurred for the purposes of investigating the cause of and response to an Impact Event. For example, a GOP should immediately notify a TOP when it experiences a forced outage of generation capacity as soon as possible, but there is no immediate benefit to notify NERC when site personnel are responding to the event in order to gain control of of the situation and determine the extent of the problem. The existing standard’s</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>requirement to file an initial report to entities, such as NERC, within 24 hours seems reasonable provided that proper real time notifications are made and the Standard Drafting Team reinstates EOP-004 Revision 1's Requirement 3.3, which allows for the extension of the 24 hour window during adverse conditions, into the requirement section of EOP-004 [the current revision locates this extension in Attachment 1, which, according to input received from Regional Entities, means that the extension would not be enforceable].</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received.</p>		
PPL Electric Utilities	No	<p>We very much appreciate the work performed by SDT and consideration of all the comments received. While we agree with the majority of the Attachment 1 changes, we suggest the SDT add further clarification to Attachment 1, Part A, Event 'Transmission Loss'. Does this mean permanent loss? Do two lines and a pole constitute a loss of three elements? E.g. Consider the loss of a 230 kV line with two tapped transformers. This does not have a significant effect on the BES, yet would it be reportable? We would prefer Attachment 1, Part A, 'Threshold Reporting' be clarified. E.g. 'Three or more "unrelated" pieces of equipment for a single event'.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes in Attachment 1 have been updated to reflect the comments that the DSR SDT received.</p>		
Lincoln Electric System	No	<p>While LES supports the bright line criteria listed in Attachment 1 for reporting Impact Events, we have concerns regarding the reporting threshold for 'Transmission loss'. For Transmission loss of three or more Transmission Elements, LES supports the MRO NSRS' suggested wording of 'Two or more BES Transmission Elements that exceed TPL Category D operating criteria or its successor.'</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
American Transmission Company	No	<p>Energy Emergency requiring Public Appeal ATC believes that the phrase 'initiating entity' is unclear and could be interpreted in multiple ways. 1) the entity has the authority to call for public appeals, 2) the entity has the authority to declare an Energy Emergency, or 3) the entity determines and identifies the need for the Energy Emergency Typically the BA's call for public appeals, so does every BA that calls for the public appeal have to make a filing? The RC declares the need for an Energy Emergency, so are they the initiating entity? A TOP could also identify the need for public appeals and notify the RC about the request. In this case, is the TOP the initiating entity? Given the above examples, ATC believes that the SDT needs to clarify who is required to make the filing. Voltage Deviations on BES Facilities ATC believes that this should be clarified because one may assume that a loss of a single bus in which voltage goes to zero for more than 15 minutes</p>

Organization	Yes or No	Question 11 Comment
		<p>is reportable. It is ATC understands that what the SDT means is a voltage dip, not an outage to a BES facility. However, given the brief description, ATC is not 100% sure whether there is a clear understanding of the standard's intent. Energy Emergency resulting in automatic firm load shedding Please provide additional clarify. ATC believes that the SDT should not use the term "Impact Event" when identifying the entity with reporting responsibility. The term "Impact Event" is identified in the standard and points to Attachment 1 but now is being used outside of that context and requires entities to interpret what qualifies as an Impact Event. The above observation also applies to those other events that use the term "Impact Event" to describe Reporting Responsibility. Footnote 1: ATC would like the phrase "as determined by the equipment owner" added to the footnote. This simple phrase will allow entities to be sure that they are responsible for determining if the damage significantly affects the reliability margin of the system. Without this phrase, entities could be subject to non-compliance actions based on differences of opinions to the extent of the damage on the system. The other option the SDT has is to provide additional clarity on what qualifies as a significant affect. Time to Submit Report: ATC strongly disagrees with the 1 hour time to submit a report because it does not fit with the purpose of this standard. The purpose of this standard is to increase awareness, however, requiring a one-hour reporting window following the event provides little to no benefit. ATC believes that these events should have a 24 hour reporting window which allows for a reasonable amount of time to gather information and report the issue. If the SDT disagrees with this observation, ATC believes a complete explanation should be provided on why knowledge of an event within an hour is significantly better than having the knowledge of the event in a 24 hour time period. ATC strongly believes that NERC will gain as much or more knowledge of the event by giving entities time to understand the event and report.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
Duke Energy	No	<p>" Attachment 1 contains three reportable events (Damage or destruction of Critical Asset, Damage or destruction of a Critical Cyber Asset, and Detection of a reportable Cyber Security Incident) that overlap with CIP-008-3 Cyber Security Incident Reporting and Response Planning and could result in redundant or conflicting content between the two standards. We propose either of the following options: 1. Remove the requirement for reporting these events from EOP-004-2 and add the timing and reporting requirements into CIP-008-3, R1.3. "Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary." OR 2. Replace the reporting requirement in CIP-008-3, R1.3. with a reference to report as required in EOP-004-2." Also, as noted in our comment to Question #4 above, the Attachment 1 Section "Entity with Reporting Responsibility" should just identify "Initiating entity" for every Event, as was done with the first three Events. That way you avoid errors in leaving an entity off, or including an entity incorrectly (as was done with the GOP on Voltage Deviations). We note that LSE is listed in the standard as an Applicable entity, and should be included in Attachment 1.</p>

Organization	Yes or No	Question 11 Comment
		<p>Our suggestion would handle this oversight. We also note that CIP-001 does not include Distribution Provider in the list of applicable entities, but EOP-004-2 does include the DP.? We reiterate our comment to Question #1 above that the DSR SDT statement that the proposed changes do not include any real-time operating notifications is inconsistent with requiring notification within one hour for thirteen of the twenty listed Events in Attachment 1.? The last six events refer to the entity that experiences the potential Impact Event. We believe that the word ?potential? should be struck, as this creates an impossibly broad reporting requirement.? Footnote 1 should be revised to strike the phrase ?has the potential to? from the parenthetical, as this creates an impossibly broad reporting requirement.? The Impact Event ?Risk to BES equipment? should be revised to ?Risk to BES equipment that results in the need for emergency actions?. The accompanying footnote 4 should be revised to read as follows: Examples could include a train derailment adjacent to BES equipment (e.g. flammable or toxic cargo that would cause the evacuation of a BES facility control center), or a report of a suspicious device near BES equipment.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The entire Attachment 1 has been updated to reflect the comments that were received. CIP-008 states that an entity will report a Cyber Security Incident to the ES-ISAC. EOP-004-2, Attachment 2 is the vehicle to report a Cyber Security Incident. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the ERO and others with a different view of what has happened. The DSR SDT understands that there may be multiple reports (for certain events) that are required by different government agencies. NERC will continue to streamline the reporting process as we move into the future.</p>		
Constellation Power Generation	No	<p>CPG has the following concerns regarding Attachment 1: ?Real-Time - On page 5 of the proposed standard, the team noted that ?the proposed changes do not include any real-time operating notifications.? However, several events in Attachment 1 require that documentation be completed and submitted to the ERO within 1 hour. For generation sites that are unmanned, or only have 1 to 2 operators on site at all times, a 1 hour requirement is not only onerous but is essentially ?real time.??Response within 1 hour - It is important to consider the imposition created by a compliance obligation and weigh it against the other demands before the operator at that time. A compliance obligation should avoid becoming a distraction from reliability related work. Under impact event type scenarios, in the first hour of the event, the primary concern should be coping with/resolving the event. Other notification requirements exists based on required agency response relative to the concern at hand (e.g. public evacuations, fire assistance, etc.) Notification within an hour under EOP-004 does not appear to represent a relevant benefit to resolving the situation and the potential cost would be borne by reliability and recovery efforts. Anything performed within the first hour of the event must be to benefit the public or benefit the restoration of power.?Damage or destruction of BES equipment ? the reporting requirement of 1 hour is extremely onerous. A good example is the failure of a major piece of equipment at a remote combustion turbine generation site. Combustion turbine generation sites are not usually manned with many people. If a failure of a major piece of equipment were to occur, the few people on site need to complete communications to affected entities, communications to their management, as well as</p>



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>emergency switching and ensuring that no other pieces of equipment are effected or harmed. There is little time to complete a form in 1 hour. This should be changed to 48 hours. The form is also inadequate for this type of event.     o Using the example above of a failure of a major piece of equipment, CPG is not sure if it's reportable per Attachment 1, which further proves that Attachment 1 is not clear. Per the footnote regarding damage to BES equipment, the failure would not be reportable, as it does not affect IROL, given the information at the plant it does not significantly affect the reliability margin of the system, and was not damaged or destroyed due to intentional or unintentional human action. However, it would be reportable per the table as the table states "equipment failure" and "external cause." Clarification is needed. "Damage or destruction of Critical Asset" This item should be removed or significantly refined. For generation assets, a critical asset is essentially the entire plant, so in many cases the information reported at this level would not be useful if the valuable details reside at the equipment level. If it is not removed, then see the notes above on the 1 hour requirement for the completion of the form. "Fuel supply emergency" 1 hour for reporting the document is unreasonable. See the earlier notes. "Risk to BES equipment" "From a non-environmental physical threat" This item is too vague and subjective. A catch all category to capture a broad list of potential risks is problematic for entities to manage in their compliance programs and to audit. This should be removed.</p>
<p><b>Response: The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</b></p>		
<p>Georgia System Operations Corporation</p>	<p>No</p>	<p>Energy Emergency requiring public appeal for load reduction:-The NERC Glossary defines "Energy Emergency" as a "condition when a Load-Serving Entity has exhausted all other options and can no longer provide its customers' expected energy requirements." Per EOP-002, an Energy Emergency Alert may be initiated by the RC upon RC sole discretion, upon BA request, or upon LSE request.-Question: Is it intended that the LSE reports the event if the LSE requests an alert, the BA reports the event if the BA requests an alert, and the RC reports it if it is a RC sole discretion decision? What if an alert is not initiated? Is it an Energy Emergency? Is it an impact event? Who must initiate the public appeal? Since it must be reported within a certain time after the issuance of the public appeal, is it not an impact event until after the initiation of the public appeal (which should be after the initiation of the alert)? Shouldn't the reporting of the impact event be done by the initiator of the public appeal? The event should probably be the public appeal and not the Energy Emergency.-"Public" should not be capitalized.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained." Energy Emergency requiring system-wide voltage reduction: See Energy Emergency requiring public appeal for load reduction above regarding requesting Energy Emergency Alerts. If this event is to be reported within a certain time after "the event", at what time is the event marked? Or is it within a certain time after the initiation of the voltage reduction and, if so, shouldn't the reporting of the impact event be done by the initiator of the voltage reduction? The event should probably be the system-wide voltage reduction and not the Energy Emergency. The reliability objective</p>

Organization	Yes or No	Question 11 Comment
		<p>of this standard is not achieved by NERC knowing of this within 1 hour and NERC does not need to know this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Energy Emergency requiring manual firm load shedding:-See Energy Emergency requiring public appeal for load reduction above regarding requesting Energy Emergency Alerts. If this event is to be reported within a certain time after the event?, at what time is the event marked? Or is it a certain time after the initiation of the shedding of load, if so, shouldn't the reporting of the impact event be done by the initiator of the shedding of the load? If the RC directs a BA to shed load, then the BA directs a DP to do it, then the DP sheds the load, who is the initiator of the load shedding? The event should probably be the firm load shedding and not the Energy Emergency.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Energy Emergency resulting in automatic firm load shedding:Whenever load is automatically shed both the DP and the TOP experience the event. So does the BA and the LSE. This event includes or between DP and TOP.? Is that intentional? Other events in the table do not include either an and or an or.? The entities are separated only by commas. NERC should not require multiple entities to report the same event. See comment for R5 above. If a DP "experiences" an automatic load shedding doesn't the TOP also experience it? Both should not report the same event.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Voltage deviations on BES Facilities:-Should GOs/GOPs be required instead to report to BAs when this condition exists with the BA then reporting to NERC? The idea of a deviation "on BES Facilities" is not clear. On any one Facility? On all Facilities in an area? How wide of an area? Voltage Deviation is not proper noun/name and is not defined in the NERC Glossary. It should not be capitalized. IROL violation: Multiple entities should not report the same event. Please define IROL Violation or use lowercase. It is assumed that IROL Violation means operation outside the IROL for a time greater than IROL TV. Loss of firm load for 15 minutes:-Multiple entities should not report the same event. The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Firm Demand is defined but not Firm load. System separation (islanding):-Multiple entities should not report the same event. A DP separating from the transmission system should not be a reportable event for a DP in and of itself. If it leads to a sufficient loss of load, it is reportable as above.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. The words separation and islanding should not be capitalized. Generation loss:-Should GOs/GOPs be required instead to report to BAs when their generation is lost with the BA then reporting to NERC when the total is 2,000 MW? A loss of generation should be clarified. Is the discovery of damaged equipment in an offline plant which makes the plant unavailable for an extended period of time a loss of generation?-It should be clarified if this event means the concurrent loss of the generation or losing the generation non-concurrently</p>

Organization	Yes or No	Question 11 Comment
		<p>but they are concurrently unavailable. What is the time window for losing the generation? Lost within seconds of each other? Minutes? Hours? Loss of off-site power to a nuclear generating plant (grid supply):-Multiple entities should not report the same event.-?Off? should be lowercase. Transmission loss:-RCs should not be required to report the loss of transmission elements to NERC. A ?loss? of a BES Transmission Element should be clarified. It should be clarified if this event means the concurrent loss of elements or the non-concurrent loss of the elements but they are concurrently unavailable. What is the time window for losing the elements? When elements are lost, it will be difficult to differentiate if they are BES Transmission Elements or not. Alarms don't immediately identify this. It could lead to gross over-reporting if no distinction is made by a TOP and the TOP reports all losses of 3 elements. It may still be over-reporting (from a reasonableness/practicality basis) even if the differentiation could be easily made and only BES Transmission Elements are reported. Threshold for reporting Transmission Loss: As stated, this will require the reporting of almost all transmission outages. This is particularly true taking into consideration the current work of the drafting team to define the Bulk Electric System. The loss of a single 115kV network line could meet the threshold for reporting as the definition of Element includes both the line itself and the circuit breakers. Instead, we recommend the following threshold "Three or more BES Transmission lines." This threshold has consistency with CIP-002-4 and draft PRC-002-2. This threshold also needs additional clarification as to the timeframe involved. Is the intent the reporting of the loss of 3 or more BES Transmission Elements anytime within a 24 hour period or must they be lost simultaneously? Also, we recommend that the three losses be the result of a related event to require reporting. Damage or destruction of BES equipment that i. affects an IROL; ii. significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); or iii. damaged or destroyed due to intentional or unintentional human action (Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly, e.g., removal of grounding straps rendering protective relaying inoperative.): -What is ?BES equipment?? Would an operator know which equipment is BES equipment and which is not or which BES equipment affects an IROL (if we had one) or which does not? It is a judgment call as to whether the effect was significant or not or if it has the potential or not. Multiple entities should not report the same event. Unplanned control center evacuation:-?Control Center? should be lowercase.-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Fuel supply emergency: Multiple entities should not report the same event. Should GOs/GOPs be required instead to report to BAs when they have a fuel supply emergency with the BA then reporting to NERC if the situation is projected to require emergency action at the BA level?-The reliability objective of this standard is not achieved by NERC knowing of this within 1 hour and the need for NERC to know this within 1 hour to meet its objective of analyzing events has not been justified or explained. Loss of all monitoring or voice communication capability (affecting a BES control center for ? 30 minutes):-Does this event mean that ALL capability at both the primary and backup control centers or just one? Forced intrusion at a BES facility (report if you cannot reasonably determine likely motivation, i.e., intrusion to steal copper or spray graffiti is not reportable unless it affects (affects ? not effects) the reliability</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 11 Comment
		<p>of the BES):-What is a ?BES facility?? It is not clear for the purposes of complying with this standard what it means to affect the reliability of the BES. Deferred for ECMS review and additional comments.Risk to BES equipment (examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment, e.g., flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center, and report of suspicious device near BES equipment.): -In the footnote, delete ?could have? from ??either could have damaged?? Something that could cause evacuation of a control center does not pose a risk to damaging BES equipment. The threshold is ?from a non-environmental physical threat? but the example (toxic cargo) IS an environmental threat.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received. The DSR SDT reviewed the term 'Energy Emergency' and has removed it from Attachment 1.</p>		
<p>City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power</p>	<p>No</p>	<p>The one hour reporting timeline is unrealistic for this event. In general it looks like other events requiring the 1 hour reporting timeline are for event that are ?initiated? by the system operator. (ie load shedding, public load reduction, EEP?). Loss of BES equipment is in general 24 hour reporting timeline. It should be, ?as soon as possible but within 24 hours."</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
<p>Indeck Energy Services</p>	<p>No</p>	<p>Comments were included in previous comments.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
<p>BC Hydro</p>		<p>For the change from 24hr to 1hr reporting for events, 1 hour goes extremely quickly in these types of events and it will be difficult to report anything meaningful. As the RC is kept informed during the event why is the report required within 1hr?</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received. EOP-004-2 is an after the fact reporting Standard. The entity experiencing an event is required to inform their RC per other NERC Standards.</p>		
<p>Brazos Electric Power Cooperative</p>	<p>No</p>	<p>Question applicability to DP.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has reviewed and updated the entities that need to report an event. Some have been reduced to a single entity where others have multiple entities. These multiple entities will have different views of the event, and will be able to provide the</p>		

Organization	Yes or No	Question 11 Comment
<p>ERO and others with a different view of what has happened. The entire Attachment 1 has been updated to reflect the comments that were received.</p>		
<p>Progress Energy</p>	<p>No</p>	<p>Progress Energy appreciates the effort of the Standard Drafting Team, but we do have some issues with the content of Attachment 1. The loss of three Transmission Elements can occur with a single transmission line outage. Progress is concerned that the possible frequency of this type of reporting could be an extreme burden. Under the column "Entity with Reporting Responsibility," why do all related entities have to report the same event? (i.e. do the RC and the TOP in the RC footprint both have to report an event, or is it either/or? The word "Each" implies separate reports. What is the Reliability-based need for both an RC and the BA/TOP/GO within the footprint to file the same report for the same event?) For vertically integrated companies it should be clear that only one report is required per Impact Event that will cover the reporting requirements for all registered entities within that company. The "damage or destruction of BES equipment" footnote contains the language "Significantly affects the reliability margin?." The word significantly should not be used in a Standard because it is subjective. Reliability margin is also undefined. System Operators must be trained on how to comply with the Standard, and thus objective criteria must be developed for reporting. "1 hour after occurrence" places a burden on System Operators for reporting when response to and information gathering dealing with the Impact Event may still be occurring. There is a note that states that the timing guidelines may not be met "under certain conditions?" but then requires a call to both its Regional Entity and notification to NERC. The focus should be on the event response and this type of reporting should occur "within an hour or as soon as practical." It is unclear what the voltage deviations of +-10% based on (i.e. is that +-10% of nominal voltage? This may require new alarm set-points to be placed in service in Energy Management Systems in order for entities to be able to prove in an audit that they reported all occurrences of voltage exceeding the 10% limit for 15 minutes or more. It has been stated by Regional Entity audit and enforcement personnel that attestations cannot be used to "prove the positive.") The word "potential" should be removed from Attachment 1 and from the definition of Impact Event. An event is either an Impact Event or not. If an entity has to evacuate its control center facility temporarily for a small fire, or any other such minor occurrence, then it activates its EOP-008 compliant backup control center, and there is no impact to reliability, then why does there need to be a report generated? The "Forced Intrusion" category is problematic. The footnote 3 states: "Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects (sic) the reliability of the BES)." "Reasonably determine likely motivation" makes this subjective. If someone breaks into a BES substation fence to steal copper, is interrupted and leaves, then entity personnel determine someone tried to break into the substation, but cannot determine why, then this table requires a report to be filed within an hour. It is unclear what the purpose of such a report would be. Progress agrees that multiple reports in a short time across multiple entities may indicate a larger issue.</p>
<p>Response: The DSR DT thanks you for your comment. The entire Attachment 1 has been updated to reflect the comments that were received. Footnotes</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 11 Comment
have been updated per comments received.		
Liberty Electric Power LLC	Yes	A qualified yes here - please clarify footnote 1 to the table. Are the listed qualifications "and" or "or" statements -IOW, if destruction of BES equipment through human error does not have the potential to result in the need for emergency actions, is it still reportable? If a 18-240 KV step-up transformer suffers minor damage because a conservator tank was valved out, is this reportable under this definition?
<p><b>Response: The DSR DT thanks you for your comment.</b> Footnotes have been update to reflect comments received. This proposed Standard is targeted at BES level Thresholds for Reporting as outlined in Attachment 1.</p>		
Ingleside Cogeneration LP	Yes	We believe that there should be close, if not perfect, synchronization between the ERO?s Event Analysis Process and Attachment 1 since they share the same ultimate goal as EOP-004-2 to improve industry awareness and BES reliability.
<p><b>Response: The DSR DT thanks you for your comment.</b> EOP-004-2 is an after the fact reporting Standard and the reports submitted by entities complying with the standard may be used by the NERC Event Analysis Program to review reported events. The Event Analysis Program may change their categories of events at anytime, but revisions to an approved standard must follow the standards development process embodied in the NERC Standard Processes Manual. Despite the differences in process, the DSR SDT is working closely with the Event Analysis Working Group to ensure alignment between the standard and the program to the maximum extent possible.</p>		
Occidental Power Marketing	Yes	There does not appear to be any reportable events for LSEs that do not own, operate, or control BES assets (or assets that directly support the BES) in Attachment 1. This would support removing such entities from the Applicability.
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT understands that every LSE may not own or operate BES assets. If of the LSE does not own or operate BES assets, then EOP-004-2 would not be applicable to that LSE. Since CIP-002 and CIP-008 are applicable to LSEs they will be required to be applicable under EOP-004-2 for cyber incidents.</p>		
Farmington Electric Utility System	Yes	
Platte River Power Authority	Yes	
New Harquahala Generating Co.	Yes	
Western Electricity Coordinating	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 11 Comment
Council		
Midwest ISO Standards Collaborators	Yes	
Southern Company	Yes	
SRP	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
American Municipal Power	Yes	

**12. Do you agree with the proposed measures for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of commenters agree with the proposed measures. Since two requirements were removed, the DSR SDT did a complete review of the Requirements and associated Measure and assured that Measurements did not add to any Requirement. The Measures have been rewritten to reflect strict accuracy to each Requirement and provide a minimum measure required for an entity to be compliant.

Organization	Yes or No	Question 12 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation	No	Several of the measures appear to introduce items that are not required by the standard. For instance, R3 requires that a test of the communications process be performed, however Measure 3 indicates that a mock impact event be performed. Measure 4 indicates that personnel be listed in the plan and be trained on the plan, however there is no requirement to include people in the plan or to train them.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Northeast Power Coordinating Council	No	Concerns with M5:a. As suggested in the response to Question 10 above, R5 should be combined with R2; b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to support the type of Impact Event experienced?. Also, the date and time of the Impact Event is provided in the reporting form. Why the need to provide additional evidence on the date and time of the Impact Event?
<p><b>Response:</b> The DSR SDT thanks you for your comment. Requirement 2 has been deleted as requested by the industry. Requirement R5 (now R2) was revised along with the measure:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 12 Comment
stamped transmittal records to show that the event was reported.		
Pacific Northwest Small Public Power Utility Comment Group	No	It is unclear when reporting to the Compliance Enforcement Authority is required. Does the registered entity report initially, and then anytime a change to the plan is made, or a drill is performed. Or is the information only provided following a request of the Compliance Enforcement Authority, and if so what is the acceptable time limit to respond?
<b>Response:</b> The DSR SDT thanks you for your comment. The Measure is designed to inform applicable entities of the minimum acceptable evidence needed to prove compliance with a requirement. The reference to Compliance Enforcement Authority has been removed since it does not assist an entity in the minimum level of evidence needed per the requirement.		
Dominion	No	1) M1 is open ended. Suggest adding ?on request? to the end of the sentence as written; 2) M4 requires evidence of ?when internal personnel were trained; however, Requirement R4 does not require training.
<b>Response:</b> The DSR SDT thanks you for your comment. The Measure is designed to inform applicable entities of the minimum acceptable evidence needed to prove compliance with a requirement. The reference to Compliance Enforcement Authority has been removed since it does not assist an entity in the minimum level of evidence needed per the requirement.		
SPP Standards Review Group	No	The measures are written as if they are adding requirements to the standards. Using wording such as ?shall provide? gives this implication. We would suggest wording such as ?examples of acceptable evidence to demonstrate compliance may be??See Question 6 for comments regarding M1. See Question 8 for comments regarding M3.
<b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.		
Midwest ISO Standards Collaborators	No	We disagree with Measurement 4. It implies that the review must be conducted in person. Why could other means such as a web training or a reminder memo not satisfy the requirement? Because Requirement 1 does not require submittal of the Operating Plan, Operating Process and/or the Operating Procedure, Measurement 1 should only require submittal to the Compliance Enforcement Authority upon its request.
<b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement 4 has been deleted.		
FirstEnergy	No	Measure M4 includes the phrase ?when internal personnel were trained on the responsibilities in the plan? implies the Requirement R4 requires training. R4 is only requiring the review of a document of the necessary

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 12 Comment
		<p>personnel and that the rest of the measure covers the needed evidence for R4. This phrase in the measure should be removed. We suggest the following for M4:M4. Responsible Entities shall provide the materials presented to verify content and the association between the people listed in the plan and those who participated in the review, documentation showing who was present.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement 4 has been deleted.</p>		
SERC OC Standards Review Group	No	<p>The measures should be revised to match the general nature of the comments we have made on each requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
PJM Interconnection LLC	No	<p>1. We disagree with M4 as it seems to indicate that all training needs to be in person and precludes any form of Computer Based Training (CBT). 2. As indicated in 10, R5 is redundant as R2 already required an entity to report any Impact Events by executing/implementing its Impact Event Operating plan. If R5 is to remain as is, then M5 goes beyond the requirement by requiring the entity to produce evidence of compliance for the type of Impact Event experienced. It is not clear as to what additional evidence is needed to support the type of Impact Event experienced?.</p>
<p>The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
We Energies	No	<p>M1 contains a redundancy: It currently reads, "Each Responsible Entity shall provide the current in force Impact Event Operating Plan to the Compliance Enforcement Authority." ("In force" is the same as "current".)M2: Change "Impact Event" to "Impact Event listed in Attachment 1".M3: This is an additional requirement. R3 does not require a mock Impact Event. R3 requires a test of the communicating Operating Process. As stated above, R3 and M3 should be deleted.M4: This is written assuming classroom training. R4 does not require formal training much less classroom training. R4 requires that those (internal) personnel who have responsibilities in the plan review the Impact Event Operating Plan.M5: When we report, how do we show to an auditor that we reported "using the plan"? Delete the reference to "the plan".</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
Compliance & Responsibility Organization	No	See comments set forth in number 2.
Exelon	No	? M1 - Suggest rewording to state "Each Responsible Entity shall provide the current revision of the Impact Event Operating Plan or equivalent implementing process"? M3 ? Need to provide more guidance on evidence of compliance to meet R.3 The DSR SDT needs to provide more guidance on the objectives and format of the drill expected (e.g., table top, simulator, mock drill) and what evidence will be required to illustrate compliance.? M5 - Suggest that the DSR SDT provide a note or provision to allow for the DOE OE-417 reporting form be submitted by the most knowledgeable functional entity (e.g., the TOP or RC) experiencing the event.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
City of Tallahassee (TAL)	No	M3 & M4 should be modified if comments above (#8 and #9) are incorporated.M4 - Providing the ?materials presented? is beyond the scope of compliance. This constitutes a review of the training program which is beyond the scope of the standard. Review of attendance sheets should be sufficient. The personnel will be listed in the Plan/Process/Procedure. Modify M4: Responsible Entities shall provide evidence of those who participated in the review, showing who was present and when internal personnel were trained on their responsibilities in the plan.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Tenaska	No	The proposed R1 through R4 should be deleted and a revised version of R5 should become R1. The proposed measures for the new R1 should be revised accordingly.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
American Municipal Power	No	M1-M4 should be eliminated and M5 should be revised to incorporate a simplified R5. M5 - Date and time of submitted report
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
Liberty Electric Power LLC	No	Due to disagreement with R3 and R4.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Arkansas Electric Cooperative Corporation	No	We applaud the drafting team's effort in crafting more meaningful measures. However, we have concerns with the measures reading like requirements in stating Responsible Entities "shall" do something. We suggest crafting the measures to provide acceptable, but not all exclusive, forms of evidence by stating something similar to "Acceptable forms of evidence may include??"
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
New Harquahala Generating Co.	No	See R3 comments
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see R3 responses.</p>		
Consumers Energy	No	We understand that DOE is migrating to an on-line reporting facility rather than the email-submitted OE-417. If they do so, Form OE-417 will not be available for providing to NERC, and the reporting specified by EOP-004 will be duplicative of that for DOE. We recommend that NERC, RFC and the DOE work cooperatively to enable a single reporting system in which on-line reports are made available to all appropriate parties.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT has been working with the U.S. Department of Energy (DOE) to streamline the reporting process. The DOE Form OE-417 will be accepted at NERC if you are reporting an event to the DOE.</p>		
Independent Electricity System Operator	No	We do not have any issues with Measures M1, M2 and M4, but have a concern with M3 and a couple of concerns with M5:M3: This Measure contains a requirement for the Responsible Entities to conduct a mock Impact Event. We disagree to have this included in the Measure. R3 requires the Responsible Entity to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The Measure should adhere to this condition only. We suggest to change the wording to: The Responsible Entity shall provide evidence that it conducted a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, documentation or a report on an actual Impact Event. M5: a. As

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 12 Comment
		<p>suggested above, R5 should be combined with R2;b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to ?support the type of Impact Event experienced?. Also, the date and time of the Impact Event is provided in the reporting from. Why do we need to provide additional evidence on the date and time of the Impact Event?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement R5 (now R2) was revised along with the measure:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported.</p>		
ISO New England, Inc	No	<p>We do not have any issues with Measures M1, M2 and M4, but have a comment on M3 and a couple of concerns with M5:M3: This Measure contains a requirement for the Responsible Entities to conduct a mock Impact Event. We disagree to have this included in the Measure. R3 requires the Responsible Entity to conduct a test of its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The Measure should adhere to this condition only. We suggest to change the wording to:The Responsible Entity shall provide evidence that it conducted a test of it its Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3. The time period between actual and or mock Impact Events shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, documentation or a report on an actual Impact Event.M5:a. As suggested above, R5 should be combined with R2;b. If R5 to remain as is, then M5 goes beyond the requirement in R5 in that it asks for evidence to support the type of Impact Event experienced. Attachment 2 already requires the reporting entity to provide all the details pertaining to the Impact Event. It is not clear what kind of additional evidence is needed to ?support the type of Impact Event experienced?. Also, the date and time of the Impact Event is provided in the reporting from. Why do we need to provide additional evidence on the date and time of the Impact Event?c. We disagree with Measurement 4. It implies that the review must be conducted in person. Why couldn't other means such as web training or a reminder memo not satisfy the requirement?</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement R5 (now R2) was revised along with the measure:</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
		<p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported.</p>
Calpine Corp	No	<p>Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. The measure for Requirement R5 should focus on the need to report accurately and promptly, not on a Responsible Entity's Operating Plan?. If the Requirements are retained, the measures should state in much greater detail what actions and documentation are required for compliance.</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. Requirement R5 (now R2) was revised along with the measure:</p> <p>R2. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk: Factor: Medium] [Time Horizon: Operations Assessment].</p> <p>M2. Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported.</p>
CenterPoint Energy	No	<p>M1: CenterPoint Energy recommends that the phrase "current in force" be updated to "current" or "currently effective". Additionally, CenterPoint Energy suggests clarifying M1 by adding "within 30 days upon request", which would be consistent with language found in measures in other standards. The revised measure would read, "Each Responsible Entity shall provide the currently effective Impact Event Operating Plan to the Compliance Enforcement Authority within 30 days upon request." M2: If R2 is deleted (as recommended in response to Question 7), then M2 should be deleted.</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. R2 was deleted along with the measure M2.</p>
ExxonMobil Research and Engineering	No	<p>Measure M3 introduces a pseudo-requirement by implying you are able to reset the testing clock if you implement our Impact Event Operating Plan in response to an Impact Event. This should be covered in Requirement R3. Measure M4 should refer to positions and evidence that people occupying those positions participated in the annual review of the Impact Event Operating Plan. Given the number of individuals involved in operations and the cycle of promotions and reassignments, it's unreasonable to expect an entity</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
		to identify specific individuals in their Impact Event Operating Plan. As the one hour time window is not long enough for entities to report all types of events when responding to the impact the Impact Event had on its facility, Measure M5 should be modified to include voice recordings and log book entries to capture verbal information reported to required parties.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Constellation Power Generation	No	See CPG?s earlier comments regarding the Requirements and Measures.
<p><b>Response:</b> The DSR SDT thanks you for your comment. See response to comments on Requirements and Measures.</p>		
Georgia System Operations Corporation	No	There are a lot of inconsistencies between the requirements and the measures. The measures add requirements that are not stated in the requirements. The measures need to be made consistent with the requirements and to not add to them. Also see comments on requirements earlier for language to move from the measures into the requirements.M2: Remove "on its Facilities." The word "its" leads to a lot of confusion regarding who reports what. Attachment 1 should make clear "what" needs to be reported. The entities' operating plan should make it clear as to who should report each "what." Furthermore, not all Impact Events are "on Facilities."M3: Replace "that it conducted a mock Impact Event" with "that it conducted a test of its Operating Process." Delete "The time period between actual and or mock Impact Events shall be nor more than 15 months."M4: The measure says that documentation showing when personnel were trained is required. R4 does not require training. The requirement and the measure should be made clear and consistent.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	M3 -The testing of the Plan by drill or mock impact event is unnecessary and burdensome.
<p><b>Response:</b> The DSR SDT thanks you for your comment. The Measure M3 has been revised as follows:  M3. The Responsible Entity shall provide evidence that it conducted a test of the communication process in its Operating Plan events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement. The time period between an actual event or test shall be no more than 15 months. Evidence may include, but is not limited to, operator logs,</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
<p>voice recordings, or dated documentation of a test. (R3)</p> <p>The intent of R3 is to ensure that the communications process of the Operating Plan works when needed. The annual test is not burdensome and an actual event will take the place of the test.</p>		
Farmington Electric Utility System	No	See comments in requirements for R3 and R4
<p><b>Response:</b> The DSR SDT thanks you for your comment. See response to comments on R3 and R4.</p>		
Indeck Energy Services	No	<p>M1 is OK. M2 should be about implementation, not about any particular events--M5 is about events. Implementation would include distribution and training. M3 should be modified to reflect a training review by entities that cannot cause a Reportable Disturbance or reportable DOE OE-417 event and for the others documentation of an actual event (which is not included in the present M3) or a drill or mock event. M4 is OK. M5 should only include the reports submitted and the date of submission. Further evidence of the event is redundant.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.</p>		
Brazos Electric Power Cooperative	No	M2 and M5 appear to duplicate each other.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement. R2/M2 have been deleted and R5/M5 is now R2/M2.</p>		
Progress Energy	No	<p>M3 states that ?In the absence of an actual Impact Event, the Responsible Entity shall provide evidence that it conducted a mock Impact Event?? Does this mean that, if an entity experiences an Impact Event that is reportable, then the entity does not have to perform its annual test? If so, this should be made clear in the Requirement.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. That is the intent of the requirement. The Rationale box has been revised to express this intent. The measure now reads:</p> <p>The Responsible Entity shall provide evidence that it conducted a test of the communication process in its Operating Plan for events created pursuant to Requirement R1, Part 1.3. Implementation of the communication process as documented in its Operating Plan for an actual event may be used as evidence to meet this requirement. The time period between an actual event or test shall be no more than 15 months. Evidence may include, but is</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 12 Comment
not limited to, operator logs, voice recordings, or dated documentation of a test. (R3)		
Occidental Power Marketing	Yes	In general, the measures are okay. However, as mentioned above for R3, there needs to be more specificity as to what is acceptable as a "mock Impact Event" for auditing purposes--especially for small entities such as LSEs that do not own, operate, or control BES assets.
<b>Response:</b> The DSR SDT thanks you for your comment. Each measure has been rewritten for the associated requirement to reflect only what is within the requirement.		
SDG&E	Yes	
Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
PSEG Companies	Yes	
Pepco Holdings Inc and Affiliates	Yes	
Southern Company	Yes	
SRP	Yes	
APX Power Markets	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 12 Comment
USACE	Yes	
Ameren	Yes	
BGE		No position or comments.
Platte River Power Authority	Yes	
Alliant Energy	Yes	
PPL Electric Utilities	Yes	
Lincoln Electric System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

**13. Do you agree with the proposed Violation Risk Factors for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Many stakeholders suggested that the reporting of events after the fact only justified a VRF of Lower for each requirement. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.

Organization	Yes or No	Question 13 Comment
Northeast Power Coordinating Council	No	If R5 is to remain as is, then the VRF should be a Lower, not a Medium. R5 stipulates the form to be used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form does not lead to unreliability.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
Bonneville Power Administration	No	R2, R3 and R4 should be lower VRFs than R5 and R1.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
PSEG Companies	No	If Requirements 1-5 remain intact the Violation Risk Factor should be reduced to a Lower not a Medium since this is an administrative requirement and does not impact the reliability of the BES.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Dominion	No	All the VRFs are "Medium." Since the requirements deal with after-the-fact reporting and the administration of reporting plans, procedures, and processes; all VRFs should be "Lower."
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		<p>the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
Pepco Holdings Inc and Affiliates	No	<p>This standard involves after the fact reporting of events. Other standards deal with the real time notifications. How do the risk factors between the two line up? A VRF of Low would seem appropriate, since a violation would not affect the reliability of the BES.</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
SPP Standards Review Group	No	<p>These are reporting requirements and therefore do not deserve the “medium” VRF. We suggest making the VRFs for all requirements for EOP-004-2 “low.”</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		<p>communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
Midwest ISO Standards Collaborators	No	<p>All violation risk factors should be Lower. All requirements are administrative in nature. While they are necessary because a certain amount of regulatory reporting will always be required, a violation will not in any direct or indirect way lead to reliability problem on the Bulk Electric System</p>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
FirstEnergy	No	<ol style="list-style-type: none"> <li>1. We believe that Requirement 5 does not warrant a “Medium” risk factor. Not using a particular form is strictly administrative in nature and the VRF should be “Low.”</li> <li>2. We believe that Requirement 4 does not warrant a “Medium” risk factor. For example, a simple review of the process does not have the same impact on the Bulk Electric System as the implementation of the Operating Plan per R2. Therefore, we believe R4 is at best a “Low” risk to the BES.</li> </ol>
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.
SERC OC Standards Review Group	No	How can an after-the-fact report require a VRF greater than low?
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
PJM Interconnection LLC	No	All VRFs should be lower as Requirements 1-5 are all administrative in nature. A violation of any of these requirements does not directly or indirectly affect the reliability of the BES.
		<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>
We Energies	No	All VRFs should be Lower. They are all administrative and will not affect BES Reliability.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
LG&E and KU Energy LLC		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p><b>Response:</b> The DSR SDT thanks you for your comment. See response to comments on Question 2.</p>		
Exelon	No	R.4 should be a low risk factor, this is an administrative requirement with no contribution to reliability.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
City of Tallahassee (TAL)	No	R1 is administrative in nature (must have a document) and should be Lower.



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
<p><b>Response:</b> The DSR SDT thanks you for your comment. The DSR SDT concurs and has assigned a “lower” VRF for Requirement R1.</p>		
United Illuminating Co	No	R3 should be Low. It is a test of the communication Plan which is use of telephone and email.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
American Municipal Power	No	No, this is not acceptable. Eliminate R1-R4. Change R5 to Lower.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Liberty Electric Power LLC	No	See Q 12.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Please see response to Question 12.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
Manitoba Hydro	No	Reduce the Long Term Planning items to Lower VRF. The planning items will not have the same impact on the reliability of the system as real time operations.
<p><b>Response:</b> The DSR SDT thanks you for your comment. Each Requirement is in the Operations Assessment or Operations Planning time horizon. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Independent Electricity System Operator	No	If R5 were to remain as is, then the VRF should be a Lower, not a Medium since R5 stipulates the form to be used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form does not give rise to unreliability.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
ISO New England, Inc	No	If R5 is to remain as is, then the VRF should be a Lower, not a Medium since R5 stipulates the form to be

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
		<p>used. It is a vehicle to convey the needed information, and as such it is an administrative requirement. Failure to use the form provided in Attachment 2 or the DOE form has no impact on reliability.</p> <p>All violation risk factors should be Lower. All requirements are administrative in nature. While they are necessary because a certain amount of regulatory reporting will always be required, a violation will not in any direct or indirect affect reliability.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Calpine Corp	No	<p>Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. If retained, the violation risk factors should be low for those Requirements, as they all simply support the requirement to actually report correctly stated in Requirement R5.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
ExxonMobil Research and	No	<p>VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
Engineering		appropriate for this requirements of this standard.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Georgia System Operations Corporation	No	<p>Failing to report to NERC any of many of the listed events does not present a reliability risk. The exception to this would be those threat events where the ES-ISAC needs to be notified. The object of the standard is to prevent or reduce the risk of Cascading. Reporting system situations to appropriate operating entities who can take some mitigating action (e.g., a LSE reporting to its BA or a BA reporting to its RC) and reporting threats to law enforcement officials could prevent or reduce the risk of Cascading but reporting to NERC (except for events where the ES-ISAC needs to know) is unlikely to do that. Reporting of most of the listed events to NERC does not meet the objective of this standard and should be removed from this standard. Such events should be reported to NERC through some other (than a Reliability Standard) requirement for reporting to NERC so that NERC can accomplish its mission of analyzing events. Analyzing events may lead to an understanding that could reduce the future risk of Cascading but analyzing events cannot be performed in time to reduce any impending risks.</p>
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 13 Comment
EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.		
Indeck Energy Services	No	If there are any, they should all be Low because this is reporting of historical events. There is no direct effect on BES reliability. Some effect could occur if someone reacts to the reports, but many are concerning unpreventable events.
<p><b>Response:</b> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a “lower” VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement 2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement 3 is insurance to make sure that an entity can communicate information about events. Requirement 2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is “medium.” The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	
Progress Energy	No	
BGE	Yes	No comments.
Platte River Power Authority	Yes	
Alliant Energy	Yes	
Midwest Reliability Organization	Yes	
Southern Company	Yes	
SRP	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 13 Comment
SDG&E	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

**14. Do you agree with the proposed Violation Severity Levels for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Most commenters agreed with the VSLs. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements. The ‘Severe’ rating for excessively long reporting times has been retained as the DSR SDT believes that fairly reflects the definition of ‘Severe’ i.e., The performance or product measured does not substantively meet the intent of the requirement.

Organization	Yes or No	Question 14 Comment
Northeast Power Coordinating Council	No	No major issues with the proposed VSLs. However, because of the preceding comments, want to see the next revision of the draft.
<i>Response:</i> The DSR SDT thanks you for your comment.		
Bonneville Power Administration	No	For R5 VSL's: suggest moving the 1-2 hours down one level to Moderate and move the >2 hours down to High with a range of 2-8 hours. Leave the "Failed to Submit" in the Severe category.
<i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has increased most reporting timeframes to 24 hours. Those that still require 1 hour reporting have been adjusted to better align with the 24 hour VSLs. Namely, taking twice as long to report is a ‘Medium’ VSL. The ‘Severe’ rating for excessively long reporting times has been retained as the DSR SDT believes that fairly reflects the definition of ‘Severe’ i.e., The performance or product measured does not substantively meet the intent of the requirement.		
Western Electricity Coordinating Council		Regarding the proposed VSLs for R3, since communication testing involves multiple parties it would be more appropriate to base severity level on the number of applicable parties which were not tested rather than how long after 15 months it took to do the test. The standard already builds in a 3 month leeway, In reality the way it is written almost guarantees a lower severity level.
<i>Response:</i> The DSR SDT thanks you for your comment. VSLs reflect the degree to which the requirements are met. The DSR SDT envisions that communication testing will include all parties referenced in the entity's operating plan. Failure to test any part of that communication process is a failure of that Part of the requirement.		
Pepco Holdings Inc and Affiliates	No	This standard involves after the fact reporting of events. Other standards deal with the real time notifications. How do the severity level between the two line up? See above VRF comments.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 14 Comment
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the VSLs appropriately align with the NERC Guidelines.</p>		
SPP Standards Review Group	No	<p>Requirement 4: We would suggest the following:Low ? The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 15 calendar months but less than 18 calendar months since the last review.Moderate - The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 18 calendar months but less than 21 calendar months since the last review.High - The Responsible Entity reviewed its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 21 calendar months but less than 24 calendar months since the last review.Severe - The Responsible Entity failed to review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan within 24 calendar months since the last review.Requirement 5: With our suggested deletion of Requirement 5, we further suggest deleting the VSLs associated with Requirement 5.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2.</p>		
SERC OC Standards Review Group	No	The VSLs should reflect the comments on the requirements above.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements.</p>		
PJM Interconnection LLC	No	VSLs should reflect the comments on the VRFs above.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the VSLs appropriately align with the NERC Guidelines.</p>		
We Energies	No	Change the VRFs as indicated above and the Time Horizons as indicated below.
<p>Response: The DSR SDT thanks you for your comment. Please see responses to those comments.</p>		
Compliance & Responsibility Organization	No	See comments set forth in number 2.
<p>Response: The DSR SDT thanks you for your comment. Please see responses Question 2.</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 14 Comment
Exelon	No	Suggest rewording the 1 hour reporting for High and Severe to state "communicate or submit" a report within ? depending on the severity of the event, an actual report may not be feasible. Similar to an NRC event report, a provision should be made for verbal notifications in lieu of an actual submitted report. An entity should not be penalized for failing to submit a written report within 1 hour if the communications were completed within the 1 hour time period meeting the intent of the Standard.
<p>Response: The DSR SDT thanks you for your comment. Attachment 1 allows you to provide a verbal report under the conditions you contemplate.</p>		
SDG&E	No	This Reliability Standard provides a list of reporting requirements that are applicable to registered entities, thus it is a paperwork exercise; therefore, SDG&E recommends that none of the requirements should exceed a ?Moderate? Violation Severity Level. Failure on the part of an applicable Registered Entity to provide an event report will have no immediate impact on the Bulk Electric System.
<p>Response: The DSR SDT thanks you for your comment. VSLs describe how fully an entity meets the requirements and are not a measure of severity or impact. These items are captured in the VRFs.</p>		
American Municipal Power		No, this is not acceptable. Eliminate R1-R4 and change R5. Severe: n/aHigh VSL: n/aMedium VSL: No report for a reportable eventLow VSL: Late report for a reportable event
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements.</p>		
Liberty Electric Power LLC	No	See Q 12.
<p>Response: The DSR SDT thanks you for your comment. Please see responses to Question 12.</p>		
Consumers Energy	No	<p>1. In reference to the Impact Event addressing ?Loss of Firm load for greater than or equal to 15 minutes?, this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to ?Within 1 hour after detection of exceeding 15-minute threshold?. Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES.2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting ?Within 1 hour after occurrence</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 14 Comment
		<p>is identified? possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the ?time to submit?.3. Referring to the ?Fuel Supply Emergency? Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has increased almost all reporting timeframe to 24 hours. Also, the fuel supply emergency has been removed from Attachment 1. Reporting period was chosen to meet NERC needs, you may have more restrictive periods for OE-417, but that is outside the jurisdiction of the DSR SDT.</p>		
Calpine Corp	No	<p>Requirements R1, R2, R3, and R4 are unnecessary, as discussed above. If retained, the violation risk factors should be low for those requirements, as they all simply support the requirement to actually report correctly stated in Requirement R5.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements.</p>		
CenterPoint Energy	No	<p>CenterPoint Energy believes that the Severe VSL for R5 (Reporting) in the current draft incorrectly equates 2X reporting with failure to submit a report. CenterPoint Energy believes the VSLs for R5 should all reflect a factor increase in time. For example, the lower VSL should be 1.5X the reporting time frame. The Moderate VSL should be 2x the reporting time frame. The High VSL should be 3x the reporting time frame. The Severe VSL should be failure to report.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R4 and R2, and R5 has become R2. The VSLs have been aligned with the revised requirements. The 'Severe' rating for excessively long reporting times has been retained as the DSR SDT believes that fairly reflects the definition of 'Severe' i.e., The performance or product measured does not substantively meet the intent of the requirement.</p>		
ExxonMobil Research and Engineering	No	<p>VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more appropriate for the requirements of this standard.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the VSLs and time horizons appropriately align with the requirements and NERC Guidelines. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2)</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 14 Comment
<p>and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p>		
Indeck Energy Services	No	<p>There should be only Lower VSL's. This is reporting of historical events and there is no direct effect on BES reliability. How does missing 3 parts of R1 compare to tripping a 4,000 MW generating station because vegetation was not properly managed? Just because there are 4 levels, doesn't mean that all Standards need to use them all. If you step back, and think about causes of cascading outages, reporting events 1 hour or 24 hours later has no significance. There is no direct preventative causation either.</p>
<p>Response: The DSR SDT thanks you for your comment. VSLs describe how fully an entity meets the requirements and are not a measure of severity or impact to the BES. These items are captured in the VRFs.</p>		
Progress Energy	No	<p>Progress disagrees with the High and Severe VSLs listed for R5. If an entity experiences an Impact Event and fails to submit a report within an hour as required, it may be that there are multiple mitigating circumstances. It is not reasonable to require reporting within an hour since identifying a reportable event often takes longer than this time period.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has increased almost all reporting timeframe to 24 hours. Also, VSLs describe how fully an entity meets the requirements and are not a measure of severity or impact to the BES. These items are captured in the VRFs.</p>		
Georgia System Operations Corporation	No	None.
Independent Electricity System Operator		<p>We do not have any major issues with the proposed VSLs. However, in view of our comments on some of the Questions, above, we reserve our comments upon seeing a revised draft.</p>
<p>Response: The DSR SDT thanks you for your comment.</p>		
ISO New England, Inc		<p>We do not have any major issues with the proposed VSLs. However, in view of our comments on some of the Questions, above, we reserve our comments upon seeing a revised draft.</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 14 Comment
<a href="#">Response: The DSR SDT thanks you for your comment.</a>		
Midwest Reliability Organization	Yes	
Midwest ISO Standards Collaborators	Yes	
Southern Company	Yes	
SRP	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
American Electric Power	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Organization	Yes or No	Question 14 Comment
BGE	Yes	No comments.
Alliant Energy	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Yes	

**15. Do you agree with the proposed Time Horizons for Requirements 1-5? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** Many stakeholders suggested that the Time Horizons for this standard should be **Operations Assessment or Operations Planning rather than Long Term Planning. The DSR SDT agrees.** The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Assessment, which is defined as ‘follow-up evaluations and reporting of real time operations’. R4 has been deleted and the time horizon for R1 and R3 has been changed to Operations Planning.

Organization	Yes or No	Question 15 Comment
Northeast Power Coordinating Council	No	For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. Consistent with other plans such as system restoration plans which need to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. Suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Assessment, which is defined as ‘follow-up evaluations and reporting of real time operations’. R4 has been deleted and the time horizon for R1 and R3 has been changed to Operations Planning.</p>		
Bonneville Power Administration	No	Depends on the answer to #7. If implementation means a signed and valid Plan, then it should be with Long Term. If reporting the events, then it should be Real-Time/Same Day Operations.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted the separate requirement to ‘implement the plan’. The reporting obligation is now R2 with a time horizon of Operations Assessment, which is defined as ‘follow-up evaluations and reporting of real time operations’.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

SPP Standards Review Group	No	Based on our previous comments in response to Question 11, we feel that the Time Horizon for R2 should be lengthened. Assigning it a Real-time Operations and Same ?day Operations timeframe has too much of an impact on real-time operations. Pushing it back will allow support personnel to do the after-the-fact reporting and keep this burden off of the operators.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The reporting obligation is now R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'.</p>		
Midwest ISO Standards Collaborators	No	R2 and R5 should be Operations Assessment since it deals with after the fact reporting. R3 should included Operations Assessment since an actual event could be used as the test.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
SERC OC Standards Review Group	No	R2 and R5 should be in the Operations Assessment time horizon.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
PJM Interconnection LLC	No	R2 and R5 should be in Operations Assessment Time Horizon as they deal with ?after-the-fact? reporting.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
We Energies	No	R2 and R5 should be Operations Assessment.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Consumers Energy	No	<p>1. In reference to the Impact Event addressing 'Loss of Firm load for greater than or equal to 15 minutes?', this is likely to occur for most entities most frequently during storm events, where the loss of load builds slowly over time. In these cases, exceeding the threshold may not be apparent until a considerable time has lapsed, making the submittal time frame impossible to meet. Even more, it may be very difficult to determine if/when 300 MW load (for the larger utilities) has been lost during storm events, as the precise load represented by distribution system outages may not be determinable, since this load is necessarily dynamic. Suggest that the threshold be modified to 'Within 1 hour after detection of exceeding 15-minute threshold?'. Additionally, these criteria are specifically storm related wide spread distribution system outages. These events do not pose a risk to the BES.2. Many of the Impact Events listed are likely to occur, if they occur, at widely-distributed system facilities, making reporting 'Within 1 hour after occurrence is identified?' possibly impractical, particularly in order to provide any meaningful information. Please give consideration to clearly permitting some degree of investigation by the entity prior to triggering the 'time to submit?'.3. Referring to the 'Fuel Supply Emergency? Impact Event, OE-417 requires 6-hour reporting, where the Impact Event Table requires 1-hour reporting. The reporting period for EOP-004-2 should be consistent with OE-417.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has increased almost all reporting timeframe to 24 hours. Also, the fuel supply emergency has been removed from Attachment 1. Reporting period was chosen to meet NERC needs, you may have more restrictive periods for OE-417, but that is outside the jurisdiction of the DSR SDT.</p>		
Independent Electricity System Operator	No	<p>For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. And consistent with other plans such as system restoration plan which needs to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. We suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning.</p>
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

ISO New England, Inc	No	For the purpose of developing and updating an Impact Event Operating Plan, there should not be any requirements that fall into the Long-term planning horizon. As the name implies, the plan is used in the operating time frame. And consistent with other plans such as system restoration plan which needs to be updated and tested annually, most of the Time Horizons in that standard (EOP-005-2) are either Operations Planning or Real-time Operations. We suggest the Time Horizon for R1, R3 and R4 be changed to Operations Planning. The Time Horizon for R2 and R5 should be changed to Operations Assessment since they both deal with after the fact reporting.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has deleted R2, and R5 has become R2 with a time horizon of Operations Planning, which is defined as 'follow-up evaluations and reporting of real time operations'. R4 has been deleted and the time horizon for R1 and R3 have been changed to Operations Planning</p>		
ExxonMobil Research and Engineering	No	VRFs, VSLs, and THs ideally should be based on the impact event type; alternatively a low VRF seems more appropriate for this requirements of this standard.
<p><i>Response:</i> The DSR SDT thanks you for your comment. With the revised standard, there are now three requirements. Requirement R1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment 1. This is procedural in nature and justifies a "lower" VRF. This requirement is administrative in nature and deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program. The two remaining requirements in EOP-004-2 are to report events based on the specifics in Attachment 1 (R2) and to test the communications protocol of the Operating Plan once per year (R3). Requirement R2 specifies that an entity is responsible for reporting events in accordance with the Operating Plan based on Attachment 1. Requirement R3 is insurance to make sure that an entity can communicate information about events. Requirement R2 specifies that the responsible entity must report an event to the appropriate entities. Some of these events are dealing with potential sabotage events. Part of the reason to report these types of events is to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events and the approved VRFs for each of the requirements is "medium." The VRFs for EOP-004-2 comport with the existing approved VRFs for both EOP-004 and CIP-001.</p> <p>The DSR SDT believe the VSLs and revised time horizons appropriately align.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	Why shorten the normal process?
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT has revised most of the reporting timelines 24 hours.</p>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Indeck Energy Services	No	These requirements have no time horizon. There about history and not about the future.
<p><i>Response:</i> The DSR SDT thanks you for your comment. All NERC standards must have a time horizon associated with each requirement. Time horizons are used as a factor in determining size of a sanction.</p>		
American Municipal Power	No	
USACE	No	
Pepco Holdings Inc and Affiliates	Yes	However, do they line up with the corresponding real time reporting procedures as mentioned above, #13 and #14?
<p><i>Response:</i> The DSR DT thanks you for your comment. Please see responses to comments #13 and #14. Since the time for reporting impact events is no more than 24 hours, the time horizon has been revised to Operations Planning.</p>		
Midwest Reliability Organization	Yes	
PPL Supply	Yes	
Dominion	Yes	
FirstEnergy	Yes	
Southern Company	Yes	
SRP	Yes	
City of Tallahassee (TAL)	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
United Illuminating Co	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
New Harquahala Generating Co.	Yes	
Platte River Power Authority	Yes	
BGE		No position or comments.
Alliant Energy	Yes	
CenterPoint Energy	Yes	
PPL Electric Utilities	Yes	
Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
Farmington Electric Utility System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	

Georgia System Operations Corporation	Yes	None.
---------------------------------------	-----	-------

**16. Do you agree with the proposed Implementation Plan for EOP-004-2? If not, please explain why not and if possible, provide an alternative that would be acceptable to you.**

**Summary Consideration:** The majority of commenters agreed with the Implementation Plan. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with. Consequently the effective date remains as first calendar day of the third calendar quarter following the regulatory approval/BOT adoption as applicable.

Organization	Yes or No	Question 16 Comment
Pepco Holdings Inc and Affiliates	No	The proposed time line is too short. It is easy to revise procedures. However developing training and integrating the training into the schedule takes time. Shorter time frame takes away adequate time to integrate into the training plan and disrupts operator schedules. Since notifications already exist and after the fact reporting does not impact BES reliability, why the need to expedite? There are many other training activities that must be coordinated with this.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
FirstEnergy	No	We believe the previous proposal for a 12 month implementation was more appropriate and suggest the team revert back to that timeframe.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Southern Company	No	The implementation time should be 12 months after approval regardless of the elapsed time taken to get the standard approved.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Exelon	No	The DSR SDT reduced the implementation from one year to between six and nine months based on the revised standard requirements. Exelon disagrees with the proposed shortened implementation timeframe. The current revision to EOP-004 still requires an entity to generate, implement and provide any necessary training for the "Impact Event Operating Plan" by a registered entity. Commenters previously supported a one year minimum; but the requirements for implementation have not changed measurably - six to nine months is not adequate to implement as written.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
SDG&E	No	SDG&E recommends a 9 month minimum timeframe for implementation.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
United Illuminating Co	No	The SDT should be specific that on the effective date an Entity will have the Operating documented and approved. The SDT should be specific that the first simulation is required to occur 15 months following the effective date. The SDT should be specific that the first annual review shall occur with in 15 months after the effective date.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
American Electric Power	No	With the scope of applicable functions expanding, more time will be required to develop broader processes and training. This will need to be extended for 18 months to get the process implemented and everyone trained.
<p>Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
CenterPoint Energy	No	CenterPoint Energy prefers the previously accepted timeline of 1 year.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Georgia System Operations Corporation	No	There is nothing about the revisions that were made to the requirements that shortens the time needed by the industry to get prepared for this revision. The removal of requirements for NERC does not shorten the requirements for the industry. Eighteen months (or 12 months minimum) should be allotted to prepare for this revision.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Brazos Electric Power Cooperative	No	A one year implementation is needed to develop and implement formal documents to meet requirements.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	No	The implementation Plan was to move up the timeline and we do not see why this needs to be pushed forward on a shortened timeline. It should remain at the one year implementation schedule especially if annual exercises are not removed from the standard requirements as this take some time to prepare.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
ExxonMobil Research and Engineering		Recommend 4th calendar quarter instead of 3rd.
<p><i>Response:</i> The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.</p>		
Consumers Energy	No	
Dominion	Yes	Dominion agrees with the Implementation Plan; however, notes that the title for EOP-004-2 is inconsistent with the actual proposed standard.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Response: The DSR SDT thanks you for your comment. The DSR SDT believe the revisions made as part of this comment period have made the standard easier to implement. This latest revision more closely aligns with existing EOP-004 requirements, which entities are already complaint with.

Farmington Electric Utility System	Yes	Nine months would be preferred
------------------------------------	-----	--------------------------------

Response: The DSR SDT thanks you for your comment. The majority of stakeholders agree with the proposed implementation plan and it will remain unchanged.

Northeast Power Coordinating Council	Yes	
Bonneville Power Administration	Yes	
Midwest Reliability Organization	Yes	
PPL Supply	Yes	
SPP Standards Review Group	Yes	
Midwest ISO Standards Collaborators	Yes	
SERC OC Standards Review Group	Yes	
PJM Interconnection LLC	Yes	
SRP	Yes	
We Energies	Yes	
Compliance & Responsibility Organization	Yes	
City of Tallahassee (TAL)	Yes	

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Lakeland Electric	Yes	
New Harquahala Generating Co.	Yes	
APX Power Markets	Yes	
American Municipal Power	Yes	
Liberty Electric Power LLC	Yes	
Arkansas Electric Cooperative Corporation	Yes	
Manitoba Hydro	Yes	
Sweeny Cogeneration LP	Yes	
USACE	Yes	
New Harquahala Generating Co.	Yes	
Independent Electricity System Operator	Yes	
ISO New England, Inc	Yes	
Platte River Power Authority	Yes	
BGE	Yes	No comments.
Alliant Energy	Yes	
PPL Electric Utilities	Yes	



**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

---

Occidental Power Marketing	Yes	
Lincoln Electric System	Yes	
American Transmission Company	Yes	
Ingleside Cogeneration LP	Yes	
Duke Energy	Yes	
Indeck Energy Services	Yes	

17. If you have any other comments you have not already provided in response to the questions above, please provide them here.

**Summary Consideration:** The majority of comments received relate to Attachment 1 and the Flowchart in the background section. The DSR SDT has made conforming revisions to each based on the comments received. The Flowchart was updated to remove references to sabotage and replaced with “Criminal act invoking federal jurisdiction”. In response to the comments received, the SDT has made numerous enhancements to Attachment 1. These revisions include:

- Added new column “Submit Attachment 2 or DOE OE-417 Report to:” which references Part 1.3 and provide the time required to submit the report.
- Combined Parts A and B into one table and reorganized it so that the events are listed in order of reporting times (either one hour or 24 hours)
- Removed references to “Impact Event” and replaced with the specific language for the event type in the “Entity with Reporting Responsibility”. For example, replaced “Impact Event” with “automatic load shedding”.

The ERO and the RE were added as applicable entities to reflect CIP-002 applicability to this standard.

Organization	Yes or No	Question 17 Comment
Georgia Transmission Corporation & Oglethorpe Power Corporation		In the discussion and related flowchart described as "A Reporting Process Solution - EOP-004," the discussion suggests that Industry should notify the state law enforcement agency and then allow the state agency to coordinate with local law enforcement. It has been our experience that we receive very good response from local law enforcement and they have existing processes to notify state or federal agencies as necessary. It appears the recommendation is to bypass the local law enforcement, but it is not clear that representatives from state or local law enforcement were included in this discussion (see proposal discussed with "FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair"). It would be helpful to see some additional clarification to understand why the state agency was chosen over local or federal agencies. Finally, we would like to express our gratitude to the DSR SDT for their hard work in making improvements to the NERC standards for event reporting.

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 17 Comment
<p><b>Response:</b> The DSR DT thanks you for your comment. The Flowchart has been updated. The DSR SDT has reviewed all comments and believes it is the responsibility of the Reporting Entity to contact the appropriate law enforcement officials.</p>		
Bonneville Power Administration		<p>Work needed on Part A Damage or Destruction of BES equipment. The Note 1 is OK, but the Threshold doesn't match well. If a PCB is damaged by lightning or an earthquake, Note 1 (human action) doesn't require Reporting (proper interpretation), but the Threshold still requires "equipment damage."</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 has been updated concerning Destruction of BES equipment and the associated footnote has been revised.</p>		
Midwest Reliability Organization		<p>On the Impact Reporting Form, number 7,8,9,10, and 11 have an astrict (*) but nothing describes what the astrict means. Recommend a foot note be added to state: * If applicable to the reported Impact Event.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1, Part B has been updated to reflect these noted changes.</p>		
Western Electricity Coordinating Council		<p>Actual Reliability Impact Table comments: Note that per the NERC glossary "Energy Emergency" only is defined for an LSE. Energy Emergency is the precursor term in the first three lines. Thus logically an LSE is the only entity which would be initiating the event and responsible for reporting for first three items. We don't believe that is the intent. We suggest you consider just eliminating ?Energy Emergency? and going with: ? Public appeal for load reduction? system-wide voltage reduction? manual firm load shedding For Loss of Off site power at Nuc Station is reporting really expected of each of the entities listed? (lots of reports) We suggest you consider just the Nuclear GOP and perhaps the associated TOP. Perhaps you could use the CIP approach as in the next two rows and say Applicable GOP and Transmission Entities under NUC-001-2 Potential Reliability Impact Table Comments: For Fuel Supply Emergency, Forced Intrusion, Risk to BES Equipment, Cyber Security Incident where owner/operator are both listed (GO/GOP or TO/TOP) could consider perhaps reporting to be assigned to only one rather than both.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has removed the use of "Energy Emergency" and has updated Loss of offsite power to a nuclear generating plant within Attachment 1. Fuel Supply emergency has been removed from Attachment 1 per comments received. The entire Attachment 1 has been updated per comments received.</p>		
Pacific Northwest Small Public Power Utility Comment Group		<p>All five requirements refer to Attachment 1 Part A either directly, or indirectly by referring to R1 plans. Attachment 1 Part A, though, only provides the thresholds required for reporting (R5). No thresholds are provided for planning (R1) or the requirements referencing the plan (R2-R4). Strictly interpreted, an entity would be required to plan for any amount of firm load loss exceeding 15 minutes (for example), implement the</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
		<p>plan for any amount and then report only those events that exceeded the applicable 200 or 300 MW level. An entity that had a peak load of less than 200 MW would still need to meet R1-R4 regarding load loss. We believe the SDT intended to use common thresholds for all the requirements. Suggest relabeling the Attachment 1 Part A column header from "Threshold for Reporting" to "Threshold." We also fail to see how an entity's size in MWh affects the threshold for reporting firm load loss.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has revised each Requirement and Attachment 1. There are other events within Attachment 1 that a responsible entity will be required to report.</p>		
Dominion		<p>The following comments are provided on the Reporting Hierarchy for Impact Events EOP-004-2: 1) A reference to sabotage still exists in a "decision block"; 2) The "entry block" only specifies "actual Impact Events" and does not address "potential"; 3) Hierarchy is misspelled in the title. Attachment 2: Impact Event Reporting Form; in questions 7, 8, 9, 10, 11 what is the purpose of the *(asterisk) behind each Task that is named?</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The Flowchart has been updated based on comments received. Attachment 2 has been updated to reflect comments received.</p>		
Pepco Holdings Inc and Affiliates		<p>IRO-000-1, Sec D1.5 and TOP-007, Sec D1.1 there are "after the fact" reporting requirements for IROL violations. Since IROL violations are included in this standard, should those standards be modified? Should the standard include a specific statement that this standard deals only with after the fact and other standards deal with real time reporting? Since this standard deals with after the fact reporting, consideration should be given to extending the time to report as defined in Attachment 1. One hour does not seem to be reasonable.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT has reviewed TOP-007 and note that the 72 hour issue is not defined within a Requirement. This issue has been forwarded to the "NERC Issues Data base." Attachment 1 has been updated to reflect this event to 24 hours per comments received.</p>		
SPP Standards Review Group		<p>In Attachment 2 just before the table, the statement is made that "NERC will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report." But the last sentence in the Guideline and Technical Basis white paper, it is stated that "For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report." These are in conflict with each other. Which is correct? We prefer the former over the latter. In Attachment 2 in Tasks 7-11 an asterisk appears in those tasks. To what does this asterisk refer?</p>

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 17 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> The DSR SDT's White Paper was the initial road map for the SDT to follow. The DSR SDT has proposed allowing entities to use the DOE Form OE-417 to report events listed within Attachment 1.</p>		
Midwest ISO Standards Collaborators		<p>We believe the reporting time lines are too aggressive for some events. Reporting events within an hour is not reasonable as an entity may still be dealing with the event. This will be particularly difficult when support personnel are not present such as during nights, holidays, and weekends.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 has been updated per comments received.</p>		
FirstEnergy		<p>FE offers the following additional comments and suggestions:</p> <ol style="list-style-type: none"> <li>1. In the Background section of EOP-004-2, on page 6 under Stakeholders in the Reporting Process, we suggest adding "Regional Entity?" and "Nuclear Regulatory Commission?".</li> <li>2. The DSR SDT makes reference to comments that Exelon provided that suggested adopting the NRC definition of "sabotage." We feel the comment made by Exelon in their previous submittal was to ensure that the DSR SDT included the Nuclear Regulatory Commission (NRC) as a key Stakeholder in the Reporting Process and FE agrees with this suggestion. Nuclear generator operators already have specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(s)(xi). We ask that the DSR SDT contact the NRC about this project to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. We believe this is a similar situation as what was recently resolved between NERC and the NRC concerning the applicability of CIPs 002 &amp; 009 for nuclear plants. Each nuclear generating site licensee must have an NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan (E-Plan). We ask that the proposed "Reporting Hierarchy for Impact Event EOP-004-2," flow chart be coordinated with the NRC to ensure it does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans.</li> </ol>
<p><b>Response: The DSR DT thanks you for your comment.</b> 1. We have added these as requested. 2. The NRC was added to the list on page 6 as requested. The events in Attachment 1 that are applicable to nuclear plants are: Generation loss (&gt;1,000 MW WECC, &gt;2,000 MW Elsewhere); Destruction of BES Equipment; Damage or destruction of Critical Asset per CIP-002; Damage or destruction of a Critical Cyber Asset per CIP-002; Forced Intrusion; Risk to BES Equipment; and Detection of a Reportable Cyber Security incident. Two of these events are addressed in the situation that you mention above (CIP-002). The other events should be reported to both the NRC and ERO if they occur. These are considered to be sabotage type events.</p>		

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
SERC OC Standards Review Group		In Attachment 1, the reporting timeline should be no less than the end of the next business day for after-the-fact reporting of events. If reporting in a time frame less than this is required for reliability, the groups or organizations receiving the reports should be included in the functional model. The emphasis should be on giving the operators the time to respond to events and not to reporting requirements. The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers.
<p><b>Response:</b> The DSR DT thanks you for your comment. Attachment 1 has been updated to reflect comments received. Many of the reporting time frames have been revised to 24 hours.</p>		
PJM Interconnection LLC		In the Compliance Enforcement Authority Section on Page 11, the second bullet says ?If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement?. We are not sure what this exactly implies or means. Additional clarification is required.
<p><b>Response:</b> The DSR DT thanks you for your comment. The statement that PJM is referring to applies to Regional Entities that also have a functional model obligation.</p>		
Southern Company		Need guidance for incorporating disturbance reporting that is in CIP-008.
<p><b>Response:</b> The DSR DT thanks you for your comment. EOP-004-2 is the reporting vehicle for CIP-008. CIP-008-4, Requirement 1, Part 1,3 will be retired upon approval of EOP-004-2.</p>		
We Energies		Attachment 2: What do the asterisks refer to? I didn't see a comment or description related to them.#7 & #10: What is ?tripped?? Automatic or manual or both.#13: This report has no Part 1.Flowchart: By the flowchart, the only time an OE-417 is filed is when I do not need to contact Law Enforcement. The Reporting Hierarchy flow chart should be modified. In the lower right corner it indicates that if sabotage is not confirmed, the state law enforcement agency investigates. Law enforcement agencies will not investigate an incident that is not a crime. Note too that state law enforcement agencies do not even investigate these kinds of events unless and until requested by local law enforcement. The local law enforcement agency always has initial jurisdiction until surrendered or seized by a superior agency's authority. Evidence Retention is incomplete. From the NERC Standards Process Manual: ?Evidence Retention: Identification, for each requirement in the standard, of the entity that is responsible for retaining evidence to demonstrate compliance, and the duration for retention of that evidence.?

Organization	Yes or No	Question 17 Comment
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 and Attachment 2 have been updated per comments received. The Flowchart has been updated per your comment.</p>		
<p>Compliance &amp; Responsibility Organization</p>		<p>Nuclear power plants (a need for a revised approach)With respect to sabotage, damage or destruction of BES equipment, damage or destruction of a Critical Asset, damage or destruction of a Critical Cyber Asset, forced intrusion, etc., nuclear plants already have a responsibility to report the events to the FBI and the Nuclear Regulatory Commission (NRC). Performing another report to NERC, with potentially different requirements, within 60 minutes of an event does not seem necessary or practical. It would also be difficult, during an event, to report to external organizations, including but not limited to the Responsible Entities? Reliability Coordinator, NERC, Responsible Entities? Regional Entity, Law Enforcement, and Governmental or Provincial Agencies when operations personnel are pre-occupied with an abnormal or emergency situation. Further, nuclear plants already have an obligation to report the loss of off site power to NRC. Similarly, now that cyber assets will be regulated by the NRC, these reporting requirements should not be applicable to a nuclear power plant. Thus, there is a need to exempt nuclear power plants from these requirements or provide more flexibility to such plants, given its pre-existing NRC reporting requirements.Attachment 1. There is no explanation for why a report must be submitted within one hour of an event. As stated with respect to nuclear, an entity should not be prioritizing between stabilizing the system and reporting. One approach that would help balance conflicting priorities is to start the time frame after ?all is clear.? Another approach could involve the use of target times, with an allowance for exceptions during emergencies or situations in which it is impracticable. Another alternative is to have two times: an earlier ?target reporting time? and second later ?mandatory reporting time.? Further, the current wording suggests that a generator owner or generator operator will be able to determine the impact or potential impact on the BES. This is not realistic, given that impacts to the BES are generally only understood at a transmission operator or reliability coordinator level. Thus, the concept of relying on generators to determine impacts on the BES needs to be eliminated.Also, as written, for a generator, Attachment 1 appears to require a report when a lightning arrestor fails at a Critical Asset. NextEra cannot see any justification for reporting such an event, and this is another reason why Attachment 1 needs more review and revision prior to the next draft of EOP-004-2. This one reason why NextEra has suggested a materiality test for reporting in a definition of Attempted or Actual Sabotage.</p>
<p><b>Response: The DSR DT thanks you for your comment.</b> Attachment 1 has been updated per comments received. Any NRC requirements or comments fall outside the scope of this project.</p>		
<p>Exelon</p>		<p>The DSR SDT makes reference to comments that were previously provided that suggested adopting the NRC definition of "sabotage." Respectfully, this commenter believes the DSR SDT did not understand the intent of the original comment. The comment made by Exelon in the October 15, 2009 submittal was to ensure that the DSR SDT made an effort to include the Nuclear Regulatory Commission (NRC) as a key Stakeholder in</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
		<p>the Reporting Process and to consider utilizing existing reporting requirements currently required by the NRC for each nuclear generator operator. Depending on the event, a nuclear generator operator (NRC licensee) also has specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72, "Immediate notification requirements for operating nuclear power reactors," paragraph (b)(2)(xi). The one hour notification requirement for an intrusion event would also meet an emergency event classification at a nuclear power plant. If an operations crew is responsible for the one hour notification and if separate notifications must be completed within the Emergency Plan event response, then an evaluation in accordance with 10 CFR 50.54, "Conditions of licensees," paragraph (q), would need to be performed to ensure that this notification requirement would not impact the ability to implement the Emergency Plan. At a minimum the DSR SDT should communicate this project to the NRC to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. Note that existing reporting/communication requirements are already established with the FBI, DHS, NORAD, FAA, State Police, LLEA and the NRC depending on the event. There are existing nuclear plant specific memorandums of understanding between the NRC and the FBI and each nuclear generating site licensee must have a NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan. The proposed "Reporting Hierarchy for Impact Event EOP-004-2," needs to be communicated and coordinated with the NRC to ensure that the flow chart does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans. Propose allowing for verbal reporting via telephone, for 1 hr. reporting with a follow up using the forms. With the revised standard EOP-004-2 it eliminates the #8; loss of electric service &gt;= 50K, however, that requirement is still required for the DOE-OE-417 form. The question is do we still have to send it to NERC / Region if NERC/ Region does not specifically still have that as a requirement? Also, with that requirement on the current EOP-004-1 it says that schedule 1 has to be filled out within 1 hour? This does not coincide with DOE-OE-417 form. The bottom line, it looks like there is inconsistency as to what is reportable per EOP-004-2 and DOE-OE-417 form, some of the items are redundant, some are not, but better guidance is needed as to which form to use when. The SDT should have a Webinar with the industry to create an understanding as to who is responsible to report what and at what time.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The NRC issues falls outside the scope of this project</p>		
City of Tallahassee (TAL)		Attachment 2 (Impact Event Reporting Form) items 8, 9, 10, and 11 have an asterisk but no identification as to what the asterisks refer to.
<p><b>Response:</b> The DSR DT thanks you for your comment. The asterisk was addressed at the bottom of the second page of the form. Attachment 2 has been</p>		



Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
updated to align with the types of events that are to be reported.		
APX Power Markets		The reporting of Impact Events needs to be clear spelled out and if moving some of that to State Agencies it needs to be consistent in all States at the same time and which State it should be reported to. We have a 24-hour Desk in one state that handles facilities in many other States. If there is an Impact Event that needs to be reported, where is that report sent to. The State the facility resides in or the State where our 24-hour Desk resides in.
<b>Response:</b> The DSR DT thanks you for your comment. Attachment 1 has been updated per comments received and a new column has been added to reflect who the impacted entity is required to report to.		
Arkansas Electric Cooperative Corporation		We appreciate the added context through the use of extended background information, rationale statements, and corresponding guideline and hope this context will remain in line with the Standards through the ballot and approval process. We have a few suggestions and questions related to this context. Our comments for this question relate to the contextual information. First of all, in the diagram on page 8, we suggest the appropriate question to ask is "Is event associated with potential criminal activity?" rather than "Report to Law Enforcement?? Also, it would be helpful to make clear the communication flow associated with the State Agency is the responsibility of the State Agency and not the Responsible Entity. This could be shown with a different colored background that calls this process out separately. In the rationale box for R3, it states "The DSR SDT intends?? We propose this should read similar to "The objective of this requirement is?? Overall, we suggest the SDT review the guidance document to make sure any changes made to the requirements are consistent with the guidance.
<b>Response:</b> The DSR DT thanks you for your comment. The flowchart has been updated per comments received. The Rationale box will be removed upon this Standard being Filled for approval.		
American Electric Power		We still do not agree that LSE, TSP and IA should be included in the applicability of this standard. Having processes to report to local or federal law enforcement agencies is ?legislating the obvious?. The focus on this standard should only be on Impact Event reporting to reliability entities.
<b>Response:</b> The DSR DT thanks you for your comment. Attachment 1 has been reviewed and updated. The LSE, TSP, and IA are required under the CIP Standards and Attachment 1 is based on reporting per the CIP requirements.		
Consumers Energy		1. We appreciate the aggregation of redundant standards on this subject, but have some concerns about the content of the aggregated standard as listed below and in reference to previous questions on this comment form.2. It is not clear whether an event that meets OE-417 reporting criteria but is not defined within EOP-

Organization	Yes or No	Question 17 Comment
		<p>004-2 is an Impact Event; for example, "loss of 50,000 or more customers for 1 hour or more" is required to be reported to DOE as a OE-417 type 11 event but it is not clear whether EOP-004-2 requires that such events be also reported to NERC. The "Reporting Hierarchy" flow chart seems to suggest that any OE-417 must still be filed with NERC/RE. If the flow chart is not consistent with the intent of the Requirements, it must be clarified.3. NERC implies active involvement of law enforcement. This assumes that law enforcement has the resources to be involved in an Impact Event investigation and fulfill the standard reporting requirements. This is an unrealistic expectation as we have experienced first-hand, a lack of response by law enforcement agencies as their resources shrink due to economic issues. Additionally, NERC is asking that we place credence in law enforcement, on our behalf, to make a definitive decision about the reporting of events. Refer to page 6 of EOP-004-2 under "Law Enforcement Reporting": "Entities rely upon law enforcement agencies to respond and investigate those Impact Events which have the potential of wider area affect?" In many cases, the internal security function must work with system operations personnel to thoroughly understand the system and the effects of certain events. It is unrealistic to think law enforcement would be in a position to make BES decisions within the timeframe given without having system operations experience. It is our experience that external agencies do not understand the integration / inter-connectivity, resiliency, or implications of our energy infrastructure.4. Within Michigan, a "Michigan Fusion Center: Michigan Intelligence Operations Center (MIOC)" has been established. - Today, we share information such as substation issues and identity theft (not internal issues) to the MIOC. The MIOC is trending incidents on critical infrastructure assets and sectors around the state. The private sector is encouraged to report to the Fusion Center. If NERC is collecting this type of information for future studies and trending / analysis, they should coordinate with each state's Fusion Center.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has reviewed and updated the Requirements per the comments received. Attachment 1 has been updated and the team has an additional column to reflect where a report should be sent. EOP-004-2 does not define what "law enforcement" is and that will be left up to each entity.</p>		
Ameren		<p>The following is a list of our greatest concerns. (1) We are concerned about the lack of definitions and use of critical non-capitalized terms. As an example, there is a reportable Impact Event if there is a +/- 10% Voltage Deviation for 15 minutes or more on BES Facilities. As a first example, why is the term Voltage Deviation capitalized when it is not in the NERC Glossary and not proposed to be added? Where is the deviation measured - at any BES metering device? What is the deviation to be reported - the nominal voltage? the high-side of the Voltage Schedule? the low-side of the Voltage Schedule? the generator terminals? when a unit is starting up? All of these are possible interpretations, but &lt; 1% of them would ever result in a Cascading outage - which is the reliability objective of this Standard. A second example is a Generation loss. The threshold for reporting is 2,000 MW, or more, for the Eastern or Western Interconnection. Is this simultaneous loss of capacity over the entire Interconnection? Or, cumulative loss within 1 hour? Or, cumulative loss within 24 hours? How many individual GOPs have responsibility for &gt; 2,000 MW? It seems</p>

Organization	Yes or No	Question 17 Comment
		<p>this would more effectively apply only to an RC and/or BA. The likelihood that one GOP would lose that much generation at once is probably remote. A third example would be the damage or destruction of BES equipment event. The term "equipment" was left lower case with a footnote explanation that includes "?due to intentional or unintentional human action?." This is likely to require the determination of intent by the human involved, which will almost certainly impossible to determine within the 1 hour reporting time. Also, what is the definition of the terms "damage" and "destruction"? Once again, if the reliability intent is to ONLY report Events that have a likely chance of leading to Cascading, this will greatly reduce the potentially enormous reporting burden. that could result without this type of clarification. (2) Without a very thorough understanding of the definitions of the terms requiring reporting, the 1 hour reporting constraint on most events will likely require that we frequently overreport events to minimize any chance of non-compliance. A webinar explaining expected reporting requirements would very useful and valuable. It is also unclear why so many Impact Events require such a short reporting time period. There will almost certainly be many times at 2:00 AM on a weekend when experts and the appropriate personnel will be available to quickly analyze an event and decide, within 1 hour, if a report is necessary. (3) Have all the new Impact Event reporting requirements been checked against reporting requirements from other Standards? For example, the Voltage Deviation Event would appear to potentially overlap/conflict with instructions from a TOP for VAR-002 compliance. Since VAR-002-2 is now in draft, has the SDT worked with that Team to determine if the requirements dovetail?</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the Requirements within EOP-004-2 and both Attachments 1 and 2 per comments received. Many of the reporting time frames have been extended to 24 hours per comments received. Voltage deviation is no longer capitalized. All event types are not intended to be new defined terms for the NERC Glossary and have been revised to lower case words. The reporting of voltage deviations is no longer applicable to the GOP which obviates the need to coordinate with the VAR-002 standard drafting team.</p>		
ISO New England, Inc		<p>Under the ?Law Enforcement Reporting? it is stated ?The Standard is intended to reduce the risk of Cascading involving Impact Events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.? We question whether a reporting standard can ?reduce the risk of cascading? and wonder if the reference to the threat ?around them? refers to law enforcement? We would expect that the appropriate operating personnel are the only entities that would be able to mitigate the potential risk to the BES.As it currently stands there is a potential duplication between the reporting requirements under EOP-004-2 (i.e. Attachment 2 Form) and the ERO Event Analysis Process that is undergoing field test (i.e. Event Report Form). This will result in entities (potentially multiple) reporting same event under two separate processes using two very similar forms. Is this the intent or will information requirements be coordinated further prior to adoption in order to meet the declared objective that the impact event reporting under EOP-004 be ?the starting vehicle for any required Event Analysis within the NERC Event Analysis Program?</p>

Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01

Organization	Yes or No	Question 17 Comment
<p><b>Response:</b> The DSR DT thanks you for your comment. The Background section was provided to assist entities in understanding the DSR SDT's process for updating CIP-001 and EOP-004, only.</p>		
Calpine Corp		<p>Focusing on reporting of actual disturbance events as listed in Attachment 1 based on potential or actual impact to the Bulk Electric System will provide maximum benefit to system reliability without adding needless levels of new documentation generated to demonstrate compliance. Absent significant evidence of systemic problems in the industry with past reporting attributable to causes other than a lack of clear guidance on the types events that require reporting, the proposed Standard should focus on the single issue of correct reporting, without attempting to micromanage how Entities internally manage such reporting.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received.</p>		
BGE		<p>Please provide a Mapping Document which shows where the four CIP-001 requirements map to in the new EOP-004-2, and note if any of the CIP-001 requirements have been eliminated. A Mapping Document was provided during the first Comment Period, but not during the second Comment Period. A Mapping Document will be very helpful to companies in aligning standard owners in reviewing this proposal and in transitioning compliance programs when the revised standard is approved.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has a current Mapping Document and it will be updated to reflect the changes that the DSR SDT has made to EOP-004-2. This Mapping document will be posted with the standard when it is posted for comment and ballot.</p>		
CenterPoint Energy		<p>CenterPoint Energy believes the flowchart found on page 8 identifying the reporting hierarchy for EOP-004 is helpful. CenterPoint Energy believes the DOE reporting items should also be included on the right side of the chart. Some of the issues with CIP-001 were a result of law enforcement's preference and procedures for notification. Law enforcement's preferences and procedures should be considered for this draft. (Reference: <a href="http://www.fbi.gov/contact-us/when">http://www.fbi.gov/contact-us/when</a>)</p>
<ul style="list-style-type: none"> <li><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the flowchart and a current Mapping Document and it will be updated to reflect the changes that the DSR SDT has made to EOP-004-2. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading "Law Enforcement Reporting": "These are the types of events that should be reported to law enforcement." The entire paragraph is:                       "The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact</li> </ul>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 17 Comment
<p>a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.”</p>		
PPL Electric Utilities		<p>We thank the SDT for addressing so many Industry concerns with the 2010 draft of EOP-004-2. We feel the current draft version of EOP-004-2 is a significant improvement over current EOP-004-1 and CIP-001-1 standard and the previous draft. Thank you for your time.</p>
<p><b>Response:</b> Thank you for your comment.</p>		
Occidental Power Marketing		<p>Occidental Power Marketing appreciates the extensive work accomplished by the SDT and their responsiveness to comments. Also, the presentation of this draft with its extensive explanation of the SDT's considerations during development of the draft were very helpful in preparing our comments.</p>
<p><b>Response:</b> Thank you for your comment.</p>		
Constellation Power Generation		<p>CPG has the following comments regarding Attachment 2: Generally, this attachment is inadequate for all events. The real-life experience with the recent SW cold snap demonstrated that the questions inadequately capture what may be of greatest concern in the situation. Question 4 ? this question is vague. It should be removed. Question 7 ? the role of generation in an event may not always be related to a trip. As experienced with the recent SW cold snap, this question may inadequately capture information relevant to the situation at hand. The drafting team should reassess how best to gather information relevant to the event and useful for evaluation. Question 8 ? generation is not required to monitor frequency during events, so this would not be answered. This question also assumes that frequency had been impacted, which is not always the case (i.e., the plant could not come online). The asterisk on some questions in Attachment 2 is not defined.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received. Attachment 2 has been streamlined to match the types of events that are to be reported. The purpose of this standard is to have events reported. Once reported, the events are included in the NERC Events Analysis Program for possible further investigation. The asterisk has been removed from Attachment 2.</p>		
Georgia System Operations Corporation		<p>Attachment 2: Impact Event Reporting Form-Instructions for filling out this form are needed.-Line 7, Generation tripped off-line: What is the asterisk for after this task and after the many others following? This should only be reported by a BA. Does generation ?tripped off-line? mean the same as generation ?lost??-Line 9, List of transmission facilities (lines, transformers, buses, etc.) tripped and locked-out: Does this means the same as BES Transmission Elements lost?-Line 10: The column headings in white text on lighter blue</p>

Organization	Yes or No	Question 17 Comment
		<p>background at the top do not seem to apply from this line on.-Line 11, Restoration Time: Restoration of what? Initial/Final clock time? Transmission? What about transmission? Generation/Demand?-Line 13, Identify the initial probable cause or known root cause of the actual or potential Impact Event if known at time of submittal of Part I of this report: ?At the time of submittal of Part I of this report??? Where is Part II? Did you mean Part A? Is Part B to be submitted at a different time?Background-Page 5, last sentence which is continued on page 6: This standard does not recognize the various ?versions? of companies in the industry. The standard is made applicable to a long list of registered entity types. In many cases, many of these entities are wrapped into one company. A company may be responsible for ?everything? in a geographic area. It may be almost every registered entity type with no other registered entities within its geographic area. There should be no conflicts or need for coordination with others for this company. Everything would be coordinated internally within that one company before being reported to NERC and no one else would be reporting to NERC.However, sometimes one company is only a LSE. When an LSE-only is having a LSE impact event, the LSE should report to some higher operating entity like its BA and should not report to NERC. Reporting should be done in a hierarchical manner within appropriate operating entities and then reported to NERC at the RC (or BA) level or as agreed among entities in any coordinated impact event reporting plans. The RC, BA, TOP, and LSE should not all be held accountable for reporting the same event.This standard does not deal exclusively with after-the-fact reporting. Some events deal with the condition of the system (risk of possible future events) or condition of an entity?s ability to operate (supplying fuel, covering load, etc.) or with a threat to the BES.-Page 6, Summary of Concepts: A single form may have been an objective but it is obviously not a concept being implemented by the standard. There are two forms.-Page 6, Law Enforcement Reporting: The object of the standard may be to prevent or reduce the risk of Cascading. Reporting system situations to appropriate operating entities who can take some mitigating action (e.g., a LSE reporting to its BA or a BA reporting to its RC) and reporting threats to law enforcement officials could prevent or reduce the risk of Cascading but reporting to NERC is unlikely to a do that. Reporting of most of the listed events to NERC does not meet the objective of this standard and should be removed from this standard. Such events should be reported to NERC through some other (than a Reliability Standard) requirement for reporting to NERC so that NERC can accomplish its mission of analyzing events. Analyzing events may lead to an understanding that could reduce the future risk of Cascading but not any impending risks.-Page 6, Stakeholders: What is ?Homeland Security ? State?? We know what the Department of Homeland Security and the State Department are but this term is not clear. -Page 6, ?State Regulators?, ?Local Law Enforcement?, and State Law Enforcement?: These are not proper nouns/names and are not defined in the NERC Glossary. They should not be capitalized.-Pages 7 &amp; 8, Law enforcement: Is each entity required to determine procedures for reporting to law enforcement and work it out with the state law enforcement agency? Do the state law enforcement agencies know this? Or is there a pre-determine procedure that is already worked out with the state law enforcement agency that entities are to follow?</p>
<ul style="list-style-type: none"> <li>• <b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received.</li> </ul>		

**Consideration of Comments on Disturbance & Sabotage Reporting – 2009-01**

Organization	Yes or No	Question 17 Comment
<p>Attachment 2 has been streamlined to match the types of events that are to be reported. The purpose of this standard is to have events reported. Once reported, the events are included in the NERC Events Analysis Program for possible further investigation. The background section of the standard provides guidance with respect to reporting events to law enforcement. For clarity, the DSR SDT has added the following sentence to the first paragraph under the heading "Law Enforcement Reporting": "These are the types of events that should be reported to law enforcement." The entire paragraph is:</p> <p>"The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES."</p>		
City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power		We like the option to use the OE_417 as the reporting form for these events.
<p><b>Response:</b> The DSR DT thanks you for your comment. EOP-004-2 allows entities to utilize the DOE Form OE-417 to report events.</p>		
Indeck Energy Services		This revision seriously missed the mark.
<p><b>Response:</b> The DSR DT thanks you for your comment. The DSR SDT has updated the requirements and Attachments 1 and 2 per comments received.</p>		
Progress Energy		<p>Progress thanks the Standard Drafting Team for their efforts on this project. The BES definition is still being revised under "Project 2010-17: Proposed Definition of Bulk Electric System." "BES equipment" is mentioned several times in this Standard. A better definition of BES is important to the effectiveness of this Standard and integral to entities ability to comply with the Standard requirements. In Attachment 2, on the Impact Event Reporting form, item 10 is "Demand Tripped" and the categories include "FIRM" and "INTERRUPTIBLE." It is unclear why interruptible load is included on the reporting form.</p>
<p><b>Response:</b> The DSR DT thanks you for your comment. The definition of BES will apply to this standard after it is approved by stakeholders, the NERC BOT and FERC. The DSR SDT has updated the requirements, Attachments 1 and 2 per comments received. Attachment 2 has been streamlined to match the types of events that are to be reported. The purpose of this standard is to have events reported. Once reported, the events are included in the NERC Events Analysis Program for possible further investigation. Firm and Interruptible load have been removed from the list of reportable events in Attachment 1.</p>		





## Standard Development Timeline

---

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 15 – October 15, 2010)
6. Second Comment Period (Formal) (March 9 – April 8, 2011)

### Proposed Action Plan and Description of Current Draft

This is the third posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a 45-day formal comment period concurrent with the formation of the ballot pool and the initial ballot.

### Future Development Plan

Anticipated Actions	Anticipated Date
Drafting team considers comments, makes conforming changes on second posting	April - October 2011
Third Comment/Ballot period	November-December 2011
Recirculation Ballot period	December 2011
Receive BOT approval	February 2012

### Effective Dates

EOP-004-2 shall become effective on the first day of the third calendar quarter after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the third calendar quarter after Board of Trustees approval.

### Version History

Version	Date	Action	Change Tracking
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Impact Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting. Retire CIP-008-4, Requirement 1, Part 1.3.	Revision to entire standard (Project 2009-01)

### **Definitions of Terms Used in Standard**

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## A. Introduction

1. **Title:** Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities.

### 4. Applicability

- 4.1. **Functional Entities: Within the context of EOP-004-2, the term “Responsible Entity” shall mean:**

- 4.1.1. Reliability Coordinator
- 4.1.2. Balancing Authority
- 4.1.3. Interchange Coordinator
- 4.1.4. Transmission Service Provider
- 4.1.5. Transmission Owner
- 4.1.6. Transmission Operator
- 4.1.7. Generator Owner
- 4.1.8. Generator Operator
- 4.1.9. Distribution Provider
- 4.1.10. Load Serving Entity
- 4.1.11. Electric Reliability Organization
- 4.1.12. Regional Entity

### 5. Background:

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

### Summary of Key Concepts

The DSRSDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the bulk electric system
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. Attachment 1, Part A pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. Attachment 1, Part B covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.

The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting.

### **Data Gathering**

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### **Law Enforcement Reporting**

The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### **Stakeholders in the Reporting Process**

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. Annual requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, responsible entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, , the number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**

A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).


### **A Reporting Process Solution – EOP-004**

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to

notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.



Reporting Hierarchy for Reportable Events



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

## B. Requirements and Measures

**R1.** Each Responsible Entity shall have an Operating Plan that includes: [*Violation Risk: Factor: Lower*] [*Time Horizon: Operations Planning*]

- 1.1. A process for identifying events listed in Attachment 1.
- 1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.
- 1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate:
  - Internal company personnel
  - The Responsible Entity's Regional Entity
  - Law enforcement
  - Governmental or provincial agencies
- 1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3.
- 1.5. A Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.

**M1.** Each Responsible Entity will provide the current, dated, in force Operating Plan which includes Parts 1.1 - 1.5 as requested.

### Rationale for R1

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective.

For the Operating Plan, Part 1.2 includes information gathering to be able to complete the report for reportable events. The main issue is to make sure an entity can a) identify when an event has occurred and b) be able to gather enough information to complete the report.

Part 1.3 could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated telephone numbers.

**R2.** Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified. *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*.

**M2.** Responsible Entities shall provide evidence that it implemented the parts of its Operating Plan to meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts, 1.4 and 1.5 as specified. Evidence may include, but is not limited to, an event report form (Attachment 2) or the OE-417 report submitted, operator logs, voice recordings, or dated documentation of review and update of the Operating Plan. (R2)

### **Rationale for R2**

Each Responsible Entity must implement the various parts of Requirement R1. Parts 1.1 and 1.2 call for identifying and gathering information for actual events. Parts 1.4 and 1.5 require updating and reviewing the Operating Plan.

**R3.** Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*.

**M3.** Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported. (R3)

### **Rationale for R3**

Each Responsible Entity must report events via its Operating Plan based on Attachment 1. For each event listed in Attachment 1, there are entities listed that are to be notified as well as the time required to perform the reporting.

**R4.** Each Responsible Entity shall verify (through actual implementation for an event, or through a drill or exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification or actual implementation. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*

### **Rationale for R4**

Each Responsible Entity must verify that its Operating Plan for communicating events is correct so that the entity can respond appropriately in the case of an actual event. The Responsible Entity may conduct a drill or exercise to test its Operating Plan for communicating events as often as it desires but the time period between tests can be no longer than 15 calendar months from the previous drill/exercise or actual event (i.e., if you conducted an exercise/drill/actual employment of the Operating Plan in January of one year, there would be another exercise/drill/actual employment by March 31 of the next calendar year). Multiple exercises in a 15 month period are not a violation of the requirement and would be encouraged to improve reliability. Evidence showing that an entity used the communication process in its Operating Plan for an actual event qualifies as evidence to meet this requirement.

- M4.** The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan for events created pursuant to Requirement R1, Part 1.3. Either implementation of the communication process as documented in its Operating Plan for an actual event or documented evidence of a drill or exercise may be used as evidence to meet this requirement. The time period between an actual event or verification shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a verification. (R3)

## **C. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1 Compliance Enforcement Authority**

Regional Entity; or

If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement; or

Third-party monitor without vested interest in the outcome for the ERO

.

#### **1.2 Evidence Retention**

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

Each Responsible Entity shall retain the current, in force document plus the ‘dated revision history’ from each version issued since the last audit for 3 calendar years for Requirement R1 and Measure M1.

Each Responsible Entity shall retain evidence from prior 3 calendar years for Requirements R2, R3, R4, and Measures M2, M3, M4.

Each Responsible Entity shall retain data or evidence for three calendar years or for the duration of any regional or Compliance Enforcement Authority investigation; whichever is longer.

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

**1.3 Compliance Monitoring and Enforcement Processes:**

Compliance Audits  
Self-Certifications  
Spot Checking  
Compliance Violation Investigations  
Self-Reporting  
Complaints

**1.4 Additional Compliance Information**

None

Table of Compliance Elements

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
<b>R1</b>	Long-term Planning	Lower	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has an Operating Plan but failed to include one of Parts 1.1 through 1.5.	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has an Operating Plan but failed to include two of Parts 1.1 through 1.5.	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has an Operating Plan but failed to include three of Parts 1.1 through 1.5.	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to include four or more of Parts 1.1 through 1.5.
<b>R2</b>	Real-time Operations and Same-day Operations	Medium	1.1: N/A  1.2: N/A  1.4: The Reliability Coordinator, Balancing Authority,	1.1: N/A  1.2: N/A  1.4: The Reliability Coordinator, Balancing Authority,	1.1: N/A  1.2: N/A  1.4: The Reliability Coordinator, Balancing Authority,	1.1: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator

			<p>Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan more than 90 days of a change, but not more than 100 days after a change.</p> <p>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more</p>	<p>Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan more than 100 days of a change, but not more than 110 days after a change.</p> <p>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 18 calendar</p>	<p>Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan more than 110 days of a change, but not more than 120 days after a change.</p> <p>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 21 calendar</p>	<p>Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to implement the process for identifying events.</p> <p>1.2: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to implement the process for gathering information for Attachment 2.</p> <p>1.4: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator</p>
--	--	--	--	--	--	--

**EOP-004-2 — Event Reporting**

			than 15 calendar months after its previous review, but not more than 18 calendar months after its previous review.	months after its previous review, but not more than 21 calendar months after its previous review.	months after its previous review, but not more than 24 calendar months after its previous review.	Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan more than 120 days of a change.  1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 24 calendar months after its previous review.
<b>R3</b>	Real-time Operations and Same-day Operations	Medium	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator



EOP-004-2 — Event Reporting

			<p>Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 24 hours but less than or equal to 36 hours after an event requiring reporting within 24 hours in Attachment 1.</p>	<p>Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 36 hours but less than or equal to 48 hours after an event requiring reporting within 24 hours in Attachment 1.</p> <p>OR</p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 1 hour but less than 2 hours after an event requiring reporting within 1 hour in Attachment 1.</p>	<p>Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 48 hours but less than or equal to 60 hours after an event requiring reporting within 24 hours in Attachment 1.</p> <p>OR</p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report in more than 2 hours but less than 3 hours after an event requiring reporting within 1 hour in Attachment 1.</p>	<p>Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 60 hours after an event requiring reporting within 24 hours in Attachment 1.</p> <p>OR</p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 3 hours after an event requiring reporting within 1 hour in Attachment 1.</p> <p>OR</p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator,</p>
--	--	--	---	---	---	---

**EOP-004-2 — Event Reporting**

						Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to submit a report for an event in Attachment 1.
<b>R4</b>	Operations Planning	Medium	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 15 calendar months after its previous test, but not more than 18 calendar months after its previous test.  OR	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 18 calendar months after its previous test, but not more than 21 months after its previous test.	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 21 calendar months after its previous test, but not more than 24 months after its previous test.	The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 24 calendar months after its previous test.  OR The Reliability Coordinator, Balancing Authority, Interchange

**EOP-004-2 — Event Reporting**

			<p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to verify the communication process in its Operating Plan within the calendar year.</p>			<p>Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to verify the communication process in its Operating Plan.</p>
--	--	--	--	--	--	---

**D. Variances**

None.

**E. Interpretations**

None.

**F. Interpretations**

Guideline and Technical Basis (attached).

**EOP-004 - Attachment 1: Events Table**

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. The affected Responsible Entity shall provide periodic verbal updates until adequate information is available to issue a written Event report. Reports to the ERO should be submitted to one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, Voice: 609-452-1422.

Attachment 1 - Reportable Events			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Submit Attachment 2 or DOE OE-417 Report to:
Destruction of BES equipment <sup>1</sup>	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the destruction of BES equipment	Initial indication the event was due to operational error, equipment failure, external cause, or intentional or unintentional human action.	The parties identified pursuant to R1.3 within 1 hour of recognition of event.
Damage or destruction of Critical Asset per CIP-002	Applicable Entities under CIP-002	Initial indication the event was due to operational error, equipment failure, external cause, or intentional or unintentional human action.	The parties identified pursuant to R1.3 within 1 hour of recognition of event.
Damage or destruction of a Critical Cyber Asset per CIP-002	Applicable Entities under CIP-002.	Through intentional or unintentional human action.	The parties identified pursuant to R1.3 within 1 hour of recognition of event.
Forced intrusion <sup>2</sup>	Each RC, BA, TO, TOP, GO, GOP that experiences the	At a BES facility	The parties identified pursuant to R1.3 within 1 hour of recognition of

<sup>1</sup>BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service. Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).

<sup>2</sup> Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).

**EOP-004-2 — Event Reporting**

Attachment 1 - Reportable Events			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Submit Attachment 2 or DOE OE-417 Report to:
	forced intrusion		event.
Risk to BES equipment <sup>3</sup>	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the risk to BES equipment	From a non-environmental physical threat	The parties identified pursuant to R1.3 within 1 hour of recognition of event.
Detection of a reportable Cyber Security Incident.	Each RC, BA, TO, TOP, GO, GOP, DP, ERO or RE that experiences the Cyber Security Incident	That meets the criteria in CIP-008	The parties identified pursuant to R1.3 within 1 hour of recognition of event.
BES Emergency requiring public appeal for load reduction	Deficient entity is responsible for reporting	Each public appeal for load reduction	The parties identified pursuant to R1.3 within 24 hours of recognition of the event.
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more	The parties identified pursuant to R.1.3 within 24 hours of recognition of the event.
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq$ 100 MW	The parties identified pursuant to R1.3 within 24 hours of recognition of the event.
BES Emergency resulting in automatic firm load shedding	Each DP or TOP that experiences the automatic load shedding	Firm load shedding $\geq$ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)	The parties identified pursuant to R1.3 within 24 hours of recognition of the event.
Voltage deviations on BES Facilities	Each TOP that experiences the voltage deviation	$\pm$ 10% sustained for $\geq$ 15 continuous minutes	The parties identified pursuant to R1.3 within 24 hours after 15 minutes of exceeding the threshold.

<sup>3</sup> Examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment.

**EOP-004-2 — Event Reporting**

Attachment 1 - Reportable Events			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Submit Attachment 2 or DOE OE-417 Report to:
IROL Violation (all Interconnections) or SOL Violation (WECC only)	Each RC that experiences the IROL Violation (all Interconnections) or SOL violation (WECC only)	Operate outside the IROL for time greater than IROL Tv (all Interconnections) or Operate outside the SOL for a time greater than the SOL Tv (WECC only).	The parties identified pursuant to R1.3 within 24 hours after exceeding the Tv threshold.
Loss of Firm load for $\geq$ 15 Minutes	Each BA, TOP, DP that experiences the loss of firm load	<ul style="list-style-type: none"> <li><math>\geq</math> 300 MW for entities with previous year's demand <math>\geq</math> 3000 MW</li> <li><math>\geq</math> 200 MW for all other entities</li> </ul>	The parties identified pursuant to R1.3 24 hours after exceeding the 15 minute threshold
System Separation (Islanding)	Each RC, BA, TOP, DP that experiences the system separation	Each separation resulting in an island of generation and load $\geq$ 100 MW	The parties identified pursuant to R1.3 within 24 hours after occurrence is identified
Generation loss	Each BA, GOP that experiences the generation loss	<ul style="list-style-type: none"> <li><math>\geq</math> 2,000 MW for entities in the Eastern or Western Interconnection</li> <li><math>\geq</math> 1000 MW for entities in the ERCOT or Quebec Interconnection</li> </ul>	The parties identified pursuant to R1.3 within 24 hours after occurrence.
Loss of Off-site power to a nuclear generating plant (grid supply)	Each TO, TOP that experiences the loss of off-site power to a nuclear generating plant	Affecting a nuclear generating station per the Nuclear Plant Interface Requirement	The parties identified pursuant to R1.3 within 24 hours after occurrence
Transmission loss	Each TOP that experiences the transmission loss	Unintentional loss of Three or more Transmission Facilities (excluding successful automatic reclosing)	The parties identified pursuant to R1.3 within 24 hours after occurrence
Unplanned Control Center evacuation	Each RC, BA, TOP that experiences the potential event	Unplanned evacuation from BES control center facility	The parties identified pursuant to R1.3 within 24 hours of recognition of event.
Loss of monitoring or all voice	Each RC, BA, TOP that experiences the loss of	Voice Communications: Affecting a BES control center for $\geq$ 30 continuous minutes	The parties identified pursuant to R1.3 within 24 hours of recognition

Attachment 1 - Reportable Events			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Submit Attachment 2 or DOE OE-417 Report to:
communication capability	monitoring or all voice communication capability	Monitoring: Affecting a BES control center for $\geq 30$ continuous minutes such that analysis tools (State Estimator, Contingency Analysis) are rendered inoperable.	of event.

EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004, Attachment 2: Event Reporting Form</b>	
<p>This form is to be used to report events to parties listed in Attachment 1, column labeled “Submit Attachment 2 or DOE OE-417 Report to:”. These parties will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted via one of the following: e-mail: <a href="mailto:esisac@nerc.com">esisac@nerc.com</a>, Facsimile: 609-452-9550, voice: 609-452-1422.</p>	
Task	Comments
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:
3.	Did the actual or potential event originate in your system?  Actual event <input type="checkbox"/> Potential event <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
4.	<b>Event Identification and Description:</b>
(Check applicable box) <input type="checkbox"/> public appeal <input type="checkbox"/> voltage reduction <input type="checkbox"/> manual firm load shedding <input type="checkbox"/> firm load shedding(undervoltage, underfrequency, SPS/RAS) <input type="checkbox"/> voltage deviation <input type="checkbox"/> IROL violation	Written description (optional unless Other is checked):



**EOP-004, Attachment 2: Event Reporting Form**

This form is to be used to report events to parties listed in Attachment 1, column labeled “Submit Attachment 2 or DOE OE-417 Report to:”. These parties will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, voice: 609-452-1422.

Task	Comments
<ul style="list-style-type: none"> <li><input type="checkbox"/> loss of firm load</li> <li><input type="checkbox"/> system separation(islanding)</li> <li><input type="checkbox"/> generation loss</li> <li><input type="checkbox"/> loss of off-site power to nuclear generating plant</li> <li><input type="checkbox"/> transmission loss</li> <li><input type="checkbox"/> damage or destruction of BES equipment</li> <li><input type="checkbox"/> damage or destruction of Critical Asset</li> <li><input type="checkbox"/> damage or destruction of Critical Cyber Asset</li> <li><input type="checkbox"/> unplanned control center evacuation</li> <li><input type="checkbox"/> fuel supply emergency</li> <li><input type="checkbox"/> loss of all monitoring or voice communication capability</li> <li><input type="checkbox"/> forced intrusion Risk to BES equipment</li> <li><input type="checkbox"/> reportable Cyber Security Incident</li> <li><input type="checkbox"/> other</li> </ul>	

## Guideline and Technical Basis

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standard deals exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### Summary of Concepts and Assumptions:

##### *The Standard:*

- Requires reporting of “events” that impact or may impact the reliability of the bulk electric system
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

#### **Discussion of Disturbance Reporting**

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.

3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (attachment 1).

### **Discussion of Event Reporting**

There are situations worthy of reporting because they have the potential to impact reliability.

Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008 or its successor standard
- Forced intrusion attempt at a substation
- Train derailment near a transmission right-of-way
- Destruction of Bulk Electrical System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electrical System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of impact events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering necessary for event analysis is provided for under the Events Analysis Program and the NERC

Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

## Standard Development Timeline

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September ~~15~~ – ~~October 15~~, 2010)
6. Second Comment Period (Formal) (March 9 – April 8, 2011)

### Proposed Action Plan and Description of Current Draft

This is the ~~first~~third posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a ~~30~~45-day formal comment period concurrent with the formation of the ballot pool and the initial ballot.

### Future Development Plan

Anticipated Actions	Anticipated Date
Drafting team considers comments, makes conforming changes, <del>and proceed to on</del> second <del>comment</del> <u>posting</u>	<del>April - October 2010</del> – <del>February 2011</del>
<del>Second Comment Period</del>	<del>March – May 2011</del>
Third Comment/Ballot period	<del>June - July</del> <u>November - December</u> 2011
Recirculation Ballot period	<del>July - August</del> <u>December</u> 2011
Receive BOT approval	<del>September 2011</del> <u>February 2012</u>

### Effective Dates

1. ~~The standard~~ EOP-004-2 shall become effective on the first ~~calendar~~ day of the third calendar quarter after ~~the date of the order providing~~ applicable regulatory approval.
2. In those jurisdictions where no regulatory approval is required, ~~the~~ this standard shall become effective on the first ~~calendar~~ day of the third calendar quarter after Board of Trustees ~~adoption~~ approval.

### Version History

Version	Date	Action	Change Tracking
2		Merged CIP-001- <del>12a</del> Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Impact Event Reporting; Retire CIP-001- <del>1a2a</del> Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting. – <u>Retire CIP-008-4, Requirement 1, Part 1.3.</u>	Revision to entire standard (Project 2009-01)

## Definitions of Terms Used in Standard

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

~~**Impact Event: Any event which has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.**~~

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## **A. Introduction**

1. **Title:** ~~Impact~~ Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of ~~Impact Event~~events with the potential to impact reliability and their causes, if known, by the Responsible Entities.
4. **Applicability**
  - 4.1. **Functional Entities: Within the context of EOP-004-2, the term “Responsible Entity” shall mean:**
    - 4.1.1. Reliability Coordinator
    - 4.1.2. Balancing Authority
    - 4.1.3. Interchange ~~Authority~~Coordinator
    - 4.1.4. Transmission Service Provider
    - 4.1.5. Transmission Owner
    - 4.1.6. Transmission Operator
    - 4.1.7. Generator Owner
    - 4.1.8. Generator Operator
    - 4.1.9. Distribution Provider
    - ~~4.1.10. Load Serving Entity~~
    - 4.1.11. Electric Reliability Organization
    - 4.1.12. Regional Entity

## **5. Background:**

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 ~~may~~could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 ~~has~~had some ‘fill-in-the-blank’ components to eliminate.



The development ~~may include~~included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards ~~(see tables for each standard at the end of this SAR for more detailed information).~~.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009. ~~A “concepts paper” was designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.~~

~~The~~  
The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the ~~SDR~~DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the ~~SDR~~DSR SDT.

The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

~~The DSR SDT has used a working definition for “Impact Events” to develop Attachment 1 as follows:~~

~~“An Impact Event is any event that has either impacted or has the potential to impact the reliability of the Bulk Electric System. Such events may be caused by equipment failure or mis-operation, environmental conditions, or human action.”~~

~~The DSR SDT has proposed this definition for~~  
**Summary of Key Concepts**

The DSRSDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the bulk electric system
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion in the NERC Glossary for “Impact Event”. The types of Impact Events that are required to be reported are contained within Attachment 1. Only these events are required to be reported under this Standard. The DSR SDT of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

~~During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage” and”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was that of sabotage or merely vandalism without the intervention of law enforcement after the fact. This will. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The Impact Events events listed in Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive. Attachment 1, Part A is to be used for those actions that have impacted the electric system and in particular the section “Damage or destruction to equipment” clearly defines that all equipment that intentional or non-intentional human error be reported. Attachment 1, Part B covers the similar items but the action has not fully occurred but may cause a risk to the electric system and is required to be reported.~~

~~To support this concept, the The types of events that are required to be reported are contained within Attachment 1. The DSR SDT has provided specific event for reporting including types of Impact coordinated with the NERC Events and timing thresholds pertaining to Analysis Working Group to develop the different types of Impact Events and who’s responsibility for reporting list of events that are to be reported under the different Impact Events. This information is outlined in Attachment 1 to the proposed this standard. Attachment 1, Part A pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. Attachment 1, Part B covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.~~

The DSR SDT wishes to make clear that the proposed ~~changes do~~ Standard does not include any real-time operating notifications for the ~~types of events covered by CIP-001, EOP-004. This listed in Attachment 1.~~ Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. ~~TOP~~ the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting.

~~The DSR SDT is proposing to consolidate disturbance and Impact Event reporting under a single standard. These two components and other key concepts are discussed in the following sections:~~

### **Summary of Concepts**

- ~~• A single form to report disturbances and Impact Events that threaten the reliability of the bulk electric system~~
- ~~• Other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements~~
- ~~• Clear criteria for reporting~~
- ~~• Consistent reporting timelines~~
- ~~• Clarity around of who will receive the information and how it will be used~~

## Data Gathering

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

## **Law Enforcement Reporting**

The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting ~~Impact Events~~. Certain outages, such as those due to vandalism and terrorism, ~~are may~~ not ~~be reasonably~~ preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those ~~Impact Event~~ events which have the potential ~~to impact a~~ wider area ~~affected upon the industry which of the BES.~~ The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of bulk power systems from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading ~~involving Impact Events~~. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

## **Stakeholders in the Reporting Process**

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

**Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The ~~present~~ CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and ~~the~~ FBI ~~or~~ RCMP. Annual requirements, under the standard, of the industry have not been clear and have led to misunderstandings and confusion in the industry as to how to demonstrate ~~that~~ the liaison is in place and effective. ~~FBI offices~~ As an example of proof of compliance with Requirement R4, responsible entities have ~~been~~ asked FBI Office personnel to ~~confirm~~ provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage ~~to include references to, , the number of~~ years the liaison relationship has been in existence, and ~~confirming~~ the validity of the telephone numbers for the FBI.

**Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, ~~passionately~~ committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

**Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**


A similar law ~~enforcement~~ enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the ~~Royal~~ Royal Canadian Mounted Police (RCMP).

**A Reporting Process Solution – EOP-004**

A proposal discussed with ~~the~~ FBI, FERC Staff, NERC Standards Project Coordinator and ~~the~~ SDT Chair is reflected in the flowchart below (Reporting Hierarchy for ~~Impact Event EOP-004-2~~ Reportable Events). Essentially, reporting an ~~Impact Event~~ event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with ~~local~~ law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and


investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Reporting Hierarchy for Reportable Events



\*Canadian entities will follow law enforcement protocols applicable in their jurisdictions

Reporting Hierarchy for Reportable Events



\*Canadian entities will follow law enforcement protocols applicable in their jurisdictions

**B. Requirements and Measures**

**R1.** Each Responsible Entity shall have an **Impact Event** Operating Plan that includes: [*Violation Risk: Factor-Medium: Lower*] [*Time Horizon: Long-term*] [*Operations Planning*]

- 1.1. ~~An Operating Process~~ A process for identifying **Impact Event** ~~events~~ events listed in Attachment 1.
- 1.2. ~~An Operating Procedure~~ A process for gathering information for Attachment 2 regarding ~~observed Impact Event~~ events listed in Attachment 1.
- 1.3. ~~An Operating Process~~ A process for communicating ~~recognized Impact Events~~ events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate:
  - Internal company personnel notification(s).
  - ~~External organizations to notify to include but not limited to the Responsible Entities' Reliability Coordinator, NERC, The Responsible Entities' Entity's Regional Entity,~~
  - ~~Law Enforcement, and enforcement~~
  - Governmental or ~~Provincial Agencies~~ provincial agencies
- 1.4. Provision(s) for updating the Impact Event Operating Plan within 90 calendar days of any change to its content in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3.
- 1.5. A Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.

**Rationale for R1**

~~Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened and why it happened when Impact Events occur. This requirement has the Registered Entity establish documentation on how that procedure, process, or plan is organized.~~

~~For the Impact Event Operating Plan, the DSR SDT envisions that Part 1.2 includes performing sufficient analysis and information gathering to be able to complete the report for reportable Impact Events. The main issue is to make sure an entity can a) identify when an Impact Event has occurred and b) be able to gather enough information to complete the report.~~

~~Part 1.3 could include a process flowchart, identification of internal positions to be notified and to make notifications, or a list of personnel by name as well as telephone numbers.~~

~~The Impact Event Operating Plan may include, but not be limited to, the following: how the entity is notified of event's occurrence, person(s) initially tasked with the overseeing the assessment or analytical study, investigatory steps typically taken, and documentation of the assessment / remedial action plan.~~



- M1. Each Responsible Entity ~~shall~~will provide the current, dated, in force ~~Impact-Event~~ Operating Plan ~~to the Compliance Enforcement Authority~~which includes Parts 1.1 - 1.5 as requested.

**R2.** Each Responsible Entity shall implement the parts of its Impact Event Operating Plan documented in that meet Requirement R1 for Impact Events listed in Attachment 1 (Parts A1.1 and B)1.2 for an actual event and Parts 1.4 and 1.5 as specified. [Violation Risk Factor: Medium] [Time Horizon: ~~Real-time Operations and Same-day Operations~~Assessment].

**M2.** ~~To the extent that an~~ Responsible Entity has an Impact Event on its Facilities, the Responsible EntityEntities shall ~~documentation of provide evidence that it implemented the implementation parts of its Impact Event Operating Plans. Such evidence could Plan to meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts, 1.4 and 1.5 as specified.~~ Evidence may include, but is not limited to, an event report form (Attachment 2) or the OE-417 report submitted, operator logs, voice recordings, or other notations and documents retained by the Registered Entity for each Impact Event. dated documentation of review and update of the Operating Plan. (R2)

### **Rationale for R2**

Each Responsible Entity must implement the various parts of Requirement R1. Parts 1.1 and 1.2 call for identifying and gathering information for actual events. Parts 1.4 and 1.5 require updating and reviewing the Operating Plan.

**R3.** Each Responsible Entity shall conduct a test of report events in accordance with its Operating Process Plan developed to address the events listed in Attachment 1. [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment].

**M3.** Responsible Entities shall provide a record of the type of event experienced; a dated copy of the Attachment 2 form or OE-417 report; and dated and time-stamped transmittal records to show that the event was reported. (R3)

**R4.** Each Responsible Entity shall verify (through actual implementation for communicating recognized Impact

### **Rationale for R3**

The DSR SDT intends for each Responsible Entity to verify that its Operating Process for communicating recognized Impact Events is correct so that the entity can respond appropriately in the case of an actual Impact Event. The Responsible Entity may conduct a drill or exercise of its Operating Process for communicating recognized Impact Events as often as it desires but the time period between such drill or exercise can be no longer than 15 months from the previous drill/exercise or actual Impact Event (i.e., if you conducted an exercise/drill/actual employment of the Operating Process in January of one year, there would be another exercise/drill/actual employment by March 31 of the next calendar year)). Multiple exercises in a 15 month period are not a violation of the requirement and would be encouraged to improve reliability.

R  
E  
P  
e  
e  
e  
e  
t  
p  
c

ing  
:  
:tual  
or  
ig  
/een  
i the  
ie

Operating Plan in January of one year, there would be another exercise/drill/actual employment by March 31 of the next calendar year). Multiple exercises in a 15 month period are not a violation of the requirement and would be encouraged to improve reliability. Evidence showing that an entity used the communication process in its Operating Plan for an actual event qualifies as evidence to meet this requirement.

~~Events~~ an event, or through a drill or exercise) the communication process in its Operating Plan, created pursuant to Requirement ~~R+1~~, Part 1.3, at least annually, (once per calendar year), with no more than 15 calendar months between ~~tests~~. verification or actual implementation. [*Violation Risk: Factor: Medium*] [*Time Horizon: Long-term Operations Planning*]

~~M3. In the absence of an actual Impact Event, the~~ **M4.** The Responsible Entity shall provide evidence that it ~~conducted a mock Impact Event and followed~~ verified the communication process in its Operating ~~Process~~Plan for ~~communicating recognized Impact Event~~events created pursuant to Requirement R1, Part 1.3. Either implementation of the communication process as documented in its Operating Plan for an actual event or documented evidence of a drill or exercise may be used as evidence to meet this requirement. The time period between ~~an actual and~~event or ~~mock Impact Events~~verification shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation: of a verification. (R3)

~~R4. Each Responsible Entity shall review its Impact Event Operating Plan with those personnel who have responsibilities identified in that plan at least annually with no more than 15 calendar months between review sessions~~ [*Violation Risk: Factor Medium*] [*Time Horizon: Long-term Planning*].

~~M4. Responsible Entities shall provide the materials presented to verify content and the association between the people listed in the plan and those who participated in the review, documentation showing who was present and when internal personnel were trained on the responsibilities in the plan.~~

~~R5. Each Responsible Entity shall report Impact Events in accordance with the Impact Event Operating Plan pursuant to Requirement R1 and Attachment 1 using the form in Attachment 2 or the DOE OE-417 reporting form.~~ [*Violation Risk: Factor: Medium*] [*Time Horizon: Real-time Operations and Same-day Operations*].

~~M5. Responsible Entities shall provide evidence demonstrating the submission of reports using the plan created pursuant to Requirement R1 and Attachment 1 using either the form in Attachment 2 or the DOE OE-417 report. Such evidence will include a copy of the Attachment 2 form or OE-417 report submitted, evidence to support the type of Impact Event experienced; the date and time of the Impact Event; as well as evidence of report submittal that includes date and time.~~

## **C. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1 Compliance Enforcement Authority**

- Regional Entity; or
- If the Responsible Entity works for the Regional Entity, then the Regional Entity will establish an agreement with the ERO or another entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement; or

~~**Compliance Monitoring and Enforcement Processes:**~~

- ~~• Compliance Audits~~
- ~~• Self-Certifications~~
- ~~• Spot Checking~~
- ~~• Compliance Violation Investigations~~
- ~~• Self-Reporting~~
- ~~• Complaints~~

Third-party monitor without vested interest in the outcome for the ERO

:

**1.2 Evidence Retention**

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

Each Responsible Entity shall retain the current, in force document plus the ‘dated revision history’ from each version issued since the last audit for 3 calendar years for Requirement R1 and Measure M1.

Each Responsible Entity shall retain evidence from prior 3 calendar years for Requirements R2, R3, R4, and Measures M2, M3, M4.

Each Responsible Entity shall retain data or evidence for three calendar years or for the duration of any regional or Compliance Enforcement Authority investigation; whichever is longer.

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

**1.3 Compliance Monitoring and Enforcement Processes:**

Compliance Audits  
Self-Certifications  
Spot Checking  
Compliance Violation Investigations  
Self-Reporting

Complaints

1.4 Additional Compliance Information

None

Table of Compliance Elements

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
<b>R1</b>	Long-term Planning	<del>Medium</del> Lower	The <del>Responsible</del> Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has an <del>Impact Event</del> Operating Plan but failed to include one of Parts 1.1 through 1.45.	The <del>Responsible</del> Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has a <del>Impact Event</del> an Operating Plan but failed to include two of Parts 1.1 through 1.45.	The <del>Responsible</del> Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has an <del>Impact Event</del> Operating Plan but failed to include three of Parts 1.1 through 1.45.	The <del>Responsible</del> Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to include <del>all four or more</del> of Parts 1.1 through 1.45.
<b>R2</b>	Real-time Operations and Same-day	Medium	N/A	N/A	N/A	The Responsible Entity failed to implement its <del>Impact Event Operating Plan</del>

	Operations					for an Impact Event listed in Attachment 1.
<b>R3R2</b>	Long-term Planning Real-time Operations and Same-day Operations	Medium	<p><u>1.1: N/A</u></p> <p><u>1.2: N/A</u></p> <p><u>1.4: The Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to conduct a test of its update the Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 in Plan more than</u></p>	<p><u>1.1: N/A</u></p> <p><u>1.2: N/A</u></p> <p><u>1.4: The Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to conduct a test of its update the Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 in Plan more than</u></p>	<p><u>1.1: N/A</u></p> <p><u>1.2: N/A</u></p> <p><u>1.4: The Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to conduct a test of its update the Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 in Plan more than</u></p>	<p><u>1.1: The Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to conduct a test of its update the Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 in Plan more than</u></p> <p><u>1.2: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Generator</u></p>



			<p><u>90 days of a change, but not more than 100 days after a change.</u></p> <p><u>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 15 calendar months <del>but less</del>after its previous review, but not more than 18 calendar months- after its previous review.</u></p>	<p><u>100 days of a change, but not more than 110 days after a change.</u></p> <p><u>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 18 calendar months <del>but less</del>after its previous review, but not more than 21 calendar months after its previous review.</u></p>	<p><u>110 days of a change, but not more than 120 days after a change.</u></p> <p><u>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 21 calendar months <del>but less</del>after its previous review, but not more than 24 calendar months after its previous review.</u></p>	<p><u>Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to implement the process for gathering information for Attachment 2.</u></p> <p><u>1.4: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Process for communicating recognized Impact Events created pursuant to Requirement R1, Part 1.3 in Plan more than 120 days of a change.</u></p>
--	--	--	--	--	--	--

						<p><u>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 24 calendar months after its previous review.</u></p>
<b>R4</b>	Long-term Planning	Medium	The Responsible Entity failed to review its Impact-Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 15 months but less than 18 months.	The Responsible Entity failed to review its Impact-Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 18 months but less than 21 months.	The Responsible Entity failed to review its Impact-Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 21 months but less than 24 months.	The Responsible Entity failed to review its Impact-Event Operating Plan with those personnel who have responsibilities identified in that plan in more than 24 months
<b>R5R3</b>	Real-time	Medium	The	The	The	The <b>Responsible</b>

<p>Operations and Same-day Operations</p>		<p><del>Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</del> <del>failed to submit</del> <del>submitted</del> a report <del>in</del> <del>more than 24 hours but less than or equal to</del> 36 hours <del>for</del> <del>after</del> an <del>Impact Event</del> <del>event</del> requiring reporting within 24 hours in Attachment 1.</p> <p>OR</p> <p><del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner,</del></p>	<p><del>Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</del> <del>failed to submit</del> <del>submitted</del> a report <del>in</del> <del>more than 36 hours but less than or equal to</del> 48 hours <del>for</del> <del>after</del> an <del>Impact Event</del> <del>event</del> requiring reporting within 24 hours in Attachment 1.</p> <p>OR</p> <p><del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner,</del></p>	<p><del>Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</del> <del>failed to submit</del> <del>submitted</del> a report <del>in</del> <del>more than 48 hours but less than or equal to</del> 60 hours <del>for</del> <del>after</del> an <del>Impact Event</del> <del>event</del> requiring reporting within 24 hours in Attachment 1.</p> <p>OR</p> <p><del>The Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider,</del></p>	<p><del>Entity failed to submit a report in</del> <del>Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</del> <del>submitted a report more than 60 hours for</del> <del>after</del> an <del>Impact Event</del> <del>event</del> requiring reporting within 24 hours in Attachment 1.</p> <p>OR</p> <p><del>The Responsible Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner,</del></p>
---	--	--	--	--	--

				<p><u>Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</u> submitted a report more than 1 hour but less than 2 hours after an event requiring reporting within 1 hour in Attachment 1.</p>	<p><u>Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</u> failed to submit a report in more than 1 hour but less than 23 hours after an <del>Impact Event</del> event requiring reporting within 1 hour in Attachment 1.</p>	<p><u>Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</u> failed to submit a report in more than 23 hours after an <del>Impact Event</del> event requiring reporting within 1 hour in Attachment 1.</p> <p>OR</p> <p>The <del>responsible entity</del> <u>Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</u> failed to submit a report for an <del>Impact Event</del> event in Attachment 1.</p>
--	--	--	--	--	---	---

<p><b>R4</b></p>	<p><del>Operations Planning</del></p>	<p>Medium</p>	<p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 15 calendar months after its previous test, but not more than 18 calendar months after its previous test.</p> <p>OR</p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider,</p>	<p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 18 calendar months after its previous test, but not more than 21 months after its previous test.</p>	<p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 21 calendar months after its previous test, but not more than 24 months after its previous test.</p>	<p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 24 calendar months after its previous test.</p> <p>OR</p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator</p>
------------------	---------------------------------------	---------------	--	--	--	--

			<del>Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to verify the communication process in its Operating Plan within the calendar year.</del>			<del>Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to verify the communication process in its Operating Plan.</del>
--	--	--	--	--	--	--

**D. Variances**

None.

**E. Interpretations**

None.

**F. Interpretations**

Guideline and Technical Basis (attached).

EOP-004 - Attachment 1: **Impact** Events Table

NOTE: Under certain adverse conditions, (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an **Impact Event** and issue a written **Impact** Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify its Regional Entity(ies) and NERC, (e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, Voice: 609-452-1422) parties per R1 and provide as much information as is available, at the time of the notification. The affected Responsible Entity shall ~~then~~ provide periodic verbal updates until adequate information is available to issue a written **Impact** Event report.

EOP-004 – Attachment 1 – Actual Reliability Impact – Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
Energy Emergency requiring Public appeal for load reduction	Initiating entity is responsible for reporting	Each public appeal for load reduction	Within 1 hour of issuing a public appeal
Energy Emergency requiring system wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more	Within 1 hour after event is initiated
Energy Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq 100$ MW	Within 1 hour after event is initiated
Energy Emergency resulting in automatic firm load shedding	Each DP or TOP that experiences the Impact Event	Firm load shedding $\geq 100$ MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)	Within 1 hour after event is initiated
Voltage Deviations on BES Facilities	Each RC, TOP, GOP that experiences the Impact Event	$\pm 10\%$ sustained for $\geq 15$ continuous minutes	Within 24 hours after 15 minute threshold
IROL Violation	Each RC, TOP that experiences the Impact Event	Operate outside the IROL for time greater than IROL Tv	Within 24 hours after Tv threshold
Loss of Firm load for $\geq 15$ Minutes	Each RC, BA, TOP, DP that experiences the Impact Event	<ul style="list-style-type: none"> <li>• <math>\geq 300</math> MW for entities with previous year's demand <math>\geq 3000</math> MW</li> <li>• <math>\geq 200</math> MW for all other entities</li> </ul>	Within 1 hour after 15 minute threshold
System Separation	Each RC, BA, TOP, DP that	Each separation resulting in an island of	Within 1 hour after occurrence is

EOP-004 — Attachment 1 — Actual Reliability Impact — Part A			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
(Islanding)	experiences the Impact Event	generation and load $\geq$ 100 MW	identified
Generation loss	Each RC, BA, GOP that experiences the Impact Event	<ul style="list-style-type: none"> <li>• <math>\geq</math> 2,000 MW for entities in the Eastern or Western Interconnection</li> <li>• <math>\geq</math> 1000 MW for entities in the ERCOT or Quebec Interconnection</li> </ul>	Within 24 hours after occurrence
Loss of Off-site power to a nuclear generating plant (grid supply)	Each RC, BA, TO, TOP, GO, GOP that experiences the Impact Event	Affecting a nuclear generating station per the Nuclear Plant Interface Requirement	Report within 24 hours after occurrence
Transmission loss	Each RC, TOP that experiences the Impact Event	Three or more BES Transmission Elements	Within 24 hours after occurrence
Damage or destruction of BES equipment <sup>4</sup>	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the Impact Event	Through operational error, equipment failure, external cause, or intentional or unintentional human action.	Within 1 hour after occurrence is identified
Damage or destruction of Critical Asset	Applicable Entities under CIP-002 or its successor.	Through operational error, equipment failure, external cause, or intentional or unintentional human action.	Within 1 hour after occurrence is identified
Damage or destruction of a Critical Cyber Asset	Applicable Entities under CIP-002 or its successor.	Through intentional or unintentional human action.	Within 1 hour after occurrence is identified

<sup>4</sup>BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action; or iv) Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly e.g., removal of grounding straps rendering protective relaying inoperative.



EOP-004 — Attachment 1 – Potential Reliability Impact — Part B			
Event	Entity with Reporting Responsibility	Threshold for Reporting	Time to Submit Report
Unplanned Control Center evacuation	Each RC, BA, TOP that experiences the potential Impact Event	Unplanned evacuation from BES control center facility	Report within 24 hour after occurrence
Fuel supply emergency	Each RC, BA, GO, GOP that experiences the potential Impact Event	Affecting BES reliability <sup>2</sup>	Report within 1 hour after occurrence
Loss of all monitoring or voice communication capability	Each RC, BA, TOP that experiences the potential Impact Event	Affecting a BES control center for $\geq 30$ continuous minutes	Report within 24 hours after occurrence
Forced intrusion <sup>3</sup>	Each RC, BA, TO, TOP, GO, GOP that experiences the potential Impact Event	At a BES facility	Report within 1 hour after verification of intrusion

<sup>2</sup> Report if problems with the fuel supply chain result in the projected need for emergency actions to manage reliability.

<sup>3</sup> Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).

<del>Risk to BES equipment<sup>4</sup></del>	<del>Each RC, BA, TO, TOP, GO, GOP, DP that experiences the potential Impact Event</del>	<del>From a non-environmental physical threat</del>	<del>Report within 1 hour after identification</del>
<del>Detection of a reportable Cyber Security Incident.</del>	<del>Each RC, BA, TO, TOP, GO, GOP, DP that experiences the potential Impact Event</del>	<del>That meets the criteria in CIP-008 (or its successor)</del>	<del>Report within 1 hour after detection</del>

<sup>4</sup>~~Examples include a train derailment adjacent to BES equipment, that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment).~~

~~EOP-004 - Attachment 2: Impact Event Reporting Form~~

~~This form is to be used to report Impact Events Reports to the ERO. NERC will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, Voice: 609-452-1422.~~

<del>Attachment 1 - Reportable Events</del>				
<del>Event</del>	<del>Entity with Reporting Responsibility</del>	<del>Impact Event Threshold for Reporting for EOP-004-2</del>	<del>Submit Attachment 2 or DOE OE-417 Report to:</del>	
	<del>Task</del>	<del>Comments</del>		
<del>1. Destruction of BES equipment<sup>5</sup></del>	<del>Entity filing the report (include company name and Compliance Registration ID number): Each RC, BA, TO, TOP, GO, GOP, DP that experiences the destruction of BES equipment</del>	<del>Initial indication the event was due to operational error, equipment failure, external cause, or intentional or unintentional human action.</del>		<del>The parties identified pursuant to R1.3 within 1 hour of recognition of event.</del>
<del>2. Damage or destruction of Critical Asset per</del>	<del>Applicable Entities under CIP-002</del>	<del>Initial indication the event was due to operational error, equipment failure, external</del>		<del>Date and Time of Impact Event.</del>

<sup>5</sup>~~BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service. Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).~~

Attachment 1 – Reportable Events				
Event	Entity with Reporting Responsibility	Impact Event Threshold for Reporting for EOP-004-2	Submit Attachment 2 or DOE OE-417 Report to:	
	Task	Comments		
<u>CIP-002</u>		<u>cause, or intentional or unintentional human action.</u>	<u>-Date: (mm/dd/yyyy) —Time/Zone: The parties identified pursuant to R1.3 within 1 hour of recognition of event.</u>	
<u>3- Damage or destruction of a Critical Cyber Asset per CIP-002</u>	<u>Applicable Entities under CIP-002.</u>	<u>Through intentional or unintentional human action.</u>	<u>Name of contact person: Email address: Telephone Number: The parties identified pursuant to R1.3 within 1 hour of recognition of event.</u>	
<u>4- Forced intrusion<sup>6</sup></u>	<u>Did the actual or potential Impact Event originate in your system? Each RC, BA, TO, TOP, GO, GOP that experiences the forced intrusion</u>	<u>Actual Impact Event <input type="checkbox"/> Potential Impact Event <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/> <input type="checkbox"/> At a BES facility</u>	<u>The parties identified pursuant to R1.3 within 1 hour of recognition of event.</u>	

<sup>6</sup> Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).

Attachment 1 – Reportable Events				
Event	Entity with Reporting Responsibility	Impact Event Threshold for Reporting for EOP-004-2	Submit Attachment 2 or DOE OE-417 Report to:	
	Task	Comments		
5- <u>Risk to BES equipment</u> <sup>7</sup>	<u>Under which NERC function are you reporting? (RC, TOP, BA, other) Each RC, BA, TO, TOP, GO, GOP, DP that experiences the risk to BES equipment</u>	<u>From a non-environmental physical threat</u>	<u>The parties identified pursuant to R1.3 within 1 hour of recognition of event.</u>	
6- <u>Detection of a reportable Cyber Security Incident.</u>	<u>Each RC, BA, TO, TOP, GO, GOP, DP, ERO or RE that experiences the Cyber Security Incident</u>	<u>That meets the criteria in CIP-008</u>	<u>Brief Description of actual or potential Impact Event:</u> <u>(More detail should be provided in the Sequence of Events section below.)</u> <u>The parties identified pursuant to R1.3 within 1 hour of recognition of event.</u>	

<sup>7</sup> Examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment.

Attachment 1 – Reportable Events			
Event	Entity with Reporting Responsibility	<u>Impact Event Threshold for Reporting for EOP-004-2</u>	Submit Attachment 2 or DOE OE-417 Report to:
	Task	Comments	
7.	Generation tripped off line*.  MW Total  List units tripped		
8. <span style="background-color: yellow;">[REDACTED]</span> BES <u>Emergency requiring public appeal for load reduction</u>	Deficient entity is responsible for reporting	Each public appeal for load reduction	Frequency*:  Just prior to Impact Event (Hz):  Immediately after Impact Event (Hz max):  Immediately after Impact Event (Hz min): <u>The parties identified pursuant to R1.3 within 24 hours of recognition of the event.</u>
9. <span style="background-color: yellow;">[REDACTED]</span> BES <u>Emergency requiring system-wide voltage reduction</u>	Initiating entity is responsible for reporting	List transmission facilities (lines, transformers, buses, etc.) tripped and locked-out*.  (Specify System wide voltage level reduction of each facility listed), 3% or	<u>The parties identified pursuant to R.1.3 within 24 hours of recognition of the event.</u>

Attachment 1 – Reportable Events			
Event	Entity with Reporting Responsibility	Impact Event Threshold for Reporting for EOP-004-2	Submit Attachment 2 or DOE OE-417 Report to:
	Task	Comments	
		more	
<del>10.</del> <span style="background-color: yellow;">[REDACTED]</span> BES <u>Emergency requiring manual firm load shedding</u>	<del>Demand tripped (MW)*: Number of affected customers*: Demand lost (MW-Minutes)*: <u>Initiating entity is responsible for reporting</u></del>	<del>FIRM Manual firm load shedding <math>\geq</math> 100 MW</del>	<del>INTERRUPTIBLE The parties identified pursuant to R1.3 within 24 hours of recognition of the event.</del>
<del>11.</del>			
<del>12.</del>			
<del>13.</del>			

Attachment 1 – Reportable Events			
Event	Entity with Reporting Responsibility	Impact Event Threshold for Reporting for EOP-004-2	Submit Attachment 2 or DOE OE-417 Report to:
	Task	Comments	
<del>14.</del>	Restoration Time*:	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		
15. <span style="background-color: yellow;"> </span> <u>BES Emergency resulting in automatic firm load shedding</u>	Each DP or TOP that experiences the automatic load shedding	Sequence of Events of actual or potential Impact Event (if potential Impact Event, please describe your assessment of potential impact to BES):	The parties identified pursuant to R1.3 within 24 hours of recognition of the event.



Attachment 1 – Reportable Events			
Event	Entity with Reporting Responsibility	<u>Impact Event Threshold for Reporting for EOP-004-2</u>	Submit Attachment 2 or DOE OE-417 Report to:
	Task	Comments	
		<u>Firm load shedding <math>\geq 100</math> MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)</u>	
<del>Voltage deviations on BES Facilities</del>	<del>Each TOP that experiences the voltage deviation</del>	<del><math>\pm 10\%</math> sustained for <math>\geq 15</math> continuous minutes</del>	<del>The parties identified pursuant to R1.3 within 24 hours after 15 minutes of exceeding the threshold.</del>
<del>16. <u>IROL Violation (all Interconnections) or SOL Violation (WECC only)</u></del>	<del>Each RC that experiences the <u>IROL Violation (all Interconnections) or SOL violation (WECC only)</u></del>	<del>Identify the initial probable cause or known root cause of the actual or potential Impact Event if known at time of submittal of Part I of this report:</del>  <del><u>Operate outside the IROL for time greater than IROL</u></del> <del><u>Tv (all Interconnections) or</u></del> <del><u>Operate outside the SOL for</u></del>	<del>The parties identified pursuant to R1.3 within 24 hours after exceeding the Tv threshold.</del>

Attachment 1 – Reportable Events			
Event	Entity with Reporting Responsibility	Impact Event Threshold for Reporting for EOP-004-2	Submit Attachment 2 or DOE OE-417 Report to:
	Task	Comments	
		a time greater than the SOL Tv (WECC only).	
Loss of Firm load for $\geq 15$ Minutes	Each BA, TOP, DP that experiences the loss of firm load	<ul style="list-style-type: none"> <li><math>\geq 300</math> MW for entities with demand <math>\geq 3000</math> MW</li> <li><math>\geq 200</math> MW for all other entities</li> </ul>	The parties identified pursuant to R1.3 the entity's within 24 hours exceeding the 15-minute threshold
17. System Separation (Islanding)	Identify any protection system misoperation(s) <sup>8</sup> :  <u>Each RC, BA, TOP, DP that experiences the system separation</u>	Each separation resulting in an island of generation and load $\geq 100$ MW	The parties identified pursuant to R1.3 within 24 hours after occurrence is identified
Generation loss	Each BA, GOP that experiences the generation loss	<ul style="list-style-type: none"> <li><math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</li> <li><math>\geq 1000</math> MW for entities in the ERCOT or Quebec Interconnection</li> </ul>	The parties identified pursuant to R1.3 within 24 hours after occurrence.
Loss of Off-site	Each TO, TOP that	Affecting a nuclear	The parties identified pursuant to R1.3 within 24 hours after

<sup>8</sup> Only applicable if it is part of the impact event the responsible entity is reporting on

Attachment 1 – Reportable Events			
Event	Entity with Reporting Responsibility	Impact Event Threshold for Reporting for EOP-004-2	Submit Attachment 2 or DOE OE-417 Report to:
	Task	Comments	
power to a nuclear generating plant (grid supply)	experiences the loss of off-site power to a nuclear generating plant	generating station per the Nuclear Plant Interface Requirement	occurrence
Transmission loss	Each TOP that experiences the transmission loss	Unintentional loss of Three or more Transmission Facilities (excluding successful automatic reclosing)	The parties identified pursuant to R1.3 within 24 hours after occurrence
<u>Unplanned Control Center evacuation</u>	<u>Each RC, BA, TOP that experiences the potential event</u>	<u>Unplanned evacuation from BES control center facility</u>	<u>The parties identified pursuant to R1.3 within 24 hours of recognition of event.</u>
<del>18-</del> <u>Loss of monitoring or all voice communication capability</u>	<del>Additional Information</del> <u>Each RC, BA, TOP that helps to further explain experiences the actual loss of monitoring or potential Impact Event if needed.</u>  <u>all voice communication</u>	<u>Voice Communications: Affecting a BES control center for ≥ 30 continuous minutes</u>  <u>Monitoring: Affecting a BES control center for ≥ 30 continuous minutes such that analysis tools (State Estimator, Contingency Analysis) are rendered inoperable.</u>	<u>The parties identified pursuant to R1.3 within 24 hours of recognition of event.</u>

Attachment 1 – Reportable Events			
Event	Entity with Reporting Responsibility	<u>Impact Event Threshold for Reporting for EOP-004-2</u>	Submit Attachment 2 or DOE OE-417 Report to:
	Task	Comments	
	<u>capability</u>		

EOP-004 - Attachment 2: Event Reporting Form

<b><u>EOP-004, Attachment 2: Event Reporting Form</u></b>	
<p><b><u>This form is to be used to report events to parties listed in Attachment 1, column labeled "Submit Attachment 2 or DOE OE-417 Report to:". These parties will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, voice: 609-452-1422.</u></b></p>	
<b><u>Task</u></b>	<b><u>Comments</u></b>
<u>1.</u>	<p><u>Entity filing the report include:</u>  <u>Company name:</u>  <u>Name of contact person:</u>  <u>Email address of contact person:</u>  <u>Telephone Number:</u>  <u>Submitted by (name):</u></p>
<u>2.</u>	<p><u>Date and Time of recognized event.</u>  <u>Date: (mm/dd/yyyy)</u>  <u>Time: (hh:mm)</u>  <u>Time/Zone:</u></p>
<u>3.</u>	<p><u>Did the actual or potential event originate in your system?</u></p> <p>Actual event <input type="checkbox"/> Potential event <input type="checkbox"/>          Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/></p>
<u>4.</u>	<b><u>Event Identification and Description:</u></b>
<p><u>(Check applicable box)</u>  <input type="checkbox"/> <u>public appeal</u>  <input type="checkbox"/> <u>voltage reduction</u>  <input type="checkbox"/> <u>manual firm load shedding</u>  <input type="checkbox"/> <u>firm load shedding(undervoltage, underfrequency, SPS/RAS)</u>  <input type="checkbox"/> <u>voltage deviation</u>  <input type="checkbox"/> <u>IROL violation</u></p>	<p><u>Written description (optional unless Other is checked):</u></p>

**EOP-004, Attachment 2: Event Reporting Form**

**This form is to be used to report events to parties listed in Attachment 1, column labeled “Submit Attachment 2 or DOE OE-417 Report to:”. These parties will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, voice: 609-452-1422.**

<u>Task</u>	<u>Comments</u>
<ul style="list-style-type: none"> <li><input type="checkbox"/> <u>loss of firm load</u></li> <li><input type="checkbox"/> <u>system separation(islanding)</u></li> <li><input type="checkbox"/> <u>generation loss</u></li> <li><input type="checkbox"/> <u>loss of off-site power to nuclear generating plant</u></li> <li><input type="checkbox"/> <u>transmission loss</u></li> <li><input type="checkbox"/> <u>damage or destruction of BES equipment</u></li> <li><input type="checkbox"/> <u>damage or destruction of Critical Asset</u></li> <li><input type="checkbox"/> <u>damage or destruction of Critical Cyber Asset</u></li> <li><input type="checkbox"/> <u>unplanned control center evacuation</u></li> <li><input type="checkbox"/> <u>fuel supply emergency</u></li> <li><input type="checkbox"/> <u>loss of all monitoring or voice communication capability</u></li> <li><input type="checkbox"/> <u>forced intrusion Risk to BES equipment</u></li> <li><input type="checkbox"/> <u>reportable Cyber Security Incident</u></li> <li><input type="checkbox"/> <u>other</u></li> </ul>	

## Guideline and Technical Basis

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and ~~is progressing toward developing standards based on the SAR. This concepts paper is designed to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT has developed.~~ has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

~~The DSR SDT also proposed to investigate incorporation of the cyber incident reporting aspects of CIP-008 under this project. This will be coordinated with the Cyber Security—Order 706 SDT (Project 2008-06).~~

~~The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC database and FERC Order 693 Directives to determine a prudent course of action with respect to these standards.~~

~~This concept paper provides stakeholders with a proposed “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. This concept paper provides the background information and thought process of the DSR SDT.~~

~~The proposed~~The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). ~~The proposed standards deal~~These standard deals exclusively with after-the-fact reporting.

The DSR SDT ~~is proposing to consolidate~~has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

## Summary of Concepts and Assumptions:

### ~~The Standard Will: Require use:~~

- ~~Requires reporting of a single form to report disturbances and “Impact Events” events~~ that ~~threaten impact or may impact~~ the reliability of the bulk electric system
- ~~Provide~~Provides clear criteria for reporting
- ~~Include~~Includes consistent reporting timelines
- ~~Identify~~Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- ~~Provide~~Provides clarity around of who will receive the information

~~The drafting team will explore other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements~~

## Discussion of Disturbance Reporting

Disturbance reporting requirements ~~currently exist~~existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria ~~are~~were in the ~~existing~~previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of ~~Impact Events~~events that are to be reported under this standard (attachment 1).

## Discussion of ~~“Impact Event”~~<sup>2</sup> Reporting

There are situations worthy of reporting because they have the potential to impact reliability. ~~The DSR SDT proposes calling such incidents ‘Impact Events’ with the following concept:~~

~~An Impact Event is any situation that has the potential to significantly impact the reliability of the Bulk Electric System. Such events may originate from malicious intent, accidental behavior, or natural occurrences.~~

~~Impact~~t Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate ~~the~~any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of ~~Impact Events~~such events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008 or its successor standard
- Forced intrusion attempt at a substation



- Train derailment near a transmission right-of-way
- Destruction of Bulk Electrical System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: ". . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*"

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electrical System using the **Impact Event** categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

~~The DST SDT discussed the reliability needs for Impact Event reporting and will consider guidance found in the document "NERC Guideline: Threat and Incident Reporting" in the development of requirements, which will include clear criteria for reporting.~~

Certain types of **Impact Event** events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of **Impact Events** impact events may have different reporting requirements. For example, an **Impact Event** that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. ~~As envisioned, the~~ The standard ~~will only require~~ requires Functional entities to report the incidents and provide known information ~~or at the time of the report. Further~~ data gathering necessary for ~~these analyses~~ event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### ***Collection of Reportable Information or "One stop shopping"***

~~The goal of the DSR SDT is to have one reporting form for all functional entities (US, Canada, Mexico) to submit to NERC. Ultimately, it may make sense to develop an electronic version to expedite completion, sharing and storage. Ideally, entities would complete a single form which could then be distributed to jurisdictional agencies and functional entities as appropriate.~~

~~Specific reporting forms<sup>9</sup> that exist today (i.e., OE-417, etc) could be included as part of the electronic form to accommodate US entities with a requirement to submit the form, or may be removed (but still be mandatory for US entities under Public Law 93-275) to streamline the proposed consolidated reliability standard for all North American entities (US, Canada, Mexico). Jurisdictional agencies may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE. Functional entities may include the RC, TOP, and BA for industry awareness. Applicability of the standard will be determined based on the specific requirements.~~

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT ~~is planning to update~~has updated the listing of reportable events ~~from~~in Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences ~~may~~ still exist.

The reporting ~~proposed~~required by ~~the DSR SDT~~this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information ~~is~~should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

---

<sup>9</sup>~~The DOE Reporting Form, OE-417 is currently a part of the EOP-004 standard. If this report is removed from the standard, it should be noted that this form is still required by law as noted on the form: NOTICE: This report is mandatory under Public Law 93-275. Failure to comply may result in criminal fines, civil penalties and other sanctions as provided by law. For the sanctions and the provisions concerning the confidentiality of information submitted on this form, see General Information portion of the instructions. Title 18 USC 1001 makes it a criminal offense for any person knowingly and willingly to make to any Agency or Department of the United States any false, fictitious, or fraudulent statements as to any matter within its jurisdiction.~~

# Unofficial Comment Form

## Disturbance and Sabotage Reporting (Project 2009-01)

Please **DO NOT** use this form to submit comments. Please use the [electronic comment form](#) to submit comments on the first formal posting for Project 2009-01—Disturbance and Sabotage Reporting. The electronic comment form must be completed by **December 12, 2011**.

[2009-01 Project Page](#)

If you have questions please contact Stephen Crutchfield at [stephen.crutchfield@nerc.net](mailto:stephen.crutchfield@nerc.net) or by telephone at 609-651-9455.

### Background

The DST SDT posted the draft standard EOP-004-2 for a formal comment period from March 9, 2011 through April 8, 2011. Based on stakeholder feedback, the DSR SDT made several revisions to the standard to improve clarity and address other concerns identified by stakeholders. The main stakeholder concerns were addressed as follows:

**Definition of Impact Event.** Many stakeholders disagreed with the need for the definition of "Impact Event" and felt that that the definition was ambiguous and created confusion. The DSR SDT agrees and has deleted the proposed definition from the standard. The list of events that are to be reported in Attachment 1 is inclusive and no further attempts to define "Impact Event" are necessary.

**Timeframe for Reporting and Event.** Many stakeholders raised concerns with the one-hour reporting requirement for certain types of events. The commenters believed that the restoration of service or the return to a stable bulk power system state may be jeopardized by having to report certain events within one hour. The DSR SDT agreed and revised the reporting time to 24 hours for most events, with the exception of damage to or destruction of BES equipment, forced intrusion or cyber related incidents.

**VRFs.** Many stakeholders suggested that the reporting of events after the fact only justified a VRF of "lower" for each requirement. With the revised standard, there are now three requirements. Requirement 1 specifies that the responsible entity have an Operating Plan for identifying and reporting events listed in Attachment A. This is procedural in nature and justifies a "lower" VRF, as this requirement deals with the means to report events after the fact. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis of reported events is addressed through the NERC Events Analysis Program in accordance with the NERC Rules of Procedure.

The three remaining requirements in EOP-004-2 require entities affected by events to report those events based on the specifics in Attachment A (Requirement R3) and to test the communications protocol of their Operating Plan once per year (R4). Requirement R2 provides for implementation of the Operating Plan as it relates to Requirement R1, Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 specifies that an entity is responsible for reporting events to the appropriate entities in accordance with the Operating Plan based on Attachment A. Requirement R4 is intended to ensure that an entity can communicate information about events. Some of these events are potential sabotage events, and communicating these events is intended to make other entities aware to help prevent further sabotage events from occurring. Existing CIP-001-1a deals with sabotage events,

and the approved VRFs for each of the requirements is "medium." The proposed VRFs for EOP-004-2 are consistent with the existing approved VRFs for both EOP-004 and CIP-001.

**Applicability.** Commenters also had concerns about the applicability of the standard to Load Serving Entities, who may not own physical assets, as well as to the ERO and Regional Entity. The DSR SDT agrees that the Distribution Provider owns the assets per the Functional Model, however the LSE is an applicable entity under CIP-002, and under the CIP standards is responsible for reporting cyber security incidents. The ERO and RE are also responsible for reporting cyber security incidents under CIP-002. Therefore, the SDT determined that it was appropriate to include LSEs, the ERO and the RE in the applicability of EOP-004-2.

After the drafting team completed its consideration of stakeholder comments, the standards and implementation plan were submitted for quality review. Based on feedback from the quality review, the drafting team has made two significant revisions to the standard. The first revision is to add a requirement for implementation of the Operating Plan listed in Requirement R1. There was only a requirement to report events, but no requirement specifically calling for updates to the Operating Plan or the annual review. This was accomplished by having two requirements. The first is Requirement R2 which specifies that an entity must implement the Operating Plan per Requirement R1, Parts 1.1, 1.2, 1.4 and 1.5:

R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.

The second Requirement is R3 which addresses Part 1.3:

R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

The second revision based on the quality review pertains to Requirement R4. The quality review suggested revising the requirement to more closely match the language in the Rationale box that the drafting team developed. This would provide better guidance for responsible entities as well as provide more clear direction to auditors. The revised requirement is:

R4. Each Responsible Entity shall verify (through actual implementation for an event, or through a drill or exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification or actual implementation.

**You do not have to answer all questions. Enter all comments in Simple Text Format.**

- 1. The DSR SDT has revised EOP-004-2 to remove the training requirement R4 based on stakeholder comments from the second formal posting. Do you agree this revision? If not, please explain in the comment area below.**

Yes

No

Comments:

- 2. The DSR SDT includes two requirement regarding implementation of the Operating Plan specified in Requirement R1. The previous version of the standard had a requirement to implement the Operating plan as well as a requirement to report events. The two requirements R2 and R3 were written to delineate implementation of the Parts of R1. Do you agree with these revisions? If not, please explain in the comment area below.**

R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.

R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

Yes

No

Comments:

- 3. The DSR SDT revised reporting times for many events listed in Attachment 1 from one hour to 24 hours. Do you agree with these revisions? If not, please explain in the comment area below.**

Yes

No

Comments:

- 4. Do you have any other comment, not expressed in questions above, for the DSR SDT?**

Comments:

## Implementation Plan

### Project 2009-01 Disturbance and Sabotage Reporting

#### Implementation Plan for EOP-004-2 – Event Reporting

##### *Approvals Required*

EOP-004-2 – Event Reporting

##### *Prerequisite Approvals*

Revisions to Sections 807 and 808 of the NERC Rules of Procedure  
Addition of Section 812 to the NERC Rules of Procedure

##### *Revisions to Glossary Terms*

None

##### *Applicable Entities*

Reliability Coordinator  
Balancing Authority  
Interchange Coordinator  
Transmission Service provider  
Transmission Owner  
Transmission Operator  
Generator Owner  
Generator Operator  
Distribution Provider  
Load-Serving Entity  
Electric Reliability Organization  
Regional Entity

##### *Conforming Changes to Other Standards*

None

##### *Effective Dates*

EOP-004-2 shall become effective on the first day of the third calendar quarter after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the third calendar quarter after Board of Trustees approval.

***Retirements***

EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.

CIP-008-4 – Cyber Security - Incident Reporting and Response Planning: Retire R1.3 which contains provisions for reporting Cyber Security Incidents. This is addressed in EOP-004-2, Requirement 1, Part 1.3.

## Implementation Plan

### Project 2009-01 Disturbance and Sabotage Reporting

#### Implementation Plan for EOP-004-2 – Event Reporting

##### *Approvals Required*

EOP-004-2 – Event Reporting

##### *Prerequisite Approvals*

Revisions to Sections 807 and 808 of the NERC Rules of Procedure  
Addition of Section 812 to the NERC Rules of Procedure

##### *Revisions to Glossary Terms*

None

##### *Applicable Entities*

Reliability Coordinator  
Balancing Authority  
Interchange Coordinator  
Transmission Service provider  
Transmission Owner  
Transmission Operator  
Generator Owner  
Generator Operator  
Distribution Provider  
Load-Serving Entity

[Electric Reliability Organization](#)

[Regional Entity](#)

##### *Conforming Changes to Other Standards*

None

##### *Effective Dates*

EOP-004-2 shall become effective on the first day of the third calendar quarter after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the third calendar quarter after Board of Trustees approval.





***Retirements***

EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.

CIP-008-4 – Cyber Security - Incident Reporting and Response Planning: Retire R1.3 which contains provisions for reporting Cyber Security Incidents. This is addressed in EOP-004-2, Requirement 1, Part 1.3.

## Project 2009-01 Disturbance and Sabotage Reporting Mapping Document

Translation of CIP-002-2a – Sabotage Reporting, EOP-004-1 – Disturbance Reporting and CIP-008-4 – Cyber Security – Incident Reporting and Response Planning (R 1.3), into EOP-004-2 – Impact Event and Disturbance Assessment, Analysis, and Reporting

Standard: CIP-001-2a – Sabotage Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting
R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi site sabotage affecting larger portions of the Interconnection.	Moved into EOP-004-2, R1	<p>R1. Each Responsible Entity shall have an Operating Plan that includes: <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i></p> <ol style="list-style-type: none"> <li>1.1. A process for identifying events listed in Attachment 1.</li> <li>1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.</li> <li>1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate: <ul style="list-style-type: none"> <li>• Internal company personnel</li> <li>• The Responsible Entities’ Regional Entity</li> </ul> </li> </ol>

		<ul style="list-style-type: none"> <li>• Law enforcement</li> <li>• Governmental or provincial agencies</li> </ul> <p>1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the plan or incorporating lessons learned pursuant to Requirement R3.</p> <p>1.5. Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.</p>
<p>R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.</p>	<p>Moved into EOP-004-2, R1</p>	<p>R1. Each Responsible Entity shall have an Operating Plan that includes: [Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]</p> <ul style="list-style-type: none"> <li>1.1. A process for identifying events listed in Attachment 1.</li> <li>1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.</li> <li>1.3. A process for communicating events listed in Attachment 1 that includes the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:             <ul style="list-style-type: none"> <li>• Internal company personnel</li> </ul> </li> </ul>

		<ul style="list-style-type: none"> <li>• The Responsible Entities’ Regional Entity</li> <li>• Law enforcement</li> <li>• Governmental or provincial agencies</li> </ul> <p>1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the plan or incorporating lessons learned pursuant to R3.</p> <p>1.5. Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.</p>
<p>R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.</p>	<p>Moved into EOP-004-2, R1</p>	<p>R1. Each Responsible Entity shall have an Operating Plan that includes: [Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]</p> <ul style="list-style-type: none"> <li>1.1. A process for identifying events listed in Attachment 1.</li> <li>1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.</li> <li>1.3. A process for communicating events listed in Attachment 1 that includes the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:             <ul style="list-style-type: none"> <li>• Internal company personnel</li> </ul> </li> </ul>

		<ul style="list-style-type: none"> <li>• Responsible Entities’ Regional Entity</li> <li>• Law enforcement</li> <li>• Governmental or provincial agencies</li> </ul> <p>1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the plan or incorporating lessons learned pursuant to R3.</p> <p>1.5. Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.</p>
<p>R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.</p>	<p>Moved into EOP-004-2, R1</p>	<p>R1. Each Responsible Entity shall have an Operating Plan that includes: [Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]</p> <p>1.1. A process for identifying events listed in Attachment 1.</p> <p>1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.</p> <p>1.3. A process for communicating events listed in Attachment 1 that includes the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:</p> <ul style="list-style-type: none"> <li>• Internal company personnel</li> </ul>

		<ul style="list-style-type: none"> <li>• Responsible Entities’ Regional Entity</li> <li>• Law enforcement</li> <li>• Governmental or provincial agencies</li> </ul> <p>1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the plan or incorporating lessons learned pursuant to R3.</p> <p>1.5. Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.</p>
--	--	--

Standard: EOP-004-1 – Disturbance Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.	Retire this fill-in-the-blank requirement.  Replace with new reporting and analysis procedure developed by NERC EAWG.	The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.
R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.	Translated into EOP-004-2, R1 and the NERC Events Analysis Process	The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.
R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.	Translated into EOP-004-2, R3	R3. Each Responsible Entity shall report impact events in accordance with the Operating Plan developed to address events listed in Attachment 1. <i>[Violation Risk: Factor: Lower] [Time Horizon: Operations Assessment]</i> .



<p>R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until sometime after they occur shall be reported within 24 hours of being recognized.</p>	<p>Translated into EOP-004-2, R3</p>	<p>R3. Each Responsible Entity shall report impact events in accordance with the Operating Plan developed to address events listed in Attachment 1. <i>[Violation Risk: Factor: Lower] [Time Horizon: Operations Assessment].</i></p>
<p>R3.2. Applicable reporting forms are provided in Attachments 022-1 and 022-2.</p>	<p>Retire – informational statement</p>	

<p>R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.</p>	<p>Retire as a requirement. Added as a "Note" to EOP-004-Attachment1-Impact Events Table</p>	<p>NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. The affected Responsible Entity shall provide periodic verbal updates until adequate information is available to issue a written Event report. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.</p>
---	--	--

<p>R3.4. If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>
<p>R4. When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>

<p>R5. The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>
<p>Request for Interpretation of CIP-001-2a, R2: Please clarify what is meant by the term, “appropriate parties.” Moreover, who within the Interconnection hierarchy deems parties to be appropriate?</p>	<p>Retire the interpretation</p>	<p>Addressed in EOP-004-2, R1 by replacing the term, ‘appropriate parties’ with a broader, more specific list of specific entities to contact in Part 1.3.</p>

Standard: CIP-008-4 – Cyber Security – Incident Reporting and Response Planning		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
R1.3. Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary.	Translated into EOP-004-2 Requirement 1, Part 1.3 and Attachment 1.	<p>Cyber Security Incidents are defined as:</p> <p>Any malicious act or suspicious event that:</p> <ul style="list-style-type: none"> <li>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</li> <li>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.</li> </ul> <p>Such events are listed in Attachment 1 as “Detection of a reportable Cyber Security Incident” and are events that are required to be reported under Reliability Standard EOP-004-2. Requirement R1, Part 1.3 requires the Responsible Entity to have “A process for communicating events listed in Attachment 1 to the Electric Reliability Organization,…” The note at the top of Attachment 1 includes the following:</p> <p>“Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</p>

## Violation Risk Factor and Violation Severity Level Assignments

### Project 2009-01 – Disturbance and Sabotage Reporting

This document provides the drafting team's justification for assignment of violation risk factors (VRFs) and violation severity levels (VSLs) for each requirement in

#### EOP-004-2 — Event Reporting

Each primary requirement is assigned a VRF and a set of one or more VSLs. These elements support the determination of an initial value range for the Base Penalty Amount regarding violations of requirements in FERC-approved Reliability Standards, as defined in the ERO Sanction Guidelines.

#### Justification for Assignment of Violation Risk Factors in EOP-004-2

The Disturbance and Sabotage Reporting Standard Drafting Team applied the following NERC criteria when proposing VRFs for the requirements in EOP-004-2:

##### ***High Risk Requirement***

A requirement that, if violated, could directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures, or could hinder restoration to a normal condition.

##### ***Medium Risk Requirement***

A requirement that, if violated, could directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system. However, violation of a medium risk requirement is unlikely to lead to bulk electric system instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly and adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. However, violation of a medium risk requirement is unlikely, under emergency, abnormal, or restoration conditions anticipated by the preparations, to lead to bulk electric system instability, separation, or cascading failures, nor to hinder restoration to a normal condition.

***Lower Risk Requirement***

A requirement that is administrative in nature and a requirement that, if violated, would not be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system; or, a requirement that is administrative in nature and a requirement in a planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. A planning requirement that is administrative in nature.

The SDT also considered consistency with the FERC Violation Risk Factor Guidelines for setting VRFs:<sup>1</sup>

**Guideline (1) — Consistency with the Conclusions of the Final Blackout Report**

The Commission seeks to ensure that Violation Risk Factors assigned to Requirements of Reliability Standards in these identified areas appropriately reflect their historical critical impact on the reliability of the Bulk-Power System.

In the VSL Order, FERC listed critical areas (from the Final Blackout Report) where violations could severely affect the reliability of the Bulk-Power System:<sup>2</sup>

- Emergency operations
- Vegetation management
- Operator personnel training
- Protection systems and their coordination
- Operating tools and backup facilities
- Reactive power and voltage control
- System modeling and data exchange
- Communication protocol and facilities
- Requirements to determine equipment ratings
- Synchronized data recorders
- Clearer criteria for operationally critical facilities
- Appropriate use of transmission loading relief.

**Guideline (2) — Consistency within a Reliability Standard**

The Commission expects a rational connection between the sub-Requirement Violation Risk Factor assignments and the main Requirement Violation Risk Factor assignment.

<sup>1</sup> North American Electric Reliability Corp., 119 FERC ¶ 61,145, order on reh'g and compliance filing, 120 FERC ¶ 61,145 (2007) (“VRF Rehearing Order”).

<sup>2</sup> Id. at footnote 15.

### **Guideline (3) — Consistency among Reliability Standards**

The Commission expects the assignment of Violation Risk Factors corresponding to Requirements that address similar reliability goals in different Reliability Standards would be treated comparably.

### **Guideline (4) — Consistency with NERC’s Definition of the Violation Risk Factor Level**

Guideline (4) was developed to evaluate whether the assignment of a particular Violation Risk Factor level conforms to NERC’s definition of that risk level.

### **Guideline (5) — Treatment of Requirements that Co-mingle More Than One Obligation**

Where a single Requirement co-mingles a higher risk reliability objective and a lesser risk reliability objective, the VRF assignment for such Requirements must not be watered down to reflect the lower risk level associated with the less important objective of the Reliability Standard.

The following discussion addresses how the SDT considered FERC’s VRF Guidelines 2 through 5. The team did not address Guideline 1 directly because of an apparent conflict between Guidelines 1 and 4. Whereas Guideline 1 identifies a list of topics that encompass nearly all topics within NERC’s Reliability Standards and implies that these requirements should be assigned a “High” VRF, Guideline 4 directs assignment of VRFs based on the impact of a specific requirement to the reliability of the system. The SDT believes that Guideline 4 is reflective of the intent of VRFs in the first instance and therefore concentrated its approach on the reliability impact of the requirements.

#### ***VRF for EOP-004-2:***

There are four requirements in EOP-004-2. Requirement R1 was assigned a “Lower” VRF while Requirements R2, R3 and R4 were assigned a “Medium” VRF.

#### ***VRF for EOP-004-2, Requirements R1:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The Requirement specifies which functional entities are required to have procedure(s) for recognition of events, gather information for completing an event report, and communicating with other entities. The VRFs are only applied at the Requirement level and each Requirement Part is treated equally.
- FERC’s Guideline 3 — Consistency among Reliability Standards. This requirement calls for an entity to have procedure(s) for recognition of events, gather information for completing an event report, and communicating with other entities. This requirement is administrative in nature and deals with the means to report events after the fact. Most event reporting requirements in Attachment 1 are



for 24 hours after an event has occurred. The current approved VRFs for EOP-004-1 are all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program.

- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. Failure to have a procedure(s) is not likely to directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system if an entity cannot report an event and that event led to other preventable events on the BES had the report been made in a timely fashion. Development of the procedure(s) is a requirement that is administrative in nature and is in a planning time frame that, if violated, would not, under emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system.. Therefore this requirement was assigned a lower VRF.
- FERC’s Guideline 5 — Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R1 contain only one objective which is to have procedure(s). The content of the procedure is specified in Parts 1.1-1.5. Since the requirement is to have a procedure(s), only one VRF was assigned.

***VRF for EOP-004-2, Requirement R2:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The requirement has no sub-requirements; only one VRF was assigned so there is no conflict.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R4 is a requirement for entities to report events using the procedure(s) for recognition of events per Requirement R1. The Standard Drafting Team views this as an aspect of implementing the Operating Plan for reporting events. The act of reporting in and of itself is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not report events. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R5 mandates that report events per their procedure(s). Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to notify another entity of the event failure, but there is a slight chance that it could occur. Therefore, this requirement was assigned a Medium VRF.

- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R5 addresses a single objective and has a single VRF.

***VRF for EOP-004-2, Requirement R3:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The requirement has no sub-requirements; only one VRF was assigned so there is no conflict.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R4 is a requirement for entities to report events using the procedure(s) for recognition of events per Requirement R1. The act of reporting in and of itself is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not report events. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R5 mandates that report events per their procedure(s). Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to notify another entity of the event failure, but there is a slight chance that it could occur. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R5 addresses a single objective and has a single VRF.

***VRF for EOP-004-2, Requirement R4:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The requirement has no sub-requirements; only one VRF was assigned so there is no conflict.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R3 specifies a time frame in which to verify the communications protocols developed in the procedures pursuant to Requirement R1. Both requirements have a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. Failure to verify a communications protocol could directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system if an entity cannot report an event and that event led to other preventable events on the BES had the report been made in a timely fashion. Therefore this requirement was assigned a medium VRF.
- FERC’s Guideline 5 — Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R3 addresses a single objective and has a single VRF.

**Justification for Assignment of Violation Severity Levels for EOP-004-2:**

In developing the VSLs for the EOP-004-2 standard, the SDT anticipated the evidence that would be reviewed during an audit, and developed its VSLs based on the noncompliance an auditor may find during a typical audit. The SDT based its assignment of VSLs on the following NERC criteria:

Lower	Moderate	High	Severe
Missing a minor element (or a small percentage) of the required performance The performance or product measured has significant value as it almost meets the full intent of the requirement.	Missing at least one significant element (or a moderate percentage) of the required performance. The performance or product measured still has significant value in meeting the intent of the requirement.	Missing more than one significant element (or is missing a high percentage) of the required performance or is missing a single vital component. The performance or product has limited value in meeting the intent of the requirement.	Missing most or all of the significant elements (or a significant percentage) of the required performance. The performance measured does not meet the intent of the requirement or the product delivered cannot be used in meeting the intent of the requirement.

FERC’s VSL guidelines are presented below, followed by an analysis of whether the VSLs proposed for each requirement in EOP-004-2 meet the FERC Guidelines for assessing VSLs:

**Guideline 1: Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance**

Compare the VSLs to any prior levels of non-compliance and avoid significant changes that may encourage a lower level of compliance than was required when levels of non-compliance were used.

**Guideline 2: Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties**

A violation of a “binary” type requirement must be a “Severe” VSL.

Do not use ambiguous terms such as “minor” and “significant” to describe noncompliant performance.

**Guideline 3: Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement**

VSLs should not expand on what is required in the requirement.

**Guideline 4: Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations**

. . . unless otherwise stated in the requirement, each instance of non-compliance with a requirement is a separate violation. Section 4 of the Sanction Guidelines states that assessing penalties on a per violation per day basis is the “default” for penalty calculations.

**VSLs for EOP-004-2 Requirements R1:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R1</b>	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a revision of CIP-001-1, R1-R4, and EOP-004-1, R2. Since the Requirement has four Parts, the VSLs were developed to count a violation of each Part equally. Therefore, four VSLs were developed.	The proposed VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSL uses the same terminology as used in the associated requirement, and is, therefore, consistent with the requirement.	The VSL is based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R2:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R2.</b>	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is for entities to implement the Operating Plan for event reporting. There are four Parts that are addressed under this requirement. Parts 1.1 and 1.2 are only applicable for an actual event and are binary in nature. Parts 1.4 and 1.5 require updates or reviews based on certain intervals. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If the update or review is not performed, then the VSL is Severe.	The proposed VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSL uses the same terminology as used in the associated requirement, and is, therefore, consistent with the requirement.	The VSL is based on a single violation and not cumulative violations.

VSLs for EOP-004-2 Requirement R3:

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R2.</b>	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a revision of EOP-004-1, R3. There is only a Severe VSL for that requirement. However, the reporting of events is based on timing intervals listed in attachment 1. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a report is not submitted, then the VSL is Severe. This maintains the current VSL.	The proposed VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSL uses the same terminology as used in the associated requirement, and is, therefore, consistent with the requirement.	The VSL is based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R4:**

R#	Compliance with NERC's Revised VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R3.</b>	Meets NERC's VSL guidelines - Severe: The performance or product measured does not substantively meet the intent of the requirement.	The most comparable VSLs for a similar requirement is EOP-008-0, R1.7 which calls for an annual update to a plan. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the verification of the communication protocol. If the verification is not achieved, then the VSL is Severe.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.



**A. Introduction**

- 1. Title:** **Sabotage Reporting**
- 2. Number:** CIP-001-1
- 3. Purpose:** Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.
- 4. Applicability**
  - 4.1.** Reliability Coordinators.
  - 4.2.** Balancing Authorities.
  - 4.3.** Transmission Operators.
  - 4.4.** Generator Operators.
  - 4.5.** Load Serving Entities.
- 5. Effective Date:** January 1, 2007

**B. Requirements**

- R1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- R2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- R3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- R4.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

**C. Measures**

- M1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

**D. Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Monitoring Responsibility**

Regional Reliability Organizations shall be responsible for compliance monitoring.

**1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to verify compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

**1.3. Data Retention**

Each Reliability Coordinator, Transmission Operator, Generator Operator, Distribution Provider, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**1.4. Additional Compliance Information**

None.

**2. Levels of Non-Compliance:**

**2.1. Level 1:** There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

**2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).

**2.1.2** Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).

**2.1.3** Has not established communications contacts, as specified in R4.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).

**2.4. Level 4:** Not applicable.

**E. Regional Differences**

None indicated.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Amended

## A. Introduction

1. **Title:** **Disturbance Reporting**
2. **Number:** EOP-004-1
3. **Purpose:** Disturbances or unusual occurrences that jeopardize the operation of the Bulk Electric System, or result in system equipment damage or customer interruptions, need to be studied and understood to minimize the likelihood of similar events in the future.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Regional Reliability Organizations.
5. **Effective Date:** January 1, 2007

## B. Requirements

- R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.
- R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.
- R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.
  - R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until some time after they occur shall be reported within 24 hours of being recognized.
  - R3.2. Applicable reporting forms are provided in Attachments 1-EOP-004 and 2-EOP-004.
  - R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that

time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.

- R3.4.** If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.
- R4.** When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.
- R5.** The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.

### C. Measures

- M1.** The Regional Reliability Organization shall have and provide upon request as evidence, its current regional reporting procedure that is used to facilitate preparation of preliminary and final disturbance reports. (Requirement 1)
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, the preliminary report, computer printouts, operator logs, or other equivalent evidence that will be used to confirm that it prepared and delivered the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1.
- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to confirm that it provided information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours. (Requirement 3.3)

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

NERC shall be responsible for compliance monitoring of the Regional Reliability Organizations.

Regional Reliability Organizations shall be responsible for compliance monitoring of Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load-serving Entities.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Regional Reliability Organization shall have its current, in-force, regional reporting procedure as evidence of compliance. (Measure 1)

Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that is either involved in a Bulk Electric System disturbance or has a reportable incident shall keep data related to the incident for a year from the event or for the duration of any regional investigation, whichever is longer. (Measures 2 through 4)

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**1.4. Additional Compliance Information**

See Attachments:

- EOP-004 Disturbance Reporting Form
- Table 1 EOP-004

**2. Levels of Non-Compliance for a Regional Reliability Organization**

**2.1. Level 1:** Not applicable.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Not applicable.

**2.4. Level 4:** No current procedure to facilitate preparation of preliminary and final disturbance reports as specified in R1.

**3. Levels of Non-Compliance for a Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load- Serving Entity:**

**3.1. Level 1:** There shall be a level one non-compliance if any of the following conditions exist:

**3.1.1** Failed to prepare and deliver the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1

**3.1.2** Failed to provide disturbance information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours as specified in R3.3

**3.1.3** Failed to prepare a final report within 60 days as specified in R3.4

**3.2. Level 2:** Not applicable.

**3.3. Level 3:** Not applicable

**3.4. Level 4:** Not applicable.

**E. Regional Differences**

None identified.

**Version History**

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	May 23, 2005	Fixed reference to attachments 1-EOP-004-0 and 2-EOP-004-0, Changed chart title 1-FAC-004-0 to 1-EOP-004-0, Fixed title of Table 1 to read 1-EOP-004-0, and fixed font.	Errata
0	July 6, 2005	Fixed email in Attachment 1-EOP-004-0 from <a href="mailto:info@nerc.com">info@nerc.com</a> to <a href="mailto:esisac@nerc.com">esisac@nerc.com</a> .	Errata

0	July 26, 2005	Fixed Header on page 8 to read EOP-004-0	Errata
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised



## **Attachment 1-EOP-004 NERC Disturbance Report Form**

### **Introduction**

These disturbance reporting requirements apply to all Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load Serving Entities, and provide a common basis for all NERC disturbance reporting. The entity on whose system a reportable disturbance occurs shall notify NERC and its Regional Reliability Organization of the disturbance using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. Reports can be sent to NERC via email ([esisac@nerc.com](mailto:esisac@nerc.com)) by facsimile (609-452-9550) using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. If a disturbance is to be reported to the U.S. Department of Energy also, the responding entity may use the DOE reporting form when reporting to NERC. Note: All Emergency Incident and Disturbance Reports (Schedules 1 and 2) sent to DOE shall be simultaneously sent to NERC, preferably electronically at [esisac@nerc.com](mailto:esisac@nerc.com).

The NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports are to be made for any of the following events:

1. The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:
  - a. Modification of operating procedures.
  - b. Modification of equipment (e.g. control systems or special protection systems) to prevent reoccurrence of the event.
  - c. Identification of valuable lessons learned.
  - d. Identification of non-compliance with NERC standards or policies.
  - e. Identification of a disturbance that is beyond recognized criteria, i.e. three-phase fault with breaker failure, etc.
  - f. Frequency or voltage going below the under-frequency or under-voltage load shed points.
2. The occurrence of an interconnected system separation or system islanding or both.
3. Loss of generation by a Generator Operator, Balancing Authority, or Load-Serving Entity — 2,000 MW or more in the Eastern Interconnection or Western Interconnection and 1,000 MW or more in the ERCOT Interconnection.
4. Equipment failures/system operational actions which result in the loss of firm system demands for more than 15 minutes, as described below:
  - a. Entities with a previous year recorded peak demand of more than 3,000 MW are required to report all such losses of firm demands totaling more than 300 MW.
  - b. All other entities are required to report all such losses of firm demands totaling more than 200 MW or 50% of the total customers being supplied immediately prior to the incident, whichever is less.
5. Firm load shedding of 100 MW or more to maintain the continuity of the bulk electric system.

6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in:
  - a. Sustained voltage excursions equal to or greater than  $\pm 10\%$ , or
  - b. Major damage to power system components, or
  - c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance as defined by steps 1 through 5 above.
7. An Interconnection Reliability Operating Limit (IROL) violation as required in reliability standard TOP-007.
8. Any event that the Operating Committee requests to be submitted to Disturbance Analysis Working Group (DAWG) for review because of the nature of the disturbance and the insight and lessons the electricity supply and delivery industry could learn.

## NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report

Check here if this is an Interconnection Reliability Operating Limit (IROL) violation report.

1.	Organization filing report.		
2.	Name of person filing report.		
3.	Telephone number.		
4.	Date and time of disturbance. Date:(mm/dd/yy) Time/Zone:		
5.	Did the disturbance originate in your system?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
6.	Describe disturbance including: cause, equipment damage, critical services interrupted, system separation, key scheduled and actual flows prior to disturbance and in the case of a disturbance involving a special protection or remedial action scheme, what action is being taken to prevent recurrence.		
7.	Generation tripped.  MW Total List generation tripped		
8.	Frequency. Just prior to disturbance (Hz): Immediately after disturbance (Hz max.): Immediately after disturbance (Hz min.):		
9.	List transmission lines tripped (specify voltage level of each line).		
10.	Demand tripped (MW): Number of affected Customers:	FIRM	INTERRUPTIBLE

	Demand lost (MW-Minutes):		
11.	Restoration time.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		

## **Attachment 2-EOP-004**

### **U.S. Department of Energy Disturbance Reporting Requirements**

#### **Introduction**

The U.S. Department of Energy (DOE), under its relevant authorities, has established mandatory reporting requirements for electric emergency incidents and disturbances in the United States. DOE collects this information from the electric power industry on Form EIA-417 to meet its overall national security and Federal Energy Management Agency's Federal Response Plan (FRP) responsibilities. DOE will use the data from this form to obtain current information regarding emergency situations on U.S. electric energy supply systems. DOE's Energy Information Administration (EIA) will use the data for reporting on electric power emergency incidents and disturbances in monthly EIA reports. In addition, the data may be used to develop legislative recommendations, reports to the Congress and as a basis for DOE investigations following severe, prolonged, or repeated electric power reliability problems.

Every Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity must use this form to submit mandatory reports of electric power system incidents or disturbances to the DOE Operations Center, which operates on a 24-hour basis, seven days a week. All other entities operating electric systems have filing responsibilities to provide information to the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity when necessary for their reporting obligations and to file form EIA-417 in cases where these entities will not be involved. EIA requests that it be notified of those that plan to file jointly and of those electric entities that want to file separately.

Special reporting provisions exist for those electric utilities located within the United States, but for whom Reliability Coordinator oversight responsibilities are handled by electrical systems located across an international border. A foreign utility handling U.S. Balancing Authority responsibilities, may wish to file this information voluntarily to the DOE. Any U.S.-based utility in this international situation needs to inform DOE that these filings will come from a foreign-based electric system or file the required reports themselves.

Form EIA-417 must be submitted to the DOE Operations Center if any one of the following applies (see Table 1-EOP-004-0 — Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies):

1. Uncontrolled loss of 300 MW or more of firm system load for more than 15 minutes from a single incident.
2. Load shedding of 100 MW or more implemented under emergency operational policy.
3. System-wide voltage reductions of 3 percent or more.
4. Public appeal to reduce the use of electricity for purposes of maintaining the continuity of the electric power system.
5. Actual or suspected physical attacks that could impact electric power system adequacy or reliability; or vandalism, which target components of any security system. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.

6. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.
7. Fuel supply emergencies that could impact electric power system adequacy or reliability.
8. Loss of electric service to more than 50,000 customers for one hour or more.
9. Complete operational failure or shut-down of the transmission and/or distribution electrical system.

The initial DOE Emergency Incident and Disturbance Report (form EIA-417 – Schedule 1) shall be submitted to the DOE Operations Center within 60 minutes of the time of the system disruption. Complete information may not be available at the time of the disruption. However, provide as much information as is known or suspected at the time of the initial filing. If the incident is having a critical impact on operations, a telephone notification to the DOE Operations Center (202-586-8100) is acceptable, pending submission of the completed form EIA-417. Electronic submission via an on-line web-based form is the preferred method of notification. However, electronic submission by facsimile or email is acceptable.

An updated form EIA-417 (Schedule 1 and 2) is due within 48 hours of the event to provide complete disruption information. Electronic submission via facsimile or email is the preferred method of notification. Detailed DOE Incident and Disturbance reporting requirements can be found at: [http://www.eia.doe.gov/cneaf/electricity/page/form\\_417.html](http://www.eia.doe.gov/cneaf/electricity/page/form_417.html).

<b>Table 1-EOP-004-0</b>				
<b>Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies</b>				
<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Uncontrolled loss of Firm System Load	$\geq 300$ MW – 15 minutes or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>2</b>	Load Shedding	$\geq 100$ MW under emergency operational policy	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>3</b>	Voltage Reductions	3% or more – applied system-wide	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>4</b>	Public Appeals	Emergency conditions to reduce demand	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>5</b>	Physical sabotage, terrorism or vandalism	On physical security systems – suspected or real	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>6</b>	Cyber sabotage, terrorism or vandalism	If the attempt is believed to have or did happen	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>7</b>	Fuel supply emergencies	Fuel inventory or hydro storage levels $\leq 50\%$ of normal	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>8</b>	Loss of electric service	$\geq 50,000$ for 1 hour or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>9</b>	Complete operation failure of electrical system	If isolated or interconnected electrical systems suffer total electrical system collapse	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
All DOE EIA-417 Schedule 1 reports are to be filed within 60-minutes after the start of an incident or disturbance				
All DOE EIA-417 Schedule 2 reports are to be filed within 48-hours after the start of an incident or disturbance				

***All entities required to file a DOE EIA-417 report (Schedule 1 & 2) shall send a copy of these reports to NERC simultaneously, but no later than 24 hours after the start of the incident or disturbance.***

<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Loss of major system component	Significantly affects integrity of interconnected system operations	NERC Prelim Final report	24 hour 60 day
<b>2</b>	Interconnected system separation or system islanding	Total system shutdown Partial shutdown, separation, or islanding	NERC Prelim Final report	24 hour 60 day
<b>3</b>	Loss of generation	$\geq 2,000$ – Eastern Interconnection $\geq 2,000$ – Western Interconnection $\geq 1,000$ – ERCOT Interconnection	NERC Prelim Final report	24 hour 60 day
<b>4</b>	Loss of firm load $\geq 15$ -minutes	Entities with peak demand $\geq 3,000$ : loss $\geq 300$ MW All others $\geq 200$ MW or 50% of total demand	NERC Prelim Final report	24 hour 60 day
<b>5</b>	Firm load shedding	$\geq 100$ MW to maintain continuity of bulk system	NERC Prelim Final report	24 hour 60 day
<b>6</b>	System operation or operation actions resulting in:	<ul style="list-style-type: none"> <li>• Voltage excursions <math>\geq 10\%</math></li> <li>• Major damage to system components</li> <li>• Failure, degradation, or misoperation of SPS</li> </ul>	NERC Prelim Final report	24 hour 60 day
<b>7</b>	IROL violation	Reliability standard TOP-007.	NERC Prelim Final report	72 hour 60 day
<b>8</b>	As requested by ORS Chairman	Due to nature of disturbance & usefulness to industry (lessons learned)	NERC Prelim Final report	24 hour 60 day

All NERC Operating Security Limit and Preliminary Disturbance reports will be filed within 24 hours after the start of the incident. If an entity must file a DOE EIA-417 report on an incident, which requires a NERC Preliminary report, the Entity may use the DOE EIA-417 form for both DOE and NERC reports.

***Any entity reporting a DOE or NERC incident or disturbance has the responsibility to also notify its Regional Reliability Organization.***



## Standards Announcement

Project 2009-01 Disturbance and Sabotage Reporting

Ballot Pool Window Now Open: Oct. 28 – Nov. 28, 2011

Formal Comment Period Open: Oct. 28 – Dec. 12, 2011

Initial Ballot Window: Dec. 2 – 12, 2011

### [Available Now](#)

EOP-004-2 – Event Reporting (clean and redline showing changes to the last posting), an implementation plan (clean and redline to the last posting), and several associated documents (listed below) have been posted for a formal comment period and initial ballot that will end at 8 p.m. Eastern on Monday, December 12, 2011. Two ballot pools are being formed – one for balloting the standard, and a separate ballot pool for the non-binding poll of the associated VRFs and VSLs. The ballot pool window is open through 8 a.m. Eastern on Monday, November 28.

***(Please note that this is 8 a.m. on the Monday following Thanksgiving weekend – Registered Ballot Body members interested in joining the ballot pools for this project should plan accordingly).***

The following associated documents have been posted for stakeholder review and comment:

- Consideration of Comments Report – Provides a summary of the modifications made to the proposed standard and supporting documents based on comments submitted during the formal comment period that ended April 8, 2011
- Mapping Document - Identifies each requirement in the two already-approved standards that are being consolidated into EOP-004-2 (EOP-004-1 and CIP-001-1a), and identifies how the requirement has been treated in the revisions proposed Draft 3 of EOP-004-2
- VRF/VSL Justification – Explains how the VRFs and VSLs the drafting team has proposed for EOP-004-2 comply with guidelines that FERC and NERC have established for VRFs and VSLs
- Unofficial comment form in Word format – This is for informal use when compiling responses – the final must be submitted electronically

### **Instructions for Joining Ballot Pools for EOP-004-2 and Associated VRFs/VSLs**

Two separate ballot pools are being formed – one ballot pool for Registered Ballot Body (RBB) members interested in balloting of EOP-004-2, and a second for RBB members interested in casting an opinion during the non-binding poll of VRFs and VSLs associated with EOP-004-2. RBB

members who join the ballot pool for the standard **will not** be automatically entered in the ballot pool for the non-binding poll, but must elect to join the second ballot pool.

To join the ballot pool to be eligible to vote in the upcoming ballots and non-binding poll go to: [Join Ballot Pool](#)

During the pre-ballot windows, members of the ballot pool may communicate with one another by using their “ballot pool list server.” (Once the balloting begins, ballot pool members are prohibited from using the ballot pool list servers.)

The ballot pool list server for the initial ballot is: [bp-2009-01\\_DSR\\_in@nerc.com](mailto:bp-2009-01_DSR_in@nerc.com)

The ballot pool list server for the non-binding poll is: [bp-2009-01\\_DSR\\_NB\\_2011\\_in@nerc.com](mailto:bp-2009-01_DSR_NB_2011_in@nerc.com)

### **Instructions for Commenting**

Please use this [electronic form](#) ONLY to submit comments. In order to avoid duplication, please indicate “submitted comments electronically” on the ballot and non-binding poll comment section to avoid duplication.

If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the [project page](#).

### **Next Steps**

An initial ballot of EOP-004-2 will be conducted beginning on Friday, December 2, 2011 through 8 p.m. Eastern on Monday, December 12, 2011.

### **Background**

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Additional information is available on the [project webpage](#).

A stakeholder interested in following the Disturbance and Sabotage Reporting Drafting Team's development of EOP-004-2 may monitor meeting agendas and notes on the team's "[Related Files](#)" web page or may submit a request to join the team's "plus" e-mail list to receive meeting agendas and meeting notes as they are distributed to the team. To join the team's "plus" e-mail list, send an e-mail request to: [sarcomm@nerc.net](mailto:sarcomm@nerc.net). Please indicate the drafting team's name in the subject line of the e-mail.

### **Standards Process**

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
116-390 Village Blvd.  
Princeton, NJ 08540  
609.452.8060 | [www.nerc.com](http://www.nerc.com)

## Standards Announcement

Project 2009-01 Disturbance and Sabotage Reporting  
Initial Ballot Window and Non-Binding Poll  
Open: December 2 –12, 2011

### [Available December 2nd](#)

An initial ballot of EOP-004-2 – Event Reporting and its associated implementation plan, and a non-binding poll of the associated VRFs and VSLs, are open tomorrow through 8 p.m. Eastern on Monday, December 12, 2011.

### **Instructions for Balloting**

Members of the ballot pools associated with this project may log in and submit their vote for the standard and opinion for the non-binding poll from the following page:  
<https://standards.nerc.net/CurrentBallots.aspx>.

### **Instructions for Commenting**

A formal comment period is also open through 8 p.m. Eastern on Monday, December 12, 2011. Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the [project page](#).

### **Special Instructions for Submitting Comments with a Ballot**

Please note that comments submitted during the formal comment period, the ballot for the standard, and the non-binding poll of VRFs and VSLs all use the same electronic form, and it is NOT necessary for ballot pool members to submit more than one set of comments (one through the electronic form, one with the ballot, and one with the non-binding poll). **The drafting team requests that all stakeholders (ballot pool members as well as other stakeholders) submit all comments through the electronic comment form.**

Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the [project page](#).

### **Next Steps**

The drafting team will consider all comments and determine what changes to make in response to stakeholder input from the comments.

## Background

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Additional information is available on the [project webpage](#).

A stakeholder interested in following the Disturbance and Sabotage Reporting Drafting Team’s development of EOP-004-2 may monitor meeting agendas and notes on the team’s “[Related Files](#)” web page or may submit a request to join the team’s “plus” e-mail list to receive meeting agendas and meeting notes as they are distributed to the team. To join the team’s “plus” e-mail list, send an e-mail request to: [sarcomm@nerc.net](mailto:sarcomm@nerc.net). Please indicate the drafting team’s name in the subject line of the e-mail.

## Standards Process

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
116-390 Village Blvd.  
Princeton, NJ 08540  
609.452.8060 | [www.nerc.com](http://www.nerc.com)

## Standards Announcement

Project 2009-01 Disturbance and Sabotage Reporting

Ballot Pool Window Now Open: Oct. 28 – Nov. 28, 2011

Formal Comment Period Open: Oct. 28 – Dec. 12, 2011

Initial Ballot Window: Dec. 2 – 12, 2011

### [Available Now](#)

EOP-004-2 – Event Reporting (clean and redline showing changes to the last posting), an implementation plan (clean and redline to the last posting), and several associated documents (listed below) have been posted for a formal comment period and initial ballot that will end at 8 p.m. Eastern on Monday, December 12, 2011. Two ballot pools are being formed – one for balloting the standard, and a separate ballot pool for the non-binding poll of the associated VRFs and VSLs. The ballot pool window is open through 8 a.m. Eastern on Monday, November 28.

***(Please note that this is 8 a.m. on the Monday following Thanksgiving weekend – Registered Ballot Body members interested in joining the ballot pools for this project should plan accordingly).***

The following associated documents have been posted for stakeholder review and comment:

- Consideration of Comments Report – Provides a summary of the modifications made to the proposed standard and supporting documents based on comments submitted during the formal comment period that ended April 8, 2011
- Mapping Document - Identifies each requirement in the two already-approved standards that are being consolidated into EOP-004-2 (EOP-004-1 and CIP-001-1a), and identifies how the requirement has been treated in the revisions proposed Draft 3 of EOP-004-2
- VRF/VSL Justification – Explains how the VRFs and VSLs the drafting team has proposed for EOP-004-2 comply with guidelines that FERC and NERC have established for VRFs and VSLs
- Unofficial comment form in Word format – This is for informal use when compiling responses – the final must be submitted electronically

### **Instructions for Joining Ballot Pools for EOP-004-2 and Associated VRFs/VSLs**

Two separate ballot pools are being formed – one ballot pool for Registered Ballot Body (RBB) members interested in balloting of EOP-004-2, and a second for RBB members interested in casting an opinion during the non-binding poll of VRFs and VSLs associated with EOP-004-2. RBB

members who join the ballot pool for the standard **will not** be automatically entered in the ballot pool for the non-binding poll, but must elect to join the second ballot pool.

To join the ballot pool to be eligible to vote in the upcoming ballots and non-binding poll go to: [Join Ballot Pool](#)

During the pre-ballot windows, members of the ballot pool may communicate with one another by using their “ballot pool list server.” (Once the balloting begins, ballot pool members are prohibited from using the ballot pool list servers.)

The ballot pool list server for the initial ballot is: [bp-2009-01\\_DSR\\_in@nerc.com](mailto:bp-2009-01_DSR_in@nerc.com)

The ballot pool list server for the non-binding poll is: [bp-2009-01\\_DSR\\_NB\\_2011\\_in@nerc.com](mailto:bp-2009-01_DSR_NB_2011_in@nerc.com)

### **Instructions for Commenting**

Please use this [electronic form](#) ONLY to submit comments. In order to avoid duplication, please indicate “submitted comments electronically” on the ballot and non-binding poll comment section to avoid duplication.

If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the [project page](#).

### **Next Steps**

An initial ballot of EOP-004-2 will be conducted beginning on Friday, December 2, 2011 through 8 p.m. Eastern on Monday, December 12, 2011.

### **Background**

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Additional information is available on the [project webpage](#).

A stakeholder interested in following the Disturbance and Sabotage Reporting Drafting Team's development of EOP-004-2 may monitor meeting agendas and notes on the team's "[Related Files](#)" web page or may submit a request to join the team's "plus" e-mail list to receive meeting agendas and meeting notes as they are distributed to the team. To join the team's "plus" e-mail list, send an e-mail request to: [sarcomm@nerc.net](mailto:sarcomm@nerc.net). Please indicate the drafting team's name in the subject line of the e-mail.

### **Standards Process**

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
116-390 Village Blvd.  
Princeton, NJ 08540  
609.452.8060 | [www.nerc.com](http://www.nerc.com)



**Name (48 Responses)**  
**Organization (48 Responses)**  
**Group Name (28 Responses)**  
**Lead Contact (28 Responses)**  
**Question 1 (69 Responses)**  
**Question 1 Comments (76 Responses)**  
**Question 2 (68 Responses)**  
**Question 2 Comments (76 Responses)**  
**Question 3 (69 Responses)**  
**Question 3 Comments (76 Responses)**  
**Question 4 (0 Responses)**  
**Question 4 Comments (76 Responses)**

Individual
Bo Jones
Westar Energy
Yes
Yes
Yes
In Requirement 1.3, the statement "and the following as appropriate" is vague and subject to interpretation. Who determines what is appropriate? We feel it would be better if the SDT would specify for each event, which party should be notified.
Group
SERC OC Standards Review Group
Gerald Beckerle
No
We agree with removing the training requirement of R4; however we believe that drills and exercises are also training and R4 should be removed in its entirety because drills and exercises on an after the fact process do not enhance reliability.
No
It is confusing why R3 is not considered part of R2, which deals with implementation of the Operating Plan and it appears that R3 could be interpreted as double jeopardy. We suggest deleting R3.
No
No event should have a reporting time less than at the close of the next business day. Any reporting of an event that requires a less reporting time should only be to entities that can help mitigate an event such as an RC or other Reliability Entity.
We believe that reporting of the events in Attachment 1 has no reliability benefit to the bulk electric system. In addition, Attachment 1, in its current form, is likely to be impossible to implement consistently across North America. A requirement, to be considered a reliability requirement, must be implementable. We suggest that Attachment 1 should be removed. We have a question about what looks like a gap in this standard: Assuming one of the drivers for the standard is to protect against a coordinated physical or cyber attack on the grid, what happens if the attack occurs in 3-4 geographically diverse areas? State or provisional law enforcement officials are not accountable under the standard, so we have no way of knowing if they report the attack to the FBI or the RCMP. Even if one or two of them did, might not the FBI, in different parts of the country, interpret it as vandalism, subject to local jurisdiction? It seems that NERC is the focal point that would have all the reports and, ideally, some knowledge how the pieces fit together. It looks like NERC's role is to solely pass information on "applicable" events to the FERC. Unless the FERC has a 24x7 role not shown in the standard, should not NERC have some type of assessment responsibility to makes inquiries at the FBI/RCMP on whether they are aware of the potential issue and are working on it? "The comments

expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers."

Individual

Michael Johnson

APX Power Markets (NCR-11034)

Yes

Yes

Yes

In my opinion the remaining items with 1 hour reporting requirements will in most cases require the input of in-complete information, since you maybe aware of the outage/disturbance, but not aware of any reason for it. If that is acceptable just to get the intitial report that there was an outage/disturbance then we are OK. I believe it would help to have that clarified in the EOP, or maybe a CAN can be created for that.

For Attachment 1 and the events titled "Unplanned Control Center evacuation" and "Loss of monitoring or all voice communication capabiliy". RC, BA, and TOP are the only listed entity types listed for reporting responsibility. We are a GOP that offers a SCADA service in several regions and those type of events could result in a loss of situational awareness for the regions we provide services. I believe the requirement for reporting should not be limited to Entity Type, but on their impact for situational awareness to the BES based on the amount of generation they control (specific to our case), or other criteria that would be critical to the BES (i.e. voltage, frequency).

Individual

David Proebstel

Clallam County PUD No.1

Yes

Yes

Yes

While we agree with the revisions as far as they went, we do not believe the SDT has adequately addressed the FERC Order to "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely "recognition" starts the clock and reporting will become a higher priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition.

Project 2008-06 proposes to withdraw the terms "Critical Asset" and "Critical Cyber Asset" from the NERC Glossary. In order to avoid a reliability gap when this occurs, we propose including High and Medium Impact BES Cyber Systems and Assets. The revised wording to add, "as appropriate" to R1.3 is a concern. We understand the SDT's intent to not require all the bulleted parties to be notified for every event type. But will a good faith effort on the part of the registered entity to deem appropriateness be subject to second guessing and possible sanctions by the Compliance Enforcement Authority if they disagree? We note that CIP-001 required an interpretation to address this issue, but cannot assume that interpretation will carry over. We suggest spelling out exactly who shall deem appropriateness. R4 continues to be an onerous requirement for smaller entities. Verification was not part of the SAR and we are not convinced it is needed for reliability. We are unsure how a DP with no generation, no BES assets, no Critical Cyber Assets, and less than 100 MW of load; would meet R4. Shall they drill for impossible events? We ask that R4 be removed. At a minimum it should exclude entities that cannot experience the events of Attachment 1. Entities that cannot experience the events of Attachment 1 should likewise be exempt from R1.2, 1.3, R2, and R3.

Group

Northeast Power Coordinating Council
Guy Zito
No
Requirement R4 is unnecessary. Whether or not the process, plan, procedure, etc. is “verified” is of no consequence. EOP standards are intended to have entities prepare for likely events (restoration/evacuation), and to provide tools for similar unforeseen events (ice storms, tornadoes, earthquakes, etc.). They should not force a script when results are what matters.
No
R1.3 should be revised as follows: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as determined by the responsible entity:… Without this change it is not clear who determines what communication level is appropriate. R1.4 should be revised as follows: Provision(s) for updating the Operating Plan following any change in assets or personnel (if the Operating Plan specifies personnel or assets), that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3. R1.5 should be deleted. Responsible Entities can determine the frequency of Operating Plan updates. Requirement 1.4 requires updating the Operating Plan within 90 calendar days for changes in “assets, personnel… or incorporating lessons learned”, (or our preceding proposed revision). This requirement eliminates the need for Requirement 1.5 requiring a review of the Operating Plan on an annual basis. The only true requirement that is results-based, not administrative and is actually required to support the Purpose of the Standard is R3.
No
The SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language. EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded. If the list of reportable events is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and in the EAP Categories 1 through 5. It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes. Event: Risk to BES equipment should be deleted. This is too vague and subjective. This will result in many “prove the negative” situations. Event: Destruction of BES equipment is also too vague. The footnote refers to equipment being “damaged or destroyed”. There is a major difference between destruction and damage. Event: Damage or Destruction of a Critical Asset or Critical Cyber Asset should be deleted. Disclosure policies regarding sensitive information could limit an entity’s ability to report. Unintentional damage to a CCA does not warrant a report. Event: BES Emergency requiring public appeal for load reduction should be modified to note that this does not apply to routine requests for customer conservation during high load periods.
Requirement 4 does not specifically state the details necessary for an entity to achieve compliance. Requirement 4 should provide more guidance as to what is required in a drill. Audit/enforcement of any requirement language that is too broad will potentially lead to Regional interpretation, inconsistency, and additional CANS. R4 should be revised to delete the 15 month requirement. CAN-0010 recognizes that entities may determine the definition of annual. The standard is too specific, and drills down into entity practices, when the results are all that should be looked for. The standard is requiring multiple reports. The Purpose of the Standard is very broad and should be revised because some of the events being reported on have no impact on the BES. Revise Purpose wording as follows: To improve industry awareness and the reliability of the Bulk Electric System “by requiring the reporting of major system events with the potential to impact reliability and their causes…” on the Bulk Electric System it can be said that every event occurring on the Bulk Electric System would have to be reported. Referring to Requirement R4, the testing of the communication process is the responsibility of the Responsible Entity. There is an event analysis process already in place. The standard prescribes different sets of criteria, and forms. There should be one recipient of event information. That recipient should be a “clearinghouse” to ensure the proper dissemination of information. Why is this standard applicable to the ERO? Requirement R2 is not necessary. It states the obvious. Requirements R2 and R3 are redundant. The standard mentions collecting information for Attachment 2, but nowhere does it state what to do with Attachment 2. None of the key concepts identified on page 5 of the standard are clearly stated or described in the requirements: • Develop a

single form to report disturbances and events that threaten the reliability of the bulk electric system.

- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements.
- Establish clear criteria for reporting.
- Establish consistent reporting timelines.
- Provide clarity for who will receive the information and how it will be used. The standard's requirements should be reviewed with an eye for deleting those that are redundant, or do not address the Purpose or intent of the standard.

Group

Luminant Power

Stewart Rake

Yes

No

Requirements R1, R2, and R4 are burdensome administrative requirements and are contradictory to the NERC stated Standards Development goals of reducing administrative requirements by moving to performance requirements. There is only one Requirement needed in this standard: "The Responsible Entity shall report events in accordance with Attachment 1." Attachment 1 should describe how events should be reported by what Entity to which party within a defined timeframe. If this requirement is met, all the other proposed requirements have no benefit to the reliability of the Bulk Electric System. Per the NERC Standard Development guidelines, only items that provide a reliability benefit should be included in a standard.

No

Luminant agrees with the changes the SDT made, however, the timeline should be modified to put higher priority activities before reporting requirements. The SDT should consider allowing entities the ability to put the safety of personnel, safety of the equipment, and possibly the stabilization of BES equipment efforts prior to initiating the one hour reporting timeline. Reporting requirements should not be prioritized above these important activities. The requirement to report one hour after the recognition of such an event may not be sufficient in all instances. Entities should not have a potential violation as a result of putting these priority issues first and not meeting the one hour reporting timeline.

The following comments all apply to Attachment 1:

- As a general comment, SDT should specifically list the entities the reportable event applies to in the table for clarity. Do not use general language referencing another standard or statements such as "Deficient entity is responsible for reporting", "Initiating entity is responsible for reporting", or other similar statements used currently in the table. This leaves this open and subject to interpretation. Also, there are a number of events that do not apply to all entities.
- Destruction of BES equipment should be Intentional Damage or Destruction of BES equipment. Unintentional actions occur and should not be a requirement for reporting under disturbance reporting.
- Actions or situations affecting equipment or generation unit availability due to human error, equipment failure, unintentional human action, external cause, etc. are reported in real time to the BA and other entities as required by other NERC Standards. Disturbance reporting should avoid the type of events that, for instance, would cause the total or partial loss of a generating unit under normal operational circumstances. There are a number of issues with the table in this regard.
- For clarity, consider changing the table to identify for each event type "who" should be notified. This appears to be missing from the table overall.
- Reportable Events, the meaning for the Event labeled "Destruction of BES equipment" is not clear. Footnote 1 adds the language "(iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service." This language can be interpreted to mean that any damage to any BES equipment caused by human action, regardless of intention, must be reported within 1 hour of recognition of the event. This requirement will be overly burdensome. If this is not the intent of the definition of "Destruction of BES equipment", the footnote should be re-worded. As such, it is subjective and left open to interpretation. It should focus only on intentional actions to damage or interrupt BES functionality. It should not be worded as such that every item that trips a unit or every item that is damaged on a unit requires a report. That is where the language right now is not clear. There are and will continue to be unintentional human error that results in taking equipment out of service. This standard was meant to replace sabotage reporting.
- Damage or destruction of Critical Asset per CIP-002 and Damage or destruction of a Critical Cyber Asset per CIP-002 should be removed from the table as Intentional Damage or Destruction of BES equipment would cover this as well.
- Risk to BES

equipment should be removed from the table as it is very subjective and broad. At a minimum, the 1 hour reporting timeline should begin after recognition and assessment of the incident. As an example, a fire close to BES equipment may not truly be a threat to the equipment and will not be known until an assessment can be made to determine the risk. • Detection of a Reportable Cyber Security incident should be removed from the table as this is covered by CIP-008 requirements. Having this in two separate standards is double jeopardy and confusing to entities. • Generation Loss event reporting should only apply to the BA. These authorities have the ability and right to contact generation resources to supply necessary information needed for reporting. This would also eliminate redundant reporting by multiple entities for the same event. • Suggest that Generation Loss MW loss would match up with the 1500 MW level identified in CIP Version 4 or Version 5 for consistency between future CIP standards and this disturbance reporting standard. This would then cover CIP and significant MW losses that should be reported. • The Generation Loss MW loss amount needs to have a time boundary. Luminant would suggest a loss of 1500 MW within 15 minutes. • Unplanned Control Center evacuation should not apply to entities that have backup Control Centers where normal operations can continue without impact to the BES. • Loss of monitoring or all voice communication capability should be separated. Also the 24 hour reporting requirement may not be feasible if communications is down for longer than 24 hours. Luminant would suggest removal of the communication reporting event as there are a number of things that could cause this to occur for longer than the reporting requirement allows, thus putting entities at jeopardy of a potential violation that is out of their control. How does an entity report if all systems and communications are down for more than 24 hours? What about in instances of a partial or total blackout? These events could last much longer than 24 hours. All computer communication would likely also be down thus rendering electronic reporting unavailable.

Individual

Michael Moltane

ITC

Yes

Yes

No

See comments to Question #4

Footnote 1 and the corresponding Threshold For Reporting associated with the first Event in Attachment 1 are not consistent and thus confusing. Qualifying the term BES equipment through a footnote is inappropriate as it leads to this confusion. For instance, does iii under Footnote 1 apply only to BES equipment that meet i and ii or is it applicable to all BES equipment? The inclusion of equipment failure, operational error and unintentional human action within the threshold of reporting for "destruction" required in the first 3 Events listed in Attachment 1 is also not appropriate. It is clear through operational history that the intent of the equipment applied to the system, the operating practices and personnel training developed/delivered to operate the BES is to result in reliable operation of the BES which has been accomplished exceedingly well given past history. This is vastly different than for intentional actions and should be excluded from the first 3 events listed in Attachment. To the extent these issues are present in another event type they will be captured accordingly. Footnote 1 should be removed and the Threshold for Reporting associated with the first three events in Attachment 1 should be updated only to include intentional human action. This will also result in including all BES equipment that was intentionally damaged in the reporting requirement and not just the small subset qualified by the existing footnote 1. This provides a much better data sample for law enforcement to make assessments from than the smaller subset qualified by what we believe the intent of footnote 1 is.

Group

PacifiCorp

Sandra Shaffer

Yes

Yes

Yes
No comment.
Group
Pacific Northwest Small Public Power Utility Comment Group
Steve Alexanderson
Yes
Yes
Yes
While we agree with the revisions as far as they went, we do not believe the SDT has adequately addressed the FERC Order to "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely "recognition" starts the clock and reporting will become a higher priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition.
Project 2008-06 proposes to withdraw the terms "Critical Asset" and "Critical Cyber Asset" from the NERC Glossary. In order to avoid a reliability gap when this occurs, we propose including High and Medium Impact BES Cyber Systems and Assets. The revised wording to add, "as appropriate" to R1.3 is a concern. We understand the SDT's intent to not require all the bulleted parties to be notified for every event type. But will a good faith effort on the part of the registered entity to deem appropriateness be subject to second guessing and possible sanctions by the Compliance Enforcement Authority if they disagree? We note that CIP-001 required an interpretation to address this issue, but cannot assume that interpretation will carry over. We suggest spelling out exactly who shall deem appropriateness. R4 continues to be an onerous requirement for smaller entities. Verification was not part of the SAR and we are not convinced it is needed for reliability. We are unsure how a DP with no generation, no BES assets, no Critical Cyber Assets, and less than 100 MW of load; would meet R4. Shall they drill for impossible events? We ask that R4 be removed. At a minimum it should exclude entities that cannot experience the events of Attachment 1. Entities that cannot experience the events of Attachment 1 should likewise be exempt from R1.2, 1.3, R2, and R3.
Individual
Tracy Richardson
Springfield Utility Board
Yes
Yes
Yes
• The Draft 3 Version History still lists the term "Impact Event" instead of "Event". • Draft 3 of EOP-004-2 – Event Reporting does not provide a definition for the term "Event" nor does the NERC Glossary of Terms Used in Reliability Standards. SUB recommends that "Event" be listed and defined in "Definitions and Terms Used in the Standard" as well as the NERC Glossary, providing a framework and giving guidance to entities for how to determine what should be considered an "Event" (ex: sabotage, unusual occurrence, metal theft, etc.).
Individual
Kasia Mihalchuk
Manitoba Hydro
Yes

Yes
Yes
Attachment 1 - The term 'Transmission Facilities' used in Attachment 1 is capitalized, but it is not a defined term in the NERC glossary. The drafting team should clarify this issue. Attachment 2 - The inclusion of 'Fuel supply emergency' in Attachment 2 creates confusion as it infers that reporting a 'fuel supply emergency' may be required by the standard even though 'fuel supply emergency' is not listed in Attachment 1. On a similar note, it is not clear what the drafting team is hoping to capture by including a checkbox for 'other' in Attachment 2.
Group
Southwest Power Pool Regional Entity
Emily Pennel
Yes
Yes
Yes
1. EOP-004-2 R1.4 states entities must update their Operating Plans within 90 calendar days of incorporating lessons learned pursuant to R3. However, neither R3 nor Attachment 1 include a timeline for incorporating lessons learned. It is unclear when the "clock starts" on incorporating improvements or lessons learned. Within 90 days of what? 90 days of the event? 90 days from when management approved the lesson learned? Auditors need to know the trigger for the 90-day clock. 2. The Event Analysis classification includes Category 1C "failure or misoperation of the BPS SPS/RAS". This category is not included in EOP-004-2's Attachment 1. This event, "failure or misoperation of the BPS SPS/RAS", needs to either be added to Attachment 1 or removed from the Event Analysis classification. It is important that EOP-004-2 Attachment 1 and the Event Analysis categories match up. Thank you for your work on this standard.
Individual
Kevin Conway
Intellibind
Yes
No
The language proposed is not clear and will continue to add confusion to entities who are trying to meet these requirements. It is not clear that the drafting team can put itself in the position of how the auditors will interpret and implement compliance against thithe R2 requirement. Requirements should be written to stand alone, not reference other requirements (or parts of the requirments. If the R1 parts 1.1, 1.2, 1.4 and 1.5 are so significant for this requirement, then they should be rewritten in R2.
Yes
Does this reporting conflict with reporting for DOE, and Regions? If so, what reporting requirements will the entity be held accountable to? Managing multiple reporting requirements for the multiple agencies is very problematic for entities and this standard should resolve those reporting requirments, as well as reduce the reporting down to one form and one submission. Reporting to ESISAC should take care of all reporting by the company. NERC should route all reports to the DOE, and regions through this mechanism.
I do not see that the rewrite of this standard is meeting the goal of clear reliability standards, and in fact the documents are looking more like legal documents. Though the original EOP-004 and CIP-001 was problematic at times, this rewrite, and the need to have such extensive guidance, attachments, and references for EOP-004-2 will create an even more difficult standard to properly meet to ensure

compliance during an audit. Though CIP-001 and EOP-004 were related, combining them in a single standard is not resolving the issues, and is in fact complicating the tasks. Requirements in this standard should deal with only one specific issue, not deal with multiple tasks. I am not sure how an auditor will consistently audit against R2, and how a violation will be categorized when an entity implements all portions of their Operating Plan, however fails to fully address all the requirements in R1, thereby not fully implementing R2, in strict interpretation. The drafting team should not set up a situation where an entity is in double jeopardy for missing an element of a requirement. I also suggest that EOP-004-2 be given a new EOP designation rather than calling it a revision. This way implementation can be better controlled, since most companies have written specific CIP-001 and EOP-004 document that will not simple transfer over to the new version. This standard is a drastic departure from the original versions. I appreciate the level of work that is going into EOP-004-2, it appears that significant time and effort has been going into the supporting documentation. It is my opinion that if this much material has to be created to state what the standard really requires, then the standard is flawed. When there are 21 pages of explanation for five requirements, especially when we have previously had 16 pages that originally covered 2 separate reliability standards, we need to reevaluate what we are really doing.

Group

Arizona Public Service Company

Janet Smith, Regulatory Affairs Supervisor

Yes

Yes

Yes

No comments

Individual

Chris Higgins / Jim Burns / Ted Snodgrass / Jeff Millenor / Russell Funk

Bonneville Power Administration

Yes

Yes

BPA believes the measures for R2 are unclear since they are similar to R3's reporting measures.

No

BPA believes that the first three elements in Attachment 1 are too generic and should be with only the intentional human criterion. The suspicious device needs to be determined as a threat (and not left behind tools) before requiring a report.

BPA believes that Attachment 1 has too many added reportable items because unintentional, equipment failure & operational errors are included in the first three items. A. Change to only "intentional human action". Otherwise, the first item "destruction of BES equipment" is too burdensome, along with its short time reporting time: i. - If a single transformer fails that shouldn't require a report. ii.- Emergency actions have to be taken for any failure of equipment, e.g. a loss of line reduces a path SOL and requires curtailments to reduce risk to the system. B. The item for "risk to BES" is not necessary until the suspicious object has been identified as a threat. If what turns out to be air impact wrench left next to BES equipment, that should not be a reportable incident as this current table implies. C. The nuclear "LOOP" should be only reported if total loss of off site source (i.e. 2 of 2 or 3 of 3) when supplying the plants load. If lightning or insulator fails causing one of the line sources to trip that's not a system disturbance especially if it is just used as a backup. It should only be a NRC process if they want to monitor that. The VRF/VSL: BPA believes that the VRF for R2 & R4 should be "Lower".

Individual

Chris de Graffenried

Consolidated Edison Co. of NY, Inc.



Yes
No
<p>Comments: • R1.3 should be revised as follows: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as determined by the responsible entity: ["appropriate: - deleted] [otherwise it is not clear who determines what communication level is appropriate] • R1.4 should be revised as follows: Provision(s) for updating the Operating Plan following ["within 90 calendar days of any" - deleted] change in assets or personnel (if the Operating Plan specifies personnel or assets) , ["other circumstances" - deleted] that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3. • R1.5 should be deleted. Responsible Entities can determine the frequency of Operating Plan updates. Requirement 1.4 requires updating the Operating Plan within 90 calendar days for changes in "assets, personnel.... or incorporating lessons learned". This requirement eliminates the need for Requirement 1.5 requiring a review of the Operating Plan on an annual basis.</p>
No
<p>Comments: We have a number of comments on Attachment 1 and will make them here: • Generally speaking the SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language. • EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded. • If the list of reportable events is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and in the EAP Categories 1 through 5. • It is not clear what the difference is between a footnote and "Threshold for Reporting". All information should be included in the body of the table, there should be no footnotes. • Event: "Risk to BES equipment" should be deleted. This is too vague and subjective. Will result in many "prove the negative" situations. • Event: "Destruction of BES equipment" is again too vague. The footnote refers to equipment being "damaged or destroyed". There is a major difference between destruction and damage. • Event: "Damage or Destruction of a Critical Asset or Critical Cyber Asset" should be deleted. Disclosure policies regarding sensitive information could limit an entity's ability to report. Unintentional damage to a CCA does not warrant a report. • Event: "BES Emergency requiring public appeal for load reduction" should be modified to note that this does not apply to routine requests for customer conservation during high load periods.</p>
<p>Comments: • Requirement 4 does not specifically state details necessary for an entity to achieve compliance. Requirement 4 should provide more guidance as to what is required in a drill. Audit / enforcement of any requirement language that is too broad will potentially lead to Regional interpretation, inconsistency, and additional CANs. • R4 should be revised to delete the 15 month requirement. CAN-0010 recognizes that entities may determine the definition of annual. • The Purpose of the Standard should be revised because some of the events being reported on have no impact on the BES. Revise Purpose as follows: To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of [add] "major system events." [delete - "with the potential to impact reliability and their causes, if known, by the Responsible Entities."]</p>
Individual
David Burke
Orange and Rockland Utilities, Inc.
Yes
No
<p>Comments: • R1.3 should be revised as follows: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as determined by the responsible entity: ["appropriate: - deleted] [otherwise it is not clear who determines what communication level is appropriate] • R1.4 should be revised as follows: Provision(s) for updating the Operating Plan following ["within 90 calendar days of any" - deleted] change in assets or personnel (if the Operating Plan specifies personnel or assets) , ["other circumstances" - deleted] that may no longer align with the Operating Plan; or incorporating lessons</p>

learned pursuant to Requirement R3. • R1.5 should be deleted. Responsible Entities can determine the frequency of Operating Plan updates. Requirement 1.4 requires updating the Operating Plan within 90 calendar days for changes in “assets, personnel.... or incorporating lessons learned”. This requirement eliminates the need for Requirement 1.5 requiring a review of the Operating Plan on an annual basis.

No

• Generally speaking the SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language. • EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded. • If the list of reportable events is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and in the EAP Categories 1 through 5. • It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes. • Event: “Risk to BES equipment” should be deleted. This is too vague and subjective. Will result in many “prove the negative” situations. • Event: “Destruction of BES equipment” is again too vague. The footnote refers to equipment being “damaged or destroyed”. There is a major difference between destruction and damage. • Event: “Damage or Destruction of a Critical Asset or Critical Cyber Asset” should be deleted. Disclosure policies regarding sensitive information could limit an entity’s ability to report. Unintentional damage to a CCA does not warrant a report. • Event: “BES Emergency requiring public appeal for load reduction” should be modified to note that this does not apply to routine requests for customer conservation during high load periods

Comments: • Requirement 4 does not specifically state details necessary for an entity to achieve compliance. Requirement 4 should provide more guidance as to what is required in a drill. Audit / enforcement of any requirement language that is too broad will potentially lead to Regional interpretation, inconsistency, and additional CANs. • R4 should be revised to delete the 15 month requirement. CAN-0010 recognizes that entities may determine the definition of annual. • The Purpose of the Standard should be revised because some of the events being reported on have no impact on the BES. Revise Purpose as follows: To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of [add] “major system events.” [delete - “with the potential to impact reliability and their causes, if known, by the Responsible Entities.”]

Individual

Alice Ireland

Xcel Energy

Yes

No

Suggest modifying R3 to indicate this is related to R 1.3. Each Responsible Entity shall report events to entities specified in R1.3 and as identified as appropriate in its Operating Plan.

Yes

Group

BC Hydro

Patricia Robertson

Yes

Yes

No

As an event would be verbally reported to the RC, all the one hour requirements to submit a written report should be moved from one hour to 24 hours.

Attachment 1: Reportable Events: BC Hvdro recommends further defining “BES equipment” for the

events Destruction of BES equipment and Risk to BES equipment. Attachment 1: Reportable Events: BC Hydro recommends defining the Forced intrusion event as the wording is very broad and open to each entities interpretation. What would be a forced intrusion ie entry or only if equipment damage occurs?

Individual

Greg Rowland

Duke Energy

Yes

Yes

No

All events in Attachment 1 should have reporting times of no less than 24 hours. As stated on page 6 of the current draft of the standard: "The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting." We maintain that a report which is required to be made within one hour after an event is, in fact, a real time report. In the first hour or even several hours after an event the operator may appropriately still be totally committed to restoring service or returning to a stable bulk power system state, and should not stop that recovery activity in order to make this "after-the-fact" report.

1. Reporting under EOP-004-2 should be more closely aligned with Events Analysis Reporting. 2. Attachment 1 – Under the column titled "Entity with Reporting Responsibility", several Events list multiple entities, using the phrase "Each RC, BA, TO, TOP, GO, GOP, DP that experiences..." or a similar phrase requiring that multiple entities report the same event. We believe these entries should be changed so that multiple reports aren't required for the same event. 3. Attachment 1 – The phrase "BES equipment" is used several times in the Events Table and footnotes to the table. "Equipment" is not a defined term and lacks clarity. "Element" and "Facility" are defined terms. Replace "BES equipment" with "BES Element" or "BES Facility". 4. Attachment 1 – The Event "Risk to BES equipment" is unclear, since some amount of risk is always present. Reword as follows: "Event that creates additional risk to a BES Element or Facility." 5. Attachment 1 – The Threshold for Reporting Voltage deviations on BES Facilities is identified as "+ 10% sustained for > 15 continuous minutes." Need to clarify + 10% of what voltage? We think it should be nominal voltage. 6. Attachment 1 - Footnote 1 contains the phrase "has the potential to". This phrase should be struck because it creates an impossibly broad compliance responsibility. Similarly, Footnote 3 contains the same phrase, as well as the word "could" several times, which should be changed so that entities can reasonably comply. 7. Attachment 1 – The "Unplanned Control Center evacuation" Event has the word "potential" in the column under "Entity with Reporting Responsibility". The word "potential" should be struck. 8. Attachment 2 – Includes "fuel supply emergency", which is not listed on Attachment 1.

Group

Progress Energy

Jim Eckelkamp

(1) Attachment 1 lists "Destruction of BES Equipment" as a reportable event but then lists "equipment failure" as one of several thresholds for reporting, with a one hour time limit for reporting. It is simply not common sense to think of the simple failure of a single piece of equipment as "destruction of BES equipment". Does the standard really expect that every BES equipment failure must be reported within one hour, regardless of cause or impact to BES reliability? What is the purpose of such extensive reporting? (2) The same comment as (1) above is applicable to the "Damage or destruction of Critical Asset" because one threshold is simple "equipment failure" as well. (3) Footnote 2 (page 20) says copper theft is not reportable "unless it effects the reliability of the BES", but footnote 1 on the same page says copper theft is reportable if "it degrades the ability of equipment to operate

properly". In this instance, the proposed standard provides two different criteria for reporting one of the most common events on the same page. (4) Forced Intrusion must be reported if "you cannot determine the likely motivation", and not based on a conclusion that the intent was to commit sabotage or intentional damage. This would require reporting many theft related instances of cut fences and forced doors (including aborted theft attempts where nothing is stolen) which would consume a great deal of time and resources and accomplish nothing. This criteria is exactly the opposite of the existing philosophy of only reporting events if there is an indication of an intent to commit sabotage or cause damage. (5) "Risk to BES equipment...from a non-environmental physical threat" is reportable, but this is an example of a vague, open ended reporting requirement that will either generate a high volume of unproductive reports or will expose reporting entities to audit risk for not reporting potential threats that could have been reported. The standard helpfully lists train derailments and suspicious devices as examples of reportable events. The existing CAN for CIP-001 (CAN-0016) is already asking for a list of events that were analyzed so the auditors can determine if a violation was committed due to failure to report. I can envision the CAN for this new standard requiring a list of all "non-environmental physical threats" that were analyzed during the audit period to determine if applicable events were reported. This could generate a great deal of work simply to provide audit documentation even if no events actually occur that are reportable. It would also be easy for an audit team to second guess a decision that was made by an entity not to report an event (what is risk?...how much risk was present due to the event?...). Also, the reporting for this vague criteria must be done within one hour. Any event with a one hour reporting requirement should be crystal clear and unambiguous. (6) Transmission Loss...of three or more Transmission Facilities" is reportable. "Facility" is a defined term in the NERC Glossary, but "Transmission Facility" is not a defined term, which will lead to confusion when this criteria is applied. This requirement raises many confusing questions. What if three or more elements are lost due to two separate or loosely related events – is this reportable or not? What processes will need to be put in place to count elements that are lost for each event and determine if reporting is required? Why must events be reported that fit an arbitrary numerical criteria without regard to any material impact on BES reliability?

Individual

Rodney Luck

Los Angeles Department of Water and Power

No

The reporting time of within 1 hour of recognition for a "Forced Intrusion" (last event category on page 20 of Draft 3, dated October 25, 2011) when considered with the associated footnote "Report if you cannot reasonably determine likely motivation" is overly burdensome and unrealistic. What is "reasonably determine likely motivation" is too general and requires further clarity. For example, LADWP has numerous facilities with extensive perimeter fencing. There is a significant difference between a forced intrusion like a hole or cut in a property line fence of a facility versus a forced intrusion at a control house. Often cuts in fences, after further investigation, are determined to be cases of minor vandalism. An investigation of this nature will take much more than the allotted hour. The NERC Design Team needs to develop difference levels for the term "Force Intrusion" that fit the magnitude of the event and provide for adequate time to determine if the event was only a case of minor vandalism or petty thief. The requirement, as currently written, would unnecessarily burden an entity in reporting events that after given more time to investigate would more than likely not have been a reportable event.

Individual

Daniel Duff

Liberty Electric Power

No

Training should be left in the standard as an option, along with an actual event, drill or exercise, to demonstrate that operating personnel have knowledge of the procedure.

Yes

Yes
Group
ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi
Mary Jo Cooper
Yes
Yes
Yes
We feel that the drafting team has done an excellent job of providing clarification and reasonable reporting requirements to the right functional entity. However we feel additional clarification should be made in the Attachment I Event Table. We suggest the following modifications: For the Event: BES Emergency resulting in automatic firm load shedding Modify the Entity with Reporting Responsibility to: Each DP or TOP that experiences the automatic load shedding within their respective distribution serving or Transmission Operating area. For the Event: Loss of Firm load for ≥ 15 Minutes Modify the Entity with Reporting Responsibility to: Each BA, TOP, DP that experiences the loss of firm load within their respective balancing, Transmission operating, or distribution serving area.
Individual
Lisa Rosintoski
Colorado Springs Utilities
Yes
No
The act of implementing the plan needs to include reporting events per R1, sub-requirement 1.3. R2 should simply state something like, "Each Responsible Entity shall implement the Operating Plan that meets the requirements of R1, as applicable, for an actual event or as specified." Suggest eliminating R3 which, seems to create double jeopardy effect.
Yes
Agree with concept to combine CIP-001 into EOP-004. Agree with elimination of "sabotage" concept. Appreciate the attempt to combine reporting requirements, but it seems that in practice will still have separate reporting to DOE and NERC/Regional Entities. EOP-004-2 A.5. "Summary of Key Concepts" refers to Att. 1 Part A and Att. 1 Part B. I believe these have now been combined. EOP-004-2 A.5. "Summary of Key Concepts" refers to development of an electronic reporting form and inclusion of regional reporting requirements. It is unfortunate no progress was made on this front.
Individual
Michael Falvo
Independent Electricity System Operator
Yes
No
We agree with the revision to R2 and R3, but assess that a requirement to enforce implementation of Part 1.3 in Requirement R1 is missing. Part 1.3 in Requirement R1 stipulates that: 1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate: • Internal company personnel • The Responsible Entity's Regional Entity • Law enforcement • Governmental or provincial agencies The implementation of Part 1.3 is not enforced by R2 or R3 or any other Requirements in the standard. Suggest to add another requirement or expand Requirement R4 (and M4) to require the implementation of this Part in addition to verifying the process.

Yes
<p>1. Measures M1, M2 and M3: Suggest to achieve consistent wording among them by saying the leading part to "Each Responsible Entity shall provide...." 2. In our comments on the previous version, we suggested the SDT to review the need to include IA, TSP and LSE for some of the reporting requirements in Attachment 1. The SDT's responded that it had to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, they will be subject to reporting. We accept this rationale. However, the revised Attachment 1 appears to be still somewhat discriminative on who needs to report an event. For example, the event of "Detection of a reportable Cyber Security Incident" (6th row in the table) requires reporting by a list of responsible entities based on the underlying requirements in CIP-008, but the list does not include the IA, TSP and LSE. We again suggest the SDT to review the need for listing the specific entities versus leaving it general by saying: "Applicable Entities under CIP-008" for this particular item, and review and establish a consistent approach throughout Attachment 1. 3. VSLs: a. Suggest to not list all the specific entities, but replace them with "Each Responsible Entity" to simplify the write-up which will allow readers to get to the violation condition much more quickly. b. For R1, it is not clear whether the conditions listed under the four columns are "OR" or "AND". We believe it means "OR", but this needs to be clarified in the VSL table. 4. The proposed implementation plan conflicts with Ontario regulatory practice respecting the effective date of the standard. It is suggested that this conflict be removed by appending to the implementation plan wording, after "applicable regulatory approval" in the Effective Dates Section on P. 2 of the draft standard and P. 1 of the draft implementation plan, to the following effect: ", or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities."</p>
Individual
John Bee on Behalf of Exelon
Exelon
Yes
Yes
Why is the reference to R1.3 missing from EOP-004-2 Requirement R2?
No
<p>Due to the size of the service territories in ComEd and PECO it's difficult to get to some of the stations within in an hour to analyze an event which causes concern with the 1 hour criteria. It is conceivable that the evaluation of an event could take longer then one hour to determine if it is reportable. Exelon cannot support this version of the standard until the 1 hour reporting criteria is clarified so that the reporting requirements are reasonable and obtainable. Exelon has concerns about the existing 1 hour reporting requirements and feels that additional guidance and verbiage is required for clarification. We would like a better understanding when the 1 hour clock starts please consider using the following clarifying statement, in the statements that read, "recognition of events" please consider replacing the word "recognition" with the word "confirmation" as in a "confirmed event"</p>
<p>1. Please replace the text "Operating Plan" with procedure(s). Many companies have procedure(s) for the reporting and recognition of sabotage events. These procedures extend beyond operating groups and provide guidance to the entire company. 2. The Loss of Off-site power event criteria is much improved from the last draft of EOP 004-2; however, some clarification is needed to more accurately align with NERC Standard NUC-001 in both nomenclature and intent. Specifically, as Exelon has previously commented, there are many different configurations supplying offsite power to a nuclear power plant and it is essential that all configurations be accounted for. As identified in the applicability section of NUC-001 the applicable transmission entities may include one or more of the following (TO, TOP, TP, TSP, BA, RC, PC, DP, LSE, and other non-nuclear GO/GOPs). Based on the response to previous comments submitted for Draft 2, Exelon understands that the DSR SDT evaluated the use of the word "source" but dismissed the use in favor of "supply" with the justification "[that] 'supply' encompasses all sources". Exelon again suggests that the word "source" is used as the event criteria in EOP-004-2 as this nomenclature is commonly used in the licensing basis of a nuclear power plant. By revising the threshold criteria to "one or more" Exelon believes the concern the DSR SDT noted is addressed and ensures all sources are addressed. In addition, by revising the threshold for reporting to a loss of "one or more" will ensure that all potential events (regardless of configuration of off-site</p>

power supplies) will be reported by any applicable transmission entity specifically identified in the nuclear plant site specific NPIRs. As previously suggested, Exelon again proposes that the loss of an off-site power source be revised to an “unplanned” loss to account for planned maintenance that is coordinated in advance in accordance with the site specific NPIRs and associated Agreements. This will also eliminate unnecessary reporting for planned maintenance. Although the loss of one off-site power source may not result in a nuclear generating unit trip, Exelon agrees that an unplanned loss of an off-site power source regardless of impact should be reported within the 24 hour time limit as proposed. Suggest that the Loss of Offsite power to a nuclear generating plant event be revised as follows: Event: Unplanned loss of any off-site power source to a Nuclear Power Plant Entity with Reporting Responsibility: The applicable Transmission Entity that owns and/or operates the off-site power source to a Nuclear Power Plant as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) and associated Agreements. Threshold for Reporting: Unplanned loss of one or more off-site power sources to a Nuclear Power Plant per the applicable NPIRs. 3. Attachment 1 Generation loss event criteria Generation loss The  $\geq 2000$  MW/ $\geq 1000$  MW generation loss criteria do not provide a time threshold or location criteria. If the 2000 MW/1000 MW is intended to be from a combination of units in a single location, what is the time threshold for the combined unit loss? For example, if a large two unit facility in the Eastern Interconnection with an aggregate full power output of 2200 MW (1100 MW per unit) trips one unit (1100 MW) [T=0 loss of 1100 MW] and is ramping back the other unit from 100% power and 2 hours later the other unit trips at 50% power [550 MW at time of trip]. The total loss is 2200 MW; however, the loss was sustained over a 2 hour period. Would this scenario require reporting in accordance with Attachment 1? What if it happened in 15 minutes? 1 hour? 24 hours? Exelon suggests the criteria revised to include a time threshold for the total loss at a single location to provide this additional guidance to the GOP (e.g., within 15 minutes to align with other similar threshold conditions). Threshold for Reporting  $\geq 2,000$  MW unplanned total loss at a single location within 15 minutes for entities in the Eastern or Western Interconnection  $\geq 1000$  MW unplanned total loss at a single location within 15 minutes for entities in the ERCOT or Quebec Interconnection 4. Exelon appreciates that the DSR SDT has added the NRC to the list of Stakeholders in the Reporting Process, but does not agree with the SDT response to FirstEnergy’s comment to Question 17 [page 206] that stated “NRC requirements or comments fall outside the scope of this project.” Quite the contrary, this project should be communicated and coordinated with the NRC to eliminate confusion and duplicative reporting requirements. There are unique and specific reporting criteria and coordination that is currently in place with the NRC, the FBI and the JTTF for all nuclear power plants. If an event is in progress at a nuclear facility, consideration should be given to coordinating such reporting as to not duplicate effort, introduce conflicting reporting thresholds, or add unnecessary burden on the part of a nuclear GO/GOP who’s primary focus is to protect the health and safety of the public during a potential radiological sabotage event (as defined by the NRC) in conjunction with potential impact to the reliability of the BES. 5. Attachment 1 Detection of a reportable Cyber Security Incident event criteria The threshold for reporting is “that meets the criteria in CIP-008”. If an entity is exempt from CIP-008, does that mean that this reportable event is therefore also not applicable in accordance with EOP-004-2 Attachment 1?

Individual

Public Utility District No. 1 of Snohomish County

John D. Martinsen

Yes

Yes

Yes

The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. The EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify if both forms will still be required to be submitted. We also need to ensure that there won’t be a duplication of efforts between the two reports. This is fairly minor, but the clarification need should be addressed.

Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System (“BES”) definition changes, as well as the CIP standards

Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist. As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts. Related to "Reportable Events" of Attachment 1: 1. A reportable event is stated as, "Risk to the BES", the threshold for reporting is, "From a non-environmental physical threat". This appears to be a catch-all event, and basically every other event in Attachment 1 should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list. 2. A reportable event is stated as, "Damage or destruction of Critical Asset per CIP-002". The term "Damage" would have to be defined in order for an entity to determine a threshold for what qualifies as "Damage" to a CA. One could argue that normal "Damage" can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard. Reporting Thresholds 1. The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing. An example is the "BES Emergency requiring manual firm load shedding of greater than or equal to 100 MW or the Loss of Firm load for  $\geq$  15 Minutes that is greater than or equal to 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases these low thresholds represent reporting of minor wind events or other seasonal system issues on Local Network used to provide distribution service. Firm Demand 1. The use of Firm Demand in the context of the draft Standards could be used to describe commercial arrangements with a customer rather than a reliability issue. Clarification of Firm Demand would be helpful

Group

MRO NSRF

WILL SMITH

Yes

Yes

Yes

Yes

Yes

Yes

: The MRO NSRF wishes to thank the SDT for incorporating changes that the industry had with reporting time periods and aligning this with the Events Analysis Working Group and Department of Energy's OE 417 reporting form.

Group

Western Electricity Coordinating Council

Steve Rueckert

Yes

Yes

Yes

Yes

Yes

Yes

Results-based standards should include, within each requirement, the purpose or reason for the requirement. The requirements of this standard, while we support the requirements, do not include the goal or proupose of meeting each stated requirement. The Measures all include language stating "the responsible entity shall provide...". During a quality review of a WECC Regional Reliability Standard we were told that the "shall provide" language is essentially another requirement to provide something. If it is truly necessary to provide this it should be in the requirements. It was suggested to us that we drop the "shall provide" language and just start each Measure with the "Evidence may include but is not limited to...".

Individual



RoLynda Shumpert
South Carolina Electric and Gas
Yes
Yes
Yes
In terms of receiving reports, is it the drafting teams expectation that separate reports be developed by both the RC and the TOP, GO, BA, etc. for an event that occurs on a company's system that is within the RC's footprint? One by the RC and one by the TOP, GO, BA, etc. In terms of meeting reporting thresholds, is it the drafting teams expectation that the RC aggregate events within its RC Area to determine whether a reporting threshold has been met within its area for the quantitative thresholds?
Individual
Kathleen Goodman
ISO New England
No
Please see further comments; we do not believe R4 is a necessary requirement in the standard and suggest it be deleted.
No
In accordance with the results-based standards concept, all that is required, for the "what" is that company X reported on event Y in accordance with the reporting requirements in attachment Z of the draft standard. Therefore, we proposed the only requirement that is necessary is R3, which should be re-written to read... "Each Responsible Entity shall report to address the events listed in Attachment 1."
Yes
Attachment 1 should be revisited. "Equipment Damage" is overly vague and will also potentially result in reporting on equipment failures which may simply be related to the age and/or vintage of equipment.
Group
Imperial Irrigation District
Jesus Sammy Alcaraz
Yes
Yes
Yes
IID strongly believes the reporting flowchart should not be part of a standard. The suggestion is to replace it with a more clear, right to the point requirement.
Individual
Curtis Crews
Texas Reliability Entity
Substantive comments: 1.ERO and Regional Entities should not be included in the Applicability of this standard. Just because they may be subject to some CIP requirements does not mean they also have to be included here. The ERO and Regional Entities do not operate equipment or systems that are

integral to the operation of the BES. Also, none of the VSLs apply to the ERO or to Regional Entities. 2.The first entry in the Events Table should say "Damage or destruction of BES equipment." Equipment may be rendered inoperable without being "destroyed," and entities should not have to determine within one hour whether damage is sufficient to cause the equipment to be considered "destroyed." Footnote 1 refers to equipment that is "damaged or destroyed." 3.In the Events Table, consider whether the item for "Voltage deviations on BES facilities" should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator and power system stabilizer) could have a similar impact on the BES as other reportable items. 4.In the Events Table, under Transmission Loss, does this item require that at least three Facilities owned by one entity must be lost to trigger the reporting requirement, or is the reporting requirement also to be triggered by loss of three Facilities during one event or occurrence that are owned by two or three different entities? 5.In the Events Table, under Transmission Loss, it is unclear how Facilities are to be counted to determine when "three or more" Facilities are lost. In the NERC Glossary, Facility is ambiguously defined as "a set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)." In many cases, a "set of electrical equipment" can be selected and counted in different ways, which makes this item ambiguous. 6.In the Events Table, under Transmission Loss, it appears that a substation bus failure would only count as a loss of one Facility, even though it might interrupt flow between several transmission lines. We believe this type of event should be reported under this standard, and appropriate revisions should be made to this entry. 7.In the Events Table, under Transmission Loss, consider including generators that are lost as a result of transmission loss events when counting Facilities. For example, if a transmission line and a transformer fail, resulting in a generator going off-line, that should count as a loss of "three or more" facilities and be reportable under this standard. 8.In the Events Table, under "Unplanned Control Center evacuation" and "Loss of monitoring or all voice communication capability," GOPs should be included. GOPs also operate control centers that would be subject to these kinds of occurrences. 9.In the Events Table, under "Loss of monitoring or all voice communication capability," we suggest adding that if there is a failure at one control center, that event is not reportable if there is a successful failover to a backup system or control center. 10."Fuel supply emergency" is included in the Event Reporting Form, but not in Attachment 1, so there is no reporting threshold or deadline provided for this type of event. Clean-up items: 1.In R1.5, capitalize "Responsible Entity" and lower-case "process". 2.In footnote 1, add "or" before "(iii)" to clarify that this event type applies to equipment that satisfies any one of these three conditions. 3.In the Event Reporting Form, "forced intrusion" and "Risk to BES equipment" are run together and should be separated. VSLs: 1.We support the substance of the VSLs, but the repeated long list of entities makes the VSLs extremely difficult to read and decipher. The repeated list of entities should be replaced by "Responsible Entities." 2.If the ERO and Regional Entities are to be subject to requirements in this standard (which we oppose), they need to be added to the VSLs.

Individual

Andrew Z. Pusztai

American Transmission Company, LLC

Yes

Yes

Yes

ATC appreciates the work of the SDT in incorporating changes that the industry had with reporting time periods and aligning this with the Events Analysis Working Group and Department of Energy's OE 417 reporting form.

Individual

Anthony Jablonski

ReliabilityFirst

ReliabilityFirst thanks the SDT for their effort on this project. ReliabilityFirst has a number of concerns/questions related to the draft EOP-004-2 standard which include the following:

1. General Comment - The SDT should consider any possible impacts that could arise related to the applicability of Generator Owners that may or may not own transmission facilities. This will help alleviate any potential or unforeseen impacts on these Generator Owners
2. General Comment – Though the rationale boxes contain useful editorial information for each requirement, they should rather contain the technical rationale or answer the question “why is this needed” for each requirement. The rationale boxes currently seem to contain suggestions on how to meet the requirements. ReliabilityFirst suggests possibly moving some of the statements in the “Guideline and Technical Basis” into the rationale boxes, as some of the rationale seems to be contained in that section.
3. General comment – The end of Measure M4 is incorrectly pointing to R3. This should refer to R4.
4. General Comment – ReliabilityFirst recommends the “Reporting Hierarchy for Reportable Events” flowchart should be removed from the “Background” section and put into an appendix. ReliabilityFirst believes the flowchart is not really background information, but an outline of the proposed process found in the new standard.
5. Applicability Comment – ReliabilityFirst questions the newly added applicability for both the Regional Entity (RE) and ERO. Standards, as outlined in many, if not all, the FERC Orders, should have applicability to users, owners and operators of the BES and not to the compliance monitoring entities (e.g. RE and ERO). Any requirements regarding event reporting for the RE and ERO should be dealt with in the NERC Rules of Procedure and/or Regional Delegation Agreements. It is also unclear who would enforce compliance on the ERO if the ERO remains an applicable entity.
6. Requirement Comment - ReliabilityFirst believes the process for communicating events in Requirement R1, Part 1.3 should be all inclusive and therefore include the bullet points. Bullet points are considered to be “OR” statements and thus ReliabilityFirst believes they should be characterized as sub-parts. Listed below is an example: 1.3. A process for communicating events listed in Attachment 1 to the following: 1.3.1 Electric Reliability Organization, 1.3.2 Responsible Entity’s Reliability Coordinator 1.3.3 Internal company personnel 1.3.4 The Responsible Entity’s Regional Entity 1.3.5 Law enforcement 1.3.6 Governmental or provincial agencies
7. Requirement Comment – ReliabilityFirst questions why Requirement R1, Part 1.1 and Part 1.2 are not required to be verified when performing a drill or exercise in Requirement R4? ReliabilityFirst believes that performing a drill or exercise utilizing the process for identifying events (Part 1.1) and the process for gathering information (Part 1.2) are needed along with the verification of the process for communicating events as listed in Part 1.3.
8. Compliance Section Comment – Section 1.1 states “If the Responsible Entity works for the Regional Entity...” and ReliabilityFirst questions the intent of this language. ReliabilityFirst is unaware of any Responsible Entities who work for a Regional Entity. Also, if the Regional Entity and ERO remain as applicable entities, in Section 1.1 of the standard, it is unclear who will act as the Compliance Enforcement Authority (CEA).
9. Compliance Section Comment – ReliabilityFirst recommends removing the second, third and fourth paragraphs from Section 1.2 since ReliabilityFirst believes entities should retain evidence for the entire time period since their last audit.
10. Compliance Section Comment – ReliabilityFirst recommends modifying the fifth paragraph from Section 1.2 as follows: “If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or until a data hold release is issued by the CEA.” ReliabilityFirst believes, as currently stated, the CEA would be required to retain information for an indefinite period of time.
11. Compliance Section Comment – ReliabilityFirst recommends removing the sixth paragraph from Section 1.2 since the requirement for the CEA to keep the last audit records and all requested and submitted subsequent audit records is already covered in the NERC ROP.
12. Attachment 1 Comment – It is unclear what the term/acronym “Tv” is referring to. It may be beneficial to include a footnote clarifying what the term “Tv” stands for.
13. VSL General Comment – although ReliabilityFirst believes that the applicability is not appropriate, as the REs and ERO are not users, owners, or operators of the Bulk Electric System, the Regional Entity and ERO are missing from all four sets of VSLs, if the applicability as currently written stays as is. If the Regional Entity and ERO are subject to compliance for all four requirements, they need to be included in the VSLs as well. Furthermore, for consistency with other standards, each VSL should begin with the phrase “The Responsible Entity...”
14. VSL 4 Comment - The second “OR” statement under the “Lower” VSL should be removed. By not verifying the communication process in its Operating Plan within the calendar year, the responsible entity completely missed the intent of the requirement and is already covered under the “Severe” VSL category.

Individual
Don Schmit

Nebraska Public Power District
Yes
Yes
Yes
Although 24 hours is a vast improvement, one business day would make more sense for after the fact reporting.
Individual
Dennis Sismaet
Seattle City Light
Yes
Yes
Yes
The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. The EOP-004 has an "optional" Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify if both forms will still be required to be submitted. We also need to ensure that there won't be a duplication of efforts between the two reports. This is fairly minor, but the clarification need should be addressed.
Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes, as well as the CIP standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist. As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts. Related to "Reportable Events" of Attachment 1: 1. A reportable event is stated as, "Risk to the BES", the threshold for reporting is, "From a non-environmental physical threat". This appears to be a catch-all event, and basically every other event in Attachment 1 should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list. 2. A reportable event is stated as, "Damage or destruction of Critical Asset per CIP-002". The term "Damage" would have to be defined in order for an entity to determine a threshold for what qualifies as "Damage" to a CA. One could argue that normal "Damage" can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard. Reporting Thresholds 1. The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing. An example is the "BES Emergency requiring manual firm load shedding of greater than or equal to 100 MW or the Loss of Firm load for ≥ 15 Minutes that is greater than or equal to 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases these low thresholds represent reporting of minor wind events or other seasonal system issues on Local Network used to provide distribution service. Firm Demand 1. The use of Firm Demand in the context of the draft Standards could be used to describe commercial arrangements with a customer rather than a reliability issue. Clarification of Firm Demand would be helpful
Individual
John Seelke
PSEG
Yes

Yes
Yes
<p>We have several comments: 1. The "Law Enforcement Reporting" section on p. 6 is unclearly written. The first three sentences are excerpted here: "The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement." The outages described prior to the last sentence are "vandalism and terrorism." The next sentence states "Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES." If the SDT intended to only have events reported to law enforcement that could to Cascading, it should state so clearly and succinctly. But other language implies otherwise. a. The footnote 1 on Attachment 1 (p. 20) states: "Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative)." Rendering a relay inoperative may or may not lead to Cascading. b. With regard to "forced intrusion," footnote 2 on Attachment 1 states: "Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects (sic) the reliability of the BES." The criterion, or criteria, for reporting an event to law enforcement needs to be unambiguous. The SDT needs to revise this "Law Enforcement Section" so that is achieved. The "law enforcement reporting" criterion, or criteria, should also be added to the flow chart on p. 9. We suggest the following as a starting point for the team to discuss: there should be two criteria for reporting an event to law enforcement: (1) BES equipment appears to have been deliberately damaged, destroyed, or stolen, whether by physical or cyber means, or (2) someone has gained, or attempted to gain, unauthorized access by forced or unauthorized entry (e.g., via a stolen employee keycard badge) into BES facilities, including by physical or cyber means. 2. The use of the terms "communicating events" in R1.3, and the use of the term "communication process" are confusing because in other places such as R3 the term "reporting" is used. If the SDT intends "communicating" to mean "reporting" as that later term is used in R3, it should use the same "reporting" term in lieu of "communicating" or "communication" elsewhere. Inconsistent terminology causes confusion. PSEG prefers the word "reporting" because it is better understood. 3. Attachment 1 needs to more clearly define what is meant by "recognition of an event." a. When equipment or a facility is involved, it would better state within "X" time (e.g., 1 hour) of "of confirmation of an event by the entity that either owns or operates the Element or Facility." b. Other reports should have a different specification of the starting time of the reporting deadline clock. For example, in the requirement for reporting a "BES Emergency requiring public appeal for load reduction," it is unclear what event is required to be reported - the "BES Emergency requiring public appeal" or "public appeal for load reduction." If the later is intended, then the event should be reported within "24 hours after a public appeal for load reduction is first issued." These statements need to be reviewed and customized for each event by the SDT so they are unambiguous. In summary, the starting time for the reporting clock to start running should be made clear for each event. This will require that the SDT review each event and customize the starting time appropriately. The phrase "recognition of an event" should not be used because it is too vague. 4. When EOP-004-2 refers to other standards, it frequently omits the version of the standard. Example: see the second and third row of Attachment 1 that refers to "CIP-002." Include the version on all standards referenced.</p>
Group
Compliance & Responsibility Office
Silvia Parada Mitchell
Yes
See comments in response to Question 4.
Yes
See comments in response to Question 4.
Yes
See comments in response to Question 4.
NextEra Energy, Inc. (NextEra) appreciates the DSR SDT revising proposed EOP-004-2, based on the

previous comments of NextEra and the stakeholders. NextEra, however, believes that EOP-004-2 needs additional refinement prior to approval. R1.3 In R1.3, NextEra is concerned that the term "internal company personnel" is unclear and may be misinterpreted. For example, NextEra does not believe this term should include all company or corporate personnel, or even all personnel in the Responsible Entity's company or business unit. Instead, the definition of personnel should be limited to those who could be directly impacted by the event or are working on the event. Thus, NextEra suggests that the language in R1.3 be revised to read: "Internal Responsible Entity personnel whose tasks require them to take specific actions to mitigate, stop the spread and/or normalize the event, or personnel who are directly impacted by the event." NextEra is concerned that R1.3, as written, will be interpreted differently from company to company, region to region, auditor to auditor, and, therefore, may result in considerable confusion during actual events as well as during the audits/stop checks of EOP-004-2 compliance. Also, in R1.3, NextEra is concerned that many of the events listed in Attachment A already must be reported to NERC under its trial (soon to be final) Event Analysis Reporting requirements (Event Analysis). NextEra believes duplicative and different reporting requirements in EOP-004-2 and the Event Analysis rules will cause confusion and inefficiencies during an actual event, which will likely be counterproductive to promoting reliability of the bulk power system. Thus, NextEra believes that any event already covered by NERC's Event Analysis should be deleted from Attachment 1. Events already covered include, for example, loss of monitoring or all voice, loss of firm load and loss of generation. If this approach is not acceptable, NextEra proposes, in the alternative, that the reporting requirements between EOP-004-2 and Event Analysis be identical. For instance, in EOP-004-2, there is a requirement to report any loss of firm load lasting for more than 15 minutes, while the Event Analysis only requires reporting the of loss of firm load above 300 megawatts and lasting more than 15 minutes. Similarly, EOP-004-2 requires the reporting of any unplanned control center evacuation, while the Event Analysis only requires reporting after the evacuation of the control center that lasted 30 minutes or more. Thus, NextEra requests that either EOP-004-2 not address events that are already set forth in NERC's Event Analysis, or, in the alternative, for those duplicative events to be reconciled and made identical, so the thresholds set forth in the Event Analysis are also used in EOP-004-2. In addition, NextEra believes that a reconciliation between the language "of recognition" in Attachment 1 and "process to identify" in R1.1 is necessary. NextEra prefers that the language in Attachment 1 be revised to read " . . . of the identification of the event under the Responsible Entity's R1.1 process." For instance, the first event under the "Submit Attachment 2 . . ." column should read: "The parties identified pursuant to R1.3 within 1 hour of the identification of an event under the Responsible Entity's R1.1 process." This change will help eliminate confusion, and will also likely address (and possibly make moot) many of the footnotes and qualifications in Attachment 1, because a Responsible Entity's process will likely require that possible events are properly vetted with subject matter experts and law enforcement, as appropriate, prior to identifying them as "events". Thus, only after any such vetting and a formal identification of an event would the one hour or twenty-four hour reporting clock start to run. R1.4, R1.5, R3 and R4 NextEra is concerned with the wording and purpose of R1.4, R1.5, R3 and R4. For example, R1.4 requires an update to the Operating Plan for ". . . any change in assets, personnel, other circumstances . . ." This language is much too broad to understand what is required or its purpose. Further, R1.4 states that the Operating Plan shall be updated for lessons learned pursuant to R3, but R3 does not address lessons learned. Although there may be lessons learned during a post event assessment, there is no requirement to conduct such an assessment. Stepping back, it appears that the proposed EOP-004-2 has a mix of updates, reviews and verifications, and the implication that there will be lessons learned. Given that EOP-004-2 is a reporting Standard, and not an operational Standard, NextEra is not inclined to agree that it needs the same testing and updating requirements like EOP-005 (restoration) or EOP-008 (control centers). Thus, it is NextEra's preference that R1.4, R1.5 and R4 be deleted, and replaced with a new R1.4 as follows: R1.4 A process for ensuring that the Responsible Entity reviews, and updates, as appropriate its Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews. If the DSR SDT does not agree with this approach, NextEra, in the alternative, proposes a second approach that consolidates R1.4, R1.5 and R4 in a new R1.4 as follows: R1.4 A process for ensuring that the Responsible Entity tests and reviews its Operating Plan at least annually (once each calendar year) with no more than 15 months between a test and review. Based on the test and review, the Operating Plan shall be updated, as appropriate, within 90 calendar days. If an actual event occurs, the Responsible Entity shall conduct a post event assessment to identify any lessons learned within 90 calendar days of the event. If the Responsible Entity identifies any lessons learned in post event assessment, the lessons

learned shall be incorporated in the Operating Plan within 90 calendar days of the date of the final post event assessment. NextEra purposely did not add language regarding "any change in assets, personnel etc," because that language is not sufficiently clear or understandable for purposes of a mandatory requirement. Although it may be argued that it is a best practice to update an Operating Plan for certain changes, unless the DST SDT can articulate specific, concrete and understandable issues that require an updated Operating Plan prior to an annual review, NextEra recommends that the concept be dropped. Nuclear Specific Concerns EOP-004-2 identifies the Nuclear Regulatory Commission (NRC) as a stakeholder in the Reporting Process, but does not address the status of reporting to the NRC in the Event Reporting flow diagram on page 9. Is the NRC considered Law Enforcement as is presented in the diagram? Since nuclear stations are under a federal license, some of the events that would trigger local/state law enforcement at non-nuclear facilities would be under federal jurisdiction at a nuclear site. There are some events listed in Attachment 1 that seem redundant or out of place. For example, a forced intrusion is a one hour report to NERC. However, if there is an ongoing forced intrusion at a nuclear power plant, there are many actions taking place, with the NRC Operations Center as the primary contact which will mobilize the local law enforcement agency, etc. It is unclear that reporting to NERC in one hour promotes reliability or the resolution of an emergency in progress. Also, is there an ability to have the NRC in an emergency notify NERC? The same concerns related to cyber security events. Procedures versus Plan NextEra also suggests replacing "Operating Plan" with "procedures". Given that EOP-004-2 is a reporting Standard and not an operational Standard, it is typical for procedures that address this standard to reside in other departments, such as Information Management and Security. In other words, the procedures needed to address the requirements of EOP-004-2 are likely broader than the NERC-defined Operating Plan. Clean-Up Items In Attachment 1, Control Centers should be capitalized in all columns so as not to be confused with control rooms. Also, the final product should clearly state that the process flow chart that is set forth before the Standard is for illustrative purposes, so there is no implication that a Registered Entity must implement multiple procedures versus one comprehensive procedure to address different reporting requirements.

Individual

Barry Lawson

NRECA

1. Please ensure that the work of the SDT is done in close coordination with Events Analysis Process (EAP) work being undertaken by the PC/OC and BOT, and with any NERC ROP additions or modifications. NRECA is concerned that the EAP work being done by these groups is not closely coordinated even though their respective work products are closely linked -- especially since the EAP references information in EOP-004. 2. The SDT needs to be consistent in its use of "BES" and "BPS" -- both acronyms are used throughout the SDT documents. NRECA strongly prefers the use of "BES" since that is what NERC standards are written for. 3. Under "Purpose" section of standard, 3rd line, add "BES" between "impact" and "reliability." Without making this change the "Purpose" section could be misconstrued to refer to reliability beyond the BES. 4. In the Background section there is reference to the Events Analysis Program. Is that the same thing as the Events Analysis Process? Is it something different? Is it referring to a specific department at NERC? Please clarify in order to reduce confusion. Also in the Background section there is reference to the Events Analysis Program personnel. Who is this referring to -- NERC staff in a specific department? Please clarify. 5. In M1 please be specific regarding what "dated" means. 6. In M3 please make it clear that if there wasn't an event, this measure is not applicable. 7. In R4 it is not clear what "verify" means. Please clarify. 8. In Attachment 1 there are references to Critical Asset and Critical Cyber Asset. These terms will likely be eliminated from the NERC Glossary of Terms when CIP V5 moves forward and is ultimately approved by FERC. This could create future problems with EOP-004 if CIP V5 is made effective as currently drafted. 9. In Attachment 1 the one hour timeframe for submitting data for the first 7 items listed is very tight. Other than being required by the EOE JE-417 form, NRECA requests that the SDT provide further support for this timeframe. If there are not distinct reasons why 1 hour is the right timeframe for this, then other timeframes should be explored with DOE. 10. While including Footnote 1 is appreciated, NRECA is concerned that this footnote will create confusion in the compliance and audit areas and request the SDT to provide more definitive guidance to help explain what these "Events"

refer to. NRECA has the same comment on Footnote 2 and 3. Specifically in Footnote 3, how do you clearly determine and audit from a factual standpoint something that “could have damaged” or “has the potential to damage the equipment?” 11. In the Guideline and Technical Basis section, in the 1st bullet, how do you determine, demonstrate and audit for something that “may impact” BES reliability? 12. On p. 28, first line, this sentence seems to state that NERC, law enforcement and other entities – not the responsible entity – will be doing event analysis. My understanding of the current and future Event Analysis Process is that the responsible entity does the event analysis. Please confirm and clarify.

Individual

Terry Harbour

MidAmerican Energy

Yes

Yes

No

MidAmerican Energy agrees with the direction of consolidating CIP-001, EOP-004 and portions of CIP-008. However, we have concerns with some of the events included in Attachment 1 and reporting timelines. EOP-004-2 needs to clearly state that initial reports can be made by a phone call, email or another method, in accordance with paragraph 674 of FERC Order 706. MidAmerican Energy believes draft Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. Based on our understanding of Attachment 1, the category of “damage or destruction of a critical cyber asset” will result in hundreds or thousands of small equipment failures being reported to NERC and DOE, with no improvement to security. For example, hard drive failures, server failures, PLC failures and relay failures could all meet the criteria of “damage or destruction of a critical cyber asset.” We recommend replacing Attachment 1 and Attachment 2 with the categories and timeframes that are listed in OE-417. This eliminates confusion between government requirements in OE-417 and NERC standards. Reporting timelines and reporting form FERC Order 706, paragraph 676, directed NERC to require a responsible entity to “at a minimum, notify the ESISAC and appropriate government authorities of a cyber security incident as soon as possible, but, in any event, within one hour of the event, even if it is a preliminary report.” In paragraph 674, FERC stated that the Commission agrees that, in the “aftermath of a cyber attack, restoring the system is the utmost priority.” They clarified: “the responsible entity does not need to initially send a full report of the incident...To report to appropriate government authorities and industry participants within one hour, it would be sufficient to simply communicate a preliminary report, including the time and nature of the incident and whatever useful preliminary information is available at the time. This could be accomplished by a phone call or another method.” While FERC did not order completion of a full report within one hour in Order 706, the draft EOP-004 Attachment 1 appears to require submittal of formal reports within one hour for six of the categories, unless there have been “certain adverse conditions” (in which case, as much information as is available must be submitted at the time of notification). The Violation Severity Levels are extreme for late submittal of a report. For example, it would be a severe violation to submit a report more than three hours following an event for an event requiring reporting in one hour. MidAmerican Energy suggests incorporating the language from FERC Order 706, paragraph 674, into the EOP-004 reporting requirement to allow preliminary reporting within one hour to be done through a phone call or another method to allow the responsible entity to focus on recovery and/or restoration, if needed. MidAmerican Energy agrees with the use of DOE OE-417 for submittal of the full report of incidents under EOP-004 and CIP-008. We would note there are two parts to this form -- Schedule 1-Alert Notice, and Schedule 2-Narrative Description. Since OE-417 already requires submittal of a final report that includes Schedule 2 within 48 hours of the event, MidAmerican Energy believes it is not necessary to include a timeline for completion of the final report within the EOP-004 standard. We would note that Schedule 2 has an estimated public reporting burden time of two hours so it is not realistic to expect Schedule 2 to be completed within one hour. Events included in Attachment 1: MidAmerican Energy believes draft Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. The categories listed in Attachment 1 with one-hour reporting timelines cause the greatest concern. None



of these categories are listed in OE-417, and all but the last row would not be considered a Cyber Security Incident under CIP-008, unless there was malicious or suspicious intent.

MidAmerican proposes eliminating the phrase "with no more than 15 months between reviews" from R1.5. While we agree this is best practice, it creates the need to track two conditions for the review, eliminates flexibility for the responsible entity and does not improve security to the Bulk Electric System. There has not been a directive from FERC to specify the definition of annual within the standard itself. In conjunction with this comment, the Violation Severity Levels for R4 should be revised to remove the references to months.

Group

ACES Power Marketing Standards Collaborators

Jean Nitz

No

We understand and agree there should be verification of the information required for such reporting (contact information, process flow charts, etc). But we still believe improvements can be made to the draft standard, in particular to requirement R4. The use of the words "or through a drill or exercise" still implies that training is required if no actual event has occurred. When you conduct a fire "drill" you are training your employees on evacuation routes and who they need to report to. Not only are you verifying your process but you are training your employees as well. It is imperative that the information in the Event Reporting process is correct but we don't agree that performing a drill on the process is necessary. We recommend modifying the requirement to focus on verifying the information needed for appropriate communications on an event. And we agree this should take place at least annually.

No

Requirement R2 requires Responsible Entities to implement the various sub-requirements in R1. We believe it is unnecessary to state that an entity must implement their Operating Plan in a separate requirement. Having a separate requirement seems redundant. If the processes in the Operating Plan are not implemented, the entity is non-compliant with the standard. There doesn't need to be an extra requirement saying entities need to implement their Operating Plan.

Yes

For many of the events listed in Attachment 1, there would be duplicate reporting the way it is written right now. For example, in the case of a fire in a substation (Destruction of BES equipment), the RC, BA, TO, TOP and perhaps the GO and GOP could all experience the event and each would have to report on it. This seems quite excessive and redundant. We recommend eliminating this duplicate reporting.

Individual

Thad Ness

American Electric Power

Yes

No

AEP prefers to avoid requirements that are purely administrative in nature. Requirements should be clear in their actions of supporting of the BES. For example, we would prefer requirements which state what is to be expected, and allowing the entities to develop their programs, processes, and procedures accordingly. It has been our understanding that industry, and perhaps NERC as well, seeks to reduce the amount to administrative (i.e. document-based) requirements. We are confident that the appropriate documentation and administrative elements would occur as a natural course of implementing and adhering to action-based requirements. In light of this perspective, we believe that that R1 and R2 is not necessary, and that R3 would be sufficient by itself. Our comments above notwithstanding, AEP strongly encourages the SDT to consider that R2 and R3, if kept, be merged into a single requirement as a violation of R2 would also be a violation of R3. Two violations would then occur for what is essentially only a single incident. Rather than having both R2 and R3, might R3 be sufficient on its own? R2 is simply a means to an end of achieving R3. If there is a need to explicitly reference implementation, that could be addressed as part of R1. For example, R1 could

state "Each Responsible Entity shall implement an Operating Plan that includes..." R1 seems disjointed, as subparts 1.4 and 1.5 (updating and reviewing the Operating Plan) do not align well with subparts 1.1 through 1.3 which are process related. If 1.4 and 1.5 are indeed needed, we recommend that they be a part of their own requirement(s). Furthermore, the action of these requirements should be changed from emphasizing provision(s) of a process to demonstrating the underlying activity. 1.4: AEP is concerned by the vagueness of requiring provision(s) for updating the Operating Plan for "changes", as such changes could occur frequently and unpredictably.

Yes

M4: Recommend removing the text "for events" so that it instead reads "The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan created pursuant to Requirement R1, Part 1.3." R4: It is not clear to what extent the verification needs to be applied if the process used is complex and includes a variety of paths and/or tasks. The draft team may wish to consider changing the wording to simply state "each Responsible Entity shall test each of the communication paths in the operating plan". We also recommend dropping "once per calendar year" as it is inconstant with the measure itself which allows for 15 months.

Individual

Guy Andrews

Georgia System Operations Corporation

Yes

Yes

Yes

The ERO and the Regional Entity should not be listed as Responsible Entities. The ERO and the Regional Entity should not have to meet the requirements of this standard, especially reporting to itself. Attachment 1 (all page numbers are from the clean draft): Page 20, destruction of BES equipment: part iii) of the footnote adds damage as an event but the heading is for destruction. Is it just for destruction? Or is it for damage or destruction? Page 21, Risk to BES equipment: Footnote 3 gives an example where there is flammable or toxic cargo. These are environmental threats. However, the threshold for reporting is for non-environmental threats. Which is it? Page 21, BES emergency requiring public appeal for load reduction: A small deficient entity within a BA may not initiate public appeals. The BA is typically the entity which initiates public appeals when the entire BA is deficient. The initiating entity should be the responsible entity not the deficient entity. Page 21, BES emergency requiring manual firm load shedding: If a RC directs a DP to shed load and the DP initiates manually shedding its load as directed, is the RC the initiating entity? Or is it the DP? Page 22, system separation (islanding): a DP does not have a view of the system to see that the system separated or how much generation and load are in the island. Remove DP. Attachment 2 (all page numbers are from the clean draft): Page 25: fuel supply emergencies will no longer be reportable under the current draft. Miscellaneous typos and quality issues (all page numbers are from the clean draft): Page 5, the last paragraph: There are two cases where Parts A or B are referred to. Attachment 1 no longer has two parts (A & B). Page 27, Discussion of Event Reporting: the second paragraph has a typo at the beginning of the sentence.

Group

Florida Municipal Power Agency

Frank Gaffney

No

First, we wish to thank the SDT for their hard work and making significant progress in significant improvements in the standard. We commend the direction that the SDT is taking. There are; however, a few unresolved issues that cause us to not support the standard at this time. An issue of possible differences in interpretation between entities and compliance monitoring and enforcement is the phrase in 1.3 that states "the following as appropriate". Who has the authority to deem what is appropriate? The requirements should be clear that the Responsible Entity is the decision maker of

who is appropriate, otherwise there is opportunity for conflict between entities and compliance. In addition, 1.4 is onerous and burdensome regarding the need to revise the plan within 90 days of "any" change, especially considering the ambiguity of "other circumstances". "Other circumstances" is open to interpretation and a potential source of conflict.

No

Both requirements are to implement the Operating Plan. Hence, R3 should be a bullet under R2 and not a separate requirement. In addition, for R2, the phrase "actual event" is ambiguous and should mean: "actual event that meets the criteria of Attachment 1" We suggest the following wording to R2 (which will result in eliminating R3) "Each Responsible Entity shall implement its Operating Plan: • For actual events meeting the threshold criteria of Attachment 1 in accordance with Requirement R1 parts 1.1, 1.2 and 1.3 • For review and updating of the Operating Plan in accordance with Requirement R1 parts 1.4 and 1.5" Note that we believe that if the SDT decides to not combine R2 and R3, then we disagree with the distinction between the two requirements. The division of implementing R1 through R2 and R3 as presented is "implementing" vs. "reporting". We believe that the correct division should rather be "implementation" of the plan (which includes reporting) vs. revisions to the plan.

No

The times don't seem aggressive enough for some of the Events related to generation capacity shortages, e.g., we would think public appeal, system wide voltage reduction and manual firm load shedding ought to be within an hour. These are indicators that the BES is "on the edge" and to help BES reliability, communication of this status is important to Interconnection-wide reliability.

The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., "Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements") so that changes to the RoP do not necessitate changes to the standard. In R4, it might be worth clarifying that, in this case, implementation of the plan for an event that does not meet the criteria of Attachment 1 and going beyond the requirements R2 and R3 could be used as evidence. Consider adding a phrase as such to M4, or a descriptive footnote that in this case, "actual event" may not be limited to those in Attachment 1. Comments to Attachment 1 table: On "Damage or destruction of Critical Asset" and "... Critical Cyber Asset", Version 5 of the CIP standards is moving away from the binary critical/non-critical paradigm to a high/medium/low risk paradigm. Suggest adding description that if version 5 is approved by FERC, that "critical" would be replaced with "high or medium risk", or include changing this standard to the scope of the CIP SDT, or consider posting multiple versions of this standard depending on the outcome of CIP v5 in a similar fashion to how FAC-003 was posted as part of the GO/TO effort of Project 2010-07. On "forced intrusion", the phrase "at BES facility" is open to interpretation as "BES Facility" (e.g., controversy surrounding CAN-0016) which would exclude control centers and other critical/high/medium cyber system Physical Security Perimeters (PSPs). We suggest changing this to "BES Facility or the PSP or Defined Physical Boundary of critical/high/medium cyber assets". This change would cause a change to the applicability of this reportable event to coincide with CIP standard applicability. On "Risk to BES equipment", that phrase is open to too wide a range of interpretation; we suggest adding the word "imminent" in front of it, i.e., "Imminent risk to BES equipment". For instance, heavy thermal loading puts equipment at risk, but not imminent risk. Also, "non-environmental" used as the threshold criteria is ambiguous. For instance, the example in the footnote, if the BES equipment is near railroad tracks, then trains getting derailed can be interpreted as part of that BES equipment's "environment", defined in Webster's as "the circumstances, objects, or conditions by which one is surrounded". It seems that the SDT really means "non-weather related", or "Not risks due to Acts of Nature". On "public appeal", in the threshold, the descriptor "each" should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event? Should LSE be an applicable entity to "loss of firm load"? As proposed, the DP is but the LSE is not. In an RTO market, will a DP know what is firm and what is non-firm load? Suggest eliminating DP from the applicability of "system separation". The system separation we care about is separation of one part of the BES from another which would not involve a DP. On "Unplanned Control Center Evacuation", CIP v5 might add GOP to the applicability, another reason to add revision of EOP-004-2 to the scope of the CIP v5 drafting team, or in other ways coordinate this SDT with that SDT. Consider posting a couple of versions of the standard depending on the outcome of CIP v5 in a similar fashion to the multiple versions of FAC-003 posted with the Go/TO effort of

Project 2010-07.
Individual
Ed Davis
Entergy Services
Entergy agrees with and supports comments submitted by the SERC OC Standards Review group.
Individual
Margaret McNaul
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency
The first three incident categories designated on Attachment 1 as reportable events should be modified. As the Standard is current drafted, each incident category (i.e., destruction of BES equipment, damage or destruction of Critical Assets, and damage or destruction of Critical Cyber Assets) requires reporting if the event was due to unintentional human action. For example, under the reporting criteria as drafted, inadvertently dropping and damaging a piece of computer equipment designated as a Critical Cyber Asset while moving or installing it would appear to require an event report within an hour of the incident. MDEA requests that the Drafting Team consider modifying footnote 1 and each of the first three event categories to reflect that reportable events include only those that (i) affect an IROL; (ii) significantly affect the reliability margin of the system; or (iii) involve equipment damage or destruction due to intentional human action that results in the removal of the BES equipment, Critical Assets, and/or Critical Cyber Assets, as applicable, from service. Footnote 2 (which now pertains only to the fourth incident category – forced intrusions) should also apply to the first three event categories. Specifically, responsible entities should report intentional damage or destruction of BES equipment, damage or destruction of Critical Assets, and damage or destruction of Critical Cyber Assets if either the damage/destruction was clearly intentional or if motivation for the damage or destruction cannot reasonably be determined and the damage or destruction affects the reliability of the BES. Attachment 1 is also unclear to the extent that the incident category involving reports for the detection of reportable Cyber Security Incidents includes a reference to CIP-008 as the reporting threshold. While entities in various functional categories (i.e., RCs, BAs, TOPs/TOs, GOPs/GOs, and DPs) are listed as being responsible for the reporting of such events, some entities in these functional categories may not currently be subject to CIP-008. If it is the Drafting Team’s intent to limit event reports for Cyber Security Incidents to include only registered entities subject to CIP-008, that clarification should be incorporated into the listing of entities with reporting responsibility for this incident category in Attachment 1.
Group
Santee Cooper
Terry L. Blackwell
Yes
Yes
Yes
The on-going development of the definition of the BES could have significant impacts on reporting requirements associated with this standard. The event titled “Risk to the BES” appears to be a catch-all event and more guidance needs to be provided on this category. The event titled “Damage or Destruction of a Critical Asset or Critical Cyber Asset per CIP-002” is ambiguous and further guidance is recommended. Ambiguity in a standard leaves it open to interpretation for all involved.
Group

Sacramento Municipal Utility District (SMUD)
Joe Tarantino
Yes
Yes
Yes
SMUD and BANC agree with the revised language in EOP-004-1 requirements, but we have identified the following issues in A-1: We commend the SDT for properly addressing the sabotage issue. However, additional confusion is caused by introducing term "damage". As "damage" is not a defined term it would be beneficial for the drafting team to provide clarification for what is meant by "damage". The threshold for reporting "Each public Appeal for load reduction" should clearly state the triggering is for the BES Emergency as routine "public appeal" for conservation could be considered a threshold for the report triggering. Regarding the SOL Violations in Attachment 1 the SOL Violations should only be those that affect the WECC paths. The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing.
Individual
Bob Thomas
Illinois Municipal Electric Agency
No
IMEA agrees with the removal of the training requirement, but also believes verification is not a necessary requirement for this standard; therefore, R4 is not necessary and should be removed.
No
R2 is not necessary, and should be removed. Subrequirement R1.4 is also not necessary and should be removed.
Yes
With the understanding this is within 24 hrs., and good professional judgment determines the amount of time to report the event to appropriate parties.
IMEA appreciates this opportunity to comment. IMEA appreciates the SDT's efforts to simplify reporting requirements by combining CIP-001 with EOP-004. [IMEA encourages NERC to continue working towards a one-stop-shop to simplify reporting on ES-ISAC.] IMEA supports, and encourages SDT consideration of, comments submitted by APPA and Florida Municipal Power Agency.
Individual
Kirit Shah
Ameren
No
The current language in the parenthesis of R4 suggests that the training requirement was actually not removed, in that "a drill or exercise" constitutes training. As documented in the last sentence of the Summary of Key Concepts section, "The proposed standard deals exclusively with after-the-fact reporting." We feel that training, even if it is called drills or exercises is not necessary for an after-the-fact report.
No
(1) The new wording while well intentioned, effectively does not add clarity and leads to confusion. From our perspective, R1, which requires and Operating Plan, which is defined by the NERC glossary as: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan." (2) Is not a proper location for an after-the-fact reporting standard? In fact it could be argued that after-the-fact reports in and of themselves do not affect the reliability of the bulk

electric system. (3) But considering the proposed standard as written with the Operating Plan in requirement R1, and implementation of the Operating Plan in requirement R2 (except the actual reporting which is in R3) and then R3 which requires implementing the reporting section R1.3, it is not clear how these requirements can be kept separate in either implementation nor by the CEA. (4) The second sentence in the second paragraph of "Rationale for R1" states: "The main issue is to make sure an entity can a) identify when an event has occurred and b) be able to gather enough information to complete the report." This is crucial for a Standard like this that is intended to mandate actions for events that are frequently totally unexpected and beyond normal planning criteria. This language needs to be added to Attachment 1 by the DSR SDT as explained in the rest of our comments

No

(1)By our count there are still six of the nineteen events listed with a one hour reporting requirement and the rest are all within 24 hour after the occurrence (or recognition of the event). This in our opinion, is reporting in real-time, which is against one of the key concepts listed in the background section: "The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting." (2)We believe the earliest preliminary report required in this standard should at the close of the next business day. Operating Entities, such as the RC, BA, TOP, GOP, DP, and LSE should not be burdened with unnecessary after-the-fact reporting while they are addressing real-time operating conditions. Entities should have the ability to allow their support staff to perform this function during the next business day as needed. We acknowledge it would not be an undue burden to cc: NERC on other required governmental reports with shorter reporting timeframes, but NERC should not expand on this practice. (3)We agree with the extension in reporting times for events that now have 24 hours of reporting time. As a GO there are still too many potential events that still require a 1 hour reporting time that is impractical, unrealistic and could lead to inappropriate escalation of normal failures. For example, the sudden loss of several control room display screens for a BES generator at 2 AM in the morning, with only 1 hour to report something, might be mistakenly interpreted as a cyber-attack. The reality is most likely something far more mundane such as the unexpected failure of an instrument transformer, critical circuit board, etc.

Yes. We have the other comments as follow: (1) The "EOP-004 Attachment 1: Events Table" is quite lengthy and written in a manner that can be quite subjective in interpretation when determining if an event is reportable. We believe this table should be clear and unambiguous for consistent and repeatable application by both reliability entities and a CEA. The table should be divided into sections such as: 9a) Events that affect the BES that are either clearly sabotage or suspected sabotage after review by an entity's security department and local/state/federal law enforcement.(b) Events that pose a risk to the BES and that clearly reach a defined threshold, such as load loss, generation loss, public appeal, EEAs, etc. that entities are required to report by the end of the next business day.(c) Other events that may prove valuable for lessons learned, but are less definitive than required reporting events. These events should be reported voluntarily and not be subject to a CEA for non-reporting.(d)Events identified through other means outside of entity reporting, but due to their nature, could benefit the industry by an event report with lessons learned. Requests to report and perform analysis on these type of events should be vetted through a ERO/Functional Entity process to ensure resources provided to this effort have an effective reliability benefit. (2)Any event reporting shall not in any manner replace or inhibit an Entity's responsibility to coordinate with other Reliability Entities (such as the RC, TOP, BA, GOP as appropriate) as required by other Standards, and good utility practice to operate the electric system in a safe and reliable manner. (3) The 1 hour reporting maximum time limit for all GO events in Attachment 1 should be lengthened to something reasonable – at least 24 hours. Operators in our energy centers are well-trained and if they have good reason to suspect an event that might have serious impact on the BES will contact the TOP quickly. However, constantly reporting events that turn out to have no serious BES impact and were only reported for fear of a violation or self-report will quickly result in a cry wolf syndrome and a great waste of resources and risk to the GO and the BES. The risk to the GO will be potential fines, and the risk to the BES will be ignoring events that truly have an impact of the BES.(4)The 2nd and 3rd Events on Attachment 1 should be reworded so they do not use terms that may have been deleted from the NERC Glossary by the time FERC approves this Standard. (5) The terms "destruction" and "damage" are key to identifying reportable events. Neither has been defined in the Standard. The term

destruction is usually defined as 100% unusable. However, the term damage can be anywhere from 1% to 99% unusable and take anywhere from 5 minutes to 5 months to repair. How will we know what the SDT intended, or an auditor will expect, without additional information? (6) We also do not understand why "destruction of BES equipment" (first item Attachment 1, first page) must be reported < 1 hour, but "system separation (islanding) > 100 MW" (Attachment 1, page 3) does not need to be reported for 24 hours. (7) The first 2 Events in Attachment 1 list criteria Threshold for Reporting as "...operational error, equipment failure, external cause, or intentional or unintentional human action." The term "intentional or unintentional human action" appears to cover "operational error" so these terms appear redundant and create risk of misreporting. Can this be clarified? (8) The footnote of the first page of Attachment 1 includes the explanation "...ii) Significantly affects the reliability margin of the system..." However, the GO is prevented from seeing the system and has no idea what BES equipment can affect the reliability margin of the system. Can this be clarified by the SDT? (9) The use of the term "BES equipment" is problematic for a GO. NERC Team 2010-17 (BES Definition) has told the industry its next work phase will include identifying the interface between the generator and the transmission system. The 2010-17 current effort at defining the BES still fails to clearly define whether or not generator tie-lines are part of the BES. In addition, NERC Team 2010-07 may also be assigned the task of defining the generator/transmission interface and possibly whether or not these are BES facilities. Can the SDT clarify the use of this term? For example, does it include the entire generator lead-line from the GSU high-side to the point of interconnection? Does it include any station service transformer supplied from the interconnected BES?

Individual

Linda Jacobson-Quinn

FEUS

Yes

Yes

No

The OE-417 requires several of the events listed in Attachment 1 be reported within 1 hour. FEUS recommends the drafting team review the events and the OE-417 form and align the reporting window requirements. For example, public appeals, load shedding, and system separation have a 1 hour requirement in OE-417.

R4 requires verification through a drill or exercise the communication process created as part of R1.3. Clarification of what a drill or exercise should be considered. In order to show compliance to R4 would the entity have to send a pseudo event report to Internal Personnel, the Regional Entity, NERC ES-ISAC, Law Enforcement, and Governmental or provincial agencies listed in R1.3 to verify the communications plan? It would not be a burden on the entity so much, however, I'm not sure the external parties want to be the recipient of approximately 2000 psuedo event reports annually. Attachment 1: BES equipment is too vague – consider changing to BES facility and including that reduces the reliability of the BES in the footnote. Is the footnote an and or an or? Attachment 1: Version 5 of CIP Requirements remove the terms Critical Asset and Critical Cyber Asset. The drafting team should consider revising the table to include BES Cyber Systems. Clarify if Damage or Destruction is physical damage (aka – cyber incidents would be part of CIP-008.) Attachment 1: Unplanned Control Center evacuation – remove "potential" from the reporting responsibility Attachment 2 – 3: change to, "Did the event originate in your system?" The requirement only requires reporting for Events – not potential events. Attachment 2 4: "Damage or Destruction to BES equipment" should be "Destruction of BES Equipment" like it is in Attachment 1 and "forced intrusion risk to BES equipment" remove "risk"

Individual

Tom Foreman

Lower Colorado River Authority

Yes

Yes

Yes

The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. EOP-004 has an "optional" Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.

Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes and CIP Standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definition of a BES element could change significantly and the concepts of "Critical Assets" and "Critical Cyber Assets" no longer exist in Version 5 of the CIP Standards. Additionally, it is debatable whether the destruction of, for example, one relay would be a reportable incident given the proposed language. Related to "Reportable Events" of Attachment 1:

1. The "Purpose" section of the Standard indicates it is designed to require the reporting of events "with the potential to impact reliability" of the BES. Footnote 1 and the "Threshold for Reporting" associated with the Event described as "Destruction of BES equipment" expand the reporting scope beyond that intent. For example, a fan on a generation unit can be destroyed because a plant employee drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be "unintentional human action" that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear.
2. Item iii) in Footnote 1 seems redundant with the Threshold for Reporting.
3. The word "Significantly" in item ii) of footnote 1 introduces an element of subjectivity. What is "significant" to one person may not be significant to someone else.
4. The word "unintentional" in Item iii) of footnote 1 may introduce nuisance reporting. The SDT should consider: (1) changing the Event description to "Damage or destruction of BES equipment" (2) removing the footnote and (3) replacing the existing "Threshold for Reporting" with the following language: "Initial indication the event: (i) was due to intentional human action, (ii) affects an IROL or (iii) in the opinion of the Responsible Entity, jeopardizes the reliability margin of the system (e.g., results in the need for emergency actions)"
5. One reportable event is, "Risk to the BES" and the threshold for reporting is, "From a non-environmental physical threat." This appears to be intended as a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list.
6. One reportable event is, "Damage or destruction of Critical Asset per CIP-002." The SDT should define the term "Damage" in order for an entity to determine a threshold for what qualifies as "Damage" to a CA. Normal "damage" can occur on a CA that should not be reportable (e.g. the screwdriver example, above).
7. For the event called "BES Emergency requiring public appeal for load reduction," the SDT should make it clear who should report such an event. For example, in the ERCOT Region, there is a requirement that ERCOT issue public appeals for load reduction (See ERCOT Protocols Section 6.5.9.4). As the draft of EOP-004-2 is currently written, every Registered Entity in the ERCOT Region would have to file a report when ERCOT issues such an appeal. Such a requirement is overly burdensome and does not enhance the reliability of the BES. The Standard should require that the Reliability Coordinator file a report when it issues a public appeal to reduce load.

Reporting Thresholds

1. See Paragraph 1 in the "Related to "Reportable Events" of Attachment 1" section, above.
2. We believe damage or destruction of Critical Assets or CCAs resulting from operational error, equipment failure or unintentional human action should not be reportable under this Standard. We recommend changing the thresholds for "Damage or destruction to Critical Assets ..." and "Damage or destruction of a [CCA]" to "Initial Indication the event was due to external cause or intentional human action."
3. We support the SDT's attempted to limit nuisance reporting related to copper thefts. However, a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could clog the reporting process with nuisance reporting and reviewing. An example is the "BES Emergency requiring manual firm load shedding" of  $\geq 100$  MW or "Loss of Firm load for  $\geq 15$  Minutes" that is  $\geq 200$  MW (300 MW if the manual demand is greater than 3000 MW). In many cases, those low thresholds would require reporting minor wind events or other seasonal system issues on a local network used to provide distribution service.

Firm Demand

1. The use of the term "Firm load" in the context of the



draft Standard seems inappropriate. "Firm load" is not defined in the NERC Glossary (although "Firm Demand" is defined). If the SDT intended to use "Firm Demand," they should revise the draft Standard. If the SDT wishes to use the term "Firm load" they should define it. [For example, we understand that some load agrees to be dropped in an emergency. In fact, in the ERCOT Region, we have a paid service referred to as "Emergency Interruptible Load Service" (EILS). If the SDT intends that "Firm load" means load other than load which has agreed to be dropped, it should make that fact clear.] Comments to Attachment 2 1. The checkbox for "fuel supply emergency" should be deleted because it is not listed as an Event on Attachment 1. 2. There should be separation between "forced intrusion" and "Risk to BES equipment." They are separate Events on Attachment 1. Comments to Guideline and Technical Basis The last paragraph appears to state NERC will accept an OE-417 form as long as it contains all of the information required by the NERC form and goes on to state the DOE form "may be included or attached to the NERC report." If the intent is for NERC to accept the OE-417 in lieu of the NERC report, this paragraph should be clarified.

Individual

Richard Salgo

NV Energy

Yes

Thankyou for responding to the stakeholder comments on this issue.

No

On my read of the Standard, R2 and R3 appear to be duplicative, and I can't really distinguish the difference between the two. The action required appears to be the same for both requirements. Even the Measures for these two sound similar. It is not clear to me what it means to "implement" other than to have evidence of the existence and understanding of roles and responsibilities under the "Operating Plan." I suggest elimination of R2 and inclusion of a line item in Measure 1 calling for evidence of the existence of an "Operating Plan" including all the required elements in R1.

Yes

Attachment 1 includes an item "Detection of a reportable cyber security incident." The reporting requirement is a report via Attachment 2 or the OE417 report form submittal. However, under CIP-008, to which this requirement is linked, the reporting is accomplished via NERC's secure CIPIS reporting tool. This appears to be a conflict in that the entity is directed to file reporting under CIP-008 that differs from this subject standard. Attachment 1 also includes a provision for reporting the "loss of firm load greater than or equal to 15 minutes in an amount of 200MW (or 300MW for peaks greater than 3000MW). This appears to be a rather low threshold, particularly in comparison with the companion loss of generation reporting threshold elsewhere in the attachment. The volume of reports triggered by this low threshold will likely lead to an inordinate number of filed reports, sapping NERC staff time and deflecting resources from more severe events that require attention. I suggest either an increase in the threshold, or the addition of the qualifier "caused by interruption/loss of BES facilities" in this reporting item. This qualifier would therefore exclude distribution-only outages that are not indicative of a BES reliability issue.

Group

SPP Standards Review Group

Robert Rhodes

Yes

Yes

No

The purpose of the reporting requirement should be clear either in the text of the requirements or through an explanation that is embodied in the language of the approved set of standards. This would be consistent with a "Results-based" architecture. What is lacking in the proposed language of this standard is recognition that registered entities differ in size and relevance of their impact on the Bulk Electric System. Also, events that are reportable differ in their impact on the registered entity. A "one-size fits all" approach to this standard may cause smaller entities with low impact on the grid to

take extraordinary measures to meet the reporting/timing requirements and yet be too "loose" for larger more sophisticated and impacting entities to meet the same requirements. Therefore, we believe language of the standard must clearly state the intent that entities must provide reports in a manner consistent with their capabilities from a size/reliability impact perspective and from a communications availability perspective. Timing requirements should allow for differences and consider these variables. Also, we would suggest including language to specifically exclude situations where communications facilities may not be available for reporting. For example, in situations where communications facilities have been lost, initial reports would be due within 6 hours of the restoration of those communication facilities. We would also suggest that Attachment 1 be broken into two distinct parts such that those events which must be reported within 1 hour stand out from those events that have to be reported within 24 hours.

The inclusion of optional entities to which to report events in R1.3 introduces ambiguity into the standard that we feel needs to be eliminated. We propose the following replacement language for R1.3: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the Responsible Entity's Regional Entity. We would also propose to incorporate the law enforcement and governmental or provincial agencies mentioned in R1.3 in Attachment 1 by adding them to the existing language for each of the event cells. For example, the first cell in that column would read: The parties identified pursuant to R1.3 and applicable law enforcement and governmental or provincial agencies within 1 hour of recognition of event. Similarly, the phrase '...and applicable law enforcement and governmental or provincial agencies...' should be inserted in all the remaining cells in the 4th column.

Individual

Nathan Mitchell

American Public Power Association

Yes

APPA agrees that removal of the training requirement was an appropriate revision to limit the burden on small registered entities. However, APPA requests clarification from the SDT on the current draft of R4. If no event occurs during the calendar year, a drill or exercise of the Operating Plan communication process is required. APPA believes that if this drill or exercise is required, then it should be a table top verification of the internal communication process such as verification of phone numbers and stepping through a Registered Entity specific scenario. This should not be a full drill with requirements to contact outside entities such as law enforcement, NERC, the RC or other entities playing out a drill scenario. This full drill would be a major burden for small entities.

Yes

No

APPA echoes the comments made by Central Lincoln: We do not believe the SDT has adequately addressed the FERC Order to "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely "recognition" starts the clock and reporting will become a higher priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition. APPA recommends the SDT evaluate a less burdensome requirement for smaller entities with reporting requirements in Attachment 1. This exception needs to address the fact that not all entities have 24 hour 7 day a week operating personnel. However, APPA cautions the SDT that changes to this standard may expose entities to reporting violations on DOE-OE-417 which imposes civil and criminal penalties on reporting events to the Department of Energy. APPA recommends that the SDT reach out to DOE for clarification of reporting requirements for DOE-OE-417 for small entities, asking DOE to change their reporting requirement to match EOP-004-2. If DOE cannot change their reporting requirement the SDT should provide an explanation in the guidance section of Reliability Standard EOP-004-2 that addresses these competing FERC/DOE directives.

Requirement R1: 1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate: • Internal company personnel • The Responsible Entity's Regional Entity • Law enforcement • Governmental or provincial agencies APPA believes that including the list of other

entities needing to be included in a process for communicating events under 1.3 may open this requirement up for interpretation. APPA requests that the SDT remove from the requirement the listing of: "Internal company personnel, The Responsible Entity's Regional Entity, Law enforcement & Governmental or provincial agencies" and include these references in a guidance document. The registered entities need to communicate with the ERO and the RC if applicable for compliance with this standard and to maintain the reliability of the BES. Communication with other entities such as internal company personnel, law enforcement and the Regional Entity are expected, but do not impact the reliability of the BES. This will simplify the reporting structure and will not be burdensome to registered entities when documenting compliance. If this is not an acceptable solution, APPA suggests revising 1.3 to remove the wording "the following as appropriate" and add "other entities as determined by the Responsible Entity. Examples of other entities may include, but are not limited to:" Then it is clear that the list is examples and should not be enforced by the auditor. 1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3. APPA understands that the SDT is following the FERC order requiring a 90 day limit on updates to any changes to the plan. However, APPA believes that "updating the Operating Plan within 90 calendar days of any change..." is a very burdensome compliance documentation requirement. APPA reminds the SDT that including DPs in this combined standard has increased the number of small Responsible Entities that will be required to document compliance. APPA requests that the SDT combine requirement 1.4 and 1.5 so the Operating Plan will be reviewed and updated with any changes on a yearly basis. If this is not an acceptable solution, APPA suggests that the "Lower VSL" exclude a violation to 1.4. The thought being, a violation of 1.4 by itself is a documentation error and should not be levied a penalty. Attachment 1: Events Table APPA believes that the intent of the SDT was to mirror the DOE OE-417 criteria in reporting requirements. With the inclusion of DP in the Applicability, however, APPA believes the SDT created an unintended excessive reporting requirement for DPs during insignificant events. APPA recommends that a qualifier be added to the events table. In DOE OE-417 local electrical systems with less than 300MW are excluded from reporting certain events since they are not significant to the BES. APPA believes that the benefit of reporting certain events on systems below this value would not outweigh the compliance burden placed on these small systems. Therefore, APPA requests that the standard drafting team add the following qualifier to the Events Table of Attachment 1: "For systems with greater than 300MW peak load." This statement should be placed in the Threshold for Reporting column for the following Events: BES Emergency requiring appeal for load reduction, BES Emergency requiring system-wide voltage reduction, BES Emergency requiring manual firm load shedding, BES Emergency resulting in automatic firm load shedding. This will match the DOE OE-417 reporting criteria and relieve the burden on small entities. Definition of "Risk to BES equipment": The SDT attempted to give examples of the Event category "Risk to BES equipment" in a footnote. This footnote gives the Responsible Entity and the Auditor a lot of room for interpretation. APPA suggests that the SDT either define this term or give a triggering mechanism that the industry would understand. One suggestion would be "Risk to BES equipment: An event that forces a Facility Owner to initiate an unplanned, non-standard or conservative operating procedure." Then list; "Examples include train derailment adjacent to BES Facilities that either could have damaged the equipment directly or has the potential to damage the equipment..." This will allow the entity to have an operating procedure linked to the event. If this suggestion is taken by the SDT then the Reporting column of Attachment 1 needs to be changed to: "The parties identified pursuant to R1.3 within 1 hour of initiating conservative operating procedures."

Individual

Angela Summer

Southwestern Power Administration

Yes

No

One hour is not enough time to make these assessments for all of the six items in attachment 1. All timing requirements should be made the same in order to simplify the reporting process.

Individual

Michelle R D'Antuono
Ingleside Cogeneration LP
Yes
: Yes. Ingleside Cogeneration LP agrees that training on an incident reporting operations plan should be at the option of the entity. However, we recommend that a statement be included in the "Guideline and Technical Basis" section that encourages drills and exercises be coincident with those conducted for Emergency Operations. Since front-line operators must send out the initial alert that a reportable condition exists, such exercises may help determine how to manage their reporting obligations during the early stages of the troubleshooting process. This is especially true where a notification must be made within an hour of discovery – a very short time period.
No
Attachment 1 and requirement R3 are written in a manner which would seem to indicate that internal personnel and law enforcement personnel would have to be copied on the submitted form – either Attachment 2 or OE-417. We believe the intent is to submit such forms to the appropriate recipients only (e.g.; the ERO and the DOE). The requirement should be re-written to clarify that this is the case.
Yes
Yes. Any reporting that is mandated during the first hour of an event must be subject to close scrutiny. Many of the same resources that are needed to troubleshoot and stabilize the local system will be engaged in the reporting – which will impair reliability if not carefully applied. We believe that the ERO should reassess the need for any immediate reporting requirements on a regular basis to confirm that it provides some value to the restoration process.
We are encouraged that the 2009-01 project team has eliminated duplicate reporting requirements from multiple organizations and governmental agencies. Ingleside Cogeneration LP believes that there are further improvements that can be made in this area – as the remaining overlap seem to be a result of legalities and preferences, not technical issues. We would like to see an ongoing commitment by NERC for a single process that will consolidate and automate data entry, submission, and distribution.
Individual
Tim Soles
Occidental Power Services, Inc. (OPSI)
Yes
No
Attachment 1 and R3 require event reports to be sent to the ERO and the entity's RC and to others "as appropriate." Although this gives the entity some discretion, it might also create some "Monday morning quarterbacking" situations. This is especially true for the one hour reporting situations as personnel that would be responding to these events are the same ones needed to report the event. OPSI suggests that the SDT reconsider and clarify reporting obligations with the objective of sending initial reports to the minimum number of entities on a need-to-know basis.
Yes
Load Serving Entities that do not own or operate BES assets should not be included in the Applicability. In current posting, the SDT states that it includes LSEs based on CIP-002; however, if the LSE does not have any BES assets, CIP-002 should also not be applicable, because the LSE could not have any Critical Assets or Critical Cyber Assets. It is understood that the SDT is trying to comply with FERC Order 693, Section 460 and 461; however, Section 461 also states "Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns." A qualifier in the Applicability of EOP-004-2 that would include only LSEs that own or operate BES assets would seem appropriate. The proposed CIP-002 Version V has such a qualifier in that it applies to a "Load-Serving Entity that owns Facilities that are part of any of the following systems or programs designed, installed, and operated for the protection or restoration of the BES: • A UFLS program required by a NERC or Regional Reliability Standard • A UVLS program required by a NERC or Regional Reliability

Standard" The SDT should consider the same wording in the Applicability section of EOP-004-2 on order to be consistent with what will become the standing version of CIP-002 (Version 5).
Group
Dominion
Connie Lowe
Yes
Yes
Yes
Dominion appreciates the changes that have been made to increase the 1 hr reporting time to 24 hours.
There is still inconsistency in Attachment 1 vs. the DOE OE-417 form; in future changes, Dominion suggests align/rename events similar to that of the 'criteria for filing' events listed in the DOE OE-417, by working in coordination with the DOE. Minor comment; in the Background section, the drafting team refers to bulk power system (redline page 5; 1st paragraph and page 7; 2nd paragraph) rather than bulk electric system. The note in Attachment 1 states in part that "the affected Responsible Entity shall notify parties per R1 and ..." Dominion believes the correct reference to be R3. In addition, capitalized terms "Event" and "Event Report" are used in this note. Dominion believes the terms should be non-capitalized as they are not NERC defined terms. Attachment 1 – "Detection of a reportable Cyber Security Incident – That meets the criteria in CIP-008". This essentially equates the criteria to be defined by the entity in its procedures as required by CIP-008 R1.1., additional clarification should be added in Attachment 1 to make this clear. The last sentence in Attachment 2 instructions should clarify that the email, facsimile and voice communication methods are for ERO notification only. Dominion continues to believe that the drill or exercise specified in R4 is unnecessary. Dominion suggests deleting this activity in the requirement.
Individual
Michael Lombardi
Northeast Utilities
Yes
Yes
Yes
- Incorporate NERC Event Analysis Reporting into this standard. Make the requirements more specific to functional registrations as opposed to having requirements applicable to "Responsible Entities". - The description of a Transmission Loss Event in Attachment 1 should be clarified to indicate that this only pertains to the loss of three or more BES elements due to a discrete event at a single point in time as opposed to a storm/weather event which may last 24 hours or more and cause the loss of three or more transmission facilities over the course of the weather event.
Group
Southern Comnpany
Antonio Grayson
No
Southern agrees with removing the training requirement of R4 from the previous version of the standard. However, Southern suggests that drills and exercises are also training and R4 in this revised standard should be removed in its entirety
No
These requirements as drafted in this revised standard potentially create a situation where an entity could be deemed non-compliant for both R2 and R3. For example, if a Responsible Entity included a reporting obligation in its Operating Plan. and failed to report an event. the Responsible Entity could

be deemed non-compliant for R2 for not "implementing" its plan and for R3 for not reporting the event to the appropriate entities. A potential solution to address this would be to add Requirement 1, Part 1.3 to Requirement 2 and remove Requirement 3 in its entirety. We also request clarification on Measure M3. Which records should have "dated and time-stamped transmittal records to show that the event was reported"? Some of the communication is handled via face-to-face conversation or through telephone conversation.

No

Southern request clarification on one of the entries in Attachment 1. The concern is with the last row on page 21 of Draft 3. What is the basis for "Voltage deviations"? The Threshold is  $\pm 10\%$  sustained for  $\geq 15$  minutes. Is the voltage deviation based on the Voltage Schedule for that particular timeframe, or is it something else (pre-contingency voltage level, nominal voltage, etc.)? In addition, the second row of Attachment 1 lists "Damage or destruction of a Critical Cyber Asset per CIP-002" as a reportable event. The threshold includes "...intentional or unintentional human action" and gives us 1 hour to report. The term "damage" may be overly broad and, without definition, is not limited in any way. If a person mistypes a command and accidentally deletes a file, or renames something, or in any way changes anything on the CCA in error, then this could be considered "damage" and becomes a reportable event. The SDT should consider more thoroughly defining what is meant by "damage". Should it incorporate the idea that the essential functions that the CCA is performing must be adversely impacted? Lastly, no event should have a reporting time shorter than at the close of the next business day. Any reporting of an event that requires a shorter reporting time should only be to entities that can help mitigate an event such as an RC or other Reliability Entity.

Southern has the following comments: (1) In Requirement R1.4, we request the SDT to clarify what is meant by the term "assets"? (2) If requirement 4 is not deleted, should we have to test every possible event described in our Operating Plan or each event listed in Attachment 1 to verify communications? (3) In the last paragraph of the "Summary of Key Concepts" section on page 6 of Draft 3, there is a statement that "Real-time reporting is achieved through the RCIS..." The only reporting required on RCIS by the Standards is for EEAs and TLRs. Please review and modify this language as needed. (4) Evidence Retention (page 12 of Draft 3): The 3 calendar year reference has no bearing on a Standard that may be audited on a cycle greater than 3 years. (5) In the NOTE for Attachment 1 (page 20 of Draft 3), what is meant by "periodic verbal updates" and to whom should the updates be made? (6) There are Prerequisite Approvals listed in the Implementation Plan. Is it appropriate to ask industry to vote on this Standard Revision that has a prerequisite approval of changes in the Rules of Procedure that have not been approved? (7) We believe the reporting of the events in Attachment 1 has no reliability benefit to the Bulk Electric System. We suggest that Attachment 1 should be removed.

Individual

Andrew Gallo

City of Austin dba Austin Energy

Yes

Yes

Yes

The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. EOP-004 has an "optional" Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.

Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes and CIP Standards Version 5 could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definition of a BES element could change significantly and the concepts of "Critical Assets" and "Critical Cyber Assets" no longer exist in Version 5 of the CIP Standards. Additionally, it is debatable whether the destruction of, for example, one relay would be a

reportable incident given the proposed language. Related to "Reportable Events" of Attachment 1: 1. The "Purpose" section of the Standard indicates it is designed to require the reporting of events "with the potential to impact reliability" of the BES. Footnote 1 and the "Threshold for Reporting" associated with the Event described as "Destruction of BES equipment" expand the reporting scope beyond that intent. For example, a fan on a generation unit can be destroyed because a plant employee drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be "unintentional human action" that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear. 2. Item iii) in Footnote 1 seems redundant with the Threshold for Reporting. 3. The word "Significantly" in item ii) of footnote 1 introduces an element of subjectivity. What is "significant" to one person may not be significant to someone else. 4. The word "unintentional" in Item iii) of footnote 1 may introduce nuisance reporting. The SDT should consider: (1) changing the Event description to "Damage or destruction of BES equipment" (2) removing the footnote and (3) replacing the existing "Threshold for Reporting" with the following language: "Initial indication the event: (i) was due to intentional human action, (ii) affects an IROL or (iii) in the opinion of the Responsible Entity, jeopardizes the reliability margin of the system (e.g., results in the need for emergency actions)" 5. One reportable event is "Risk to the BES" and the threshold for reporting is, "From a non-environmental physical threat." This appears to be intended as a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list. 6. One reportable event is "Damage or destruction of Critical Asset per CIP-002." The SDT should define the term "Damage" in order for an entity to determine a threshold for what qualifies as "Damage" to a CA. Normal "damage" can occur on a CA that should not be reportable (e.g. the screwdriver example, above). 7. For the event called "BES Emergency requiring public appeal for load reduction," the SDT should make it clear who should report such an event. For example, in the ERCOT Region, there is a requirement that ERCOT issue public appeals for load reduction (See ERCOT Protocols Section 6.5.9.4). As the draft of EOP-004-2 is currently written, every Registered Entity in the ERCOT Region would have to file a report when ERCOT issues such an appeal. Such a requirement is overly burdensome and does not enhance the reliability of the BES. The Standard should require that the Reliability Coordinator file a report when it issues a public appeal to reduce load. Reporting Thresholds 1. See Paragraph 1 in the "Related to 'Reportable Events' of Attachment 1" section, above. 2. We believe damage or destruction of Critical Assets or CCAs resulting from operational error, equipment failure or unintentional human action should not be reportable under this Standard. We recommend changing the thresholds for "Damage or destruction of Critical Asset..." and "Damage or destruction of a [CCA]" to "Initial Indication the event was due to external cause or intentional human action." 3. We support the SDT's attempted to limit nuisance reporting related to copper thefts. However, a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could clog the reporting process with nuisance reporting and reviewing. An example is the "BES Emergency requiring manual firm load shedding" of  $\geq 100$  MW or "Loss of Firm load for  $\geq 15$  Minutes" that is  $\geq 200$  MW (300 MW if the manual demand is greater than 3000 MW). In many cases, those low thresholds would require reporting minor wind events or other seasonal system issues on a local network used to provide distribution service. Firm Load 1. The use of the term "Firm load" in the context of the draft Standard seems inappropriate. "Firm load" is not defined in the NERC Glossary (although "Firm Demand" is defined). If the SDT intended to use "Firm Demand," they should revise the draft Standard to use that language. If the SDT wishes to use the term "Firm load" they should define it. [For example, we understand that some load agrees to be dropped in an emergency. In fact, in the ERCOT Region, we have a paid service referred to as "Emergency Interruptible Load Service" (EILS). If the SDT intends that "Firm load" means load other than load which has agreed to be dropped, it should make that fact clear.] Comments to Attachment 2 1. The checkbox for "fuel supply emergency" should be deleted because it is not listed as an Event on Attachment 1. 2. There should be separation between "forced intrusion" and "Risk to BES equipment." They are separate Events on Attachment 1. Comments to Guideline and Technical Basis The last paragraph appears to state NERC will accept an OE-417 form as long as it contains all of the information required by the NERC form and goes on to state the DOE form "may be included or attached to the NERC report." If the intent is for NERC to accept the OE-417 in lieu of the NERC report, this paragraph should be clarified.

Group

FirstEnergy

Sam Ciccone
Yes
FirstEnergy supports this removal and thanks the drafting team.
Yes
Yes
Although we agree with the timeframes for reporting, we have other concerns as listed in our response to Question 4.
<p>1. Attachment 1 – Regarding the 1st event listed in the table, “Destruction of BES Equipment” and its accompanying Footnote 1, we believe that this event should be broken into two separate events that incorporate the specifics in the footnote as follows: a. “Destruction of BES equipment that associated with an IROL per FAC-014-2.” Regarding the 1st event we have proposed – We have proposed this be made specific to IROL as stated in Footnote 1 part i. Also, we believe that only the RC and TOP would have the ability to quickly determine and report within 1 hour if the destruction is associated with an IROL. The other entities listed would not necessarily know if the event affects and IROL. Therefore, we also propose that the Entities with Reporting Responsibilities (column 2) be revised to only include the RC and TOP. b. “Destruction of BES equipment that removes the equipment from service.” Regarding the 3rd event we have proposed – We have proposed this be made specific to destruction of BES equipment that removes the equipment from service as stated in Footnote 1 part iii. Also, the other part of footnote 1 part iii which states “Damaged or destroyed due to intentional or unintentional human action” is not required since it is covered in the threshold for reporting. Also the term “Damaged” in this part iii is not appropriate since these events are limited to equipment that has been destroyed. We also propose that the Entities with Reporting Responsibilities (column 2) for this event would remain the same as it states now since any of those entities may observe out of service BES equipment. Regarding part ii of footnote 1, we do not believe that this event needs to be separated. Regarding the phrase “significantly affects the reliability margin of the system be clarified so that it is not left up to the entity to interpret a “significant” affect. Lastly, since we have incorporated parts i and iii into the two separate events and removed part ii as proposed above, the only statement that needs to be left in the Footnote 1 is: “Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).”</p> <p>2. Attachment 1 – We ask that the team add an “Event #” column to the table so that each of the events listed can be referred to by #, such as Event 1, Event 2, etc.</p> <p>3. Attachment 1 – Event titled “Damage or destruction of a Critical Cyber Asset per CIP-002”, the proposed threshold for reporting seems incomplete. We suggest the threshold for this event match the threshold for the Critical Asset event which states: “Initial indication the event was due to operational error, equipment failure, external cause, or intentional or unintentional human action.”</p> <p>4. Attachment 1 – Events titled “Damage or destruction of a Critical Assets per CIP-002” and “Damage or destruction of a Critical Cyber Asset per CIP-002” seem ambiguous due to the term “damage”. We suggest removal of “damage” or clarity as to what is considered a damaged asset.</p> <p>5. VSL Table – Instead of listing every entity, it may be more efficient to simply say “The Responsible Entity” in the VSL for each requirement.</p> <p>6. Guideline and Technical Basis section – This section does not provide guidance on each of the requirements of the standard. We suggest the team consider adding guidance for the requirements.</p>
Group
PPL Electric Utilities and PPL Supply Organizations`
Annette M. Bannon
Yes
Yes
Our comments center around the footnotes and events 'Destruction of BES equipment' and 'Loss of Off-site power to a nuclear generating plant'. We request the SDT consider adding a statement to the standard that acknowledges that not all registered entities have visibility to the information in the footnotes. E.G. Destruction of BES equipment. A GO/GOP does not necessarily know if loss of specific



BES equipment would affect any IROL and therefore would not be able to consider this criteria in its reporting decision. Loss of BES equipment would be reported to the BA/RC and the BA/RC would know of an IROL impact and the BA/RC is the appropriate entity to report. We request the SDT consider the information in the footnotes for inclusion in the table directly. Consider Event 'Destruction of BES equipment'. Is footnote 1 a scoping statement? Is it part of the threshold? Is it the impact? Is it defining Destruction? If the BES equipment was destroyed by weather and does not affect an IROL, then is no report is needed? Alternatively, do you still apply the threshold and say it was external cause and therefore report? We suggest including a flowchart on how to use Attachment 1 with an example. The flowchart would explain the order in which to consider the event and the threshold, and footnotes if they remain. Regarding Attachment 1 Footnote 1 'do not report copper theft...unless it degrades the ability of equipment to operate correctly.', is this defining destruction as not operating correctly ? or is the entirety of footnote 1 a definition of destruction? Regarding Attachment 1 Footnote 1, iii, we request this be changed for consistency with the Event and suggest removing damage from the footnote. i.e. The event is 'destruction' whereas the footnote says 'damaged or destroyed'. The standard does not provide guidance on damage vs destruction which could lead to differing reporting conclusions. Is the reporting line out of service, beyond repair, or is it timeframe based? Regarding Attachment 1 Footnote 2 ' to steal copper... unless it affects the reliability of the BES', is affecting the reliability of the BES a consideration in all the events? PPL believes this is the case and request this statement be made. This could be included in the flowchart as a decision point. Regarding Event 'Loss of Off-site power to a nuclear generating plant', the threshold for reporting does not designate if the off-site loss is planned and/or unplanned – or if the reporting threshold includes the loss of one source of off-site power or is the reporting limited to when all off-site sources are unavailable. PPL recommends the event be 'Total unplanned loss of offsite power to a nuclear generating plant (grid supply)' Thank you for considering our comments.

Group

CenterPoint Energy

John Brockhan

Yes

No

CenterPoint Energy believes the current R2 is unnecessary and duplicative. Upon reporting events as required by R3, entities will be implementing the relevant parts of their Operating Plan that address R1.1 and R1.2. This duplication is clear when reading M2 and M3. Acceptable evidence is an event report. R2 should be modified to remove this duplicative requirement.

No

CenterPoint Energy agrees with the revision that allows more time for reporting some events; however, some 1 hour requirements remain. The Company does not agree with this timeframe for any event.

CenterPoint Energy appreciates the SDT's consideration of comments and removal of the term, Impact Event. However, the Company still suggests removing the phrase "with the potential to impact" from the purpose as it is vast and vague. An alternative purpose would be "To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events that impact reliability and their causes if known". The focus should remain on those events that truly impact the reliability of the BES. CenterPoint Energy remains very concerned about the types of events that the SDT has retained in Attachment 1 as indicated in the following comments: Destruction of BES Equipment – The loss of BES equipment should not be reportable unless the reliability of the BES is impacted. Footnote 5, iii should be modified to tie the removal of a piece of equipment from service back to reliability of the BES. Risk to BES equipment: This Event is too vague to be meaningful and should be deleted. The Event should be modified to "Detection of an imminent physical threat to BES equipment". Any reporting time frame of 1 hour is unreasonable; Entities will still be responding to the Event and gathering information. A 24 hour reporting time frame would be more reasonable and would still provide timely information. System Separation: The 100 MW threshold is too low for a reliability impact. A more appropriate threshold is 500 MW. Loss of Monitoring or all voice communication capability: The two elements of this Event should be separated for clarity as follows: "Loss of monitoring of Real-Time conditions" and "Loss of all voice communication capability."

Individual
James Saucedo
Energy Northwest - Columbia
Yes
Yes
No
Energy Northwest - Columbia (ENWC) has concerns about the existing 1 hour reporting requirements and feels that additional guidance and verbiage is required for clarification. ENWC would like the word "recognition" in the statement that reads, "recognition of events," be replaced by "confirmation" as in "confirmed event." Also, we would like clarification as to when the 1 hour clock starts. Please consider changing recognition in "within 1 hour of recognition of event" and incorporating in "confirmation."
1. The Loss of Off-site power event criteria is much improved from the last draft of EOP 004-2; however, some clarification is needed to more accurately align with NERC Standard NUC-001 in both nomenclature and intent. Specifically, there are many different configurations supplying offsite power to a nuclear power plant and it is essential that all configurations be accounted for. As identified in the applicability section of NUC-001 the applicable transmission entities may include one or more of the following (TO, TOP, TP, TSP, BA, RC, PC, DP, LSE, and other non-nuclear GO/GOPs). Based on the response to previous comments submitted for Draft 2, Energy Northwest understands that the DSR SDT evaluated the use of the word "source" but dismissed the use in favor of "supply" with the justification "[that] 'supply' encompasses all sources". Energy Northwest suggests that the word "source" is used as the event criteria in EOP-004-2 as this nomenclature is commonly used in the licensing basis of a nuclear power plant. By revising the threshold criteria to "one or more" Energy Northwest believes the concern the DSR SDT noted is addressed and ensures all sources are addressed. In addition, by revising the threshold for reporting to a loss of "one or more" will ensure that all potential events (regardless of configuration of off-site power supplies) will be reported by any applicable transmission entity specifically identified in the nuclear plant site specific NPIRs. Energy Northwest proposes that the loss of an off-site power source be revised to an "unplanned" loss to account for planned maintenance that is coordinated in advance in accordance with the site specific NPIRs and associated Agreements. This will also eliminate unnecessary reporting for planned maintenance. Although the loss of one off-site power source may not result in a nuclear generating unit trip, Energy Northwest agrees that an unplanned loss of an off-site power source regardless of impact should be reported within the 24 hour time limit as proposed. Suggest that the Loss of Offsite power to a nuclear generating plant event be revised as follows: Event: Unplanned loss of any off-site power source to a Nuclear Power Plant Entity with Reporting Responsibility: The applicable Transmission Entity that owns and/or operates the off-site power source to a Nuclear Power Plant as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) and associated Agreements. Threshold for Reporting: Unplanned loss of one or more off-site power sources to a Nuclear Power Plant per the applicable NPIRs. 2. Please consider changing "Operating Plan" with "Procedure(s)". Procedures extend beyond operating groups and provide guidance to the entire company.
Group
Electric Compliance
Tom McElhinney
Yes
Yes
Yes
The concepts of "Critical Assets" and "Critical Cyber Assets" no longer exist in Version 5 of the CIP Standards and so this may cause confusion. Recommend modifying to be in accordance with Version 5. Additionally, it is debatable whether the destruction of, for example, one relay would be a reportable incident given the proposed language. We recommend modifying the language to insure

nuisance reporting is minimized. One reportable event is, "Risk to the BES" and the threshold for reporting is, "From a non-environmental physical threat." This appears to be a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list. Footnote 1 and the "Threshold for Reporting" associated with the Event described as "Destruction of BES equipment" expand the reporting scope. For example, a fan on a transformer can be destroyed because a technician drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be "unintentional human action" that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear. Proposed Footnote: BES equipment that become damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service that i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii). Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative). The word "Significantly" in item ii) of footnote 1 and "as appropriate" in section 1.3 introduces elements of subjectivity. What is "significant" or "appropriate" to one person may not be to someone else. In section 1.4, we believe that revising the plan within 90 days of "any" change should be changed to 180 days or else classes of events should be made so that only substantial changes are required to made within the 90 day timeframe.

Individual

Scott Berry

Indiana Municipal Power Agency

No

IMPA does not believe that R4 is necessary. In addition, if a drill or exercise is used to verify the communication process, some of the parties listed in R1.3 may not want to participate in the drill or exercise every 15 months, such as law enforcement and governmental agencies. IMPA would propose a contacting these agencies every 15 months to verify their contact information only and updating their information in the plan as needed, without performing a drill or exercise.

No

Both requirements seem to be implementing the Operating Plan which means R3 should be a bullet under R2 and not a separate requirement. IMPA supports making R2 and R3 one requirement and eliminating the current R3 requirement. In addition, R2 needs to be clarified when addressing an actual event. IMPA recommends saying "an actual event that meets the criteria of Attachment 1."

No

IMPA believes that some of the times may not be aggressive enough that are related to generation capacity shortages. In addition, IMPA believes clarity needs to be added when saying within 1 hour of recognition of event. For example, A fence cutting may not be discovered for days at a remote substation and then a determination has to be made if it was "forced intrusion" – Does that one hour apply once the determination is made that is was "forced intrusion" or from the time the discovery was made? Some of the 1 hour time limits can be expanded to allow for more time, such as forced intrusion, destruction of BES equipment, Risk to BES equipment, etc.

Many of the items listed in Attachment 1 are onerous and burdensome when it comes to making judgments or determinations. What one may consider "Risk to BES equipment" another person may not make the same determination. Clarity needs to be added to make the events easier to determine and that will result in less issues when it comes to compliance audits. IMPA does not understand the usage of the terms Critical Asset and Critical Cyber Asset as they will be retired with CIP version 5. IMPA believes the data retention requirements are way too complicated and need to be simplified. It seems like it would be less complicated if one data retention period applied to all data associated with this standard. On "public appeal", in the threshold, the descriptor "each" should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event?

Individual

Maggy Powell

Constellation Energy on behalf of Baltimore Gas & Electric, Constellation Power Generation, Constellation Energy Commodities Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.

Yes

Yes, we support removal of the training requirement.

Yes

While we support the delineation of the different activities associated with implementation and reporting, further clarification would be helpful. R1. 1.3: As currently written, it is somewhat confusing, in particular the use of the qualifier "as appropriate". In addition, the use of the word "communicating" to capture both reporting to reliability authorities and notifying others may leave the requirement open to question. Below is a proposed revision: 1.3 A process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and for communicating to others as defined in the Responsible Entity's Operating Plan, such as: • Internal company personnel • The Responsible Entity's Regional Entity • Law Enforcement • Government or provincial agencies R1, 1.4: the last phrase of the requirements seems to be leftover from an earlier version. The requirement should end after the word "Plan". R1, 1.5: "Process" should not be capitalized. While we understand the intent of the draft language and appreciate the effort to streamline the requirements, we propose an adjusted delineation below that we feel tracks more cleanly to the structure of a compliance program. Proposed revised language: R2. Each Responsible Entity shall implement its Operating Plan to meet Requirement R1, parts 1.1 and 1.2 for an actual event(s). M2. Responsible Entities shall provide evidence that it implemented its Operating Plan to meet Requirement R1, Parts 1.1 and 1.2 for an actual event. Evidence may include, but is not limited to, an submitted event report form (Attachment 2) or a submitted OE-417 report, operator logs, or voice recording. R3. Each Responsible Entity shall implement its Operating Plan to meet Requirement R1, parts 1.4 and 1.5. M3. Responsible Entities shall provide evidence that it implemented its Operating Plan to meet Requirement R1, Parts 1.4 and 1.5. Evidence may include, but is not limited to, dated documentation of review and update of the Operating Plan. R4. Each Responsible Entity shall verify (through implementation for an actual event, or through a drill, exercise or table top exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification. M4. The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan for events created pursuant to Requirement R1, Part 1.3. Either implementation of the communication process as documented in its Operating Plan for an actual event or documented evidence of a drill, exercise, or table top exercise may be used as evidence to meet this requirement. The time period between verification shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a verification.

Yes

We agree with the change to the reporting times in Attachment 1. While this is an improvement, other concerns with the language in the events table language remain. Please see additional details below: General items: • All submission instructions (column 4 in Events Table) should qualify the recognition of the event as "of recognition of event as a reportable event." • Is the ES-ISAC the appropriate contact for the ERO given that these two entities are separate even though they are currently managed by NERC? In addition, are the phone numbers in the Attachment 1 NOTE accurate? Is it possible they will change in a different cycle than the standard? Specific Event Language: • Destruction of BES Equipment, footnote: Footnote 1, item iii confuses the clarification added in items i. and ii. Footnote 1 should be modified to state BES equipment that (i) an entity knows will affect an IROL or has been notified the loss affects an IROL; (ii) significantly affects the reserve margin of a Balancing Authority or Reserve Sharing Group. Item iii should be dropped. • Damage or destruction of Critical Asset per CIP-002: Within the currently developing revisions to CIP-002 (version 5), Critical Asset will be retired as a glossary term. As well as addressing the durability of this event category, additional delineation is needed regarding which asset disruptions are to be reported. A CA as currently defined incorporates assets in a broad perspective, for instance a generating plant may be a Critical Asset. As currently written in Attachment 1, reporting may be required for unintended events, such as a boiler leak that takes a plant offline for a minor repair. Event #1 – Destruction of BES Equipment – captures incidents at the relevant equipment regardless of whether they are a Critical Asset or not. We recommend dropping this event. However, if reference

to CIP-002 assets remains, it will be important to capture reporting of the events relevant to reliability and not just more events.

- Damage or destruction of a Critical Cyber Asset per CIP-002: Because CCAs are defined at the component level, including this trigger is appropriate; however, as with CAs, the CCA term is scheduled to be retired under CIP-002 version 5.
- Forced Intrusion: The footnote confuses the goal of including this event category. In addition, "forced" doesn't need to define the incident. Constellation proposes the following to better define the event: Intrusion that affects or attempts to affect the reliable operation of the BES (1) (1) Examples of "affecting reliable operation of the BES are": (i) device operations, (ii) protective equipment degradation, (iii) communications systems degradation including telemetered values and device status.
- Risk to BES equipment: This category is too vague to be effective and the footnote further complicates the expectations around this event. The catch all concept of reporting potential risks to BES equipment is problematic. It's not clear what the reliability goal of this category is. Risk is not an event, it is an analysis. How are entities to comply with this "event", never mind within an hour? It appears that the information contemplated within this scenario would be better captured within the greater efforts underway by NERC to assess risks to the BES. This event should be removed from the Attachment 1 list in EOP-004.
- BES Emergency requiring system-wide voltage reduction: the Entity with Reporting Responsibility should be limited to RC and TOP.
- Voltage deviations on BES Facilities: The Threshold for Reporting language needs more detail to explain +/- 10% of what? Proposed revision:  $\pm 10\%$  outside the voltage schedule band sustained for  $\geq 15$  continuous minutes
- IROL Violation (all Interconnections) or SOL Violation (WECC only): Should "Interconnections" be capitalized?
- Transmission loss: The reporting threshold should provide more specifics around what constitutes Transmission Facilities. One minor item, under the Threshold for Reporting, "Three" does not need to be capitalized.

Background Section: The background section in this revision of EOP-004 reads more like guidance than a background of the development of the event reporting standard. Because of the background remains as part of the standard, the language raises questions as to role it plays relative to the standard language. For instance, the Law Enforcement Reporting section states: "Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES." It's not clear how "potential to impact to a wider area of the BES" is defined and where it fits into the standard. As well, and perhaps more problematic, is the Reporting Hierarchy for Reportable Events flow chart. While the flow chart concept is quite useful as a guidance tool, the flow chart currently in the Background raises questions. For instance, the Procedure to Report to Law Enforcement sequence does not map to language in the requirements. Further, Entities would not know about the interaction between law enforcement agencies. Please see additional recommended revisions to the requirement language and to the Events Table in the Q2 and Q3 responses. Attachment 2: Event Reporting Form: The review of the form is one of the many aspects to compare with the developments within the Events Analysis Process (EAP) developments. We support the effort to create one form for submissions. The recent draft EAP posted as part of Planning Committee and Operating Committee agendas includes a form requiring a few bits of additional relevant information when compared to the EOP-004 form. This may be a valuable approach to avoid follow up inquiries that may result if the form is too limited. We suggest that consideration be given to the proposed EAP form. One specific note on the Proposed EOP-004 Attachment 2: The "Potential event" box in item 3 should be eliminated to track with the removal of the "Risk to the BES" category.

Group
Salt River Project
Brenton Lopez
Yes
Yes
Yes

The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the NERC Event Analysis process, but there is some duplication of efforts. EOP-004 has an "optional" Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be

duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.

Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes and CIP Standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definition of a BES element could change significantly and the concepts of "Critical Assets" and "Critical Cyber Assets" no longer exist in Version 5 of the CIP Standards. Additionally, it is debatable whether the destruction of, for example, one relay would be a reportable incident given the proposed language. Related to "Reportable Events" of Attachment 1: 1. The "Purpose" section of the Standard indicates it is designed to require the reporting of events "with the potential to impact reliability" of the BES. Footnote 1 and the "Threshold for Reporting" associated with the Event described as "Destruction of BES equipment" expand the reporting scope beyond that intent. For example, a fan on a generation unit can be destroyed because a plant employee drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be "unintentional human action" that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear. 2. Item iii) in Footnote 1 seems redundant with the Threshold for Reporting. 3. The word "Significantly" in item ii) of footnote 1 introduces an element of subjectivity. What is "significant" to one person may not be significant to someone else. 4. The word "unintentional" in Item iii) of footnote 1 may introduce nuisance reporting. The SDT should consider: (1) changing the Event description to "Damage or destruction of BES equipment" (2) removing the footnote and (3) replacing the existing "Threshold for Reporting" with the following language: "Initial indication the event: (i) was due to intentional human action, (ii) affects an IROL or (iii) in the opinion of the Responsible Entity, jeopardizes the reliability margin of the system (e.g., results in the need for emergency actions)" 5. One reportable event is, "Risk to the BES" and the threshold for reporting is, "From a non-environmental physical threat." This appears to be intended as a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list. 6. One reportable event is, "Damage or destruction of Critical Asset per CIP-002." The SDT should define the term "Damage" in order for an entity to determine a threshold for what qualifies as "Damage" to a CA. Normal "damage" can occur on a CA that should not be reportable (e.g. the screwdriver example, above). Reporting Thresholds 1. We believe damage or destruction of Critical Assets or CCAs resulting from operational error, equipment failure or unintentional human action should not be reportable under this Standard. We recommend changing the thresholds for "Damage or destruction to Critical Assets ..." and "Damage or destruction of a [CCA]" to "Initial Indication the event was due to external cause or intentional human action." 2. We support the SDT's attempted to limit nuisance reporting related to copper thefts. However, a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could clog the reporting process with nuisance reporting and reviewing. An example is the "BES Emergency requiring manual firm load shedding" of  $\geq 100$  MW or "Loss of Firm load for  $\geq 15$  Minutes" that is  $\geq 200$  MW (300 MW if the manual demand is greater than 3000 MW). In many cases, those low thresholds would require reporting minor wind events or other seasonal system issues on a local network used to provide distribution service. Firm Demand 1. The use of the term "Firm load" in the context of the draft Standard seems inappropriate. "Firm load" is not defined in the NERC Glossary (although "Firm Demand" is defined). If the SDT intended to use "Firm Demand," they should revised the draft Standard. If the SDT wishes to use the term "Firm load" they should define it. [For example, we understand that some load agrees to be dropped in an emergency. In fact, in the ERCOT Region, we have a paid service referred to as "Emergency Interruptible Load Service" (EILS). If the SDT intends that "Firm load" means load other than load which has agreed to be dropped, it should make that fact clear.] Comments to Attachment 2 1. The checkbox for "fuel supply emergency" should be deleted because it is not listed as an Event on Attachment 1. 2. There should be separation between "forced intrusion" and "Risk to BES equipment." They are separate Events on Attachment 1. Comments to Guideline and Technical Basis The last paragraph appears to state NERC will accept an OE-417 form as long as it contains all of the information required by the NERC form and goes on to state the DOE form "may be included or attached to the NERC report." If the intent is for NERC to accept the OE-417 in lieu of the NERC report, this paragraph should be clarified.

Individual

Michael Brytowski
Great River Energy
No
We understand and agree there should be verification of the information required for such reporting (contact information, process flow charts, etc). But we still believe improvements can be made to the draft standard, in particular to requirement R4. The use of the words "or through a drill or exercise" still implies that training is required if no actual event has occurred. When you conduct a fire "drill" you are training your employees on evacuation routes and who they need to report to. Not only are you verifying your process but you are training your employees as well. It is imperative that the information in the Event Reporting process is correct but we don't agree that performing a drill on the process is necessary. We recommend modifying the requirement to focus on verifying the information needed for appropriate communications on an event. And we agree this should take place at least annually.
No
Requirement R2 requires Responsible Entities to implement the various subrequirements in R1. We believe it is unnecessary to state that an entity must implement their Operating Plan in a separate requirement. Having a separate requirement seems redundant. If the processes in the Operating Plan are not implemented, the entity is non-compliant with the standard. There doesn't need to be an extra requirement saying entities need to implement their Operating Plan.
Yes
For many of the events listed in Attachment 1, there would be duplicate reporting the way it is written right now. For example, in the case of a fire in a substation (Destruction of BES equipment), the RC, BA, TO, TOP and perhaps the GO and GOP could all experience the event and each would have to report on it. This seems quite excessive and redundant. We recommend eliminating this duplicate reporting.
Individual
Christine Hasha
Electric Reliability Council of Texas, Inc.
Yes
Yes
No
Destruction of BES equipment: 1. Request that the term "destruction" be clarified. Damage or destruction of Critical Asset per CIP-002: 1. Request that the terms "damage" and "destruction" be clarified. 2. Is the expectation that an entity report each individual device or system equipment failure or each mistake made by someone administering a system? 3. Request that "initial indication of the event" be changed to "confirmation of the event". Event monitoring and management systems may receive many events that are determined to be harmless and put the entity at no risk. This can only be determined after analysis of the associated events is performed. Damage or destruction of a Critical Cyber Asset per CIP-002: 1. Request that the terms "damage" and "destruction" be clarified. 2. Is the expectation that an entity report each individual device or system equipment failure or each mistake made by someone administering a system? 3. Request that "initial indication of the event" be changed to "confirmation of the event". Event monitoring and management systems may receive many events that are determined to be harmless and put the entity at no risk. This can only be determined after analysis of the associated events is performed. Risk to BES equipment: Request that the terms "risk" be clarified.
Individual
Darryl Curtis
Oncor Electric Delivery Company LLC
Yes

No
NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC considers ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.
Yes
NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC considers ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.
Group
Kansas City Power & Light
Michael Gammon
Yes
No
Requirement R1.1 is confusing regarding the "process for identifying events listed in Attachment 1". Considering Attachment 1, the Events Table, already identifies the events required for reporting, please clearly describe in the requirement what the "process" referred to in requirement R1.1 represents.
No
The reportable events listed in Attachment 1 can be categorized as events that have had a reliability impact and those events that could have a reliability impact. The listed events that could have a reliability impact should have a 24 hour reporting requirement and the events that have had a reliability impact are appropriate at a 1 hour reporting. The following events with a 1 hour report requirement are recommended to change to 24 hour: Forced Intrusion and Risk to BES Equipment. In addition, the Attachment 1 Events Table is incomplete as many of the listed events are incomplete regarding reporting time requirements and event descriptions. Also recommend removing (ii) from note 5 with event "Destruction of BES equipment" as this part of the note is already described in the event description and insinuates reporting of equipment losses that do not have a reliability impact. The events, "Damage or destruction of Critical Asset per CIP-002" and "Damage or destruction of a Critical Cyber Asset per CIP-002", does not have sufficient clarity regarding what that represents. A note similar in nature to Note 5 for BES equipment is recommended.
The implementation plan indicates that much of CIP-008 is retained. The reporting requirements in CIP-008 and the required reportable events outlined in Attachment 1 are an overlap with CIP-008-3 R1.1 which says "Procedures to characterize and classify events as reportable Cyber Security Incidents" and CIP-008-3 R1.3 which requires processes to address reporting to the ES-ISAC. There is also a NERC document titled, Security Guideline for the Electricity Sector: Threat and Incident Reporting, which is a guideline to "assist entities to identify and classify incidents for reporting to the ES-ISAC". The SDT should consider the content of the Security Guideline for the Electricity Sector: Threat and Incident Reporting when considering the reporting requirements proposed EOP-004. The efforts to incorporate CIP-008 into EOP-004 are insufficient and will result in serious confusion between proposed EOP-004 and CIP-008 and reporting expectations. Considering the complexity CIP incident reporting and the interests of ES-ISAC, it may be beneficial to leave CIP-008 out of the proposed EOP-004 and limit EOP-004 to the reporting interests of NERC. The flowchart states, "Notification Protocol to State Agency Law Enforcement". Please correct this to, "Notification to State, Provincial, or Local Law Enforcement", to be consistent with the language in the background section part, "A Reporting Process Solution – EOP-004". Measure 4 is not clear enough regarding the extent to which drills should be performed. Does the measure mean that all events in the events list need to be drilled or is drilling a subset of the events list sufficient? Please clearly indicate the extent of drilling that is required or clearly indicate in the requirement the extent of the drills to be performed is the responsibility of the Responsible Entity to identify in their "processes". Evidence Retention – it is not clear what the phrase "prior 3 calendar years" represents in the third paragraph of this section



regarding data retention for requirements and measures for R2, R3, R4 and M2, M3, M4 respectively. Please clarify what this means. Is that different than the meaning of "since the last audit for 3 calendar years" for R1 and M1? VSL for R2 under Severe regarding R1.1 may require revision considering the comment regarding R1.1 in item 2 previously stated. In addition, the VRF for R2 is MEDIUM. R2 is administrative regarding the implementation of the requirements specified in R1. Documentation and maintenance should be considered LOWER. There is no VSL for R4 and a VSL for R4 needs to be proposed.

### **Additional Comments Received:**

#### **Southwestern Power Administration's Comments for Project 2009-1**

Submitted by Angela Summer

"Attachment 1 contains elements that do not need to be included, and redundant elements such as:

Forced intrusion at BES Facility - A facility break-in does not necessarily mean that the facility has been impacted or has undergone damage or destruction.

Detection of a reportable Cyber Security Incident per CIP-008 - If entities are addressing this requirement in CIP-008, why do so again in EOP-004 (Attachment 2-EOP-004, Reporting Requirement number 5)?

Transmission Loss: Each TOP that experiences transmission loss of three or more facilities - This element should be removed or rewritten so that it only applies when the loss includes a contingent element of an IROL facility."

# Standards Announcement

Project 2009-01 – Disturbance and Sabotage Reporting

## Initial Ballot and Non-binding Poll Results

### [Now Available](#)

An initial ballot of EOP-004-2 – Event Reporting and its implementation plan, and a non-binding poll of the associated VRFs and VSLs, concluded on December 12, 2011. Voting statistics are listed below, and the [Ballot Results](#) webpage provides a link to the initial ballot detailed results.

#### **Initial Ballot Results for EOP-004-2**

Quorum: 87.97%

Approval: 36.21%

#### **Non-Binding Poll Results**

85.28% of those who registered to participate provided an opinion or abstention; 45% of those who provided an opinion indicated support for the VRFs and VSLs.

### **Next Steps**

The drafting team will consider all comments received during the comment period and ballot.

### **Background**

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate. The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards. Additional information is available on the [project webpage](#).

A stakeholder interested in following the Disturbance and Sabotage Reporting Drafting Team’s development of EOP-004-2 may monitor meeting agendas and notes on the team’s [“Related Files”](#) web page or may submit a request to join the team’s “plus” email list to receive meeting agendas and

meeting notes as they are distributed to the team. To join the team's "plus" e-mail list, send an e-mail request to: [sarcomm@nerc.net](mailto:sarcomm@nerc.net). Please indicate the drafting team's name in the subject line of the e-mail.

### **Standards Development Process**

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
116-390 Village Blvd.  
Princeton, NJ 08540  
609.452.8060 | [www.nerc.com](http://www.nerc.com)

User Name

Password

Log in

Register

- Ballot Pools
- Current Ballots
- Ballot Results
- Registered Ballot Body
- Proxy Voters

[Home Page](#)

Ballot Results	
<b>Ballot Name:</b>	Project 2009-01 Disturbance and Sabotage Reporting Initial Ballot_in
<b>Ballot Period:</b>	12/2/2011 - 12/12/2011
<b>Ballot Type:</b>	Initial
<b>Total # Votes:</b>	373
<b>Total Ballot Pool:</b>	424
<b>Quorum:</b>	<b>87.97 % The Quorum has been reached</b>
<b>Weighted Segment Vote:</b>	36.21 %
<b>Ballot Results:</b>	<b>The standard will proceed to recirculation ballot.</b>

Summary of Ballot Results									
Segment	Ballot Pool	Segment Weight	Affirmative		Negative		Abstain # Votes	No Vote	
			# Votes	Fraction	# Votes	Fraction			
1 - Segment 1.	104	1	32	0.4	48	0.6	6	18	
2 - Segment 2.	11	0.6	1	0.1	5	0.5	1	4	
3 - Segment 3.	108	1	33	0.344	63	0.656	4	8	
4 - Segment 4.	37	1	12	0.375	20	0.625	1	4	
5 - Segment 5.	91	1	32	0.432	42	0.568	5	12	
6 - Segment 6.	53	1	14	0.292	34	0.708	2	3	
7 - Segment 7.	0	0	0	0	0	0	0	0	
8 - Segment 8.	8	0.6	4	0.4	2	0.2	1	1	
9 - Segment 9.	4	0.3	0	0	3	0.3	0	1	
10 - Segment 10.	8	0.8	3	0.3	5	0.5	0	0	
<b>Totals</b>	<b>424</b>	<b>7.3</b>	<b>131</b>	<b>2.643</b>	<b>222</b>	<b>4.657</b>	<b>20</b>	<b>51</b>	

Individual Ballot Pool Results				
Segment	Organization	Member	Ballot	Comments
1	Ameren Services	Kirit Shah	Negative	<a href="#">View</a>
1	American Electric Power	Paul B. Johnson	Negative	<a href="#">View</a>
1	American Transmission Company, LLC	Andrew Z Puszta	Affirmative	
1	Arizona Public Service Co.	Robert Smith	Affirmative	
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative	
1	Austin Energy	James Armke	Abstain	
1	Avista Corp.	Scott J Kinney	Negative	<a href="#">View</a>
1	Balancing Authority of Northern California	Kevin Smith	Negative	

1	Baltimore Gas & Electric Company	Gregory S Miller	Negative	<a href="#">View</a>
1	BC Hydro and Power Authority	Patricia Robertson	Negative	<a href="#">View</a>
1	Beaches Energy Services	Joseph S Stonecipher	Negative	<a href="#">View</a>
1	Black Hills Corp	Eric Egge		
1	Bonneville Power Administration	Donald S. Watkins	Negative	
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey		
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Negative	<a href="#">View</a>
1	Central Maine Power Company	Joseph Turano Jr.	Negative	
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Affirmative	
1	Clark Public Utilities	Jack Stamper	Negative	<a href="#">View</a>
1	Colorado Springs Utilities	Paul Morland	Affirmative	
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Negative	<a href="#">View</a>
1	CPS Energy	Richard Castrejana	Negative	<a href="#">View</a>
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative	
1	Dayton Power & Light Co.	Hertzel Shamash	Affirmative	
1	Deseret Power	James Tucker	Affirmative	
1	Dominion Virginia Power	Michael S Crowley		
1	Duke Energy Carolina	Douglas E. Hils	Negative	<a href="#">View</a>
1	East Kentucky Power Coop.	George S. Carruba		
1	Empire District Electric Co.	Ralph F Meyer	Affirmative	<a href="#">View</a>
1	Entergy Services, Inc.	Edward J Davis	Negative	<a href="#">View</a>
1	FirstEnergy Corp.	William J Smith	Negative	<a href="#">View</a>
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton		
1	Florida Power & Light Co.	Mike O'Neil		
1	Gainesville Regional Utilities	Luther E. Fair	Affirmative	<a href="#">View</a>
1	Georgia Transmission Corporation	Jason Snodgrass	Abstain	
1	Grand River Dam Authority	James M Stafford		
1	Great River Energy	Gordon Pietsch	Affirmative	<a href="#">View</a>
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Negative	<a href="#">View</a>
1	Hydro One Networks, Inc.	Ajay Garg	Negative	<a href="#">View</a>
1	Hydro-Quebec TransEnergie	Bernard Pelletier		
1	Idaho Power Company	Ronald D. Schellberg	Affirmative	
1	Imperial Irrigation District	Tino Zaragoza	Affirmative	<a href="#">View</a>
1	International Transmission Company Holdings Corp	Michael Moltane	Negative	<a href="#">View</a>
1	JEA	Ted Hobson	Negative	<a href="#">View</a>
1	Kansas City Power & Light Co.	Michael Gammon	Negative	<a href="#">View</a>
1	Keys Energy Services	Stanley T Rzad		
1	Lakeland Electric	Larry E Watt	Negative	<a href="#">View</a>
1	Lee County Electric Cooperative	John W Delucca	Negative	
1	Lincoln Electric System	Doug Bantam	Affirmative	
1	Los Angeles Department of Water & Power	Ly M Le	Negative	
1	Lower Colorado River Authority	Martyn Turner		
1	Manitoba Hydro	Joe D Petaski	Affirmative	<a href="#">View</a>
1	MEAG Power	Danny Dees	Abstain	
1	MidAmerican Energy Co.	Terry Harbour	Negative	<a href="#">View</a>
1	Minnkota Power Coop. Inc.	Richard Burt	Affirmative	
1	National Grid	Saurabh Saksena		
1	Nebraska Public Power District	Cole C Brodine	Affirmative	<a href="#">View</a>
1	New Brunswick Power Transmission Corporation	Randy MacDonald	Negative	<a href="#">View</a>
1	New York Power Authority	Arnold J. Schuff	Negative	
1	New York State Electric & Gas Corp.	Raymond P Kinney	Negative	
1	Northeast Utilities	David Boguslawski	Negative	<a href="#">View</a>
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative	
1	NorthWestern Energy	John Canavan	Affirmative	<a href="#">View</a>
1	Ohio Valley Electric Corp.	Robert Matthey	Negative	
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Abstain	<a href="#">View</a>
1	Omaha Public Power District	Doug Peterchuck	Affirmative	
1	Oncor Electric Delivery	Brenda Pulis	Affirmative	<a href="#">View</a>
1	Orlando Utilities Commission	Brad Chase	Negative	<a href="#">View</a>
1	PacifiCorp	Ryan Millard	Affirmative	
1	PECO Energy	Ronald Schloendorn	Negative	
1	Platte River Power Authority	John C. Collins	Affirmative	
1	Portland General Electric Co.	John T Walker	Affirmative	
1	Potomac Electric Power Co.	David Thorne	Affirmative	

1	PowerSouth Energy Cooperative	Larry D Avery	Negative	
1	PPL Electric Utilities Corp.	Brenda L Truhe	Negative	<a href="#">View</a>
1	Progress Energy Carolinas	Brett A Koelsch	Negative	<a href="#">View</a>
1	Public Service Company of New Mexico	Laurie Williams		
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Negative	<a href="#">View</a>
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel		
1	Public Utility District No. 2 of Grant County	Kyle M. Hussey	Affirmative	
1	Puget Sound Energy, Inc.	Denise M Lietz		
1	Raj Rana	Rajendrasinh D Rana	Abstain	
1	Rochester Gas and Electric Corp.	John C. Allen	Negative	<a href="#">View</a>
1	Sacramento Municipal Utility District	Tim Kelley	Negative	
1	Salmon River Electric Cooperative	Kathryn Spence	Negative	<a href="#">View</a>
1	Salt River Project	Robert Kondziolka	Negative	
1	Santee Cooper	Terry L Blackwell	Negative	<a href="#">View</a>
1	SCE&G	Henry Delk, Jr.		
1	Seattle City Light	Pawel Krupa	Negative	<a href="#">View</a>
1	Sho-Me Power Electric Cooperative	Denise Stevens		
1	Sierra Pacific Power Co.	Rich Salgo	Negative	<a href="#">View</a>
1	Snohomish County PUD No. 1	Long T Duong	Negative	
1	South California Edison Company	Steven Mavis	Affirmative	
1	Southern Company Services, Inc.	Robert Schaffeld	Negative	<a href="#">View</a>
1	Southern Illinois Power Coop.	William Hutchison	Negative	<a href="#">View</a>
1	Southwest Transmission Cooperative, Inc.	James Jones	Affirmative	
1	Sunflower Electric Power Corporation	Noman Lee Williams	Negative	<a href="#">View</a>
1	Tampa Electric Co.	Beth Young		
1	Tennessee Valley Authority	Larry Akens	Abstain	
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative	
1	Tucson Electric Power Co.	John Tolo	Affirmative	
1	United Illuminating Co.	Jonathan Appelbaum	Negative	<a href="#">View</a>
1	Westar Energy	Allen Klassen	Affirmative	
1	Western Area Power Administration	Brandy A Dunn	Affirmative	
1	Xcel Energy, Inc.	Gregory L Pieper		
2	Alberta Electric System Operator	Mark B Thompson	Abstain	<a href="#">View</a>
2	BC Hydro	Venkataramakrishnan Vinnakota	Negative	<a href="#">View</a>
2	California ISO	Rich Vine		
2	Electric Reliability Council of Texas, Inc.	Charles B Manning	Negative	<a href="#">View</a>
2	Independent Electricity System Operator	Barbara Constantinescu	Affirmative	<a href="#">View</a>
2	ISO New England, Inc.	Kathleen Goodman	Negative	<a href="#">View</a>
2	Midwest ISO, Inc.	Marie Knox		
2	New Brunswick System Operator	Alden Briggs	Negative	<a href="#">View</a>
2	New York Independent System Operator	Gregory Campoli	Negative	<a href="#">View</a>
2	PJM Interconnection, L.L.C.	Tom Bowe		
2	Southwest Power Pool, Inc.	Charles Yeung		
3	AEP	Michael E DeLoach	Negative	<a href="#">View</a>
3	Alabama Power Company	Richard J. Mandes	Negative	<a href="#">View</a>
3	Alameda Municipal Power	Douglas Draeger	Negative	<a href="#">View</a>
3	Ameren Services	Mark Peters	Negative	
3	American Public Power Association	Nathan Mitchell	Abstain	<a href="#">View</a>
3	Anaheim Public Utilities Dept.	Kelly Nguyen	Affirmative	
3	APS	Steven Norris	Affirmative	
3	Arkansas Electric Cooperative Corporation	Philip Huff	Negative	<a href="#">View</a>
3	Atlantic City Electric Company	NICOLE BUCKMAN	Affirmative	
3	BC Hydro and Power Authority	Pat G. Harrington	Negative	
3	Blachly-Lane Electric Co-op	Bud Tracy	Negative	<a href="#">View</a>
3	Bonneville Power Administration	Rebecca Berdahl	Negative	<a href="#">View</a>
3	Central Electric Cooperative, Inc. (Redmond, Oregon)	Dave Markham	Negative	<a href="#">View</a>
3	Central Lincoln PUD	Steve Alexanderson	Negative	<a href="#">View</a>
3	City of Alexandria	Michael Marcotte	Negative	
3	City of Austin dba Austin Energy	Andrew Gallo	Negative	<a href="#">View</a>
3	City of Bartow, Florida	Matt Culverhouse	Negative	
3	City of Clewiston	Lynne Mila		
3	City of Farmington	Linda R Jacobson	Negative	<a href="#">View</a>
3	City of Garland	Ronnie C Hoeinghaus	Abstain	
3	City of Green Cove Springs	Gregg R Griffin	Negative	<a href="#">View</a>
3	City of Palo Alto	Eric R Scott	Affirmative	

3	City of Redding	Bill Hughes	Negative	View
3	Clatskanie People's Utility District	Brian Fawcett	Abstain	
3	Clearwater Power Co.	Dave Hagen	Negative	View
3	Cleco Corporation	Michelle A Corley	Affirmative	
3	Colorado Springs Utilities	Charles Morgan	Affirmative	
3	ComEd	Bruce Krawczyk	Negative	
3	Consolidated Edison Co. of New York	Peter T Yost	Negative	View
3	Constellation Energy	CJ Ingersoll	Negative	View
3	Consumers Energy	Richard Blumenstock	Negative	View
3	Consumers Power Inc.	Roman Gillen	Negative	View
3	Coos-Curry Electric Cooperative, Inc	Roger Meader	Negative	View
3	Cowlitz County PUD	Russell A Noble	Negative	View
3	CPS Energy	Jose Escamilla	Negative	View
3	Delmarva Power & Light Co.	Michael R. Mayer	Affirmative	
3	Detroit Edison Company	Kent Kujala	Affirmative	
3	Dominion Resources Services	Michael F. Gildea	Affirmative	
3	Duke Energy Carolina	Henry Ernst-Jr	Negative	View
3	Entergy	Joel T Plessinger	Negative	
3	Fall River Rural Electric Cooperative	Bryan Case	Negative	View
3	FirstEnergy Energy Delivery	Stephan Kern	Negative	View
3	Florida Municipal Power Agency	Joe McKinney	Negative	View
3	Florida Power Corporation	Lee Schuster	Negative	View
3	Georgia Power Company	Anthony L Wilson	Negative	View
3	Georgia Systems Operations Corporation	William N. Phinney	Negative	View
3	Grays Harbor PUD	Wesley W Gray		
3	Great River Energy	Brian Glover	Affirmative	View
3	Gulf Power Company	Paul C Caldwell	Negative	View
3	Hydro One Networks, Inc.	David Kiguel	Negative	View
3	Imperial Irrigation District	Jesus S. Alcaraz	Affirmative	View
3	JEA	Garry Baker	Affirmative	
3	Kansas City Power & Light Co.	Charles Locke	Negative	View
3	Kissimmee Utility Authority	Gregory D Woessner	Negative	
3	Kootenai Electric Cooperative	Dave Kahly	Affirmative	View
3	Lakeland Electric	Norman D Harryhill	Negative	View
3	Lane Electric Cooperative, Inc.	Rick Crinklaw	Negative	View
3	Lincoln Electric System	Jason Fortik	Affirmative	
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Negative	
3	Louisville Gas and Electric Co.	Charles A. Freibert	Negative	View
3	Manitoba Hydro	Greg C. Parent	Affirmative	View
3	Manitowoc Public Utilities	Thomas E Reed	Affirmative	
3	MidAmerican Energy Co.	Thomas C. Mielnik	Negative	View
3	Mississippi Power	Jeff Franklin	Negative	View
3	Modesto Irrigation District	Jack W Savage		
3	Municipal Electric Authority of Georgia	Steven M. Jackson	Abstain	
3	Muscatine Power & Water	John S Bos	Affirmative	
3	Nebraska Public Power District	Tony Eddleman	Affirmative	View
3	New York Power Authority	Marilyn Brown	Negative	
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Negative	
3	North Carolina Electric Membership Corp.	Doug White	Negative	
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative	
3	Northern Lights Inc.	Jon Shelby	Negative	View
3	Ocala Electric Utility	David Anderson		
3	Old Dominion Electric Coop.	Bill Watson	Negative	View
3	Orange and Rockland Utilities, Inc.	David Burke	Negative	View
3	Orlando Utilities Commission	Ballard K Muters	Negative	
3	Owensboro Municipal Utilities	Thomas T Lyons	Negative	
3	Pacific Gas and Electric Company	John H Hagen	Affirmative	
3	PacifiCorp	Dan Zollner	Affirmative	
3	Platte River Power Authority	Terry L Baker	Affirmative	
3	PNM Resources	Michael Mertz		
3	Potomac Electric Power Co.	Robert Reuter	Affirmative	
3	Progress Energy Carolinas	Sam Waters	Negative	View
3	Public Service Electric and Gas Co.	Jeffrey Mueller	Negative	View
3	Public Utility District No. 1 of Benton County	Gloria Bender	Affirmative	
3	Public Utility District No. 1 of Clallam County	David Proebstel	Affirmative	
3	Puget Sound Energy, Inc.	Erin Apperson	Affirmative	
3	Raft River Rural Electric Cooperative	Heber Carpenter	Negative	View


3	Rutherford EMC	Thomas M Haire	Affirmative	View
3	Sacramento Municipal Utility District	James Leigh-Kendall	Negative	
3	Salt River Project	John T. Underhill	Negative	View
3	Santee Cooper	James M Poston	Negative	View
3	Seattle City Light	Dana Wheelock	Negative	View
3	Seminole Electric Cooperative, Inc.	James R Frauen		
3	Snohomish County PUD No. 1	Mark Oens	Negative	View
3	South Carolina Electric & Gas Co.	Hubert C Young	Affirmative	
3	Southern California Edison Co.	David B Coher	Negative	
3	Southern Maryland Electric Coop.	Mark R Jones	Affirmative	
3	Tacoma Public Utilities	Travis Metcalfe	Affirmative	
3	Tampa Electric Co.	Ronald L Donahey	Negative	
3	Tennessee Valley Authority	Ian S Grant		
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative	
3	Umatilla Electric Cooperative	Steve Eldrige	Negative	View
3	Westar Energy	Bo Jones	Affirmative	
3	Wisconsin Electric Power Marketing	James R Keller	Affirmative	
3	Wisconsin Public Service Corp.	Gregory J Le Grave	Negative	View
3	Xcel Energy, Inc.	Michael Ibold		
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative	
4	American Municipal Power	Kevin Koloini	Negative	
4	Arkansas Electric Cooperative Corporation	Ronnie Frizzell	Negative	View
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative	
4	Central Lincoln PUD	Shamus J Gamache	Negative	View
4	City of Austin dba Austin Energy	Reza Ebrahimian	Negative	View
4	City of Clewiston	Kevin McCarthy		
4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	Negative	
4	City of Redding	Nicholas Zettel	Negative	View
4	City Utilities of Springfield, Missouri	John Allen	Affirmative	View
4	Consumers Energy	David Frank Ronk	Negative	View
4	Cowlitz County PUD	Rick Syring	Negative	View
4	Detroit Edison Company	Daniel Herring	Affirmative	
4	Flathead Electric Cooperative	Russ Schneider	Negative	
4	Florida Municipal Power Agency	Frank Gaffney	Negative	View
4	Fort Pierce Utilities Authority	Thomas Richards	Affirmative	View
4	Georgia System Operations Corporation	Guy Andrews	Negative	View
4	Illinois Municipal Electric Agency	Bob C. Thomas	Negative	View
4	Imperial Irrigation District	Diana U Torres	Affirmative	View
4	Indiana Municipal Power Agency	Jack Alvey	Negative	View
4	Integrus Energy Group, Inc.	Christopher Plante		
4	LaGen	Richard Comeaux		
4	Madison Gas and Electric Co.	Joseph DePoorter	Affirmative	
4	North Carolina Electric Membership Corp.	Bob Beadle	Negative	
4	Northern California Power Agency	Tracy R Bibb	Affirmative	
4	Ohio Edison Company	Douglas Hohlbaugh	Negative	View
4	Oklahoma Municipal Power Authority	Ashley Stringer	Affirmative	
4	Pacific Northwest Generating Cooperative	Aleka K Scott	Negative	View
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative	
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Negative	View
4	Sacramento Municipal Utility District	Mike Ramirez	Negative	
4	Seattle City Light	Hao Li	Negative	View
4	South Mississippi Electric Power Association	Steven McElhaney		
4	Tacoma Public Utilities	Keith Morisette	Affirmative	
4	West Oregon Electric Cooperative, Inc.	Marc M Farmer	Negative	View
4	White River Electric Association Inc.	Frank L. Sampson	Abstain	
4	Wisconsin Energy Corp.	Anthony Jankowski	Affirmative	
5	AEP Service Corp.	Brock Ondayko		
5	AES Corporation	Leo Bernier	Affirmative	
5	Amerenue	Sam Dwyer	Negative	
5	Arizona Public Service Co.	Edward Cambridge	Affirmative	
5	Avista Corp.	Edward F. Groce	Negative	View
5	BC Hydro and Power Authority	Clement Ma	Negative	View
5	Black Hills Corp	George Tatar	Affirmative	
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla	Negative	
5	Bonneville Power Administration	Francis J. Halpin	Negative	View



5	BrightSource Energy, Inc.	Chifong Thomas	Affirmative	
5	Caithness Long Island, LLC	Jason M Moore	Affirmative	
5	Chelan County Public Utility District #1	John Yale	Abstain	
5	City and County of San Francisco	Daniel Mason	Affirmative	
5	City of Austin dba Austin Energy	Jeanie Doty	Negative	View
5	City of Redding	Paul Cummings	Negative	View
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick	Affirmative	
5	City of Tallahassee	Brian Horton		
5	City Water, Light & Power of Springfield	Steve Rose		
5	Cogentrix Energy, Inc.	Mike D Hirst	Affirmative	
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative	
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Negative	View
5	Constellation Power Source Generation, Inc.	Amir Y Hammad	Negative	View
5	Consumers Energy Company	David C Greyerbiehl	Abstain	
5	Cowlitz County PUD	Bob Essex	Negative	View
5	CPS Energy	Robert Stevens	Negative	
5	Detroit Edison Company	Christy Wicke	Affirmative	
5	Dominion Resources, Inc.	Mike Garton	Affirmative	
5	Duke Energy	Dale Q Goodwine	Negative	View
5	Dynegy Inc.	Dan Roethemeyer	Negative	View
5	E.ON Climate & Renewables North America, LLC	Dana Showalter		
5	Edison Mission Energy	Ellen Oswald		
5	Electric Power Supply Association	John R Cashin		
5	Exelon Nuclear	Michael Korchynsky	Negative	
5	ExxonMobil Research and Engineering	Martin Kaufman	Negative	
5	FirstEnergy Solutions	Kenneth Dresner		
5	Florida Municipal Power Agency	David Schumann	Negative	View
5	Great River Energy	Preston L Walsh	Affirmative	View
5	Green Country Energy	Greg Froehling	Affirmative	
5	Imperial Irrigation District	Marcela Y Caballero	Affirmative	View
5	Indeck Energy Services, Inc.	Rex A Roehl		
5	JEA	John J Babik	Negative	View
5	Kissimmee Utility Authority	Mike Blough	Negative	
5	Lakeland Electric	James M Howard	Negative	
5	Liberty Electric Power LLC	Daniel Duff	Negative	View
5	Lincoln Electric System	Dennis Florom	Affirmative	
5	Los Angeles Department of Water & Power	Kenneth Silver	Negative	
5	Lower Colorado River Authority	Tom Foreman	Negative	View
5	Luminant Generation Company LLC	Mike Laney	Negative	View
5	Manitoba Hydro	S N Fernando	Affirmative	View
5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Abstain	
5	MEAG Power	Steven Grego	Abstain	
5	MidAmerican Energy Co.	Christopher Schneider	Negative	View
5	Muscatine Power & Water	Mike Avesing	Affirmative	
5	Nebraska Public Power District	Don Schmit	Affirmative	View
5	New York Power Authority	Gerald Mannarino	Negative	
5	NextEra Energy	Allen D Schriver	Negative	
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Negative	
5	Northern California Power Agency	Hari Modi	Affirmative	
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative	
5	Occidental Chemical	Michelle R DAntuono	Affirmative	View
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative	
5	Orlando Utilities Commission	Richard Kinias	Negative	
5	Pacific Gas and Electric Company	Richard J. Padilla	Affirmative	
5	PacifiCorp	Sandra L. Shaffer	Affirmative	
5	Platte River Power Authority	Roland Thiel	Affirmative	
5	Portland General Electric Co.	Gary L Tingley	Affirmative	
5	PowerSouth Energy Cooperative	Tim Hattaway	Negative	View
5	PPL Generation LLC	Annette M Bannon	Negative	View
5	Progress Energy Carolinas	Wayne Lewis	Negative	
5	PSEG Fossil LLC	Tim Kucey	Negative	View
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative	
5	Puget Sound Energy, Inc.	Tom Flynn		
5	Sacramento Municipal Utility District	Bethany Hunter	Negative	
5	Salt River Project	William Alkema	Negative	

5	Santee Cooper	Lewis P Pierce	Negative	View
5	Seattle City Light	Michael J. Haynes	Negative	View
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins		
5	Siemens PTI	Edwin Cano	Affirmative	
5	Snohomish County PUD No. 1	Sam Niefeld	Negative	View
5	South Mississippi Electric Power Association	Jerry W Johnson		
5	Southern California Edison Co.	Denise Yaffe	Negative	View
5	Southern Company Generation	William D Shultz	Negative	View
5	Tampa Electric Co.	RJames Rocha	Negative	
5	Tenaska, Inc.	Scott M Helyer	Affirmative	
5	Tennessee Valley Authority	David Thompson	Abstain	
5	Tri-State G & T Association, Inc.	Barry Ingold	Affirmative	
5	U.S. Army Corps of Engineers	Melissa Kurtz	Affirmative	
5	Vandolah Power Company L.L.C.	Douglas A. Jensen		
5	Wisconsin Electric Power Co.	Linda Horn	Affirmative	
5	Wisconsin Public Service Corp.	Leonard Rentmeester	Negative	View
5	Xcel Energy, Inc.	Liam Noailles	Affirmative	
6	ACES Power Marketing	Jason L Marshall	Negative	View
6	AEP Marketing	Edward P. Cox	Negative	View
6	Ameren Energy Marketing Co.	JENNIFER RICHARDSON	Negative	
6	APS	RANDY A YOUNG	Affirmative	
6	Arkansas Electric Cooperative Corporation	Keith Sugg	Negative	View
6	Bonneville Power Administration	Brenda S. Anderson	Negative	
6	City of Austin dba Austin Energy	Lisa L Martin	Negative	View
6	City of Redding	Marvin Briggs	Negative	View
6	Cleco Power LLC	Robert Hirschak	Affirmative	
6	Colorado Springs Utilities	Lisa C Rosintoski	Affirmative	
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Negative	View
6	Constellation Energy Commodities Group	Brenda Powell	Negative	View
6	Dominion Resources, Inc.	Louis S. Slade	Affirmative	
6	Duke Energy Carolina	Walter Yeager	Negative	View
6	Entergy Services, Inc.	Terri F Benoit	Negative	
6	Exelon Power Team	Pulin Shah	Negative	View
6	FirstEnergy Solutions	Kevin Querry	Negative	View
6	Florida Municipal Power Agency	Richard L. Montgomery	Negative	View
6	Florida Municipal Power Pool	Thomas Washburn	Negative	View
6	Florida Power & Light Co.	Silvia P. Mitchell	Negative	View
6	Imperial Irrigation District	Cathy Bretz	Affirmative	View
6	Kansas City Power & Light Co.	Jessica L Klinghoffer	Negative	View
6	Lakeland Electric	Paul Shipp	Negative	View
6	Lincoln Electric System	Eric Ruskamp	Affirmative	
6	Los Angeles Department of Water & Power	Brad Packer	Negative	
6	Luminant Energy	Brad Jones	Negative	View
6	Manitoba Hydro	Daniel Prowse	Affirmative	View
6	MidAmerican Energy Co.	Dennis Kimm	Negative	
6	New York Power Authority	William Palazzo	Negative	
6	North Carolina Municipal Power Agency #1	Matthew Schull		
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative	
6	Omaha Public Power District	David Ried	Affirmative	
6	Orlando Utilities Commission	Claston Augustus Sunanon	Negative	
6	PacifiCorp	Scott L Smith	Affirmative	
6	Platte River Power Authority	Carol Ballantine	Affirmative	
6	PPL EnergyPlus LLC	Mark A Heimbach	Negative	View
6	Progress Energy	John T Sturgeon	Negative	View
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Negative	View
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen	Abstain	
6	Sacramento Municipal Utility District	Diane Enderby	Negative	
6	Salt River Project	Steven J Hulet	Negative	
6	Santee Cooper	Michael Brown	Negative	View
6	Seattle City Light	Dennis Sismaet	Negative	View
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak		
6	Snohomish County PUD No. 1	William T Moojen	Negative	View
6	South California Edison Company	Lujuanna Medina	Negative	
6	Southern Company Generation and Energy Marketing	John J. Ciza	Negative	View
6	Tacoma Public Utilities	Michael C Hill	Affirmative	
6	Tampa Electric Co.	Benjamin F Smith II	Negative	

6	Tennessee Valley Authority	Marjorie S. Parsons	<a href="#">Abstain</a>	
6	Westar Energy	Grant L Wilkerson	<a href="#">Affirmative</a>	
6	Western Area Power Administration - UGP Marketing	Peter H Kinney		
6	Xcel Energy, Inc.	David F. Lemmons	<a href="#">Affirmative</a>	
8		Edward C Stein	<a href="#">Affirmative</a>	
8		Roger C Zaklukiewicz		
8		James A Maenner	<a href="#">Negative</a>	<a href="#">View</a>
8	JDRJC Associates	Jim Cyrulewski	<a href="#">Abstain</a>	
8	Pacific Northwest Generating Cooperative	Margaret Ryan	<a href="#">Negative</a>	<a href="#">View</a>
8	Power Energy Group LLC	Peggy Abbadini	<a href="#">Affirmative</a>	
8	Utility Services, Inc.	Brian Evans-Mongeon	<a href="#">Affirmative</a>	
8	Volkman Consulting, Inc.	Terry Volkman	<a href="#">Affirmative</a>	
9	California Energy Commission	William M Chamberlain		
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	<a href="#">Negative</a>	<a href="#">View</a>
9	National Association of Regulatory Utility Commissioners	Diane J Barney	<a href="#">Negative</a>	<a href="#">View</a>
9	New York State Department of Public Service	Thomas Dvorsky	<a href="#">Negative</a>	<a href="#">View</a>
10	Midwest Reliability Organization	James D Burley	<a href="#">Affirmative</a>	
10	New York State Reliability Council	Alan Adamson	<a href="#">Negative</a>	
10	Northeast Power Coordinating Council	Guy V. Zito	<a href="#">Negative</a>	<a href="#">View</a>
10	ReliabilityFirst Corporation	Anthony E Jablonski	<a href="#">Negative</a>	<a href="#">View</a>
10	SERC Reliability Corporation	Carter B. Edge	<a href="#">Negative</a>	<a href="#">View</a>
10	Southwest Power Pool RE	Emily Pennel	<a href="#">Affirmative</a>	<a href="#">View</a>
10	Texas Reliability Entity, Inc.	Donald G Jones	<a href="#">Negative</a>	<a href="#">View</a>
10	Western Electricity Coordinating Council	Steven L. Rueckert	<a href="#">Affirmative</a>	<a href="#">View</a>



[Legal and Privacy](#) : 609.452.8060 voice : 609.452.9550 fax : 116-390 Village Boulevard : Princeton, NJ 08540-5721  
 Washington Office: 1120 G Street, N.W. : Suite 990 : Washington, DC 20005-3801

[Account Log-In/Register](#)

Copyright © 2010 by the North American Electric Reliability Corporation. : All rights reserved.  
 A New Jersey Nonprofit Corporation

## 2009-01 Disturbance and Sabotage Reporting Non-Binding Poll Results

Ballot Results				
<b>Non-Binding Poll Name:</b>	Project 2009-01 Disturbance And Sabotage Reporting-Non-binding Poll			
<b>Poll Period:</b>	12/2/2011 - 12/12/2011			
<b>Total # Opinions:</b>	264			
<b>Total Ballot Pool:</b>	394			
<b>Summary Results:</b>	85.28% of those who registered to participate provided an opinion or abstention; 45% of those who provided an opinion indicated support for the VRFs and VSLs.			
Individual Ballot Pool Results				
Segment	Organization	Member	Ballot	Comments
1	Ameren Services	Kirit Shah	Negative	<a href="#">View</a>
1	American Electric Power	Paul B. Johnson	Negative	<a href="#">View</a>
1	American Transmission Company, LLC	Andrew Z Puztai	Abstain	
1	Arizona Public Service Co.	Robert Smith	Affirmative	
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative	
1	Avista Corp.	Scott J Kinney	Negative	<a href="#">View</a>
1	Balancing Authority of Northern California	Kevin Smith	Negative	
1	Baltimore Gas & Electric Company	Gregory S Miller	Abstain	
1	BC Hydro and Power Authority	Patricia Robertson	Abstain	
1	Beaches Energy Services	Joseph S Stonecipher	Negative	<a href="#">View</a>
1	Black Hills Corp	Eric Egge		
1	Bonneville Power Administration	Donald S. Watkins	Affirmative	
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey		
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Abstain	
1	Central Maine Power Company	Joseph Turano Jr.	Negative	
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Affirmative	
1	Clark Public Utilities	Jack Stamper	Abstain	
1	Colorado Springs Utilities	Paul Morland	Affirmative	
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Negative	<a href="#">View</a>
1	CPS Energy	Richard Castrejano	Affirmative	
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative	
1	Dayton Power & Light Co.	Hertzel Shamash	Affirmative	
1	Deseret Power	James Tucker	Affirmative	

1	Dominion Virginia Power	Michael S Crowley		
1	Duke Energy Carolina	Douglas E. Hils	Negative	<a href="#">View</a>
1	East Kentucky Power Coop.	George S. Carruba		
1	Empire District Electric Co.	Ralph F Meyer	Affirmative	<a href="#">View</a>
1	Entergy Services, Inc.	Edward J Davis	Negative	
1	FirstEnergy Corp.	William J Smith	Negative	<a href="#">View</a>
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton		
1	Florida Power & Light Co.	Mike O'Neil		
1	Gainesville Regional Utilities	Luther E. Fair	Affirmative	
1	Georgia Transmission Corporation	Jason Snodgrass	Abstain	
1	Grand River Dam Authority	James M Stafford		
1	Great River Energy	Gordon Pietsch	Affirmative	
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Affirmative	
1	Hydro One Networks, Inc.	Ajay Garg	Abstain	
1	Hydro-Quebec TransEnergie	Bernard Pelletier		
1	Idaho Power Company	Ronald D. Schellberg	Affirmative	
1	Imperial Irrigation District	Tino Zaragoza	Affirmative	
1	International Transmission Company Holdings Corp	Michael Moltane	Abstain	
1	JEA	Ted Hobson	Affirmative	
1	Kansas City Power & Light Co.	Michael Gammon	Negative	<a href="#">View</a>
1	Keys Energy Services	Stanley T Rzad		
1	Lakeland Electric	Larry E Watt	Negative	
1	Lee County Electric Cooperative	John W Delucca	Abstain	
1	Lincoln Electric System	Doug Bantam	Affirmative	
1	Los Angeles Department of Water & Power	Ly M Le	Negative	
1	Lower Colorado River Authority	Martyn Turner		
1	Manitoba Hydro	Joe D Petaski	Affirmative	
1	MEAG Power	Danny Dees	Abstain	
1	MidAmerican Energy Co.	Terry Harbour	Negative	
1	Minnkota Power Coop. Inc.	Richard Burt	Affirmative	
1	National Grid	Saurabh Saksena		
1	Nebraska Public Power District	Cole C Brodine	Abstain	
1	New Brunswick Power Transmission Corporation	Randy MacDonald	Negative	
1	New York Power Authority	Arnold J. Schuff	Negative	
1	New York State Electric & Gas Corp.	Raymond P Kinney	Abstain	
1	Northeast Utilities	David Boguslawski	Affirmative	
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative	
1	NorthWestern Energy	John Canavan	Affirmative	
1	Ohio Valley Electric Corp.	Robert Matthey	Negative	
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Abstain	
1	Omaha Public Power District	Doug Peterchuck	Affirmative	
1	Oncor Electric Delivery	Brenda Pulis	Affirmative	
1	Orlando Utilities Commission	Brad Chase	Negative	<a href="#">View</a>

1	PacifiCorp	Ryan Millard	Abstain	
1	PECO Energy	Ronald Schloendorn	Negative	
1	Platte River Power Authority	John C. Collins	Affirmative	
1	Portland General Electric Co.	John T Walker	Affirmative	
1	PowerSouth Energy Cooperative	Larry D Avery	Negative	
1	PPL Electric Utilities Corp.	Brenda L Truhe	Negative	<a href="#">View</a>
1	Progress Energy Carolinas	Brett A Koelsch	Negative	<a href="#">View</a>
1	Public Service Company of New Mexico	Laurie Williams		
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Abstain	
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel		
1	Puget Sound Energy, Inc.	Denise M Lietz		
1	Rochester Gas and Electric Corp.	John C. Allen	Abstain	
1	Sacramento Municipal Utility District	Tim Kelley	Negative	
1	Salmon River Electric Cooperative	Kathryn Spence	Negative	<a href="#">View</a>
1	Salt River Project	Robert Kondziolka	Negative	
1	Santee Cooper	Terry L Blackwell	Negative	<a href="#">View</a>
1	SCE&G	Henry Delk, Jr.		
1	Seattle City Light	Pawel Krupa	Negative	<a href="#">View</a>
1	Sho-Me Power Electric Cooperative	Denise Stevens		
1	Sierra Pacific Power Co.	Rich Salgo	Affirmative	
1	Snohomish County PUD No. 1	Long T Duong	Abstain	
1	South California Edison Company	Steven Mavis	Affirmative	
1	Southern Company Services, Inc.	Robert Schaffeld	Negative	<a href="#">View</a>
1	Southern Illinois Power Coop.	William Hutchison	Negative	<a href="#">View</a>
1	Southwest Transmission Cooperative, Inc.	James Jones	Affirmative	
1	Southwestern Power Administration	Angela L Summer	Negative	
1	Sunflower Electric Power Corporation	Noman Lee Williams	Affirmative	
1	Tampa Electric Co.	Beth Young		
1	Tennessee Valley Authority	Larry Akens	Abstain	
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative	
1	Tucson Electric Power Co.	John Tolo	Negative	<a href="#">View</a>
1	United Illuminating Co.	Jonathan Appelbaum	Negative	<a href="#">View</a>
1	Westar Energy	Allen Klassen	Abstain	
1	Western Area Power Administration	Brandy A Dunn	Affirmative	
1	Xcel Energy, Inc.	Gregory L Pieper		
2	Alberta Electric System Operator	Mark B Thompson	Abstain	
2	BC Hydro	Venkataramakrishnan Vinnakota	Abstain	
2	California ISO	Rich Vine		
2	Electric Reliability Council of Texas, Inc.	Charles B Manning	Negative	<a href="#">View</a>
2	Independent Electricity System Operator	Barbara Constantinescu	Affirmative	
2	Midwest ISO, Inc.	Marie Knox		
2	New Brunswick System Operator	Alden Briggs	Abstain	
2	New York Independent System	Gregory Campoli	Abstain	

	Operator			
2	PJM Interconnection, L.L.C.	Tom Bowe		
2	Southwest Power Pool, Inc.	Charles Yeung		
3	AEP	Michael E DeLoach	Negative	<a href="#">View</a>
3	Alabama Power Company	Richard J. Mandes	Negative	<a href="#">View</a>
3	Ameren Services	Mark Peters	Negative	
3	Anaheim Public Utilities Dept.	Kelly Nguyen	Affirmative	
3	APS	Steven Norris	Abstain	
3	Arkansas Electric Cooperative Corporation	Philip Huff	Affirmative	
3	BC Hydro and Power Authority	Pat G. Harrington	Abstain	
3	Bonneville Power Administration	Rebecca Berdahl	Affirmative	
3	Central Lincoln PUD	Steve Alexanderson	Negative	<a href="#">View</a>
3	City of Austin dba Austin Energy	Andrew Gallo	Negative	
3	City of Bartow, Florida	Matt Culverhouse	Negative	
3	City of Clewiston	Lynne Mila		
3	City of Farmington	Linda R Jacobson	Affirmative	
3	City of Garland	Ronnie C Hoeinghaus	Abstain	
3	City of Green Cove Springs	Gregg R Griffin	Negative	<a href="#">View</a>
3	City of Redding	Bill Hughes	Negative	<a href="#">View</a>
3	Clatskanie People's Utility District	Brian Fawcett	Abstain	
3	Cleco Corporation	Michelle A Corley	Abstain	<a href="#">View</a>
3	Colorado Springs Utilities	Charles Morgan	Affirmative	
3	ComEd	Bruce Krawczyk	Negative	
3	Consolidated Edison Co. of New York	Peter T Yost	Negative	
3	Constellation Energy	CJ Ingersoll	Abstain	
3	Consumers Energy	Richard Blumenstock	Negative	
3	Cowlitz County PUD	Russell A Noble	Negative	<a href="#">View</a>
3	CPS Energy	Jose Escamilla	Affirmative	
3	Detroit Edison Company	Kent Kujala	Affirmative	
3	Dominion Resources Services	Michael F. Gildea	Abstain	
3	Duke Energy Carolina	Henry Ernst-Jr	Negative	<a href="#">View</a>
3	Entergy	Joel T Plessinger	Negative	
3	FirstEnergy Energy Delivery	Stephan Kern	Negative	<a href="#">View</a>
3	Florida Municipal Power Agency	Joe McKinney	Negative	<a href="#">View</a>
3	Florida Power Corporation	Lee Schuster	Negative	
3	Georgia Power Company	Anthony L Wilson	Negative	<a href="#">View</a>
3	Georgia Systems Operations Corporation	William N. Phinney	Negative	<a href="#">View</a>
3	Grays Harbor PUD	Wesley W Gray		
3	Great River Energy	Brian Glover	Affirmative	
3	Gulf Power Company	Paul C Caldwell	Negative	<a href="#">View</a>
3	Hydro One Networks, Inc.	David Kiguel	Abstain	
3	Imperial Irrigation District	Jesus S. Alcaraz	Affirmative	
3	JEA	Garry Baker	Affirmative	
3	Kansas City Power & Light Co.	Charles Locke	Negative	<a href="#">View</a>
3	Kissimmee Utility Authority	Gregory D Woessner	Negative	
3	Kootenai Electric Cooperative	Dave Kahly	Affirmative	

3	Lakeland Electric	Norman D Harryhill	Negative	<a href="#">View</a>
3	Lincoln Electric System	Jason Fortik	Affirmative	
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Negative	
3	Louisville Gas and Electric Co.	Charles A. Freibert		
3	Manitoba Hydro	Greg C. Parent	Affirmative	
3	Manitowoc Public Utilities	Thomas E Reed	Affirmative	
3	MidAmerican Energy Co.	Thomas C. Mielnik	Abstain	
3	Mississippi Power	Jeff Franklin	Negative	<a href="#">View</a>
3	Modesto Irrigation District	Jack W Savage		
3	Municipal Electric Authority of Georgia	Steven M. Jackson	Abstain	
3	Muscatine Power & Water	John S Bos	Affirmative	
3	Nebraska Public Power District	Tony Eddleman	Abstain	
3	New York Power Authority	Marilyn Brown	Negative	
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Negative	
3	North Carolina Electric Membership Corp.	Doug White	Affirmative	
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative	
3	Ocala Electric Utility	David Anderson		
3	Old Dominion Electric Coop.	Bill Watson		
3	Orange and Rockland Utilities, Inc.	David Burke	Negative	<a href="#">View</a>
3	Orlando Utilities Commission	Ballard K Mutters	Negative	
3	Owensboro Municipal Utilities	Thomas T Lyons	Negative	
3	Pacific Gas and Electric Company	John H Hagen	Affirmative	
3	PacifiCorp	Dan Zollner	Affirmative	
3	Platte River Power Authority	Terry L Baker	Affirmative	
3	PNM Resources	Michael Mertz		
3	Potomac Electric Power Co.	Robert Reuter	Abstain	
3	Progress Energy Carolinas	Sam Waters	Negative	<a href="#">View</a>
3	Public Service Electric and Gas Co.	Jeffrey Mueller	Abstain	
3	Public Utility District No. 1 of Clallam County	David Proebstel	Affirmative	
3	Puget Sound Energy, Inc.	Erin Apperson	Affirmative	
3	Rutherford EMC	Thomas M Haire	Affirmative	
3	Sacramento Municipal Utility District	James Leigh-Kendall	Negative	
3	Salt River Project	John T. Underhill	Negative	<a href="#">View</a>
3	Santee Cooper	James M Poston	Negative	<a href="#">View</a>
3	Seattle City Light	Dana Wheelock	Negative	<a href="#">View</a>
3	Seminole Electric Cooperative, Inc.	James R Frauen		
3	Snohomish County PUD No. 1	Mark Oens	Negative	<a href="#">View</a>
3	South Carolina Electric & Gas Co.	Hubert C Young	Abstain	
3	Southern Maryland Electric Coop.	Mark R Jones	Affirmative	
3	Tacoma Public Utilities	Travis Metcalfe	Affirmative	
3	Tampa Electric Co.	Ronald L Donahey	Negative	
3	Tennessee Valley Authority	Ian S Grant		
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative	
3	Westar Energy	Bo Jones	Abstain	



3	Xcel Energy, Inc.	Michael Ibold		
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative	
4	American Municipal Power	Kevin Koloini	Negative	
4	Arkansas Electric Cooperative Corporation	Ronnie Frizzell	Affirmative	
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative	
4	Central Lincoln PUD	Shamus J Gamache	Negative	<a href="#">View</a>
4	City of Austin dba Austin Energy	Reza Ebrahimian	Negative	<a href="#">View</a>
4	City of Clewiston	Kevin McCarthy		
4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	Negative	
4	City of Redding	Nicholas Zettel	Negative	<a href="#">View</a>
4	City Utilities of Springfield, Missouri	John Allen	Affirmative	<a href="#">View</a>
4	Consumers Energy	David Frank Ronk	Negative	
4	Cowlitz County PUD	Rick Syring	Negative	<a href="#">View</a>
4	Detroit Edison Company	Daniel Herring	Affirmative	
4	Flathead Electric Cooperative	Russ Schneider	Negative	
4	Florida Municipal Power Agency	Frank Gaffney	Negative	<a href="#">View</a>
4	Fort Pierce Utilities Authority	Thomas Richards	Abstain	
4	Georgia System Operations Corporation	Guy Andrews	Negative	<a href="#">View</a>
4	Illinois Municipal Electric Agency	Bob C. Thomas	Abstain	
4	Imperial Irrigation District	Diana U Torres	Affirmative	
4	Indiana Municipal Power Agency	Jack Alvey	Abstain	
4	Integrus Energy Group, Inc.	Christopher Plante		
4	LaGen	Richard Comeaux		
4	Madison Gas and Electric Co.	Joseph DePoorter	Affirmative	
4	Northern California Power Agency	Tracy R Bibb	Affirmative	
4	Ohio Edison Company	Douglas Hohlbaugh	Negative	<a href="#">View</a>
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative	
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Abstain	
4	Sacramento Municipal Utility District	Mike Ramirez	Negative	
4	Seattle City Light	Hao Li	Negative	<a href="#">View</a>
4	South Mississippi Electric Power Association	Steven McElhaney		
4	Tacoma Public Utilities	Keith Morisette	Affirmative	
4	Wisconsin Energy Corp.	Anthony Jankowski	Affirmative	
5	AEP Service Corp.	Brock Ondayko		
5	AES Corporation	Leo Bernier	Affirmative	
5	Amerenue	Sam Dwyer	Negative	
5	Arizona Public Service Co.	Edward Cambridge	Abstain	
5	Avista Corp.	Edward F. Groce	Negative	<a href="#">View</a>
5	BC Hydro and Power Authority	Clement Ma	Abstain	
5	Black Hills Corp	George Tatar	Affirmative	
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla		
5	Bonneville Power Administration	Francis J. Halpin	Affirmative	

5	BrightSource Energy, Inc.	Chifong Thomas	Affirmative	
5	Caithness Long Island, LLC	Jason M Moore	Abstain	
5	Chelan County Public Utility District #1	John Yale	Abstain	
5	City and County of San Francisco	Daniel Mason	Abstain	
5	City of Austin dba Austin Energy	Jeanie Doty	Negative	<a href="#">View</a>
5	City of Redding	Paul Cummings	Negative	<a href="#">View</a>
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick	Affirmative	
5	City of Tallahassee	Brian Horton		
5	City Water, Light & Power of Springfield	Steve Rose		
5	Cleco Power	Stephanie Huffman	Abstain	<a href="#">View</a>
5	Cogentrix Energy, Inc.	Mike D Hirst	Affirmative	
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative	
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Negative	<a href="#">View</a>
5	Constellation Power Source Generation, Inc.	Amir Y Hammad	Abstain	
5	Consumers Energy Company	David C Greyerbiehl	Abstain	
5	Cowlitz County PUD	Bob Essex	Negative	<a href="#">View</a>
5	CPS Energy	Robert Stevens	Affirmative	
5	Detroit Edison Company	Christy Wicke	Affirmative	
5	Dominion Resources, Inc.	Mike Garton	Abstain	
5	Duke Energy	Dale Q Goodwine	Negative	<a href="#">View</a>
5	Dynegy Inc.	Dan Roethemeyer	Negative	<a href="#">View</a>
5	E.ON Climate & Renewables North America, LLC	Dana Showalter		
5	Edison Mission Energy	Ellen Oswald		
5	Electric Power Supply Association	John R Cashin		
5	Exelon Nuclear	Michael Korchynsky	Negative	
5	ExxonMobil Research and Engineering	Martin Kaufman	Negative	
5	FirstEnergy Solutions	Kenneth Dresner		
5	Florida Municipal Power Agency	David Schumann	Negative	<a href="#">View</a>
5	Gainesville Regional Utilities	Karen C Alford	Abstain	
5	Great River Energy	Preston L Walsh	Affirmative	<a href="#">View</a>
5	Green Country Energy	Greg Froehling	Affirmative	
5	Imperial Irrigation District	Marcela Y Caballero	Affirmative	
5	Indeck Energy Services, Inc.	Rex A Roehl		
5	JEA	John J Babik	Affirmative	
5	Kissimmee Utility Authority	Mike Blough	Negative	
5	Lakeland Electric	James M Howard	Negative	
5	Liberty Electric Power LLC	Daniel Duff	Negative	
5	Lincoln Electric System	Dennis Florom	Affirmative	
5	Los Angeles Department of Water & Power	Kenneth Silver	Negative	
5	Lower Colorado River Authority	Tom Foreman	Affirmative	
5	Luminant Generation Company LLC	Mike Laney	Negative	<a href="#">View</a>
5	Manitoba Hydro	S N Fernando	Affirmative	

5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Abstain	
5	MEAG Power	Steven Grego	Abstain	
5	MidAmerican Energy Co.	Christopher Schneider	Negative	<a href="#">View</a>
5	Muscatine Power & Water	Mike Avesing	Affirmative	
5	Nebraska Public Power District	Don Schmit	Abstain	
5	New York Power Authority	Gerald Mannarino	Negative	
5	NextEra Energy	Allen D Schriver	Negative	
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Affirmative	
5	Northern California Power Agency	Hari Modi	Affirmative	
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative	
5	Occidental Chemical	Michelle R DAntuono	Affirmative	<a href="#">View</a>
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative	
5	Orlando Utilities Commission	Richard Kinas		
5	Pacific Gas and Electric Company	Richard J. Padilla	Affirmative	
5	PacifiCorp	Sandra L. Shaffer	Abstain	
5	Platte River Power Authority	Roland Thiel	Affirmative	
5	Portland General Electric Co.	Gary L Tingley	Affirmative	
5	PowerSouth Energy Cooperative	Tim Hattaway	Negative	
5	PPL Generation LLC	Annette M Bannon	Negative	<a href="#">View</a>
5	Progress Energy Carolinas	Wayne Lewis	Negative	
5	PSEG Fossil LLC	Tim Kucey	Abstain	
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative	
5	Puget Sound Energy, Inc.	Tom Flynn		
5	Sacramento Municipal Utility District	Bethany Hunter	Negative	
5	Salt River Project	William Alkema	Negative	
5	Santee Cooper	Lewis P Pierce	Negative	<a href="#">View</a>
5	Seattle City Light	Michael J. Haynes	Negative	
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins		
5	Siemens PTI	Edwin Cano	Affirmative	
5	Snohomish County PUD No. 1	Sam Nietfeld	Negative	<a href="#">View</a>
5	South Mississippi Electric Power Association	Jerry W Johnson		
5	Southern California Edison Co.	Denise Yaffe	Negative	<a href="#">View</a>
5	Southern Company Generation	William D Shultz	Negative	
5	Tampa Electric Co.	RJames Rocha	Negative	
5	Tenaska, Inc.	Scott M Helyer	Affirmative	
5	Tennessee Valley Authority	David Thompson	Abstain	
5	Tri-State G & T Association, Inc.	Barry Ingold	Affirmative	
5	U.S. Army Corps of Engineers	Melissa Kurtz	Affirmative	
5	Vandolah Power Company L.L.C.	Douglas A. Jensen		
5	Xcel Energy, Inc.	Liam Noailles		
6	ACES Power Marketing	Jason L Marshall	Affirmative	
6	AEP Marketing	Edward P. Cox	Negative	<a href="#">View</a>
6	Ameren Energy Marketing Co.	Jennifer Richardson	Negative	
6	APS	RANDY A YOUNG	Affirmative	

6	Arkansas Electric Cooperative Corporation	Keith Sugg	Affirmative	
6	Bonneville Power Administration	Brenda S. Anderson	Affirmative	
6	City of Austin dba Austin Energy	Lisa L Martin	Abstain	
6	City of Redding	Marvin Briggs	Negative	<a href="#">View</a>
6	Cleco Power LLC	Robert Hirchak	Abstain	<a href="#">View</a>
6	Colorado Springs Utilities	Lisa C Rosintoski	Affirmative	
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Negative	<a href="#">View</a>
6	Constellation Energy Commodities Group	Brenda Powell	Negative	
6	Dominion Resources, Inc.	Louis S. Slade	Abstain	
6	Duke Energy Carolina	Walter Yeager	Negative	<a href="#">View</a>
6	Entergy Services, Inc.	Terri F Benoit	Negative	
6	Exelon Power Team	Pulin Shah	Negative	<a href="#">View</a>
6	FirstEnergy Solutions	Kevin Querry	Negative	<a href="#">View</a>
6	Florida Municipal Power Agency	Richard L. Montgomery	Negative	<a href="#">View</a>
6	Florida Municipal Power Pool	Thomas Washburn	Negative	<a href="#">View</a>
6	Florida Power & Light Co.	Silvia P. Mitchell	Abstain	
6	Imperial Irrigation District	Cathy Bretz	Affirmative	
6	Kansas City Power & Light Co.	Jessica L Klinghoffer	Negative	<a href="#">View</a>
6	Lakeland Electric	Paul Shipps	Negative	<a href="#">View</a>
6	Lincoln Electric System	Eric Ruskamp	Affirmative	
6	Los Angeles Department of Water & Power	Brad Packer	Negative	
6	Luminant Energy	Brad Jones	Negative	<a href="#">View</a>
6	Manitoba Hydro	Daniel Prowse	Affirmative	
6	MidAmerican Energy Co.	Dennis Kimm	Negative	
6	New York Power Authority	William Palazzo	Negative	
6	North Carolina Municipal Power Agency #1	Matthew Schull		
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative	
6	Omaha Public Power District	David Ried	Affirmative	
6	Orlando Utilities Commission	Claston Augustus Sunanon	Negative	
6	PacifiCorp	Scott L Smith	Abstain	
6	Platte River Power Authority	Carol Ballantine	Affirmative	
6	PPL EnergyPlus LLC	Mark A Heimbach	Negative	<a href="#">View</a>
6	Progress Energy	John T Sturgeon	Negative	
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Abstain	
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen	Abstain	
6	Sacramento Municipal Utility District	Diane Enderby	Negative	
6	Salt River Project	Steven J Hulet	Negative	
6	Santee Cooper	Michael Brown	Negative	<a href="#">View</a>
6	Seattle City Light	Dennis Sismaet	Negative	<a href="#">View</a>
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak		
6	Snohomish County PUD No. 1	William T Moojen	Abstain	
6	South California Edison Company	Lujuanna Medina	Negative	
6	Southern Company Generation and	John J. Ciza	Negative	<a href="#">View</a>

	Energy Marketing			
6	Tacoma Public Utilities	Michael C Hill	Affirmative	
6	Tampa Electric Co.	Benjamin F Smith II		
6	Tennessee Valley Authority	Marjorie S. Parsons	Abstain	
6	Westar Energy	Grant L Wilkerson	Abstain	
6	Western Area Power Administration - UGP Marketing	Peter H Kinney		
6	Xcel Energy, Inc.	David F. Lemmons		
8		Roger C Zaklukiewicz		
8		Edward C Stein	Affirmative	
8		James A Maenner	Negative	
8	APX	Michael Johnson	Affirmative	
8	JDRJC Associates	Jim Cyrulewski	Abstain	
8	Power Energy Group LLC	Peggy Abbadini	Abstain	
8	Utility Services, Inc.	Brian Evans-Mongeon	Abstain	
8	Volkman Consulting, Inc.	Terry Volkman	Affirmative	
9	California Energy Commission	William M Chamberlain		
9	Central Lincoln PUD	Bruce Lovelin	Negative	<a href="#">View</a>
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	Negative	
10	Midwest Reliability Organization	James D Burley	Affirmative	
10	New York State Reliability Council	Alan Adamson	Affirmative	
10	Northeast Power Coordinating Council	Guy V. Zito	Negative	<a href="#">View</a>
10	ReliabilityFirst Corporation	Anthony E Jablonski	Negative	<a href="#">View</a>
10	SERC Reliability Corporation	Carter B. Edge	Abstain	
10	Southwest Power Pool RE	Emily Pannel	Affirmative	
10	Texas Reliability Entity, Inc.	Donald G Jones	Affirmative	<a href="#">View</a>
10	Western Electricity Coordinating Council	Steven L. Rueckert	Affirmative	

# Consideration of Comments

## Disturbance and Sabotage Reporting (Project 2009-01)

The Disturbance and Sabotage Reporting Drafting Team thanks all commenters who submitted comments on the second formal posting for Project 2009-01—Disturbance and Sabotage Reporting. The standard was posted for a 45-day public comment period from October 28, 2011 through December 12, 2011 and included an initial ballot during the last 10 days of the comment period. Stakeholders were asked to provide feedback on the standard and associated documents through a special electronic comment form. There were 76 sets of comments, including comments from approximately 171 different people from approximately 140 companies representing nine of the ten Industry Segments as shown in the table on the following pages.

All comments submitted may be reviewed in their original format on the standard's project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President of Standards and Training, Herb Schrayshuen, at 404-446-2560 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

### Summary Consideration

EOP-004-2 was posted for a 45-day formal comment period and initial ballot from October 28-December 12, 2011. The DSR SDT received comments from stakeholders to improve the readability and clarity of the requirements of the standard. The revisions that were made to the standard are summarized in the following paragraphs.

#### Purpose Statement

The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:

“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”

<sup>1</sup> The appeals process is in the Standard Processes Manual  
[http://www.nerc.com/files/Appendix\\_3A\\_Standard\\_Processes\\_Manual\\_Rev%201\\_20110825.pdf](http://www.nerc.com/files/Appendix_3A_Standard_Processes_Manual_Rev%201_20110825.pdf)

### Operating Plan

Based on stakeholder comments, Requirement R1 was revised for clarity. Part 1.1 was revised to replace the word “identifying” with “recognizing” and Part 1.2 was eliminated. This also aligns the language of the standard with FERC Order 693, Paragraph 471.

“(2) specify baseline requirements regarding what issues should be addressed in the **procedures for recognizing** {emphasis added} sabotage events and making personnel aware of such events;”

Requirement R1, Part 1.3 (now Part 1.2) was revised by eliminating the phrase “as appropriate” and adding language indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:

“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”

The SDT envisions that most entities will only need to slightly modify their existing CIP-001 Sabotage Reporting procedures to comply with the Operating Plan requirement in this proposed standard. As many of the features of both sabotage reporting procedures and the Operating Plan are substantially similar, the SDT feels that some information in the sabotage reporting procedures may need to be updated and verified.

### Operating Plan Review and Communications Testing

Requirement R1, Part 1.4 was removed and Requirement 1, Part, 1.5 was separated out as new Requirement 4. Requirement R4 was revised and is now R3. FERC Order 693, Paragraph 466 includes provisions for periodic review and update of the Operating Plan:

“466. The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”

Requirement R3 requires an annual test of the communication portion of Requirement R1 while Requirement R4 requires an annual review of the Operating Plan.:

“R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.”

“R4. Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1.”

The DSR SDT envisions that the annual test will include verification that communication information contained in the Operating Plan is correct. As an example, the annual update of the Operating Plan could include calling “others as defined in the Responsibility Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator.

#### Operating Plan Implementation

Most stakeholders indicated that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:

“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”

#### Reporting Timelines

The DSR SDT received many comments regarding the various entries of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments; those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is “A reportable Cyber Security Incident” as it is required by CIP-008 and FERC Order 706, Paragraph 673:



“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”

The table was reformatted to separate one hour reporting and 24 hour reporting. The last column of the table was also deleted and the information contained in the table was transferred to the sentence above each table. These sentences are:

“One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event.”

“Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event.”

Note that the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.

### Cyber-Related Events

The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1. Stakeholders pointed out these events are adequately addressed through the CIP-008 and “Damage or Destruction of a Facility” reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:

“Any malicious act or suspicious event that:

- Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,
- Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”

A Critical Asset is defined as:

“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”

Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.

### Damage or Destruction

The event for “Destruction of BES equipment” has been revised to “Damage or destruction of a Facility”. The threshold for reporting information was expanded for clarity:

“Damage or destruction of a Facility that: affects an IROL  
OR  
Results in the need for actions to avoid an Adverse Reliability Impact  
OR  
Results from intentional human action.”

### Facility Definition

The DSR SDT used the defined term “Facility” to add clarity for this event as well as other events in Attachment 1. A Facility is defined as:

“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”

The DSR SDT did not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

### Physical Threats

Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “Any physical threat that could impact the operability of a Facility”.

Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.

The footnote regarding this event type was expanded to provide additional guidance in:

“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also, report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”

#### Use of DOE OE-417

The DSR SDT received many comments requesting consistency with DOE OE-417 thresholds and timelines. These items, as well as, the Events Analysis Working Group’s (EAWG) requirements were considered in creating Attachment 1, but differences remain for the following reasons:

- EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’
- OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America
- NERC has no control over the criteria in OE-417, which can change at any time
- Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary

In an effort to minimize administrative burden, US entities may use the OE-417 form rather than Attachment 2 to report under EOP-004. The SDT was informed by the DOE of its new online process coming later this year. In this process, entities may be able to record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses, thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.

#### Miscellaneous

Other minor edits were made to Attachment 1. Several words were capitalized but not defined terms. The DSR SDT did not intend for these terms to be capitalized (defined terms) and these words were reverted to lower case. The event type “Loss of monitoring or all voice communication capability” was divided into two separate events as “Loss of monitoring capability” and “Loss of all voice communication capability”.

Attachment 2 was updated to reflect the revisions to Attachment 1. The reference to “actual or potential events” was removed. Also, the event type of “other” and “fuel supply emergency” was removed as well.

It was noted that ‘Transmission Facilities’ is not a defined term in the NERC Glossary. Transmission and Facilities are separately defined terms. The combination of these two definitions are what the DSR SDT has based the applicability of “Transmission Facilities” in Attachment 1.

**Index to Questions, Comments, and Responses**

1. The DSR SDT has revised EOP-004-2 to remove the training requirement R4 based on stakeholder comments from the second formal posting. Do you agree this revision? If not, please explain in the comment area below..... 18
2. The DSR SDT includes two requirement regarding implementation of the Operating Plan specified in Requirement R1. The previous version of the standard had a requirement to implement the Operating plan as well as a requirement to report events. The two requirements R2 and R3 were written to delineate implementation of the Parts of R1. Do you agree with these revisions? If not, please explain in the comment area below..... 42
  - R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.
  - R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.
3. The DSR SDT revised reporting times for many events listed in Attachment 1 from one hour to 24 hours. Do you agree with these revisions? If not, please explain in the comment area below..... 79
4. Do you have any other comment, not expressed in the questions above, for the DSR SDT?.....156

**The Industry Segments are:**

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	Gerald Beckerle	SERC OC Standards Review Group	X		X								
Additional Member		Additional Organization		Region	Segment Selection									
1.	Charlie Cook	TVA			5, 6, 1, 3									
2.	Jake Miller	Dynegy	SERC		5									
3.	Joel Wise	TVA	SERC		1, 3, 5, 6									
4.	Tim Hattaway	PowerSouth	SERC		1, 5									
5.	Robert Thomasson	BREC	SERC		1									
6.	Shaun Anders	CWLP	SERC		1, 3									
7.	Jim Case	Entergy	SERC		1, 3, 6									
8.	Tim Lyons	OMU	SERC		3, 5									
9.	Len Sandberg	Dominion Virginia Power	SERC		1, 3, 5, 6									
10.	Brad Young	LGE-KU	SERC		3									

Group/Individual	Commenter	Organization	Registered Ballot Body Segment												
			1	2	3	4	5	6	7	8	9	10			
11. Larry Akens	TVA	SERC	1, 3, 5, 6												
12. Mike Hirst	Cogentrix	SERC	5												
13. Wayne Van Liere	LGE-KU	SERC	3												
14. Scott Brame	NCEMC	SERC	1, 3, 4, 5												
15. Steve Corbin	SERC Reliability Corp.	SERC	10												
16. John Johnson	SERC Reliability Corp.	SERC	10												
17. John Troha	SERC Reliability Corp.	SERC	10												
2.	Group	Guy Zito	Northeast Power Coordinating Council												X
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment</b>											
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10											
2.	Greg Campoli	New York Independent System Operator	NPCC	2											
3.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1											
4.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1											
5.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10											
6.	Ben Wu	Orange and Rockland Utilities	NPCC	1											
7.	Peter Yost	Consolidated Edison co. of New York, Inc.	NPCC	3											
8.	Kathleen Goodman	ISO - New England	NPCC	2											
9.	Chantel Haswell	FPL Group, Inc.	NPCC	5											
10.	David Kiguel	Hydro One Networks Inc.	NPCC	1											
11.	Michael R. Lombardi	Northeast Utilities	NPCC	1											
12.	Randy Macdonald	New Brunswick Power Transmission	NPCC	9											
13.	Bruce Metruck	New York Power Authority	NPCC	6											
14.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10											
15.	Robert Pellegrini	The United Illuminating Company	NPCC	1											
16.	Si-Truc Phan	Hydro-Quebec TransEnergie	NPCC	1											
17.	David Ramkalawan	Ontario Power Generation, Inc.	NPCC	5											
18.	Saurabh Saksena	National Grid	NPCC	1											
19.	Michael Schiavone	National Grid	NPCC	1											
20.	Wayne Sipperly	New York Power Authority	NPCC	5											
21.	Tina Teng	Independent Electricity System Operator	NPCC	2											
22.	Donald Weaver	New Brunswick System Operator	NPCC	2											

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
3.	Group	Steve Alexanderson	Pacific Northwest Small Public Power Utility Comment Group			X	X					X	
Additional Member		Additional Organization	Region	Segment Selection									
1.	Russell A. Noble	Cowlitz County PUD No. 1	WECC	3, 4, 5									
2.	Ronald Sporseen	Blachly-Lane Electric Cooperative	WECC	3									
3.	Ronald Sporseen	Central Electric Cooperative	WECC	3									
4.	Ronald Sporseen	Consumers Power	WECC	1, 3									
5.	Ronald Sporseen	Clearwater Power Company	WECC	3									
6.	Ronald Sporseen	Douglas Electric Cooperative	WECC	3									
7.	Ronald Sporseen	Fall River Rural Electric Cooperative	WECC	3									
8.	Ronald Sporseen	Northern Lights	WECC	3									
9.	Ronald Sporseen	Lane Electric Cooperative	WECC	3									
10.	Ronald Sporseen	Lincoln Electric Cooperative	WECC	3									
11.	Ronald Sporseen	Raft River Rural Electric Cooperative	WECC	3									
12.	Ronald Sporseen	Lost River Electric Cooperative	WECC	3									
13.	Ronald Sporseen	Salmon River Electric Cooperative	WECC	3									
14.	Ronald Sporseen	Umatilla Electric Cooperative	WECC	3									
15.	Ronald Sporseen	Coos-Curry Electric Cooperative	WECC	3									
16.	Ronald Sporseen	West Oregon Electric Cooperative	WECC	3									
17.	Ronald Sporseen	Pacific Northwest Generating Cooperative	WECC	3, 4, 8									
18.	Ronald Sporseen	Power Resources Cooperative	WECC	5									
4.	Group	Emily Pannel	Southwest Power Pool Regional Entity										X
Additional Member		Additional Organization	Region	Segment Selection									
1.	John Allen	City Utilities of Springfield	SPP	1, 4									
2.	Clem Cassmeyer	Western Farmer's Electric Cooperative	SPP	1, 3, 5									
3.	Michelle Corley	Cleco Power	SPP	1, 3, 5									
4.	Kevin Emery	Carthage Water and Electric Plant	SPP	NA									
5.	Jonathan Hayes	Southwest Power Pool	SPP	2									
6.	Philip Huff	Arkansas Electric Cooperative Corporation	SPP	3, 4, 5, 6									
7.	Ashley Stringer	Oklahoma Municipal Power Authority	SPP	4									
5.	Group	Patricia Robertson	BC Hydro	X	X	X		X					

Group/Individual	Commenter	Organization	Registered Ballot Body Segment									
			1	2	3	4	5	6	7	8	9	10
<b>Additional Member Additional Organization Region Segment Selection</b>												
1.	Patricia Robertson	BC Hydro	WECC	1								
2.	Rama Vinnakota	BC Hydro	WECC	2								
3.	Pat Harrington	BC Hydro	WECC	3								
4.	Clement Ma	BC Hydro	WECC	5								
5.	Daniel O'Hearn	BC Hydro	WECC	6								
6.	Group	Mary Jo Cooper	ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi			X						X
<b>Additional Member Additional Organization Region Segment Selection</b>												
1.	Elizabeth Kirkley	City of Lodi	WECC	3								
2.	Colin Murphey	City of Ukiah	WECC	3								
3.	Douglas Draeger	Alameda Municipal Power	WECC	3								
4.	Ken Dizes	Salmen River Electric Coop	WECC	3								
7.	Group	WILL SMITH	MRO NSRF									
<b>Additional Member Additional Organization Region Segment Selection</b>												
1.	MAHMOOD SAFI	OPPD	MRO	1, 3, 5, 6								
2.	CHUCK LAWRENCE	ATC	MRO	1								
3.	TOM WEBB	WPS	MRO	3, 4, 5, 6								
4.	JODI JENSON	WAPA	MRO	1, 6								
5.	KEN GOLDSMITH	ALTW	MRO	4								
6.	ALICE IRELAND	NSP (XCEL)	MRO	1, 3, 5, 6								
7.	DAVE RUDOLPH	BEPC	MRO	1, 3, 5, 6								
8.	ERIC RUSKAMP	LES	MRO	1, 3, 5, 6								
9.	JOE DEPOORTER	MGE	MRO	3, 4, 5, 6								
10.	SCOTT NICKELS	RPU	MRO	4								
11.	TERRY HARBOUR	MEC	MRO	1, 3, 5, 6								
12.	MARIE KNOX	MISO	MRO	2								
13.	LEE KITTELSON	OTP	MRO	1, 3, 4, 5								
14.	SCOTT BOS	MPW	MRO	1, 3, 5, 6								
15.	TONY EDDLEMAN	NPPD	MRO	1, 3, 5								



Group/Individual	Commenter	Organization	Registered Ballot Body Segment																																									
			1	2	3	4	5	6	7	8	9	10																																
16. MIKE BRYTOWSKI	GRE	MRO	1, 3, 5, 6																																									
17. RICHARD BURT	MPC	MRO	1, 3, 5, 6																																									
8.	Group	Steve Rueckert	Western Electricity Coordinating Council																																									
No Additional members listed.																																												
9.	Group	Jesus Sammy Alcaraz	Imperial Irrigation District																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Tino Zaragoza</td> <td>IID</td> <td>WECC</td> <td>1</td> </tr> <tr> <td>2. Jesus Sammy Alcaraz</td> <td>IID</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>3. Diana Torres</td> <td>IID</td> <td>WECC</td> <td>4</td> </tr> <tr> <td>4. Marcela Caballero</td> <td>IID</td> <td>WECC</td> <td>5</td> </tr> <tr> <td>5. Cathy Bretz</td> <td>IID</td> <td>WECC</td> <td>6</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Tino Zaragoza	IID	WECC	1	2. Jesus Sammy Alcaraz	IID	WECC	3	3. Diana Torres	IID	WECC	4	4. Marcela Caballero	IID	WECC	5	5. Cathy Bretz	IID	WECC	6								
Additional Member	Additional Organization	Region	Segment Selection																																									
1. Tino Zaragoza	IID	WECC	1																																									
2. Jesus Sammy Alcaraz	IID	WECC	3																																									
3. Diana Torres	IID	WECC	4																																									
4. Marcela Caballero	IID	WECC	5																																									
5. Cathy Bretz	IID	WECC	6																																									
10.	Group	Jean Nitz	ACES Power Marketing Standards Collaborators																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Chris Bradley</td> <td>Big Rivers Electric Corporation</td> <td>SERC</td> <td>1</td> </tr> <tr> <td>2. Erin Woods</td> <td>East Kentucky Power Cooperative</td> <td>SERC</td> <td>1, 3, 5</td> </tr> <tr> <td>3. Susan Sosbe</td> <td>Wabash Valley Power Association</td> <td>RFC</td> <td>3</td> </tr> <tr> <td>4. Scott Brame</td> <td>North Carolina Electric Membership Corporation</td> <td>RFC</td> <td>5, 1, 3, 4</td> </tr> <tr> <td>5. Shari Heino</td> <td>Brazos Electric Power Cooperative, Inc.</td> <td>ERCOT</td> <td>1</td> </tr> <tr> <td>6. Lindsay Shepard</td> <td>Western Farmers Electric Cooperative</td> <td>SPP</td> <td>1, 5</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Chris Bradley	Big Rivers Electric Corporation	SERC	1	2. Erin Woods	East Kentucky Power Cooperative	SERC	1, 3, 5	3. Susan Sosbe	Wabash Valley Power Association	RFC	3	4. Scott Brame	North Carolina Electric Membership Corporation	RFC	5, 1, 3, 4	5. Shari Heino	Brazos Electric Power Cooperative, Inc.	ERCOT	1	6. Lindsay Shepard	Western Farmers Electric Cooperative	SPP	1, 5				
Additional Member	Additional Organization	Region	Segment Selection																																									
1. Chris Bradley	Big Rivers Electric Corporation	SERC	1																																									
2. Erin Woods	East Kentucky Power Cooperative	SERC	1, 3, 5																																									
3. Susan Sosbe	Wabash Valley Power Association	RFC	3																																									
4. Scott Brame	North Carolina Electric Membership Corporation	RFC	5, 1, 3, 4																																									
5. Shari Heino	Brazos Electric Power Cooperative, Inc.	ERCOT	1																																									
6. Lindsay Shepard	Western Farmers Electric Cooperative	SPP	1, 5																																									
11.	Group	Frank Gaffney	Florida Municipal Power Agency																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Timothy Beyrle</td> <td>City of New Smyrna Beach</td> <td>FRCC</td> <td>4</td> </tr> <tr> <td>2. Greg Woessner</td> <td>KissimmeeUtility Authority</td> <td>FRCC</td> <td>3</td> </tr> <tr> <td>3. Jim Howard</td> <td>Lakeland Electric</td> <td>FRCC</td> <td>3</td> </tr> <tr> <td>4. Lynne Mila</td> <td>City of Clewiston</td> <td>FRCC</td> <td>3</td> </tr> <tr> <td>5. Joe Stonecipher</td> <td>Beaches Energy Services</td> <td>FRCC</td> <td>1</td> </tr> <tr> <td>6. Cairo Vanegas</td> <td>Fort Pierce Utility Authority</td> <td>FRCC</td> <td>4</td> </tr> <tr> <td>7. Randy Hahn</td> <td>Ocala Utility Services</td> <td>FRCC</td> <td>3</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Timothy Beyrle	City of New Smyrna Beach	FRCC	4	2. Greg Woessner	KissimmeeUtility Authority	FRCC	3	3. Jim Howard	Lakeland Electric	FRCC	3	4. Lynne Mila	City of Clewiston	FRCC	3	5. Joe Stonecipher	Beaches Energy Services	FRCC	1	6. Cairo Vanegas	Fort Pierce Utility Authority	FRCC	4	7. Randy Hahn	Ocala Utility Services	FRCC	3
Additional Member	Additional Organization	Region	Segment Selection																																									
1. Timothy Beyrle	City of New Smyrna Beach	FRCC	4																																									
2. Greg Woessner	KissimmeeUtility Authority	FRCC	3																																									
3. Jim Howard	Lakeland Electric	FRCC	3																																									
4. Lynne Mila	City of Clewiston	FRCC	3																																									
5. Joe Stonecipher	Beaches Energy Services	FRCC	1																																									
6. Cairo Vanegas	Fort Pierce Utility Authority	FRCC	4																																									
7. Randy Hahn	Ocala Utility Services	FRCC	3																																									
12.	Group	Terry L. Blackwell	Santee Cooper																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection																												
Additional Member	Additional Organization	Region	Segment Selection																																									

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
1. S. T. Abrams	Santee Cooper	SERC 1												
2. Wayne Ahl	Santee Cooper	SERC 1												
3. Rene Free	Santee Cooper	SERC 1												
13. Group	Joe Tarantino	Sacramento Municipal Utility District (SMUD)	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Kevin Smith	BANC	WECC 1												
14. Group	Robert Rhodes	SPP Standards Review Group		X										
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. John Allen	City Utilities of Springfield	SPP 1, 4												
2. Clem Cassmeyer	Western Farmer's Electric Cooperative	SPP 1, 3, 5												
3. Michelle Corley	Cleco Power	SPP 1, 3, 5												
4. Kevin Emery	Carthage Water and Electric Plant	SPP NA												
5. Jonathan Hayes	Southwest Power Pool	SPP 2												
6. Philip Huff	Arkansas Electric Cooperative Corporation	SPP 3, 4, 5, 6												
7. Ashley Stringer	Oklahoma Municipal Power Authority	SPP 4												
15. Group	Connie Lowe	Dominion	X		X		X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Louis Slade		RFC 3, 6												
2. Michael Crowley		SERC 1, 3												
3. Mike Garton		NPCC 5, 6												
4. Michael Gildea		MRO 5, 6												
16. Group	Sam Ciccone	FirstEnergy	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Doug Hohlbaugh	FE	RFC 1, 3, 4, 5, 6												
2. Larry Raczkowski	FE	RFC 1, 3, 4, 5, 6												
3. Jim Eckels	FE	RFC 1												
4. John Reed	FE	RFC 1												
5. Ken Dresner	FE	RFC 5												
6. Bill Duge	FE	RFC 5												
7. Kevin Querry	FE	RFC 5												

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
17.	Group	Annette M. Bannon	PPL Electric Utilities and PPL Supply Organizations'	X				X	X				
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Brenda Truhe	PPL Electric Utilities	RFC 1										
2.	Annette Bannon	PPL Generation	RFC 5										
3.	Annette Bannon	PPL Generation	WECC 5										
4.	Mark Heimbach	PPL EnergyPlus	MRO 6										
5.	Mark Heimbach	PPL EnergyPlus	NPCC 6										
6.	Mark Heimbach	PPL EnergyPlus	RFC 6										
7.	Mark Heimbach	PPL EnergyPlus	SERC 6										
8.	Mark Heimbach	PPL EnergyPlus	SPP 6										
9.	Mark Heimbach	PPL EnergyPlus	WECC 6										
18.	Group	Tom McElhinney	Electric Compliance	X		X		X					
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Ted Hobson		FRCC 1										
2.	John Babik		FRCC 5										
3.	Garry Baker		3										
19.	Group	Michael Gammon	Kansas City Power & Light	X		X		X	X				
<b>Additional Member Additional Organization Region Segment Selection</b>													
1.	Scott Harris	KCP&L	SPP 1, 3, 5, 6										
2.	Monica Strain	KCP&L	SPP 1, 3, 5, 6										
3.	Brett Holland	KCP&L	SPP 1, 3, 5, 6										
4.	Jennifer Flandermeyer	KCP&L	SPP 1, 3, 5, 6										
20.	Individual	Stewart Rake	Luminant Power					X					
21.	Individual	Sandra Shaffer	PacifiCorp	X		X		X	X				
22.	Individual	Janet Smith, Regulatory Affairs Supervisor	Arizona Public Service Company	X		X		X	X				
23.	Individual	Jim Eckelkamp	Progress Energy	X		X		X	X				
24.	Individual	Silvia Parada Mitchell	Compliance & Responsibility Office	X		X		X	X				
25.	Individual	Antonio Grayson	Southern Company	X		X		X	X				

Group/Individual		Commenter	Organization	Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
26.	Individual	John Brockhan	CenterPoint Energy	X											
27.	Individual	Brenton Lopez	Salt River Project	X		X		X	X						
28.	Individual	Bo Jones	Westar Energy	X		X		X	X						
29.	Individual	Michael Johnson	APX Power Markets (NCR-11034)						X						
30.	Individual	David Proebstel	Clallam County PUD No.1			X									
31.	Individual	Michael Moltane	ITC	X											
32.	Individual	Tracy Richardson	Springfield Utility Board			X									
33.	Individual	Kasia Mihalchuk	Manitoba Hydro	X		X		X	X						
34.	Individual	Kevin Conway	Intellibind									X			
35.	Individual	Chris Higgins / Jim Burns / Ted Snodgrass / Jeff Millenor / Russell Funk	Bonneville Power Administration	X		X		X	X						
36.	Individual	Chris de Graffenried	Consolidated Edison Co. of NY, Inc.	X		X		X	X						
37.	Individual	David Burke	Orange and Rockland Utilities, Inc.	X		X									
38.	Individual	Alice Ireland	Xcel Energy	X		X		X	X						
39.	Individual	Greg Rowland	Duke Energy	X		X		X	X						
40.	Individual	Rodney Luck	Los Angeles Department of Water and Power	X		X		X	X						
41.	Individual	Daniel Duff	Liberty Electric Power					X							
42.	Individual	Lisa Rosintoski	Colorado Springs Utilities	X		X		X	X						
43.	Individual	Michael Falvo	Independent Electricity System Operator		X										
44.	Individual	John Bee on Behalf of Exelon	Exelon	X		X		X							
45.	Individual	John D. Martinsen	Public Utility District No. 1 of Snohomish County												
46.	Individual	RoLynda Shumpert	South Carolina Electric and Gas	X		X		X	X						
47.	Individual	Kathleen Goodman	ISO New England		X										

Group/Individual		Commenter	Organization	Registered Ballot Body Segment																	
				1	2	3	4	5	6	7	8	9	10								
48.	Individual	Curtis Crews	Texas Reliability Entity																		X
49.	Individual	Andrew Z. Pusztai	American Transmission Company, LLC	X																	
50.	Individual	Anthony Jablonski	ReliabilityFirst																		X
51.	Individual	Don Schmit	Nebraska Public Power District	X		X		X													
52.	Individual	Dennis Sismaet	Seattle City Light	X		X	X	X	X												
53.	Individual	John Seelke	PSEG	X		X		X	X												
54.	Individual	Barry Lawson	NRECA																		
55.	Individual	Terry Harbour	MidAmerican Energy	X		X		X													
56.	Individual	Thad Ness	American Electric Power	X		X		X	X												
57.	Individual	Guy Andrews	Georgia System Operations Corporation	X		X	X	X	X												
58.	Individual	Ed Davis	Entergy Services																		
59.	Individual	Margaret McNaul	Thompson Coburn LLP on behalf of Miss. Delta Energy Agency																		
60.	Individual	Bob Thomas	Illinois Municipal Electric Agency				X														
61.	Individual	Kirit Shah	Ameren	X		X		X	X												
62.	Individual	Linda Jacobson-Quinn	FEUS			X															
63.	Individual	Tom Foreman	Lower Colorado River Authority	X		X		X	X												
64.	Individual	Richard Salgo	NV Energy																		
65.	Individual	Nathan Mitchell	American Public Power Association			X															
66.	Individual	Angela Summer	Southwestern Power Administration	X																	
67.	Individual	Michelle R D'Antuono	Ingleside Cogeneration LP					X													
68.	Individual	Tim Soles	Occidental Power Services, Inc. (OPSI)			X			X												
69.	Individual	Michael Lombardi	Northeast Utilities	X		X		X													
70.	Individual	Andrew Gallo	City of Austin dba Austin Energy	X		X	X	X	X												
71.	Individual	James Saucedo	Energy Northwest - Columbia					X													
72.	Individual	Scott Berry	Indiana Municipal Power Agency				X														

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
73.	Individual	Maggy Powell	Constellation Energy on behalf of Baltimore Gas & Electric, Constellation Power Generation, Constellation Energy Commodities Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.	X		X		X	X				
74.	Individual	Michael Brytowski	Great River Energy	X		X		X	X				
75.	Individual	Christine Hasha	Electric Reliability Council of Texas, Inc.		X								
76.	Individual	Darryl Curtis	Oncor Electric Delivery Company LLC	X									

1. The DSR SDT has revised EOP-004-2 to remove the training requirement R4 based on stakeholder comments from the second formal posting. Do you agree this revision? If not, please explain in the comment area below.

**Summary Consideration:** As a result of the industry comments, the SDT has further modified the standard as follows:

- Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom events are communicated.
- Combined relevant parts of Requirement R1, Parts 1.4, 1.5 and Requirement R4 into Requirement 1, Part 1.3.
- Deleted the requirement for drills or exercises
- Clarified that only Registered Entities conduct annual tests of the communication process outlined in Requirement 1, Part 1.2
- Changed the review of the Operating Plan to 'annually'

The DSR SDT envisions the testing under Requirement R1, Part 1.3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsibility Entity’s Operating Plan” (see Part 1.2) to verify their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.

Despite some industry opposition, both the periodic review of the Operating Plan and the testing requirements were maintained to meet the intent of FERC Order 693, Paragraph 466:

“The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”

Organization	Yes or No	Question 1 Comment
Beaches Energy Services, City of	Negative	First, I wish to thank the SDT for their hard work and making significant progress in significant improvements in the standard. I commend the

Organization	Yes or No	Question 1 Comment
Green Cove Springs		<p>direction that the SDT is taking. There are; however, a few unresolved issues that cause me to not support the standard at this time. 1. An issue of possible differences in interpretation between entities and compliance monitoring and enforcement is the phrase in 1.3 that states “the following as appropriate”. Who has the authority to deem what is appropriate? The requirements should be clear that the Responsible Entity is the decision maker of who is appropriate, otherwise there is opportunity for conflict between entities and compliance. <i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan.</i></p> <p>In addition, 1.4 is onerous and burdensome regarding the need to revise the plan within 90 days of “any” change, especially considering the ambiguity of “other circumstances”. “Other circumstances” is open to interpretation and a potential source of conflict.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
New Brunswick Power Transmission Corporation	Negative	<p>It is NBPT’s opinion that because this is a standard associated with reporting events after an occurrence, it is overly burdensome to require drills and exercises for verification purposes as described in R4.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications</i></p>



Organization	Yes or No	Question 1 Comment
		<i>process in Part 1.2.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
United Illuminating Co.	Negative	<p>R4 is not clear what is expected. There is a difference between testing a process that consists of identify an event then select commuication contacts versus needing to test contacts for each event in Attachment 1 and drill each event and document each event drill.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement r3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>In R2 the phrase "as specified" should be replaced or completed, as specified by what.</p> <p><i>The DSR SDT has deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read: “Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004</i></p>

Organization	Yes or No	Question 1 Comment
		<a href="#">Attachment1.</a>
<b>Response: Thank you for your comment. Please see response above.</b>		
City of Farmington	Negative	<p>R4 requires verification through a drill or exercise the communication process created as part of R1.3. Clarification of what a drill or exercise should be considered. In order to show compliance to R4 would the entity have to send a pseudo event report to Internal Personnel, the Regional Entity, NERC ES-ISAC, Law Enforcement, and Governmental or provincial agencies listed in R1.3 to verify the communications plan? It would not be a burden on the entity so much, however, I'm not sure the external parties want to be the recipient of approximately 2000 psuedo event reports annually.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Hydro One Networks, Inc.	Negative	Referring to Requirement R4, the communication process can be verified without having to go through a drill or exercise. Any specific testing or

Organization	Yes or No	Question 1 Comment
		<p>verification of the process is the responsibility of the Responsible Entity.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>Despite some industry opposition, both periodic review of the Operating Plan and the test requirements were maintained to meet the intent of FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ameren Services	Negative	<p>The current language in the parenthesis of R4 suggests that the training requirement was actually not removed, in that "a drill or exercise" constitutes training. As documented in the last sentence of the Summary of Key Concepts section, "The proposed standard deals exclusively with after-the-fact reporting." We feel that training, even if it is called drills or exercises is not necessary for an after-the-fact report.</p> <p><i>Requirement R4 related to an annual test of the communication portion of</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>Despite some industry opposition, both periodic review of the Operating Plan and the test requirements were maintained to meet the intent of FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Liberty Electric Power LLC</p>	<p>Negative</p>	<p>Voting no due to training not being an option to fill the "drill" requirement. The reason for R4 seems to be to assure personnel will respond to an event in accordance with the entity procedure. Entities meet their obligations for other regulatory requirements with training, and should be permitted to do so for R4.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing, Hoosier Energy Rural Electric Cooperative, Inc., Sunflower Electric Power Corporation, Great River Energy</p>	<p>Negative</p>	<p>We appreciate the efforts of the SDT in considering the comments of stakeholders from prior comment periods. We believe this draft is greatly improved over the previous version and we agree with the elimination of the term "sabotage" which is a difficult term to define. The determination of an act of sabotage should be left to the proper law enforcement authorities. However, we also realize that the proper authorities would be hard pressed to make these determinations without reporting from industry when there are threats to BES equipment or facilities. We understand and agree there should be verification of the information required for such reporting (contact information, process flow charts, etc). But we still believe improvements can be made to the draft standard. The use of the words “or through a drill or exercise” in Requirement R4 still implies that training is required if no actual event has occurred. When you conduct a fire “drill” you are training your employees on evacuation routes and who they need to report to. Not only are you verifying your process but you are training your employees as well. It is imperative that the information in the Event</p>

Organization	Yes or No	Question 1 Comment
		<p>Reporting process is correct but we don't agree that performing a drill on the process is necessary. We recommend modifying the requirement to focus on verifying the information needed for appropriate communications on an event. And we agree this should take place at least annually.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>First, we wish to thank the SDT for their hard work and making significant progress in significant improvements in the standard. We commend the direction that the SDT is taking. There are; however, a few unresolved issues that cause us to not support the standard at this time. An issue of possible differences in interpretation between entities and compliance monitoring and enforcement is the phrase in 1.3 that states "the following as appropriate". Who has the authority to deem what is appropriate? The</p>

Organization	Yes or No	Question 1 Comment
		<p>requirements should be clear that the Responsible Entity is the decision maker of who is appropriate, otherwise there is opportunity for conflict between entities and compliance.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan. Part 1.2 now reads: “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>In addition, 1.4 is onerous and burdensome regarding the need to revise the plan within 90 days of “any” change, especially considering the ambiguity of “other circumstances”. “Other circumstances” is open to interpretation and a potential source of conflict.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Illinois Municipal Electric Agency</p>	<p>No</p>	<p>IMEA agrees with the removal of the training requirement, but also believes verification is not a necessary requirement for this standard; therefore, R4 is not necessary and should be removed.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Indiana Municipal Power Agency</p>	<p>No</p>	<p>IMPA does not believe that R4 is necessary. In addition, if a drill or exercise is used to verify the communication process, some of the parties listed in R1.3 may not want to participate in the drill or exercise every 15 months, such as law enforcement and governmental agencies. IMPA would propose a contacting these agencies every 15 months to verify their contact information only and updating their information in the plan as needed, without performing a drill or exercise.</p> <p><i>This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of</i></p>



Organization	Yes or No	Question 1 Comment
		<p><i>FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ISO New England</p>	<p>No</p>	<p>Please see further comments; we do not believe R4 is a necessary requirement in the standard and suggest it be deleted.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>

Organization	Yes or No	Question 1 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Northeast Power Coordinating Council</p>	<p>No</p>	<p>Requirement R4 is unnecessary. Whether or not the process, plan, procedure, etc. is “verified” is of no consequence. EOP standards are intended to have entities prepare for likely events (restoration/evacuation), and to provide tools for similar unforeseen events (ice storms, tornadoes, earthquakes, etc.). They should not force a script when results are what matters.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		

Organization	Yes or No	Question 1 Comment
Southern Company	No	<p>Southern agrees with removing the training requirement of R4 from the previous version of the standard. However, Southern suggests that drills and exercises are also training and R4 in this revised standard should be removed in its entirety</p> <p><i>The “drill or exercise” language has been deleted. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ameren	No	<p>The current language in the parenthesis of R4 suggests that the training requirement was actually not removed, in that "a drill or exercise" constitutes training. As documented in the last sentence of the Summary of</p>

Organization	Yes or No	Question 1 Comment
		<p>Key Concepts section, "The proposed standard deals exclusively with after-the-fact reporting." We feel that training, even if it is called drills or exercises is not necessary for an after-the-fact report.</p> <p><i>The "drill or exercise" language has been deleted. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Liberty Electric Power</p>	<p>No</p>	<p>Training should be left in the standard as an option, along with an actual event, drill or exercise, to demonstrate that operating personnel have knowledge of the procedure.</p> <p><i>The "drill or exercise" language has been deleted. Requirement R4 related</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>	<p>No</p>	<p>We agree with removing the training requirement of R4; however we believe that drills and exercises are also training and R4 should be removed in its entirety because drills and exercises on an after the fact process do not enhance reliability.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1 This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>The testing requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing Standards Collaborators/Great River Energy</p>	<p>No</p>	<p>We understand and agree there should be verification of the information required for such reporting (contact information, process flow charts, etc). But we still believe improvements can be made to the draft standard, in particular to requirement R4. The use of the words “or through a drill or exercise” still implies that training is required if no actual event has occurred. When you conduct a fire “drill” you are training your employees on evacuation routes and who they need to report to. Not only are you verifying your process but you are training your employees as well. It is imperative that the information in the Event Reporting process is correct but we don't agree that performing a drill on the process is necessary. We recommend modifying the requirement to focus on verifying the information needed for appropriate communications on an event. And we agree this should take place at least annually.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. This has</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Ingleside Cogeneration LP</p>	<p>Yes</p>	<p>: Yes. Ingleside Cogeneration LP agrees that training on an incident reporting operations plan should be at the option of the entity. However, we recommend that a statement be included in the “Guideline and Technical Basis” section that encourages drills and exercises be coincident with those conducted for Emergency Operations. Since front-line operators must send out the initial alert that a reportable condition exists, such exercises may help determine how to manage their reporting obligations during the early stages of the troubleshooting process. This is especially true where a notification must be made within an hour of discovery - a very short time period.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has</i></p>

Organization	Yes or No	Question 1 Comment
		<p><i>been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p><i>This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Public Power Association</p>	<p>Yes</p>	<p>APPA agrees that removal of the training requirement was an appropriate revision to limit the burden on small registered entities. However, APPA requests clarification from the SDT on the current draft of R4. If no event occurs during the calendar year, a drill or exercise of the Operating Plan communication process is required. APPA believes that if this drill or exercise is required, then it should be a table top verification of the internal communication process such as verification of phone numbers and stepping through a Registered Entity specific scenario. This should not be a full drill with requirements to contact outside entities such as law enforcement, NERC, the RC or other entities playing out a drill scenario. This full drill would be a major burden for small entities.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has</i></p>



Organization	Yes or No	Question 1 Comment
		<p><i>been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
FirstEnergy	Yes	FirstEnergy supports this removal and thanks the drafting team.
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Compliance & Responsibility Office	Yes	See comments in response to Question 4.
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
NV Energy	Yes	Thank you for responding to the stakeholder comments on this issue.
<p><b>Response: Thank you for your comment.</b></p>		
Constellation Energy on behalf of Baltimore Gas & Electric, Constellation Power Generation, Constellation Energy Commodities	Yes	Yes, we support removal of the training requirement.

Organization	Yes or No	Question 1 Comment
Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.		
<b>Response: Thank you for your comment.</b>		
Pacific Northwest Small Public Power Utility Comment Group	Yes	
Southwest Power Pool Regional Entity	Yes	
BC Hydro	Yes	
ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi	Yes	
MRO NSRF	Yes	
Western Electricity Coordinating Council	Yes	
Imperial Irrigation District	Yes	
Santee Cooper	Yes	
Sacramento Municipal Utility District (SMUD)	Yes	

Organization	Yes or No	Question 1 Comment
SPP Standards Review Group	Yes	
Dominion	Yes	
PPL Electric Utilities and PPL Supply Organizations`	Yes	
Electric Compliance	Yes	
Kansas City Power & Light	Yes	
Luminant Power	Yes	
PacifiCorp	Yes	
Arizona Public Service Company	Yes	
CenterPoint Energy	Yes	
Salt River Project	Yes	
Westar Energy	Yes	
APX Power Markets (NCR-11034)	Yes	
Clallam County PUD No.1	Yes	
ITC	Yes	
Springfield Utility Board	Yes	

Organization	Yes or No	Question 1 Comment
Manitoba Hydro	Yes	
Intellibind	Yes	
Bonneville Power Administration	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Orange and Rockland Utilities, Inc.	Yes	
Xcel Energy	Yes	
Duke Energy	Yes	
Colorado Springs Utilities	Yes	
Independent Electricity System Operator	Yes	
Exelon	Yes	
Public Utility District No. 1 of Snohomish County	Yes	
South Carolina Electric and Gas	Yes	
American Transmission Company, LLC	Yes	
Nebraska Public Power District	Yes	

Organization	Yes or No	Question 1 Comment
Seattle City Light	Yes	
PSEG	Yes	
MidAmerican Energy	Yes	
American Electric Power	Yes	
Georgia System Operations Corporation	Yes	
FEUS	Yes	
Lower Colorado River Authority	Yes	
Southwestern Power Administration	Yes	
Occidental Power Services, Inc. (OPSI)	Yes	
Northeast Utilities	Yes	
City of Austin dba Austin Energy	Yes	
Energy Northwest - Columbia	Yes	
Electric Reliability Council of Texas, Inc.	Yes	
Oncor Electric Delivery Company LLC	Yes	

Organization	Yes or No	Question 1 Comment
Progress Energy		
Los Angeles Department of Water and Power		
Texas Reliability Entity		
ReliabilityFirst		
NRECA		
Entergy Services		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		

2. The DSR SDT includes two requirement regarding implementation of the Operating Plan specified in Requirement R1. The previous version of the standard had a requirement to implement the Operating plan as well as a requirement to report events. The two requirements R2 and R3 were written to delineate implementation of the Parts of R1. Do you agree with these revisions? If not, please explain in the comment area below.

R2. Each Responsible Entity shall implement the parts of its Operating Plan that meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts 1.4 and 1.5 as specified.

R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1.

**Summary Consideration:** Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:

**“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”**

Organization	Yes or No	Question 2 Comment
Ameren Services	Negative	<p>(2) The new wording while well intentioned, effectively does not add clarity and leads to confusion. From our perspective, R1, which requires and Operating Plan, which is defined by the NERC glossary as: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan."</p> <p><i>The DSR SDT thanks you for your comment. The SDT has made changes to the</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>requirements highlighted in your comments.</i></p> <p><i>FERC Order 693, Paragraph 466 includes provisions for periodic review and update of the Operating Plan: “466. The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>(3) Is not a proper location for an after-the-fact reporting standard? In fact it could be argued that after-the-fact reports in and of themselves do not affect the reliability of the bulk electric system.</p> <p><i>The DSR SDT does not agree with this comment. Reporting of an event will give the Electric Reliability Organization and your Reliability Coordinator the situational awareness of what has occurred on your part of the BES. Plus as described in your Operating Plan, you would have communicated the event as you saw fit. By broadcasting that an event has occurred you will increase the awareness of your company (as described in your Operating Plan) and increase the awareness of the Electric Reliability Organization and your Reliability Coordinator.</i></p> <p>(4) But considering the proposed standard as written with the Operating Plan in requirement R1, and implementation of the Operating Plan in requirement R2 (except the actual reporting which is in R3) and then R3 which requires implementing the reporting section R1.3, it is not clear how these requirements can be kept separate in either implementation nor by the CEA.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2). The test and review requirement is</i></p>



Organization	Yes or No	Question 2 Comment
		<p><i>included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>(5) The second sentence in the second paragraph of “Rationale for R1” states: “The main issue is to make sure an entity can a) identify when an event has occurred and b) be able to gather enough information to complete the report.” This is crucial for a Standard like this that is intended to mandate actions for events that are frequently totally unexpected and beyond normal planning criteria. This language needs to be added to Attachment 1 by the DSR SDT as explained in the rest of our comments.</p> <p><i>The DSR SDT has updated the Rationale for Part 1.2 (previous Part 1.3) to read as: “Part 1.2 could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information.” Whereas Part 1.2 now states:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Old Dominion Electric Coop.</p>	<p>Negative</p>	<p>I disagree with two things in the presently drafted standard. First, I do not feel a separate requirement to implement the plan is necessary (R2),</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>and I do not think that verification of the communications process should require a minimum of a drill or exercise. This is verified now under the current standard CIP-001 through verification contact with the appropriate authorities and this should be enough to verify that the communications for the plan is in place.</p> <p><i>The “drill or exercise” language has been removed. Requirement R4 related to an annual test of the communication portion of Requirement 1. This has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing, Hoosier Energy Rural Electric Cooperative, Inc., Sunflower Electric Power Corporation,</p>	<p>Negative</p>	<p>Requirement R2 requires Responsible Entities to implement the various sub-requirements in R1. We believe it is unnecessary to state that an entity must implement their Operating Plan in a separate requirement. Having a separate requirement seems redundant. If the processes in the Operating Plan are not</p>

Organization	Yes or No	Question 2 Comment
<p>Great River Energy/ ACES Power Marketing Standards Collaborators/ Great River Energy</p>		<p>implemented, the entity is non-compliant with the standard.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>There doesn't need to be an extra requirement saying entities need to implement their Operating Plan.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Hydro One Networks, Inc.</p>	<p>Negative</p>	<p>Requirement R2 seems to not be necessary. Who would have a plan and not implement it? This may also introduce double jeopardy issues should some entity not have a plan as required in R1. They would be unable to implement something they did not have so automatically non-compliant with R1 and R2. o Requirements R2 and R3 seem to be redundant. Isn't implementing the Operating Plan the same as reporting events in accordance with its Operating Plan?</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>The standard mentions collecting information for Attachment 2, but the standard does not state what to do with Attachment 2. Is it merely a record for demonstrating compliance with R3?</p> <p><i>The DSR SDT has updated Requirement R2 to read: “Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in Attachment 1.”</i></p> <p><i>The DSR SDT has also added the following statement to Attachment 1 for 1 hour reporting time frame and 24 hour reporting time frame, respectfully:</i></p> <p><i>“One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event”</i></p> <p><i>And</i></p> <p><i>“Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 2 Comment
<p>Beaches Energy Services, City of Green Cove Springs</p>	<p>Negative</p>	<p>Requirements R2 and R3 are to implement the Operating Plan. Hence, R3 should be a bullet under R2 and not a separate requirement. In addition, for R2, the phrase “actual event” is ambiguous and should mean: “actual event that meets the criteria of Attachment 1” I suggest the following wording to R2 (which will result in eliminating R3) “Each Responsible Entity shall implement its Operating Plan: o For actual events meeting the threshold criteria of Attachment 1, in accordance with Requirement R1 parts 1.1, 1.2 and 1.3</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>o For review and updating of the Operating Plan, in accordance with Requirement R1 parts 1.4 and 1.5” Note that I believe that if the SDT decides to not combine R2 and R3, then we disagree with the distinction between the two requirements.</p> <p><i>Requirements R2 and R3 have been combined. Requirement 1, Part 1.4 was removed.</i></p> <p>The division of implementing R1 through R2 and R3 as presented is “implementing” vs. “reporting”. We believe that the correct division should rather be “implementation” of the plan (which includes reporting) vs. revisions to the plan.</p> <p><i>The DSR SDT has updated Requirement R2 to read as: “R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1.”</i></p> <p><i>FERC Order 693 section 617 states “...the Commission directs the ERO to develop a</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>modification to EOP-004-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the Bulk-Power System to provide data...". In order for entities to provide data they are required to implement their Operating Plan.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Ameren</p>	<p>No</p>	<p>(1) The new wording while well intentioned, effectively does not add clarity and leads to confusion. From our perspective, R1, which requires and Operating Plan, which is defined by the NERC glossary as: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan."</p> <p><i>The DSR SDT has maintained Requirement 1 with the wording of "Operating Plan" which gives entities the flexibility of containing an Operating Process or Operating Procedure, as stated as "An Operating Plan may contain Operating Procedures and Operating Processes. Please note the use of "may contain" in the NERC approved definition.</i></p> <p><i>Requirement 1 now reads as"</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the</i></li> </ul>

Organization	Yes or No	Question 2 Comment
		<p><i>Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p>(2) Is not a proper location for an after-the-fact reporting standard? In fact it could be argued that after-the-fact reports in and of themselves do not affect the reliability of the bulk electric system.</p> <p><i>The DSR SDT does not agree with this comment. Reporting of an event will give the Electric Reliability Organization and your Reliability Coordinator the situational awareness of what has occurred on your part of the BES. Plus as described in your Operating Plan, you would have communicated the event as you saw fit. By broadcasting that an event has occurred you will increase the awareness of your company (as described in your Operating Plan) and increase the awareness of the Electric Reliability Organization and your Reliability Coordinator.</i></p> <p>(3) But considering the proposed standard as written with the Operating Plan in requirement R1, and implementation of the Operating Plan in requirement R2 (except the actual reporting which is in R3) and then R3 which requires implementing the reporting section R1.3, it is not clear how these requirements can be kept separate in either implementation nor by the CEA.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2).</i></p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>procedures.”</i></p> <p>(4) The second sentence in the second paragraph of “Rationale for R1” states: “The main issue is to make sure an entity can a) identify when an event has occurred and b) be able to gather enough information to complete the report.” This is crucial for a Standard like this that is intended to mandate actions for events that are frequently totally unexpected and beyond normal planning criteria. This language needs to be added to Attachment 1 by the DSR SDT as explained in the rest of our comments</p> <p><i>The DSR SDT has updated the Rationale for Part 1.2 (previous Part 1.3) to read as: “Part 1.2 could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information.” Whereas Part 1.2 now states:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Electric Power</p>	<p>No</p>	<p>AEP prefers to avoid requirements that are purely administrative in nature. Requirements should be clear in their actions of supporting of the BES. For example, we would prefer requirements which state what is to be expected, and allowing the entities to develop their programs, processes, and procedures accordingly. It has been our understanding that industry, and perhaps NERC as well, seeks to reduce the amount to administrative (i.e. document-based) requirements. We are confident</p>



Organization	Yes or No	Question 2 Comment
		<p>that the appropriate documentation and administrative elements would occur as a natural course of implementing and adhering to action-based requirements. In light of this perspective, we believe that that R1 and R2 is not necessary, and that R3 would be sufficient by itself. Our comments above notwithstanding, AEP strongly encourages the SDT to consider that R2 and R3, if kept, be merged into a single requirement as a violation of R2 would also be a violation of R3. Two violations would then occur for what is essentially only a single incident. Rather than having both R2 and R3, might R3 be sufficient on its own? R2 is simply a means to an end of achieving R3.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2).</i></p> <p>.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>If there is a need to explicitly reference implementation, that could be addressed as part of R1. For example, R1 could state “Each Responsible Entity shall implement an Operating Plan that includes...”R1 seems disjointed, as subparts 1.4 and 1.5 (updating and reviewing the Operating Plan) do not align well with subparts 1.1 through 1.3 which are process related. If 1.4 and 1.5 are indeed needed, we recommend that they be a part of their own requirement(s). Furthermore, the action of these requirements should be changed from emphasizing provision(s) of a process to demonstrating the underlying activity.</p>

Organization	Yes or No	Question 2 Comment
		<p><i>The DSR SDT has maintained Requirement 1 with the wording of “Operating Plan” which gives entities the flexibility of containing an Operating Process or Operating Procedure, as stated as “An Operating Plan may contain Operating Procedures and Operating Processes. Please note the use of “may contain” in the NERC approved definition.</i></p> <p><i>Requirement 1 now reads as “Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p><i>1.4 AEP is concerned by the vagueness of requiring provision(s) for updating the Operating Plan for “changes”, as such changes could occur frequently and unpredictably.</i></p> <p><i>Part 1.4 was removed from the standard.</i></p> <p><i>It is the sole responsibility of the Applicable Entity to determine when an annual review of the Operating Plan is required. The Operating Plan has the minimum requirement for an annual review. You may review your Operating Plan as often as you see appropriate.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Occidental Power Services,	No	Attachment 1 and R3 require event reports to be sent to the ERO and the entity’s RC and to others “as appropriate.” Although this gives the entity some discretion, it

Organization	Yes or No	Question 2 Comment
Inc. (OPSI)		<p>might also create some “Monday morning quarterbacking” situations. This is especially true for the one hour reporting situations as personnel that would be responding to these events are the same ones needed to report the event. OPSI suggests that the SDT reconsider and clarify reporting obligations with the objective of sending initial reports to the minimum number of entities on a need-to-know basis.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan.</i></p> <p><i>The DSR SDT also received many comments regarding the various events of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO and their Reliability Coordinator within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is “A reportable Cyber Security Incident” as it required by CIP-008.</i></p> <p><i>FERC Order 706, paragraph 673 states: “...each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but, in any event within one hour of the event...”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ingleside Cogeneration LP	No	<p>Attachment 1 and requirement R3 are written in a manner which would seem to indicate that internal personnel and law enforcement personnel would have to be copied on the submitted form - either Attachment 2 or OE-417. We believe the intent is to submit such forms to the appropriate recipients only (e.g.; the ERO and</p>

Organization	Yes or No	Question 2 Comment
		<p>the DOE). The requirement should be re-written to clarify that this is the case.</p> <p><i>The DSR SDT thanks you for your comment. Requirement 1 has been updated and now reads as"</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p><i>The Applicable Entity's Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and for communicating to others as defined in the Responsible Entity's Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity's Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your company's needs and wants.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>Both requirements are to implement the Operating Plan. Hence, R3 should be a bullet under R2 and not a separate requirement. In addition, for R2, the phrase "actual event" is ambiguous and should mean: "actual event that meets the criteria of Attachment 1" We suggest the following wording to R2 (which will result in eliminating R3)"Each Responsible Entity shall implement its Operating Plan: o For actual events meeting the threshold criteria of Attachment 1 in accordance with</p>

Organization	Yes or No	Question 2 Comment
		<p>Requirement R1 parts 1.1, 1.2 and 1.3</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>o For review and updating of the Operating Plan in accordance with Requirement R1 parts 1.4 and 1.5”Note that we believe that if the SDT decides to not combine R2 and R3, then we disagree with the distinction between the two requirements.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p> <p>The division of implementing R1 through R2 and R3 as presented is “implementing” vs. “reporting”. We believe that the correct division should rather be “implementation” of the plan (which includes reporting) vs. revisions to the plan.</p> <p><i>The DSR SDT has updated Requirement R2 to read as: “R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1.”</i></p> <p><i>FERC Order 693 section 617 states “...the Commission directs the ERO to develop a modification to EOP-001-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Bulk-Power System to provide data...". In order for entities to provide data they are required to implement their Operating Plan.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Indiana Municipal Power Agency</p>	<p>No</p>	<p>Both requirements seem to be implementing the Operating Plan which means R3 should be a bullet under R2 and not a separate requirement. IMPA supports making R2 and R3 one requirement and eliminating the current R3 requirement.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>"R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p> <p>In addition, R2 needs to be clarified when addressing an actual event. IMPA recommends saying "an actual event that meets the criteria of Attachment 1."</p> <p><i>The DSR SDT has implemented your suggestion.</i></p> <p><i>Requirement R2now reads as: "Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 2 Comment
CenterPoint Energy	No	<p>CenterPoint Energy believes the current R2 is unnecessary and duplicative. Upon reporting events as required by R3, entities will be implementing the relevant parts of their Operating Plan that address R1.1 and R1.2. This duplication is clear when reading M2 and M3. Acceptable evidence is an event report. R2 should be modified to remove this duplicative requirement.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Orange and Rockland Utilities, Inc./Consolidated Edison Co. Of NY, Inc.	No	<p>Comments:</p> <ul style="list-style-type: none"> <li>o R1.3 should be revised as follows: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as determined by the responsible entity: ["appropriate: - deleted] [otherwise it is not clear who determines what communication level is appropriate]</li> <li>o R1.4 should be revised as follows: Provision(s) for updating the Operating Plan following ["within 90 calendar days of any" - deleted] change in assets or personnel (if the Operating Plan specifies personnel or assets) , ["other circumstances" - deleted] that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3.</li> <li>o R1.5 should be deleted. Responsible Entities can determine the frequency of Operating Plan updates. Requirement 1.4 requires updating the Operating Plan within 90 calendar days for changes in “assets, personnel.... or incorporating lessons</li> </ul>

Organization	Yes or No	Question 2 Comment
		<p>learned”.</p> <p><i>Requirement 1 has been updated and now reads as”</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p>This requirement eliminates the need for Requirement 1.5 requiring a review of the Operating Plan on an annual basis.</p> <p><i>The test and review requirement is included in the Standard to meet the intent of FERC Order 693, paragraph 466: “The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
ISO New England	No	<p>In accordance with the results-based standards concept, all that is required, for the “what” is that company X reported on event Y in accordance with the reporting requirements in attachment Z of the draft standard. Therefore, we proposed the only requirement that is necessary is R3, which should be re-written to read...”Each</p>



Organization	Yes or No	Question 2 Comment
		<p>Responsible Entity shall report to address the events listed in Attachment 1."</p> <p><i>Requirement 1 and 2 is the basis of the "what" you have described in your comment. Whereas Attachment 1 contains a minimum list of events that apply to Requirement 1, this is why Requirement R2 was rewritten as: "R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1."</i></p> <p><i>The DSR SDT was directed to incorporate certain items such as; FERC Order 693, paragraph 466: "The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>	<p>No</p>	<p>It is confusing why R3 is not considered part of R2, which deals with implementation of the Operating Plan and it appears that R3 could be interpreted as double jeopardy. We suggest deleting R3.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>"R2. Each Responsible Entity shall implement the Operating Plan that meets Requirement R1 for events listed in Attachment 1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 2 Comment
Oncor Electric Delivery Company LLC	No	<p>NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC considers ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.</p> <p><i>The Event Analysis Program may use a reported event as a basis to analyze an event. The reporting required in EOP-004-2 provides the input to the Events Analysis Process. The processes of the Event Analysis Program fall outside the scope of this project, but the DSR SDT has collaborated with them of events contained in Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
NV Energy	No	<p>On my read of the Standard, R2 and R3 appear to be duplicative, and I can't really distinguish the difference between the two. The action required appears to be the same for both requirements. Even the Measures for these two sound similar. It is not clear to me what it means to "implement" other than to have evidence of the existence and understanding of roles and responsibilities under the "Operating Plan." I suggest elimination of R2 and inclusion of a line item in Measure 1 calling for evidence of the existence of an "Operating Plan" including all the required elements in R1.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>"R2 Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p>

Organization	Yes or No	Question 2 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Northeast Power Coordinating Council</p>	<p>No</p>	<p>R1.3 should be revised as follows: A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as determined by the responsible entity:...Without this change it is not clear who determines what communication level is appropriate.</p> <p><i>Requirement 1, Part 1.3 (now Part 1.2) was updated per comments received.</i></p> <p><i>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p>R1.4 should be revised as follows: Provision(s) for updating the Operating Plan following any change in assets or personnel (if the Operating Plan specifies personnel or assets), that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3. R1.5 should be deleted. Responsible Entities can determine the frequency of Operating Plan updates. Requirement 1.4 requires updating the Operating Plan within 90 calendar days for changes in “assets, personnel.... or incorporating lessons learned”, (or our preceding proposed revision).</p> <p><i>Requirement 1, part 1.4 has been deleted and Requirement R2 has been updated to read as: “R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p>This requirement eliminates the need for Requirement 1.5 requiring a review of the Operating Plan on an annual basis.</p>

Organization	Yes or No	Question 2 Comment
		<p>The only true requirement that is results-based, not administrative and is actually required to support the Purpose of the Standard is R3.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i></p> <p><i>“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Illinois Municipal Electric Agency</p>	<p>No</p>	<p>R2 is not necessary, and should be removed. Subrequirement R1.4 is also not necessary and should be removed.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Kansas City Power &amp; Light</p>	<p>No</p>	<p>Requirement R1.1 is confusing regarding the “process for identifying events listed in Attachment 1”. Considering Attachment 1, the Events Table, already identifies the events required for reporting, please clearly describe in the requirement what the “process” referred to in requirement R1.1 represents.</p> <p><i>The DSR SDT has reviewed FERC Order 693 and paragraph 471 states: “...(2) specify</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>baseline requirement regarding what issues should be addressed in the procedures for recognizing sabotage events and making personnel aware of such events...”</i></p> <p><i>The DSR SDT has written Requirement 1, Part 1.1 to read as: “A process for recognizing each of the events listed in EOP-004 Attachment 1”. An Applicable Entity may rely on SCADA alarms as a process for recognizing an event or being made aware of an event through a scheduled Facility check. The DSR SDT has not been overly prescriptive on part 1.1 but has allowed each Applicable Entity to determine their own process for recognizing events listed in Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Luminant Power	No	<p>Requirements R1, R2, and R4 are burdensome administrative requirements and are contradictory to the NERC stated Standards Development goals of reducing administrative requirements by moving to performance requirements.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to indicate that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>There is only one Requirement needed in this standard: “The Responsible Entity shall report events in accordance with Attachment 1.” Attachment 1 should describe how events should be reported by what Entity to which party within a defined timeframe. If this requirement is met, all the other proposed requirements have no benefit to the reliability of the Bulk Electric System. Per the NERC Standard Development guidelines, only items that provide a reliability benefit should be included in a standard.</p> <p><i>The DSR SDT has updated Attachment 1 to a minimum threshold for Applicable Entities to report contained events. Requirement R2 has been updated to reflect that Applicable Entities shall implement their Operating Plan per Requirement 1 for events listed in Attachment 1. Requirement R2 reads as: “R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Xcel Energy</p>	<p>No</p>	<p>Suggest modifying R3 to indicate this is related to R 1.3.Each Responsible Entity shall report events to entities specified in R1.3 and as identified as appropriate in its Operating Plan.</p> <p><i>Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>(now R2)</i></p> <p><i>R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Colorado Springs Utilities	No	<p>The act of implementing the plan needs to include reporting events per R1, sub-requirement 1.3. R2 should simply state something like, "Each Responsible Entity shall implement the Operating Plan that meets the requirements of R1, as applicable, for an actual event or as specified." Suggest eliminating R3 which, seems to create double jeopardy effect.</p> <p><i>Requirement R2 was updated to reflect comments received to read as: "R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1." R3 was deleted.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Intellibind	No	<p>The language proposed is not clear and will continue to add confusion to entities who are trying to meet these requirements. It is not clear that the drafting team can put itself in the position of how the auditors will interpret and implement compliance against thithe R2 requirement. Requirements should be written to stand alone, not reference other requirements (or parts of the requirments. If the R1 parts 1.1, 1.2, 1.4 and 1.5 are so significant for this requirement, then they should be rewritten in R2.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Southern Company</p>	<p>No</p>	<p>These requirements as drafted in this revised standard potentially create a situation where an entity could be deemed non-compliant for both R2 and R3. For example, if a Responsible Entity included a reporting obligation in its Operating Plan, and failed to report an event, the Responsible Entity could be deemed non-compliant for R2 for not “implementing” its plan and for R3 for not reporting the event to the appropriate entities. A potential solution to address this would be to add Requirement 1, Part 1.3 to Requirement 2 and remove Requirement 3 in its entirety.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p>We also request clarification on Measure M3. Which records should have “dated and time-stamped transmittal records to show that the event was reported”? Some of the communication is handled via face-to-face conversation or through telephone</p>



Organization	Yes or No	Question 2 Comment
		<p>conversation.</p> <p><i>Measurement 3 has been deleted since Requirement 3 has been deleted. The new Measurement 2 allows for "...or other documentation". This may be in any form that the Applicable Entity wishes to maintain that they met Requirement 2. The Electric Reliability Organization does allow "Attestations" along with voice recordings as proof of compliance.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Independent Electricity System Operator</p>	<p>No</p>	<p>We agree with the revision to R2 and R3, but assess that a requirement to enforce implementation of Part 1.3 in Requirement R1 is missing. Part 1.3 in Requirement R1 stipulates that:1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate: o Internal company personnel o The Responsible Entity’s Regional Entity o Law enforcement o Governmental or provincial agenciesThe implementation of Part 1.3 is not enforced by R2 or R3 or any other Requirements in the standard. Suggest to add another requirement or expand Requirement R4 (and M4) to require the implementation of this Part in addition to verifying the process.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p><i>Requirement 1 has been updated and now reads as”</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <p><i>1.1 A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></p> <p><i>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Independent Electricity System Operator</p>	<p>Affirmative</p>	<p>The IESO believes that a requirement to enforce implementation of Part 1.3 in Requirement R1 is missing. Part 1.3 in Requirement R1 stipulates that: 1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the following as appropriate:</p> <ul style="list-style-type: none"> <li>o Internal company personnel</li> <li>o The Responsible Entity’s Regional Entity</li> <li>o Law enforcement</li> <li>o Governmental or provincial agencies</li> </ul> <p>The implementation of Part 1.3 is not enforced by R2 or R3 or any other Requirements in the standard. The IESO suggests that another requirement be added or Requirement R4 (and M4) be expanded to require the implementation of this Part in addition to verifying the process.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>timeframe specified in EOP-004 Attachment 1.”</i></p> <p><i>Requirement 1 has been updated and now reads as”</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <p><i>1.1 A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></p> <p><i>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Bonneville Power Administration</p>	<p>Yes</p>	<p>BPA believes the measures for R2 are unclear since they are similar to R3’s reporting measures.</p>
<p><b>Response: Thank you for your comment. The SDT has revised the standard to have a single implementation requirement with a single associated measure.</b></p>		
<p>Compliance &amp; Responsibility Office</p>	<p>Yes</p>	<p>See comments in response to Question 4.</p>
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
<p>Constellation Energy on behalf of Baltimore Gas &amp; Electric, Constellation Power Generation, Constellation Energy Commodities Group,</p>	<p>Yes</p>	<p>While we support the delineation of the different activities associated with implementation and reporting, further clarification would be helpful. R1. 1.3: As currently written, it is somewhat confusing, in particular the use of the qualifier “as appropriate”.</p> <p><i>The DSR SDT has updated Requirement 1, Part 1.2 to read as: “A process for</i></p>

Organization	Yes or No	Question 2 Comment
<p>Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.</p>		<p><i>communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>In addition, the use of the word “communicating” to capture both reporting to reliability authorities and notifying others may leave the requirement open to question. Below is a proposed revision: 1.3 A process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan, such as:</p> <ul style="list-style-type: none"> <li>o Internal company personnel</li> <li>o The Responsible Entity’s Regional Entity</li> <li>o Law Enforcement</li> <li>o Government or provincial agencies</li> </ul> <p>R1, 1.4: the last phrase of the requirements seems to be leftover from an earlier version. The requirement should end after the word “Plan”.R1, 1.5: “Process” should not be capitalized. While we understand the intent of the draft language and appreciate the effort to streamline the requirements, we propose an adjusted delineation below that we feel tracks more cleanly to the structure of a compliance program. Proposed revised language:R2. Each Responsible Entity shall implement its Operating Plan to meet Requirement R1, parts 1.1 and 1.2 for an actual event(s).M2. Responsible Entities shall provide evidence that it implemented it Operating Plan to meet Requirement R1, Parts 1.1 and 1.2 for an actual event.</p> <p><i>The DSR SDT has updated Requirement 1, Part 1.2 to read as: “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator;</i></p>

Organization	Yes or No	Question 2 Comment
		<p><i>law enforcement governmental or provincial agencies.”</i></p> <p><i>The Applicable Entity’s Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your company’s needs and wants.</i></p> <p><i>DSR SDT has revised R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.</i></p> <p><i>DSR SDT has revised M2. “Each Responsible Entity will have, for each event experienced, a dated copy of the completed EOP-004 Attachment 2 form or DOE form OE-417 report submitted for that event; and dated and time-stamped transmittal records to show that the event was reported supplemented by operator logs or other operating documentation. Other forms of evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other operating documentation for situations where filing a written report was not possible.</i></p> <p>Evidence may include, but is not limited to, an submitted event report form (Attachment 2) or a submitted OE-417 report, operator logs, or voice recording.R3. Each Responsible Entity shall implement its Operating Plan to meet Requirement R1, parts 1.4 and 1.5.M3. Responsible Entities shall provide evidence that it implemented it Operating Plan to meet Requirement R1, Parts 1.4 and 1.5. Evidence may include, but is not limited to, dated documentation of review and update of the Operating Plan.</p>

Organization	Yes or No	Question 2 Comment
		<p>R4. Each Responsible Entity shall verify (through implementation for an actual event, or through a drill, exercise or table top exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification.</p> <p>M4. The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan for events created pursuant to Requirement R1, Part 1.3. Either implementation of the communication process as documented in its Operating Plan for an actual event or documented evidence of a drill, exercise, or table top exercise may be used as evidence to meet this requirement. The time period between verification shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a verification.</p> <p><i>Requirement 4 (now R3) was revised as:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p><i>M3. Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. (R3)</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Exelon	Yes	Why is the reference to R1.3 missing from EOP-004-2 Requirement R2?

Organization	Yes or No	Question 2 Comment
		<p><i>R1.3 was associated with implementation in R3 which was removed from the standard. DSR SDT has revised R2 to read as: "Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Pacific Northwest Small Public Power Utility Comment Group	Yes	
Southwest Power Pool Regional Entity	Yes	
BC Hydro	Yes	
ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi	Yes	
MRO NSRF	Yes	
Western Electricity Coordinating Council	Yes	
Imperial Irrigation District	Yes	
Santee Cooper	Yes	

Organization	Yes or No	Question 2 Comment
Sacramento Municipal Utility District (SMUD)	Yes	
SPP Standards Review Group	Yes	
Dominion	Yes	
FirstEnergy	Yes	
PPL Electric Utilities and PPL Supply Organizations`	Yes	
Electric Compliance	Yes	
PacifiCorp	Yes	
Arizona Public Service Company	Yes	
Salt River Project	Yes	
Westar Energy	Yes	
APX Power Markets (NCR-11034)	Yes	
Clallam County PUD No.1	Yes	
ITC	Yes	
Springfield Utility Board	Yes	



Organization	Yes or No	Question 2 Comment
Manitoba Hydro	Yes	
Duke Energy	Yes	
Liberty Electric Power	Yes	
Public Utility District No. 1 of Snohomish County	Yes	
South Carolina Electric and Gas	Yes	
American Transmission Company, LLC	Yes	
Nebraska Public Power District	Yes	
Seattle City Light	Yes	
PSEG	Yes	
MidAmerican Energy	Yes	
Georgia System Operations Corporation	Yes	
FEUS	Yes	
Lower Colorado River Authority	Yes	

Organization	Yes or No	Question 2 Comment
American Public Power Association	Yes	
Northeast Utilities	Yes	
City of Austin dba Austin Energy	Yes	
Energy Northwest - Columbia	Yes	
Electric Reliability Council of Texas, Inc.	Yes	
		R2 and R3 appear redundant.
Progress Energy		
Los Angeles Department of Water and Power		
Texas Reliability Entity		
ReliabilityFirst		
NRECA		
Entergy Services		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		

Organization	Yes or No	Question 2 Comment
Southwestern Power Administration		

3. The DSR SDT revised reporting times for many events listed in Attachment 1 from one hour to 24 hours. Do you agree with these revisions? If not, please explain in the comment area below.

**Summary Consideration:** The DSR SDT appreciates the industry comments on the difficulty associated with reporting events that impact reliability. However, the SDT desires to point out that it is not the objective of this standard to provide an analysis of the event; but to provide the known facts of the events at the reporting threshold of onehour or 24hours depending upon the type of event. The SDT worked with the DOE and the NERC EAWG to develop reporting timelines consistent between the parties in an effort to promote consistency and uniformity.

The SDT has not established any requirement for a final or follow up report. The obligation is to report the facts known at the time. Once the report has been provided to the parties identified in the Operating Plan, no further action is required. All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:

“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”

For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report, and is consistent with current in-force standard EOP-004-1.

Organization	Yes or No	Question 3 Comment
Ameren Services	Negative	(6)By our count there are still six of the nineteen events listed with a one hour reporting requirement and the rest are all within 24 hour after the occurrence (or recognition of the event). This in our opinion, is reporting in real-time, which is against one of the key concepts listed in the background section:"The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of

Organization	Yes or No	Question 3 Comment
		<p>standards). The proposed standard deals exclusively with after-the-fact reporting." <i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(7)We believe the earliest preliminary report required in this standard should at the close of the next business day. Operating Entities, such as the RC, BA, TOP, GOP, DP, and LSE should not be burdened with unnecessary after-the-fact reporting while they are addressing real-time operating conditions. Entities should have the ability to allow their support staff to perform this function during the next business day as needed. We acknowledge it would not be an undue burden to cc: NERC on other required governmental reports with shorter reporting timeframes, but NERC should not expand on this practice.</p> <p><i>No preliminary report is required within the revised standard. Also, timelines have been revised (Please see response to item (6) above).</i></p> <p>(8)We agree with the extension in reporting times for events that now have 24 hours of reporting time. As a GO there are still too many potential events that still require a 1 hour reporting time that is impractical, unrealistic and could lead to inappropriate escalation of normal failures. For example, the sudden loss of several control room display screens for a BES generator at 2 AM in the morning, with only 1 hour to report something, might be mistakenly interpreted as a cyber-attack. The reality is</p>

Organization	Yes or No	Question 3 Comment
		<p>most likely something far more mundane such as the unexpected failure of an instrument transformer, critical circuit board, etc.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(9) The "EOP-004 Attachment 1: Events Table" is quite lengthy and written in a manner that can be quite subjective in interpretation when determining if an event is reportable. We believe this table should be clear and unambiguous for consistent and repeatable application by both reliability entities and a CEA. The table should be divided into sections such as: 9a) Events that affect the BES that are either clearly sabotage or suspected sabotage after review by an entity's security department and local/state/federal law enforcement.(b) Events that pose a risk to the BES and that clearly reach a defined threshold, such as load loss, generation loss, public appeal, EEAs, etc. that entities are required to report by the end of the next business day.(c) Other events that may prove valuable for lessons learned, but are less definitive than required reporting events. These events should be reported voluntarily and not be subject to a CEA for non-reporting.(d)Events identified through other means outside of entity reporting, but due to their nature, could benefit the industry by an event report with lessons learned. Requests to report and perform analysis on these type of events should be vetted through a ERO/Functional Entity process to ensure resources provided to this effort have an effective reliability benefit.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></li> </ul> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p><b>(10)</b>Any event reporting shall not in any manner replace or inhibit an Entity's responsibility to coordinate with other Reliability Entities (such as the RC, TOP, BA, GOP as appropriate) as required by other Standards, and good utility practice to operate the electric system in a safe and reliable manner.</p> <p><i>The DSR SDT agrees and believes the revised reporting timelines support that concept.</i></p> <p><b>(11)</b> The 1 hour reporting maximum time limit for all GO events in Attachment 1 should be lengthened to something reasonable - at least 24 hours. Operators in our energy centers are well-trained and if they have good reason to suspect an event</p>

Organization	Yes or No	Question 3 Comment
		<p>that might have serious impact on the BES will contact the TOP quickly. However, constantly reporting events that turn out to have no serious BES impact and were only reported for fear of a violation or self-report will quickly result in a cry wolf syndrome and a great waste of resources and risk to the GO and the BES. The risk to the GO will be potential fines, and the risk to the BES will be ignoring events that truly have an impact of the BES.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(12)The 2nd and 3rd Events on Attachment 1 should be reworded so they do not use terms that may have been deleted from the NERC Glossary by the time FERC approves this Standard.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>(13) The terms "destruction" and "damage" are key to identifying reportable events. Neither has been defined in the Standard. The term destruction is usually defined as 100% unusable. However, the term damage can be anywhere from 1% to 99%</p>



Organization	Yes or No	Question 3 Comment
		<p>unusable and take anywhere from 5 minutes to 5 months to repair. How will we know what the SDT intended, or an auditor will expect, without additional information?</p> <p><i>The 'Damage or Destruction' event category has been revised to say '...to a Facility', (a defined term) and thresholds have be modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term "Facility" to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p> <p style="padding-left: 40px;"><i>"A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)"</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>(14)We also do not understand why "destruction of BES equipment" (first item Attachment 1, first page) must be reported &lt; 1 hour, but "system separation (islanding) &gt; 100 MW" (Attachment 1, page 3) does not need to be reported for 24 hours.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>(15)The first 2 Events in Attachment 1 list criteria Threshold for Reporting as “...operational error, equipment failure, external cause, or intentional or unintentional human action.” The term “intentional or unintentional human action” appears to cover “operational error” so these terms appear redundant and create risk of misreporting. Can this be clarified?</p> <p><i>The second event has been deleted and the language has been clarified in the ‘Threshold for Reporting’ column in the ‘Damage or Destruction’ event category. The updated Threshold for Reporting now reads as:</i></p> <p><i>“Damage or destruction of a Facility that:</i></p> <ul style="list-style-type: none"> <li><i>• Affects an IROL (per FAC-014)</i></li> <li><i>OR</i></li> <li><i>• Results in the need for actions to avoid an Adverse Reliability Impact</i></li> <li><i>OR</i></li> <li><i>• Results from intentional human action.”</i></li> </ul> <p>(16)The footnote of the first page of Attachment 1 includes the explanation “...ii) Significantly affects the reliability margin of the system...” However, the GO is prevented from seeing the system and has no idea what BES equipment can affect the reliability margin of the system. Can this be clarified by the SDT?</p> <p><i>The footnote has been deleted and relevant information moved to the ‘Threshold for Reporting column in the ‘Damage or Destruction’ event category.</i></p> <p>(17) The use of the term “BES equipment” is problematic for a GO. NERC Team 2010-</p>

Organization	Yes or No	Question 3 Comment
		<p>17 (BES Definition) has told the industry its next work phase will include identify</p> <p><i>The term “BES equipment” is no longer used. The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have been modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p> <p style="text-align: center;"><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Beaches Energy Services, City of Green Cove Springs</p>	<p>Negative</p>	<p>3. Att. 1, going from 1 to 24 hrs: The times don’t seem aggressive enough for some of the Events related to generation capacity shortages, e.g., we would think public appeal, system wide voltage reduction and manual firm load shedding ought to be within an hour. These are indicators that the BES is “on the edge” and to help BES reliability, communication of this status is important to Interconnection-wide reliability.</p> <p><i>This standard concerns after-the-fact reporting. It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. This standard does not preclude a Responsible Entity from reporting more quickly than required by Attachment 1.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>4. The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., “Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements”) so that changes to the RoP do not necessitate changes to the standard.</p> <p><i>The DSR SDT believes that although the evidence retention language is the same as the current RoP, it is not specifically linked, so changes to the RoP will not necessitate changes to the standard.</i></p> <p>In R4, it might be worth clarifying that, in this case, implementation of the plan for an event that does not meet the criteria of Attachment 1 and going beyond the requirements R2 and R3 could be used as evidence. Consider adding a phrase as such to M4, or a descriptive footnote that in this case, “actual event” may not be limited to those in Attachment 1.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to read:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1. ”</i></p> <p>Comments to Attachment 1 table: On “Damage or destruction of Critical Asset” and “... Critical Cyber Asset”, Version 5 of the CIP standards is moving away from the</p>

Organization	Yes or No	Question 3 Comment
		<p>binary critical/non-critical paradigm to a high/medium/low risk paradigm. Suggest adding description that if version 5 is approved by FERC, that “critical” would be replaced with “high or medium risk”, or include changing this standard to the scope of the CIP SDT, or consider posting multiple versions of this standard depending on the outcome of CIP v5 in a similar fashion to how FAC-003 was posted as part of the GO/TO effort of Project 2010-07.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>On “forced intrusion”, the phrase “at BES facility” is open to interpretation as “BES Facility” (e.g., controversy surrounding CAN-0016) which would exclude control centers and other critical/high/medium cyber system Physical Security Perimeters (PSPs). We suggest changing this to “BES Facility or the PSP or Defined Physical Boundary of critical/high/medium cyber assets”. This change would cause a change to the applicability of this reportable event to coincide with CIP standard applicability. On “Risk to BES equipment”, that phrase is open to too wide a range of interpretation; we suggest adding the word “imminent” in front of it, i.e., “Imminent risk to BES equipment”. For instance, heavy thermal loading puts equipment at risk, but not imminent risk. Also, “non-environmental” used as the threshold criteria is ambiguous. For instance, the example in the footnote, if the BES equipment is near railroad tracks, then trains getting derailed can be interpreted as part of that BES equipment’s “environment”, defined in Webster’s as “the circumstances, objects, or conditions by which one is surrounded”. It seems that the SDT really means “non-weather related”, or “Not risks due to Acts of Nature”.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p>On “public appeal”, in the threshold, the descriptor “each” should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event?</p> <p><i>To clarify your point, the threshold has been changed to ‘Public appeal or load reduction event’.</i></p> <p>Should LSE be an applicable entity to “loss of firm load”? As proposed, the DP is but the LSE is not. In an RTO market, will a DP know what is firm and what is non-firm load? Suggest eliminating DP from the applicability of “system separation”. The system separation we care about is separation of one part of the BES from another which would not involve a DP.</p> <p><i>The DSR SDT believes the current applicability is correct and the threshold provides sufficient discrimination to drive the proper Applicable Entities to report.</i></p> <p>On “Unplanned Control Center Evacuation”, CIP v5 might add GOP to the applicability, another reason to add revision of EOP-004-2 to the scope of the CIP v5 drafting team, or in other ways coordinate this SDT with that SDT. Consider posting a couple of versions of the standard depending on the outcome of CIP v5 in a similar fashion to the multiple versions of FAC-003 posted with the GO/TO effort of Project 2010-07.</p> <p><i>The DSR SDT believes the current applicability is correct. The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds. Note that EOP-008-0 is only Applicable to Balancing Authorities, Transmission Operators and Reliability Coordinators, this is the basis for the "Entity with reporting Responsibilities" and reads as" "Each RC, BA, TOP that experiences the event".</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Arkansas Electric Cooperative Corporation</p>	<p>Negative</p>	<p>AECC appreciates the efforts of the SDT to address our comments from the previous posting and feels the Standards have shown great improvement in the current posting. Our negative vote stems from concerns around the 1 hour reporting requirements for events having no size thresholds and ambiguity for external entity reporting in R1.3. Please refer to the comments submitted by the SPP Standards Review Group.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 3 Comment
PowerSouth Energy Cooperative	Negative	<p>Attachment 1 needs to be eliminated. It is confusing to operators and doesn't enhance the reliability of the BES.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Clark Public Utilities	Negative	<p>Attachment 1 provides confusion not clarification. Just use the OE-417 reporting form for any and all events identified in that form for any one-hour or six-hour reporting. Utilities are required by law to provide the DOE notification and the SDT has just confused the situation by attempting (as it appears) to rename the one-hour reporting events. In some instances, Attachment 1 contradicts the DOE reporting. Public appeals for load reduction are required within 24 hours (according to the Events Table) but OE-417 requires such public appeals to be reported within one</p>



Organization	Yes or No	Question 3 Comment
		<p>hour.</p> <p>Clark recommends the Events Table show first the one hour reporting of OE-417, then the six hour reporting of OE-417, and finally any additional reporting that is desired but not reportable to DOE. This will help in not confusing seemingly related events. The table should indicate which form is to be used and should mandate Form OE-417 for all DOE reportable events and the Attachment 2: Event Reporting Form for all reportable events not subject to the DOE reporting requirements.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>Clark questions whether the event labeled Forced Intrusion really needs to be reported in one hour. It can take several hours to determine if a forced entry actually occurred. Clark is also unsure if reporting forced intrusions at these facilities (if no other disturbance occurs) will provide any information useful in preventing system disturbances but believes this event should be changed to a 24 hour notification.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>The event labeled Detection of a reportable Cyber Security Incident should have the Entity with Reporting Responsibility changed to the following: “Applicable Entities under CIP-008.” The Threshold for Reporting on this event is based on the criteria in CIP-008. If an entity is not an applicable entity under CIP-008, it should not have a reporting requirement based on CIP-008 that appears in EOP-004.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
City of Farmington	Negative	<p>Attachment 1: BES equipment is too vague - consider changing to BES facility and including that reduces the reliability of the BES in the footnote. Is the footnote an and or an or?</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>Attachment 1: Version 5 of CIP Requirements the use of the terms Critical Asset and Critical Cyber Asset. The drafting team should consider revising the table to be flexible so it will not require modification when new versions of CIP become effective. Clarify if Damage or Destruction is physical damage (aka - cyber incidents would be part of CIP-008 covered separately in Attachment 1.)</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Attachment 1: Unplanned Control Center evacuation - remove “potential” from the reporting responsibility Attachment 1:</p> <p><i>The ‘potential’ language has been removed. The threshold for Reporting now reads as: “Each RC, BA, TOP that experiences the event”.</i></p> <p>SOL Tv - is not defined.</p> <p><i>The SOL Violation (WECC only) event has been revised to remove Tv and replace it with “30 minutes” to be consistent with TOP-007-WECC requirements. The event has</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>also been revised to indicate an SOL associated with a Major WECC transfer path.</i></p> <p>Attachment 2 - 3: change to, “Did the event originate in your system?” The requirement only requires reporting for Events - not potential events. This implies if there is potential for an event to occur, the entity should report (potential of a public appeal or potential to shed firm load)</p> <p><i>The ‘actual or potential’ language has been removed.</i></p> <p>Attachment 2 4: “Damage or Destruction to BES equipment” should be “Destruction of BES Equipment” like it is in Attachment 1 and “forced intrusion risk to BES equipment” remove “risk”</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘...to a Facility’, (a defined term) and thresholds have be modified to provide clarity. Also, the reporting timeline is now 24 hours.</i></p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>The OE-417 requires several of the events listed in Attachment 1 be reported within 1 hour. FEUS recommends the drafting team review the events and the OE-417 form and align the reporting window requirements. For example, public appeals, load shedding, and system separation have a 1 hour requirement in OE-417.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Wisconsin Public Service Corp.	Negative	<p>EOP-004 Attachment 1 states: That any Damage or destruction of a Critical Cyber Asset per CIP-002 Applicable Entities under CIP-002 Through intentional or unintentional human action. Requires reporting in 1 hour of recognition of event. This is too low of a threshold for reporting. Unintentional damage could be caused by an individual spilling coffee on a laptop. Hardly the item for a report.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 3 Comment
<p>ACES Power Marketing, Hoosier Energy Rural Electric Cooperative, Inc., Sunflower Electric Power Corporation, Great River Energy</p>	<p>Negative</p>	<p>For many of the events listed in Attachment 1, there would be duplicate reporting the way it is written right now. For example, in the case of a fire in a substation (Destruction of BES equipment), the RC, BA, TO, TOP and perhaps the GO and GOP could all experience the event and each would have to report on it. This seems quite excessive and redundant. We recommend eliminating this duplicate reporting.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Consumers Energy</p>	<p>Negative</p>	<p>Forced intrusion needs to be specifically defined. A 1-hour report requirement is not necessary but for critical events that would have wide-ranging impact.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>Requirements 2 and 3 should be combined into a single requirement.</p> <p><i>The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>MidAmerican Energy Co.</p>	<p>Negative</p>	<p>MidAmerican Energy believes Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. Based on our understanding of Attachment 1, the category of “damage or destruction of a critical cyber asset” will likely result in hundreds or thousands of small equipment failures being reported to NERC and DOE, with no improvement to security. For example, hard drive failures, server failures, PLC failures and relay failures could all meet the criteria of “damage or destruction of a critical cyber asset.” which would be required reporting in 1 hour.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>EOP-004-2 needs to clearly state that initial reports can be made by a phone call, email or another method, in accordance with paragraph 674 of FERC Order 706. MidAmerican recommends replacing Attachment 1 and Attachment 2 with the categories and timeframes that are listed in OE-417. This eliminates confusion between government requirements in OE-417 and NERC standards.</p> <p><i>Attachment 1 provides the flexibility to make a verbal report. The header of Attachment 1 states:</i></p> <p><i>“NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p><i>Attachment 2 provides the flexibility to make a verbal report. The header of Attachment 2 states:</i></p> <p><i>“This form is to be used to report events. The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports to the ERO should be submitted via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, voice: 609-452-1422.”</i></p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>EOP-004 requirements were designed to meet NERC and the industry’s needs;</i></li> </ul>



Organization	Yes or No	Question 3 Comment
		<p><i>accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></p> <ul style="list-style-type: none"> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>MidAmerican Energy Co.</p>	<p>Negative</p>	<p>MidAmerican Energy believes Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. EOP-004-2 needs to clearly state that initial reports can be made by a phone call, email or another method, in accordance with paragraph 674 of FERC Order 706. MidAmerican recommends replacing Attachment 1 and Attachment 2 with the categories and timeframes that are listed in OE-417. This eliminates confusion between government requirements in OE-417 and NERC standards.</p> <p><i>Attachment 1 provides the flexibility to make a verbal report. The header of Attachment 1 states:</i></p> <p><i>"NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p><i>Attachment 2 provides the flexibility to make a verbal report. The header of Attachment 2 states:</i></p> <p><i>“This form is to be used to report events. The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports to the ERO should be submitted via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, voice: 609-452-1422.”</i></p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Seattle City Light</p>	<p>Negative</p>	<p>Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes, as well as the CIP standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist. As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>Related to "Reportable Events" of Attachment 1: 1. A reportable event is stated as, "Risk to the BES", the threshold for reporting is, "From a non-environmental physical threat". This appears to be a catch-all event, and basically every other event in Attachment 1 should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>a threat, not when it may have first occurred.</i></p> <p>2. A reportable event is stated as, “Damage or destruction of Critical Asset per CIP-002”. The term “Damage” would have to be defined in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. One could argue that normal “Damage” can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard. Reporting Thresholds 1.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing. An example is the “BES Emergency requiring manual firm load shedding of greater than or equal to 100 MW or the Loss of Firm load for = 15 Minutes that is greater than or equal to 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases these low thresholds represent reporting of minor wind events or other seasonal system issues on Local Network used to provide distribution service.</p> <p><i>These thresholds reflect those used in the current in-force EOP-004-1, and haven’t congested the reporting process to date.</i></p> <p>Firm Demand 1. The use of Firm Demand in the context of the draft Standards could be used to describe commercial arrangements with a customer rather than a</p>

Organization	Yes or No	Question 3 Comment
		<p>reliability issue. Clarification of Firm Demand would be helpful</p> <p><i>The DSR SDT did not use the words 'Firm Demand' anywhere in the proposed standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Constellation Energy; Constellation Energy Commodities Group; Constellation Power Source Generation, Inc.</p>	<p>Negative</p>	<p>Please see the comments offered in the concurrent comment form. While Constellation is voting negative on this ballot, we recognize the progress made by the drafting team and find the proposal very close to acceptable. It should be noted that our negative vote is due to remaining concerns with the Attachment 1: Event Table categories language. In the comment form Constellation proposes revisions to both the requirement language and to the Event Table language; however, the Event Table language is the greater hurdle</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Salt River Project</p>	<p>Negative</p>	<p>Related to “Reportable Events” of Attachment 1: 1. A reportable event is stated as, “Risk to the BES”, the threshold for reporting is, “From a non-environmental physical threat”. This as appears to be a catch-all event, and basically every other event should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. A reportable event is stated as, “Damage or destruction of Critical Asset per CIP-002”. The term “Damage” would have to be defined in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. One could argue that normal “Damage” can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Southern California Edison Co.</p>	<p>Negative</p>	<p>SCE and WECC are in agreement on one key point (removing the requirement to</p>

Organization	Yes or No	Question 3 Comment
		<p>determine if an act was "sabotage"), however, I continue to believe SCE will find the one-hour reporting requirement difficult to manage.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>City of Redding</p>	<p>Negative</p>	<p>The following comments are directed toward Attachment 1: We commend the SDT for properly addressing the sabotage issue. However, additional confusion is caused by introducing term "damage". As "damage" is not a defined term it would be beneficial for the drafting team to provide clarification for what is meant by "damage".</p> <p><i>The 'Damage or Destruction' event category has been revised to say '...to a Facility', (a defined term) and thresholds have be modified to provide clarity. Also, the reporting timeline is now 24 hours.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>The threshold for reporting “Each public Appeal for load reduction” should clearly state the triggering is for the BES Emergency as routine “public appeal” for conservation could be considered a threshold for the report triggering..</p> <p><i>The DSR SDT believes the current language of the event category ‘BES Emergency...’ clearly excludes routine conservation requests. The Threshold for Reporting has been updated to read as: “Public appeal for load reduction event”.</i></p> <p>Regarding the SOL violations in Attachment 1 the SOL violations should only be those that affect the WECC Paths.</p> <p><i>The SOL Violation (WECC only) event has been revised to remove Tv and replace it with “30 minutes” to be consistent with TOP-007-WECC requirements. The event is now “SOL for Major WECC Transfer Paths (WECC only)”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Avista Corp.	Negative	<p>The VSLs associated with not reporting in an hour for some of the events (Destruction of BES Equipment) is too severe. Operators need to be able to deal with events and not worry about reporting until the system is secure. Back office personnel are only available 40-50 hours per week, so the reporting burden falls on the Operator.</p> <p><i>The DSR SDT believes the VSL is appropriate for the only remaining 1 hour event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Avista Corp.	Negative	<p>There is definitely a need to communicate and report out system events to NERC, RCs, and adjacent utilities. However, this new standard has gone too far with regards to reporting of certain events within a 1 hour timeframe and the associated VSLs for going beyond the hour time period. Operators need to be able to deal with the system events and not worry about reporting out for the “Destruction of BES</p>



Organization	Yes or No	Question 3 Comment
		<p>equipment” (first row in Attachment 1 -Reportable Events). Operators only have 40-50 hours out of 168 hours in a week where supporting personnel are also on shift, so this reporting burden will usually fall on the Operators not back office support. Again this is another example of the documentation requirements of a standard being more important than actually operating the system.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>The “Destruction of BES equipment” event is too ambiguous and will lead to interpretations by auditors to determine violations. The ambiguity will also lead to the reporting of all BES equipment outages to avoid potential violations of the standard. It usually takes more than an hour to determine the cause and extent of an outage.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘...to a Facility’, (a defined term) and thresholds have been modified to provide clarity. Also, the reporting timeline is now 24 hours.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>National Association of Regulatory Utility Commissioners</p>	<p>Negative</p>	<p>Therequirement that any event with the potential to impact reliability be reported is overly broad and requires more focus.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ (which this footnote referenced) have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Alameda Municipal Power, Salmon River Electric Cooperative</p>	<p>Negative</p>	<p>We feel that the drafting team has done an excellent job of providing clarify and reasonable reporting requirements to the right functional entity. We support the modifications but would like to have two additional minor modification in order to provide additional clarification to the Attachment I Event Table. We suggest the following clarifications: For the Event: BES Emergency resulting in automatic firm load shedding Modify the Entity with Reporting Responsibility to: Each DP or TOP that experiences the automatic load shedding within their respective distribution serving or Transmission Operating area.</p> <p><i>The DSR SDT believes the current language is sufficient and cannot envision how a BA, TOP, or DP could ‘experience the automatic load shedding’ if it didn’t take place in its balancing, transmission operating, or distribution serving area.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>For the Event: Loss of Firm load for = 15 Minutes Modify the Entity with Reporting Responsibility to: Each BA, TOP, DP that experiences the loss of firm load within their respective balancing, Transmission operating, or distribution serving area. With these modifications or similar modifications we fully support the proposed Standard.</p> <p><i>The DSR SDT believes the current language is sufficient and cannot envision how a BA, TOP, or DP could 'experience the loss of firm load' if it didn't take place in its balancing, transmission operating, or distribution serving area.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Orange and Rockland Utilities, Inc.</p>	<p>No</p>	<p>o Generally speaking the SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language. o EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded. o If the list of reportable events is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and in the EAP Categories 1 through 5.</p> <p><i>OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may</i></li> </ul>

Organization	Yes or No	Question 3 Comment
		<p><i>trigger further information requests from EAWG as necessary</i></p> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>o It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>o Event: “Risk to BES equipment” should be deleted. This is too vague and subjective. Will result in many “prove the negative” situations.’</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>o Event: “Destruction of BES equipment” is again too vague. The footnote refers to equipment being “damaged or destroyed”. There is a major difference between</p>

Organization	Yes or No	Question 3 Comment
		<p>destruction and damage.</p> <p><i>The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have been modified to provide clarity.</i></p> <p>o Event: "Damage or Destruction of a Critical Asset or Critical Cyber Asset" should be deleted. Disclosure policies regarding sensitive information could limit an entity's ability to report. Unintentional damage to a CCA does not warrant a report.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>o Event: "BES Emergency requiring public appeal for load reduction" should be modified to note that this does not apply to routine requests for customer conservation during high load periods</p> <p><i>The DSR SDT believes the current language of the event category 'BES Emergency...' clearly excludes routine conservation requests.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Ameren	No	<p>(1)By our count there are still six of the nineteen events listed with a one hour reporting requirement and the rest are all within 24 hour after the occurrence (or recognition of the event). This in our opinion, is reporting in real-time, which is against one of the key concepts listed in the background section:"The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of</p>

Organization	Yes or No	Question 3 Comment
		<p>standards). The proposed standard deals exclusively with after-the-fact reporting."</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>(2)We believe the earliest preliminary report required in this standard should at the close of the next business day. Operating Entities, such as the RC, BA, TOP, GOP, DP, and LSE should not be burdened with unnecessary after-the-fact reporting while they are addressing real-time operating conditions. Entities should have the ability to allow their support staff to perform this function during the next business day as needed. We acknowledge it would not be an undue burden to cc: NERC on other required governmental reports with shorter reporting timeframes, but NERC should not expand on this practice.</p> <p><i>No preliminary report is required within the revised standard.</i></p> <p>(3)We agree with the extension in reporting times for events that now have 24 hours of reporting time. As a GO there are still too many potential events that still require</p>

Organization	Yes or No	Question 3 Comment
		<p>a 1 hour reporting time that is impractical, unrealistic and could lead to inappropriate escalation of normal failures. For example, the sudden loss of several control room display screens for a BES generator at 2 AM in the morning, with only 1 hour to report something, might be mistakenly interpreted as a cyber-attack. The reality is most likely something far more mundane such as the unexpected failure of an instrument transformer, critical circuit board, etc.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Duke Energy	No	<p>All events in Attachment 1 should have reporting times of no less than 24 hours. As stated on page 6 of the current draft of the standard: "The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting."We maintain</p>

Organization	Yes or No	Question 3 Comment
		<p>that a report which is required to be made within one hour after an event is, in fact, a real time report. In the first hour or even several hours after an event the operator may appropriately still be totally committed to restoring service or returning to a stable bulk power system state, and should not stop that recovery activity in order to make this “after-the-fact” report.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Public Power Association</p>	<p>No</p>	<p>APPA echoes the comments made by Central Lincoln: We do not believe the SDT has adequately addressed the FERC Order to “Consider whether separate, less burdensome requirements for smaller entities may be appropriate.” The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely “recognition” starts the clock and reporting will become a higher</p>



Organization	Yes or No	Question 3 Comment
		<p>priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition. APPA recommends the SDT evaluate a less burdensome requirement for smaller entities with reporting requirements in Attachment 1. This exception needs to address the fact that not all entities have 24 hour 7 day a week operating personnel.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p> <p>However, APPA cautions the SDT that changes to this standard may expose entities to reporting violations on DOE-OE-417 which imposes civil and criminal penalties on reporting events to the Department of Energy. APPA recommends that the SDT reach out to DOE for clarification of reporting requirements for DOE-OE-417 for small entities, asking DOE to change their reporting requirement to match EOP-004-2. If</p>

Organization	Yes or No	Question 3 Comment
		<p>DOE cannot change their reporting requirement the SDT should provide an explanation in the guidance section of Reliability Standard EOP-004-2 that addresses these competing FERC/DOE directives.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
BC Hydro	No	<p>As an event would be verbally reported to the RC, all the one hour requirements to submit a written report should be moved from one hour to 24 hours.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Bonneville Power Administration</p>	<p>No</p>	<p>BPA believes that the first three elements in Attachment 1 are too generic and should be with only the intentional human criterion. The suspicious device needs to be determined as a threat (and not left behind tools) before requiring a report.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. These thresholds include intentional human action as well as impact-based for those cases when cause isn’t known. The determination of a threat as you suggest is now part of the revised event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>CenterPoint Energy</p>	<p>No</p>	<p>CenterPoint Energy agrees with the revision that allows more time for reporting some events; however, some 1 hour requirements remain. The Company does not agree with this timeframe for any event.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p>Response: Thank you for your comment Please see response above.</p>		
<p>Consolidated Edison Co. of NY, Inc.</p>	<p>No</p>	<p>Comments: We have a number of comments on Attachment 1 and will make them here:</p> <ul style="list-style-type: none"> <li>o Generally speaking the SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language.</li> <li>o EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded.</li> <li>o If the list of reportable events</li> </ul>

Organization	Yes or No	Question 3 Comment
		<p>is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and in the EAP Categories 1 through 5.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>o It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘Any physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>o Event: “Risk to BES equipment” should be deleted. This is too vague and subjective. Will result in many “prove the negative” situations.’</p>

Organization	Yes or No	Question 3 Comment
		<p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>o Event: “Destruction of BES equipment” is again too vague. The footnote refers to equipment being “damaged or destroyed”. There is a major difference between destruction and damage.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity.</i></p> <p>o Event: “Damage or Destruction of a Critical Asset or Critical Cyber Asset” should be deleted. Disclosure policies regarding sensitive information could limit an entity’s ability to report. Unintentional damage to a CCA does not warrant a report.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>o Event: “BES Emergency requiring public appeal for load reduction” should be modified to note that this does not apply to routine requests for customer conservation during high load periods.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>The DSR SDT believes the current language 'BES Emergency...' clearly excludes routine conservation requests.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Electric Reliability Council of Texas, Inc.</p>	<p>No</p>	<p>Destruction of BES equipment: 1. Request that the term “destruction” be clarified.</p> <p><i>The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity.</i></p> <p>Damage or destruction of Critical Asset per CIP-002: 1. Request that the terms “damage” and “destruction” be clarified. 2. Is the expectation that an entity report each individual device or system equipment failure or each mistake made by someone administering a system?</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>3. Request that “initial indication of the event” be changed to “confirmation of the event”. Event monitoring and management systems may receive many events that are determined to be harmless and put the entity at no risk. This can only be determined after analysis of the associated events is performed.</p> <p><i>The 'initial indication of the event' is no longer part of the threshold for 'Damage or Destruction of a Facility'</i></p> <p>Risk to BES equipment: Request that the terms “risk” be clarified.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'.</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Exelon</p>	<p>No</p>	<p>Due to the size of the service territories in ComEd and PECO it's difficult to get to some of the stations within in an hour to analyze an event which causes concern with the 1 hour criteria. It is conceivable that the evaluation of an event could take longer then one hour to determine if it is reportable. Exelon cannot support this version of the standard until the 1 hour reporting criteria is clarified so that the reporting requirements are reasonable and obtainable. Exelon has concerns about the existing 1 hour reporting requirements and feels that additional guidance and verbiage is required for clarification. We would like a better understanding when the 1 hour clock starts please consider using the following clarifying statement, in the statements that read, "recognition of events" please consider replacing the word "recognition" with the word "confirmation" as in a "confirmed event"</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force</i></p>



Organization	Yes or No	Question 3 Comment
		<p><i>standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Energy Northwest - Columbia</p>	<p>No</p>	<p>Energy Northwest - Columbia (ENWC) has concerns about the existing 1 hour reporting requirements and feels that additional guidance and verbiage is required for clarification. ENWC would like the word "recognition" in the statement that reads, "recognition of events," be replaced by "confirmation" as in "confirmed event."Also, we would like clarification as to when the 1 hour clock starts. Please consider changing recognition in "within 1 hour of recognition of event" and incorporating in "confirmation."</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 3 Comment
Indiana Municipal Power Agency	No	<p>IMPA believes that some of the times may not be aggressive enough that are related to generation capacity shortages.</p> <p><i>This standard concerns after-the-fact reporting. It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. This standard does not preclude a Responsible Entity from reporting more quickly than required by Attachment 1.</i></p> <p>In addition, IMPA believes clarity needs to be added when saying within 1 hour of recognition of event. For example, A fence cutting may not be discovered for days at a remote substation and then a determination has to be made if it was “forced intrusion” - Does that one hour apply once the determination is made that is was “forced intrusion” or from the time the discovery was made? Some of the 1 hour time limits can be expanded to allow for more time, such as forced intrusion, destruction of BES equipment, Risk to BES equipment, etc.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘Any physical threat that could impact the operability of a Facility’. Timelines start at the moment the Responsible Entity determines the event represents a threat, not when it first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Luminant Power	No	<p>Luminant agrees with the changes the SDT made, however, the timeline should be modified to put higher priority activities before reporting requirements. The SDT should consider allowing entities the ability to put the safety of personnel, safety of the equipment, and possibly the stabilization of BES equipment efforts prior to initiating the one hour reporting timeline. Reporting requirements should not be prioritized above these important activities. The requirement to report one hour after the recognition of such an event may not be sufficient in all instances. Entities</p>

Organization	Yes or No	Question 3 Comment
		<p>should not have a potential violation as a result of putting these priority issues first and not meeting the one hour reporting timeline.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>Actions taken to maintain the reliability of the BES in real-time always take precedence over reporting. The revised thresholds should ensure there is no perverse driver to act differently.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
MidAmerican Energy	No	<p>MidAmerican Energy agrees with the direction of consolidating CIP-001, EOP-004 and portions of CIP-008. However, we have concerns with some of the events included in Attachment 1 and reporting timelines. EOP-004-2 needs to clearly state that initial reports can be made by a phone call, email or another method, in accordance with paragraph 674 of FERC Order 706.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>MidAmerican Energy believes draft Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. Based on our understanding of Attachment 1, the category of “damage or destruction of a critical cyber asset” will result in hundreds or thousands of small equipment failures being reported to NERC and DOE, with no improvement to security. For example, hard drive failures, server failures, PLC failures and relay failures could all meet the criteria of “damage or destruction of a critical cyber asset.”</p> <p><i>The DSR SDT agrees and the ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>We recommend replacing Attachment 1 and Attachment 2 with the categories and timeframes that are listed in OE-417. This eliminates confusion between government requirements in OE-417 and NERC standards.</p> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may</i></li> </ul>

Organization	Yes or No	Question 3 Comment
		<p><i>trigger further information requests from EAWG as necessary</i></p> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>Reporting timelines and reporting form FERC Order 706, paragraph 676, directed NERC to require a responsible entity to “at a minimum, notify the ESISAC and appropriate government authorities of a cyber security incident as soon as possible, but, in any event, within one hour of the event, even if it is a preliminary report.” In paragraph 674, FERC stated that the Commission agrees that, in the “aftermath of a cyber attack, restoring the system is the utmost priority.” They clarified: “the responsible entity does not need to initially send a full report of the incident...To report to appropriate government authorities and industry participants within one hour, it would be sufficient to simply communicate a preliminary report, including the time and nature of the incident and whatever useful preliminary information is available at the time. This could be accomplished by a phone call or another method.” While FERC did not order completion of a full report within one hour in Order 706, the draft EOP-004 Attachment 1 appears to require submittal of formal reports within one hour for six of the categories, unless there have been “certain adverse conditions” (in which case, as much information as is available must be submitted at the time of notification).</p> <p><i>It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. As stated above, all one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673. For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions, which would certainly include the aftermath of a cyber attack that had</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>major impact on the BES.</i></p> <p>The Violation Severity Levels are extreme for late submittal of a report. For example, it would be a severe violation to submit a report more than three hours following an event for an event requiring reporting in one hour.</p> <p><i>The DSR SDT believes the VSL is appropriate now that it only applies to the remaining 1 hour reportable event, which is the Reportable Cyber Event under CIP-008.</i></p> <p>MidAmerican Energy suggests incorporating the language from FERC Order 706, paragraph 674, into the EOP-004 reporting requirement to allow preliminary reporting within one hour to be done through a phone call or another method to allow the responsible entity to focus on recovery and/or restoration, if needed. MidAmerican Energy agrees with the use of DOE OE-417 for submittal of the full report of incidents under EOP-004 and CIP-008. We would note there are two parts to this form -- Schedule 1-Alert Notice, and Schedule 2-Narrative Description. Since OE-417 already requires submittal of a final report that includes Schedule 2 within 48 hours of the event, MidAmerican Energy believes it is not necessary to include a timeline for completion of the final report within the EOP-004 standard. We would note that Schedule 2 has an estimated public reporting burden time of two hours so it is not realistic to expect Schedule 2 to be completed within one hour. Events included in Attachment 1: MidAmerican Energy believes draft Attachment 1 expands the scope of what must be reported beyond what is required by FERC directives and beyond what is needed to improve security of the BES. The categories listed in Attachment 1 with one-hour reporting timelines cause the greatest concern. None of these categories are listed in OE-417, and all but the last row would not be considered a Cyber Security Incident under CIP-008, unless there was malicious or suspicious intent.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>	<p>No</p>	<p>No event should have a reporting time less than at the close of the next business day. Any reporting of an event that requires a less reporting time should only be to entities that can help mitigate an event such as an RC or other Reliability Entity.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 3 Comment
Southwestern Power Administration	No	<p>One hour is not enough time to make these assessments for all of the six items in attachment 1. All timing requirements should be made the same in order to simplify the reporting process.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
ITC	No	See comments to Question #4
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
Southern Company	No	<p>Southern request clarification on one of the entries in Attachment 1. The concern is with the last row on page 21 of Draft 3. What is the basis for "Voltage deviations"? The Threshold is <math>\hat{\pm}10\%</math> sustained for <math>\hat{\approx} 15</math> minutes. Is the voltage deviation based on the Voltage Schedule for that particular timeframe, or is it something else (pre-contingency voltage level, nominal voltage, etc.)?</p> <p><i>A sustained voltage deviation of <math>\pm 10\%</math> on the BES is significant deviation and is indicative of a shortfall of reactive resources either pre- or post-contingency. The DSR SDT is indifferent to which of nominal, pre-contingency, or scheduled voltage, is used</i></p>



Organization	Yes or No	Question 3 Comment
		<p><i>as the baseline, but for simplicity and to promote a common understanding suggest using nominal voltage.</i></p> <p>In addition, the second row of Attachment 1 lists “Damage or destruction of a Critical Cyber Asset per CIP-002” as a reportable event. The threshold includes “...intentional or unintentional human action” and gives us 1 hour to report. The term “damage” may be overly broad and, without definition, is not limited in any way. If a person mistypes a command and accidentally deletes a file, or renames something, or in any way changes anything on the CCA in error, then this could be considered “damage” and becomes a reportable event. The SDT should consider more thoroughly defining what is meant by “damage”. Should it incorporate the idea that the essential functions that the CCA is performing must be adversely impacted?</p> <p><i>The DSR SDT agrees and the ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Lastly, no event should have a reporting time shorter than at the close of the next business day. Any reporting of an event that requires a shorter reporting time should only be to entities that can help mitigate an event such as an RC or other Reliability Entity.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>FEUS</p>	<p>No</p>	<p>The OE-417 requires several of the events listed in Attachment 1 be reported within 1 hour. FEUS recommends the drafting team review the events and the OE-417 form and align the reporting window requirements. For example, public appeals, load shedding, and system separation have a 1 hour requirement in OE-417.</p> <p><i>OE-417 thresholds and reporting timelines were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America. Non-US Responsible Entities cannot be obligated to report in shorter timelines simply to make the two forms line up. The current in-force EOP-004 requires 24 hour reporting on the items you have identified and so does the latest version of EOP-004-2</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p>

Organization	Yes or No	Question 3 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>SPP Standards Review Group</p>	<p>No</p>	<p>The purpose of the reporting requirement should be clear either in the text of the requirements or through an explanation that is embodied in the language of the approved set of standards. This would be consistent with a “Results-based” architecture. What is lacking in the proposed language of this standard is recognition that registered entities differ in size and relevance of their impact on the Bulk Electric System. Also, events that are reportable differ in their impact on the registered entity. A “one-size fits all” approach to this standard may cause smaller entities with low impact on the grid to take extraordinary measures to meet the reporting/timing requirements and yet be too “loose” for larger more sophisticated and impacting entities to meet the same requirements. Therefore, we believe language of the standard must clearly state the intent that entities must provide reports in a manner consistent with their capabilities from a size/reliability impact perspective and from a communications availability perspective. Timing requirements should allow for differences and consider these variables. Also, we would suggest including language to specifically exclude situations where communications facilities may not be available for reporting. For example, in situations where communications facilities have been lost, initial reports would be due within 6 hours of the restoration of those communication facilities.</p> <p><i>The DSR SDT has reviewed Attachment 1 and made revisions to Event types, used the NERC approved term ‘Facility’, and revised some of the language under ‘Entity with Reporting Responsibility’ to ensure that these reportable events correctly represent the relative impact to the BES. Also, all one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p> <p>We would also suggest that Attachment 1 be broken into two distinct parts such that those events which must be reported within 1 hour stand out from those events that have to be reported within 24 hours.</p> <p><i>The DSR SDT agrees and has implemented your suggestion.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Kansas City Power &amp; Light</p>	<p>No</p>	<p>The reportable events listed in Attachment 1 can be categorized as events that have had a reliability impact and those events that could have a reliability impact. The listed events that could have a reliability impact should have a 24 hour reporting requirement and the events that have had a reliability impact are appropriate at a 1 hour reporting. The following events with a 1 hour report requirement are recommended to change to 24 hour: Forced Intrusion and Risk to BES Equipment.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>

Organization	Yes or No	Question 3 Comment
		<p>In addition, the Attachment 1 Events Table is incomplete as many of the listed events are incomplete regarding reporting time requirements and event descriptions.</p> <p><i>Attachment 1 has been revised to more clearly indicate reporting timelines and some of the event descriptions were changed to add clarity.</i></p> <p>Also recommend removing (ii) from note 5 with event “Destruction of BES equipment” as this part of the note is already described in the event description and insinuates reporting of equipment losses that do not have a reliability impact.</p> <p><i>This footnote has been deleted</i></p> <p>The events, “Damage or destruction of Critical Asset per CIP-002” and “Damage or destruction of a Critical Cyber Asset per CIP-002”, does not have sufficient clarity regarding what that represents. A note similar in nature to Note 5 for BES equipment is recommended.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Los Angeles Department of Water and Power</p>	<p>No</p>	<p>The reporting time of within 1 hour of recognition for a "Forced Intrusion" (last event category on page 20 of Draft 3, dated October 25, 2011) when considered with the associated footnote “Report if you cannot reasonably determine likely motivation” is overly burdensome and unrealistic. What is “reasonably determine likely motivation” is too general and requires further clarity. For example, LADWP has numerous facilities with extensive perimeter fencing. There is a significant</p>

Organization	Yes or No	Question 3 Comment
		<p>difference between a forced intrusion like a hole or cut in a property line fence of a facility versus a forced intrusion at a control house. Often cuts in fences, after further investigation, are determined to be cases of minor vandalism. An investigation of this nature will take much more than the allotted hour. The NERC Design Team needs to develop difference levels for the term “Force Intrusion” that fit the magnitude of the event and provide for adequate time to determine if the event was only a case of minor vandalism or petty thief. The requirement, as currently written, would unnecessarily burden an entity in reporting events that after given more time to investigate would more than likely not have been a reportable event.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Northeast Power Coordinating Council</p>	<p>No</p>	<p>The SDT should work with the NERC team drafting the Events Analysis Process (EAP) to ensure that the reporting events align and use the same descriptive language. EOP-004 should use the exact same events as OE-417. These could be considered a baseline set of reportable events. If the SDT believes that there is justification to add additional reporting events beyond those identified in OE-417, then the event table could be expanded. If the list of reportable events is expanded beyond the OE-417 event list, the supplemental events should be the same in both EOP-004-2 and</p>

Organization	Yes or No	Question 3 Comment
		<p>in the EAP Categories 1 through 5.</p> <p><i>OE-417 thresholds and reporting timelines were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America. Non-US Responsible Entities cannot be obligated to report in shorter timelines simply to make the two forms line up. The current in-force EOP-004 requires 24 hour reporting on the items you have identified and so does the latest version of EOP-004-2</i></li> <li><i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004.</i></p> <p>It is not clear what the difference is between a footnote and “Threshold for Reporting”. All information should be included in the body of the table, there should be no footnotes.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>Event: Risk to BES equipment should be deleted. This is too vague and subjective. This will result in many “prove the negative” situations.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>Event: Damage or Destruction of a Critical Asset or Critical Cyber Asset should be deleted. Disclosure policies regarding sensitive information could limit an entity’s ability to report. Unintentional damage to a CCA does not warrant a report.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Event: BES Emergency requiring public appeal for load reduction should be modified to note that this does not apply to routine requests for customer conservation during high load periods.</p> <p><i>The DSR SDT believes the current language of the event category ‘BES Emergency...’ clearly excludes routine conservation requests.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>The times don’t seem aggressive enough for some of the Events related to generation capacity shortages, e.g., we would think public appeal, system wide voltage reduction and manual firm load shedding ought to be within an hour. These are indicators that the BES is “on the edge” and to help BES reliability,</p>



Organization	Yes or No	Question 3 Comment
		<p>communication of this status is important to Interconnection-wide reliability.</p> <p><i>This standard concerns after-the-fact reporting. It is assumed that Responsible Entities will make appropriate real-time notifications as per other applicable standards, operating agreements, and good utility practice. This standard does not preclude a Responsible Entity from reporting more quickly than required by Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>NorthWestern Energy</p>	<p>Affirmative</p>	<p>In Attachment 1 NorthWestern Energy does not agree with the Transmission loss event, the threshold for reporting is “Unintentional loss of Three or more Transmission Facilities (excluding successful automatic reclosing).” There are lots of instances where this can happen and not have any major impacts to the BES. This reporting requirement is stemming from the Event Analysis Reporting Requirements and in many instances does not constitute an emergency.</p> <p><i>You are correct. This event is used as a trigger to the Events Analysis Process.</i></p> <p>Also, in Attachment 1 it is not clear when the DOE OE-417 form MUST be submitted. It give an option to use this form or another form but does not state when it must be used - confusing.</p> <p><i>For the purposes of EOP-004, Responsible Entities may use either Attachment 2 or OE-417. Submission of OE-417 to the DOE is mandatory for US entities and outside the scope of NERC. Giving you the option to submit OE-417 to NERC and your RC to satisfy EOP-004 is permitted as a matter of convenience so you don't have to submit two different forms for the same event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Rutherford EMC</p>	<p>Affirmative</p>	<p>The SDT should consider adding a clause in the standard exempting small DP/LSEs</p>

Organization	Yes or No	Question 3 Comment
		<p>from the standard if the DP/LSE annually reviews and approves that it owns no facilities or equipment creating an event as described in Attachment 1.</p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Fort Pierce Utilities Authority	Affirmative	<p>The triggering event “Detection of a reportable Cyber Security Incident” listed in Attachment 1 assigns essentially all utilities reporting responsibility. This is not in line its reporting threshold, which is an event meeting the criteria in CIP-008. Shouldn’t the responsibility fall on only those responsible for compliance with CIP-008, version 3 or 4, as determined by CIP-002? The SDT should also give additional consideration to necessary provisions to make it align with the proposed CIP-008-5.</p> <p><i>The ‘Entity with Reporting Responsibility’ has been changed to reflect your comment to ‘Each Responsible Entity applicable under CIP-008 that experiences the Cyber Security Incident.’</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Nebraska Public Power District	Yes	<p>Although 24 hours is a vast improvement, one business day would make more sense for after the fact reporting.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
FirstEnergy	Yes	<p>Although we agree with the timeframes for reporting, we have other concerns as listed in our response to Question 4.</p>
<p><b>Response: Thank you for your comment. Please see response to question 4.</b></p>		
Intellibind	Yes	<p>Does this reporting conflict with reporting for DOE, and Regions? If so, what reporting requirements will the entity be held accountable to? Managing multiple reporting requirements for the multiple agencies is very problematic for entities and this standard should resolve those reporting requirements, as well as reduce the reporting down to one form and one submission. Reporting to ESISAC should take care of all reporting by the company. NERC should route all reports to the DOE, and regions through this mechanism.</p> <p><i>OE-417 thresholds and reporting timelines were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America. Non-US Responsible Entities cannot be obligated to report in shorter timelines simply to make the two forms line up. NERC has no control over the criteria in OE-417, which can change at any time</i></li> </ul>

Organization	Yes or No	Question 3 Comment
		<p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. NERC cannot take on the statutory obligation of US entities to report to the DOE.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Dominion	Yes	<p>Dominion appreciates the changes that have been made to increase the 1 hr reporting time to 24 hours.</p>
<p><b>Response: Thank you for your comment.</b></p>		
APX Power Markets (NCR-11034)	Yes	<p>In my opinion the remaining items with 1 hour reporting requirements will in most cases require the input of in-complete information, since you maybe aware of the outage/disturbance, but not aware of any reason for it. If that is acceptable just to get the intial report that there was an outage/disturbance then we are OK. I believe it would help to have that clarified in the EOP, or maybe a CAN can be created for that.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions.</i></p>

Organization	Yes or No	Question 3 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Compliance &amp; Responsibility Office</p>	<p>Yes</p>	<p>See comments in response to Question 4.</p>
<p><b>Response: Thank you for your comment. See response to Question 4.</b></p>		
<p>Lower Colorado River Authority</p>	<p>Yes</p>	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>City of Austin dba Austin Energy</p>	<p>Yes</p>	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may</i></p>

Organization	Yes or No	Question 3 Comment
		<i>trigger further information requests from EAWG as necessary.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Public Utility District No. 1 of Snohomish County	Yes	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. The EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify if both forms will still be required to be submitted. We also need to ensure that there won’t be a duplication of efforts between the two reports. This is fairly minor, but the clarification need should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Seattle City Light	Yes	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the Event Analysis process, but there is some duplication of efforts. The EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify if both forms will still be required to be submitted. We also need to ensure that there won’t be a duplication of efforts between the two reports. This is fairly minor, but the clarification need should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		

Organization	Yes or No	Question 3 Comment
Salt River Project	Yes	<p>The proposed reporting form for EOP-004-2 is less extensive than the Brief Report required by the NERC Event Analysis process, but there is some duplication of efforts. EOP-004 has an “optional” Written Description section for the event, while the Brief Report requires more detailed information such as a sequence of events, contributing causes, restoration times, etc. Please clarify whether Registered Entities will still be required to submit both forms. Please also ensure there will not be duplication of efforts between the two reports. Although this is fairly minor, the clarification should be addressed.</p> <p><i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Constellation Energy on behalf of Baltimore Gas &amp; Electric, Constellation Power Generation, Constellation Energy Commodities Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.</p>	Yes	<p>We agree with the change to the reporting times in Attachment 1. While this is an improvement, other concerns with the language in the events table language remain. Please see additional details below: General items:</p> <ul style="list-style-type: none"> <li>o All submission instructions (column 4 in Events Table) should qualify the recognition of the event as “of recognition of event as a reportable event.”</li> </ul> <p><i>Column 4 has been deleted. The table headings now state that Responsible Entities must submit the report within X hours of recognition of event.</i></p> <ul style="list-style-type: none"> <li>o Is the ES-ISAC the appropriate contact for the ERO given that these two entities are separate even though they are currently managed by NERC?</li> </ul> <p><i>Yes. This is the current reporting contact and this is the advice that the DSR SDT team received from NERC.</i></p> <p>In addition, are the phone numbers in the Attachment 1 NOTE accurate? Is it possible they will change in a different cycle than the standard?</p>

Organization	Yes or No	Question 3 Comment
		<p><i>Yes. The standard will require updating should the phone number change.</i></p> <p>Specific Event Language: o Destruction of BES Equipment, footnote: Footnote 1, item iii confuses the clarification added in items i. and ii. Footnote 1 should be modified to state BES equipment that (i) an entity knows will affect an IROL or has been notified the loss affects an IROL; (ii) significantly affects the reserve margin of a Balancing Authority or Reserve Sharing Group. Item iii should be dropped.</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say “to a Facility’, (a defined term) and thresholds have be modified to provide clarity. Footnotes for this event have been deleted.</i></p> <p>o Damage or destruction of Critical Asset per CIP-002: Within the currently developing revisions to CIP-002 (version 5), Critical Asset will be retired as a glossary term. As well as addressing the durability of this event category, additional delineation is needed regarding which asset disruptions are to be reported. A CA as currently defined incorporates assets in a broad perspective, for instance a generating plant may be a Critical Asset. As currently written in Attachment 1, reporting may be required for unintended events, such as a boiler leak that takes a plant offline for a minor repair. Event #1 - Destruction of BES Equipment - captures incidents at the relevant equipment regardless of whether they are a Critical Asset or not. We recommend dropping this event. However, if reference to CIP-002 assets remains, it will be important to capture reporting of the events relevant to reliability and not just more events. o Damage or destruction of a Critical Cyber Asset per CIP-002: Because CCAs are defined at the component level, including this trigger is appropriate; however, as with CAs, the CCA term is scheduled to be retired under CIP-002 version 5.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately</i></p>



Organization	Yes or No	Question 3 Comment
		<p><i>addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>o Forced Intrusion: The footnote confuses the goal of including this event category. In addition, "forced" doesn't need to define the incident. Constellation proposes the following to better define the event: Intrusion that affects or attempts to affect the reliable operation of the BES (1)(1) Examples of "affecting reliable operation of the BES are": (i) device operations, (ii) protective equipment degradation, (iii) communications systems degradation including telemetered values and device status. o Risk to BES equipment: This category is too vague to be effective and the footnote further complicates the expectations around this event. The catch all concept of reporting potential risks to BES equipment is problematic. It's not clear what the reliability goal of this category is. Risk is not an event, it is an analysis. How are entities to comply with this "event", never mind within an hour? It appears that the information contemplated within this scenario would be better captured within the greater efforts underway by NERC to assess risks to the BES. This event should be removed from the Attachment 1 list in EOP-004.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' (which this footnote referenced) have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>o BES Emergency requiring system-wide voltage reduction: the Entity with Reporting Responsibility should be limited to RC and TOP.</p>

Organization	Yes or No	Question 3 Comment
		<p><i>Entity with Reporting Responsibility states 'Initiating entity is responsible for reporting', which the DSR SDT feels is adequate direction in conjunction with the event: BES Emergency requiring system-wide voltage reduction.</i></p> <p>o Voltage deviations on BES Facilities: The Threshold for Reporting language needs more detail to explain +/- 10% of what? Proposed revision: <math>\hat{\pm}</math> 10% outside the voltage schedule band sustained for <math>\hat{\%}\%¥</math> 15 continuous minutes</p> <p>o IROL Violation (all Interconnections) or SOL Violation (WECC only): Should "Interconnections" be capitalized?</p> <p>o Transmission loss: The reporting threshold should provide more specifics around what constitutes Transmission Facilities. One minor item, under the Threshold for Reporting, "Three" does not need to be capitalized.</p> <p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Pacific Northwest Small Public Power Utility Comment Group</p>	<p>Yes</p>	<p>While we agree with the revisions as far as they went, we do not believe the SDT has adequately addressed the FERC Order to "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely "recognition" starts the clock and reporting will become a higher priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Clallam County PUD No.1</p>	<p>Yes</p>	<p>While we agree with the revisions as far as they went, we do not believe the SDT has adequately addressed the FERC Order to "Consider whether separate, less burdensome requirements for smaller entities may be appropriate." The one and 24 hour reporting requirements continue to be burdensome to the smaller entities that do not maintain 24/7 dispatch centers. The one hour reporting requirement means that an untimely "recognition" starts the clock and reporting will become a higher priority than restoration. The note regarding adverse conditions does not help unless we were to consider the very lack of 24/7 dispatch to be such a condition.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category 'A physical threat that could impact the operability of a Facility' the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p><i>The DSR SDT believes that reliability is best served by imposing reporting criteria based on impact to the BES rather than an arbitrary entity size threshold. With these latest revisions, all the proposed event categories provide thresholds that will capture the appropriate entities and provide a manageable timeframe.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Illinois Municipal Electric Agency	Yes	With the understanding this is within 24 hrs., and good professional judgment determines the amount of time to report the event to appropriate parties.
<p><b>Response: Thank you for your comment.</b></p>		
Ingleside Cogeneration LP	Yes	<p>Yes. Any reporting that is mandated during the first hour of an event must be subject to close scrutiny. Many of the same resources that are needed to troubleshoot and stabilize the local system will be engaged in the reporting - which will impair reliability if not carefully applied. We believe that the ERO should reassess the need for any immediate reporting requirements on a regular basis to confirm that it provides some value to the restoration process.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706,</i></p>

Organization	Yes or No	Question 3 Comment
		<p><i>Paragraph 673:</i></p> <p><i>“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1. Also, Attachment 1 provides the flexibility to make a verbal report under adverse conditions. For the revised event category ‘A physical threat that could impact the operability of a Facility’ the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Southwest Power Pool Regional Entity	Yes	
ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi	Yes	
MRO NSRF	Yes	
Western Electricity Coordinating Council	Yes	
Imperial Irrigation District	Yes	

Organization	Yes or No	Question 3 Comment
ACES Power Marketing Standards Collaborators	Yes	
Santee Cooper	Yes	
Sacramento Municipal Utility District (SMUD)	Yes	
Electric Compliance	Yes	
PacifiCorp	Yes	
Arizona Public Service Company	Yes	
Westar Energy	Yes	
Springfield Utility Board	Yes	
Manitoba Hydro	Yes	
Xcel Energy	Yes	
Liberty Electric Power	Yes	
Colorado Springs Utilities	Yes	
Independent Electricity System Operator	Yes	
South Carolina Electric and	Yes	

Organization	Yes or No	Question 3 Comment
Gas		
ISO New England	Yes	
American Transmission Company, LLC	Yes	
PSEG	Yes	
American Electric Power	Yes	
Georgia System Operations Corporation	Yes	
NV Energy	Yes	
Occidental Power Services, Inc. (OPSI)	Yes	
Northeast Utilities	Yes	
Great River Energy	Yes	
Oncor Electric Delivery Company LLC	Yes	
PPL Electric Utilities and PPL Supply Organizations`		
Progress Energy		

Organization	Yes or No	Question 3 Comment
Texas Reliability Entity		
ReliabilityFirst		
NRECA		
Entergy Services		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		



4. Do you have any other comment, not expressed in questions above, for the DSR SDT?

**Summary Consideration:** The issues addressed in this question resulted in the DSR SDT reviewing and updating each requirement, Attachment 1 and Attachment 2. The DSR SDT has removed ambiguous language such as “risk” and “potential” based on comments received. All of the time frames in Attachment 1 have been moved to 24 hours upon recognition with the exception to reporting of CIP-008 events that remains one hour per FERC Order 706. Attachment 2 has been rewritten to mirror Attachment 1 events for entities who wish to use Attachment 2 in lieu of the DOE Form OE 417. VSLs have been reviewed to match the updated requirements.

Organization	Yes or No	Question 4 Comment
Cleco Corporation, Cleco Power, Cleco Power LLC	Abstain	Cleco does not use the VSL or VRF.
<b>Response: Thank you for your comment</b>		
Oklahoma Gas and Electric Co.	Abstain	Please see comments on SPP ballot
<b>Response: Thank you for your comment. See response to those comments.</b>		
Alberta Electric System Operator	Abstain	The Alberta Electric System Operator will need to modify parts of this standard to fit the provincial model when it develops the Alberta Reliability Standard.
<b>Response: Thank you for your comment.</b>		
Gainesville Regional Utilities	Affirmative	Looking forward to the added clarity.
<b>Response: Thank you for your comment.</b>		

Organization	Yes or No	Question 4 Comment
Manitoba Hydro	Affirmative	<p>Manitoba Hydro is voting affirmative but would like to point out the following issues:                      -Attachment 1: The term ‘Transmission Facilities’ used in Attachment 1 is capitalized, but it is not a defined term in the NERC glossary. The drafting team should clarify what is meant by ‘Transmission Facilities’ and remove the capitalization. –</p> <p><i>The DSR SDT has reviewed the NERC Glossary of Terms and notes that Transmission and Facilities are both defined. The combination of these two definitions are what the DSR SDT has based the applicability of “Transmission Facilities” in Attachment 1.</i></p> <p>Attachment 2: The inclusion of ‘fuel supply emergency’ in Attachment 2 creates confusion as it infers that reporting a ‘fuel supply emergency’ may be required by the standard even though it is not listed as a reportable event in Attachment 1. On a similar note, it is not clear what the drafting team is hoping to capture by including a checkbox for ‘other’ in Attachment 2.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Oncor Electric Delivery	Affirmative	<p>NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC consider ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.</p> <p><i>The reporting of events as required in EOP-004 is the input to the Events Analysis Program. Events are reported to the ERO and the EAP will follow up as per the EAP processes and procedures.</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>City Utilities of Springfield, Missouri</p>	<p>Affirmative</p>	<p>SPRM supports the comments from SPP.</p>
<p><b>Response: Thank you for your comment. Please see response to comments from SPP.</b></p>		
<p>Kootenai Electric Cooperative</p>	<p>Affirmative</p>	<p>The changes are an improvement over the existing standards.</p>
<p><b>Response: Thank you for your comment.</b></p>		
<p>Empire District Electric Co.</p>	<p>Affirmative</p>	<p>We agree with the comments provided by SPP</p>
<p><b>Response: Thank you for your comment. Please see response to SPP comments.</b></p>		
<p>Lakeland Electric</p>	<p>Negative</p>	<p>1. Further clarity is needed. For example the standard stipulates in R1.3 ".as appropriate." Who deems what is appropriate? Also in R1.4 ".other circumstances" is open to interpretation.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase "as appropriate" and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity's Operating Plan.</i></p> <p><i>Requirement R1, Part 1.4 was removed from the standard</i></p> <p>2. Remove paragraph 1 of the data retention section as it parrots the Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2. Possibly place a pointer to the CMEP in the data retention section.</p> <p><i>The item in question is standard boilerplate language that is being placed in all NERC standards.</i></p>

Organization	Yes or No	Question 4 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>CPS Energy</p>	<p>Negative</p>	<p>oR1.4: CPS Energy believes that “updating the Operating Plan within 90 calendar days of any change...” is a very burdensome compliance documentation requirement.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p> <p>oAttachment 1: Events Table: In DOE OE-417 local electrical systems with less than 300MW are excluded from reporting certain events since they are not significant to the BES. CPS Energy believes that the benefit of reporting certain events on systems below this value would outweigh the compliance burden placed on these small systems.</p> <p><i>Upon review of the DOE OE 417, it states “Local Utilities in Alaska, Hawaii, Puerto Rico, the U.S. Virgin Islands, and the U.S. Territories - If the local electrical system is less than 300 MW, then only file if criteria 1, 2, 3 or 4 are met”. Please be advised this exception applies to entities outside the continental USA.</i></p>
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Lakeland Electric</p>	<p>Negative</p>	<p>An issue of possible differences in interpretation between entities and compliance monitoring and enforcement is the phrase in 1.3 that states “the following as appropriate”. Who has the authority to deem what is appropriate?</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to communicate events to as stated in the entity’s Operating Plan</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Dynegy Inc.; Southern Illinois Power Coop.; Louisville Gas and Electric Co.</p>	<p>Negative</p>	<p>Comments submitted as part of the SERC OC; I agree with the comments of the SERC OC Standards Review group that have been provided to NERC.; We are a signatory to the SERC OC RRG comments filed last week.</p>
<p><b>Response: Thank you for your comment. Please see response to the SERC OC RRG comments.</b></p>		
<p>Hydro One Networks, Inc.</p>	<p>Negative</p>	<p>First and foremost we are not supportive of continuance of standards that are not "results based". Standards written to gather data, make reports etc. should not be written. There should be other processes for reporting in place that will not be subject to ERO oversight and further compliance burdens.</p> <p><i>The DSR SDT has been following the guidance set by NERC to write a "results based" standard. As with any process there may be many different ways to achieve the same outcome. The NERC Quality Process has not indicated any request to update this Standard, concerning the Results Based Standard format.</i></p> <p>o We are disappointed that the standard does not appear to reduce reporting requirements nor does it promote more efficient reporting. We encourage the SDT to take a results based approach and coordinate and reduce reporting through efficiencies between the various agencies and NERC.</p> <p><i>The DSR SDT is staying within scope of the approved SAR and will be forwarding your concern of efficiencies between various agencies and NERC</i></p> <p>o The Purpose statement is very broad, and "...by requiring the reporting of events with the potential to impact reliability and their causes..." on the Bulk Electric System it can be said that every event occurring on the Bulk Electric System would have to be reported. There is already an event analysis process in place. Could this reporting</p>

Organization	Yes or No	Question 4 Comment
		<p>be effectively performed in that effort?</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i></p> <p style="padding-left: 40px;"><i>“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”</i></p> <p>o The standard prescribes different sets of criteria, and forms.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>o There should be one recipient of event information. That recipient should be a</p>

Organization	Yes or No	Question 4 Comment
		<p>“clearinghouse” to ensure the proper dissemination of information.</p> <p><i>The DSR SDT is proposing revisions to the NERC Rules of Procedure that address your comment:</i></p> <p><i>812. NERC Reporting Clearinghouse</i>  <i>NERC will establish a system to collect report forms as established for this section or standard, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations.</i></p> <p>o Why is this standard applicable to the ERO?</p> <p><i>The ERO is applicable to CIP-008 and therefore is applicable to this proposed Standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>FirstEnergy Corp., FirstEnergy Energy Delivery, FirstEnergy Solutions, Ohio Edison Company</p>	<p>Negative</p>	<p>FirstEnergy appreciates the hard work of the drafting team and believes it has made great improvements to the standards. However, we must vote negative at this time until a few issues are clarified per our comments submitted through the formal comment period.</p>
<p><b>Response: Thank you for your comment. Please see response to your other comments.</b></p>		
<p>Lakeland Electric</p>	<p>Negative</p>	<p>In general; here has not been sufficient prudence review for the standard, especially R1, to justify a performance based standard around a Frequency Response Measure</p> <p><i>Based on your short comment, Requirement 1 has been modified as requested by stakeholders. The DSR SDT cannot answer the issue of Frequency Response Measures</i></p>

Organization	Yes or No	Question 4 Comment
		<i>since it is not within the scope of the SAR.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Northeast Power Coordinating Council	Negative	NPCC believes that further revision of the standard is necessary so is not able to support the VSLs at this time. Comments to the standard will be made in the formal comment period.
<b>Response: Thank you for your comment. Please see responses to your other comments.</b>		
Central Lincoln PUD; Blachly-Lane Electric Co-op; Central Electric Cooperative, Inc. (Redmond, Oregon); Clearwater Power Co.; Consumers Power Inc.; Coos-Curry Electric Cooperative, Inc; Fall River Rural Electric Cooperative; Lane Electric Cooperative, Inc.; Northern Lights Inc.; Pacific Northwest Generating Cooperative; Raft River Rural Electric Cooperative; Umatilla Electric Cooperative; West Oregon Electric Cooperative, Inc.; Cowlitz County PUD	Negative	Please see comments submitted by the Pacific Northwest Small Public Power Utility Comment Group.
<b>Response: Thank you for your comment. Please see responses to comments of the Pacific Northwest Small Public Power Utility</b>		



Organization	Yes or No	Question 4 Comment
<b>Comment Group.</b>		
Rochester Gas and Electric Corp.	Negative	RG&E supports comments to be submitted to NPCC.
New Brunswick System Operator	Negative	See comments submitted by the NPCC Reliability Standards Committee and the IRC Standards Review Committee.
Florida Municipal Power Pool	Negative	See FMPPA's comments
<b>Response: Thank you for your comment. See responses to those comments.</b>		
Commonwealth of Massachusetts Department of Public Utilities	Negative	<p>Standards written to gather data, make reports etc. should not be written. There should be other processes for reporting in place that will not be subject to ERO oversight and further compliance burdens.</p> <p><i>FERC Order 693 section 617 states "...the Commission directs the ERO to develop a modification to EOP-004-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the Bulk-Power System to provide data...". In order for entities to provide data they are required to implement their Operating Plan. EOP-004-2 will satisfy this FERC directive.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Hydro One Networks, Inc.	Negative	<p>Suggested key concepts for the SDT consideration in this standard: ? Develop a single form to report disturbances and events that threaten the reliability of the bulk electric system ? Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements ? Establish clear criteria for reporting ?</p> <p><i>The DSR SDT has only provided one form within this proposed Standard, please see</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 2. Based on stakeholder feedback, the DSR SDT has allowed stakeholders to use the DOE Form OE 417. Please note that not every Stakeholder in NERC wishes to use the DOE Form OE 417.</i></p> <p>Establish consistent reporting timelines ?</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>Provide clarity around who will receive the information and how it will be used ? Explore other opportunities beside a standard to effectively achieve the same outcome. Standards should be strictly results based, whose purpose is to achieve an adequate level of reliability on the BES.</p> <p><i>The DSR SDT has clearly stated who will receive the information: Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase "as appropriate" and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:</i></p> <p><i>"1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p><i>The information received will be mainly used for situational awareness and other processes.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Orlando Utilities Commission	Negative	<p>The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes, as well as the CIP standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist. As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
James A Maenner	Negative	<p>The information in section “5 Background” should be moved from the standard to a supporting document.</p> <p><i>The DSR SDT will refer to guidance within the Standards Development process on the proper place to maintain Background information.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>The reporting exemption language for weather in the Note on Attachment 1 - Events Table should be included in R3, not just a note.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p>The “Guideline and Technical Basis”, last 3 pages, should be moved from the standard to a supporting document.</p> <p><i>The Guideline and Technical Basis section is a part of the Results-Based Standard format and the information contained in it is in the correct place.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Kansas City Power &amp; Light Co.</p>	<p>Negative</p>	<p>The proposed Standard is in need of additional work to complete the Attachment 1, complete the VSL's, and clarify language and content within the proposed standard.</p> <p><i>The DSR SDT has reviewed and revamped all Requirements and both Attachments based on stakeholders feedback. This will provide clarity for entities to follow.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 4 Comment
SERC Reliability Corporation	Negative	<p>The purpose of the standard "To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events with the potential to impact reliability and their causes, if known, by the Responsible Entities" has not been achieved as written. There is the potential for the information and data contemplated by this standard to be useful in achieving the stated purpose through follow-on activities of the industry, the regions, and NERC. However, as drafted, Attachment 1 will inform the ERO of the existence of only a portion of the "events with the potential to impact reliability and their causes, if known".</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></p> <p>Events listed in Appendix E to the ERO Event Analysis Process document should be incorporated into the standard instead of hardwiring inconsistency by requiring a different set of events. Alternatively, the SDT should explore deleting Attachment 1 and instead referencing the ERO Event Analysis process (which as a learning organization will have systematic changes to the reporting thresholds over time). At first this may seem contrary to the SDT objective of eliminating fill-in-the-blank aspects of the existing standard but the SDT should explore the Commission's willingness to accept a reference document for reporting thresholds. Additionally, it is unclear how NERC's role as the ES-ISAC is supported through the requirements of this reliability standard. It appears to undermine the ability of NERC (ES-ISAC) to be made timely aware of threats to the critical infrastructure--at odds with its purpose. Thus, this draft does not achieve the elimination of redundant reporting envisioned in the SAR, nor does it achieve the objective of supporting NERC in the analysis of disturbances or blackouts.</p> <p><i>The DSR SDT is following NERC's ANSI approved process for standards development.</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>The ERO Events Analysis process does not have the frame work as required by the ANSI development process. Within this proposed Standard, when an Attachment 1 event is recognized, the ERO (which is the ES-ISAC) will be one of the first to be notified, as will the entities Reliability Coordinator. This will enhance situational awareness as per the entity’s Operation Plan and this Standard.</i></p> <p><i>FERC Order 693 section 617 states “...the Commission directs the ERO to develop a modification to EOP-004-1 through the reliability Standards development process that includes any Requirement necessary for users, owners, and operators of the Bulk-Power System to provide data...”. In order for entities to provide data they are required to implement their Operating Plan. EOP-004-2 will satisfy this FERC directive.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Tucson Electric Power Co.	Negative	<p>The tie between an Operating Plan and reportable disturbance events is not clear. Being the exception, I feel that a reportable disturbance methodology should be part of an Emergency Operating Plan.</p> <p><i>EOP-004-2 provides Applicable Entities with the minimum report requirements for events contained in Attachment 1. NERC has defined Operating Plan in part as: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes." An entity may include a reportable disturbance methodology within their Operating Plan since this Standard does not preclude it.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
United Illuminating Co.	Negative	The VSL table is mistyped. R2 lists 1.1 and 1.5. R4 VRF should be lower.

Organization	Yes or No	Question 4 Comment
		<i>Requirement R4 (now R3) calls for conducting an annual test of the communications process in Requirement 1, Part 1.2. It is not strictly administrative in nature and therefore does not meet the VRF guideline for a Lower VRF. .</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
PSEG Energy Resources & Trade LLC, PSEG Fossil LLC, Public Service Electric and Gas Co.	Negative	There are several items that need clarification. See PSEG's separately provided comments.
<b>Response: Thank you for your comment. Please see response to your other comments.</b>		
Kansas City Power & Light Co.	Negative	There is no VSL for R4.  <i>The VSL for Requirement R4 was inadvertently redlined in the redline version of the standard, but it was present in the clean version.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Ameren Services	Negative	We believe that these [VRFs and VSLs] will change as we expect some changes in the draft standard.
<b>Response: Thank you for your comment.</b>		
New York State Department of Public Service	Negative	While the proposed standard consolidates many reporting requirements, the requirement that any event with the "potential to impact reliability" be reported is overly broad and will prove to be burdensome and distracting to system operations.  <i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i>

Organization	Yes or No	Question 4 Comment
		<p><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Springfield Utility Board		<p>o The Draft 3 Version History still lists the term "Impact Event" instead of "Event". <i>This has been corrected.</i></p> <p>o Draft 3 of EOP-004-2 - Event Reporting does not provide a definition for the term "Event" nor does the NERC Glossary of Terms Used in Reliability Standards. SUB recommends that "Event" be listed and defined in "Definitions and Terms Used in the Standard" as well as the NERC Glossary, providing a framework and giving guidance to entities for how to determine what should be considered an "Event" (ex: sabotage, unusual occurrence, metal theft, etc.).</p> <p><i>The DSR SDT has reviewed this issue and has changed "Event" to "event". Attachment 1 contains each reportable 'event'.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Northeast Utilities		<p>- Incorporate NERC Event Analysis Reporting into this standard. Make the requirements more specific to functional registrations as opposed to having requirements applicable to "Responsible Entities".- The description of a Transmission Loss Event in A</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1. The DSR SDT has reviewed and reworded "Entities with Reporting Responsibilities" to require the minimum amount of entities who will be required to report each event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		



Organization	Yes or No	Question 4 Comment
Progress Energy		<p>(1) Attachment 1 lists “Destruction of BES Equipment” as a reportable event but then lists “equipment failure” as one of several thresholds for reporting, with a one hour time limit for reporting. It is simply not common sense to think of the simple failure of a single piece of equipment as “destruction of BES equipment”. Does the standard really expect that every BES equipment failure must be reported within one hour, regardless of cause or impact to BES reliability? What is the purpose of such extensive reporting?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> </ul> <p>(2) The same comment as (1) above is applicable to the “Damage or destruction of Critical Asset” because one threshold is simple “equipment failure” as well.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>(3) Footnote 2 (page 20) says copper theft is not reportable “unless it effects the reliability of the BES”, but footnote 1 on the same page says copper theft is reportable if “it degrades the ability of equipment to operate properly”. In this instance, the proposed standard provides two different criteria for reporting one of the most common events on the same page.</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “A physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>(4) Forced Intrusion must be reported if “you cannot determine the likely motivation”, and not based on a conclusion that the intent was to commit sabotage or intentional damage. This would require reporting many theft related instances of cut fences and forced doors (including aborted theft attempts where nothing is stolen) which would consume a great deal of time and resources and accomplish nothing. This criteria is exactly the opposite of the existing philosophy of only reporting events if there is an indication of an intent to commit sabotage or cause damage.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p>(5) “Risk to BES equipment...from a non-environmental physical threat” is reportable, but this is an example of a vague, open ended reporting requirement that will either</p>

Organization	Yes or No	Question 4 Comment
		<p>generate a high volume of unproductive reports or will expose reporting entities to audit risk for not reporting potential threats that could have been reported. The standard helpfully lists train derailments and suspicious devices as examples of reportable events.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p>The existing CAN for CIP-001 (CAN-0016) is already asking for a list of events that were analyzed so the auditors can determine if a violation was committed due to failure to report. I can envision the CAN for this new standard requiring a list of all “non-environmental physical threats” that were analyzed during the audit period to determine if applicable events were reported. This could generate a great deal of work simply to provide audit documentation even if no events actually occur that are reportable. It would also be easy for an audit team to second guess a decision that was made by an entity not to report an event (what is risk?...how much risk was present due to the event?...). Also, the reporting for this vague criteria must be done within one hour. Any event with a one hour reporting requirement should be crystal clear and unambiguous.</p> <p><i>The DSR SDT has reworded and updated Attachment 1 per comments received and believes that the language used obviates the need for CAN-016. CAN-0016 has been</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>remanded.</i></p> <p>(6) Transmission Loss...of three or more Transmission Facilities” is reportable. “Facility” is a defined term in the NERC Glossary, but “Transmission Facility” is not a defined term, which will lead to confusion when this criteria is applied. This requirement raises many confusing questions. What if three or more elements are lost due to two separate or loosely related events - is this reportable or not? What processes will need to be put in place to count elements that are lost for each event and determine if reporting is required? Why must events be reported that fit an arbitrary numerical criteria without regard to any material impact on BES reliability?</p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:</i></p> <p style="text-align: center;"><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
MRO NSRF		<p>: The MRO NSRF wishes to thank the SDT for incorporating changes that the industry had with reporting time periods and aligning this with the Events Analysis Working Group and Department of Energy’s OE 417 reporting form.</p>

Organization	Yes or No	Question 4 Comment
<p>Response: Thank you for your comment.</p>		
<p>FirstEnergy</p>		<p>1. Attachment 1 - Regarding the 1st event listed in the table, “Destruction of BES Equipment” and its accompanying Footnote 1, we believe that this event should be broken into two separate events that incorporate the specifics in the footnote as follows: a. “Destruction of BES equipment that associated with an IROL per FAC-014-2.” Regarding the 1st event we have proposed - We have proposed this be made specific to IROL as stated in Footnote 1 part i. Also, we believe that only the RC and TOP would have the ability to quickly determine and report within 1 hour if the destruction is associated with an IROL. The other entities listed would not necessarily know if the event affects and IROL. Therefore, we also propose that the Entities with Reporting Responsibilities (column 2) be revised to only include the RC and TOP.</p> <p><i>The DSR SDT agrees with your comment and made the following changes:</i></p> <p><i>‘Threshold for Reporting’ column in the ‘Damage or Destruction’ event category. The updated Threshold for Reporting now reads as:</i></p> <p><i>“Damage or destruction of a Facility that:</i></p> <ul style="list-style-type: none"> <li><i>• Affects an IROL (per FAC-014)</i></li> <li><i>OR</i></li> <li><i>• Results in the need for actions to avoid an Adverse Reliability Impact</i></li> <li><i>OR</i></li> <li><i>• Results from intentional human action.”</i></li> </ul> <p>b. "Destruction of BES equipment that removes the equipment from service." Regarding the 3rd event we have proposed - We have proposed this be made specific to destruction of BES equipment that removes the equipment from service as stated in Footnote 1 part iii. Also, the other part of footnote 1 part iii which states “Damaged or destroyed due to intentional or unintentional human action” is not</p>

Organization	Yes or No	Question 4 Comment
		<p>required since it is covered in the threshold for reporting. Also the term “Damaged” in this part iii is not appropriate since these events are limited to equipment that has been destroyed. We also propose that the Entities with Reporting Responsibilities (column 2) for this event would remain the same as it states now since any of those entities may observe out of service BES equipment. Regarding part ii of footnote 1, we do not believe that this event needs to be separated. Regarding the phrase “significantly affects the reliability margin of the system be clarified so that it is not left up to the entity to interpret a “significant” affect. Lastly, since we have incorporated parts i and iii into the two separate events and removed part ii as proposed above, the only statement that needs to be left in the Footnote 1 is: “Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).”</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “Any physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>2. Attachment 1 - We ask that the team add an “Event #” column to the table so that each of the events listed can be referred to by #, such as Event 1, Event 2, etc.</p> <p><i>The DSR SDT believes that the minimum reporting attributes are contained in Attachment 1.</i></p> <p>3. Attachment 1 - Event titled “Damage or destruction of a Critical Cyber Asset per</p>

Organization	Yes or No	Question 4 Comment
		<p>CIP-002”, the proposed threshold for reporting seems incomplete. We suggest the threshold for this event match the threshold for the Critical Asset event which states: “Initial indication the event was due to operational error, equipment failure, external cause, or intentional or unintentional human action.”4. Attachment 1 - Events titled “Damage or destruction of a Critical Assets per CIP-002” and “Damage or destruction of a Critical Cyber Asset per CIP-002” seem ambiguous due to the term “damage”. We suggest removal of “damage” or clarity as to what is considered a damaged asset.5. VSL Table - Instead of listing every entity, it may be more efficient to simply say “The Responsible Entity” in the VSL for each requirement.6. Guideline and Technical Basis section - This section does not provide guidance on each of the requirements of the standard. We suggest the team consider adding guidance for the requirements.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Southwest Power Pool Regional Entity</p>		<p>1. EOP-004-2 R1.4 states entities must update their Operating Plans within 90 calendar days of incorporating lessons learned pursuant to R3. However, neither R3 nor Attachment 1 include a timeline for incorporating lessons learned. It is unclear when the “clock starts” on incorporating improvements or lessons learned. Within 90 days of what? 90 days of the event? 90 days from when management approved the lesson learned? Auditors need to know the trigger for the 90-day clock.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p> <p>2. The Event Analysis classification includes Category 1C “failure or misoperation of</p>

Organization	Yes or No	Question 4 Comment
		<p>the BPS SPS/RAS". This category is not included in EOP-004-2's Attachment 1. This event, "failure or misoperation of the BPS SPS/RAS", needs to either be added to Attachment 1 or removed from the Event Analysis classification. It is important that EOP-004-2 Attachment 1 and the Event Analysis categories match up. Thank you for your work on this standard.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Independent Electricity System Operator</p>		<p>1. Measures M1, M2 and M3: Suggest to achieve consistent wording among them by saying the leading part to "Each Responsible Entity shall provide...."</p> <p><i>The DSR SDT is following the guidance within the Standards Development process on</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>the wording pertaining to items outside the realm of a requirement.</i></p> <p>2. In our comments on the previous version, we suggested the SDT to review the need to include IA, TSP and LSE for some of the reporting requirements in Attachment 1. The SDT’s responded that it had to follow the requirements of the standards as they currently apply. Since these entities are applicable to the underlying standards identified in Attachment 1, they will be subject to reporting. We accept this rationale. However, the revised Attachment 1 appears to be still somewhat discriminative on who needs to report an event. For example, the event of “Detection of a reportable Cyber Security Incident” (6th row in the table) requires reporting by a list of responsible entities based on the underlying requirements in CIP-008, but the list does not include the IA, TSP and LSE. We again suggest the SDT to review the need for listing the specific entities versus leaving it general by saying: “Applicable Entities under CIP-008” for this particular item, and review and establish a consistent approach throughout Attachment 1.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008.</i></p> <p>3. VSLs: a. Suggest to not list all the specific entities, but replace them with “Each Responsible Entity” to simplify the write-up which will allow readers to get to the violation condition much more quickly. b. For R1, it is not clear whether the conditions listed under the four columns are “OR” or “AND”. We believe it means “OR”, but this needs to be clarified in the VSL table.4. The proposed implementation plan conflicts with Ontario regulatory practice respecting the effective date of the standard. It is suggested that this conflict be removed by appending to the implementation plan wording, after “applicable regulatory approval” in the Effective Dates Section on P. 2 of the draft standard and P. 1 of the draft implementation plan, to the following effect: “, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.”</p> <p><i>The DSR SDT is following the guidance within the Standards Development process on</i></p>

Organization	Yes or No	Question 4 Comment
		<i>the wording pertaining to items outside the realm of a requirement.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
NRECA		<p>1. Please ensure that the work of the SDT is done in close coordination with Events Analysis Process (EAP) work being undertaken by the PC/OC and BOT, and with any NERC ROP additions or modifications. NRECA is concerned that the EAP work being done by these groups is not closely coordinated even though their respective work products are closely linked -- especially since the EAP references information in EOP-004.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an opportunity not a 'must-have'</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>2. The SDT needs to be consistent in its use of "BES" and "BPS" - boths acronyms are used throughout the SDT documents. NRECA strongly prefers the use of "BES" since that is what NERC standards are written for.</p> <p><i>The DSR SDT has used BES within EOP-004-2. All references to BPS have been removed.</i></p> <p>3. Under "Purpose" section of standard, 3rd line, add "BES" between "impact" and "reliability." Without making this change the "Purpose" section could be misconstrued to refer to reliability beyond the BES.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><b><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></b></p> <p>4. In the Background section there is reference to the Events Analysis Program. Is that the same thing as the Events Analysis Process? Is it something different? Is it referring to a specific department at NERC? Please clarify in order to reduce confusion. Also in the Background section there is reference to the Events Analysis Program personnel. Who is this referring to -- NERC staff in a specific department? Please clarify.</p> <p><i>The DSR SDT was explaining that the DSR SDT and has been coordinating with the "Events Analysis Working Group.</i></p> <p>5. In M1 please be specific regarding what "dated" means.</p> <p><i>This is a common term used with many NERC Standards and simply means that your evidence is dated and time stamped.</i></p> <p>6. In M3 please make it clear that if there wasn't an event, this measure is not applicable</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has not implied that Applicable Entities need to prove that something did not happen.</i></p> <p>7. In R4 it is not clear what “verify” means. Please clarify.</p> <p><i>R4 (now R3) was revised to remove “verify”</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p>8. In Attachment 1 there are references to Critical Asset and Critical Cyber Asset. These terms will likely be eliminated from the NERC Glossary of Terms when CIP V5 moves forward and is ultimately approved by FERC. This could create future problems with EOP-004 if CIP V5 is made effective as currently drafted.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008.</i></p> <p>9. In Attachment 1 the one hour timeframe for submitting data for the first 7 items listed is very tight. Other than being required by the EOE )E-417 form, NRECA requests that the SDT provide further support for this timeframe. If there are not distinct reasons why 1 hour is the right timeframe for this, then other timeframes should be explored with DOE.</p> <p><i>The DSR SDT also received many comments regarding the various events of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO and their Reliability Coordinator within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is “A reportable Cyber</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Security Incident” as it required by CIP-008.</i></p> <p><i>FERC Order 706, paragraph 673 states: “...each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but, in any event within one hour of the event...”</i></p> <p><i>Note that members of NRECA may be required to submit the DOE Form OE 417, and this agency’s reporting requirements are not within scope of the project.</i></p> <p>10. While including Footnote 1 is appreciated, NRECA is concerned that this footnote will create confusion in the compliance and audit areas and request the SDT to provide more definitive guidance to help explain what these "Events" refer to. NRECA has the same comment on Footnote 2 and 3. Specifically in Footnote 3, how do you clearly determine and audit from a factual standpoint something that “could have damaged” or “has the potential to damage the equipment?”</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “A physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>11. In the Guideline and Technical Basis section, in the 1st bullet, how do you determine, demonstrate and audit for something that “may impact” BES reliability?</p> <p><i>This statement has been removed per comments received.</i></p> <p>12. On p. 28, first line, this sentence seems to state that NERC, law enforcement and other entities - not the responsible entity - will be doing event analysis. My understanding of the current and future Event Analysis Process is that the</p>

Organization	Yes or No	Question 4 Comment
		<p>responsible entity does the event analysis. Please confirm and clarify.</p> <p><i>EOP-004-2 requires Applicable Entities to “report “ and “communicate” as stated in Requirement 1, Part 1.2: “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p><i>The Event Analysis Program may use a reported event as a basis to analyze an event. The processes of the Event Analysis Program fall outside the scope of this project, but the DSR SDT has collaborated with them of events contained in Attachment 1.</i></p> <p><i>The Standard does not require the Applicable Entity to analyze a reported event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Exelon</p>		<p>1. Please replace the text “Operating Plan” with procedure(s). Many companies have procedure(s) for the reporting and recognition of sabotage events. These procedures extend beyond operating groups and provide guidance to the entire company.</p> <p><i>Thank you for your comment. The DSR SDT intends on keeping “Operating Plan” within EOP-004-2 since NERC has it defined as:</i></p> <p><i>“A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan”. As stated, the Operating Plan may contain Operating procedures or Operating Processes. This will give Applicable Entities the greatest flexibility in achieving compliance with this Standard.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>2. The Loss of Off-site power event criteria is much improved from the last draft of EOP 004-2; however, some clarification is needed to more accurately align with NERC Standard NUC-001 in both nomenclature and intent. Specifically, as Exelon has previously commented, there are many different configurations supplying offsite power to a nuclear power plant and it is essential that all configurations be accounted for. As identified in the applicability section of NUC-001 the applicable transmission entities may include one or more of the following (TO, TOP, TP, TSP, BA, RC, PC, DP, LSE, and other non-nuclear GO/GOPs). Based on the response to previous comments submitted for Draft 2, Exelon understands that the DSR SDT evaluated the use of the word “source” but dismissed the use in favor of “supply” with the justification “[that] ‘supply’ encompasses all sources”. Exelon again suggests that the word “source” is used as the event criteria in EOP-004-2 as this nomenclature is commonly used in the licensing basis of a nuclear power plant. By revising the threshold criteria to “one or more” Exelon believes the concern the DSR SDT noted is addressed and ensures all sources are addressed. In addition, by revising the threshold for reporting to a loss of “one or more” will ensure that all potential events (regardless of configuration of off-site power supplies) will be reported by any applicable transmission entity specifically identified in the nuclear plant site specific NPIRs. As previously suggested, Exelon again proposes that the loss of an off-site power source be revised to an “unplanned” loss to account for planned maintenance that is coordinated in advance in accordance with the site specific NPIRs and associated Agreements. This will also eliminate unnecessary reporting for planned maintenance. Although the loss of one off-site power source may not result in a nuclear generating unit trip, Exelon agrees that an unplanned loss of an off-site power source regardless of impact should be reported within the 24 hour time limit as proposed. Suggest that the Loss of Offsite power to a nuclear generating plant event be revised as follows: Event: Unplanned loss of any off-site power source to a Nuclear Power Plant Entity with Reporting Responsibility: The applicable Transmission Entity that owns and/or operates the off-site power source to a</p>

Organization	Yes or No	Question 4 Comment
		<p>Nuclear Power Plant as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) and associated Agreements. Threshold for Reporting: Unplanned loss of one or more off-site power sources to a Nuclear Power Plant per the applicable NPIRs.</p> <p><i>Based on comments received, this event has been updated within Attachment 1 to read as:</i></p> <p><i>“Complete loss of off-site power to a nuclear generating plant (grid supply)”.</i></p> <p>3. Attachment 1 Generation loss event criteria Generation lossThe 2000 MW/1000 MW generation loss criteria do not provide a time threshold or location criteria. If the 2000 MW/1000 MW is intended to be from a combination of units in a single location, what is the time threshold for the combined unit loss? For example, if a large two unit facility in the Eastern Interconnection with an aggregate full power output of 2200 MW (1100 MW per unit) trips one unit (1100 MW) [T=0 loss of 1100 MW] and is ramping back the other unit from 100% power and 2 hours later the other unit trips at 50% power [550 MW at time of trip]. The total loss is 2200 MW; however, the loss was sustained over a 2 hour period. Would this scenario require reporting in accordance with Attachment 1? What if it happened in 15 minutes? 1 hour? 24 hours? Exelon suggests the criteria revised to include a time threshold for the total loss at a single location to provide this additional guidance to the GOP (e.g., within 15 minutes to align with other similar threshold conditions). Threshold for Reporting 2,000 MW unplanned total loss at a single location within 15 minutes for entities in the Eastern or Western Interconnection 1000 MW unplanned total loss at a single location within 15 minutes for entities in the ERCOT or Quebec Interconnection</p> <p><i>The DSR SDT has not modified this event since it is being maintained as it is presently enforceable within EOP-004-1.</i></p> <p>4. Exelon appreciates that the DSR SDT has added the NRC to the list of Stakeholders in the Reporting Process, but does not agree with the SDT response to FirstEnergy’s</p>



Organization	Yes or No	Question 4 Comment
		<p>comment to Question 17 [page 206] that stated “NRC requirements or comments fall outside the scope of this project.” Quite the contrary, this project should be communicated and coordinated with the NRC to eliminate confusion and duplicative reporting requirements. There are unique and specific reporting criteria and coordination that is currently in place with the NRC, the FBI and the JTTF for all nuclear power plants. If an event is in progress at a nuclear facility, consideration should be given to coordinating such reporting as to not duplicate effort, introduce conflicting reporting thresholds, or add unnecessary burden on the part of a nuclear GO/GOP who’s primary focus is to protect the health and safety of the public during a potential radiological sabotage event (as defined by the NRC) in conjunction with potential impact to the reliability of the BES.</p> <p><i>The DSR SDT has established a minimum amount of reporting for events listed in Attachment 1. The NRC does not fall under the jurisdiction of NERC and so therefore it is not within scope of this project.</i></p> <p>5. Attachment 1 Detection of a reportable Cyber Security Incident event criteria. The threshold for reporting is “that meets the criteria in CIP-008”. If an entity is exempt from CIP-008, does that mean that this reportable event is therefore also not applicable in accordance with EOP-004-2 Attachment 1?</p> <p><i>If an entity is exempt from CIP-008, then they do not have to report this type of event. Entities can report any situation at anytime to whomever they wish. If an entity is responsible for items that fall under a Cyber Security Incident, then they would report per this standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Duke Energy</p>		<p>1. Reporting under EOP-004-2 should be more closely aligned with Events Analysis Reporting.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>2. Attachment 1 - Under the column titled “Entity with Reporting Responsibility”, several Events list multiple entities, using the phrase “Each RC, BA, TO, TOP, GO, GOP, DP that experiences...” or a similar phrase requiring that multiple entities report the same event. We believe these entries should be changed so that multiple reports aren’t required for the same event.</p> <p><i>The DSR SDT agrees that there may be some dual reporting for the same event. The minimum Applicable Entities have been review and updated where updates could be made. The DSR SDT believes that a dual report will provide a clearer picture of the breadth and depth of an event the Electric Reliability Organization and the Applicable Entities Reliability Coordinator.</i></p> <p>3. Attachment 1 - The phrase “BES equipment” is used several times in the Events Table and footnotes to the table. “Equipment” is not a defined term and lacks clarity. “Element” and “Facility” are defined terms. Replace “BES equipment” with</p>

Organization	Yes or No	Question 4 Comment
		<p>“BES Element” or “BES Facility”.</p> <p><i>The DST SDT has removed the term “equipment” from Attachment 1 per comments received.</i></p> <p>4. Attachment 1 - The Event “Risk to BES equipment” is unclear, since some amount of risk is always present. Reword as follows: “Event that creates additional risk to a BES Element or Facility.”</p> <p><i>The DSR SDT has removed this event from Attachment 1. Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p>5. Attachment 1 - The Threshold for Reporting Voltage deviations on BES Facilities is identified as “+ 10% sustained for &gt; 15 continuous minutes.” Need to clarify + 10% of what voltage? We think it should be nominal voltage.</p> <p><i>A sustained voltage deviation of ± 10% on the BES is significant deviation and is indicative of a shortfall of reactive resources either pre- or post-contingency. The DSR SDT is indifferent to which of nominal, pre-contingency, or scheduled voltage, is used as the baseline, but for simplicity and to promote a common understanding suggest using nominal voltage.</i></p> <p>6. Attachment 1 - Footnote 1 contains the phrase “has the potential to”. This phrase should be struck because it creates an impossibly broad compliance responsibility. Similarly, Footnote 3 contains the same phrase, as well as the word “could” several times, which should be changed so that entities can reasonably comply.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: "A physical threat that could impact the operability of a Facility". This event has the following footnote, which states: "Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility."</i></p> <p>7. Attachment 1 - The "Unplanned Control Center evacuation" Event has the word "potential" in the column under "Entity with Reporting Responsibility". The word "potential" should be struck.8. Attachment 2 - Includes "fuel supply emergency", which is not listed on Attachment 1.</p> <p><i>The DSR SDT has removed the word "potential" from this event. It now reads as: "Each RC, BA, TOP that experiences the event"</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Energy Northwest - Columbia</p>		<p>1. The Loss of Off-site power event criteria is much improved from the last draft of EOP 004-2; however, some clarification is needed to more accurately align with NERC Standard NUC-001 in both nomenclature and intent. Specifically, there are many different configurations supplying offsite power to a nuclear power plant and it is essential that all configurations be accounted for. As identified in the applicability section of NUC-001 the applicable transmission entities may include one or more of the following (TO, TOP, TP, TSP, BA, RC, PC, DP, LSE, and other non-nuclear GO/GOPs). Based on the response to previous comments submitted for Draft 2, Energy Northwest understands that the DSR SDT evaluated the use of the word "source" but dismissed the use in favor of "supply" with the justification "[that] 'supply' encompasses all sources". Energy Northwest suggests that the word</p>

Organization	Yes or No	Question 4 Comment
		<p>“source” is used as the event criteria in EOP-004-2 as this nomenclature is commonly used in the licensing basis of a nuclear power plant. By revising the threshold criteria to “one or more” Energy Northwest believes the concern the DSR SDT noted is addressed and ensures all sources are addressed. In addition, by revising the threshold for reporting to a loss of “one or more” will ensure that all potential events (regardless of configuration of off-site power supplies) will be reported by any applicable transmission entity specifically identified in the nuclear plant site specific NPIRs. Energy Northwest proposes that the loss of an off-site power source be revised to an “unplanned” loss to account for planned maintenance that is coordinated in advance in accordance with the site specific NPIRs and associated Agreements. This will also eliminate unnecessary reporting for planned maintenance. Although the loss of one off-site power source may not result in a nuclear generating unit trip, Energy Northwest agrees that an unplanned loss of an off-site power source regardless of impact should be reported within the 24 hour time limit as proposed. Suggest that the Loss of Offsite power to a nuclear generating plant event be revised as follows: Event: Unplanned loss of any off-site power source to a Nuclear Power Plant Entity with Reporting Responsibility: The applicable Transmission Entity that owns and/or operates the off-site power source to a Nuclear Power Plant as defined in the applicable Nuclear Plant Interface Requirements (NPIRs) and associated Agreements. Threshold for Reporting: Unplanned loss of one or more off-site power sources to a Nuclear Power Plant per the applicable NPIRs.</p> <p><i>Based on comments received, this event has been updated within Attachment 1 to read as:</i></p> <p><i>“Complete loss of off-site power to a nuclear generating plant (grid supply)”.</i></p> <p>2. Please consider changing "Operating Plan" with "Procedure(s)". Procedures extend beyond operating groups and provide guidance to the entire company.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT intends on keeping “Operating Plan” within EOP-004-2 since NERC has it defined as:</i></p> <p><i>“A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan”. As stated, the Operating Plan may contain Operating procedures or Operating Processes. This will give Applicable Entities the greatest flexibility in achieving compliance with this Standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Colorado Springs Utilities		<p>Agree with concept to combine CIP-001 into EOP-004. Agree with elimination of “sabotage” concept. Appreciate the attempt to combine reporting requirements, but it seems that in practice will still have separate reporting to DOE and NERC/Regional Entities. EOP-004-2 A.5. “Summary of Key Concepts” refers to Att. 1 Part A and Att. 1 Part B. I believe these have now been combined. EOP-004-2 A.5. “Summary of Key Concepts” refers to development of an electronic reporting form and inclusion of regional reporting requirements. It is unfortunate no progress was made on this front.</p>
<p><b>Response: Thank you for your comment. The DSR SDT is providing a proposed revision to the NERC Rules of Procedure to address the electronic reporting concept. These proposed revisions will be posted with the standard.</b></p>		
American Transmission Company, LLC		<p>ATC appreciates the work of the SDT in incorporating changes that the industry had with reporting time periods and aligning this with the Events Analysis Working Group and Department of Energy’s OE 417 reporting form.</p>
<p><b>Response: Thank you for your comment.</b></p>		

Organization	Yes or No	Question 4 Comment
Manitoba Hydro		<p>Attachment 1 - The term 'Transmission Facilities' used in Attachment 1 is capitalized, but it is not a defined term in the NERC glossary. The drafting team should clarify this issue.</p> <p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p> <p>Attachment 2 - The inclusion of 'Fuel supply emergency' in Attachment 2 creates confusion as it infers that reporting a 'fuel supply emergency' may be required by the standard even though 'fuel supply emergency' is not listed in Attachment 1. On a similar note, it is not clear what the drafting team is hoping to capture by including a checkbox for 'other' in Attachment 2.</p> <p><i>The DSR SDT has removed both "fuel supply emergency" and "other" from Attachment 2.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
NV Energy		<p>Attachment 1 includes an item "Detection of a reportable cyber security incident." The reporting requirement is a report via Attachment 2 or the OE417 report form submittal. However, under CIP-008, to which this requirement is linked, the reporting is accomplished via NERC's secure CIPIS reporting tool. This appears to be a conflict in that the entity is directed to file reporting under CIP-008 that differs from this subject standard.</p> <p><i>CIP-008-4, Requirement 1, Part 1.3 states that an entity must have:</i></p> <p><i>1.3 Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary.</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>EOP-004-2 also allows for submittal of the report to the ESISAC.</i></p> <p>Attachment 1 also includes a provision for reporting the "loss of firm load greater than or equal to 15 minutes in an amount of 200MW (or 300MW for peaks greater than 3000MW). This appears to be a rather low threshold, particularly in comparison with the companion loss of generation reporting threshold elsewhere in the attachment. The volume of reports triggered by this low threshold will likely lead to an inordinate number of filed reports, sapping NERC staff time and deflecting resources from more severe events that require attention. I suggest either an increase in the threshold, or the addition of the qualifier "caused by interruption/loss of BES facilities" in this reporting item. This qualifier would therefore exclude distribution-only outages that are not indicative of a BES reliability issue.</p> <p><i>The DSR SDT has not modified this event since it is being maintained as it is presently enforceable within EOP-004-1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
BC Hydro		<p>Attachment 1: Reportable Events: BC Hydro recommends further defining "BES equipment" for the events Destruction of BES equipment and Risk to BES equipment.</p> <p>Attachment 1: Reportable Events: BC Hydro recommends defining the Forced intrusion event as the wording is very broad and open to each entities interpretation. What would be a forced intrusion ie entry or only if equipment damage occurs?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity.</i></li> </ul>



Organization	Yes or No	Question 4 Comment
		<p><i>The footnote was deleted</i></p> <ul style="list-style-type: none"> <li><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></li> </ul> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
ISO New England		<p>Attachment 1 should be revisited. “Equipment Damage” is overly vague and will also potentially result in reporting on equipment failures which may simply be related to the age and/or vintage of equipment.</p> <p><i>The DSR SDT has revised this event based on comments received. The new event is “Damage or destruction of a Facility” which has a threshold of “Damage or destruction of a Facility that:</i></p> <p><i>Affects an IROL (per FAC-014)</i></p> <p><i>OR</i></p> <p><i>Results in the need for actions to avoid an Adverse Reliability Impact</i></p> <p><i>OR</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Results from intentional human action."</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Constellation Energy on behalf of Baltimore Gas &amp; Electric, Constellation Power Generation, Constellation Energy Commodities Group, Constellation Control and Dispatch, Constellation NewEnergy and Constellation Energy Nuclear Group.</p>		<p>Background Section: The background section in this revision of EOP-004 reads more like guidance than a background of the development of the event reporting standard. Because of the background remains as part of the standard, the language raises questions as to role it plays relative to the standard language. For instance, the Law Enforcement Reporting section states: "Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES." It's not clear how "potential to impact to a wider area of the BES" is defined and where it fits into the standard. As well, and perhaps more problematic, is the Reporting Hierarchy for Reportable Events flow chart. While the flow chart concept is quite useful as a guidance tool, the flow chart currently in the Background raises questions. For instance, the Procedure to Report to Law Enforcement sequence does not map to language in the requirements. Further, Entities would not know about the interaction between law enforcement agencies.</p> <p><i>The DSR SDT included the flow chart as an example of how an entity might report and communicate an event. For clarity, we have added the phrase "Example of Reporting Process Including Law Enforcement" to the top of the page.</i></p> <p>Please see additional recommended revisions to the requirement language and to the Events Table in the Q2 and Q3 responses.</p> <p><i>The DSR SDT has removed the wording of "potential" based on comments received.</i></p> <p>Attachment 2: Event Reporting Form: The review of the form is one of the many aspects to compare with the developments within the Events Analysis Process (EAP) developments. We support the effort to create one form for submissions. The</p>

Organization	Yes or No	Question 4 Comment
		<p>recent draft EAP posted as part of Planning Committee and Operating Committee agendas includes a form requiring a few bits of additional relevant information when compared to the EOP-004 form. This may be a valuable approach to avoid follow up inquiries that may result if the form is too limited. We suggest that consideration be given to the proposed EAP form. One specific note on the Proposed EOP-004 Attachment 2: The “Potential event” box in item 3 should be eliminated to track with the removal of the “Risk to the BES” category.</p> <p><i>The DSR SDT has updated Attachment 2 to remove potential event and “Risk to the BES” category based on comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Bonneville Power Administration</p>		<p>BPA believes that Attachment 1 has too many added reportable items because unintentional, equipment failure &amp; operational errors are included in the first three items.</p> <p>A. Change to only “intentional human action”. Otherwise, the first item “destruction of BES equipment” is too burdensome, along with its short time reporting time: i. - If a single transformer fails that shouldn’t require a report. ii.- Emergency actions have to be taken for any failure of equipment, e.g. a loss of line reduces a path SOL and requires curtailments to reduce risk to the system.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> </ul> <p>B. The item for “risk to BES” is not necessary until the suspicious object has been identified as a threat. If what turns out to be air impact wrench left next to BES</p>

Organization	Yes or No	Question 4 Comment
		<p>equipment, that should not be a reportable incident as this current table implies. <i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>C. The nuclear “LOOP” should be only reported if total loss of offsite source (i.e. 2 of 2 or 3 of 3) when supplying the plants load. If lightning or insulator fails causing one of the line sources to trip that’s not a system disturbance especially if it is just used as a backup. It should only be a NRC process if they want to monitor that.</p> <p><i>The DSR SDT has updated this event per your comment, it now reads as: “Complete loss of off-site power to a nuclear generating plant (grid supply)”</i></p> <p>The VRF/VSL: BPA believes that the VRF for R2 &amp; R4 should be “Lower”. <i>The DSR SDT has reviewed and updated the two new requirements and believe the VRF’s follow the NERC Standard development process.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
CenterPoint Energy		<p>CenterPoint Energy appreciates the SDT’s consideration of comments and removal of the term, Impact Event. However, the Company still suggests removing the phrase “with the potential to impact” from the purpose as it is vast and vague. An</p>

Organization	Yes or No	Question 4 Comment
		<p>alternative purpose would be "To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of events that impact reliability and their causes if known". The focus should remain on those events that truly impact the reliability of the BES.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><b><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></b></p> <p>CenterPoint Energy remains very concerned about the types of events that the SDT has retained in Attachment 1 as indicated in the following comments: Destruction of BES Equipment - The loss of BES equipment should not be reportable unless the reliability of the BES is impacted.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> </ul> <p>Footnote 5, iii should be modified to tie the removal of a piece of equipment from service back to reliability of the BES. Risk to BES equipment: This Event is too vague to be meaningful and should be deleted. The Event should be modified to "Detection of an imminent physical threat to BES equipment".</p> <p><i>The SDR SDT discussed this event as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "A physical threat that could impact the operability of a Facility".</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>Any reporting time frame of 1 hour is unreasonable; Entities will still be responding to the Event and gathering information. A 24 hour reporting time frame would be more reasonable and would still provide timely information.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>System Separation: The 100 MW threshold is too low for a reliability impact. A more appropriate threshold is 500 MW.</p> <p><i>The DSR SDT has reviewed your request and have determined the event as written "Each separation resulting in an island of generation and load ≥ 100 MW" does impact the reliability of the BES.</i></p> <p>Loss of Monitoring or all voice communication capability: The two elements of this Event should be separated for clarity as follows: "Loss of monitoring of Real-Time conditions" and "Loss of all voice communication capability."</p> <p><i>The DSR SDT has broken this event down into two distinct events: "Loss of all voice communication capability" and "Complete or partial loss of monitoring capability", per comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Orange and Rockland Utilities, Inc./Consolidated Edison Co. of NY, Inc.</p>		<p>Comments:</p> <ul style="list-style-type: none"> <li>o Requirement 4 does not specifically state details necessary for an entity to achieve compliance. Requirement 4 should provide more guidance as to what is required in a drill. Audit / enforcement of any requirement language that is too broad will potentially lead to Regional interpretation, inconsistency, and additional CANS.</li> <li>o R4 should be revised to delete the 15 month requirement. CAN-0010 recognizes that entities may determine the definition of annual.</li> </ul> <p><i>Requirement R4 has been revised as you suggested.</i></p> <ul style="list-style-type: none"> <li>o The Purpose of the Standard should be revised because some of the events being reported on have no impact on the BES. Revise Purpose as follows: To improve industry awareness and the reliability of the Bulk Electric System by requiring the reporting of [add] "major system events." [delete - "with the potential to impact</li> </ul>

Organization	Yes or No	Question 4 Comment
		<p>reliability and their causes, if known, by the Responsible Entities.”]</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability”. The Purpose statement now reads:</i></p> <p><b><i>“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”</i></b></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Entergy Services		<p>Entergy agrees with and supports comments submitted by the SERC OC Standards Review group.</p>
<p><b>Response: Thank you for your comment.</b></p>		
ITC		<p>Footnote 1 and the corresponding Threshold For Reporting associated with the first Event in Attachment 1 are not consistent and thus confusing. Qualifying the term BES equipment through a footnote is inappropriate as it leads to this confusion. For instance, does iii under Footnote 1 apply only to BES equipment that meet i and ii or is it applicable to all BES equipment?</p> <p><i>The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>The inclusion of equipment failure, operational error and unintentional human action within the threshold of reporting for “destruction” required in the first 3 Events listed in Attachment 1 is also not appropriate. It is clear through operational history that the intent of the equipment applied to the system, the operating practices and personnel training developed/delivered to operate the BES is to result in reliable operation of the BES which has been accomplished exceedingly well given past history. This is vastly different than for intentional actions and should be excluded from the first 3 events listed in Attachment. To the extent these issues are present in another event type they will be captured accordingly.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>Footnote 1 should be removed and the Threshold for Reporting associated with the first three events in Attachment 1 should be updated only to include intentional human action. This will also result in including all BES equipment that was intentionally damaged in the reporting requirement and not just the small subset qualified by the existing footnote 1. This provides a much better data sample for law enforcement to make assessments from than the smaller subset qualified by what we believe the intent of footnote 1 is.</p> <p><i>The SDR SDT discussed this event as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "A physical threat that could impact the operability of a Facility".</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>APX Power Markets (NCR-11034)</p>		<p>For Attachment 1 and the events titled "Unplanned Control Center evacuation" and "Loss of monitoring or all voice communication capability". RC, BA, and TOP are the only listed entity types listed for reporting responsibility. We are a GOP that offers a SCADA service in several regions and those type of events could result in a loss of situational awareness for the regions we provide services. I believe the requirement for reporting should not be limited to Entity Type, but on their impact for situational awareness to the BES based on the amount of generation they control (specific to our case), or other criteria that would be critical to the BES (i.e. voltage, frequency).</p> <p><i>Note that EOP-008-0 is only applicable to Balancing Authorities, Transmission Operators and Reliability Coordinators, this is the basis for the “Entity with reporting Responsibilities” and reads as “Each RC, BA, TOP that experiences the event”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ACES Power Marketing Standards Collaborators/ Great River Energy</p>		<p>For many of the events listed in Attachment 1, there would be duplicate reporting the way it is written right now. For example, in the case of a fire in a substation (Destruction of BES equipment), the RC, BA, TO, TOP and perhaps the GO and GOP could all experience the event and each would have to report on it. This seems quite excessive and redundant. We recommend eliminating this duplicate reporting.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Intellibind</p>		<p>I do not see that the rewrite of this standard is meeting the goal of clear reliability standards, and in fact the documents are looking more like legal documents. Though the original EOP-004 and CIP-001 was problematic at times, this rewrite, and the need to have such extensive guidance, attachments, and references for EOP-004-2 will create an even more difficult standard to properly meet to ensure compliance during an audit. Though CIP-001 and EOP-004 were related, combining them in a single standard is not resolving the issues, and is in fact complicating the tasks. Requirements in this standard should deal with only one specific issue, not deal with multiple tasks. I am not sure how an auditor will consistently audit against R2, and how a violation will be categorized when an entity implements all portions of their Operating Plan, however fails to fully address all the requirements in R1, thereby not fully implementing R2, in strict interpretation.</p> <p><i>The DSR SDT does not agree that the proposed EOP-004-2 "will create an even more difficult standard to properly meet to ensure compliance during an audit". The DSR SDT main concern is the reporting of events per Attachment 1 is in-line with the Purpose of this Standard that states: "To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities." The NERC Reliability Standards are designed to support the reliability of the BES. Requirement R2 has been updated to read as: "'R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.'" Based on comments received.</i></p> <p>The drafting team should not set up a situation where an entity is in double jeopardy for missing an element of a requirement. I also suggest that EOP-004-2 be given a</p>

Organization	Yes or No	Question 4 Comment
		<p>new EOP designation rather than calling it a revision. This way implementation can be better controlled, since most companies have written specific CIP-001 and EOP-004 document that will not simple transfer over to the new version. This standard is a drastic departure from the original versions. I appreciate the level of work that is going into EOP-004-2, it appears that significant time and effort has been going into the supporting documentation. It is my opinion that if this much material has to be created to state what the standard really requires, then the standard is flawed. When there are 21 pages of explanation for five requirements, especially when we have previously had 16 pages that originally covered 2 separate reliability standards, we need to reevaluate what we are really doing.</p> <p><i>The DSR SDT has revised EOP-004 and CIP-001 using the results based standard development process. This process calls for the drafting team to develop documentation regarding its thoughts during the development process. This allows for a more robust standard which contains background material for an entity to have sufficient guidance to show compliance with the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Imperial Irrigation District		<p>IID strongly believes the reporting flowchart should not be part of a standard. The suggestion is to replace it with a more clear, right to the point requirement.</p> <p><i>The DSR SDT has discussed this issue and believes it would be too prescriptive to have a flow chart as a requirement. If desired, an entity can have a flow chart as part of the Operating Plan as stated in Requirement 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Illinois Municipal Electric Agency		<p>IMEA appreciates this opportunity to comment. IMEA appreciates the SDT's efforts to simplify reporting requirements by combining CIP-001 with EOP-004. [IMEA encourages NERC to continue working towards a one-stop-shop to simplify reporting on ES-ISAC.] IMEA supports, and encourages SDT consideration of, comments</p>

Organization	Yes or No	Question 4 Comment
		submitted by APPA and Florida Municipal Power Agency.
<p><b>Response: Thank you for your comment. Please see the responses to the other comments that you mention.</b></p>		
Westar Energy		<p>In Requirement 1.3, the statement “and the following as appropriate” is vague and subject to interpretation. Who determines what is appropriate? We feel it would be better if the SDT would specify for each event, which party should be notified.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
South Carolina Electric and Gas		<p>In terms of receiving reports, is it the drafting teams expectation that separate reports be developed by both the RC and the TOP, GO, BA, etc. for an event that occurs on a company's system that is within the RC's footprint? One by the RC and one by the TOP, GO, BA, etc. In terms of meeting reporting thresholds, is it the drafting teams expectation that the RC aggregate events within its RC Area to determine whether a reporting threshold has been met within its area for the quantitative thresholds?</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>that could affect just one of the entities with reporting responsibility isn't missed.</i></p> <p><i>It is possible for the Applicable Entities within the Reliability Coordinator's area to be part of a JRO/CFR but this is outside the scope of this Project.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Occidental Power Services, Inc. (OPSI)</p>		<p>Load Serving Entities that do not own or operate BES assets should not be included in the Applicability. In current posting, the SDT states that it includes LSEs based on CIP-002; however, if the LSE does not have any BES assets, CIP-002 should also not be applicable, because the LSE could not have any Critical Assets or Critical Cyber Assets. It is understood that the SDT is trying to comply with FERC Order 693, Section 460 and 461; however, Section 461 also states "Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns." A qualifier in the Applicability of EOP-004-2 that would include only LSEs that own or operate BES assets would seem appropriate. The proposed CIP-002 Version V has such a qualifier in that it applies to a "Load-Serving Entity that owns Facilities that are part of any of the following systems or programs designed, installed, and operated for the protection or restoration of the BES: o A UFLS program required by a NERC or Regional Reliability Standard o A UVLS program required by a NERC or Regional Reliability Standard" The SDT should consider the same wording in the Applicability section of EOP-004-2 on order to be consistent with what will become the standing version of CIP-002 (Version 5).</p> <p><i>The DSR SDT has "considered" section 460 and 461 of FERC Order 693 and has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p> <p><i>The DSR SDT wishes to draw your attention to section 459 of FERC Order 693 which states: "... an adversary may target a small user, owner or operator because it may</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>have similar equipment or protections as a larger facility, that is, the adversary may use an attack against a smaller facility as a training ‘exercise’.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>American Electric Power</p>		<p>M4: Recommend removing the text “for events” so that it instead reads “The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan created pursuant to Requirement R1, Part 1.3.”R4: It is not clear to what extent the verification needs to be applied if the process used is complex and includes a variety of paths and/or tasks. The draft team may wish to consider changing the wording to simply state “each Responsible Entity shall test each of the communication paths in the operating plan”. We also recommend dropping “once per calendar year” as it is inconstant with the measure itself which allows for 15 months.</p> <p><i>The DSR SDT has revised R4 (now R3 and the associated measure M3:</i></p> <p><i>M3. Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. (R3)</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Indiana Municipal Power Agency</p>		<p>Many of the items listed in Attachment 1 are onerous and burdensome when it comes to making judgments or determinations. What one may consider “Risk to BES equipment” another person may not make the same determination. Clarity needs to</p>



Organization	Yes or No	Question 4 Comment
		<p>be added to make the events easier to determine and that will result in less issues when it comes to compliance audits.</p> <p>IMPA does not understand the usage of the terms Critical Asset and Critical Cyber Asset as they will be retired with CIP version 5. IMPA believes the data retention requirements are way too complicated and need to be simplified. It seems like it would be less complicated if one data retention period applied to all data associated with this standard.</p> <p><i>The DSR has revised many of the events listed in Attachment 1 to provide clarity. We have also removed the references to Critical Asset and Critical Cyber Asset.</i></p> <p>On “public appeal”, in the threshold, the descriptor “each” should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event?</p> <p><i>The DSR SDT has updated the Public Appeal event to read as: “Public appeal for load reduction event” based on comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
MidAmerican Energy		<p>MidAmerican proposes eliminating the phrase “with no more than 15 months between reviews” from R1.5. While we agree this is best practice, it creates the need to track two conditions for the review, eliminates flexibility for the responsible entity and does not improve security to the Bulk Electric System. There has not been a directive from FERC to specify the definition of annual within the standard itself. In conjunction with this comment, the Violation Severity Levels for R4 should be revised to remove the references to months.</p> <p><i>The DSR SDT has removed this phrase from the requirement (now R3).</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Oncor Electric Delivery Company LLC</p>		<p>NERC's Event Analysis Program tends to parallel many of the reporting requirements as outlined in EOP-004 Version 2. Oncor recommends that NERC considers ways of streamlining the reporting process by either incorporating the Event Analysis obligations into EOP-004-2 or reducing the scope of the Event Analysis program as currently designed to consist only of "exception" reporting.</p> <p><i>The DSR SDT has reviewed the Event Analysis Programs criteria. The DSR SDT has determined that Attachment 1 covers the minimum reporting requirements.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Compliance &amp; Responsibility Office</p>		<p>NextEra Energy, Inc. (NextEra) appreciates the DSR SDT revising proposed EOP-004-2, based on the previous comments of NextEra and the stakeholders. NextEra, however, believes that EOP-004-2 needs additional refinement prior to approval. R1.3In R1.3, NextEra is concerned that the term “internal company personnel” is unclear and may be misinterpreted. For example, NextEra does not believe this term should include all company or corporate personnel, or even all personnel in the Responsible Entity’s company or business unit. Instead, the definition of personnel should be limited to those who could be directly impacted by the event or are working on the event. Thus, NextEra suggests that the language in R1.3 be revised to read: “Internal Responsible Entity personnel whose tasks require them to take specific actions to mitigate, stop the spread and/or normalize the event, or personnel who are directly impacted by the event.” NextEra is concerned that R1.3, as written, will be interpreted differently from company to company, region to region, auditor to auditor, and, therefore, may result in considerable confusion during actual events as well as during the audits/stop checks of EOP-004-2 compliance.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has written Requirement R1, Part 1.2 in a way to allow the entity to determine who should receive the communication within your company as stated in your Operating Plan.</i></p> <p>Also, in R1.3, NextEra is concerned that many of the events listed in Attachment A already must be reported to NERC under its trial (soon to be final) Event Analysis Reporting requirements (Event Analysis). NextEra believes duplicative and different reporting requirements in EOP-004-2 and the Event Analysis rules will cause confusion and inefficiencies during an actual event, which will likely be counterproductive to promoting reliability of the bulk power system. Thus, NextEra believes that any event already covered by NERC’s Event Analysis should be deleted from Attachment 1. Events already covered include, for example, loss of monitoring or all voice, loss of firm load and loss of generation. If this approach is not acceptable, NextEra proposes, in the alternative, that the reporting requirements between EOP-004-2 and Event Analysis be identical. For instance, in EOP-004-2, there is a requirement to report any loss of firm load lasting for more than 15 minutes, while the Event Analysis only requires reporting the of loss of firm load above 300 megawatts and lasting more than 15 minutes. Similarly, EOP-004-2 requires the reporting of any unplanned control center evacuation, while the Event Analysis only requires reporting after the evacuation of the control center that lasted 30 minutes or more. Thus, NextEra requests that either EOP-004-2 not address events that are already set forth in NERC’s Event Analysis, or, in the alternative, for those duplicative events to be reconciled and made identical, so the thresholds set forth in the Event Analysis are also used in EOP-004-2.</p> <p><i>The DSR SDT has worked with the EAWG to develop Attachment 1. At one point they matched. The event for loss of load matches and we revised the “unplanned control center evacuation” event to be for 30 minutes or more.</i></p> <p>In addition, NextEra believes that a reconciliation between the language “of recognition” in Attachment 1 and “process to identify” in R1.1 is necessary. NextEra prefers that the language in Attachment 1 be revised to read “. . . of the</p>

Organization	Yes or No	Question 4 Comment
		<p>identification of the event under the Responsible Entity’s R1.1 process.” For instance, the first event under the “Submit Attachment 2 . . . .” column should read: “The parties identified pursuant to R1.3 within 1 hour of the identification of an event under the Responsible Entity’s R1.1 process.” This change will help eliminate confusion, and will also likely address (and possibly make moot) many of the footnotes and qualifications in Attachment 1, because a Responsible Entity’s process will likely require that possible events are properly vetted with subject matter experts and law enforcement, as appropriate, prior to identifying them as “events”. Thus, only after any such vetting and a formal identification of an event would the one hour or twenty-four hour reporting clock start to run. R1.4, R1.5, R3 and R4NextEra is concerned with the wording and purpose of R1.4, R1.5, R3 and R4.</p> <p><i>The language was revised in Requirement 1, Part 1.1 to “recognize” based on other comments received.</i></p> <p>For example, R1.4 requires an update to the Operating Plan for “. . . any change in assets, personnel, other circumstances . . . .” This language is much too broad to understand what is required or its purpose. Further, R1.4 states that the Operating Plan shall be updated for lessons learned pursuant to R3, but R3 does not address lessons learned. Although there may be lessons learned during a post event assessment, there is no requirement to conduct such an assessment. Stepping back, it appears that the proposed EOP-004-2 has a mix of updates, reviews and verifications, and the implication that there will be lessons learned. Given that EOP-004-2 is a reporting Standard, and not an operational Standard, NextEra is not inclined to agree that it needs the same testing and updating requirements like EOP-005 (restoration) or EOP-008 (control centers). Thus, it is NextEra’s preference that R1.4, R1.5 and R4 be deleted, and replaced with a new R1.4 as follows:R1.4 A process for ensuring that the Responsibly Entity reviews, and updates, as appropriate its Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.If the DSR SDT does not agree with this approach, NextEra, in the alternative, proposes a second approach that consolidates R1.4, R1.5 and R4 in a new R1.4 as follows:R1.4 A process for ensuring that the Responsibly Entity tests</p>

Organization	Yes or No	Question 4 Comment
		<p>and reviews its Operating Plan at least annually (once each calendar year) with no more than 15 months between a test and review. Based on the test and review, the Operating Plan shall be updated, as appropriate, within 90 calendar days. If an actual event occurs, the Responsible Entity shall conduct a post event assessment to identify any lessons learned within 90 calendar days of the event. If the Responsible Entity identifies any lessons learned in post event assessment, the lessons learned shall be incorporated in the Operating Plan within 90 calendar days of the date of the final post event assessment. NextEra purposely did not add language regarding “any change in assets, personnel etc,” because that language is not sufficiently clear or understandable for purposes of a mandatory requirement. Although it may be argued that it is a best practice to update an Operating Plan for certain changes, unless the DST SDT can articulate specific, concrete and understandable issues that require an updated Operating Plan prior to an annual review, NextEra recommends that the concept be dropped.</p> <p><i>Requirement 1, Part 1.4 was merged with Part 1.5 as well as R4. The resulting requirement is now Requirement 3:</i></p> <p><i>“Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p>Nuclear Specific ConcernsEOP-004-2 identifies the Nuclear Regulatory Commission (NRC) as a stakeholder in the Reporting Process, but does not address the status of reporting to the NRC in the Event Reporting flow diagram on page 9. Is the NRC considered Law Enforcement as is presented in the diagram? Since nuclear stations are under a federal license, some of the events that would trigger local/state law enforcement at non-nuclear facilities would be under federal jurisdiction at a nuclear site.</p> <p><i>The process flowchart is an example of how an entity might operate. If an event requires notification of the NRC, this would be an example of notification of a regulatory authority. It is anticipated that the reporting entity would also notify law</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>enforcement if appropriate.</i></p> <p>There are some events listed in Attachment 1 that seem redundant or out of place. For example, a forced intrusion is a one hour report to NERC. However, if there is an ongoing forced intrusion at a nuclear power plant, there are many actions taking place, with the NRC Operations Center as the primary contact which will mobilize the local law enforcement agency, etc.</p> <p><i>The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "Any physical threat that could impact the operability of a Facility".</i></p> <p>It is unclear that reporting to NERC in one hour promotes reliability or the resolution of an emergency in progress.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a 'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>Also, is there an ability to have the NRC in an emergency notify NERC? The same concerns related to cyber security events.Procedures versus PlanNextEra also suggests replacing "Operating Plan" with "procedures". Given that EOP-004-2 is a reporting Standard and not an operational Standard, it is typical for procedures that address this standard to reside in other departments, such as Information Management and Security. In other words, the procedures needed to address the requirements of EOP-004-2 are likely broader than the NERC-defined Operating Plan.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Within your Operating Plan you are required to “report” events to the ERO and your RC and communicate this information (to others) as you define it within your company’s Operating Plan. This will allow you to customize any events as you see fit.</i></p> <p>Clean-Up Items In Attachment 1, Control Centers should be capitalized in all columns so as not to be confused with control rooms.</p> <p><i>Since “control center” is not a defined term, it has been revised to lower case.</i></p> <p>Also, the final product should clearly state that the process flow chart that is set forth before the Standard is for illustrative purposes, so there is no implication that a Registered Entity must implement multiple procedures versus one comprehensive procedure to address different reporting requirements.</p> <p><i>The introduction of the flow chart is clearly marked “Example of Reporting Process including Law Enforcement”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
PacifiCorp		No comment.
Arizona Public Service Company		No comments
PPL Electric Utilities and PPL Supply Organizations`		<p>Our comments center around the footnotes and events 'Destruction of BES equipment' and 'Loss of Off-site power to a nuclear generating plant'. We request the SDT consider adding a statement to the standard that acknowledges that not all registered entities have visibility to the information in the footnotes. E.G. Destruction of BES equipment. A GO/GOP does not necessarily know if loss of specific BES equipment would affect any IROL and therefore would not be able to consider this criteria in its reporting decision. Loss of BES equipment would be reported to the BA/RC and the BA/RC would know of an IROL impact and the BA/RC</p>

Organization	Yes or No	Question 4 Comment
		<p>is the appropriate entity to report. We request the SDT consider the information in the footnotes for inclusion in the table directly. Consider Event 'Destruction of BES equipment'. Is footnote 1 a scoping statement? Is it part of the threshold? Is it the impact? Is it defining Destruction? If the BES equipment was destroyed by weather and does not affect an IROL, then is no report is needed? Alternatively, do you still apply the threshold and say it was external cause and therefore report?</p> <p><i>Several event categories were removed or combined to improve Attachment 1. The footnotes that you mention were removed and included in the threshold for reporting column. If an entity does not experience an event, then they should not report on it. As you suggest, most GO /GOPs do not see the transmission system. It is anticipated that they will report for events on their Facilities.</i></p> <p>We suggest including a flowchart on how to use Attachment 1 with an example. The flowchart would explain the order in which to consider the event and the threshold, and footnotes if they remain. Regarding Attachment 1 Footnote 1 'do not report copper theft...unless it degrades the ability of equipment to operate correctly.', is this defining destruction as not operating correctly ? or is the entirety of footnote 1 a definition of destruction? Regarding Attachment 1 Footnote 1, iii, we request this be changed for consistency with the Event and suggest removing damage from the footnote. i.e. The event is 'destruction' whereas the footnote says 'damaged or destroyed'. The standard does not provide guidance on damage vs destruction which could lead to differing reporting conclusions. Is the reporting line out of service, beyond repair, or is it timeframe based? Regarding Attachment 1 Footnote 2 ' to steal copper... unless it affects the reliability of the BES', is affecting the reliability of the BES a consideration in all the events? PPL believes this is the case and request this statement be made. This could be included in the flowchart as a decision point. Regarding Event 'Loss of Off-site power to a nuclear generating plant', the threshold for reporting does not designate if the off-site loss is planned and/or unplanned - or if the reporting threshold includes the loss of one source of off-site power or is the reporting limited to when all off-site sources are unavailable. PPL recommends the event be 'Total unplanned loss of offsite power to a nuclear generating plant (grid</p>



Organization	Yes or No	Question 4 Comment
		<p>supply)'Thank you for considering our comments.</p> <p><i>The SDR SDT discussed "Forced Intrusion" as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was revised to "A physical threat that could impact the operability of a Facility".</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>"Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility."</i></p> <p><i>The DSR SDT has updated the Requirements based on comments received along with updating Attachment 1 and 2. Please review the updated standard for all your concerns.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>City of Austin dba Austin</p>		<p>Overarching Concern related to EOP-004-2 draft:The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes</p>

Organization	Yes or No	Question 4 Comment
Energy		<p>and CIP Standards Version 5 could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definition of a BES element could change significantly and the concepts of “Critical Assets” and “Critical Cyber Assets” no longer exist in Version 5 of the CIP Standards.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Additionally, it is debatable whether the destruction of, for example, one relay would be a reportable incident given the proposed language. Related to “Reportable Events” of Attachment 1:1. The “Purpose” section of the Standard indicates it is designed to require the reporting of events “with the potential to impact reliability” of the BES. Footnote 1 and the “Threshold for Reporting” associated with the Event described as “Destruction of BES equipment” expand the reporting scope beyond that intent. For example, a fan on a generation unit can be destroyed because a plant employee drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be “unintentional human action” that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. Item iii) in Footnote 1 seems redundant with the Threshold for Reporting.3. The word “Significantly” in item ii) of footnote 1 introduces an element of subjectivity. What is “significant” to one person may not be significant to someone else.4. The word “unintentional” in Item iii) of footnote 1 may introduce nuisance reporting. The SDT should consider: (1) changing the Event description to “Damage or destruction of BES equipment” (2) removing the footnote and (3) replacing the existing “Threshold for Reporting” with the following language:”Initial indication the event: (i) was due to intentional human action, (ii) affects an IROL or (iii) in the opinion of the Responsible Entity, jeopardizes the reliability margin of the system (e.g., results in the need for emergency actions)”</p> <p><i>The SDR SDT revised this event to “Damage or destruction of a Facility” and removed the footnote. The threshold for reporting now reads:</i></p> <p><i>Damage or destruction of a Facility that:</i>  <i>Affects an IROL (per FAC-014)</i>  <i>OR</i>  <i>Results in the need for actions to avoid an Adverse Reliability Impact</i>  <i>OR</i>  <i>Results from intentional human action.</i></p> <p>5. One reportable event is “Risk to the BES” and the threshold for reporting is, “From a non-environmental physical threat.” This appears to be intended as a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>6. One reportable event is “Damage or destruction of Critical Asset per CIP-002.” The SDT should define the term “Damage” in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. Normal “damage” can occur on a CA that should not be reportable (e.g. the screwdriver example, above).</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>7. For the event called “BES Emergency requiring public appeal for load reduction,” the SDT should make it clear who should report such an event. For example, in the ERCOT Region, there is a requirement that ERCOT issue public appeals for load reduction (See ERCOT Protocols Section 6.5.9.4). As the draft of EOP-004-2 is currently written, every Registered Entity in the ERCOT Region would have to file a report when ERCOT issues such an appeal. Such a requirement is overly burdensome and does not enhance the reliability of the BES. The Standard should require that the Reliability Coordinator file a report when it issues a public appeal to reduce load.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn't missed.</i></p> <p>Reporting Thresholds<sup>1</sup>. See Paragraph 1 in the “Related to 'Reportable Events' of Attachment 1” section, above.    2. We believe damage or destruction of Critical</p>

Organization	Yes or No	Question 4 Comment
		<p>Assets or CCAs resulting from operational error, equipment failure or unintentional human action should not be reportable under this Standard. We recommend changing the thresholds for “Damage or destruction of Critical Asset...” and “Damage or destruction of a [CCA]” to “Initial Indication the event was due to external cause or intentional human action.” 3. We support the SDT’s attempted to limit nuisance reporting related to copper thefts. However, a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could clog the reporting process with nuisance reporting and reviewing. An example is the “BES Emergency requiring manual firm load shedding” of “¥ 100 MW or “Loss of Firm load for ¥ 15 Minutes” that is ¥ 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases, those low thresholds would require reporting minor wind events or other seasonal system issues on a local network used to provide distribution service. Firm Load1. The use of the term “Firm load” in the context of the draft Standard seems inappropriate. “Firm load” is not defined in the NERC Glossary (although “Firm Demand” is defined). If the SDT intended to use “Firm Demand,” they should revise the draft Standard to use that language. If the SDT wishes to use the term “Firm load” they should define it. [For example, we understand that some load agrees to be dropped in an emergency. In fact, in the ERCOT Region, we have a paid service referred to as “Emergency Interruptible Load Service” (EILS). If the SDT intends that “Firm load” means load other than load which has agreed to be dropped, it should make that fact clear.]</p> <p><i>The thresholds and events listed in Attachment 1 are currently required under DOE OE-417 and NERC reporting requirements.</i></p> <p>Comments to Attachment 21. The checkbox for “fuel supply emergency” should be deleted because it is not listed as an Event on Attachment 1.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>2. There should be separation between “forced intrusion” and “Risk to BES equipment.” They are separate Events on Attachment 1.</p> <p><i>Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p>Comments to Guideline and Technical Basis The last paragraph appears to state NERC will accept an OE-417 form as long as it contains all of the information required by the NERC form and goes on to state the DOE form “may be included or attached to the NERC report.” If the intent is for NERC to accept the OE-417 in lieu of the NERC report, this paragraph should be clarified.</p> <p><i>The DSR SDT received many comments requesting consistency with DOE OE-417 thresholds and timelines. These items as well as the Events Analysis Working Group’s (EAWG) requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>North America</i></p> <ul style="list-style-type: none"> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use the OE-417 form rather than Attachment 2 to report under EOP-004. The SDT was informed by the DOE of its new online process coming later this year. In this process, entities may be able to record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses, thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Salt River Project/ Lower Colorado River Authority</p>		<p>Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes and CIP Standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definition of a BES element could change significantly and the concepts of "Critical Assets" and "Critical Cyber Assets" no longer exist in Version 5 of the CIP Standards.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>Additionally, it is debatable whether the destruction of, for example, one relay would</p>

Organization	Yes or No	Question 4 Comment
		<p>be a reportable incident given the proposed language. Related to “Reportable Events” of Attachment 1:1. The “Purpose” section of the Standard indicates it is designed to require the reporting of events “with the potential to impact reliability” of the BES. Footnote 1 and the “Threshold for Reporting” associated with the Event described as “Destruction of BES equipment” expand the reporting scope beyond that intent. For example, a fan on a generation unit can be destroyed because a plant employee drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be “unintentional human action” that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. Item iii) in Footnote 1 seems redundant with the Threshold for Reporting.3. The word “Significantly” in item ii) of footnote 1 introduces an element of subjectivity. What is “significant” to one person may not be significant to someone else.4. The word “unintentional” in Item iii) of footnote 1 may introduce nuisance reporting. The SDT should consider: (1) changing the Event description to “Damage or destruction of BES equipment” (2) removing the footnote and (3) replacing the</p>



Organization	Yes or No	Question 4 Comment
		<p>existing “Threshold for Reporting” with the following language: “Initial indication the event: (i) was due to intentional human action, (ii) affects an IROL or (iii) in the opinion of the Responsible Entity, jeopardizes the reliability margin of the system (e.g., results in the need for emergency actions)”</p> <p><i>The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>5. One reportable event is, “Risk to the BES” and the threshold for reporting is, “From a non-environmental physical threat.” This appears to be intended as a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>6. One reportable event is, "Damage or destruction of Critical Asset per CIP-002." The SDT should define the term "Damage" in order for an entity to determine a threshold for what qualifies as "Damage" to a CA. Normal "damage" can occur on a CA that should not be reportable (e.g. the screwdriver example, above). Reporting Thresholds<sup>1</sup>. We believe damage or destruction of Critical Assets or CCAs resulting from operational error, equipment failure or unintentional human action should not be reportable under this Standard. We recommend changing the thresholds for "Damage or destruction to Critical Assets ..." and "Damage or destruction of a [CCA]" to "Initial Indication the event was due to external cause or intentional human action."</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>2. We support the SDT's attempted to limit nuisance reporting related to copper thefts. However, a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could clog the reporting process with nuisance reporting and reviewing. An example is the "BES Emergency requiring manual firm load shedding" of <math>\geq 100</math> MW or "Loss of Firm load for <math>\geq 15</math> Minutes" that is <math>\geq 200</math> MW (300 MW if the manual demand is greater than 3000 MW). In many cases, those low thresholds would require reporting minor wind events or other seasonal system issues on a local network used to provide distribution service. Firm Demand<sup>1</sup>. The use of the term "Firm load" in the context of the draft Standard seems inappropriate.</p>

Organization	Yes or No	Question 4 Comment
		<p>“Firm load” is not defined in the NERC Glossary (although “Firm Demand” is defined). If the SDT intended to use “Firm Demand,” they should revised the draft Standard. If the SDT wishes to use the term “Firm load” they should define it. [For example, we understand that some load agrees to be dropped in an emergency. In fact, in the ERCOT Region, we have a paid service referred to as “Emergency Interruptible Load Service” (EILS). If the SDT intends that “Firm load” means load other than load which has agreed to be dropped, it should make that fact clear.]</p> <p><i>The thresholds and event types in Attachment 1 are from current DOE OE-417 and NERC reporting requirements.</i></p> <p>Comments to Attachment 21. The checkbox for “fuel supply emergency” should be deleted because it is not listed as an Event on Attachment 1.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p> <p>2. There should be separation between “forced intrusion” and “Risk to BES equipment.” They are separate Events on Attachment 1.</p> <p><i>Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>meaningful to industry awareness are reported.</i></p> <p>Comments to Guideline and Technical Basis                      The last paragraph appears to state NERC will accept an OE-417 form as long as it contains all of the information required by the NERC form and goes on to state the DOE form “may be included or attached to the NERC report.” If the intent is for NERC to accept the OE-417 in lieu of the NERC report, this paragraph should be clarified.</p> <p><i>The DSR SDT received many comments requesting consistency with DOE OE-417 thresholds and timelines. These items as well as the Events Analysis Working Group’s (EAWG) requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use the OE-417 form rather than Attachment 2 to report under EOP-004. The SDT was informed by the DOE of its new online process coming later this year. In this process, entities may be able to record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses, thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.</i></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Public Utility District No. 1 of Snohomish County/Seattle City Light</p>		<p>Overarching Concern related to EOP-004-2 draft: The contemporaneous drafting efforts related to both the proposed Bulk Electric System ("BES") definition changes, as well as the CIP standards Version 5, could significantly impact the EOP-004-2 reporting requirements. Caution needs to be exercised when referencing these definitions, as the definitions of a BES element could change significantly and Critical Assets may no longer exist.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>As it relates to the proposed reporting criteria, it is debatable as to whether or not the destruction of, for example, one relay would be a reportable incident under this definition going forward given the current drafting team efforts. Related to "Reportable Events" of Attachment 1:1. A reportable event is stated as, "Risk to the BES", the threshold for reporting is, "From a non-environmental physical threat". This appears to be a catch-all event, and basically every other event in Attachment 1 should be reported because it is a risk to the BES. Due to the subjectivity of this event, suggest removing it from the list.</p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>2. A reportable event is stated as, “Damage or destruction of Critical Asset per CIP-002”. The term “Damage” would have to be defined in order for an entity to determine a threshold for what qualifies as “Damage” to a CA. One could argue that normal “Damage” can occur on a CA that is not necessary to report. There should also be caution here in adding CIP interpretation within this standard.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Reporting Thresholds1. The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing. An example is the “BES Emergency requiring manual firm load shedding of greater than or equal to 100 MW or the Loss of Firm load for 15 Minutes that is greater than or equal to 200 MW (300 MW if the manual demand is greater than 3000 MW). In many cases these low thresholds represent reporting of minor wind events or other seasonal system issues on Local Network used to provide distribution service. Firm Demand1. The use of Firm Demand in the context of the draft Standards could be used to describe commercial arrangements with a customer rather than a reliability issue. Clarification of Firm Demand would be helpful</p> <p><i>The DSR SDT has updated the requirements based on comments received along with updating Attachment 1 and 2. Please review the updated standard for all your</i></p>

Organization	Yes or No	Question 4 Comment
		<i>concerns.</i>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Pacific Northwest Small Public Power Utility Comment Group</p>		<p>Project 2008-06 proposes to withdraw the terms “Critical Asset” and “Critical Cyber Asset” from the NERC Glossary. In order to avoid a reliability gap when this occurs, we propose including High and Medium Impact BES Cyber Systems and Assets.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>The revised wording to add, “as appropriate” to R1.3 is a concern. We understand the SDT’s intent to not require all the bulleted parties to be notified for every event type. But will a good faith effort on the part of the registered entity to deem appropriateness be subject to second guessing and possible sanctions by the Compliance Enforcement Authority if they disagree? We note that CIP-001 required an interpretation to address this issue, but cannot assume that interpretation will carry over. We suggest spelling out exactly who shall deem appropriateness.</p> <p><i>The phrase “as appropriate” was removed and Requirement 1, Part 1.2 was revised to:</i></p> <p><i>A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p>R4 continues to be an onerous requirement for smaller entities. Verification was not</p>

Organization	Yes or No	Question 4 Comment
		<p>part of the SAR and we are not convinced it is needed for reliability. We are unsure how a DP with no generation, no BES assets, no Critical Cyber Assets, and less than 100 MW of load; would meet R4. Shall they drill for impossible events? We ask that R4 be removed. At a minimum it should exclude entities that cannot experience the events of Attachment 1. Entities that cannot experience the events of Attachment 1 should likewise be exempt from R1.2, 1.3, R2, and R3.</p> <p><i>Requirement R4 (now R3) was revised to :</i></p> <p><i>Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</i></p> <p><i>Requirement R1, Part 1.1 specifies that an entity must have a process for recognizing “applicable events”. An entity is only required to have the Operating Plan as it relates to events applicable to that entity. The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event. The DSR SDT has updated the Requirements based on comments received along with updating Attachment 1 and 2. Please review the updated Standard for all your concerns.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Clallam County PUD No.1		<p>Project 2008-06 proposes to withdraw the terms “Critical Asset” and “Critical Cyber Asset” from the NERC Glossary. In order to avoid a reliability gap when this occurs,</p>



Organization	Yes or No	Question 4 Comment
		<p>we propose including High and Medium Impact BES Cyber Systems and Assets.</p> <p><i>The 'Damage or Destruction' events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and 'Damage or Destruction of a Facility' reporting thresholds.</i></p> <p>The revised wording to add, “as appropriate” to R1.3 is a concern. We understand the SDT’s intent to not require all the bulleted parties to be notified for every event type. But will a good faith effort on the part of the registered entity to deem appropriateness be subject to second guessing and possible sanctions by the Compliance Enforcement Authority if they disagree? We note that CIP-001 required an interpretation to address this issue, but cannot assume that interpretation will carry over. We suggest spelling out exactly who shall deem appropriateness.</p> <p>Part 1.3 (now Part 1.2 was revised to:</p> <p>1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</p> <p>R4 continues to be an onerous requirement for smaller entities. Verification was not part of the SAR and we are not convinced it is needed for reliability. We are unsure how a DP with no generation, no BES assets, no Critical Cyber Assets, and less than 100 MW of load; would meet R4. Shall they drill for impossible events? We ask that R4 be removed. At a minimum it should exclude entities that cannot experience the events of Attachment 1. Entities that cannot experience the events of Attachment 1 should likewise be exempt from R1.2, 1.3, R2, and R3.</p> <p><i>Part 1.1 has been revised to include “applicable events listed in EOP-004, Attachment</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>1.” If an entity cannot experience an event, then it would not be an applicable event.</i></p> <p><i>Requirement R4 (now R3) has been revised to:</i></p> <p><i>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p><i>The DSR SDT envisions that the testing under R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
FEUS		<p>R4 requires verification through a drill or exercise the communication process created as part of R1.3. Clarification of what a drill or exercise should be considered. In order to show compliance to R4 would the entity have to send a pseudo event report to Internal Personnel, the Regional Entity, NERC ES-ISAC, Law Enforcement, and Governmental or provincial agencies listed in R1.3 to verify the communications plan? It would not be a burden on the entity so much, however, I’m not sure the external parties want to be the recipient of approximately 2000 psuedo event reports annually.</p> <p><i>Requirement R4 (now R3) related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R1, R3 now reads: “Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.”The DSR SDT envisions that the testing under Requirement 3 will include</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling “others as defined in the Responsible Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. This language does not preclude the verification of contact information taking place during a training event.</i></p> <p>Attachment 1: BES equipment is too vague - consider changing to BES facility and including that reduces the reliability of the BES in the footnote. Is the footnote an and or an or? Attachment 1: Version 5 of CIP Requirements remove the terms Critical Asset and Critical Cyber Asset. The drafting team should consider revising the table to include BES Cyber Systems. Clarify if Damage or Destruction is physical damage (aka - cyber incidents would be part of CIP-008.)</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>Attachment 1: Unplanned Control Center evacuation - remove “potential” from the reporting responsibility</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2.</i></p> <p>Attachment 2 - 3: change to, “Did the event originate in your system?” The requirement only requires reporting for Events - not potential events.</p> <p><i>The DSR SDT has streamlined Attachment 2, per comments received.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>Attachment 2 4: “Damage or Destruction to BES equipment” should be “Destruction of BES Equipment” like it is in Attachment 1 and “forced intrusion risk to BES equipment” remove “risk”</p> <p><i>The DSR SDT has streamlined Attachment 2 to reflect the events of Attachment 1, per comments received.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
ReliabilityFirst		<p>ReliabilityFirst thanks the SDT for their effort on this project. ReliabilityFirst has a number of concerns/questions related to the draft EOP-004-2 standard which include the following:</p> <ol style="list-style-type: none"> <li>1. General Comment - The SDT should consider any possible impacts that could arise related to the applicability of Generator Owners that may or may not own transmission facilities. This will help alleviate any potential or unforeseen impacts on these Generator Owners</li> </ol> <p><i>The DSR SDT cannot apply items such as GO/TO issues when NERC and the Regions are not in agreement to what the issue and solution is.</i></p> <ol style="list-style-type: none"> <li>2. General Comment - Though the rationale boxes contain useful editorial information for each requirement, they should rather contain the technical rationale or answer the question “why is this needed” for each requirement. The rationale boxes currently seem to contain suggestions on how to meet the requirements. ReliabilityFirst suggests possibly moving some of the statements in the “Guideline and Technical Basis” into the rationale boxes, as some of the rationale seems to be contained in that section.</li> </ol> <p><i>The DSR SDT will continue to update rationale boxes per comments received.</i></p> <ol style="list-style-type: none"> <li>3. General comment - The end of Measure M4 is incorrectly pointing to R3. This should refer to R4.</li> </ol> <p><i>Measurement 4 has been corrected.</i></p> <ol style="list-style-type: none"> <li>4. General Comment - ReliabilityFirst recommends the “Reporting Hierarchy for</li> </ol>

Organization	Yes or No	Question 4 Comment
		<p>Reportable Events” flowchart should be removed from the “Background” section and put into an appendix. ReliabilityFirst believes the flowchart is not really background information, but an outline of the proposed process found in the new standard.</p> <p><i>The DSR SDT provided a flow chart for stakeholders to use if desired. EOP-004-2 sets a minimum level of reporting per the events described in Attachment 1. The DSR SDT has received negative feedback in past drafts, the DSR SDT was too prescriptive.</i></p> <p>5. Applicability Comment - ReliabilityFirst questions the newly added applicability for both the Regional Entity (RE) and ERO. Standards, as outlined in many, if not all, the FERC Orders, should have applicability to users, owners and operators of the BES and not to the compliance monitoring entities (e.g. RE and ERO). Any requirements regarding event reporting for the RE and ERO should be dealt with in the NERC Rules of Procedure and/or Regional Delegation Agreements. It is also unclear who would enforce compliance on the ERO if the ERO remains an applicable entity.</p> <p><i>The ERO is an Applicable Entity under the current version of CIP-008 and therefore they are held to EOP-004-2. Note, this proposed Standard has been through two Quality Reviews and there has been no rejection from NERC .</i></p> <p>6. Requirement Comment - ReliabilityFirst believes the process for communicating events in Requirement R1, Part 1.3 should be all inclusive and therefore include the bullet points. Bullet points are considered to be “OR” statements and thus ReliabilityFirst believes they should be characterized as sub-parts. Listed below is an example:1.3. A process for communicating events listed in Attachment 1 to the following:1.3.1 Electric Reliability Organization, 1.3.2 Responsible Entity’s Reliability Coordinator 1.3.3 Internal company personnel 1.3.4 The Responsible Entity’s Regional Entity 1.3.5 Law enforcement 1.3.6 Governmental or provincial agencies</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: “Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Part 1.2. ". The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>7. Requirement Comment - ReliabilityFirst questions why Requirement R1, Part 1.1 and Part 1.2 are not required to be verified when performing a drill or exercise in Requirement R4? ReliabilityFirst believes that performing a drill or exercise utilizing the process for identifying events (Part 1.1) and the process for gathering information (Part 1.2) are needed along with the verification of the process for communicating events as listed in Part 1.3.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: "Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. ". The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>8. Compliance Section Comment - Section 1.1 states "If the Responsible Entity works for the Regional Entity..." and ReliabilityFirst questions the intent of this language. ReliabilityFirst is unaware of any Responsible Entities who work for a Regional Entity. Also, if the Regional Entity and ERO remain as applicable entities, in Section 1.1 of</p>

Organization	Yes or No	Question 4 Comment
		<p>the standard, it is unclear who will act as the Compliance Enforcement Authority (CEA).</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from NERC guideline documents</i></p> <p>9. Compliance Section Comment - ReliabilityFirst recommends removing the second, third and fourth paragraphs from Section 1.2 since ReliabilityFirst believes entities should retain evidence for the entire time period since their last audit.</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from NERC guideline documents</i></p> <p>10. Compliance Section Comment - ReliabilityFirst recommends modifying the fifth paragraph from Section 1.2 as follows: “If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until found compliant or until a data hold release is issued by the CEA.” ReliabilityFirst believes, as currently stated, the CEA would be required to retain information for an indefinite period of time.</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from NERC guideline documents.</i></p> <p>11. Compliance Section Comment - ReliabilityFirst recommends removing the sixth paragraph from Section 1.2 since the requirement for the CEA to keep the last audit records and all requested and submitted subsequent audit records is already covered in the NERC ROP.</p> <p><i>The DSR SDT has followed the guidance in the Standards Development process to assure that “template” information is correct. The language included is directly from</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>NERC guideline documents</i></p> <p>12. Attachment 1 Comment - It is unclear what the term/acronym “Tv” is referring to. It may be beneficial to include a footnote clarifying what the term “Tv” stands for.</p> <p><i>Tv is based on FAC-010 and the DSR SDT believes that this is clear to affected stakeholders.</i></p> <p>13. VSL General Comment - although ReliabilityFirst believes that the applicability is not appropriate, as the REs and ERO are not users, owners, or operators of the Bulk Electric System, the Regional Entity and ERO are missing from all four sets of VSLs, if the applicability as currently written stays as is. If the Regional Entity and ERO are subject to compliance for all four requirements, they need to be included in the VSLs as well. Furthermore, for consistency with other standards, each VSL should begin with the phrase “The Responsible Entity...”</p> <p><i>The DSR SDT will follow the guidance in the Standards Development process to assure that “template” information is correct.</i></p> <p>14. VSL 4 Comment - The second “OR” statement under the “Lower” VSL should be removed. By not verifying the communication process in its Operating Plan within the calendar year, the responsible entity completely missed the intent of the requirement and is already covered under the “Severe” VSL category.</p> <p><i>The DSR SDT will follow the guidance in the Standards Development process to assure that “template” information is correct.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Northeast Power Coordinating</p>		<p>Requirement 4 does not specifically state the details necessary for an entity to</p>



Organization	Yes or No	Question 4 Comment
Council		<p>achieve compliance. Requirement 4 should provide more guidance as to what is required in a drill. Audit/enforcement of any requirement language that is too broad will potentially lead to Regional interpretation, inconsistency, and additional CANs.R4 should be revised to delete the 15 month requirement. CAN-0010 recognizes that entities may determine the definition of annual.The standard is too specific, and drills down into entity practices, when the results are all that should be looked for.The standard is requiring multiple reports.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: "Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. ". The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p> <p>The Purpose of the Standard is very broad and should be revised because some of the events being reported on have no impact on the BES. Revise Purpose wording as follows: To improve industry awareness and the reliability of the Bulk Electric System "by requiring the reporting of major system events with the potential to impact reliability and their causes..." on the Bulk Electric System it can be said that every event occurring on the Bulk Electric System would have to be reported.</p> <p><i>The DSR SDT revised the purpose statement to remove ambiguous language "with the potential to impact reliability". The Purpose statement now reads:</i></p> <p><i>"To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities."</i></p>

Organization	Yes or No	Question 4 Comment
		<p>Referring to Requirement R4, the testing of the communication process is the responsibility of the Responsible Entity. There is an event analysis process already in place. The standard prescribes different sets of criteria, and forms. There should be one recipient of event information. That recipient should be a “clearinghouse” to ensure the proper dissemination of information.</p> <p><i>EOP-004 is a standard that requires reporting of events to the ERO. The events analysis program receives these reports and determines whether further analysis is appropriate.</i></p> <p>Why is this standard applicable to the ERO?</p> <p><i>NERC as the ERO is currently a Responsible Entity under CIP-008, and therefore the proposed EOP-004-2 has the ERO as a Responsible Entity.</i></p> <p>Requirement R2 is not necessary. It states the obvious. Requirements R2 and R3 are redundant. The standard mentions collecting information for Attachment 2, but nowhere does it state what to do with Attachment 2.</p> <p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“Requirement R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p>

Organization	Yes or No	Question 4 Comment
		<p>None of the key concepts identified on page 5 of the standard are clearly stated or described in the requirements:</p> <ul style="list-style-type: none"> <li>o Develop a single form to report disturbances and events that threaten the reliability of the bulk electric system.</li> </ul> <p><i>OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li>• <i>EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <ul style="list-style-type: none"> <li>o Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements.</li> <li>o Establish clear criteria for reporting.</li> <li>o Establish consistent reporting timelines.</li> </ul> <p><i>The DSR SDT does allow entities to use the DOE Form OE 417 in lieu of Attachment 2 to report an event. Attachment 1 has been updated to provide consistent criteria for reporting as well as reporting timelines. All one hour reporting timelines have been changed to 24 hours with the exception of a ‘Reportable Cyber Security Incident’. This is maintained due to FERC Order 706, Paragraph 673:</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>“...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>o Provide clarity for who will receive the information and how it will be used. The standard’s requirements should be reviewed with an eye for deleting those that are redundant, or do not address the Purpose or intent of the standard.</p> <p><i>Requirement R1 has been updated and now reads as”</i></p> <p><i>Each Responsible Entity shall have an Operating Plan that includes:</i></p> <ul style="list-style-type: none"> <li><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></li> <li><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></li> </ul> <p><i>The Applicable Entity’s Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your</i></p>

Organization	Yes or No	Question 4 Comment
		<i>company's needs and wants.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
American Public Power Association		<p>Requirement R1:1.3. A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity's Reliability Coordinator and the following as appropriate: o Internal company personnel o The Responsible Entity's Regional Entity o Law enforcement o Governmental or provincial agencies APPA believes that including the list of other entities needing to be included in a process for communicating events under 1.3 may open this requirement up for interpretation. APPA requests that the SDT remove from the requirement the listing of; "Internal company personnel, The Responsible Entity's Regional Entity, Law enforcement &amp; Governmental or provincial agencies" and include these references in a guidance document. The registered entities need to communicate with the ERO and the RC if applicable for compliance with this standard and to maintain the reliability of the BES. Communication with other entities such as internal company personnel, law enforcement and the Regional Entity are expected, but do not impact the reliability of the BES. This will simplify the reporting structure and will not be burdensome to registered entities when documenting compliance. If this is not an acceptable solution, APPA suggests revising 1.3 to remove the wording "the following as appropriate" and add "other entities as determined by the Responsible Entity. Examples of other entities may include, but are not limited to:" Then it is clear that the list is examples and should not be enforced by the auditor.</p> <p><i>Requirement R1 has been updated and now reads as</i></p> <p><i>"Each Responsible Entity shall have an Operating Plan that includes:</i></p> <p><i>1.1. A process for recognizing each of the events listed in EOP-004 Attachment 1.</i></p> <p><i>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.</i></p> <p><i>The Applicable Entity’s Operating Plan is to contain the process for reporting events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and for communicating to others as defined in the Responsible Entity’s Operating Plan. All events in Attachment 1 are required to be reported to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator. The Operating Plan may include: internal company personnel, your Regional Entity, law enforcement, and governmental or provisional agencies, as you identify within your Operating Plan. This gives you the flexibility to tailor your Operating Plan to fit your company’s needs and wants.</i></p> <p>1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3. APPA understands that the SDT is following the FERC order requiring a 90 day limit on updates to any changes to the plan. However, APPA believes that “updating the Operating Plan within 90 calendar days of any change...” is a very burdensome compliance documentation requirement. APPA reminds the SDT that including DPs in this combined standard has increased the number of small Responsible Entities that will be required to document compliance. APPA requests that the SDT combine requirement 1.4 and 1.5 so the Operating Plan will be reviewed and updated with any changes on a yearly basis. If this is not an acceptable solution, APPA suggests that the “Lower VSL” exclude a violation to 1.4. The thought being, a violation of 1.4 by itself is a documentation error and should not be levied a penalty.</p> <p><i>Requirement 1, Part 1.4 has been removed from the standard.</i></p> <p>Attachment 1: Events Table APPA believes that the intent of the SDT was to mirror the DOE OE-417 criteria in reporting requirements. With the inclusion of DP in the</p>

Organization	Yes or No	Question 4 Comment
		<p>Applicability, however, APPA believes the SDT created an unintended excessive reporting requirement for DPs during insignificant events.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p>APPA recommends that a qualifier be added to the events table. In DOE OE-417 local electrical systems with less than 300MW are excluded from reporting certain events since they are not significant to the BES.</p> <p>APPA believes that the benefit of reporting certain events on systems below this value would not outweigh the compliance burden placed on these small systems. Therefore, APPA requests that the standard drafting team add the following qualifier to the Events Table of Attachment 1: “For systems with greater than 300MW peak load.” This statement should be placed in the Threshold for Reporting column for the following Events: BES Emergency requiring appeal for load reduction, BES</p>

Organization	Yes or No	Question 4 Comment
		<p>Emergency requiring system-wide voltage reduction, BES Emergency requiring manual firm load shedding, BES Emergency resulting in automatic firm load shedding. This will match the DOE OE-417 reporting criteria and relieve the burden on small entities.</p> <p><i>Upon review of the DOE OE 417, it states “Local Utilities in Alaska, Hawaii, Puerto Rico, the U.S. Virgin Islands, and the U.S. Territories - If the local electrical system is less than 300 MW, then only file if criteria 1, 2, 3 or 4 are met”. Please be advised this exception applies to entities outside the continental USA.</i></p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn’t missed.</i></p> <p>Definition of “Risk to BES equipment”:The SDT attempted to give examples of the Event category “Risk to BES equipment” in a footnote. This footnote gives the Responsible Entity and the Auditor a lot of room for interpretation. APPA suggests that the SDT either define this term or give a triggering mechanism that the industry would understand. One suggestion would be “Risk to BES equipment: An event that forces a Facility Owner to initiate an unplanned, non-standard or conservative operating procedure.” Then list; “Examples include train derailment adjacent to BES Facilities that either could have damaged the equipment directly or has the potential to damage the equipment...” This will allow the entity to have an operating procedure linked to the event. If this suggestion is taken by the SDT then the Reporting column of Attachment 1 needs to be changed to: “The parties identified pursuant to R1.3 within 1 hour of initiating conservative operating procedures.”</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Western Electricity Coordinating Council</p>		<p>Results-based standards should include, within each requirement, the purpose or reason for the requirement. The requirements of this standard, while we support the requirements, do not include the goal or proupose of meeting each stated requirement. The Measures all include language stating “the responsible entity shall provide...”. During a quality review of a WECC Regional Reliability Standard we were told that the “shall provide” language is essentially another requirement to provide something. If it is truly necessary to provide this it should be in the requirements. It was suggested to us that we drop the “shall provide” language and just start each Measure with the “Evidence may include but is not limited to...”.</p> <p><i>The DSR SDT changed each instance of “shall” to “will” within the measures. We will defer to NERC Quality Review comments for any additional revisions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Sacramento Municipal Utility District (SMUD)</p>		<p>SMUD and BANC agree with the revised language in EOP-004-1 requirements, but we have identified the following issues in A-1:We commend the SDT for properly addressing the sabotage issue. However, additional confusion is caused by introducing term "damage". As "damage" is not a defined term it would be beneficial for the drafting team to provide clarification for what is meant by "damage".</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></li> </ul> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p><i>As discussed in prior comment forms, the DSR SDT has elected not to define “sabotage”. As defined in an Entity’s operating Plan, the requirement is to report and communicate an event as listed in Attachment 1. EOP-004-2 does not require analysis of any event listed in Attachment 1.</i></p> <p>The threshold for reporting "Each public Appeal for load reduction" should clearly state the triggering is for the BES Emergency as routine "public appeal" for conservation could be considered a threshold for the report triggering.</p> <p><i>To clarify your point, the threshold has been changed to ‘Public appeal or load reduction event’.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>Regarding the SOL Violations in Attachment 1 the SOL Violations should only be those that affect the WECC paths.</p> <p><i>The DSR SDT has included the following language for WECC’s SOL violation in Attachment 1:</i></p> <p><i>“IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)”</i></p> <p>The SDT made attempts to limit nuisance reporting related to copper thefts and so on which is supported. However a number of the thresholds identified in EOP-004-2 Attachment 1 are very low and could congest the reporting process with nuisance reporting and reviewing.</p> <p><i>The DSR SDT made reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Southern Company		<p>Southern has the following comments:(1) In Requirement R1.4, we request the SDT to clarify what is meant by the term “assets”?</p> <p><i>The DSR SDT has deleted Requirement R1, Part 1.4, thus “assets” is not contained in EOP-004-2 based on comments received.</i></p> <p>2) If requirement 4 is not deleted, should we have to test every possible event described in our Operating Plan or each event listed in Attachment 1 to verify communications?</p> <p><i>The DSR SDT has deleted Requirement R4 based on comments received.</i></p> <p>(3) In the last paragraph of the “Summary of Key Concepts” section on page 6 of</p>

Organization	Yes or No	Question 4 Comment
		<p>Draft 3, there is a statement that “Real-time reporting is achieved through the RCIS...” The only reporting required on RCIS by the Standards is for EEAs and TLRs. Please review and modify this language as needed.</p> <p><i>The DSR SDT believes “The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting” is correct.</i></p> <p>(4) Evidence Retention (page 12 of Draft 3): The 3 calendar year reference has no bearing on a Standard that may be audited on a cycle greater than 3 years.</p> <p><i>The DSR SDT has updated the Evidence Retention section with standard language provided by NERC staff.</i></p> <p>(5) In the NOTE for Attachment 1 (page 20 of Draft 3), what is meant by “periodic verbal updates” and to whom should the updates be made?</p> <p><i>The DSR SDT has updated the note in question to remove the language of “periodic verbal updates”, it now reads as:</i></p> <p><i>“NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p>(6) There are Prerequisite Approvals listed in the Implementation Plan. Is it appropriate to ask industry to vote on this Standard Revision that has a prerequisite approval of changes in the Rules of Procedure that have not been approved?</p> <p><i>The proposed revisions to the Rules of Procedure should have been posted with the</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>standard. This posting will occur with the successive ballot of EOP-004-2.</i></p> <p>(7) We believe the reporting of the events in Attachment 1 has no reliability benefit to the Bulk Electric System. We suggest that Attachment 1 should be removed.</p> <p><i>The DSR SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Texas Reliability Entity</p>		<p>Substantive comments:1.ERO and Regional Entities should not be included in the Applicability of this standard. Just because they may be subject to some CIP requirements does not mean they also have to be included here. The ERO and Regional Entities do not operate equipment or systems that are integral to the operation of the BES. Also, none of the VSLs apply to the ERO or to Regional Entities.</p> <p><i>The DSR SDT is following guidance that NERC has provided to the DSR SDT. The ERO and the RE are applicable entities under CIP-008. Reporting of Cyber Security Incidents is the responsibility of the ERO and the RE.</i></p> <p>2.The first entry in the Events Table should say “Damage or destruction of BES equipment.” Equipment may be rendered inoperable without being “destroyed,” and entities should not have to determine within one hour whether damage is sufficient to cause the equipment to be considered “destroyed.” Footnote 1 refers to equipment that is “damaged or destroyed.”</p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity.</i></p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for several events listed in</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>Attachment 1. A Facility is defined as:</i></p> <p><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>3.In the Events Table, consider whether the item for “Voltage deviations on BES facilities” should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator and power system stabilizer) could have a similar impact on the BES as other reportable items.</p> <p><i>The DSR SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p> <p>4.In the Events Table, under Transmission Loss, does this item require that at least three Facilities owned by one entity must be lost to trigger the reporting requirement, or is the reporting requirement also to be triggered by loss of three Facilities during one event or occurrence that are owned by two or three different entities?</p> <p><i>The DSR SDT has stated in Attachment 1 that “Each TOP that experiences the transmission loss”. This would mean per individual TOP.</i></p> <p>5.In the Events Table, under Transmission Loss, it is unclear how Facilities are to be counted to determine when “three or more” Facilities are lost. In the NERC Glossary, Facility is ambiguously defined as “a set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)” In many cases, a “set of electrical equipment” can be selected and counted in different ways, which makes this item ambiguous.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Both Transmission and Facilities are defined terms and the DSR SDT feels this gives sufficient direction.</i></p> <p>6.In the Events Table, under Transmission Loss, it appears that a substation bus failure would only count as a loss of one Facility, even though it might interrupt flow between several transmission lines. We believe this type of event should be reported under this standard, and appropriate revisions should be made to this entry.</p> <p><i>The DSR SDT used the defined term “Facility” to add clarity for this event as well as other events in Attachment 1. A Facility is defined as:</i></p> <p style="padding-left: 40px;"><i>“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</i></p> <p><i>The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.</i></p> <p>7.In the Events Table, under Transmission Loss, consider including generators that are lost as a result of transmission loss events when counting Facilities. For example, if a transmission line and a transformer fail, resulting in a generator going off-line, that should count as a loss of “three or more” facilities and be reportable under this standard.</p> <p><i>Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p> <p>8.In the Events Table, under “Unplanned Control Center evacuation” and “Loss of monitoring or all voice communication capability,” GOPs should be included. GOPs also operate control centers that would be subject to these kinds of occurrences.</p> <p><i>Attachment 1 is the minimum set of events that will be required to report and</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>communicate per your Operating Plan will be aware of system conditions.</i></p> <p>9.In the Events Table, under “Loss of monitoring or all voice communication capability,” we suggest adding that if there is a failure at one control center, that event is not reportable if there is a successful failover to a backup system or control center.</p> <p><i>The DSR SDT has split this event into two separate events based on comments received, it now reads as: “Loss of all voice communication capability” and “Complete or partial loss of monitoring capability”.</i></p> <p>10.”Fuel supply emergency” is included in the Event Reporting Form, but not in Attachment 1, so there is no reporting threshold or deadline provided for this type of event.</p> <p><i>Attachment 2 was updated to reflect the revisions to Attachment 1. The reference to “actual or potential events” was removed. Also, the event type of “other” and “fuel supply emergency” was removed as well.</i></p> <p>Clean-up items:1.In R1.5, capitalize “Responsible Entity” and lower-case “process”.</p> <p><i>The DSR SDT has deleted Requirement 1, part 1.5.</i></p> <p>2.In footnote 1, add “or” before “iii)” to clarify that this event type applies to equipment that satisfies any one of these three conditions.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>3.In the Event Reporting Form, “forced intrusion” and “Risk to BES equipment” are run together and should be separated.</p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred.</i></p> <p>VSLs:1.We support the substance of the VSLs, but the repeated long list of entities makes the VSLs extremely difficult to read and decipher. The repeated list of entities should be replaced by “Responsible Entities.” 2.If the ERO and Regional Entities are to be subject to requirements in this standard (which we oppose), they need to be added to the VSLs.</p> <p><i>The DSR SDT has revised the VSLs to eliminate the list of entities and lead with “Responsible Entity”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
		<p>Suggest removing 1.4 since 1.5 ensures a annual review. . The implementation of the plan should also include the necessary reporting.</p> <p><i>Requirement R1, Part 1.4 has been removed.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Electric Compliance</p>		<p>The concepts of “Critical Assets” and “Critical Cyber Assets” no longer exist in Version 5 of the CIP Standards and so this may cause confusion. Recommend modifying to be in accordance with Version 5. Additionally, it is debatable whether the</p>

Organization	Yes or No	Question 4 Comment
		<p>destruction of, for example, one relay would be a reportable incident given the proposed language. We recommend modifying the language to insure nuisance reporting is minimized. One reportable event is, “Risk to the BES” and the threshold for reporting is, “From a non-environmental physical threat.” This appears to be a catch-all reportable event. Due to the subjectivity of this event description, we suggest removing it from the list.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”</i> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>Footnote 1 and the “Threshold for Reporting” associated with the Event described as “Destruction of BES equipment” expand the reporting scope. For example, a fan on a</p> </li></ul>

Organization	Yes or No	Question 4 Comment
		<p>transformer can be destroyed because a technician drops a screwdriver into it. We believe such an event should not be reportable under EOP-004-2. Yet, as written, a Responsible Entity could interpret that event as reportable (because it would be “unintentional human action” that destroyed a piece of equipment associated with the BES). If the goal of the SDT was to include such events, we think the draft Standard goes too far in requiring reporting. If the SDT did not intend to include such events, the draft Standard should be revised to make that fact clear. Proposed Footnote: BES equipment that become damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service that i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii). Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>The word “Significantly” in item ii) of footnote 1 and “as appropriate” in section 1.3 introduces elements of subjectivity. What is “significant” or “appropriate” to one person may not be to someone else.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>In section 1.4, we believe that revising the plan within 90 days of “any” change should be changed to 180 days or else classes of events should be made so that only</p>

Organization	Yes or No	Question 4 Comment
		<p>substantial changes are required to made within the 90 day timeframe.</p> <p><i>Requirement R1, Part 1.4 was removed from the standard.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Georgia System Operations Corporation</p>		<p>The ERO and the Regional Entity should not be listed as Responsible Entities. The ERO and the Regional Entity should not have to meet the requirements of this standard, especially reporting to itself.</p> <p><i>The ERO and the RE are applicable under the CIP-008 standard and are therefore applicable under EOP-004.</i></p> <p>Attachment 1 (all page numbers are from the clean draft):Page 20, destruction of BES equipment: part iii) of the footnote adds damage as an event but the heading is for destruction. Is it just for destruction? Or is it for damage or destruction?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The ‘Destruction’ event category has been revised to include damage or destruction of a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></p> <p>Page 21, Risk to BES equipment: Footnote 3 gives an example where there is flammable or toxic cargo. These are environmental threats. However, the threshold for reporting is for non-environmental threats. Which is it?</p> <p><i>For this event, environmental threats are considered to be severe weather, earthquakes, etc. rather than an external threat.</i></p> <p>Page 21, BES emergency requiring public appeal for load reduction: A small deficient</p>

Organization	Yes or No	Question 4 Comment
		<p>entity within a BA may not initiate public appeals. The BA is typically the entity which initiates public appeals when the entire BA is deficient. The initiating entity should be the responsible entity not the deficient entity.</p> <p><i>The DSR SDT revised this event to indicate the “initiating” entity is responsible for reporting.</i></p> <p>Page 21, BES emergency requiring manual firm load shedding: If a RC directs a DP to shed load and the DP initiates manually shedding its load as directed, is the RC the initiating entity? Or is it the DP?</p> <p><i>The DSR SDT believes the wording of “initiating entity” provides enough clarity for each applicable entity to understand. In this case, the RC made the call to shed load and therefore should report.</i></p> <p>Page 22, system separation (islanding): a DP does not have a view of the system to see that the system separated or how much generation and load are in the island. Remove DP.</p> <p><i>The DSR SDT disagrees with your comment. DP’s may be the first to recognize that they are islanded or separated from the system.</i></p> <p>Attachment 2 (all page numbers are from the clean draft):Page 25: fuel supply emergencies will no longer be reportable under the current draft.</p> <p><i>The DSR SDT has removed both “fuel supply emergency” and “other” from Attachment 2 based on comments received.</i></p> <p>Miscellaneous typos and quality issues (all page numbers are from the clean draft):Page 5, the last paragraph: There are two cases where Parts A or B are referred to. Attachment 1 no longer has two parts (A &amp; B).Page 27, Discussion of Event Reporting: the second paragraph has a typo at the beginning of the sentence.</p>

Organization	Yes or No	Question 4 Comment
		<i>The DSR SDT has corrected these typos.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
Thompson Coburn LLP on behalf of Miss. Delta Energy Agency		<p>The first three incident categories designated on Attachment 1 as reportable events should be modified. As the Standard is current drafted, each incident category (i.e., destruction of BES equipment, damage or destruction of Critical Assets, and damage or destruction of Critical Cyber Assets) requires reporting if the event was due to unintentional human action. For example, under the reporting criteria as drafted, inadvertently dropping and damaging a piece of computer equipment designated as a Critical Cyber Asset while moving or installing it would appear to require an event report within an hour of the incident.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”</i> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> </li></ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>MDEA requests that the Drafting Team consider modifying footnote 1 and each of the first three event categories to reflect that reportable events include only those that (i) affect an IROL; (ii) significantly affect the reliability margin of the system; or (iii) involve equipment damage or destruction due to intentional human action that results in the removal of the BES equipment, Critical Assets, and/or Critical Cyber Assets, as applicable, from service.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>Footnote 2 (which now pertains only to the fourth incident category - forced intrusions) should also apply to the first three event categories. Specifically, responsible entities should report intentional damage or destruction of BES equipment, damage or destruction of Critical Assets, and damage or destruction of Critical Cyber Assets if either the damage/destruction was clearly intentional or if motivation for the damage or destruction cannot reasonably be determined and the damage or destruction affects the reliability of the BES.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>Attachment 1 is also unclear to the extent that the incident category involving reports for the detection of reportable Cyber Security Incidents includes a reference to CIP-008 as the reporting threshold. While entities in various functional categories</p>

Organization	Yes or No	Question 4 Comment
		<p>(i.e., RCs, BAs, TOPs/TOs, GOPs/GOs, and DPs) are listed as being responsible for the reporting of such events, some entities in these functional categories may not currently be subject to CIP-008. If it is the Drafting Team’s intent to limit event reports for Cyber Security Incidents to include only registered entities subject to CIP-008, that clarification should be incorporated into the listing of entities with reporting responsibility for this incident category in Attachment 1.</p> <p><i>The “Entity with reporting responsibility” for the event “A reportable Cyber Security Incident” has been revised to “Each Responsible Entity applicable under CIP-008-4 or its successor that experiences the Cyber Security Incident”.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Luminant Power		<p>The following comments all apply to Attachment 1:</p> <ul style="list-style-type: none"> <li>o As a general comment, SDT should specifically list the entities the reportable event applies to in the table for clarity. Do not use general language referencing another standard or statements such as “Deficient entity is responsible for reporting”, “Initiating entity is responsible for reporting”, or other similar statements used currently in the table. This leaves this open and subject to interpretation.</li> </ul> <p><i>The DSR SDT disagrees with your comment. This language provides the most flexibility for applicable entities and maintains a minimum level of who is required to report or communicate events based an entity’s Operating Plan, as described in Requirement 1.</i></p> <p>Also, there are a number of events that do not apply to all entities.</p> <ul style="list-style-type: none"> <li>o Destruction of BES equipment should be Intentional Damage or Destruction of BES equipment. Unintentional actions occur and should not be a requirement for reporting under disturbance reporting.</li> </ul> <p><i>The event for “Destruction of BES equipment” has been revised to “Damage or destruction of a Facility”. The threshold for reporting information was expanded for</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>clarity:</i></p> <p><i>“Damage or destruction of a Facility that: affects an IROL OR Results in the need for actions to avoid an Adverse Reliability Impact OR Results from intentional human action.”</i></p> <p>o Actions or situations affecting equipment or generation unit availability due to human error, equipment failure, unintentional human action, external cause, etc. are reported in real time to the BA and other entities as required by other NERC Standards. Disturbance reporting should avoid the type of events that, for instance, would cause the total or partial loss of a generating unit under normal operational circumstances. There are a number of issues with the table in this regard.</p> <p><i>The DSR SDT has removed such language based on comments received.</i></p> <p>o For clarity, consider changing the table to identify for each event type “who” should be notified. This appears to be missing from the table overall.</p> <p><i>The DSR SDT has updated Requirement R1, Part 1.2 to read as: ““1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p> <p>o Reportable Events, the meaning for the Event labeled “Destruction of BES equipment” is not clear. Footnote 1 adds the language “iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment</p>

Organization	Yes or No	Question 4 Comment
		<p>from service.” This language can be interpreted to mean that any damage to any BES equipment caused by human action, regardless of intention, must be reported within 1 hour of recognition of the event. This requirement will be overly burdensome. If this is not the intent of the definition of “Destruction of BES equipment”, the footnote should be re-worded. As such, it is subjective and left open to interpretation. It should focus only on intentional actions to damage or interrupt BES functionality. It should not be worded as such that every item that trips a unit or every item that is damaged on a unit requires a report. That is where the language right now is not clear. There are and will continue to be unintentional human error that results in taking equipment out of service. This standard was meant to replace sabotage reporting.</p> <p><i>All footnotes are deleted and appropriate content moved to ‘Thresholds for Reporting’ with the exception of the footnote relating to the new event category ‘A physical threat that could impact the operability of a Facility’. This remaining footnote provides examples only.</i></p> <p>o Damage or destruction of Critical Asset per CIP-002 and Damage or destruction of a Critical Cyber Asset per CIP-002 should be removed from the table as Intentional Damage or Destruction of BES equipment would cover this as well.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Asset.”</i></p> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>o Risk to BES equipment should be removed from the table as it is very subjective and broad. At a minimum, the 1 hour reporting timeline should begin after recognition and assessment of the incident. As an example, a fire close to BES equipment may not truly be a threat to the equipment and will not be known until an assessment can be made to determine the risk.</p> <p><i>The DSR SDT has removed this event based on comments received.</i></p> <p>o Detection of a Reportable Cyber Security incident should be removed from the table as this is covered by CIP-008 requirements. Having this in two separate standards is double jeopardy and confusing to entities.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p>

Organization	Yes or No	Question 4 Comment
		<ul style="list-style-type: none"> <li>• <i>Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li>• <i>Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”</i></li> </ul> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>o Generation Loss event reporting should only apply to the BA. These authorities have the ability and right to contact generation resources to supply necessary information needed for reporting. This would also eliminate redundant reporting by multiple entities for the same event.</p> <p><i>The DSR SDT has tried to minimize duplicative reporting, but recognizes there may be events that trigger more than one report. The current applicability ensures an event that could affect just one of the entities with reporting responsibility isn’t missed.</i></p> <p>o Suggest that Generation Loss MW loss would match up with the 1500 MW level identified in CIP Version 4 or Version 5 for consistency between future CIP standards and this disturbance reporting standard. This would then cover CIP and significant MW losses that should be reported.</p> <p><i>The DSR SDT disagrees as this threshold is based on the current EOP-004-1.</i></p> <p>o The Generation Loss MW loss amount needs to have a time boundary. Luminant</p>

Organization	Yes or No	Question 4 Comment
		<p>would suggest a loss of 1500 MW within 15 minutes.</p> <p><i>The DSR SDT disagrees as this threshold is based on the current EOP-004-1.</i></p> <p>o Unplanned Control Center evacuation should not apply to entities that have backup Control Centers where normal operations can continue without impact to the BES.</p> <p><i>The DSR SDT disagrees with your comment. By reporting and communicating per an entity's Operating Plan, you will provide situational awareness to entities per your Operating Plan.</i></p> <p>o Loss of monitoring or all voice communication capability should be separated. Also the 24 hour reporting requirement may not be feasible if communications is down for longer than 24 hours.</p> <p><i>The DSR SDT has split this event into two separate events based on comments received, it now reads as: "Loss of all voice communication capability" and "Complete or partial loss of monitoring capability".</i></p> <p>Luminant would suggest removal of the communication reporting event as there are a number of things that could cause this to occur for longer than the reporting requirement allows, thus putting entities at jeopardy of a potential violation that is out of their control. How does an entity report if all systems and communications are down for more than 24 hours? What about in instances of a partial or total blackout? These events could last much longer than 24 hours. All computer communication would likely also be down thus rendering electronic reporting unavailable.</p> <p><i>EOP-004-2 only requires an entity to report and communicate per their Operating Plan within the time frames set in Attachment 1.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 4 Comment
Kansas City Power & Light		<p>The implementation plan indicates that much of CIP-008 is retained. The reporting requirements in CIP-008 and the required reportable events outlined in Attachment 1 are an overlap with CIP-008-3 R1.1 which says “Procedures to characterize and classify events as reportable Cyber Security Incidents” and CIP-008-3 R1.3 which requires processes to address reporting to the ES-ISAC. There is also a NERC document titled, Security Guideline for the Electricity Sector: Threat and Incident Reporting, which is a guideline to “assist entities to identify and classify incidents for reporting to the ES-ISAC”. The SDT should consider the content of the Security Guideline for the Electricity Sector: Threat and Incident Reporting when considering the reporting requirements proposed EOP-004. The efforts to incorporate CIP-008 into EOP-004 are insufficient and will result in serious confusion between proposed EOP-004 and CIP-008 and reporting expectations. Considering the complexity CIP incident reporting and the interests of ES-ISAC, it may be beneficial to leave CIP-008 out of the proposed EOP-004 and limit EOP-004 to the reporting interests of NERC.</p> <p><i>Attachment 2 (or the DOE Form OE 417) is the reporting form to be used for reporting a “Cyber Security Incident”.</i></p> <p>The flowchart states, “Notification Protocol to State Agency Law Enforcement”. Please correct this to, “Notification to State, Provincial, or Local Law Enforcement”, to be consistent with the language in the background section part, “A Reporting Process Solution - EOP-004”.</p> <p><i>The DSR SDT has updated the “Example of reporting _Process including Law Enforcement”, and please note that this is only an “example”.</i></p> <p>Measure 4 is not clear enough regarding the extent to which drills should be performed. Does the measure mean that all events in the events list need to be drilled or is drilling a subset of the events list sufficient? Please clearly indicate the extent of drilling that is required or clearly indicate in the requirement the extent of the drills to be performed is the responsibility of the Responsible Entity to identify in their “processes”.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Requirement R4 (now R3) has been revised and the measure now reads:</i></p> <p><i>Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. (R3)</i></p> <p>Evidence Retention - it is not clear what the phrase “prior 3 calendar years” represents in the third paragraph of this section regarding data retention for requirements and measures for R2, R3, R4 and M2, M3, M4 respectively. Please clarify what this means. Is that different than the meaning of “since the last audit for 3 calendar years” for R1 and M1?</p> <p><i>This has been revised for clarity and to be consistent with NERC Guidance documents. The new evidence retention reads:</i></p> <p><i>Each Responsible Entity shall retain the current, in force document plus the ‘date change page’ from each version issued since the last audit or the current and previous version for Requirements R1, R4 and Measures M1, M4.</i></p> <p><i>Each Responsible Entity shall retain evidence from prior 3 calendar years for Requirements R2, R3 and Measures M2, M3.</i></p> <p>VSL for R2 under Severe regarding R1.1 may require revision considering the comment regarding R1.1 in item 2 previously stated. In addition, the VRF for R2 is MEDIUM. R2 is administrative regarding the implementation of the requirements specified in R1. Documentation and maintenance should be considered LOWER. There is no VSL for R4 and a VSL for R4 needs to be proposed.</p> <p><i>The DSR SDT reviewed and updated both VSL’s for the new requirements.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		

Organization	Yes or No	Question 4 Comment
SPP Standards Review Group		<p>The inclusion of optional entities to which to report events in R1.3 introduces ambiguity into the standard that we feel needs to be eliminated. We propose the following replacement language for R1.3:A process for communicating events listed in Attachment 1 to the Electric Reliability Organization, the Responsible Entity’s Reliability Coordinator and the Responsible Entity’s Regional Entity.We would also propose to incorporate the law enforcement and governmental or provincial agencies mentioned in R1.3 in Attachment 1 by adding them to the existing language for each of the event cells. For example, the first cell in that column would read:The parties identified pursuant to R1.3 and applicable law enforcement and governmental or provincial agencies within 1 hour of recognition of event.Similarly, the phrase ‘...and applicable law enforcement and governmental or provincial agencies...’ should be inserted in all the remaining cells in the 4th column.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Requirement R1,Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
Santee Cooper		<p>The on-going development of the definition of the BES could have significant impacts on reporting requirements associated with this standard.The event titled “Risk to the</p>



Organization	Yes or No	Question 4 Comment
		<p>BES” appears to be a catch-all event and more guidance needs to be provided on this category.</p> <p><i>Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had overlap in the perceived reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “A physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p>The event titled “Damage or Destruction of a Critical Asset or Critical Cyber Asset per CIP-002” is ambiguous and further guidance is recommended. Ambiguity in a standard leaves it open to interpretation for all involved.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<ul style="list-style-type: none"> <li>• <i>Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.</i></li> </ul> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Florida Municipal Power Agency</p>		<p>The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., “Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements”) so that changes to the RoP do not necessitate changes to the standard.</p> <p><i>The language incorporated in this section of the standard is boilerplate language provided by NERC staff for inclusion in each standard.</i></p> <p>In R4, it might be worth clarifying that, in this case, implementation of the plan for an event that does not meet the criteria of Attachment 1 and going beyond the requirements R2 and R3 could be used as evidence. Consider adding a phrase as such to M4, or a descriptive footnote that in this case, “actual event” may not be limited to those in Attachment 1.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>Most stakeholders believed that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:</i></p> <p><i>“Requirement R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1.”</i></p> <p>Comments to Attachment 1 table: On “Damage or destruction of Critical Asset” and “... Critical Cyber Asset”, Version 5 of the CIP standards is moving away from the binary critical/non-critical paradigm to a high/medium/low risk paradigm. Suggest adding description that if version 5 is approved by FERC, that “critical” would be replaced with “high or medium risk”, or include changing this standard to the scope of the CIP SDT, or consider posting multiple versions of this standard depending on the outcome of CIP v5 in a similar fashion to how FAC-003 was posted as part of the GO/TO effort of Project 2010-07.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as stakeholders pointed out that these events were adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds. CIP-008 addresses Cyber Security Incidents which are defined as:</i></p> <p><i>“Any malicious act or suspicious event that:</i></p> <ul style="list-style-type: none"> <li><i>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</i></li> <li><i>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Asset.”</i></p> <p><i>A Critical Asset is defined as:</i></p> <p><i>“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”</i></p> <p><i>Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.</i></p> <p>On “forced intrusion”, the phrase “at BES facility” is open to interpretation as “BES Facility” (e.g., controversy surrounding CAN-0016) which would exclude control centers and other critical/high/medium cyber system Physical Security Perimeters (PSPs). We suggest changing this to “BES Facility or the PSP or Defined Physical Boundary of critical/high/medium cyber assets”. This change would cause a change to the applicability of this reportable event to coincide with CIP standard applicability.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘ to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>On "Risk to BES equipment", that phrase is open to too wide a range of interpretation; we suggest adding the word "imminent" in front of it, i.e., "Imminent risk to BES equipment". For instance, heavy thermal loading puts equipment at risk, but not imminent risk. Also, "non-environmental" used as the threshold criteria is ambiguous. For instance, the example in the footnote, if the BES equipment is near railroad tracks, then trains getting derailed can be interpreted as part of that BES equipment's "environment", defined in Webster's as "the circumstances, objects, or conditions by which one is surrounded". It seems that the SDT really means "non-weather related", or "Not risks due to Acts of Nature".</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The 'Damage or Destruction' event category has been revised to say 'to a Facility', (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• 'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>On "public appeal", in the threshold, the descriptor "each" should be deleted, e.g., if a single event causes an entity to be short of capacity, do you really want that entity reporting each time they issue an appeal via different types of media, e.g., radio, TV, etc., or for a repeat appeal every several minutes for the same event?</p> <p><i>The DSR SDT has updated the event concerning "public appeals" based on comments received and now reads as: "Public appeal for load reduction event".</i></p> <p>Should LSE be an applicable entity to "loss of firm load"? As proposed, the DP is but the LSE is not. In an RTO market, will a DP know what is firm and what is non-firm load? Suggest eliminating DP from the applicability of "system separation". The system separation we care about is separation of one part of the BES from another which would not involve a DP.</p> <p><i>The DSR SDT believes the "Entity with Reporting Responsibility" maintains the minimum number and type of entities that will be required to report such an event.</i></p> <p>On "Unplanned Control Center Evacuation", CIP v5 might add GOP to the applicability, another reason to add revision of EOP-004-2 to the scope of the CIP v5 drafting team, or in other ways coordinate this SDT with that SDT. Consider posting a couple of versions of the standard depending on the outcome of CIP v5 in a similar fashion to the multiple versions of FAC-003 posted with the Go/TO effort of Project 2010-07.</p>

Organization	Yes or No	Question 4 Comment
		<p><i>The DSR SDT can only provide information on approved standards, not yet to be defined standards.</i></p>
<p><b>Response: Thank you for your comment.</b> Please see response above.</p>		
<p>Dominion</p>		<p>There is still inconsistency in Attachment 1 vs. the DOE OE-417 form; in future changes, Dominion suggests align/rename events similar to that of the ‘criteria for filing’ events listed in the DOE OE-417, by working in coordination with the DOE.</p> <p><i>Thank you for your comment. Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG’s requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>• EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’</i></li> <li><i>• OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li><i>• NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li><i>• Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p><i>Please note that not all entities in North America are required to submit the DOE Form OE 417.</i></p> <p>Minor comment; in the Background section, the drafting team refers to bulk power</p>

Organization	Yes or No	Question 4 Comment
		<p>system (redline page 5; 1st paragraph and page 7; 2nd paragraph) rather than bulk electric system.</p> <p><i>This has been revised to Bulk Electric System.</i></p> <p>The note in Attachment 1 states in part that “the affected Responsible Entity shall notify parties per R1 and ...” Dominion believes the correct reference to be R3. In addition, capitalized terms “Event” and “Event Report” are used in this note. Dominion believes the terms should be non-capitalized as they are not NERC defined terms.</p> <p><i>The DSR SDT has updated this note based on comments received and now reads as: “NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written event report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per R1 and provide as much information as is available at the time of the notification. Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</i></p> <p>Attachment 1 - “Detection of a reportable Cyber Security Incident - That meets the criteria in CIP-008”. This essentially equates the criteria to be defined by the entity in its procedures as required by CIP-008 R1.1., additional clarification should be added in Attachment 1 to make this clear.</p> <p><i>The DSR SDT believes that this event language provides enough clarity by providing the minimum events to be reported.</i></p> <p>The last sentence in Attachment 2 instructions should clarify that the email, facsimile and voice communication methods are for ERO notification only.</p> <p><i>The DSR SDT agrees and has revised the sentence to include “to the ERO”.</i></p> <p>Dominion continues to believe that the drill or exercise specified in R4 is</p>



Organization	Yes or No	Question 4 Comment
		<p>unnecessary. Dominion suggests deleting this activity in the requirement.</p> <p><i>Requirement R4 related to an annual test of the communication portion of Requirement R1 by a drill or exercise and this has been removed. Requirement R3 now reads: "Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. "</i></p> <p><i>The DSR SDT envisions that the testing under Requirement R3 will include verification of contact information contained in the Operating Plan is correct. As an example, the annual review of the Operating Plan could include calling "others as defined in the Responsible Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Ingleside Cogeneration LP</p>		<p>We are encouraged that the 2009-01 project team has eliminated duplicate reporting requirements from multiple organizations and governmental agencies. Ingleside Cogeneration LP believes that there are further improvements that can be made in this area - as the remaining overlap seem to be a result of legalities and preferences, not technical issues. We would like to see an ongoing commitment by NERC for a single process that will consolidate and automate data entry, submission, and distribution.</p> <p><i>Attachment 1 is the basis for EOP-004-2; it contains the events and thresholds for reporting. OE-417, as well as, the EAWG's requirements were considered in creating Attachment 1, but there remain differences for the following reasons:</i></p> <ul style="list-style-type: none"> <li><i>EOP-004 requirements were designed to meet NERC and the industry's needs; accommodation of other reporting obligations was considered as an</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>opportunity not a 'must-have'</i></p> <ul style="list-style-type: none"> <li>• <i>OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America</i></li> <li>• <i>NERC has no control over the criteria in OE-417, which can change at any time</i></li> <li>• <i>Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary</i></li> </ul> <p><i>In an effort to minimize administrative burden, US entities may use OE-417 rather than Attachment 2 to report under EOP-004. Note you may have to report the same event more quickly to the DOE than is required by EOP-004, but this cannot be helped due to bullet point 2 above.</i></p> <p><i>Please note that not all entities in North America are required to submit the DOE Form OE 417.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>SERC OC Standards Review Group</p>		<p>We believe that reporting of the events in Attachment 1 has no reliability benefit to the bulk electric system. In addition, Attachment 1, in its current form, is likely to be impossible to implement consistently across North America. A requirement, to be considered a reliability requirement, must be implementable. We suggest that Attachment 1 should be removed.</p> <p><i>The DSR SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.</i></p> <p>We have a question about what looks like a gap in this standard: Assuming one of the drivers for the standard is to protect against a coordinated physical or cyber attack on the grid, what happens if the attack occurs in 3-4 geographically diverse areas? State or provisional law enforcement officials are not accountable under the standard, so we have no way of knowing if they report the attack to the FBI or the</p>

Organization	Yes or No	Question 4 Comment
		<p>RCMP. Even if one or two of them did, might not the FBI, in different parts of the country, interpret it as vandalism, subject to local jurisdiction? It seems that NERC is the focal point that would have all the reports and, ideally, some knowledge how the pieces fit together. It looks like NERC's role is to solely pass information on "applicable" events to the FERC. Unless the FERC has a 24x7 role not shown in the standard, should not NERC have some type of assessment responsibility to makes inquiries at the FBI/RCMP on whether they are aware of the potential issue and are working on it?" The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review group only and should not be construed as the position of SERC Reliability Corporation, its board or its officers."</p> <p><i>Requirement R1, Part 1.2 was updated and now reads as: "A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement governmental or provincial agencies."</i></p> <p><i>By reporting to the ERO all events, this will allow the ERO to coordinate with other agencies as they see fit.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>ZGlobal on behalf of City of Ukiah, Alameda Municipal Power, Salmen River Electric, City of Lodi</p>		<p>We feel that the drafting team has done an excellent job of providing clarification and reasonable reporting requirements to the right functional entity. However we feel additional clarification should be made in the Attachment I Event Table. We suggest the following modifications: For the Event: BES Emergency resulting in automatic firm load shedding Modify the Entity with Reporting Responsibility to: Each DP or TOP that experiences the automatic load shedding within their respective distribution serving or Transmission Operating area.</p> <p><i>The DSR SDT believes the "Entity with Reporting Responsibility" contains the minimum</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>entities that will be required to report and reads as: "Each DP or TOP that experiences the automatic load shedding"</i></p> <p>For the Event: Loss of Firm load for 15 Minutes Modify the Entity with Reporting Responsibility to: Each BA, TOP, DP that experiences the loss of firm load within their respective balancing, Transmission operating, or distribution serving area.</p> <p><i>The DSR SDT believes the "Entity with Reporting Responsibility" contains the minimum entities that will be required to report and reads as: "Each BA, TOP, DP that experiences the loss of firm load"</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>PSEG</p>		<p>We have several comments:1. The "Law Enforcement Reporting" section on p. 6 is unclearly written. The first three sentences are excerpted here: "The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement."The outages described prior to the last sentence are "vandalism and terrorism." The next sentence states "Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES." If the SDT intended to only have events reported to law enforcement that could to Cascading, it should state so clearly and succinctly. But other language implies otherwise.</p> <p><i>The DSR SDT has updated the "Example of reporting _Process including Law Enforcement", and please note that this is only an "example".</i></p> <p>a. The footnote 1 on Attachment 1 (p. 20) states: "Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g.,</p>

Organization	Yes or No	Question 4 Comment
		<p>removal of grounding straps rendering protective relaying inoperative).” Rendering a relay inoperative may or may not lead to Cascading.</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: “A physical threat that could impact the operability of a Facility”. This event has the following footnote, which states: “Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>b. With regard to “forced intrusion,” footnote 2 on Attachment 1 states: “Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects (sic) the reliability of the BES.” The criterion, or criteria, for reporting an event to law enforcement needs to be unambiguous. The SDT needs to revise this “Law Enforcement Section” so that is achieved. The “law enforcement reporting” criterion, or criteria, should also be added to the flow chart on p. 9. We suggest the following as a starting point for the team to discuss: there should be two criteria for reporting an event to law enforcement: (1) BES equipment appears to have been deliberately damaged, destroyed, or stolen, whether by physical or cyber means, or (2) someone has gained, or attempted to gain, unauthorized access by forced or unauthorized entry (e.g., via a stolen employee keycard badge) into BES facilities, including by physical or cyber means.</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows: The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>deleted</i></p> <p><i>'Forced intrusion' and 'Risk to BES Equipment' have been combined under a new event type called 'A physical threat that could impact the operability of a Facility'. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>2. The use of the terms “communicating events” in R1.3, and the use of the term “communication process” are confusing because in other places such as R3 the term “reporting” is used. If the SDT intends “communicating” to mean “reporting” as that later term is used in R3, it should use the same “reporting” term in lieu of “communicating” or “communication” elsewhere. Inconsistent terminology causes confusion. PSEG prefers the word “reporting” because it is better understood.</p> <p><i>Requirement R1, Part 1.3 (now Part 1.2) was revised to add clarifying language by eliminating the phrase “as appropriate” and indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Requirement R1, Part 1.2 now reads:</i></p> <p><i>“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement governmental or provincial agencies.”</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>The SDT envisions that most entities will only need to slightly modify their existing CIP-001 Sabotage Reporting procedures in order to comply with the Operating Plan requirement in this proposed standard. As many of the features of both are substantially similar, the SDT feels that some information may need to updated and verified.</i></p> <p>3. Attachment 1 needs to more clearly define what is meant by “recognition of an event.”a. When equipment or a facility is involved, it would better state within “X” time (e.g., 1 hour) of “of confirmation of an event by the entity that either owns or operates the Element or Facility.”</p> <p><i>Based on stakeholder comments, Requirement R1 was revised for clarity. Requirement R1, Part 1.1 was revised to replace the word “identifying” with “recognizing” and Part 1.2 was eliminated. This also aligns the language of the standard with FERC Order 693, Paragraph 471.</i></p> <p><i>“(2) specify baseline requirements regarding what issues should be addressed in the procedures for recognizing {emphasis added} sabotage events and making personnel aware of such events;”</i></p> <p>b. Other reports should have a different specification of the starting time of the reporting deadline clock. For example, in the requirement for reporting a “BES Emergency requiring public appeal for load reduction,” it is unclear what event is required to be reported - the “BES Emergency requiring public appeal” or “public appeal for load reduction.” If the later is intended, then the event should be reported within “24 hours after a public appeal for load reduction is first issued.” These statements need to be reviewed and customized for each event by the SDT so they are unambiguous.</p> <p><i>All one hour reporting timelines have been changed to 24 hours with the exception of a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>'Reportable Cyber Security Incident'. This is maintained due to FERC Order 706, Paragraph 673:</i></p> <p><i>"...direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>For the remaining events, 24 hours should provide sufficient time to manage the incident in real-time before having to report and is consistent with current in-force standard EOP-004-1.</i></p> <p>In summary, the starting time for the reporting clock to start running should be made clear for each event. This will require that the SDT review each event and customize the starting time appropriately. The phrase "recognition of an event" should not be used because it is too vague.</p> <p><i>Based on stakeholder comments, Requirement R1 was revised for clarity. Part 1.1 was revised to replace the word "identifying" with "recognizing" and Part 1.2 was eliminated. This also aligns the language of the standard with FERC Order 693, Paragraph 471.</i></p> <p><i>"(2) specify baseline requirements regarding what issues should be addressed in the procedures for recognizing {emphasis added} sabotage events and making personnel aware of such events;"</i></p> <p>4. When EOP-004-2 refers to other standards, it frequently omits the version of the standard. Example: see the second and third row of Attachment 1 that refers to "CIP-002." Include the version on all standards referenced.</p> <p><i>References to CIP-002 have been removed from the standard. The intent of referencing those standards is to prevent rewriting the standard within EOP-004-2. The threshold for reporting CIP-008 events is written as "That meets the criteria in CIP-008-4 or its successor."</i></p>



Organization	Yes or No	Question 4 Comment
<p>Response: Thank you for your comment. Please see response above.</p>		
<p>Ameren</p>		<p>Yes. We have the other comments as follow:(1) The "EOP-004 Attachment 1: Events Table" is quite lengthy and written in a manner that can be quite subjective in interpretation when determining if an event is reportable. We believe this table should be clear and unambiguous for consistent and repeatable application by both reliability entities and a CEA.</p> <p><i>The DSR SDT has reviewed and further revised Attachment 1 based on comments received. We believe that it is both concise and easily interpreted.</i></p> <p>The table should be divided into sections such as: 9a) Events that affect the BES that are either clearly sabotage or suspected sabotage after review by an entity's security department and local/state/federal law enforcement.(b) Events that pose a risk to the BES and that clearly reach a defined threshold, such as load loss, generation loss, public appeal, EEAs, etc. that entities are required to report by the end of the next business day.(c) Other events that may prove valuable for lessons learned, but are less definitive than required reporting events. These events should be reported voluntarily and not be subject to a CEA for non-reporting.</p> <p><i>The DSR SDT received many comments regarding the various entries of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is "A reportable Cyber Security Incident" as it required by CIP-008 and FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>The table was reformatted to separate one hour reporting and 24 hour reporting. The last column of the table was also deleted and the information contained in it was transferred to the sentence above each table. These sentences are:</i></p> <p><i>"One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event."</i></p> <p><i>"Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event."</i></p> <p>(d)Events identified through other means outside of entity reporting, but due to their nature, could benefit the industry by an event report with lessons learned. Requests to report and perform analysis on these type of events should be vetted through a ERO/Functional Entity process to ensure resources provided to this effort have an effective reliability benefit.</p> <p><i>The DSR SDT has deleted the "lessons learned" language. Requirement R4 now only requires an annual review of the Operating Plan - the '90 days' and ' other circumstances' elements have been removed.</i></p> <p>(2)Any event reporting shall not in any manner replace or inhibit an Entity's responsibility to coordinate with other Reliability Entities (such as the RC, TOP, BA, GOP as appropriate) as required by other Standards, and good utility practice to operate the electric system in a safe and reliable manner.</p> <p><i>The DSR SDT concurs with your comment.</i></p>

Organization	Yes or No	Question 4 Comment
		<p>(3) The 1 hour reporting maximum time limit for all GO events in Attachment 1 should be lengthened to something reasonable - at least 24 hours. Operators in our energy centers are well-trained and if they have good reason to suspect an event that might have serious impact on the BES will contact the TOP quickly. However, constantly reporting events that turn out to have no serious BES impact and were only reported for fear of a violation or self-report will quickly result in a cry wolf syndrome and a great waste of resources and risk to the GO and the BES. The risk to the GO will be potential fines, and the risk to the BES will be ignoring events that truly have an impact of the BES.</p> <p><i>The DSR SDT received many comments regarding the various entries of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments as well as those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is "A reportable Cyber Security Incident" as it required by CIP-008 and FERC Order 706, Paragraph 673:</i></p> <p><i>"direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event..."</i></p> <p><i>The table was reformatted to separate one hour reporting and 24 hour reporting. The last column of the table was also deleted and the information contained in it was transferred to the sentence above each table. These sentences are:</i></p> <p><i>"One Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>event.”</i></p> <p><i>“Twenty-four Hour Reporting: Submit Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event.”</i></p> <p>(4)The 2nd and 3rd Events on Attachment 1 should be reworded so they do not use terms that may have been deleted from the NERC Glossary by the time FERC approves this Standard.</p> <p><i>The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1, as these events are adequately addressed through the CIP-008 and ‘Damage or Destruction of a Facility’ reporting thresholds.</i></p> <p>(5) The terms “destruction” and “damage” are key to identifying reportable events. Neither has been defined in the Standard. The term destruction is usually defined as 100% unusable. However, the term damage can be anywhere from 1% to 99% unusable and take anywhere from 5 minutes to 5 months to repair. How will we know what the SDT intended, or an auditor will expect, without additional information?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren’t related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p><i>(6)We also do not understand why “destruction of BES equipment” (first item Attachment 1, first page) must be reported &lt; 1 hour, but “system separation (islanding) &gt; 100 MW” (Attachment 1, page 3) does not need to be reported for 24 hours.</i></p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <p><i>The ‘Damage or Destruction’ event category has been revised to say ‘to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></p> <p><i>‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p> <p>(7)The first 2 Events in Attachment 1 list criteria Threshold for Reporting as "...operational error, equipment failure, external cause, or intentional or unintentional human action." The term "intentional or unintentional human action" appears to cover "operational error" so these terms appear redundant and create risk of misreporting. Can this be clarified?</p> <p><i>The DSR SDT has updated this language based on comments received and now reads as: " Damage or destruction of a Facility that:</i></p> <p><i>Affects an IROL (per FAC-014)</i></p> <p><i>OR</i></p> <p><i>Results in the need for actions to avoid an Adverse Reliability Impact</i></p> <p><i>OR</i></p> <p><i>Results from intentional human action."</i></p> <p>(8)The footnote of the first page of Attachment 1 includes the explanation "...ii) Significantly affects the reliability margin of the system..." However, the GO is prevented from seeing the system and has no idea what BES equipment can affect the reliability margin of the system. Can this be clarified by the SDT?</p> <p><i>The DSR SDT has removed all footnotes with the exception of the updated event within Attachment 1 that states: "A physical threat that could impact the operability of a Facility". This event has the following footnote, which states: "Examples include a</i></p>

Organization	Yes or No	Question 4 Comment
		<p><i>train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>(9) The use of the term “BES equipment” is problematic for a GO. NERC Team 2010-17 (BES Definition) has told the industry its next work phase will include identifying the interface between the generator and the transmission system. The 2010-17 current effort at defining the BES still fails to clearly define whether or not generator tie-lines are part of the BES. In addition, NERC Team 2010-07 may also be assigned the task of defining the generator/transmission interface and possibly whether or not these are BES facilities. Can the SDT clarify the use of this term? For example, does it include the entire generator lead-line from the GSU high-side to the point of interconnection? Does it include any station service transformer supplied from the interconnected BES?</p> <p><i>The DSR SDT has modified Attachment 1 to bring more clarity. The more subjective events were rewritten as follows:</i></p> <ul style="list-style-type: none"> <li><i>• The ‘Damage or Destruction’ event category has been revised to say ‘ to a Facility’, (a defined term) and thresholds have be modified to provide clarity. The footnote was deleted</i></li> <li><i>• ‘Forced intrusion’ and ‘Risk to BES Equipment’ have been combined under a new event type called ‘A physical threat that could impact the operability of a Facility’. Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported. Note that the reporting timeline (now revised to 24 hours) starts when the situation has been determined as a threat, not when it</i></li> </ul>

Organization	Yes or No	Question 4 Comment
		<p><i>may have first occurred. Also, the footnote only contains examples.</i></p> <p><i>These two remaining event categories that aren't related to power system phenomena are essential as they effectively translate the intent of CIP-001 into EOP-004.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p>Performance Analysis Subcommittee</p>		<p>There continues to be some confusion regarding whether the loss of firm load was consistent with the planned operation of the system or was an unintended consequence. As such it might be helpful if instead of a single check box for loss of firm load there were two check boxes 1) loss of firm load – consequential and 2) loss of firm load non-consequential.</p> <p><i>Thank you for your comment. The DSR SDT believes that Attachment 2 contains the minimum amount of information under this standard. Any entity reporting an event can add as much information as they see fit.</i></p>
<p><b>Response: Thank you for your comment. Please see response above.</b></p>		
<p><b>Southwestern Power Administration's</b></p>		<p>"Attachment 1 contains elements that do not need to be included, and redundant elements such as:</p> <p>Forced intrusion at BES Facility - A facility break-in does not necessarily mean that the facility has been impacted or has undergone damage or destruction.</p> <p><i>The DSR SDT discussed this event as well as the event "Risk to BES equipment". These two event types had overlap in the perceived reporting requirements. The DSR SDT removed "Forced Intrusion" as a category and the "Risk to BES equipment" event was</i></p>



Organization	Yes or No	Question 4 Comment
		<p><i>revised to “Any physical threat that could impact the operability of a Facility”.</i></p> <p><i>Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.</i></p> <p><i>The footnote regarding this event type was expanded to provide additional guidance in:</i></p> <p><i>“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”</i></p> <p>Detection of a reportable Cyber Security Incident per CIP-008 - If entities are addressing this requirement in CIP-008, why do so again in EOP-004 (Attachment 2- EOP-004, Reporting Requirement number 5)?</p> <p><i>The reporting aspects of CIP-008 have been removed from CIP-008 and are included in EOP-004. Please see the Implementation Plan with regards to the retirement of CIP-008, R1.3</i></p> <p>Transmission Loss: Each TOP that experiences transmission loss of three or more facilities - This element should be removed or rewritten so that it only applies when the loss includes a contingent element of an IROL facility."</p> <p><i>The DSR SDT disagrees with limiting this type of event to only “a contingent element</i></p>

Organization	Yes or No	Question 4 Comment
		<i>of an IROL facility.” It is important for situational awareness and trending analysis to have these types of events reported.</i>
<b>Response: Thank you for your comment. Please see response above.</b>		
The Performance Analysis Subcommittee		<p>There continues to be some confusion regarding whether the loss of firm load was consistent with the planned operation of the system or was an unintended consequence. As such it might be helpful if instead of a single check box for loss of firm load there were two check boxes 1) loss of firm load – consequential and 2) loss of firm load non-consequential.</p> <p><i>The DSR SDT believes that this information should be obtained in follow up through the Events Analysis Program. The reporting entity may have concerns or difficulties in determining if load is consequential or non-consequential in its initial analysis for the report. Further investigation outside of the reporting time of 24 hours may be needed to make this determination.</i></p>
<b>Response: Thank you for your comment. Please see response above.</b>		
Xcel Energy		
Los Angeles Department of Water and Power		
Liberty Electric Power		
Nebraska Public Power District		
Southwestern Power Administration		

Organization	Yes or No	Question 4 Comment
Electric Reliability Council of Texas, Inc.		

**END OF REPORT**

## Standard Development Timeline

---

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 15 – October 15, 2010)
6. Second Comment Period (Formal) (March 9 – April 8, 2011)
7. Third Comment Period and Initial Ballot (October 28 – December 12, 2011)

### Proposed Action Plan and Description of Current Draft

This is the fourth posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a 30-day formal comment period concurrent with the formation of the ballot pool and the successive ballot.

### Future Development Plan

<b>Anticipated Actions</b>	<b>Anticipated Date</b>
Drafting team considers comments, makes conforming changes on third posting	January - March 2012
Fourth Comment/Ballot period	March – April 2012
Recirculation Ballot period	May 2012
Receive BOT approval	June 2012
File with regulatory authorities	August 2012

## EOP-004-2 — Event Reporting

---

### Effective Dates

EOP-004-2 shall become effective on the first day of the third calendar quarter after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the third calendar quarter after Board of Trustees approval, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

### Version History

Version	Date	Action	Change Tracking
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting. Retire CIP-008-3, Requirement 1, Part 1.3.	Revision to entire standard (Project 2009-01)

### **Definitions of Terms Used in Standard**

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## A. Introduction

1. **Title:** Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.
4. **Applicability**
  - 4.1. **Functional Entities: Within the context of EOP-004-2, the term “Responsible Entity” shall include the following entities as shown in EOP-004 Attachment 1:**
    - 4.1.1. Reliability Coordinator
    - 4.1.2. Balancing Authority
    - 4.1.3. Interchange Coordinator
    - 4.1.4. Transmission Service Provider
    - 4.1.5. Transmission Owner
    - 4.1.6. Transmission Operator
    - 4.1.7. Generator Owner
    - 4.1.8. Generator Operator
    - 4.1.9. Distribution Provider
    - 4.1.10. Load Serving Entity
    - 4.1.11. Electric Reliability Organization
    - 4.1.12. Regional Entity

## 5. Background:

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient Bulk Electric System reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

### **Summary of Key Concepts**

The DSRSDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the Bulk Electric System
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1 pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. EOP-004 Attachment 1 covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.



The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting.

### **Data Gathering**

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### **Law Enforcement Reporting**

The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### **Stakeholders in the Reporting Process**

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. Annual requirements, under the standard, of the industry have not been clear and have led to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, responsible entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**


A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

## B. Requirements and Measures

**R1.** Each Responsible Entity shall have an event reporting Operating Plan that includes: *[Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]*

- 1.1. A process for recognizing each of the applicable events listed in EOP-004 Attachment 1 (except for Cyber Security Incidents characterized and classified according to the requirements in CIP-008-3 or its successor).
- 1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies.

**M1.** Each Responsible Entity will have a current, dated, event reporting Operating Plan which includes Parts 1.1 – 1.2.

### Rationale for R1

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; i.e. Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC Events Analysis Program. These other parties use this information to promote reliability, develop a culture of reliability excellence, provide industry collaboration and promote a learning organization.

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective.

Part 1.1 clarifies that entities must address each of the “applicable” events listed in EOP-004 Attachment 1. Not all responsible entities must address all events; e.g., some events are only applicable to the Reliability Coordinator. Part 1.1 acknowledges that Cyber Security Incidents are characterized and classified according to the requirements in CIP-008-3.

Part 1.2 could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information.

An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.

- R2.** Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1. *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*
- M2.** Each Responsible Entity will have, for each event experienced, a dated copy of the completed EOP-004 Attachment 2 form or DOE form OE-417 report submitted for that event; and dated and time-stamped transmittal records to show that the event was reported supplemented by operator logs or other operating documentation. Other forms of evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other operating documentation for situations where filing a written report was not possible. (R2)
- R3.** Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*
- M3.** Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. (R3)

### **Rationale for R2**

Each Responsible Entity must report and communicate events according to its Operating Plan after the fact based on the information in EOP-004 Attachment 1. By implementing the event reporting Operating Plan, the Responsible Entity will assure situational awareness to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies as deemed necessary by the Registered Entity. By communicating events per the Operating Plan, the Responsible Entity will assure that people/agencies are aware of the current situation and they may prepare to mitigate current and further events.

### **Rationale for R3 and R4**

Requirements 3 and 4 call for annual test of the communications process in Part 1.2 as well as an annual review of the event reporting Operating Plan. These two requirements help ensure that the event reporting Operating Plan is up to date and entities will be effective in reporting events to assure situational awareness to the Electric Reliability Organization and their Reliability Coordinator. This will assure that the BES remains secure and stable by mitigation actions that the Reliability Coordinator has within its function.

- R4.** Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1. [*Violation Risk Factor: Medium*] [*Time Horizon: Operations Planning*]
- M4.** Each Responsible Entity will have dated and time-stamped records to show that the annual review of the event reporting Operating Plan was conducted. Such evidence may include, but are not limited to, the current document plus the ‘date change page’ from each version that was reviewed. (R4)

## **C. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1 Compliance Enforcement Authority**

The Regional Entity shall serve as the Compliance enforcement authority unless the applicable entity is owned, operated, or controlled by the Regional Entity. In such cases the ERO or a Regional entity approved by FERC or other applicable governmental authority shall serve as the CEA.

For NERC, a third-party monitor without vested interest in the outcome for NERC shall serve as the Compliance Enforcement Authority.

#### **1.2 Evidence Retention**

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

Each Responsible Entity shall retain the current, document plus the ‘date change page’ from each version issued since the last audit for Requirements R1, R4 and Measures M1, M4.

Each Responsible Entity shall retain evidence from prior 3 calendar years for Requirements R2, R3 and Measure M2, M3.

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until mitigation is complete and approved or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

**1.3 Compliance Monitoring and Enforcement Processes:**

Compliance Audit  
Self-Certification  
Spot Checking  
Compliance Investigation  
Self-Reporting  
Complaint

**1.4 Additional Compliance Information**

None



Table of Compliance Elements

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
<b>R1</b>	Operations Planning	Lower	N/A	N/A	The Responsible Entity has an event reporting Operating Plan but failed to include one of Parts 1.1 through 1.2.	The Responsible Entity failed to include both Parts 1.1 and 1.2.
<b>R2</b>	Operations Assessment	Medium	<p>The Responsible Entity submitted a report more than 24 hours but less than or equal to 36 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p>The Responsible Entity submitted a report in the appropriate timeframe but failed to provide all of the required information.</p>	<p>The Responsible Entity submitted a report more than 36 hours but less than or equal to 48 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p>The Responsible Entity submitted a report more than 1 hour but less than 2 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</p>	<p>The Responsible Entity submitted a report more than 48 hours but less than or equal to 60 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p>The Responsible Entity submitted a report in more than 2 hours but less than 3 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</p>	<p>The Responsible Entity submitted a report more than 60 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p>The Responsible Entity submitted a report more than 3 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</p> <p>OR</p> <p>The Responsible Entity failed to submit a report for an event in</p>

**EOP-004-2 — Event Reporting**

						EOP-004 Attachment 1.
<b>R3</b>	Operations Planning	Medium	The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by less than one calendar month.	The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by one calendar month or more but less than two calendar months.	The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by two calendar months or more but less than three calendar months.	The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by three calendar months or more.  OR The Responsible Entity failed to perform the annual test of the communications process in Part 1.2.
<b>R4</b>	Operations Planning	Medium	The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by less than one calendar month.	The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by one calendar month or more but less than two calendar months.	The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by two calendar months or more but less than three calendar months.	The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by three calendar months or more.  OR The Responsible Entity failed to perform the annual review of the event reporting Operating Plan

**D. Variances**

None.

**E. Interpretations**

None.

**F. Interpretations**

Guideline and Technical Basis (attached).

## EOP-004 - Attachment 1: Reportable Events

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R1 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, Voice: 609-452-1422.

**One Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event.**

Event	Entity with Reporting Responsibility	Threshold for Reporting
A reportable Cyber Security Incident.	Each Responsible Entity applicable under CIP-008-3 or its successor that experiences the Cyber Security Incident	That meets the criteria in CIP-008-3 or its successor

### Rationale Box for EOP-004 Attachment 1:

The DSR SDT used the defined term "Facility" to add clarity for several events listed in Attachment 1. A Facility is defined as:

"A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)"

The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

**EOP-004-2 — Event Reporting**

**Twenty-four Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hours of recognition of the event.**

Event	Entity with Reporting Responsibility	Threshold for Reporting
Damage or destruction of a Facility	Each BA, TO, TOP, GO, GOP, DP that experiences the damage or destruction of a Facility	Damage or destruction of a Facility that: Affects an IROL (per FAC-014) OR Results in the need for actions to avoid an Adverse Reliability Impact OR Results from actual or suspected intentional human action.
Any physical threat that could impact the operability of a Facility <sup>1</sup>	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the event	Threat to a Facility excluding weather related threats.
BES Emergency requiring public appeal for load reduction	Initiating entity is responsible for reporting	Public appeal for load reduction event
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq$ 100 MW

<sup>1</sup> Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.

**EOP-004-2 — Event Reporting**

Event	Entity with Reporting Responsibility	Threshold for Reporting
BES Emergency resulting in automatic firm load shedding	Each DP or TOP that implements automatic load shedding	Firm load shedding $\geq 100$ MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)
Voltage deviation on a Facility	Each TOP that observes the voltage deviation	$\pm 10\%$ sustained for $\geq 15$ continuous minutes
IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)	Each RC that experiences the IROL Violation (all Interconnections) or SOL violation for Major WECC Transfer Paths (WECC only)	Operate outside the IROL for time greater than IROL $T_v$ (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only).
Loss of firm load for $\geq 15$ Minutes	Each BA, TOP, DP that experiences the loss of firm load	<ul style="list-style-type: none"> <li>• <math>\geq 300</math> MW for entities with previous year's demand <math>\geq 3,000</math> MW</li> <li>• <math>\geq 200</math> MW for all other entities</li> </ul>
System separation (islanding)	Each RC, BA, TOP, DP that experiences the system separation	Each separation resulting in an island of generation and load $\geq 100$ MW
Generation loss	Each BA, GOP that experiences the generation loss	<ul style="list-style-type: none"> <li>• <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</li> <li>• <math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection</li> </ul>
Complete loss of off-site power to a nuclear generating plant (grid supply)	Each TO, TOP that experiences the complete loss of off-site power to a nuclear generating plant	Affecting a nuclear generating station per the Nuclear Plant Interface Requirement
Transmission loss	Each TOP that experiences the transmission loss	Unintentional loss of three or more Transmission Facilities (excluding successful automatic reclosing)
Unplanned control center evacuation	Each RC, BA, TOP that experiences the event	Unplanned evacuation from BES control center facility for 30 minutes or more.
Loss of all voice communication capability	Each RC, BA, TOP that experiences the loss of all voice communication capability	Affecting a BES control center for $\geq 30$ continuous minutes

**EOP-004-2 — Event Reporting**

---

Event	Entity with Reporting Responsibility	Threshold for Reporting
Complete or partial loss of monitoring capability	Each RC, BA, TOP that experiences the complete or partial loss of monitoring capability	Affecting a BES control center for $\geq 30$ continuous minutes such that analysis tools (State Estimator, Contingency Analysis) are rendered inoperable.

EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004 Attachment 2: Event Reporting Form</b>	
<p><b>Use this form to report events. The Electric Reliability Organization and the Responsible Entity's Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:esisac@nerc.com">esisac@nerc.com</a>, Facsimile: 609-452-9550, voice: 609-452-1422.</b></p>	
Task	Comments
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:
3.	Did the event originate in your system?      Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
4.	<b>Event Identification and Description:</b>
(Check applicable box) <input type="checkbox"/> public appeal <input type="checkbox"/> voltage reduction <input type="checkbox"/> manual firm load shedding <input type="checkbox"/> firm load shedding(undervoltage, underfrequency, SPS/RAS) <input type="checkbox"/> voltage deviation <input type="checkbox"/> IROL violation <input type="checkbox"/> loss of firm load <input type="checkbox"/> system separation (islanding) <input type="checkbox"/> generation loss <input type="checkbox"/> complete loss of off-site power to nuclear generating plant <input type="checkbox"/> transmission loss <input type="checkbox"/> damage or destruction of Facility <input type="checkbox"/> unplanned control center evacuation <input type="checkbox"/> loss of all voice communication capability <input type="checkbox"/> complete or partial loss of monitoring capability <input type="checkbox"/> physical threat that could impact the operability of a Facility <input type="checkbox"/> reportable Cyber Security Incident	Written description (optional):



## Guideline and Technical Basis

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standard deals exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### Summary of Concepts and Assumptions:

##### ***The Standard:***

- Requires reporting of “events” that impact or may impact the reliability of the Bulk Electric System
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

##### **Discussion of Disturbance Reporting**

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.

3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (EOP-004 Attachment 1).

### **Discussion of Event Reporting**

There are situations worthy of reporting because they have the potential to impact reliability.

Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008-3 or its successor standard
- Forced intrusion attempt at a substation
- Train derailment near a transmission right-of-way
- Destruction of Bulk Electric System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electric System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering necessary for event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for

performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in EOP-004 Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

## Standard Development Timeline

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 15 – October 15, 2010)
6. Second Comment Period (Formal) (March 9 – April 8, 2011)
7. Third Comment Period and Initial Ballot (October 28 – December 12, 2011)

### Proposed Action Plan and Description of Current Draft

This is the ~~third~~fourth posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a ~~45~~30-day formal comment period concurrent with the formation of the ballot pool and the ~~initial~~successive ballot.

### Future Development Plan

Anticipated Actions	Anticipated Date
Drafting team considers comments, makes conforming changes on <del>second</del> <u>third</u> posting	<del>April – October 2011</del> <u>January - March 2012</u>
<del>Third</del> <u>Fourth</u> Comment/Ballot period	<del>November-December 2011</del> <u>March – April 2012</u>
Recirculation Ballot period	<del>December 2011</del> <u>May 2012</u>
Receive BOT approval	<del>February</del> <u>June</u> 2012
<u>File with regulatory authorities</u>	<u>August 2012</u>

### Effective Dates

EOP-004-2 shall become effective on the first day of the third calendar quarter after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the third calendar quarter after Board of Trustees approval, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

### Version History

Version	Date	Action	Change Tracking
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 <del>Impact</del> Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting. Retire CIP-008-43, Requirement 1, Part 1.3.	Revision to entire standard (Project 2009-01)

### Definitions of Terms Used in Standard

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## A. Introduction

1. **Title:** Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve ~~industry awareness and~~ the reliability of the Bulk Electric System by requiring the reporting of events ~~with the potential to impact reliability and their causes, if known, by the~~ Responsible Entities.

### 4. Applicability

- 4.1. **Functional Entities:** Within the context of EOP-004-2, the term “Responsible Entity” shall ~~mean~~ **include the following entities as shown in EOP-004 Attachment 1:**

- 4.1.1. Reliability Coordinator
- 4.1.2. Balancing Authority
- 4.1.3. Interchange Coordinator
- 4.1.4. Transmission Service Provider
- 4.1.5. Transmission Owner
- 4.1.6. Transmission Operator
- 4.1.7. Generator Owner
- 4.1.8. Generator Operator
- 4.1.9. Distribution Provider
- 4.1.10. Load Serving Entity
- 4.1.11. Electric Reliability Organization
- 4.1.12. Regional Entity

### 5. Background:

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient ~~bulk power system~~Bulk Electric System reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

### Summary of Key Concepts

The DSRSDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the ~~bulk electric system~~Bulk Electric System
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1, ~~Part A~~ pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417.



EOP-004 Attachment 1, ~~Part B~~ covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.

The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting.

### Data Gathering

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### Law Enforcement Reporting

The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of ~~bulk power systems~~ Bulk Electric System from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### Stakeholders in the Reporting Process

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. Annual requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, responsible entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**


A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### A Reporting Process Solution – EOP-004

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

## B. Requirements and Measures

**R1.** Each Responsible Entity shall have an event reporting Operating Plan that includes: [*Violation Risk: Factor: Lower*] [*Time Horizon: Operations Planning*]

1.1. A process for identifying/recognizing each of the applicable events listed in EOP-004 Attachment 1 (except for Cyber Security Incidents characterized and classified according to the requirements in CIP-008-3 or its successor).

~~1.2. A process for gathering information for Attachment 2 regarding events listed in Attachment 1.~~

~~1.3. A process for communicating each of the applicable~~ events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization, and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator ~~and the following as appropriate:~~

- ~~• Internal company personnel~~
- ~~• The Responsible Entity's Regional Entity~~
- ~~• Law; law enforcement~~
- ~~• Governmental, governmental or provincial agencies~~

### Rationale for R1

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; i.e. Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC Events Analysis Program. These other parties use this information to promote reliability, develop a culture of reliability excellence, provide industry collaboration and promote a learning organization.

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective.

Part 1.1 clarifies that entities must address each of the "applicable" events listed in EOP-004 Attachment 1. Not all responsible entities must address all events; e.g., some events are only applicable to the Reliability Coordinator. Part 1.1 acknowledges that Cyber Security Incidents are characterized and classified according to the requirements in CIP-008-3.

Part 1.2 could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information. An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.

~~1.4. Provision(s) for updating the Operating Plan within 90 calendar days of any change in assets, personnel, other circumstances that may no longer align with the Operating Plan; or incorporating lessons learned pursuant to Requirement R3.~~

~~1.5.1.2. A Process for ensuring the responsible entity reviews the Operating Plan at least annually (once each calendar year) with no more than 15 months between reviews.~~

**M1.** Each Responsible Entity will ~~provide the~~have a current, dated, ~~in force~~event reporting Operating Plan which includes Parts 1.1 ~~– 1.5 as requested~~2.

~~R2. Each Responsible Entity shall implement the parts of its event reporting Operating Plan that meet Requirement R1, Parts for applicable events listed in EOP-004 Attachment 1.1, and 1.2 for an actual event and Parts 1.4 and 1.5 as in accordance with the timeframe specified in EOP-004 Attachment 1. [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment].~~

**Rationale for R2**

~~Each Responsible Entity must implement the various parts of Requirement R1. Parts 1.1 and 1.2 call for identifying and gathering information for actual events. Parts 1.4 and 1.5 require updating and reviewing the Operating Plan. Each Responsible Entity must report and communicate events according to its Operating Plan after the fact based on the information in EOP-004 Attachment 1. By implementing the event reporting Operating Plan, the Responsible Entity will assure situational awareness to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies as deemed necessary by the Registered Entity. By communicating events per the Operating Plan, the Responsible Entity will assure that people/agencies are aware of the current situation and they may prepare to mitigate current and further events.~~

~~M2. Responsible Entities shall provide evidence that it implemented the parts of its Operating Plan to meet Requirement R1, Parts 1.1 and 1.2 for an actual event and Parts, 1.4 and 1.5 as specified. Evidence may include, but is not limited to, an event report form (Attachment 2) or the OE-417 report submitted, operator logs, voice recordings, or dated documentation of review and update of the Operating Plan. (R2)~~

~~R3. Each Responsible Entity shall report events in accordance with its Operating Plan developed to address the events listed in Attachment 1. [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment].~~

~~M3. Responsible Entities shall provide a record of the type of Each Responsible Entity will have, for each event experienced, a dated copy of the completed EOP-004 Attachment 2 form or DOE form or OE-417 report submitted for that event; and dated and time-stamped transmittal records to show that the event was reported. (R3 supplemented by operator logs or other operating documentation. Other forms of evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other operating documentation for situations where filing a written report was not possible. (R2)~~

**Rationale for R3 and R4**

~~Requirements 3 and 4 call for annual test of the communications process in Part 1.2 as well as an annual review of the event reporting Operating Plan. These two requirements help ensure that the event reporting Operating Plan is up to date and entities will be effective in reporting events to assure situational awareness to the Electric Reliability Organization and their Reliability Coordinator. This will assure that the BES remains secure and stable by mitigation actions that the Reliability Coordinator has within its function.~~

~~R3. Each Responsible Entity shall conduct an annual test, not including notification to~~

the Electric Reliability Organization, of the communications process in Part 1.2. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]

- M3.** Each Responsible Entity will have dated and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. (R3)
- R4.** ~~Each Responsible Entity shall verify (through actual implementation for an event, or through a drill or exercise) the communication process in its Operating Plan, created pursuant to Requirement 1, Part 1.3, at least annually (once per calendar year), with no more than 15 calendar months between verification or actual implementation. conduct an annual review of the event reporting Operating Plan in Requirement R1. [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]~~
- M4.** ~~The Responsible Entity shall provide evidence that it verified the communication process in its Operating Plan for events created pursuant to Requirement R1, Part 1.3. Either implementation of the communication process as documented in its Operating Plan for an actual event or documented evidence of a drill or exercise may be used as evidence to meet this requirement. The time period between an actual event or verification shall be no more than 15 months. Evidence may include, but is not limited to, operator logs, voice recordings, or dated documentation of a verification. (R3) Each Responsible Entity will have dated and time-stamped records to show that the annual review of the event reporting Operating Plan was conducted. Such evidence may include, but are not limited to, the current document plus the ‘date change page’ from each version that was reviewed. (R4)~~

---

## C. Compliance

### 1. Compliance Monitoring Process

#### 1.1 Compliance Enforcement Authority

~~The Regional Entity; or~~  
~~If shall serve as the Responsible Entity works for~~ Compliance enforcement authority unless the Regional Entity, then applicable entity is owned, operated, or controlled by the Regional Entity ~~will establish an agreement with. In such cases~~ the ERO or another Regional entity approved by the ERO and FERC (i.e. another Regional Entity) to be responsible for compliance enforcement; ~~or~~ other applicable governmental authority shall serve as the CEA.



~~Third~~For NERC, a third-party monitor without vested interest in the outcome for the ~~ERONERC~~ shall serve as the Compliance Enforcement Authority.

## 1.2 Evidence Retention

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

Each Responsible Entity shall retain the current, ~~in force~~-document plus the '~~dated revision history~~date change page' from each version issued since the last audit for ~~3 calendar years for Requirement~~Requirements R1, R4 and ~~Measure~~Measures M1, M4.

Each Responsible Entity shall retain evidence from prior 3 calendar years for Requirements R2, R3, ~~R4~~, and ~~Measures~~Measure M2, M3, ~~M4~~.

~~Each Responsible Entity shall retain data or evidence for three calendar years or for the duration of any regional or Compliance Enforcement Authority investigation; whichever is longer.~~

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until ~~found compliant~~mitigation is complete and approved or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

## 1.3 Compliance Monitoring and Enforcement Processes:

Compliance ~~Audits~~Audit

Self-~~Certifications~~Certification

Spot Checking

Compliance ~~Violation Investigations~~Investigation

Self-Reporting

~~Complaints~~Complaint

## 1.4 Additional Compliance Information

None

Table of Compliance Elements

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	<del>Long-term Operations Planning</del>	Lower	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has an Operating Plan but failed to include one of Parts 1.1 through 1.5. N/A</del>	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity has an Operating Plan but failed to include two of Parts 1.1 through 1.5. N/A</del>	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Generator Operator, Distribution Provider or Load Serving Responsible Entity has an event reporting Operating Plan but failed to include three one of Parts 1.1 through 1.5.</del>	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Generator Operator, Distribution Provider or Load Serving Responsible Entity failed to include four or more of both Parts 1.1 through and 1.5.</del>
R2	<del>Real-time Operations and Same-day Operations Assessmen</del>	Medium	<del>1.1: N/A</del>	<del>The Responsible Entity submitted a report more than 36</del>	<del>The Responsible Entity submitted a report more than 48</del>	<del>1.1: The Reliability Coordinator, Balancing Authority,</del>

t		<p><del>1.2: N/A</del></p> <p><del>1.4: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan more than 90 days of a change, but not more than 100 days after a change.</del></p> <p><del>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator,</del></p>	<p><del>hours but less than or equal to 48 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</del></p> <p><del>OR</del></p> <p><del>1.1: N/A</del></p> <p><del>1.2: N/A</del></p> <p><del>1.4: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan</del></p>	<p><del>hours but less than or equal to 60 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</del></p> <p><del>OR 1.1: N/A</del></p> <p><del>1.2: N/A</del></p> <p><del>1.4: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan more than 110 days of a change, but not more than 120 days after a change.</del></p>	<p><del>Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to implement the process for identifying events.</del></p> <p><del>1.2: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to implement the</del></p>
---	--	--	---	---	--

			<p>Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 15 calendar months after its previous review, but not more than 18 calendar months after its previous review. <u>The Responsible Entity submitted a report more than 24 hours but less than or equal to 36 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</u></p>	<p>more than 100 days of a change, but not more than 110 days after a change.</p> <p>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 18 calendar months after its previous review, but not more than 21 calendar months after its previous review. <u>The</u></p>	<p>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 21 calendar months after its previous review, but not more than 24 calendar months after its previous review.</p> <p><u>The Responsible Entity submitted a report in more than 2 hours but less than 3 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</u></p>	<p>process for gathering information for Attachment 2.</p> <p>1.4: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to update the Operating Plan more than 120 days of a change.</p> <p>1.5: The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission</p>
--	--	--	--	---	---	--

			<p><u>OR</u></p> <p><u>The Responsible Entity submitted a report in the appropriate timeframe but failed to provide all of the required information.</u></p>	<p><u>Responsible Entity submitted a report more than 1 hour but less than 2 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</u></p>		<p><del>Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity reviewed the Operating Plan, more than 24 calendar months after its previous review. The Responsible Entity submitted a report more than 60 hours after an event requiring reporting within 24 hours in EOP-004 Attachment 1.</del></p> <p><u>OR</u></p> <p><u>The Responsible Entity submitted a report more than 3 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</u></p> <p><u>OR</u></p> <p><u>The Responsible Entity failed to submit a report for an event in EOP-004</u></p>
--	--	--	--	--	--	--

						<u>Attachment 1.</u>
<b>R3</b>	<del>Real-time Operations and Same-day Operations Planning</del>	Medium	<p><del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 24 hours but less than or equal to 36 hours after an event requiring reporting within 24 hours in Attachment 1.</del></p> <p><u>The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by less</u></p>	<p><del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 36 hours but less than or equal to 48 hours after an event requiring reporting within 24 hours in Attachment 1.</del></p> <p>OR</p> <p><del>The Reliability Coordinator, Balancing Authority, Interchange</del></p>	<p><del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 48 hours but less than or equal to 60 hours after an event requiring reporting within 24 hours in Attachment 1.</del></p> <p><u>The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by two calendar months or more but less than three calendar</u></p>	<p><del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Distribution Provider or Load Serving Entity submitted a report more than 60 hours after an event requiring reporting within 24 hours in Attachment 1.</del></p> <p><u>The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by three calendar months or more.</u></p> <p>OR</p> <p><u>The Reliability</u></p>

			<p><u>than one calendar month.</u></p>	<p><del>Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity</del> submitted a report more than 1 hour but less than 2 hours after an event requiring reporting within 1 hour in Attachment 1. <u>The Responsible Entity performed the annual test of the communications process in Part 1.2 but was late by one calendar month or more but less than two calendar months.</u></p>	<p><u>months.</u></p> <p><del>OR</del></p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Generator Operator, Distribution Provider or Load Serving Entity submitted a report in more than 2 hours but less than 3 hours after an event requiring reporting within 1 hour in Attachment 1.</p>	<p><del>Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Generator Operator, Distribution Provider or Load Serving Entity</del> submitted a report more than 3 hours after an event requiring reporting within 1 hour in Attachment 1. <u>Responsible Entity failed to perform the annual test of the communications process in Part 1.2.</u></p> <p><del>OR</del></p> <p>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider,</p>
--	--	--	--	--	--	--

EOP-004-2 — Event Reporting

						Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to submit a report for an event in Attachment 1.
R4	-Operations Planning	Medium	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan,</del>	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan,</del>	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Operator, Distribution Provider or Load Serving Entity verified the communication process in its Operating Plan, more than 21 calendar months after its previous test, but not</del>	<del>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Operator, Distribution Provider or Load Serving Entity verified performed the communication process in its annual review of the event reporting</del> Operating



			<p><del>more than 15 calendar months after its previous test, but not more than 18 calendar months after its previous test.</del></p> <p><u>OR</u></p> <p><u>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, Distribution Provider or Load Serving Entity failed to verify the communication process in its Operating Plan within the calendar year. The Responsible Entity</u></p>	<p><del>more than 18 calendar months after its previous test, but not more than 21 months after its previous test. The</del></p> <p><u>Responsible Entity performed the annual review of the event reporting Operating Plan but was late by one calendar month or more but less than two calendar months.</u></p>	<p><del>more than 24 months after its previous test. The Responsible Entity performed the annual review of the event reporting Operating Plan but</del></p> <p><u>was late by two calendar months or more but less than three calendar months.</u></p>	<p><del>Plan, more than 24 but was late by three calendar months after its previous test or more.</del></p> <p><u>OR</u></p> <p><u>The Reliability Coordinator, Balancing Authority, Interchange Coordinator, Transmission Service Provider, Transmission Owner, Generator Operator, Generator Operator, Distribution Provider or Load Serving Entity failed to verify the communication process in its Operating Plan. The Responsible Entity failed to perform the annual review of the event reporting Operating Plan</u></p>
--	--	--	---	---	--	--

			<u>performed the annual review of the event reporting Operating Plan but was late by less than one calendar month.</u>			
--	--	--	--	--	--	--

**D. Variances**

None.

**E. Interpretations**

None.

**F. Interpretations**

Guideline and Technical Basis (attached).

EOP-004 - Attachment 1: Reportable Events~~Table~~

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R1 and provide as much information as is available at the time of the notification. ~~The affected Responsible Entity shall provide periodic verbal updates until adequate information is available to issue a written Event report.~~ Reports Submit reports to the ERO ~~should be submitted to~~ via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, Voice: 609-452-1422.

**One Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event.**

<u>Event</u>	<u>Entity with Reporting Responsibility</u>	<u>Threshold for Reporting</u>
<u>A reportable Cyber Security Incident.</u>	<u>Each Responsible Entity applicable under CIP-008-43 or its successor that experiences the Cyber Security Incident</u>	<u>That meets the criteria in CIP-008-43 or its successor</u>

**Rationale Box for EOP-004 Attachment 1:**

The DSR SDT used the defined term "Facility" to add clarity for several events listed in Attachment 1. A Facility is defined as:

"A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)"

The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

**Twenty-four Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hours of recognition of the event.**

Event	Entity with Reporting Responsibility	Threshold for Reporting
<del>Destruction</del> <u>Damage or destruction of BES equipment<sup>1</sup> at a Facility</u>	Each <del>RC</del> , BA, TO, TOP, GO, GOP, DP that experiences the <u>damage or destruction of BES equipment at a Facility</u>	<del>Initial indication</del> <u>Damage or destruction of a Facility that:</u>  <u>Affects an IROL (per FAC-014)</u>  <u>OR</u>  <u>Results in the event was due need for actions to operational error, equipment failure, external cause, or avoid an Adverse Reliability Impact</u>  <u>OR</u>  <u>Results from actual or suspected intentional <del>or unintentional</del> human action.</u>
<del>Damage or destruction of Critical Asset per CIP-002</del>	<del>Applicable Entities under CIP-002</del>	<del>Initial indication the event was due to operational error, equipment failure, external cause, or intentional or unintentional human action.</del>
<del>Damage or destruction of a Critical Cyber Asset per CIP-002</del>	<del>Applicable Entities under CIP-002.</del>	<del>Through intentional or unintentional human action.</del>
<del>Forced intrusion<sup>2</sup></del>	<del>Each RC, BA, TO, TOP, GO, GOP that</del>	<del>At a BES facility</del>

<sup>1</sup>~~BES equipment that: i) Affects an IROL; ii) Significantly affects the reliability margin of the system (e.g., has the potential to result in the need for emergency actions); iii) Damaged or destroyed due to intentional or unintentional human action which removes the BES equipment from service. Do not report copper theft from BES equipment unless it degrades the ability of equipment to operate correctly (e.g., removal of grounding straps rendering protective relaying inoperative).~~

<sup>2</sup>~~Report if you cannot reasonably determine likely motivation (i.e., intrusion to steal copper or spray graffiti is not reportable unless it effects the reliability of the BES).~~

EOP-004-2 — Event Reporting

Event	Entity with Reporting Responsibility	Threshold for Reporting	
	<del>experiences the forced intrusion</del>		
<del>Risk to BES equipment</del> <sup>3</sup> <u>Any physical threat that could impact the operability of a Facility</u> <sup>4</sup>	Each RC, BA, TO, TOP, GO, GOP, DP that experiences the <del>risk to BES equipment</del> <u>event</u>	<del>From a non-environmental physical threat</del> <u>Threat to a Facility excluding weather related threats.</u>	
<del>Detection of a reportable Cyber Security Incident.</del>	<del>Each RC, BA, TO, TOP, GO, GOP, DP, ERO or RE that experiences the Cyber Security Incident</del>	<del>That meets the criteria in CIP-008</del>	
BES- Emergency requiring public appeal for load reduction	<del>Deficient</del> <u>Initiating</u> entity is responsible for reporting	<del>Each public</del> <u>Public</u> appeal for load reduction <u>event</u>	
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more	
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding ≥ 100 MW	
BES Emergency resulting in automatic firm load shedding	Each DP or TOP that <del>experiences</del> <u>implements</u> automatic load shedding	Firm load shedding ≥ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)	
Voltage <del>deviations</del> <u>deviation</u> on <del>BES Facilities</del> <u>a Facility</u>	Each <del>TOP</del> that <del>experiences</del> <u>observes</u> the voltage deviation	± 10% sustained for ≥ 15 continuous minutes	

<sup>3</sup> ~~Examples include a train derailment adjacent to BES equipment that either could have damaged the equipment directly or has the potential to damage the equipment (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a BES facility control center) and report of suspicious device near BES equipment.~~

<sup>4</sup> ~~Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.~~

EOP-004-2 — Event Reporting

Event	Entity with Reporting Responsibility	Threshold for Reporting
IROL Violation (all Interconnections) or SOL Violation <del>for Major WECC Transfer Paths</del> (WECC only)	Each RC that experiences the IROL Violation (all Interconnections) or SOL violation <del>for Major WECC Transfer Paths</del> (WECC only)	Operate outside the IROL for time greater than IROL T <sub>v</sub> (all Interconnections) or Operate outside the SOL for <del>a time greater than the SOL T<sub>v</sub></del> <u>30 minutes for Major WECC Transfer Paths</u> (WECC only).
Loss of <del>Firm</del> firm load for ≥ 15 Minutes	Each BA, TOP, DP that experiences the loss of firm load	<ul style="list-style-type: none"> <li>• ≥ 300 MW for entities with previous year's demand ≥ <del>3000</del> <u>3,000</u> MW</li> <li>• ≥ 200 MW for all other entities</li> </ul>
System <del>Separation</del> <u>(Islanding separation)</u> <del>(islanding)</del>	Each RC, BA, TOP, DP that experiences the system separation	Each separation resulting in an island of generation and load ≥ 100 MW
Generation loss	Each BA, GOP that experiences the generation loss	<ul style="list-style-type: none"> <li>• ≥ 2,000 MW for entities in the Eastern or Western Interconnection</li> <li>• ≥ <del>1000</del> <u>1,000</u> MW for entities in the ERCOT or Quebec Interconnection</li> </ul>
<del>Loss</del> <u>Complete loss</u> of <del>Off</del> off-site power to a nuclear generating plant (grid supply)	Each TO, TOP that experiences the <u>complete</u> loss of off-site power to a nuclear generating plant	Affecting a nuclear generating station per the Nuclear Plant Interface Requirement
Transmission loss	Each TOP that experiences the transmission loss	Unintentional loss of <del>Three</del> <u>three</u> or more Transmission Facilities (excluding successful automatic reclosing)
Unplanned <del>Control Center</del> <u>control center</u> evacuation	Each RC, BA, TOP that experiences the <del>potential</del> event	Unplanned evacuation from BES control center facility <u>for 30 minutes or more.</u>
<u>Loss of all voice communication capability</u>	<u>Each RC, BA, TOP that experiences the loss of all voice communication capability</u>	<u>Affecting a BES control center for ≥ 30 continuous minutes</u>
<del>Loss</del> <u>Complete or partial loss</u> of monitoring <del>or all voice communication</del> capability	Each RC, BA, TOP that experiences the <u>complete or partial</u> loss of <del>or all voice communication</del> monitoring <del>or all voice communication</del> capability	<del>Voice Communications:—</del> <u>Affecting a BES control center for ≥ 30 continuous minutes</u> <del>Monitoring:—</del> <u>Affecting a BES control center for ≥ 30 continuous minutes such that analysis tools (State Estimator, Contingency</u>

**EOP-004-2 — Event Reporting**

---

Event	Entity with Reporting Responsibility	Threshold for Reporting
		Analysis) are rendered inoperable.



EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004, Attachment 2: Event Reporting Form</b>	
<p><del>This Use this form is to be used to report events to parties listed in Attachment 1, column labeled "Submit Attachment 2 or DOE OE-417 Report to:". These parties, The Electric Reliability Organization and the Responsible Entity's Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:esisac@nerc.com">esisac@nerc.com</a>, Facsimile: 609-452-9550, voice: 609-452-1422.</del></p>	
Task	Comments
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:
3.	Did the <del>actual or potential</del> event originate in your system?  Actual event <input type="checkbox"/> Potential event <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
4.	<p style="text-align: center;"><b>Event Identification and Description:</b></p> (Check applicable box) <input type="checkbox"/> public appeal <input type="checkbox"/> voltage reduction <input type="checkbox"/> manual firm load shedding <input type="checkbox"/> firm load shedding(undervoltage, underfrequency, SPS/RAS) <input type="checkbox"/> voltage deviation <input type="checkbox"/> IROL violation <input type="checkbox"/> loss of firm load <input type="checkbox"/> system separation_(islanding) <input type="checkbox"/> generation loss <input type="checkbox"/> <del>complete</del> loss of off-site power to nuclear generating plant <input type="checkbox"/> transmission loss <input type="checkbox"/> damage or destruction of <del>BES equipment</del> <b>Facility</b> <input type="checkbox"/> <del>damage or destruction of Critical Asset</del> <input type="checkbox"/> <del>damage or destruction of Critical Cyber Asset</del> <input type="checkbox"/> unplanned control center evacuation <input type="checkbox"/> <del>fuel supply emergency</del> <input type="checkbox"/> loss of all <del>monitoring or</del> voice communication capability

**EOP-004, Attachment 2: Event Reporting Form**

~~This Use this form is to be used to report events to parties listed in Attachment 1, column labeled “Submit Attachment 2 or DOE OE-417 Report to:”. These parties, The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Reports should be submitted. Submit reports to the ERO~~ via one of the following: e-mail: [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, voice: 609-452-1422.

Task	Comments
<ul style="list-style-type: none"> <li><input type="checkbox"/> <del>forced intrusion Risk to BES equipment</del> <u>complete or partial loss of monitoring capability</u></li> <li><input type="checkbox"/> <u>physical threat that could impact the operability of a Facility</u></li> <li><input type="checkbox"/> reportable Cyber Security Incident</li> <li><input type="checkbox"/> <del>other</del></li> </ul>	

## Guideline and Technical Basis

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standard deals exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### Summary of Concepts and Assumptions:

##### *The Standard:*

- Requires reporting of “events” that impact or may impact the reliability of the ~~bulk electric system~~ Bulk Electric System
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

#### Discussion of Disturbance Reporting

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.

3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (~~attachment~~[EOP-004 Attachment 1](#)).

### Discussion of Event Reporting

There are situations worthy of reporting because they have the potential to impact reliability.

†Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- Detection of cyber intrusion that meets criteria of CIP-008-~~3~~ or its successor standard
- Forced intrusion attempt at a substation
- Train derailment near a transmission right-of-way
- Destruction of Bulk ~~Electrical~~[Electric](#) System equipment

### *What about sabotage?*

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk ~~Electrical~~[Electric](#) System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement.

Other types of ~~impact~~ events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### **Potential Uses of Reportable Information**

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering

necessary for event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in [EOP-004 Attachment 1](#) based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

# Comment Form

## Project 2009-01 Disturbance and Sabotage Reporting

Please **DO NOT** use this form for submitting comments. Please use the [electronic form](#) to submit comments on the draft standard EOP-004-2. Comments must be submitted by **May 24, 2012**. If you have questions please contact [Stephen Crutchfield](#) by email or by telephone at (609) 651-9455.

### Background Information

EOP-004-2 was posted for a 45-day formal comment period and initial ballot from October 28 through December 12, 2011. The DSR SDT received comments from stakeholders to improve the readability and clarity of the requirements of the standard. The revisions that were made to the standard are summarized in the following paragraphs.

### *Purpose Statement*

The DSR SDT revised the purpose statement to remove ambiguous language “with the potential to impact reliability.” The Purpose statement now reads:

“To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.”

### *Operating Plan*

Based on stakeholder comments, Requirement R1 was revised for clarity. Part 1.1 was revised to replace the word “identifying” with “recognizing” and Part 1.2 was eliminated. This also aligns the language of the standard with FERC Order 693, Paragraph 471.

“(2) specify baseline requirements regarding what issues should be addressed in the **procedures for recognizing** {emphasis added} sabotage events and making personnel aware of such events;”

Requirement R1, Part 1.3 (now Part 1.2) was revised by eliminating the phrase “as appropriate” and adding language indicating that the Responsible Entity is to define its process for reporting and with whom to report events. Part 1.2 now reads:

“1.2 A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.”

The SDT envisions that most entities will only need to slightly modify their existing CIP-001 Sabotage Reporting procedures to comply with the Operating Plan requirement in this proposed standard. As many of the features of both sabotage reporting procedures and the Operating Plan are substantially similar, the SDT feels that some information in the sabotage reporting procedures may need to be updated and verified.

### ***Operating Plan Review and Communications Testing***

Requirement R1, Part 1.4 was removed and Requirement 1, Part, 1.5 was separated out as new Requirement 4. Requirement R4 was revised and is now R3. FERC Order 693, Paragraph 466 includes provisions for periodic review and update of the Operating Plan:

“466. The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures.”

Requirement R3 requires an annual test of the communication portion of Requirement R1 while Requirement R4 requires an annual review of the Operating Plan.:

“R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.”

“R4. Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1.”

The DSR SDT envisions that the annual test will include verification that communication information contained in the Operating Plan is correct. As an example, the annual update of the Operating Plan could include calling “others as defined in the Responsibility Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator.

### ***Operating Plan Implementation***

Most stakeholders indicated that Requirements R2 and R3 were redundant and having both in the standard was not necessary. Requirement R2 called for implementation of Parts 1.1, 1.2, 1.4 and 1.5. Requirement R3 called for reporting events in accordance with the Operating Plan. The DSR SDT deleted Requirement R2 based on stakeholder comments and revised R3 (now R2) to:

“R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment1.”

**Reporting Timelines**

The DSR SDT received many comments regarding the various entries of Attachment 1. Many commenters questioned the reliability benefit of reporting events to the ERO within 1 hour. Most of the events with a one hour reporting requirement were revised to 24 hours based on stakeholder comments; those types of events are currently required to be reported within 24 hours in the existing mandatory and enforceable standards. The only remaining type of event that is to be reported within one hour is “A reportable Cyber Security Incident” as it is required by CIP-008 and FERC Order 706, Paragraph 673:

“direct the ERO to modify CIP-008 to require each responsible entity to contact appropriate government authorities and industry participants in the event of a cyber security incident as soon as possible, but in any event, within one hour of the event...”

The table was reformatted to separate one-hour reporting and 24-hour reporting. The last column of the table was also deleted and the information contained in the table was transferred to the sentence above each table. These sentences are:

“One Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event.”

“Twenty-four Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hour of recognition of the event.”

Note that the reporting timeline of 24 hours starts when the situation has been determined as a threat, not when it may have first occurred.

**Cyber-Related Events**

The ‘Damage or Destruction’ events specifically relating to Critical Assets and Critical Cyber Assets were removed from Attachment 1. Stakeholders pointed out these events are adequately addressed through the CIP-008 and “Damage or Destruction of a Facility” reporting thresholds.



CIP-008 addresses Cyber Security Incidents which are defined as:

“Any malicious act or suspicious event that:

- Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,
- Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.”

A Critical Asset is defined as:

“Facilities, systems, and equipment which, if destroyed, degraded, or otherwise rendered unavailable, would affect the reliability or operability of the Bulk Electric System.”

Since there is an existing event category for damage or destruction of Facilities, having a separate event for “Damage or Destruction of a Critical Asset” is unnecessary.

#### ***Damage or Destruction***

The event for “Destruction of BES equipment” has been revised to “Damage or destruction of a Facility”. The threshold for reporting information was expanded for clarity:

“Damage or destruction of a Facility that:

Affects an IROL (per FAC-014)

OR

Results in the need for actions to avoid an Adverse Reliability Impact

OR

Results from actual or suspected intentional human action.”

#### ***Facility Definition***

The DSR SDT used the defined term “Facility” to add clarity for this event as well as other events in Attachment 1. A Facility is defined as:

“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”

The DSR SDT did not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

### ***Physical Threats***

Several stakeholders expressed concerns relating to the “Forced Intrusion” event. Their concerns related to ambiguous language in the footnote. The SDR SDT discussed this event as well as the event “Risk to BES equipment”. These two event types had perceived overlap in the reporting requirements. The DSR SDT removed “Forced Intrusion” as a category and the “Risk to BES equipment” event was revised to “Any physical threat that could impact the operability of a Facility”.

Using judgment is unavoidable for this type of event. This language was chosen because the Responsible Entity is the best position to exercise this judgment and determine whether or not an event poses a threat to its Facilities. The DSR SDT believes this revised event type will minimize administrative burden and ensure that events meaningful to industry awareness are reported.

The footnote regarding this event type was expanded to provide additional guidance in:

“Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also, report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.”

### ***Use of DOE Form OE-417***

The DSR SDT received many comments requesting consistency with DOE OE-417 thresholds and timelines. These items, as well as, the Events Analysis Working Group’s (EAWG) requirements were considered in creating Attachment 1, but differences remain for the following reasons:

- EOP-004 requirements were designed to meet NERC and the industry’s needs; accommodation of other reporting obligations was considered as an opportunity not a ‘must-have’
- OE-417 only applies to US entities, whereas EOP-004 requirements apply across North America
- NERC has no control over the criteria in OE-417, which can change at any time
- Reports made under EOP-004 provide a minimum set of information, which may trigger further information requests from EAWG as necessary

In an effort to minimize administrative burden, US entities may use the OE-417 form rather than Attachment 2 to report under EOP-004. The SDT was informed by the DOE of its new online process coming later this year. In this process, entities may be able to record email addresses associated with their Operating Plan so that when the report is submitted to DOE, it will automatically be forwarded to the posted email addresses, thereby eliminating some administrative burden to forward the report to multiple organizations and agencies.

**Miscellaneous**

Other minor edits were made to Attachment 1. Several words were capitalized that are not defined terms. The DSR SDT did not intend for these terms to be capitalized (defined terms) and these words were reverted to lower case. The event type “Loss of monitoring or all voice communication capability” was divided into two separate events as “Loss of monitoring capability” and “Loss of all voice communication capability”.

Attachment 2 was updated to reflect the revisions to Attachment 1. The reference to “actual or potential events” was removed. Also, the event type of “other” and “fuel supply emergency” was removed as well.

It was noted that ‘Transmission Facilities’ is not a defined term in the NERC Glossary. Transmission and Facilities are separately defined terms. The combination of these two definitions are what the DSR SDT has based the applicability of “Transmission Facilities” in Attachment 1.

**You do not have to answer all questions.**

- 1. The DSR SDT has revised EOP-004-2 by removing Requirement 1, Part 1.4 and separating Parts 1.3 and 1.5 into new Requirements R3 and R4. Requirement R3 calls for an annual test of the communications portion of the Operating Plan and Requirement R4 requires an annual review of the Operating Plan. Do you agree with this revision? If not, please explain in the comment area below.**

Yes

No

Comments:

- 2. The DSR SDT made clarifying revisions to Attachment 1 based on stakeholder feedback. Do you agree with these revisions? If not, please explain in the comment area below.**

Yes

No

Comments:

- 3. The DSR SDT has proposed a new Section 812 to be incorporated into the NERC Rules of Procedure. Do you agree with the proposed addition? If not, please explain in the comment area below.**

Yes

No

Comments:

- 4. Do you have any other comment, not expressed in the questions above, for the DSR SDT?**

Comments:

## Implementation Plan

### Project 2009-01 Disturbance and Sabotage Reporting

#### Implementation Plan for EOP-004-2 – Event Reporting

##### *Approvals Required*

EOP-004-2 – Event Reporting

##### *Prerequisite Approvals*

None

##### *Revisions to Glossary Terms*

None

**Note:** Project 2008-06 is currently developing Version 5 of the CIP Cyber Security Standards, and, in conjunction with proposed CIP-008-5, the Project 2008-06 drafting team proposes to add the term, “Reportable Cyber Security Incident” to the Glossary of Terms used in NERC Reliability Standards. The proposed definition, as posted for formal comment and simultaneous successive ballot from April 12, 2012, through May 21, 2012, is, “Any Cyber Security Incident that has compromised or disrupted one or more reliability tasks of a functional entity.” If the term “Reportable Cyber Security Incident” is added to the Glossary of Terms used in NERC Reliability Standards, as posted or substantially similar to the definition proposed in draft 2 of the CIP Cyber Security Standards by Project 2008-06, then the phrase “reportable Cyber Security Incident” shall be changed to “Reportable Cyber Security Incident” wherever that phrase occurs in EOP-004-2 upon the effective date of CIP-008-5.

##### *Applicable Entities*

Reliability Coordinator

Balancing Authority

Interchange Coordinator

Transmission Service provider

Transmission Owner

Transmission Operator

Generator Owner

Generator Operator

Distribution Provider

Load-Serving Entity

Electric Reliability Organization

Regional Entity

*Conforming Changes to Other Standards*

None

*Effective Dates*

EOP-004-2 shall become effective on the first day of the third calendar quarter after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the third calendar quarter after Board of Trustees approval, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

EOP-004-1 is in effect until EOP-004-2 is accepted by all applicable regulatory authorities. Upon acceptance by the applicable regulatory authorities, EOP-004-2 will be assigned an effective date. Until such effective date is attained, EOP-004-1 will remain in effect.

*Retirements*

**EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting** should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.

**CIP-008-3 – Cyber Security - Incident Reporting and Response Planning:** Retire Requirement R1.3 which contains provisions for reporting Cyber Security Incidents. This is addressed in EOP-004-2, Requirement R2 and Attachment 1. If any successor version of the CIP-008-3 standard contains provisions for reporting Cyber Security Incidents, then those provisions should be retired upon the effective date of EOP-004-2.

# Implementation Plan

## Project 2009-01 Disturbance and Sabotage Reporting

### Implementation Plan for EOP-004-2 – Event Reporting

#### *Approvals Required*

EOP-004-2 – Event Reporting

#### *Prerequisite Approvals*

~~Revisions to Sections 807 and 808 of the NERC Rules of Procedure~~

~~Addition of Section 812 to the NERC Rules of Procedure~~

None

#### *Revisions to Glossary Terms*

None

Note: Project 2008-06 is currently developing Version 5 of the CIP Cyber Security Standards, and, in conjunction with proposed CIP-008-5, the Project 2008-06 drafting team proposes to add the term, “Reportable Cyber Security Incident” to the Glossary of Terms used in NERC Reliability Standards. The proposed definition, as posted for formal comment and simultaneous successive ballot from April 12, 2012, through May 21, 2012, is, “Any Cyber Security Incident that has compromised or disrupted one or more reliability tasks of a functional entity.” If the term “Reportable Cyber Security Incident” is added to the Glossary of Terms used in NERC Reliability Standards, as posted or substantially similar to the definition proposed in draft 2 of the CIP Cyber Security Standards by Project 2008-06, then the phrase “reportable Cyber Security Incident” shall be changed to “Reportable Cyber Security Incident” wherever that phrase occurs in EOP-004-2 upon the effective date of CIP-008-5.

#### *Applicable Entities*

Reliability Coordinator

Balancing Authority

Interchange Coordinator

Transmission Service provider

Transmission Owner

Transmission Operator

Generator Owner

Generator Operator

Distribution Provider

Load-Serving Entity  
Electric Reliability Organization  
Regional Entity

***Conforming Changes to Other Standards***

None

***Effective Dates***

EOP-004-2 shall become effective on the first day of the third calendar quarter after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the third calendar quarter after Board of Trustees approval, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

EOP-004-1 is in effect until EOP-004-2 is accepted by all applicable regulatory authorities. Upon acceptance by the applicable regulatory authorities, EOP-004-2 will be assigned an effective date. Until such effective date is attained, EOP-004-1 will remain in effect.

***Retirements***

**EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting** should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.

**CIP-008-43 – Cyber Security - Incident Reporting and Response Planning:** Retire Requirement R1.3 which contains provisions for reporting Cyber Security Incidents. This is addressed in EOP-004-2, Requirement 1, Part 1.3R2 and Attachment 1. If any successor version of the CIP-008-3 standard contains provisions for reporting Cyber Security Incidents, then those provisions should be retired upon the effective date of EOP-004-2.



## Project 2009-01 Disturbance and Sabotage Reporting Mapping Document

Translation of CIP-002-2a – Sabotage Reporting, EOP-004-1 – Disturbance Reporting and CIP-008-4 – Cyber Security – Incident Reporting and Response Planning (R 1.3), into EOP-004-2 – Impact Event and Disturbance Assessment, Analysis, and Reporting

### Standard: CIP-001-2a – Sabotage Reporting

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting
<p>R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi site sabotage affecting larger portions of the Interconnection.</p>	<p>Moved into EOP-004-2, R1</p>	<p>R1. Each Responsible Entity shall have an Operating Plan that includes: <i>[Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]</i></p> <ul style="list-style-type: none"> <li>1.1. A process for recognizing each of the applicable events listed in EOP-004 Attachment 1.</li> <li>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.</li> </ul>

<p>R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.</p>	<p>Moved into EOP-004-2, R1</p>	<p>R1. Each Responsible Entity shall have an Operating Plan that includes:  <i>[Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]</i></p> <ul style="list-style-type: none"> <li>1.1. A process for recognizing each of the applicable events listed in EOP-004 Attachment 1.</li> <li>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.</li> </ul>
<p>R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.</p>	<p>Moved into EOP-004-2, R1</p>	<p>R1. Each Responsible Entity shall have an Operating Plan that includes:  <i>[Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]</i></p> <ul style="list-style-type: none"> <li>1.1. A process for recognizing each of the applicable events listed in EOP-004 Attachment 1.</li> <li>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.</li> </ul>

<p>R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.</p>	<p>Moved into EOP-004-2, R1</p>	<p>R1. Each Responsible Entity shall have an Operating Plan that includes:  <i>[Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]</i></p> <ul style="list-style-type: none"> <li>1.1. A process for recognizing each of the applicable events listed in EOP-004 Attachment 1.</li> <li>1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.</li> </ul>
---	---------------------------------	---

Standard: EOP-004-1 – Disturbance Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.	Retire this fill-in-the-blank requirement.  Replace with new reporting and analysis procedure developed by NERC EAWG.	The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.
R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.	Translated into EOP-004-2, R1 and the NERC Events Analysis Process	The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.
R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.	Translated into EOP-004-2, R2	R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</i>

<p>R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until sometime after they occur shall be reported within 24 hours of being recognized.</p>	<p>Translated into EOP-004-2, R2</p>	<p>R2. Each Responsible Entity shall implement its event reporting Operating Plan for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</i></p>
<p>R3.2. Applicable reporting forms are provided in Attachments 022-1 and 022-2.</p>	<p>Retire – informational statement</p>	

<p>R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.</p>	<p>Retire as a requirement. Added as a "Note" to EOP-004-Attachment1-Impact Events Table</p>	<p>NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R1 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:esisac@nerc.com">esisac@nerc.com</a>, Facsimile: 609-452-9550, Voice: 609-452-1422.</p>
---	--	--

<p>R3.4. If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>
<p>R4. When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>

<p>R5. The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>
<p>Request for Interpretation of CIP-001-2a, R2: Please clarify what is meant by the term, “appropriate parties.” Moreover, who within the Interconnection hierarchy deems parties to be appropriate?</p>	<p>Retire the interpretation</p>	<p>Addressed in EOP-004-2, R1 by replacing the term, ‘appropriate parties’ with a broader, more specific list of specific entities to contact in Part 1.2.</p>



Standard: CIP-008-4 – Cyber Security – Incident Reporting and Response Planning		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
R1.3. Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary.	Translated into EOP-004-2 Requirement 1, Part 1.2 and Attachment 1.	<p>Cyber Security Incidents are defined as:</p> <p>Any malicious act or suspicious event that:</p> <ul style="list-style-type: none"> <li>• Compromises, or was an attempt to compromise, the Electronic Security Perimeter or Physical Security Perimeter of a Critical Cyber Asset, or,</li> <li>• Disrupts, or was an attempt to disrupt, the operation of a Critical Cyber Asset.</li> </ul> <p>Such events are listed in Attachment 1 as “Detection of a reportable Cyber Security Incident” and are events that are required to be reported under Reliability Standard EOP-004-2. Requirement R1, Part 1.2 requires the Responsible Entity to have “A process for reporting events listed in Attachment 1 to the Electric Reliability Organization,...” The note at the top of Attachment 1 includes the following:</p> <p>“Reports to the ERO should be submitted to one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.”</p>

## Project 2009-01 Disturbance and Sabotage Reporting Consideration of Issues and Directives

Project 2009-01 Disturbance and Sabotage Reporting		
Issue or Directive	Source	Consideration of Issue or Directive
<p>"What is meant by: "establish contact with the FBI"? Is a phone number adequate? Many entities which call the FBI are referred back to the local authority. The AOT noted that on the FBI website it states to contact the local authorities. Is this a question for Homeland Security to deal with for us?"</p> <p>Establish communications contacts, as applicable with local FBI and RCMP officials. Some entities are very remote and the sheriff is the only local authority does the FBI still need to be contacted?</p> <p>Registered Entities have sabotage reporting processes and procedures in place but not all personnel has been trained.</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>The DSR SDT has been in contact with FBI staff and developed a notification flow chart for law enforcement as it pertains to EOP-004. The "Background" section of the standard outlines the reporting hierarchy that exists between local, state, provincial and federal law enforcement. The entity experiencing an event should notify the appropriate state or provincial law enforcement agency that will then coordinate with local law enforcement for investigation. These local, state and provincial agencies will coordinate with higher levels of law enforcement or other governmental agencies.</p>

<p>Question: How do you “and make the operator aware”</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>This has been removed from the standard. Requirement R1, Part 1.1 requires that the entity has a process for recognizing events.</p>
<p>How does this standard pertain to Load Serving Entities, LSE's.</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>LSE is an applicable entity since LSEs are currently applicable under CIP-008.</p>
<p>We direct the ERO to explore ways to address these concerns – including central coordination of sabotage reports and a uniform reporting format – in developing modifications to the Reliability Standard with the appropriate governmental agencies that have levied the reporting requirements.</p>	<p>CIP-001-1; Order 693</p>	<p>See “Background” section of the standard.</p>

"Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event. Paragraph 461. Several commenters agree with the Commission's concern that the term "sabotage" should be defined. For the reasons stated in the NOPR, we direct that the ERO further define the term and provide guidance on triggering events that would cause an entity to report an event. However, we disagree with those commenters that suggest the term "sabotage" is so vague as to justify a delay in approval or the application of monetary penalties. As explained in the NOPR, we believe that the term sabotage is commonly understood and that common understanding should suffice in most instances.

CIP-001-1; Order 693

The DSR SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of "event". The DSR SDT considered the FERC directive to "further define sabotage" and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term "sabotage" is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

<p>The ERO should consider suggestions raised by commenters such as FirstEnergy and Xcel to define the specified period for reporting an incident beginning from when an event is discovered or suspected to be sabotage, and APPA’s concerns regarding events at unstaffed or remote facilities, and triggering events occurring outside staffed hours at small entities.</p>	<p>CIP-001-1; Order 693</p>	<p>Attachment 1 defines the timelines and events which are to be reported under this standard. The required reporting is either one hour or 24 hours (depending on the type of event) “of recognition of the event.”</p>
--	-----------------------------	--

<p>Modify CIP-001-1 1 to require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specific period of time, even if it is a preliminary report. Further, in the interim while the matter is being addressed by the Reliability Standards development process, we direct the ERO to provide advice to entities that have concerns about the reporting of particular circumstances as they arise.</p>	<p>CIP-001-1; Order 693</p>	<p>Per Requirement R1, the entity is to develop procedure(s) that include event reporting to law enforcement and governmental agencies. The DSR SDT also proposes revisions to the NERC Rules of Procedure to report events to the FERC.</p> <p>812. NERC will establish a system to collect report forms as established for this section or standard, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations.</p>
--	-----------------------------	--

Consider the need for wider application of the standard. Consider whether separate, less burdensome requirements for smaller entities may be appropriate. Paragraph 458. The Commission acknowledges the concerns of the commenters about the applicability of CIP-001-1 to small entities and has addressed the concerns of small entities generally earlier in this Final Rule. Our approval of the ERO Compliance Registry criteria to determine which users, owners and operators are responsible for compliance addresses the concerns of APPA and others. 459. However, the Commission believes that there are specific reasons for applying this Reliability Standard to such entities, as discussed in the NOPR. APPA indicates that some small LSEs do not own or operate “hard assets” that are normally thought of as “at risk” to sabotage. The Commission is concerned that, an adversary might determine that a small LSE is the appropriate target when the adversary aims at a particular population or facility. Or an adversary may target a small user, owner or operator because it may have similar equipment or protections as a larger facility, that is, the adversary may use an attack against a smaller facility as a training “exercise.” {continued below}

CIP-001-1; Order 693

Attachment 1 defines the timelines and events which are to be reported under this standard. The applicable entities are also identified for each type of event.

<p>The knowledge of sabotage events that occur at any facility (including small facilities) may be helpful to those facilities that are traditionally considered to be the primary targets of adversaries as well as to all members of the electric sector, the law enforcement community and other critical infrastructures. 460. For these reasons, the Commission remains concerned that a wider application of CIP-001-1 may be appropriate for Bulk Power System reliability. Balancing these concerns with our earlier discussion of the applicability of Reliability Standards to smaller entities, we will not direct the ERO to make any specific modification to CIP-001-1 to address applicability. However, we direct the ERO, as part of its Work Plan, to consider in the Reliability Standards development process, possible revisions to CIP-001-1 that address our concerns. Regarding the need for wider application of the Reliability Standard. Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns.</p>		
---	--	--



<p>The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures. At this time, the commission does not specify a review period as suggested by FirstEnergy and MRO and, rather, believes that the appropriate period should be determined through the ERO’s Reliability Standards development process. However, the Commission directs that the ERO begin this process by considering a staggered schedule of annual testing of the procedures with modifications made when warranted formal review of the procedures every two or three years.</p>	<p>CIP-001-1; Order 693</p>	<p>The standard is responsive this directive with the following language in Requirement R3:</p> <p>R3. Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.</p> <p>The DSR SDT envisions that this will include verification that contact information contained in the Operating Plan is correct. As an example, the annual update of the Operating Plan could include calling others as defined in the Responsibility Entity’s Operating Plan (see Part 1.2) to verify that their contact information is correct and current. If any discrepancies are noted, the Operating Plan would be updated.</p>
--	-----------------------------	--

Consider FirstEnergy's suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality. Paragraph 451. A number of commenters agree with the Commission's concern that the term sabotage" needs to be better defined and guidance provided on the triggering events that would cause an entity to report an event. FirstEnergy states that this definition should differentiate between cyber and physical sabotage and should exclude unintentional operator error. It advocates a threshold of materiality to exclude acts that do not threaten to reduce the ability to provide service or compromise safety and security. SoCal Edison states that clarification regarding the meaning of sabotage and the triggering event for reporting would be helpful and prevent over reporting.

CIP-001-1; Order 693

This addressed in Attachment 1. There are specific event types for both cyber and physical security with their respective report submittal requirements.

"Include a requirement to report a sabotage event to the proper government authorities. Develop the language to specifically implement this directive. Paragraph 467. CIP-001-1, Requirement R4, requires that each applicable entity establish communications contacts, as applicable, with the local FBI or Royal Canadian Mounted Police officials and develop reporting procedures as appropriate to its circumstances. The Commission in the NOPR expressed concern that the Reliability Standard does not require an applicable entity to actually contact the appropriate governmental or regulatory body in the event of sabotage. Therefore, the Commission proposed that NERC modify the Reliability Standard to require an applicable entity to "contact appropriate federal authorities, such as the Department of Homeland Security, in the event of sabotage within a specified period of time."212 468. As mentioned above, NERC and others object to the wording of the proposed directive as overly prescriptive and note that the reference to "appropriate federal authorities" fails to recognize the international application of the Reliability Standard. The example of the Department of Homeland Security as an "appropriate federal authority" was not intended to be an exclusive designation. Nonetheless, the Commission agrees that a reference to "federal authorities" could create confusion. Accordingly, we modify the direction in the NOPR and now direct the ERO to address our underlying concern regarding mandatory reporting of a sabotage event. The ERO's Reliability Standards development process should develop the language to implement this directive."

See Background section of Standard.

A proposal discussed with FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Event EOP-004-2). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial level law enforcement agency. The state or provincial level law enforcement agency will coordinate with local law enforcement to investigate. If the state or provincial level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial level law enforcement agency will notify and coordinate with the FBI or the RCMP.

<p>On March 4, 2008, NERC submitted a compliance filing in response to a December 20, 2007 Order, in which the Commission reversed a NERC decision to register three retail power marketers to comply with Reliability Standards applicable to load serving entities (LSEs) and directed NERC to submit a plan describing how it would address a possible “reliability gap” that NERC asserted would result if the LSEs were not registered. NERC’s compliance filing included the following proposal for a short-term plan and a long-term plan to address the potential gap:</p> <ul style="list-style-type: none"> <li>· Short-term: Using a posting and open comment process, NERC will revise the registration criteria to define “Non-Asset Owning LSEs” as a subset of Load Serving Entities and will specify the reliability standards applicable to that subset.</li> <li>· Longer-term: NERC will determine the changes necessary to terms and requirements in reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers and process them through execution of the three-year Reliability Standards Development Plan. In this revised Reliability Standards Development Plan, NERC is commencing the implementation of its stated long-term plan to address the issues surrounding accountability for loads served by retail marketers/suppliers.</li> </ul> <p>The NERC Reliability Standards Development Procedure will be used to identify the changes necessary to terms and requirements in reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. Specifically, the following description has been incorporated into the scope for</p>	<p>CIP-001-1 and EOP-004 ORDER ON ELECTRIC RELIABILITY ORGANIZATION REGISTRY_DETERMINATIONS; ORDER ON COMPLIANCE FILING</p>	<p>The LSE is an applicable entity, since LSEs are currently applicable under CIP-008. If an entity owns distribution assets, that entity will be registered as a Distribution Provider. Attachment 1 defines the timelines and events which are to be reported under this standard. The applicable entities are also identified for each type of event.</p>
--	---	--

affected projects in this revised Reliability Standards Development Plan that includes a standard applicable to Load Serving Entities:  
Source: FERC's December 20, 2007 Order in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000.

Issue: In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none own physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be followed.

Each drafting team responsible for reliability standards that are applicable to LSEs is to review and change as necessary, requirements in the reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:

- FERC's December 20, 2007 Order  
([http://www.nerc.com/files/LSE\\_decision\\_order.pdf](http://www.nerc.com/files/LSE_decision_order.pdf))
- NERC's March 4, 2008  
(<http://www.nerc.com/files/FinalFiledLSE3408.pdf>),
- FERC's April 4, 2008 Order  
(<http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf>), and
- NERC's July 31, 2008  
(<http://www.nerc.com/files/FinalFiled-compFiling-LSE-07312008.pdf>)

compliance filings to FERC on this subject.

<p>Object to multi-site requirement</p>	<p>Version 0 Team CIP-001-1</p>	<p>The Standard was revised for clarity. Attachment 1 defines the timelines and events which are to be reported under this standard. The applicable entities are also identified for each type of event.</p>
<p>Definition of sabotage required</p> <p>VRFs Team Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures.</p>	<p>Version 0 Team CIP-001-1</p>	<p>No definition for sabotage was developed. The DSR SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of “event”. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p>

<p>Coordination and follow up on lessons learned from event analyses          Consider adding to EOP-004 – Disturbance Reporting Proposed requirement: Regional Entities (REs) shall work together with Reliability Coordinators, Transmission Owners, and Generation Owners to develop an Event Analysis Process to prevent similar events from happening and follow up with the recommendations. This process shall be defined within the appropriate NERC Standard</p>	<p>Events Analysis Team          Reliability Issue</p>	<p>The DSR SDT envisions EOP-004-2 to be a reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
<p>Consider changes to R1 and R3.4 to standardize the disturbance reporting requirements (requirements for disturbance reporting need to be added to this standard). Regions currently have procedures, but not in the form of a standard. The drafting team will need to review regional requirements to determine reporting requirements for the North American standard.</p>	<p>Fill in the Blank Team</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
<p>Can there be a violation without an event?</p>	<p>NERC Audit Observation Team</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. In the opinion of the DSR SDT, there cannot be a violation of Requirement R2 without an event. Since Requirement R1 calls for an Operating Plan, there can be a violation of R1 without an event.</p>

<p>Consider APPA’s concern about generator operators and LSEs analyzing performance of their equipment and provide data and information on the equipment to assist others with analysis.          Paragraph 607. APPA is concerned about the scope of Requirement R2 because, in its opinion, Requirement R2 appears to impose an open-ended obligation on entities such as generation operators and LSEs that may have neither the data nor the tools to promptly analyze disturbances that could have originated elsewhere. APPA proposes that Requirement R2 be modified to require affected entities to promptly begin analyses to ensure timely reporting to NERC and DOE.</p>	<p>EOP-004-1 Order 693</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
---	----------------------------	--



<p>From: David Cook          Sent: Wednesday, July 16, 2008 6:06 PM          To: Rick Sergel; Dave Nevius; David A. Whiteley; Management          Subject: RE: FERC request for DOE-417s</p> <p>I agree the real fix is to revise the EOP-004 standard. I agree that we can't (and shouldn't try) to do that by way of amendments to our Rules of Procedure. So we should include that fix in the standards work plan, do the best we can in the meantime to provide FERC with the 417s, and I'll have the conversation with Joe McClelland about not being able to do what the Commission directed in Order 693 (i.e., change the standards by way of a change in the Rules of Procedure).</p> <p>David</p>	<p>EOP-004-1 Other</p>	<p>Per Requirement R1, the entity is to develop procedure(s) that include event reporting to law enforcement and governmental agencies. The DSR SDT also proposes revisions to the NERC Rules of Procedure to report events to the FERC.</p> <p>812. NERC will establish a system to collect report forms as established for this section or standard, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations.</p>
--	------------------------	--

In response to a SAR submitted by Glenn Kaht of ReliabilityFirst: As part of a regional compliance violation investigation, a possible reliability gap was identified related to EOP-004-1 — Disturbance Reporting. The existing standard limits reporting of generation outages to just those outages associated with loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. This requirement has been interpreted as meaning that only generation outages that must be reported are those that occur with the loss of a bulk power transmission element. By not reporting large generation losses that occur without the loss of a bulk power transmission element, the industry is overlooking a potential opportunity to identify and learn from these losses.

Specifically, Item 1 of Attachment 1 of EOP-004 requires the reporting of events if “The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:” The Standard then lists six different actions that may occur as a result of the event in order to be reportable. All six of these actions appear to be dependent on “The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations” in order for the event to be reportable. Some of these events may significantly impact the reliable operation of the bulk power system. Consider a revision to EOP-004-1 — Disturbance Reporting requiring a Generator Operator (GOP) that

Standards Committee Action  
From 01/13/2010

The DSR SDT has worked closely with the NERC EAWG to develop the event reporting requirements shown in Attachment 1. The EAWG and the DSR SDT considered this request and weighed it against reliability needs for reporting.

experiences the loss of generation greater than 500 MW that results in modification of equipment (e.g. control systems, or Power Load Unbalancer (PLU)) to be a reportable event.		
too many reports, narrow requirement to RC	Version 0 Team	There is only one report required under this standard. An entity may submit the report using Attachment 2 or the DEO OE-417 report form.
How does this apply to generator operator?	Version 0 Team	See attachment 1 for specific generator operator applicability.

## Violation Risk Factor and Violation Severity Level Assignments

### Project 2009-01 – Disturbance and Sabotage Reporting

This document provides the drafting team's justification for assignment of violation risk factors (VRFs) and violation severity levels (VSLs) for each requirement in

#### EOP-004-2 — Event Reporting

Each primary requirement is assigned a VRF and a set of one or more VSLs. These elements support the determination of an initial value range for the Base Penalty Amount regarding violations of requirements in FERC-approved Reliability Standards, as defined in the ERO Sanction Guidelines.

#### Justification for Assignment of Violation Risk Factors in EOP-004-2

The Disturbance and Sabotage Reporting Standard Drafting Team applied the following NERC criteria when proposing VRFs for the requirements in EOP-004-2:

##### ***High Risk Requirement***

A requirement that, if violated, could directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures, or could hinder restoration to a normal condition.

##### ***Medium Risk Requirement***

A requirement that, if violated, could directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system. However, violation of a medium risk requirement is unlikely to lead to bulk electric system instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly and adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. However, violation of a medium risk requirement is unlikely, under emergency, abnormal, or restoration conditions anticipated by the preparations, to lead to bulk electric system instability, separation, or cascading failures, nor to hinder restoration to a normal condition.

***Lower Risk Requirement***

A requirement that is administrative in nature and a requirement that, if violated, would not be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system; or, a requirement that is administrative in nature and a requirement in a planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. A planning requirement that is administrative in nature.

The SDT also considered consistency with the FERC Violation Risk Factor Guidelines for setting VRFs:<sup>1</sup>

**Guideline (1) — Consistency with the Conclusions of the Final Blackout Report**

The Commission seeks to ensure that Violation Risk Factors assigned to Requirements of Reliability Standards in these identified areas appropriately reflect their historical critical impact on the reliability of the Bulk-Power System.

In the VSL Order, FERC listed critical areas (from the Final Blackout Report) where violations could severely affect the reliability of the Bulk-Power System:<sup>2</sup>

- Emergency operations
- Vegetation management
- Operator personnel training
- Protection systems and their coordination
- Operating tools and backup facilities
- Reactive power and voltage control
- System modeling and data exchange
- Communication protocol and facilities
- Requirements to determine equipment ratings
- Synchronized data recorders
- Clearer criteria for operationally critical facilities
- Appropriate use of transmission loading relief.

**Guideline (2) — Consistency within a Reliability Standard**

The Commission expects a rational connection between the sub-Requirement Violation Risk Factor assignments and the main Requirement Violation Risk Factor assignment.

<sup>1</sup> North American Electric Reliability Corp., 119 FERC ¶ 61,145, order on reh'g and compliance filing, 120 FERC ¶ 61,145 (2007) (“VRF Rehearing Order”).

<sup>2</sup> Id. at footnote 15.

### **Guideline (3) — Consistency among Reliability Standards**

The Commission expects the assignment of Violation Risk Factors corresponding to Requirements that address similar reliability goals in different Reliability Standards would be treated comparably.

### **Guideline (4) — Consistency with NERC’s Definition of the Violation Risk Factor Level**

Guideline (4) was developed to evaluate whether the assignment of a particular Violation Risk Factor level conforms to NERC’s definition of that risk level.

### **Guideline (5) — Treatment of Requirements that Co-mingle More Than One Obligation**

Where a single Requirement co-mingles a higher risk reliability objective and a lesser risk reliability objective, the VRF assignment for such Requirements must not be watered down to reflect the lower risk level associated with the less important objective of the Reliability Standard.

The following discussion addresses how the SDT considered FERC’s VRF Guidelines 2 through 5. The team did not address Guideline 1 directly because of an apparent conflict between Guidelines 1 and 4. Whereas Guideline 1 identifies a list of topics that encompass nearly all topics within NERC’s Reliability Standards and implies that these requirements should be assigned a “High” VRF, Guideline 4 directs assignment of VRFs based on the impact of a specific requirement to the reliability of the system. The SDT believes that Guideline 4 is reflective of the intent of VRFs in the first instance and therefore concentrated its approach on the reliability impact of the requirements.

#### ***VRF for EOP-004-2:***

There are four requirements in EOP-004-2. Requirement R1 was assigned a Lower VRF while Requirements R2, R3 and R4 were assigned a Medium VRF.

#### ***VRF for EOP-004-2, Requirements R1:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The Requirement specifies which entities are required to have processes for recognition of events and for communicating with other entities. This Requirement is the only administrative Requirement within the Standard. The VRF is only applied at the Requirement level. FERC’s Guideline 3 — Consistency among Reliability Standards. This requirement calls for an entity to have processes for recognition of events and communicating with other entities. This requirement is administrative in nature and deals with the means to report events after the fact. Most event reporting requirements in Attachment 1 are for 24 hours after an event has occurred. The current approved VRFs for EOP-004-1 are all lower with the

exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program.

- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. Failure to have an event reporting Operating Plan is not likely to directly affect the electrical state or the capability of the bulk electric system. , Development of the Operating Plan is a requirement that is administrative in nature and is in a planning time frame that, if violated, would not, under emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system.. Therefore this requirement was assigned a Lower VRF.
- FERC’s Guideline 5 — Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R1 contains only one objective which is to have an Operating Plan with two distinct processes. The content of the Operating Plan is specified in Parts 1.1-1.2. Since the requirement is to have an Operating Plan, only one VRF was assigned.

***VRF for EOP-004-2, Requirement R2:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to implement its Operating Plan and is assigned a Medium VRF. There are two other Requirements in this Standard which specify an annual test of the Operating Plan (R3) and an annual review of the Operating Plan (R4). Each of these Requirements is assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R2 is a requirement for entities to report events using the process for recognition of events per Requirement R1. Failure to report events is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not report events. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R2 mandates that Responsible Entities implement their Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to notify another entity of the event failure, but there is a slight chance that it could occur. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R2 addresses a single objective and has a single VRF.

***VRF for EOP-004-2, Requirement R3:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to perform an annual test of the Operating Plan and is assigned a Medium VRF. There are two other Requirements in this Standard which specify that the Responsible Entity implement its Operating Plan (R2) and perform an annual review of the Operating Plan (R4). Each of these Requirements is assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R3 is a requirement for entities to perform an annual test of the Operating Plan. Failure to perform an annual test of the Operating Plan is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not perform an annual test of the Operating Plan and it is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R3 mandates that Responsible Entities perform an annual test of the Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to perform an annual test of the Operating Plan, but there is a slight chance that it could occur if the Operating Plan is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R3 addresses a single objective and has a single VRF.

***VRF for EOP-004-2, Requirement R4:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to perform an annual review of the Operating Plan and is assigned a Medium VRF. There are two other Requirements in this Standard which specify that the Responsible Entity implement its Operating Plan (R2) and perform an annual test of the Operating Plan (R3). Each of these Requirements is assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R4 is a requirement for entities to perform an annual test of the Operating Plan. Failure to perform an annual review of the Operating Plan is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not perform an annual review of the Operating Plan and it is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.



- FERC's Guideline 4 — Consistency with NERC's Definition of a VRF. EOP-004-2, Requirement R4 mandates that Responsible Entities perform an annual review of the Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to notify another entity of the event failure, but there is a slight chance that it could occur if the Operating Plan is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC's Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R4 addresses a single objective and has a single VRF.

**Justification for Assignment of Violation Severity Levels for EOP-004-2:**

In developing the VSLs for the EOP-004-2 standard, the SDT anticipated the evidence that would be reviewed during an audit, and developed its VSLs based on the noncompliance an auditor may find during a typical audit. The SDT based its assignment of VSLs on the following NERC criteria:

Lower	Moderate	High	Severe
<p>Missing a minor element (or a small percentage) of the required performance</p> <p>The performance or product measured has significant value as it almost meets the full intent of the requirement.</p>	<p>Missing at least one significant element (or a moderate percentage) of the required performance.</p> <p>The performance or product measured still has significant value in meeting the intent of the requirement.</p>	<p>Missing more than one significant element (or is missing a high percentage) of the required performance or is missing a single vital component.</p> <p>The performance or product has limited value in meeting the intent of the requirement.</p>	<p>Missing most or all of the significant elements (or a significant percentage) of the required performance.</p> <p>The performance measured does not meet the intent of the requirement or the product delivered cannot be used in meeting the intent of the requirement.</p>

FERC’s VSL guidelines are presented below, followed by an analysis of whether the VSLs proposed for each requirement in EOP-004-2 meet the FERC Guidelines for assessing VSLs:

**Guideline 1: Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance**

Compare the VSLs to any prior levels of non-compliance and avoid significant changes that may encourage a lower level of compliance than was required when levels of non-compliance were used.

**Guideline 2: Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties**

A violation of a “binary” type requirement must be a “Severe” VSL.

Do not use ambiguous terms such as “minor” and “significant” to describe noncompliant performance.

**Guideline 3: Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement**

VSLs should not expand on what is required in the requirement.

**Guideline 4: Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations**

. . . unless otherwise stated in the requirement, each instance of non-compliance with a requirement is a separate violation. Section 4 of the Sanction Guidelines states that assessing penalties on a per violation per day basis is the “default” for penalty calculations.

**VSLs for EOP-004-2 Requirements R1:**

R#	Compliance with NERC's VSL Guidelines	<p>Guideline 1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>Guideline 2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 3</p> <p>Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>Guideline 4</p> <p>Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>
<b>R1</b>	<p>Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.</p>	<p>The proposed requirement is a revision of CIP-001-1, R1-R4, and EOP-004-1, R2. Since the Requirement has three Parts, the VSLs were developed to count a violation of each Part equally. Therefore, three VSLs were developed.</p>	<p>The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.</p>	<p>The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.</p>	<p>The VSLs are based on a single violation and not cumulative violations.</p>

**VSLs for EOP-004-2 Requirement R2:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R2</b>	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a revision of EOP-004-1, R3. There is only a Severe VSL for that requirement. However, the reporting of events is based on timing intervals listed in EOP-004 Attachment 1. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a report is not submitted, then the VSL is Severe. This maintains the current VSL.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R3:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
R3	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a new Requirement. The test of the Operating Plan is based on the calendar year. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a test is not performed, then the VSL is Severe.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R4:**

R#	Compliance with NERC's VSL Guidelines	<p>Guideline 1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>Guideline 2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 3</p> <p>Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>Guideline 4</p> <p>Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>
R3	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a new Requirement. The review of the Operating Plan is based on the calendar year. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a review is not performed, then the VSL is Severe.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

The Project 2009-01 Disturbance and Sabotage Reporting SDT has drafted the following addition to the NERC Rules of Procedure to support the reporting of events as required by the directive in Order No. 693 P 470.

## **SECTION 800 — RELIABILITY ASSESSMENT AND PERFORMANCE ANALYSIS**

### **812. NERC Reporting Clearinghouse**

NERC will establish a system to collect report forms as established for this section or standard, from any Registered Entities, pertaining to data requirements identified in Section 800 of this Procedure. Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations.



### A. Introduction

1. **Title:** **Sabotage Reporting**
2. **Number:** CIP-001-2a
3. **Purpose:** Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Transmission Owners (only in ERCOT Region).
  - 4.7. Generator Owners (only in ERCOT Region).
5. **Effective Date:** ERCOT Regional Variance will be effective the first day of the first calendar quarter after applicable regulatory approval.

### B. Requirements

- R1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- R2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- R3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- R4.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

### C. Measures

- M1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

Regional Reliability Organizations shall be responsible for compliance monitoring.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to verify compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Reliability Coordinator, Transmission Operator, Generator Operator, Distribution Provider, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

#### **1.4. Additional Compliance Information**

None.

### **2. Levels of Non-Compliance:**

**2.1. Level 1:** There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

- 2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).

- 2.1.2 Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).
- 2.1.3 Has not established communications contacts, as specified in R4.
- 2.2. **Level 2:** Not applicable.
- 2.3. **Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).
- 2.4. **Level 4:** Not applicable.

## **E. ERCOT Interconnection-wide Regional Variance**

### **Requirements**

- EA.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- EA.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- EA.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- EA.4.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall establish communications contacts with local Federal Bureau of Investigation (FBI) officials and develop reporting procedures as appropriate to their circumstances.

### **Measures**

- M.A.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement EA1.
- M.A.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements EA2 and EA3.
- M.A.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to, procedures, policies, a letter of understanding, communication records,

or other equivalent evidence that will be used to confirm that it has established communications contacts with the local FBI officials to communicate sabotage events (Requirement EA4).

**Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Enforcement Authority**

Regional Entity shall be responsible for compliance monitoring.

**1.2. Data Retention**

Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Amended
1	April 4, 2007	Regulatory Approval — Effective Date	New
1a	February 16, 2010	Added Appendix 1 — Interpretation of R2 approved by the NERC Board of Trustees	Addition
1a	February 2, 2011	Interpretation of R2 approved by FERC on February 2, 2011	Same addition
	June 10, 2010	TRE regional ballot approved variance	By Texas RE
	August 24, 2010	Regional Variance Approved by Texas RE Board of Directors	
2a	February 16, 2011	Approved by NERC Board of Trustees	

**Standard CIP-001-2a— Sabotage Reporting**

---

2a	August 2, 2011	FERC Order issued approving Texas RE Regional Variance	
----	----------------	--	--

Appendix 1

<b>Requirement Number and Text of Requirement</b>
<p><b>CIP-001-1:</b></p> <p><b>R2.</b> Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.</p>
<b>Question</b>
<p>Please clarify what is meant by the term, “appropriate parties.” Moreover, who within the Interconnection hierarchy deems parties to be appropriate?</p>
<b>Response</b>
<p>The drafting team interprets the phrase “appropriate parties in the Interconnection” to refer collectively to entities with whom the reporting party has responsibilities and/or obligations for the communication of physical or cyber security event information. For example, reporting responsibilities result from NERC standards IRO-001 Reliability Coordination — Responsibilities and Authorities, COM-002-2 Communication and Coordination, and TOP-001 Reliability Responsibilities and Authorities, among others. Obligations to report could also result from agreements, processes, or procedures with other parties, such as may be found in operating agreements and interconnection agreements.</p> <p>The drafting team asserts that those entities to which communicating sabotage events is appropriate would be identified by the reporting entity and documented within the procedure required in CIP-001-1 Requirement R2.</p> <p>Regarding “who within the Interconnection hierarchy deems parties to be appropriate,” the drafting team knows of no interconnection authority that has such a role.</p>

## A. Introduction

1. **Title:** Cyber Security — Incident Reporting and Response Planning
2. **Number:** CIP-008-3
3. **Purpose:** Standard CIP-008-3 ensures the identification, classification, response, and reporting of Cyber Security Incidents related to Critical Cyber Assets. Standard CIP-008-23 should be read as part of a group of standards numbered Standards CIP-002-3 through CIP-009-3.
4. **Applicability**
  - 4.1. Within the text of Standard CIP-008-3, “Responsible Entity” shall mean:
    - 4.1.1 Reliability Coordinator.
    - 4.1.2 Balancing Authority.
    - 4.1.3 Interchange Authority.
    - 4.1.4 Transmission Service Provider.
    - 4.1.5 Transmission Owner.
    - 4.1.6 Transmission Operator.
    - 4.1.7 Generator Owner.
    - 4.1.8 Generator Operator.
    - 4.1.9 Load Serving Entity.
    - 4.1.10 NERC.
    - 4.1.11 Regional Entity.
  - 4.2. The following are exempt from Standard CIP-008-3:
    - 4.2.1 Facilities regulated by the U.S. Nuclear Regulatory Commission or the Canadian Nuclear Safety Commission.
    - 4.2.2 Cyber Assets associated with communication networks and data communication links between discrete Electronic Security Perimeters.
    - 4.2.3 Responsible Entities that, in compliance with Standard CIP-002-3, identify that they have no Critical Cyber Assets.
5. **Effective Date:** The first day of the third calendar quarter after applicable regulatory approvals have been received (or the Reliability Standard otherwise becomes effective the first day of the third calendar quarter after BOT adoption in those jurisdictions where regulatory approval is not required).

## B. Requirements

- R1. Cyber Security Incident Response Plan — The Responsible Entity shall develop and maintain a Cyber Security Incident response plan and implement the plan in response to Cyber Security Incidents. The Cyber Security Incident response plan shall address, at a minimum, the following:
  - R1.1. Procedures to characterize and classify events as reportable Cyber Security Incidents.
  - R1.2. Response actions, including roles and responsibilities of Cyber Security Incident response teams, Cyber Security Incident handling procedures, and communication plans.

- R1.3.** Process for reporting Cyber Security Incidents to the Electricity Sector Information Sharing and Analysis Center (ES-ISAC). The Responsible Entity must ensure that all reportable Cyber Security Incidents are reported to the ES-ISAC either directly or through an intermediary.
- R1.4.** Process for updating the Cyber Security Incident response plan within thirty calendar days of any changes.
- R1.5.** Process for ensuring that the Cyber Security Incident response plan is reviewed at least annually.
- R1.6.** Process for ensuring the Cyber Security Incident response plan is tested at least annually. A test of the Cyber Security Incident response plan can range from a paper drill, to a full operational exercise, to the response to an actual incident.
- R2.** Cyber Security Incident Documentation — The Responsible Entity shall keep relevant documentation related to Cyber Security Incidents reportable per Requirement R1.1 for three calendar years.

### **C. Measures**

- M1.** The Responsible Entity shall make available its Cyber Security Incident response plan as indicated in Requirement R1 and documentation of the review, updating, and testing of the plan.
- M2.** The Responsible Entity shall make available all documentation as specified in Requirement R2.

### **D. Compliance**

#### **1. Compliance Monitoring Process**

##### **1.1. Compliance Enforcement Authority**

- 1.1.1** Regional Entity for Responsible Entities that do not perform delegated tasks for their Regional Entity.
- 1.1.2** ERO for Regional Entity.
- 1.1.3** Third-party monitor without vested interest in the outcome for NERC.

##### **1.2. Compliance Monitoring Period and Reset Time Frame**

Not applicable.

##### **1.3. Compliance Monitoring and Enforcement Processes**

Compliance Audits  
Self-Certifications  
Spot Checking  
Compliance Violation Investigations  
Self-Reporting  
Complaints

##### **1.4. Data Retention**

- 1.4.1** The Responsible Entity shall keep documentation other than that required for reportable Cyber Security Incidents as specified in Standard CIP-008-3 for the previous full calendar year unless directed by its Compliance Enforcement



Authority to retain specific evidence for a longer period of time as part of an investigation.

- 1.4.2 The Compliance Enforcement Authority in conjunction with the Registered Entity shall keep the last audit records and all requested and submitted subsequent audit records.

**1.5. Additional Compliance Information**

- 1.5.1 The Responsible Entity may not take exception in its cyber security policies to the creation of a Cyber Security Incident response plan.
- 1.5.2 The Responsible Entity may not take exception in its cyber security policies to reporting Cyber Security Incidents to the ES ISAC.

**2. Violation Severity Levels (To be developed later.)**

**E. Regional Variances**

None identified.

**Version History**

Version	Date	Action	Change Tracking
2		Modifications to clarify the requirements and to bring the compliance elements into conformance with the latest guidelines for developing compliance elements of standards. Removal of reasonable business judgment. Replaced the RRO with the RE as a responsible entity. Reworking of Effective Date. Changed compliance monitor to Compliance Enforcement Authority.	
3		Updated Version number from -2 to -3 In Requirement 1.6, deleted the sentence pertaining to removing component or system from service in order to perform testing, in response to FERC order issued September 30, 2009.	
3	12/16/09	Approved by NERC Board of Trustees	Update

## A. Introduction

1. **Title:** **Disturbance Reporting**
2. **Number:** EOP-004-1
3. **Purpose:** Disturbances or unusual occurrences that jeopardize the operation of the Bulk Electric System, or result in system equipment damage or customer interruptions, need to be studied and understood to minimize the likelihood of similar events in the future.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Regional Reliability Organizations.
5. **Effective Date:** January 1, 2007

## B. Requirements

- R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.
- R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.
- R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.
  - R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until some time after they occur shall be reported within 24 hours of being recognized.
  - R3.2. Applicable reporting forms are provided in Attachments 1-EOP-004 and 2-EOP-004.
  - R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that

time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.

- R3.4.** If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.
- R4.** When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.
- R5.** The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.

### C. Measures

- M1.** The Regional Reliability Organization shall have and provide upon request as evidence, its current regional reporting procedure that is used to facilitate preparation of preliminary and final disturbance reports. (Requirement 1)
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, the preliminary report, computer printouts, operator logs, or other equivalent evidence that will be used to confirm that it prepared and delivered the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1.
- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to confirm that it provided information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours. (Requirement 3.3)

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

NERC shall be responsible for compliance monitoring of the Regional Reliability Organizations.

Regional Reliability Organizations shall be responsible for compliance monitoring of Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load-serving Entities.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Regional Reliability Organization shall have its current, in-force, regional reporting procedure as evidence of compliance. (Measure 1)

Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that is either involved in a Bulk Electric System disturbance or has a reportable incident shall keep data related to the incident for a year from the event or for the duration of any regional investigation, whichever is longer. (Measures 2 through 4)

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**1.4. Additional Compliance Information**

See Attachments:

- EOP-004 Disturbance Reporting Form
- Table 1 EOP-004

**2. Levels of Non-Compliance for a Regional Reliability Organization**

**2.1. Level 1:** Not applicable.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Not applicable.

**2.4. Level 4:** No current procedure to facilitate preparation of preliminary and final disturbance reports as specified in R1.

**3. Levels of Non-Compliance for a Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load- Serving Entity:**

**3.1. Level 1:** There shall be a level one non-compliance if any of the following conditions exist:

**3.1.1** Failed to prepare and deliver the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1

**3.1.2** Failed to provide disturbance information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours as specified in R3.3

**3.1.3** Failed to prepare a final report within 60 days as specified in R3.4

**3.2. Level 2:** Not applicable.

**3.3. Level 3:** Not applicable

**3.4. Level 4:** Not applicable.

**E. Regional Differences**

None identified.

**Version History**

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	May 23, 2005	Fixed reference to attachments 1-EOP-004-0 and 2-EOP-004-0, Changed chart title 1-FAC-004-0 to 1-EOP-004-0, Fixed title of Table 1 to read 1-EOP-004-0, and fixed font.	Errata
0	July 6, 2005	Fixed email in Attachment 1-EOP-004-0 from <a href="mailto:info@nerc.com">info@nerc.com</a> to <a href="mailto:esisac@nerc.com">esisac@nerc.com</a> .	Errata

0	July 26, 2005	Fixed Header on page 8 to read EOP-004-0	Errata
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised

## **Attachment 1-EOP-004 NERC Disturbance Report Form**

### **Introduction**

These disturbance reporting requirements apply to all Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load Serving Entities, and provide a common basis for all NERC disturbance reporting. The entity on whose system a reportable disturbance occurs shall notify NERC and its Regional Reliability Organization of the disturbance using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. Reports can be sent to NERC via email ([esisac@nerc.com](mailto:esisac@nerc.com)) by facsimile (609-452-9550) using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. If a disturbance is to be reported to the U.S. Department of Energy also, the responding entity may use the DOE reporting form when reporting to NERC. Note: All Emergency Incident and Disturbance Reports (Schedules 1 and 2) sent to DOE shall be simultaneously sent to NERC, preferably electronically at [esisac@nerc.com](mailto:esisac@nerc.com).

The NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports are to be made for any of the following events:

1. The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:
  - a. Modification of operating procedures.
  - b. Modification of equipment (e.g. control systems or special protection systems) to prevent reoccurrence of the event.
  - c. Identification of valuable lessons learned.
  - d. Identification of non-compliance with NERC standards or policies.
  - e. Identification of a disturbance that is beyond recognized criteria, i.e. three-phase fault with breaker failure, etc.
  - f. Frequency or voltage going below the under-frequency or under-voltage load shed points.
2. The occurrence of an interconnected system separation or system islanding or both.
3. Loss of generation by a Generator Operator, Balancing Authority, or Load-Serving Entity — 2,000 MW or more in the Eastern Interconnection or Western Interconnection and 1,000 MW or more in the ERCOT Interconnection.
4. Equipment failures/system operational actions which result in the loss of firm system demands for more than 15 minutes, as described below:
  - a. Entities with a previous year recorded peak demand of more than 3,000 MW are required to report all such losses of firm demands totaling more than 300 MW.
  - b. All other entities are required to report all such losses of firm demands totaling more than 200 MW or 50% of the total customers being supplied immediately prior to the incident, whichever is less.
5. Firm load shedding of 100 MW or more to maintain the continuity of the bulk electric system.

6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in:
  - a. Sustained voltage excursions equal to or greater than  $\pm 10\%$ , or
  - b. Major damage to power system components, or
  - c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance as defined by steps 1 through 5 above.
7. An Interconnection Reliability Operating Limit (IROL) violation as required in reliability standard TOP-007.
8. Any event that the Operating Committee requests to be submitted to Disturbance Analysis Working Group (DAWG) for review because of the nature of the disturbance and the insight and lessons the electricity supply and delivery industry could learn.



## NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report

Check here if this is an Interconnection Reliability Operating Limit (IROL) violation report.

1.	Organization filing report.		
2.	Name of person filing report.		
3.	Telephone number.		
4.	Date and time of disturbance. Date:(mm/dd/yy) Time/Zone:		
5.	Did the disturbance originate in your system?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
6.	Describe disturbance including: cause, equipment damage, critical services interrupted, system separation, key scheduled and actual flows prior to disturbance and in the case of a disturbance involving a special protection or remedial action scheme, what action is being taken to prevent recurrence.		
7.	Generation tripped.  MW Total List generation tripped		
8.	Frequency. Just prior to disturbance (Hz): Immediately after disturbance (Hz max.): Immediately after disturbance (Hz min.):		
9.	List transmission lines tripped (specify voltage level of each line).		
10.	Demand tripped (MW): Number of affected Customers:	FIRM	INTERRUPTIBLE

	Demand lost (MW-Minutes):		
11.	Restoration time.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		

## **Attachment 2-EOP-004**

### **U.S. Department of Energy Disturbance Reporting Requirements**

#### **Introduction**

The U.S. Department of Energy (DOE), under its relevant authorities, has established mandatory reporting requirements for electric emergency incidents and disturbances in the United States. DOE collects this information from the electric power industry on Form EIA-417 to meet its overall national security and Federal Energy Management Agency's Federal Response Plan (FRP) responsibilities. DOE will use the data from this form to obtain current information regarding emergency situations on U.S. electric energy supply systems. DOE's Energy Information Administration (EIA) will use the data for reporting on electric power emergency incidents and disturbances in monthly EIA reports. In addition, the data may be used to develop legislative recommendations, reports to the Congress and as a basis for DOE investigations following severe, prolonged, or repeated electric power reliability problems.

Every Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity must use this form to submit mandatory reports of electric power system incidents or disturbances to the DOE Operations Center, which operates on a 24-hour basis, seven days a week. All other entities operating electric systems have filing responsibilities to provide information to the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity when necessary for their reporting obligations and to file form EIA-417 in cases where these entities will not be involved. EIA requests that it be notified of those that plan to file jointly and of those electric entities that want to file separately.

Special reporting provisions exist for those electric utilities located within the United States, but for whom Reliability Coordinator oversight responsibilities are handled by electrical systems located across an international border. A foreign utility handling U.S. Balancing Authority responsibilities, may wish to file this information voluntarily to the DOE. Any U.S.-based utility in this international situation needs to inform DOE that these filings will come from a foreign-based electric system or file the required reports themselves.

Form EIA-417 must be submitted to the DOE Operations Center if any one of the following applies (see Table 1-EOP-004-0 — Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies):

1. Uncontrolled loss of 300 MW or more of firm system load for more than 15 minutes from a single incident.
2. Load shedding of 100 MW or more implemented under emergency operational policy.
3. System-wide voltage reductions of 3 percent or more.
4. Public appeal to reduce the use of electricity for purposes of maintaining the continuity of the electric power system.
5. Actual or suspected physical attacks that could impact electric power system adequacy or reliability; or vandalism, which target components of any security system. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.

6. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.
7. Fuel supply emergencies that could impact electric power system adequacy or reliability.
8. Loss of electric service to more than 50,000 customers for one hour or more.
9. Complete operational failure or shut-down of the transmission and/or distribution electrical system.

The initial DOE Emergency Incident and Disturbance Report (form EIA-417 – Schedule 1) shall be submitted to the DOE Operations Center within 60 minutes of the time of the system disruption. Complete information may not be available at the time of the disruption. However, provide as much information as is known or suspected at the time of the initial filing. If the incident is having a critical impact on operations, a telephone notification to the DOE Operations Center (202-586-8100) is acceptable, pending submission of the completed form EIA-417. Electronic submission via an on-line web-based form is the preferred method of notification. However, electronic submission by facsimile or email is acceptable.

An updated form EIA-417 (Schedule 1 and 2) is due within 48 hours of the event to provide complete disruption information. Electronic submission via facsimile or email is the preferred method of notification. Detailed DOE Incident and Disturbance reporting requirements can be found at: [http://www.eia.doe.gov/cneaf/electricity/page/form\\_417.html](http://www.eia.doe.gov/cneaf/electricity/page/form_417.html).

<b>Table 1-EOP-004-0</b>				
<b>Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies</b>				
<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Uncontrolled loss of Firm System Load	$\geq 300$ MW – 15 minutes or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>2</b>	Load Shedding	$\geq 100$ MW under emergency operational policy	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>3</b>	Voltage Reductions	3% or more – applied system-wide	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>4</b>	Public Appeals	Emergency conditions to reduce demand	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>5</b>	Physical sabotage, terrorism or vandalism	On physical security systems – suspected or real	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>6</b>	Cyber sabotage, terrorism or vandalism	If the attempt is believed to have or did happen	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>7</b>	Fuel supply emergencies	Fuel inventory or hydro storage levels $\leq 50\%$ of normal	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>8</b>	Loss of electric service	$\geq 50,000$ for 1 hour or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>9</b>	Complete operation failure of electrical system	If isolated or interconnected electrical systems suffer total electrical system collapse	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
All DOE EIA-417 Schedule 1 reports are to be filed within 60-minutes after the start of an incident or disturbance				
All DOE EIA-417 Schedule 2 reports are to be filed within 48-hours after the start of an incident or disturbance				

***All entities required to file a DOE EIA-417 report (Schedule 1 & 2) shall send a copy of these reports to NERC simultaneously, but no later than 24 hours after the start of the incident or disturbance.***

<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Loss of major system component	Significantly affects integrity of interconnected system operations	NERC Prelim Final report	24 hour 60 day
<b>2</b>	Interconnected system separation or system islanding	Total system shutdown Partial shutdown, separation, or islanding	NERC Prelim Final report	24 hour 60 day
<b>3</b>	Loss of generation	$\geq 2,000$ – Eastern Interconnection $\geq 2,000$ – Western Interconnection $\geq 1,000$ – ERCOT Interconnection	NERC Prelim Final report	24 hour 60 day
<b>4</b>	Loss of firm load $\geq 15$ -minutes	Entities with peak demand $\geq 3,000$ : loss $\geq 300$ MW All others $\geq 200$ MW or 50% of total demand	NERC Prelim Final report	24 hour 60 day
<b>5</b>	Firm load shedding	$\geq 100$ MW to maintain continuity of bulk system	NERC Prelim Final report	24 hour 60 day
<b>6</b>	System operation or operation actions resulting in:	<ul style="list-style-type: none"> <li>• Voltage excursions <math>\geq 10\%</math></li> <li>• Major damage to system components</li> <li>• Failure, degradation, or misoperation of SPS</li> </ul>	NERC Prelim Final report	24 hour 60 day
<b>7</b>	IROL violation	Reliability standard TOP-007.	NERC Prelim Final report	72 hour 60 day
<b>8</b>	As requested by ORS Chairman	Due to nature of disturbance & usefulness to industry (lessons learned)	NERC Prelim Final report	24 hour 60 day

All NERC Operating Security Limit and Preliminary Disturbance reports will be filed within 24 hours after the start of the incident. If an entity must file a DOE EIA-417 report on an incident, which requires a NERC Preliminary report, the Entity may use the DOE EIA-417 form for both DOE and NERC reports.

***Any entity reporting a DOE or NERC incident or disturbance has the responsibility to also notify its Regional Reliability Organization.***

## Standards Announcement

Project 2009-01 Disturbance and Sabotage Reporting  
Ballot Windows Now Open: Successive Ballot and Non-binding  
Poll: May 15 – May 24, 2012

### Now Available

A successive ballot of EOP-004-2 – Event Reporting and a non-binding poll of the associated VRFs and VSLs is open May 15, 2012 through **8 p.m. Eastern on Thursday, May 24, 2012.**

The following documents have been posted for stakeholder review and comment:

- EOP-004-2 (clean and redline showing changes to the last posting)
- Implementation Plan (clean and redline showing changes to the last posting)
- Consideration of Comments Report – Provides a summary of the modifications made to the proposed standard and supporting documents based on comments submitted during the formal comment period that ended December 12, 2011
- Mapping Document - Identifies each requirement in the two already-approved standards that are being consolidated into EOP-004-2 (EOP-004-1 and CIP-001-2a), and identifies how the requirement has been treated in the proposed Draft 4 of EOP-004-2
- VRF/VSL Justification – Explains how the VRFs and VSLs the drafting team has proposed for EOP-004-2 comply with guidelines that FERC and NERC have established for VRFs and VSLs
- Unofficial comment form in Word format for informal use when compiling responses – the final must be submitted electronically

### **Instructions**

Members of the ballot pools associated with this project may log in and submit their vote for the Standard and opinion in the non-binding poll of the associated VRFs and VSLs by clicking [here](#).

Due to modifications to NERC's balloting software, voters will no longer be able to submit commits via the balloting software.

### **Next Steps**

The drafting team will consider all comments submitted during this formal comment and ballot period to determine whether to make additional revisions to the standard.

## Background

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

This project combines CIP-001-1 and EOP-004-1 into a single standard, EOP-004-2, that requires after-the-fact reporting of various types of events.

Additional information is available on the [project webpage](#).

A stakeholder interested in following the Disturbance and Sabotage Reporting Drafting Team’s development of EOP-004-2 may monitor meeting agendas and notes on the team’s [“Related Files”](#) web page or may submit a request to join the team’s “plus” email list to receive meeting agendas and meeting notes as they are distributed to the team. To join the team’s “plus” email list, send an email request to: [sarcomm@nerc.net](mailto:sarcomm@nerc.net). Please indicate the drafting team’s name in the subject line of the email.

## Standards Process

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd. NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)



## Standards Announcement

Project 2009-01 Disturbance and Sabotage Reporting

Formal Comment Period Open: April 25 – May 24, 2012

Ballot Windows Open: Successive Ballot and Non-binding

Poll: May 15 – May 24, 2012

### [Now Available](#)

EOP-004-2 – Event Reporting (clean and redline showing changes to the last posting), an implementation plan (clean and redline to the last posting), and several associated documents (listed below) have been posted for a formal comment period and successive ballot and non-binding poll of associated VRFs and VSLs that will end at **8 p.m. Eastern on Thursday, May 24, 2012**.

The following associated documents have been posted for stakeholder review and comment:

- Consideration of Comments Report – Provides a summary of the modifications made to the proposed standard and supporting documents based on comments submitted during the formal comment period that ended December 12, 2011
- Mapping Document - Identifies each requirement in the two already-approved standards that are being consolidated into EOP-004-2 (EOP-004-1 and CIP-001-2a, and identifies how the requirement has been treated in the proposed Draft 4 of EOP-004-2
- VRF/VSL Justification – Explains how the VRFs and VSLs the drafting team has proposed for EOP-004-2 comply with guidelines that FERC and NERC have established for VRFs and VSLs
- Unofficial comment form in Word format – This is for informal use when compiling responses – the final must be submitted electronically

### Instructions

All members of the ballot pool must cast a new ballot since the votes and comments from the last ballot will not be carried over. In addition, members of the ballot pool will need to cast a new opinion on the VRFs and VSLs. Members of the ballot pools associated with this project may log in and submit their vote for the Standard and non-binding poll of the associated VRFs and VSLs by clicking [here](#).

### Special Instructions for Submitting Comments with a Ballot

Please note that comments submitted during the formal comment period, the ballot and the non-binding poll use the same electronic form. Therefore, it is NOT necessary for ballot pool members to submit more than one set of comments. Companies or entities with representatives in multiple segments of the ballot pool may submit a single set of comments by identifying themselves as a “group” on the comment form. Likewise, it is preferable for a group of separate entities that develop comments jointly to submit the comments as a “group.” **The drafting team requests that all stakeholders (ballot pool members as well as other stakeholders) submit all comments through the electronic comment form, and that companies in multiple segments as well as individual entities that develop joint comments with other entities submit their comments as a “group,” with the list of group members and their associated Industry Segments.**

### Next Steps

A successive ballot and non-binding poll of the associated VRFs and VSLs of EOP-004-2 will be conducted beginning on Tuesday, May 15, 2012 through 8 p.m. Eastern on Thursday, May 24, 2012.

### Background

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Additional information is available on the [project webpage](#).

A stakeholder interested in following the Disturbance and Sabotage Reporting Drafting Team’s development of EOP-004-2 may monitor meeting agendas and notes on the team’s [“Related Files”](#) webpage or may submit a request to join the team’s “plus” email list to receive meeting agendas and meeting notes as they are distributed to the team. To join the team’s “plus” email list, send an email request to: [sarcomm@nerc.net](mailto:sarcomm@nerc.net). Please indicate the drafting team’s name in the subject line of the email.

**Standards Process**

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd.NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)

## Standards Announcement

Project 2009-01 Disturbance and Sabotage Reporting

Formal Comment Period Open: April 25 – May 24, 2012

Ballot Windows Open: Successive Ballot and Non-binding

Poll: May 15 – May 24, 2012

### [Now Available](#)

EOP-004-2 – Event Reporting (clean and redline showing changes to the last posting), an implementation plan (clean and redline to the last posting), and several associated documents (listed below) have been posted for a formal comment period and successive ballot and non-binding poll of associated VRFs and VSLs that will end at **8 p.m. Eastern on Thursday, May 24, 2012.**

The following associated documents have been posted for stakeholder review and comment:

- Consideration of Comments Report – Provides a summary of the modifications made to the proposed standard and supporting documents based on comments submitted during the formal comment period that ended December 12, 2011
- Mapping Document - Identifies each requirement in the two already-approved standards that are being consolidated into EOP-004-2 (EOP-004-1 and CIP-001-2a, and identifies how the requirement has been treated in the proposed Draft 4 of EOP-004-2
- VRF/VSL Justification – Explains how the VRFs and VSLs the drafting team has proposed for EOP-004-2 comply with guidelines that FERC and NERC have established for VRFs and VSLs
- Unofficial comment form in Word format – This is for informal use when compiling responses – the final must be submitted electronically

### **Instructions**

All members of the ballot pool must cast a new ballot since the votes and comments from the last ballot will not be carried over. In addition, members of the ballot pool will need to cast a new opinion on the VRFs and VSLs. Members of the ballot pools associated with this project may log in and submit their vote for the Standard and non-binding poll of the associated VRFs and VSLs by clicking [here](#).

### **Special Instructions for Submitting Comments with a Ballot**

Please note that comments submitted during the formal comment period, the ballot and the non-binding poll use the same electronic form. Therefore, it is NOT necessary for ballot pool members to submit more than one set of comments. Companies or entities with representatives in multiple segments of the ballot pool may submit a single set of comments by identifying themselves as a “group” on the comment form. Likewise, it is preferable for a group of separate entities that develop comments jointly to submit the comments as a “group.” **The drafting team requests that all stakeholders (ballot pool members as well as other stakeholders) submit all comments through the electronic comment form, and that companies in multiple segments as well as individual entities that develop joint comments with other entities submit their comments as a “group,” with the list of group members and their associated Industry Segments.**

### **Next Steps**

A successive ballot and non-binding poll of the associated VRFs and VSLs of EOP-004-2 will be conducted beginning on Tuesday, May 15, 2012 through 8 p.m. Eastern on Thursday, May 24, 2012.

### **Background**

Stakeholders have indicated that identifying potential acts of “sabotage” is difficult to do in real time, and additional clarity is needed to identify thresholds for reporting potential acts of sabotage in CIP-001-1. Stakeholders have also reported that EOP-004-1 has some requirements that reference out-of-date Department of Energy forms, making the requirements ambiguous. EOP-004-1 also has some ‘fill-in-the-blank’ components to eliminate.

The project will include addressing previously identified stakeholder concerns and FERC directives; will bring the standards into conformance with the latest approved version of the ERO Rules of Procedure; and may include other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient bulk power system reliability standards.

Additional information is available on the [project webpage](#).

A stakeholder interested in following the Disturbance and Sabotage Reporting Drafting Team’s development of EOP-004-2 may monitor meeting agendas and notes on the team’s [“Related Files”](#) webpage or may submit a request to join the team’s “plus” email list to receive meeting agendas and meeting notes as they are distributed to the team. To join the team’s “plus” email list, send an email request to: [sarcomm@nerc.net](mailto:sarcomm@nerc.net). Please indicate the drafting team’s name in the subject line of the email.

**Standards Process**

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd.NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)

# Standards Announcement

## Project 2009-01 Disturbance and Sabotage Reporting

### Successive Ballot Results

#### [Now Available](#)

A successive ballot of EOP-004-2 – Event Reporting, and non-binding pools of the associated VRFs and VSLs, concluded on Thursday, May 24, 2012. Voting statistics are listed below, and the [Ballot Results](#) page provides a link to the detailed results.

### Successive Ballot Results for Project 2009-01

Ballot Results	Non-binding Poll Results	
Quorum: 84.43%	Quorum:	79.95%
Approval: 46.18%	Supportive Opinions:	52.67%

### Next Steps

The drafting team will consider all comments submitted during the comment period and ballot, and based on the comments will determine whether to make additional changes.

### Background

EOP-004-2 – Event Reporting consolidates requirements from CIP-001-2a – Sabotage Report and EOP-004-1 – Disturbance Reporting.

### Standards Development Process

The [Standards Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

User Name

Password

Log in

Register

- Ballot Pools
- Current Ballots
- Ballot Results
- Registered Ballot Body
- Proxy Voters

Home Page

Ballot Results	
<b>Ballot Name:</b>	Project 2009-01 Disturbance and Sabotage Reporting EOP-004-2 _in
<b>Ballot Period:</b>	5/15/2012 - 5/24/2012
<b>Ballot Type:</b>	Initial
<b>Total # Votes:</b>	358
<b>Total Ballot Pool:</b>	424
<b>Quorum:</b>	<b>84.43 % The Quorum has been reached</b>
<b>Weighted Segment Vote:</b>	46.18 %
<b>Ballot Results:</b>	<b>The standard will proceed to recirculation ballot.</b>

Summary of Ballot Results									
Segment	Ballot Pool	Segment Weight	Affirmative		Negative		Abstain # Votes	No Vote	
			# Votes	Fraction	# Votes	Fraction			
1 - Segment 1.	104	1	41	0.5	41	0.5	6	16	
2 - Segment 2.	11	0.9	2	0.2	7	0.7	2	0	
3 - Segment 3.	108	1	35	0.393	54	0.607	6	13	
4 - Segment 4.	37	1	15	0.484	16	0.516	2	4	
5 - Segment 5.	91	1	39	0.574	29	0.426	7	16	
6 - Segment 6.	53	1	18	0.474	20	0.526	3	12	
7 - Segment 7.	0	0	0	0	0	0	0	0	
8 - Segment 8.	8	0.6	4	0.4	2	0.2	0	2	
9 - Segment 9.	4	0.2	0	0	2	0.2	1	1	
10 - Segment 10.	8	0.5	3	0.3	2	0.2	1	2	
<b>Totals</b>	<b>424</b>	<b>7.2</b>	<b>157</b>	<b>3.325</b>	<b>173</b>	<b>3.875</b>	<b>28</b>	<b>66</b>	

Individual Ballot Pool Results				
Segment	Organization	Member	Ballot	Comments
1	Ameren Services	Kirit Shah	Negative	
1	American Electric Power	Paul B. Johnson		
1	American Transmission Company, LLC	Andrew Z Pusztai	Negative	
1	Arizona Public Service Co.	Robert Smith	Affirmative	
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative	
1	Austin Energy	James Armke	Affirmative	
1	Avista Corp.	Scott J Kinney	Affirmative	
1	Balancing Authority of Northern California	Kevin Smith	Affirmative	



1	Baltimore Gas & Electric Company	Gregory S Miller	Abstain
1	BC Hydro and Power Authority	Patricia Robertson	Negative
1	Beaches Energy Services	Joseph S Stonecipher	Negative
1	Black Hills Corp	Eric Egge	
1	Bonneville Power Administration	Donald S. Watkins	Negative
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey	Negative
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Negative
1	Central Maine Power Company	Joseph Turano Jr.	Negative
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Negative
1	Clark Public Utilities	Jack Stamper	Negative
1	Colorado Springs Utilities	Paul Morland	Affirmative
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Negative
1	CPS Energy	Richard Castrejana	Affirmative
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative
1	Dayton Power & Light Co.	Hertzel Shamash	Affirmative
1	Deseret Power	James Tucker	Negative
1	Dominion Virginia Power	Michael S Crowley	Affirmative
1	Duke Energy Carolina	Douglas E. Hils	Negative
1	East Kentucky Power Coop.	George S. Carruba	Abstain
1	Empire District Electric Co.	Ralph F Meyer	Affirmative
1	Entergy Services, Inc.	Edward J Davis	Negative
1	FirstEnergy Corp.	William J Smith	Affirmative
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton	Affirmative
1	Florida Power & Light Co.	Mike O'Neil	Negative
1	Gainesville Regional Utilities	Luther E. Fair	
1	Georgia Transmission Corporation	Jason Snodgrass	Negative
1	Grand River Dam Authority	James M Stafford	
1	Great River Energy	Gordon Pietsch	Negative
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Negative
1	Hydro One Networks, Inc.	Ajay Garg	Negative
1	Hydro-Quebec TransEnergie	Bernard Pelletier	
1	Idaho Power Company	Ronald D Schellberg	
1	Imperial Irrigation District	Tino Zaragoza	Affirmative
1	International Transmission Company Holdings Corp	Michael Moltane	Affirmative
1	JEA	Ted Hobson	
1	Kansas City Power & Light Co.	Michael Gammon	Affirmative
1	Keys Energy Services	Stanley T Rzad	
1	Lakeland Electric	Larry E Watt	
1	Lee County Electric Cooperative	John W Delucca	Affirmative
1	Lincoln Electric System	Doug Bantam	
1	Los Angeles Department of Water & Power	Ly M Le	
1	Lower Colorado River Authority	Martyn Turner	Affirmative
1	Manitoba Hydro	Joe D Petaski	Negative
1	MEAG Power	Danny Dees	Affirmative
1	MidAmerican Energy Co.	Terry Harbour	Negative
1	Minnkota Power Coop. Inc.	Richard Burt	
1	National Grid	Saurabh Saksena	Negative
1	Nebraska Public Power District	Cole C Brodine	Negative
1	New Brunswick Power Transmission Corporation	Randy MacDonald	
1	New York Power Authority	Arnold J. Schuff	Affirmative
1	New York State Electric & Gas Corp.	Raymond P Kinney	Abstain
1	Northeast Utilities	David Boguslawski	Negative
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative
1	NorthWestern Energy	John Canavan	Affirmative
1	Ohio Valley Electric Corp.	Robert Matthey	Negative
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Negative
1	Omaha Public Power District	Doug Peterchuck	Affirmative
1	Oncor Electric Delivery	Brenda Pulis	Affirmative
1	Orlando Utilities Commission	Brad Chase	Affirmative
1	PacifiCorp	Ryan Millard	Affirmative
1	PECO Energy	Ronald Schloendorn	Negative
1	Platte River Power Authority	John C. Collins	Affirmative
1	Portland General Electric Co.	John T Walker	Affirmative
1	Potomac Electric Power Co.	David Thorne	Affirmative


1	PowerSouth Energy Cooperative	Larry D Avery	Negative
1	PPL Electric Utilities Corp.	Brenda L Truhe	Affirmative
1	Progress Energy Carolinas	Brett A Koelsch	Negative
1	Public Service Company of New Mexico	Laurie Williams	Affirmative
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Negative
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel	Affirmative
1	Public Utility District No. 2 of Grant County	Kyle M. Hussey	
1	Puget Sound Energy, Inc.	Denise M Lietz	Negative
1	Raj Rana	Rajendrasinh D Rana	Abstain
1	Rochester Gas and Electric Corp.	John C. Allen	Negative
1	Sacramento Municipal Utility District	Tim Kelley	Affirmative
1	Salmon River Electric Cooperative	Kathryn Spence	Affirmative
1	Salt River Project	Robert Kondziolka	Affirmative
1	Santee Cooper	Terry L Blackwell	Negative
1	SCE&G	Henry Delk, Jr.	
1	Seattle City Light	Pawel Krupa	Affirmative
1	Sho-Me Power Electric Cooperative	Denise Stevens	Abstain
1	Sierra Pacific Power Co.	Rich Salgo	Affirmative
1	Snohomish County PUD No. 1	Long T Duong	Affirmative
1	South California Edison Company	Steven Mavis	Negative
1	Southern Company Services, Inc.	Robert A. Schaffeld	Negative
1	Southern Illinois Power Coop.	William Hutchison	Negative
1	Southwest Transmission Cooperative, Inc.	James Jones	Negative
1	Sunflower Electric Power Corporation	Noman Lee Williams	
1	Tampa Electric Co.	Beth Young	Affirmative
1	Tennessee Valley Authority	Larry Akens	Abstain
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative
1	Tucson Electric Power Co.	John Tolo	Negative
1	United Illuminating Co.	Jonathan Appelbaum	Negative
1	Westar Energy	Allen Klassen	Negative
1	Western Area Power Administration	Brandy A Dunn	Affirmative
1	Xcel Energy, Inc.	Gregory L Pieper	Negative
2	Alberta Electric System Operator	Mark B Thompson	Affirmative
2	BC Hydro	Venkataramakrishnan Vinnakota	Negative
2	California ISO	Rich Vine	Negative
2	Electric Reliability Council of Texas, Inc.	Charles B Manning	Abstain
2	Independent Electricity System Operator	Barbara Constantinescu	Affirmative
2	ISO New England, Inc.	Kathleen Goodman	Negative
2	Midwest ISO, Inc.	Marie Knox	Negative
2	New Brunswick System Operator	Alden Briggs	Negative
2	New York Independent System Operator	Gregory Campoli	Abstain
2	PJM Interconnection, L.L.C.	Tom Bowe	Negative
2	Southwest Power Pool, Inc.	Charles H. Yeung	Negative
3	AEP	Michael E Deloach	Negative
3	Alabama Power Company	Richard J. Mandes	Negative
3	Alameda Municipal Power	Douglas Draeger	Affirmative
3	Ameren Services	Mark Peters	Negative
3	American Public Power Association	Nathan Mitchell	Abstain
3	Anaheim Public Utilities Dept.	Kelly Nguyen	
3	APS	Steven Norris	Affirmative
3	Arkansas Electric Cooperative Corporation	Philip Huff	Negative
3	Atlantic City Electric Company	NICOLE BUCKMAN	Affirmative
3	BC Hydro and Power Authority	Pat G. Harrington	Negative
3	Blachly-Lane Electric Co-op	Bud Tracy	Negative
3	Bonneville Power Administration	Rebecca Berdahl	Negative
3	Central Electric Cooperative, Inc. (Redmond, Oregon)	Dave Markham	Negative
3	Central Lincoln PUD	Steve Alexanderson	Negative
3	City of Alexandria	Michael Marcotte	
3	City of Austin dba Austin Energy	Andrew Gallo	Affirmative
3	City of Bartow, Florida	Matt Culverhouse	Abstain
3	City of Clewiston	Lynne Mila	Negative
3	City of Farmington	Linda R Jacobson	Negative
3	City of Garland	Ronnie C Hoeinghaus	Affirmative
3	City of Green Cove Springs	Gregg R Griffin	
3	City of Palo Alto	Eric R Scott	Affirmative

3	City of Redding	Bill Hughes	Affirmative	
3	Clatskanie People's Utility District	Brian Fawcett		
3	Clearwater Power Co.	Dave Hagen	Negative	
3	Cleco Corporation	Michelle A Corley	Negative	
3	Colorado Springs Utilities	Charles Morgan	Affirmative	
3	ComEd	Bruce Krawczyk	Negative	
3	Consolidated Edison Co. of New York	Peter T Yost	Negative	
3	Constellation Energy	CJ Ingersoll	Abstain	
3	Consumers Energy	Richard Blumenstock	Negative	
3	Consumers Power Inc.	Roman Gillen	Negative	
3	Coos-Curry Electric Cooperative, Inc	Roger Meader	Negative	
3	Cowlitz County PUD	Russell A Noble	Affirmative	
3	CPS Energy	Jose Escamilla	Affirmative	
3	Delmarva Power & Light Co.	Michael R. Mayer	Affirmative	
3	Detroit Edison Company	Kent Kujala	Negative	
3	Dominion Resources Services	Michael F. Gildea	Affirmative	
3	Duke Energy Carolina	Henry Ernst-Jr	Negative	
3	Entergy	Joel T Plessinger	Negative	
3	Fall River Rural Electric Cooperative	Bryan Case	Negative	
3	FirstEnergy Energy Delivery	Stephan Kern	Affirmative	
3	Florida Municipal Power Agency	Joe McKinney	Negative	
3	Florida Power Corporation	Lee Schuster	Negative	
3	Georgia Power Company	Anthony L Wilson	Negative	
3	Georgia Systems Operations Corporation	William N. Phinney	Negative	
3	Grays Harbor PUD	Wesley W Gray		
3	Great River Energy	Brian Glover	Negative	
3	Gulf Power Company	Paul C Caldwell	Negative	
3	Hydro One Networks, Inc.	David Kiguel	Negative	
3	Imperial Irrigation District	Jesus S. Alcaraz	Affirmative	
3	JEA	Garry Baker		
3	Kansas City Power & Light Co.	Charles Locke	Affirmative	
3	Kissimmee Utility Authority	Gregory D Woessner	Negative	
3	Kootenai Electric Cooperative	Dave Kahly	Affirmative	
3	Lakeland Electric	Norman D Harryhill		
3	Lane Electric Cooperative, Inc.	Rick Crinklaw	Negative	
3	Lincoln Electric System	Jason Fortik	Negative	
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Affirmative	
3	Louisville Gas and Electric Co.	Charles A. Freibert	Affirmative	
3	Manitoba Hydro	Greg C. Parent	Negative	
3	Manitowoc Public Utilities	Thomas E Reed	Negative	
3	MidAmerican Energy Co.	Thomas C. Mielnik	Negative	
3	Mississippi Power	Jeff Franklin	Negative	
3	Modesto Irrigation District	Jack W Savage	Affirmative	
3	Municipal Electric Authority of Georgia	Steven M. Jackson	Affirmative	
3	Muscatine Power & Water	John S Bos	Negative	
3	Nebraska Public Power District	Tony Eddleman	Negative	
3	New York Power Authority	Marilyn Brown	Affirmative	
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Negative	
3	North Carolina Electric Membership Corp.	Doug White	Negative	
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative	
3	Northern Lights Inc.	Jon Shelby	Negative	
3	Ocala Electric Utility	David Anderson	Negative	
3	Old Dominion Electric Coop.	Bill Watson		
3	Orange and Rockland Utilities, Inc.	David Burke	Negative	
3	Orlando Utilities Commission	Ballard K Mutters	Abstain	
3	Owensboro Municipal Utilities	Thomas T Lyons	Affirmative	
3	Pacific Gas and Electric Company	John H Hagen	Affirmative	
3	PacifiCorp	Dan Zollner	Affirmative	
3	Platte River Power Authority	Terry L Baker	Affirmative	
3	PNM Resources	Michael Mertz	Affirmative	
3	Potomac Electric Power Co.	Robert Reuter	Affirmative	
3	Progress Energy Carolinas	Sam Waters	Negative	
3	Public Service Electric and Gas Co.	Jeffrey Mueller	Negative	
3	Public Utility District No. 1 of Benton County	Gloria Bender	Affirmative	
3	Public Utility District No. 1 of Clallam County	David Proebstel		
3	Puget Sound Energy, Inc.	Erin Apperson		
3	Raft River Rural Electric Cooperative	Heber Carpenter	Negative	

3	Rutherford EMC	Thomas M Haire	Negative
3	Sacramento Municipal Utility District	James Leigh-Kendall	Affirmative
3	Salt River Project	John T. Underhill	Affirmative
3	Santee Cooper	James M Poston	Negative
3	Seattle City Light	Dana Wheelock	Affirmative
3	Seminole Electric Cooperative, Inc.	James R Frauen	Affirmative
3	Snohomish County PUD No. 1	Mark Oens	
3	South Carolina Electric & Gas Co.	Hubert C Young	Abstain
3	Southern California Edison Co.	David B Coher	Negative
3	Southern Maryland Electric Coop.	Mark R Jones	
3	Tacoma Public Utilities	Travis Metcalfe	Negative
3	Tampa Electric Co.	Ronald L. Donahey	Affirmative
3	Tennessee Valley Authority	Ian S Grant	Abstain
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative
3	Umatilla Electric Cooperative	Steve Eldrige	Negative
3	Westar Energy	Bo Jones	Negative
3	Wisconsin Electric Power Marketing	James R Keller	Negative
3	Wisconsin Public Service Corp.	Gregory J Le Grave	
3	Xcel Energy, Inc.	Michael Ibold	Negative
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative
4	American Municipal Power	Kevin Koloini	Negative
4	Arkansas Electric Cooperative Corporation	Ronnie Frizzell	Negative
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative
4	Central Lincoln PUD	Shamus J Gamache	Negative
4	City of Austin dba Austin Energy	Reza Ebrahimian	Affirmative
4	City of Clewiston	Kevin McCarthy	Negative
4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	
4	City of Redding	Nicholas Zettel	Affirmative
4	City Utilities of Springfield, Missouri	John Allen	Affirmative
4	Consumers Energy	David Frank Ronk	Negative
4	Cowlitz County PUD	Rick Syring	Affirmative
4	Detroit Edison Company	Daniel Herring	Affirmative
4	Flathead Electric Cooperative	Russ Schneider	Negative
4	Florida Municipal Power Agency	Frank Gaffney	Negative
4	Fort Pierce Utilities Authority	Thomas Richards	
4	Georgia System Operations Corporation	Guy Andrews	Negative
4	Illinois Municipal Electric Agency	Bob C. Thomas	Negative
4	Imperial Irrigation District	Diana U Torres	Affirmative
4	Indiana Municipal Power Agency	Jack Alvey	Negative
4	Integrus Energy Group, Inc.	Christopher Plante	Abstain
4	LaGen	Richard Comeaux	Abstain
4	Madison Gas and Electric Co.	Joseph DePoorter	Affirmative
4	North Carolina Electric Membership Corp.	Bob Beadle	Negative
4	Northern California Power Agency	Tracy R Bibb	Affirmative
4	Ohio Edison Company	Douglas Hohlbaugh	Affirmative
4	Oklahoma Municipal Power Authority	Ashley Stringer	Negative
4	Pacific Northwest Generating Cooperative	Aleka K Scott	Negative
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Affirmative
4	Sacramento Municipal Utility District	Mike Ramirez	Affirmative
4	Seattle City Light	Hao Li	Affirmative
4	South Mississippi Electric Power Association	Steven McElhaney	
4	Tacoma Public Utilities	Keith Morisette	Negative
4	West Oregon Electric Cooperative, Inc.	Marc M Farmer	Negative
4	White River Electric Association Inc.	Frank L. Sampson	
4	Wisconsin Energy Corp.	Anthony Jankowski	Negative
5	AEP Service Corp.	Brock Ondayko	Negative
5	AES Corporation	Leo Bernier	Affirmative
5	Amerenue	Sam Dwyer	Negative
5	Arizona Public Service Co.	Edward Cambridge	Affirmative
5	Avista Corp.	Edward F. Groce	Affirmative
5	BC Hydro and Power Authority	Clement Ma	Negative
5	Black Hills Corp	George Tatar	Affirmative
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla	Negative
5	Bonneville Power Administration	Francis J. Halpin	Negative

5	BrightSource Energy, Inc.	Chifong Thomas		
5	Caithness Long Island, LLC	Jason M Moore	Abstain	
5	Chelan County Public Utility District #1	John Yale	Abstain	
5	City and County of San Francisco	Daniel Mason	Abstain	
5	City of Austin dba Austin Energy	Jeanie Doty	Affirmative	
5	City of Redding	Paul Cummings	Affirmative	
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick	Negative	
5	City of Tallahassee	Brian Horton		
5	City Water, Light & Power of Springfield	Steve Rose	Affirmative	
5	Cogentrix Energy, Inc.	Mike D Hirst	Affirmative	
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative	
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Negative	
5	Constellation Power Source Generation, Inc.	Amir Y Hammad	Abstain	
5	Consumers Energy Company	David C Greyerbiehl		
5	Cowlitz County PUD	Bob Essex	Affirmative	
5	CPS Energy	Robert Stevens	Affirmative	
5	Detroit Edison Company	Christy Wicke	Affirmative	
5	Dominion Resources, Inc.	Mike Garton	Affirmative	
5	Duke Energy	Dale Q Goodwine	Negative	
5	Dynegy Inc.	Dan Roethemeyer	Affirmative	
5	E.ON Climate & Renewables North America, LLC	Dana Showalter		
5	Edison Mission Energy	Ellen Oswald		
5	Electric Power Supply Association	John R Cashin	Abstain	
5	Exelon Nuclear	Michael Korchynsky	Negative	
5	ExxonMobil Research and Engineering	Martin Kaufman	Negative	
5	FirstEnergy Solutions	Kenneth Dresner	Affirmative	
5	Florida Municipal Power Agency	David Schumann	Negative	
5	Great River Energy	Preston L Walsh	Negative	
5	Green Country Energy	Greg Froehling		
5	Imperial Irrigation District	Marcela Y Caballero	Affirmative	
5	Indeck Energy Services, Inc.	Rex A Roehl		
5	JEA	John J Babik	Affirmative	
5	Kissimmee Utility Authority	Mike Blough	Negative	
5	Lakeland Electric	James M Howard		
5	Liberty Electric Power LLC	Daniel Duff	Affirmative	
5	Lincoln Electric System	Dennis Florom	Negative	
5	Los Angeles Department of Water & Power	Kenneth Silver	Affirmative	
5	Lower Colorado River Authority	Tom Foreman		
5	Luminant Generation Company LLC	Mike Laney	Negative	
5	Manitoba Hydro	S N Fernando	Negative	
5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Abstain	
5	MEAG Power	Steven Grego	Affirmative	
5	MidAmerican Energy Co.	Christopher Schneider	Negative	
5	Muscatine Power & Water	Mike Avesing	Negative	
5	Nebraska Public Power District	Don Schmit	Negative	
5	New York Power Authority	Gerald Mannarino	Affirmative	
5	NextEra Energy	Allen D Schriver	Negative	
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Negative	
5	Northern California Power Agency	Hari Modi	Affirmative	
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative	
5	Occidental Chemical	Michelle R DAntuono	Affirmative	
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative	
5	Orlando Utilities Commission	Richard Kinias		
5	Pacific Gas and Electric Company	Richard J. Padilla	Affirmative	
5	PacifiCorp	Sandra L. Shaffer	Affirmative	
5	Platte River Power Authority	Roland Thiel	Affirmative	
5	Portland General Electric Co.	Gary L Tingley	Affirmative	
5	PowerSouth Energy Cooperative	Tim Hattaway	Affirmative	
5	PPL Generation LLC	Annette M Bannon	Affirmative	
5	Progress Energy Carolinas	Wayne Lewis	Negative	
5	PSEG Fossil LLC	Tim Kucey	Negative	
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative	
5	Puget Sound Energy, Inc.	Tom Flynn	Negative	
5	Sacramento Municipal Utility District	Bethany Hunter	Affirmative	
5	Salt River Project	William Alkema	Affirmative	

5	Santee Cooper	Lewis P Pierce	Negative	
5	Seattle City Light	Michael J. Haynes	Affirmative	
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins	Affirmative	
5	Siemens PTI	Edwin Cano		
5	Snohomish County PUD No. 1	Sam Niefeld	Affirmative	
5	South Mississippi Electric Power Association	Jerry W Johnson		
5	Southern California Edison Co.	Denise Yaffe		
5	Southern Company Generation	William D Shultz	Negative	
5	Tampa Electric Co.	RJames Rocha	Affirmative	
5	Tenaska, Inc.	Scott M. Helyer	Affirmative	
5	Tennessee Valley Authority	David Thompson	Abstain	
5	Tri-State G & T Association, Inc.	Barry Ingold	Affirmative	
5	U.S. Army Corps of Engineers	Melissa Kurtz		
5	Vandolah Power Company L.L.C.	Douglas A. Jensen		
5	Wisconsin Electric Power Co.	Linda Horn	Negative	
5	Wisconsin Public Service Corp.	Leonard Rentmeester		
5	Xcel Energy, Inc.	Liam Noailles	Negative	
6	ACES Power Marketing	Jason L Marshall	Abstain	
6	AEP Marketing	Edward P. Cox	Negative	
6	Ameren Energy Marketing Co.	Jennifer Richardson	Negative	
6	APS	RANDY A YOUNG	Affirmative	
6	Arkansas Electric Cooperative Corporation	Keith Sugg		
6	Bonneville Power Administration	Brenda S. Anderson	Negative	
6	City of Austin dba Austin Energy	Lisa L Martin	Affirmative	
6	City of Redding	Marvin Briggs	Affirmative	
6	Cleco Power LLC	Robert Hirschak	Negative	
6	Colorado Springs Utilities	Lisa C Rosintoski	Affirmative	
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Negative	
6	Constellation Energy Commodities Group	Brenda L Powell	Negative	
6	Dominion Resources, Inc.	Louis S. Slade	Affirmative	
6	Duke Energy Carolina	Walter Yeager		
6	Entergy Services, Inc.	Terri F Benoit	Negative	
6	Exelon Power Team	Pulin Shah	Abstain	
6	FirstEnergy Solutions	Kevin Querry	Affirmative	
6	Florida Municipal Power Agency	Richard L. Montgomery	Negative	
6	Florida Municipal Power Pool	Thomas Washburn	Negative	
6	Florida Power & Light Co.	Silvia P. Mitchell	Negative	
6	Imperial Irrigation District	Cathy Bretz	Affirmative	
6	Kansas City Power & Light Co.	Jessica L Klinghoffer		
6	Lakeland Electric	Paul Shipps	Negative	
6	Lincoln Electric System	Eric Ruskamp	Negative	
6	Los Angeles Department of Water & Power	Brad Packer		
6	Luminant Energy	Brad Jones	Negative	
6	Manitoba Hydro	Daniel Prowse	Negative	
6	MidAmerican Energy Co.	Dennis Kimm	Negative	
6	New York Power Authority	William Palazzo	Affirmative	
6	North Carolina Municipal Power Agency #1	Matthew Schull	Affirmative	
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative	
6	Omaha Public Power District	David Ried	Affirmative	
6	Orlando Utilities Commission	Claston Augustus Sunanon		
6	PacifiCorp	Scott L Smith	Affirmative	
6	Platte River Power Authority	Carol Ballantine	Affirmative	
6	PPL EnergyPlus LLC	Mark A Heimbach	Affirmative	
6	Progress Energy	John T Sturgeon	Negative	
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Negative	
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen		
6	Sacramento Municipal Utility District	Diane Enderby	Affirmative	
6	Salt River Project	Steven J Hulet	Affirmative	
6	Santee Cooper	Michael Brown	Negative	
6	Seattle City Light	Dennis Sismaet	Affirmative	
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak		
6	Snohomish County PUD No. 1	William T Moojen		
6	South California Edison Company	Lujuanna Medina		
6	Southern Company Generation and Energy Marketing	John J. Ciza	Negative	
6	Tacoma Public Utilities	Michael C Hill		
6	Tampa Electric Co.	Benjamin F Smith II		



6	Tennessee Valley Authority	Marjorie S. Parsons	Abstain
6	Westar Energy	Grant L Wilkerson	Negative
6	Western Area Power Administration - UGP Marketing	Peter H Kinney	Affirmative
6	Xcel Energy, Inc.	David F. Lemmons	
8		Edward C Stein	Affirmative
8		Roger C Zaklukiewicz	Affirmative
8		James A Maenner	
8	JDRJC Associates	Jim Cyrulewski	Affirmative
8	Pacific Northwest Generating Cooperative	Margaret Ryan	Negative
8	Power Energy Group LLC	Peggy Abbadini	
8	Utility Services, Inc.	Brian Evans-Mongeon	Affirmative
8	Volkman Consulting, Inc.	Terry Volkman	Negative
9	California Energy Commission	William M Chamberlain	Abstain
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	Negative
9	National Association of Regulatory Utility Commissioners	Diane J. Barney	Negative
9	New York State Department of Public Service	Thomas Dvorsky	
10	Midwest Reliability Organization	James D Burley	
10	New York State Reliability Council	Alan Adamson	Negative
10	Northeast Power Coordinating Council	Guy V. Zito	Abstain
10	ReliabilityFirst Corporation	Anthony E Jablonski	Affirmative
10	SERC Reliability Corporation	Carter B. Edge	
10	Southwest Power Pool RE	Emily Pennel	Affirmative
10	Texas Reliability Entity, Inc.	Donald G Jones	Negative
10	Western Electricity Coordinating Council	Steven L. Rueckert	Affirmative

Legal and Privacy : 609.452.8060 voice : 609.452.9550 fax : 116-390 Village Boulevard : Princeton, NJ 08540-5721  
 Washington Office: 1120 G Street, N.W. : Suite 990 : Washington, DC 20005-3801

[Account Log-In/Register](#)

Copyright © 2010 by the North American Electric Reliability Corporation. : All rights reserved.  
 A New Jersey Nonprofit Corporation

# Non-binding Poll Results

Project 2009-01: Disturbance and Sabotage Reporting

Non-binding Poll Results	
<b>Non-binding Poll Name:</b>	Project 2009-01 DSR Non-binding Poll
<b>Poll Period:</b>	5/15/2012 - 5/24/2012
<b>Total # Opinions:</b>	315
<b>Total Ballot Pool:</b>	394
<b>Summary Results:</b>	79.95% of those who registered to participate provided an opinion or an abstention; 52.67% of those who provided an opinion indicated support for the VRFs and VSLs.

Individual Ballot Pool Results			
Segment	Organization	Member	Opinions

1	Ameren Services	Kirit Shah	Negative
1	American Electric Power	Paul B. Johnson	
1	American Transmission Company, LLC	Andrew Z Puszta	Abstain
1	Arizona Public Service Co.	Robert Smith	Affirmative
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative
1	Avista Corp.	Scott J Kinney	Affirmative
1	Balancing Authority of Northern California	Kevin Smith	Abstain
1	Baltimore Gas & Electric Company	Gregory S Miller	Abstain
1	BC Hydro and Power Authority	Patricia Robertson	Abstain
1	Beaches Energy Services	Joseph S Stonecipher	Negative
1	Black Hills Corp	Eric Egge	
1	Bonneville Power Administration	Donald S. Watkins	Negative
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey	Negative
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Negative
1	Central Maine Power Company	Joseph Turano Jr.	Negative
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Negative
1	Clark Public Utilities	Jack Stamper	Affirmative
1	Colorado Springs Utilities	Paul Morland	Affirmative
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Negative
1	CPS Energy	Richard Castrejana	
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative
1	Dayton Power & Light Co.	Hertzel Shamash	Affirmative
1	Deseret Power	James Tucker	Abstain
1	Dominion Virginia Power	Michael S Crowley	Abstain
1	Duke Energy Carolina	Douglas E. Hils	Negative
1	East Kentucky Power Coop.	George S. Carruba	Abstain
1	Empire District Electric Co.	Ralph F Meyer	Affirmative
1	Entergy Services, Inc.	Edward J Davis	Negative



1	FirstEnergy Corp.	William J Smith	Affirmative
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton	Affirmative
1	Florida Power & Light Co.	Mike O'Neil	Negative
1	Gainesville Regional Utilities	Luther E. Fair	
1	Georgia Transmission Corporation	Jason Snodgrass	Abstain
1	Grand River Dam Authority	James M Stafford	
1	Great River Energy	Gordon Pietsch	Negative
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Abstain
1	Hydro One Networks, Inc.	Ajay Garg	Negative
1	Hydro-Quebec TransEnergie	Bernard Pelletier	
1	Idaho Power Company	Ronald D. Schellberg	
1	Imperial Irrigation District	Tino Zaragoza	Affirmative
1	International Transmission Company Holdings Corp	Michael Moltane	Abstain
1	JEA	Ted Hobson	Affirmative
1	Kansas City Power & Light Co.	Michael Gammon	Affirmative
1	Keys Energy Services	Stanley T Rzad	
1	Lakeland Electric	Larry E Watt	
1	Lee County Electric Cooperative	John W Delucca	Affirmative
1	Lincoln Electric System	Doug Bantam	
1	Los Angeles Department of Water & Power	Ly M Le	
1	Lower Colorado River Authority	Martyn Turner	Affirmative
1	Manitoba Hydro	Joe D Petaski	Negative
1	MEAG Power	Danny Dees	Affirmative
1	MidAmerican Energy Co.	Terry Harbour	Negative
1	Minnkota Power Coop. Inc.	Richard Burt	
1	National Grid	Saurabh Saksena	Affirmative
1	Nebraska Public Power District	Cole C Brodine	Negative
1	New Brunswick Power Transmission Corporation	Randy MacDonald	
1	New York Power Authority	Arnold J. Schuff	Affirmative
1	New York State Electric & Gas Corp.	Raymond P Kinney	Abstain
1	Northeast Utilities	David Boguslawski	Abstain
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative
1	NorthWestern Energy	John Canavan	
1	Ohio Valley Electric Corp.	Robert Matthey	Abstain
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Negative
1	Omaha Public Power District	Doug Peterchuck	Affirmative
1	Oncor Electric Delivery	Brenda Pulis	Affirmative
1	Orlando Utilities Commission	Brad Chase	Affirmative
1	PacifiCorp	Ryan Millard	Abstain
1	PECO Energy	Ronald Schloendorn	Negative
1	Platte River Power Authority	John C. Collins	Abstain
1	Portland General Electric Co.	John T Walker	Affirmative
1	PowerSouth Energy Cooperative	Larry D Avery	Negative
1	PPL Electric Utilities Corp.	Brenda L Truhe	Abstain

1	Progress Energy Carolinas	Brett A Koelsch	Negative
1	Public Service Company of New Mexico	Laurie Williams	Affirmative
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Abstain
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel	Abstain
1	Puget Sound Energy, Inc.	Denise M Lietz	Negative
1	Rochester Gas and Electric Corp.	John C. Allen	Affirmative
1	Sacramento Municipal Utility District	Tim Kelley	Abstain
1	Salmon River Electric Cooperative	Kathryn Spence	
1	Salt River Project	Robert Kondziolka	Affirmative
1	Santee Cooper	Terry L Blackwell	Negative
1	SCE&G	Henry Delk, Jr.	
1	Seattle City Light	Pawel Krupa	Affirmative
1	Sho-Me Power Electric Cooperative	Denise Stevens	Abstain
1	Sierra Pacific Power Co.	Rich Salgo	Abstain
1	Snohomish County PUD No. 1	Long T Duong	Affirmative
1	South California Edison Company	Steven Mavis	Negative
1	Southern Company Services, Inc.	Robert A. Schaffeld	Negative
1	Southern Illinois Power Coop.	William Hutchison	Negative
1	Southwest Transmission Cooperative, Inc.	James Jones	
1	Southwestern Power Administration	Angela L Summer	Abstain
1	Sunflower Electric Power Corporation	Noman Lee Williams	
1	Tampa Electric Co.	Beth Young	
1	Tennessee Valley Authority	Larry Akens	Abstain
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative
1	Tucson Electric Power Co.	John Tolo	Negative
1	United Illuminating Co.	Jonathan Appelbaum	Negative
1	Westar Energy	Allen Klassen	Negative
1	Western Area Power Administration	Brandy A Dunn	Affirmative
1	Xcel Energy, Inc.	Gregory L Pieper	
2	Alberta Electric System Operator	Mark B Thompson	Abstain
2	BC Hydro	Venkataramakrishnan Vinnakota	Abstain
2	California ISO	Rich Vine	Negative
2	Electric Reliability Council of Texas, Inc.	Charles B Manning	
2	Independent Electricity System Operator	Barbara Constantinescu	Negative
2	Midwest ISO, Inc.	Marie Knox	Negative
2	New Brunswick System Operator	Alden Briggs	Abstain
2	New York Independent System Operator	Gregory Campoli	Abstain
2	PJM Interconnection, L.L.C.	Tom Bowe	
2	Southwest Power Pool, Inc.	Charles H. Yeung	Abstain
3	AEP	Michael E Deloach	Abstain
3	Alabama Power Company	Richard J. Mandes	Negative
3	Ameren Services	Mark Peters	Negative
3	Anaheim Public Utilities Dept.	Kelly Nguyen	
3	APS	Steven Norris	Affirmative
3	Arkansas Electric Cooperative	Philip Huff	Affirmative

	Corporation		
3	BC Hydro and Power Authority	Pat G. Harrington	Abstain
3	Bonneville Power Administration	Rebecca Berdahl	Negative
3	Central Lincoln PUD	Steve Alexanderson	Abstain
3	City of Austin dba Austin Energy	Andrew Gallo	Affirmative
3	City of Bartow, Florida	Matt Culverhouse	Abstain
3	City of Clewiston	Lynne Mila	Negative
3	City of Farmington	Linda R Jacobson	Abstain
3	City of Garland	Ronnie C Hoeinghaus	Affirmative
3	City of Green Cove Springs	Gregg R Griffin	
3	City of Redding	Bill Hughes	Affirmative
3	Clatskanie People's Utility District	Brian Fawcett	
3	Cleco Corporation	Michelle A Corley	Negative
3	Colorado Springs Utilities	Charles Morgan	Affirmative
3	ComEd	Bruce Krawczyk	Negative
3	Consolidated Edison Co. of New York	Peter T Yost	Negative
3	Constellation Energy	CJ Ingersoll	Abstain
3	Consumers Energy	Richard Blumenstock	Negative
3	Cowlitz County PUD	Russell A Noble	Affirmative
3	CPS Energy	Jose Escamilla	
3	Detroit Edison Company	Kent Kujala	Negative
3	Dominion Resources Services	Michael F. Gildea	
3	Duke Energy Carolina	Henry Ernst-Jr	Negative
3	Entergy	Joel T Plessinger	Negative
3	FirstEnergy Energy Delivery	Stephan Kern	Affirmative
3	Florida Municipal Power Agency	Joe McKinney	Negative
3	Florida Power Corporation	Lee Schuster	
3	Georgia Power Company	Anthony L Wilson	Negative
3	Georgia Systems Operations Corporation	William N. Phinney	Negative
3	Grays Harbor PUD	Wesley W Gray	
3	Great River Energy	Brian Glover	Negative
3	Gulf Power Company	Paul C Caldwell	Negative
3	Hydro One Networks, Inc.	David Kiguel	Negative
3	Imperial Irrigation District	Jesus S. Alcaraz	Affirmative
3	JEA	Garry Baker	
3	Kansas City Power & Light Co.	Charles Locke	Affirmative
3	Kissimmee Utility Authority	Gregory D Woessner	Abstain
3	Kootenai Electric Cooperative	Dave Kahly	Abstain
3	Lakeland Electric	Norman D Harryhill	
3	Lincoln Electric System	Jason Fortik	Affirmative
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Abstain
3	Louisville Gas and Electric Co.	Charles A. Freibert	
3	Manitoba Hydro	Greg C. Parent	Negative
3	Manitowoc Public Utilities	Thomas E Reed	Negative
3	MidAmerican Energy Co.	Thomas C. Mielnik	Abstain
3	Mississippi Power	Jeff Franklin	Negative
3	Modesto Irrigation District	Jack W Savage	Affirmative

3	Municipal Electric Authority of Georgia	Steven M. Jackson	Affirmative
3	Muscatine Power & Water	John S Bos	Negative
3	Nebraska Public Power District	Tony Eddleman	Abstain
3	New York Power Authority	Marilyn Brown	Affirmative
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Affirmative
3	North Carolina Electric Membership Corp.	Doug White	
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative
3	Ocala Electric Utility	David Anderson	Negative
3	Old Dominion Electric Coop.	Bill Watson	
3	Orange and Rockland Utilities, Inc.	David Burke	Negative
3	Orlando Utilities Commission	Ballard K Mutters	Abstain
3	Owensboro Municipal Utilities	Thomas T Lyons	Affirmative
3	Pacific Gas and Electric Company	John H Hagen	Affirmative
3	PacifiCorp	Dan Zollner	Affirmative
3	Platte River Power Authority	Terry L Baker	Abstain
3	PNM Resources	Michael Mertz	Affirmative
3	Potomac Electric Power Co.	Robert Reuter	Abstain
3	Progress Energy Carolinas	Sam Waters	Negative
3	Public Service Electric and Gas Co.	Jeffrey Mueller	Abstain
3	Public Utility District No. 1 of Clallam County	David Proebstel	
3	Puget Sound Energy, Inc.	Erin Apperson	
3	Rutherford EMC	Thomas M Haire	Negative
3	Sacramento Municipal Utility District	James Leigh-Kendall	Abstain
3	Salt River Project	John T. Underhill	Affirmative
3	Santee Cooper	James M Poston	Negative
3	Seattle City Light	Dana Wheelock	Affirmative
3	Seminole Electric Cooperative, Inc.	James R Frauen	Affirmative
3	Snohomish County PUD No. 1	Mark Oens	
3	South Carolina Electric & Gas Co.	Hubert C Young	Abstain
3	Southern Maryland Electric Coop.	Mark R Jones	
3	Tacoma Public Utilities	Travis Metcalfe	Negative
3	Tampa Electric Co.	Ronald L Donahey	
3	Tennessee Valley Authority	Ian S Grant	Abstain
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative
3	Westar Energy	Bo Jones	Negative
3	Xcel Energy, Inc.	Michael Ibold	Abstain
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative
4	American Municipal Power	Kevin Koloini	Negative
4	Arkansas Electric Cooperative Corporation	Ronnie Frizzell	Abstain
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative
4	Central Lincoln PUD	Shamus J Gamache	Negative
4	City of Austin dba Austin Energy	Reza Ebrahimian	
4	City of Clewiston	Kevin McCarthy	Negative
4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	

4	City of Redding	Nicholas Zettel	Affirmative
4	City Utilities of Springfield, Missouri	John Allen	Affirmative
4	Consumers Energy	David Frank Ronk	Negative
4	Cowlitz County PUD	Rick Syring	Affirmative
4	Detroit Edison Company	Daniel Herring	Affirmative
4	Flathead Electric Cooperative	Russ Schneider	Abstain
4	Florida Municipal Power Agency	Frank Gaffney	Negative
4	Fort Pierce Utilities Authority	Thomas Richards	
4	Georgia System Operations Corporation	Guy Andrews	Negative
4	Illinois Municipal Electric Agency	Bob C. Thomas	Abstain
4	Imperial Irrigation District	Diana U Torres	Affirmative
4	Indiana Municipal Power Agency	Jack Alvey	Abstain
4	Integrus Energy Group, Inc.	Christopher Plante	Negative
4	LaGen	Richard Comeaux	Abstain
4	Madison Gas and Electric Co.	Joseph DePoorter	Abstain
4	Northern California Power Agency	Tracy R Bibb	Affirmative
4	Ohio Edison Company	Douglas Hohlbaugh	Affirmative
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Abstain
4	Sacramento Municipal Utility District	Mike Ramirez	Abstain
4	Seattle City Light	Hao Li	Affirmative
4	South Mississippi Electric Power Association	Steven McElhanev	
4	Tacoma Public Utilities	Keith Morissette	Negative
4	Wisconsin Energy Corp.	Anthony Jankowski	Negative
5	AEP Service Corp.	Brock Ondayko	Abstain
5	AES Corporation	Leo Bernier	Affirmative
5	Amerenue	Sam Dwyer	Negative
5	Arizona Public Service Co.	Edward Cambridge	Affirmative
5	Avista Corp.	Edward F. Groce	Affirmative
5	BC Hydro and Power Authority	Clement Ma	Abstain
5	Black Hills Corp	George Tatar	Affirmative
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla	
5	Bonneville Power Administration	Francis J. Halpin	Negative
5	BrightSource Energy, Inc.	Chifong Thomas	Abstain
5	Caithness Long Island, LLC	Jason M Moore	Abstain
5	Chelan County Public Utility District #1	John Yale	Abstain
5	City and County of San Francisco	Daniel Mason	Abstain
5	City of Austin dba Austin Energy	Jeanie Doty	Affirmative
5	City of Redding	Paul Cummings	Affirmative
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick	Negative
5	City of Tallahassee	Brian Horton	
5	City Water, Light & Power of Springfield	Steve Rose	Affirmative
5	Cleco Power	Stephanie Huffman	Negative

5	Cogentrix Energy, Inc.	Mike D Hirst	Affirmative
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Negative
5	Constellation Power Source Generation, Inc.	Amir Y Hammad	Abstain
5	Consumers Energy Company	David C Greyerbiehl	
5	Cowlitz County PUD	Bob Essex	Affirmative
5	CPS Energy	Robert Stevens	
5	Detroit Edison Company	Christy Wicke	Affirmative
5	Dominion Resources, Inc.	Mike Garton	Abstain
5	Duke Energy	Dale Q Goodwine	Negative
5	Dynegy Inc.	Dan Roethemeyer	Abstain
5	E.ON Climate & Renewables North America, LLC	Dana Showalter	
5	Edison Mission Energy	Ellen Oswald	
5	Electric Power Supply Association	John R Cashin	
5	Exelon Nuclear	Michael Korchynsky	Negative
5	ExxonMobil Research and Engineering	Martin Kaufman	Negative
5	FirstEnergy Solutions	Kenneth Dresner	Affirmative
5	Florida Municipal Power Agency	David Schumann	Negative
5	Gainesville Regional Utilities	Karen C Alford	
5	Great River Energy	Preston L Walsh	Negative
5	Green Country Energy	Greg Froehling	
5	Imperial Irrigation District	Marcela Y Caballero	Affirmative
5	Indeck Energy Services, Inc.	Rex A Roehl	
5	JEA	John J Babik	Affirmative
5	Kissimmee Utility Authority	Mike Blough	Negative
5	Lakeland Electric	James M Howard	
5	Liberty Electric Power LLC	Daniel Duff	
5	Lincoln Electric System	Dennis Florom	Affirmative
5	Los Angeles Department of Water & Power	Kenneth Silver	Affirmative
5	Lower Colorado River Authority	Tom Foreman	
5	Luminant Generation Company LLC	Mike Laney	Affirmative
5	Manitoba Hydro	S N Fernando	Negative
5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Abstain
5	MEAG Power	Steven Grego	Affirmative
5	MidAmerican Energy Co.	Christopher Schneider	Negative
5	Muscatine Power & Water	Mike Avesing	Negative
5	Nebraska Public Power District	Don Schmit	Abstain
5	New York Power Authority	Gerald Mannarino	Affirmative
5	NextEra Energy	Allen D Schriver	Negative
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Negative
5	Northern California Power Agency	Hari Modi	Affirmative
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative
5	Occidental Chemical	Michelle R DAntuono	Affirmative
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative

5	Orlando Utilities Commission	Richard Kinias	
5	Pacific Gas and Electric Company	Richard J. Padilla	Affirmative
5	PacifiCorp	Sandra L. Shaffer	Abstain
5	Platte River Power Authority	Roland Thiel	Abstain
5	Portland General Electric Co.	Gary L Tingley	Affirmative
5	PowerSouth Energy Cooperative	Tim Hattaway	Abstain
5	PPL Generation LLC	Annette M Bannon	Affirmative
5	Progress Energy Carolinas	Wayne Lewis	Negative
5	PSEG Fossil LLC	Tim Kucey	Abstain
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative
5	Puget Sound Energy, Inc.	Tom Flynn	Negative
5	Sacramento Municipal Utility District	Bethany Hunter	Abstain
5	Salt River Project	William Alkema	Affirmative
5	Santee Cooper	Lewis P Pierce	Negative
5	Seattle City Light	Michael J. Haynes	Abstain
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins	Affirmative
5	Siemens PTI	Edwin Cano	
5	Snohomish County PUD No. 1	Sam Nietfeld	Affirmative
5	South Mississippi Electric Power Association	Jerry W Johnson	
5	Southern California Edison Co.	Denise Yaffe	
5	Southern Company Generation	William D Shultz	Negative
5	Tampa Electric Co.	RJames Rocha	Affirmative
5	Tenaska, Inc.	Scott M. Helyer	Abstain
5	Tennessee Valley Authority	David Thompson	Abstain
5	Tri-State G & T Association, Inc.	Barry Ingold	Affirmative
5	U.S. Army Corps of Engineers	Melissa Kurtz	
5	Vandolah Power Company L.L.C.	Douglas A. Jensen	
5	Xcel Energy, Inc.	Liam Noailles	
6	ACES Power Marketing	Jason L Marshall	Abstain
6	AEP Marketing	Edward P. Cox	Abstain
6	Ameren Energy Marketing Co.	Jennifer Richardson	Negative
6	APS	RANDY A YOUNG	Affirmative
6	Arkansas Electric Cooperative Corporation	Keith Sugg	
6	Bonneville Power Administration	Brenda S. Anderson	Negative
6	City of Austin dba Austin Energy	Lisa L Martin	Affirmative
6	City of Redding	Marvin Briggs	Affirmative
6	Cleco Power LLC	Robert Hirchak	Negative
6	Colorado Springs Utilities	Lisa C Rosintoski	Affirmative
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Negative
6	Constellation Energy Commodities Group	Brenda Powell	
6	Dominion Resources, Inc.	Louis S. Slade	Abstain
6	Duke Energy Carolina	Walter Yeager	
6	Entergy Services, Inc.	Terri F Benoit	Negative
6	Exelon Power Team	Pulin Shah	
6	FirstEnergy Solutions	Kevin Query	Affirmative

6	Florida Municipal Power Agency	Richard L. Montgomery	Negative
6	Florida Municipal Power Pool	Thomas Washburn	Negative
6	Florida Power & Light Co.	Silvia P. Mitchell	Abstain
6	Imperial Irrigation District	Cathy Bretz	Affirmative
6	Kansas City Power & Light Co.	Jessica L Klinghoffer	
6	Lakeland Electric	Paul Shipps	Negative
6	Lincoln Electric System	Eric Ruskamp	Affirmative
6	Los Angeles Department of Water & Power	Brad Packer	
6	Luminant Energy	Brad Jones	Affirmative
6	Manitoba Hydro	Daniel Prowse	Negative
6	MidAmerican Energy Co.	Dennis Kimm	Abstain
6	New York Power Authority	William Palazzo	Affirmative
6	North Carolina Municipal Power Agency #1	Matthew Schull	Abstain
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative
6	Omaha Public Power District	David Ried	Affirmative
6	Orlando Utilities Commission	Claston Augustus Sunanon	
6	PacifiCorp	Scott L Smith	Abstain
6	Platte River Power Authority	Carol Ballantine	Abstain
6	PPL EnergyPlus LLC	Mark A Heimbach	Affirmative
6	Progress Energy	John T Sturgeon	Negative
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Abstain
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen	Abstain
6	Sacramento Municipal Utility District	Diane Enderby	Abstain
6	Salt River Project	Steven J Hulet	Affirmative
6	Santee Cooper	Michael Brown	Negative
6	Seattle City Light	Dennis Sismaet	Affirmative
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak	
6	Snohomish County PUD No. 1	William T Moojen	
6	South California Edison Company	Lujuanna Medina	
6	Southern Company Generation and Energy Marketing	John J. Ciza	Negative
6	Tacoma Public Utilities	Michael C Hill	
6	Tampa Electric Co.	Benjamin F Smith II	
6	Tennessee Valley Authority	Marjorie S. Parsons	Abstain
6	Westar Energy	Grant L Wilkerson	Negative
6	Western Area Power Administration - UGP Marketing	Peter H Kinney	Affirmative
6	Xcel Energy, Inc.	David F. Lemmons	
8		Edward C Stein	Affirmative
8		Roger C Zaklukiewicz	Affirmative
8		James A Maenner	
8	APX	Michael Johnson	Affirmative
8	JDRJC Associates	Jim Cyrulewski	Affirmative
8	Power Energy Group LLC	Peggy Abbadini	
8	Utility Services, Inc.	Brian Evans-Mongeon	Abstain



8	Volkman Consulting, Inc.	Terry Volkman	Negative
9	California Energy Commission	William M Chamberlain	Abstain
9	Central Lincoln PUD	Bruce Lovelin	Affirmative
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	Negative
10	Midwest Reliability Organization	James D Burley	
10	New York State Reliability Council	Alan Adamson	Negative
10	Northeast Power Coordinating Council	Guy V. Zito	Abstain
10	ReliabilityFirst Corporation	Anthony E Jablonski	Negative
10	SERC Reliability Corporation	Carter B Edge	Abstain
10	Southwest Power Pool RE	Emily Pennel	Affirmative
10	Texas Reliability Entity, Inc.	Donald G Jones	Affirmative
10	Western Electricity Coordinating Council	Steven L. Rueckert	Abstain

**Name (59 Responses)**  
**Organization (59 Responses)**  
**Group Name (28 Responses)**  
**Lead Contact (28 Responses)**  
**Question 1 (76 Responses)**  
**Question 1 Comments (87 Responses)**  
**Question 2 (77 Responses)**  
**Question 2 Comments (87 Responses)**  
**Question 3 (62 Responses)**  
**Question 3 Comments (87 Responses)**  
**Question 4 (0 Responses)**  
**Question 4 Comments (87 Responses)**

Individual
Brian Evans-Mongeon
Utility Services
Yes
While agreeing with the change, confusion may exist with the CAN that exists for the term "Annual". Utility Services suggests that the language be changed to "Every calendar year" or something equivalent. Given everything that transpired in the discussion on the term annual, using a different phrase may be advantageous.
Yes
Yes
There are no other comments at this time.
Individual
E Hahn
MWDSC
No
Tranmsission Owners (TO) should not be included as a "Responsible Entity" for this or other requirements because the Operating Plan is usually prepared by the Transmission Operator (TOP). For TOs who are not also TOPs, there are usually delegation agreements. CIP-001 never directly applied to TOs.
No
See comment for question 1
Individual
Scott McGough
Georgia System Operations Corporation
Yes
No
See comments under no. 4 below.
Yes
a) Reporting most of these items ... • Does not "provide for reliable operation of the BES" • Does not include "requirements for the operation of existing BES facilities" • Is not necessary to "provide for reliable operation of the BES" ... and is therefore not in accordance with the statutory and regulatory definitions of a Reliability Standard. They should not be in a Reliability Standard. Most of this is an

administrative activity to provide information for NERC to perform some mandated analysis. b) A reportable Cyber Security Incident: Delete this item from the table. It is covered in another standard and does not need to be duplicated in another standard. c) Damage or destruction of a Facility: Entities MAY only need to slightly modify their existing CIP-001 Sabotage Reporting procedures from a compliance perspective of HAVING an Operating Plan but not from a perspective of complying with the Plan. A change from an entity reporting "sabotage" on "its" facilities (especially when the common understanding of CIP-001 is to report sabotage on facilities as "one might consider facilities in everyday discussions") to reporting "damage on its Facilities" (as defined in the Glossary) is a significant change. An operator does not know off the top of his head the definition of Facility or Element. He will not know for any particular electrical device whether or not reporting is required. Although the term is useful for legal and regulatory needs, it is problematic for practical operational needs. This creates the need for a big change in guidance, training, and tools for an operator to know which pieces of equipment this applies to. There is the need to translate from NERC-ese to Operator-ese. Much more time is needed to implement. The third threshold ("Results from actual or suspected intentional human action") perpetuates the problem of knowing the human's intention. Also, what if the action was intended but the result was not intended? The third threshold is ambiguous and subject to interpretation. The original intent of this project was to get away from the problem of the term sabotage due to its ambiguity and subjectivity. This latest change reverses all of the work so far toward that original goal. Instead of the drafted language, change this item to reporting "Damage or destruction of a Facility and any involved human action" and use only the first two threshold criteria. d) Any physical threat that could impact the operability of a Facility: See comment above about the term "Facility" and the need for a much longer implementation time. e) Transmission loss: This item is very unclear. What is meant by "loss?" Above, it says to report damage or destruction of a Facility. This says to report the loss of 3 Facilities. Is the intent here to report when there are 3 or more Facilities that are unintentionally and concurrently out of service for longer than a certain threshold of time? The intent should not be to include equipment failure? Three is very arbitrary. An entity with a very large footprint with a very large number of electrical devices is highly likely to have 3 out of service at one time. An entity with very few electrical devices is less likely to have 3. Delete the word Transmission. It is somewhat redundant. A Facility is BES Element. I believe all BES Elements are Transmission Facilities. A Facility operates as a single "electrical device." What if more than 3 downstream electrical devices are all concurrently out of service due to the failure of one upstream device? Would that meet the criteria? A situation meeting the criteria will be difficult to detect. Need better operator tools, specific procedures for this, training, and more implementation time. f) The implementation plan says current version stays in effect until accepted by ALL regulatory authorities but it also says that the new version takes effect 12 months after the BOT or the APPLICABLE authorities accept it. It is possible that ONE regulatory authority will not accept it for 13 months and both versions will be in effect. It is also possible for ALL regulatory authorities to accept it at the same time, the current version to no longer be in effect, but the new version will not be in effect for 12 months.

Group

Northeast Power Coordinating Council

Guy Zito

No

Regarding Requirement R3, add the following wording from Measure M3 to the end of R3 after the wording "in Part 1.2.": The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Regarding Requirement R4, replace the words "an annual review" with the words "a periodic review." Add the following to R4: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years. This does not preclude an annual review in an Entity's operating plan. The Entity will then be audited to its plan. If the industry approves a five (5) year periodic review 'cap', and FERC disagrees, then FERC will have to issue a directive, state it reasons and provide justification for an annual review that is not arbitrary or capricious. Adding the one year "test" requirement adds to the administrative tracking burden and adds no reliability value.

No

Regarding Attachment 1, language identical to event descriptions in the NERC Event Analysis Process and FERC OE-417 should be used. Creating a third set of event descriptions is not helpful to system

operators. Recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible. The following pertains to Attachment 1: Replace the Attachment 1 "NOTE" with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity's Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required. The proposed "events" are subjective and will lead to confusion and questions as to what has to be reported. Event: A reportable Cyber Security Incident. All reportable Cyber Security Incidents may not require "One Hour Reporting." A "one-size fits all" approach may not be appropriate for the reporting of all Cyber Security Incidents. The NERC "Security Guideline for the Electricity Sector: Threat and Incident Reporting" document provides time-frames for Cyber Security Incident Reporting. For example, a Cyber Security Compromise is recommended to be reported within one hour of detection, however, Information Theft or Loss is recommended to be reported within 48 hours. Recommend listing the Event as "A confirmed reportable Cyber Security Incident. The existing NERC "Security Guideline for the Electricity Sector: Threat and Incident Reporting" document uses reporting time-frames based on "detection" and "discovery." Recommend using the word confirmed because of the investigation time that may be required from the point of initial "detection" or "discovery" to the point of confirmation, when the compliance "time-clock" would start for the reporting requirement in EOP-004-2. Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read: Results from actual or suspected intentional human action, excluding unintentional human errors. Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word "could" is hypothetical and therefore unverifiable and un-auditable. The word "impact" is undefined. Please delete this reporting requirement, or provide a list of hypothetical "could impact" events, as well as a specific definition and method for determining a specific physical impact threshold for "could impact" events other than "any." Event: BES Emergency requiring public appeal for load reduction. Replace wording in the Event column with language from #8 on the OE-417 Reporting Form to eliminate reporting confusion. Following this sentence add, "This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event." Event: Complete or partial loss of monitoring capability Event wording: Delete the words "or partial" to conform the wording to the NERC Event Analysis Process. Event: Transmission Loss Revise to BES Transmission Loss Event: Generation Loss Revise to BES Generation Loss

No

The proposed new section does not contain specifics of the proposed system nor the interfacing outside of the system to support the report collecting.

The proposed standard is not consistent with NERC's new Risk Based Compliance Monitoring. a. The performance based action to "implement its event reporting Operating Plan" on defined events, as required in R2, could be considered a valid requirement. However, the concern is that this requirement could be superseded by the NERC Events Analysis Process and existing OE-417 Reporting. b. The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. However, controls should not be part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting is redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules. Form EOP-004, Attachment 2: Event Reporting Form: Delete from the Task column the words "or partial". Delete from the Task column the words "physical threat that could impact the operability of a Facility". VSL's may have to be revised to reflect revised wording.

Individual

Don Jones

Texas Reliability Entity

Yes

No

(1) In the Events Table, consider whether the item for "Voltage deviation on Facility" should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator or power system stabilizer) could have a similar impact on the BES as other reportable items. Note: We made this comment last time, and the SDT's posted response was non-responsive to this concern. (2) In the Events Table, under Transmission Loss, the SDT indicated that reporting is triggered only if three or more Transmission Facilities operated by a single TOP are lost. What if four Facilities are lost, with two Facilities operated by each of two TOPs? That is a larger event than three Facilities lost by one TOP, but there is no reporting requirement? Determining event status by facility ownership is not an appropriate measure. The reporting requirements should be based on the magnitude, duration, or impact of the event, and not on what entities own or operate the facilities. (3) In the Events Table, under Transmission Loss, the criteria "loss of three or more Transmission Facilities" is very indefinite and ambiguous. For example, how will bus outages be considered? Many entities consider a bus as a single "Facility," but loss of a single bus may impact as many as six 345kV transmission lines and cause a major event. It is not clear if this type of event would be reportable under the listed event threshold? Is the single-end opening of a transmission line considered as a loss of a Facility under the reporting criteria? (4) Combinations of events should be reportable. For example, a single event resulting in the loss of two Transmission Facilities (line and transformer) and a 950 MW generator would not be reportable under this standard. But loss of two lines and a transformer, or a 1000 MW generator, would be reportable. It is important to capture all events that have significant impacts. (5) In the Events Table, under "Unplanned control center evacuation," "Loss of all voice communication capability" and "Complete or partial loss of monitoring capability," GOPs should be included. GOPs also operate control centers that are subject to these kinds of occurrences, with potentially major impacts to the BES. Note that large GOP control centers are classified as "High Impact" facilities in the CIP Version 5 standards, and a single facility can control more than 10,000 MW of generation. (6) The "BES Emergency resulting in automatic firm load shedding" event row within Attachment 1 should include the BA as a responsible entity for reporting. Note that EOP-003-1 requires the BA to shed load in emergency situations (R1, R5 as examples), and any such occurrence should be reported.

(1) The ERO and Regional Entities should not be included in the Applicability of this standard. The only justification given for including them was they are required to comply with CIP-008. CIP-008 contains its own reporting requirements, and no additional reliability benefit is provided by including ERO and Regional Entities in EOP-004. Furthermore, stated NERC policy is to avoid writing requirements that apply to the ERO and Regional Entities, and we do not believe there is any sufficient reason to deviate from that policy in this standard. (2) Under Compliance, in section 1.1, all the words in "Compliance Enforcement Authority" should be capitalized. (3) Under Evidence Retention, it is not sufficient to retain only the "date change page" from prior versions of the Plan. It is not unduly burdensome for the entity to retain all prior versions of its "event reporting Operating Plan" since the last audit, and it should be required to do so. (What purpose is supposed to be served by retaining only the "date change pages"?) (4) The title of part F, "Interpretations," is incorrect on page 23. Should perhaps be "Associated Documents."

Group
Arizona Public Service Company
Janet Smith, Regulatory Affairs Supervisor
Yes
Yes
Yes
None
Individual
Jonathan Appelbaum
United Illuminating Company
Yes

R3 should be clear that the annual test of the plan does not mean each communication path for each applicable event on an annual basis.

Yes

The phrasing of the event labeled as Event Damage or Destruction of a Facility may be improved in the Threshold for Reporting Column. Suggest the introduction sentence for this event should be phrased as Where the Damage or Destruction of a Facility: etc. The rationale for the change is that as written it is unclear if the list that follows is meant to modify the word Facilities or the overall introductory sentence. The confusion being caused by the word That. What is important to be reported is if a Facility is damaged and then an IROL is affected it should be reported, not that if a Facility is comprising an IROL Facility is damaged but there is no impact on the IROL. Second, the top of each table is the phrase Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event. This creates the requirement that the actual form is required to be transmitted to parties other than NERC/DOE. The suggested revision is Submit EOP-004 Attachment 2 or DOE-OE-417 report to NERC and/or DOE, and complete notification to other organizations identified pursuant to Requirement R1 Part 1.2 within one hour etc..

The measures M3 and M4 require evidence to be dated and time stamped. The time stamp is excessive and provides no benefit. A dated document is sufficient. The measure M2 requires in addition to a record of the transmittal of the EOP-004 Attachment 2 form or DOE-417 form that an operator log or other operating documentation is provided. It is unclear why this supplemental evidence of operator logs is required. We are assuming that the additional operator logs or documentation is required to demonstrate that the communication was completed to organizations other than NERC and DOE of the event. If true then the measure should be clear on this topic. For communication to NERC and DOE use the EOP-004 Form or OE-417 form and retain the transmittal record. For communication to other organizations pursuant to R1 Part 1.2 evidence may include but not limited to, operator logs, transmittal record, attestations, or voice recordings.

Individual

Dan Roethemeyer

Dynegy Inc.

Yes

Yes

Use of the term "Part x.x" throughout the Standard is somewhat confusing. I can't recall other Standards using that type of term. Suggest using the term "Requirement" instead.

Individual

Anthony Jablonski

ReliabilityFirst

ReliabilityFirst votes in the Affirmative for this standard because the standard further enhances reliability by clearing up confusion and ambiguity of reporting events which were previously reported under the EOP-004-1 and CIP-001-1 standards. Even though ReliabilityFirst votes in the Affirmative, we offer the following comments for consideration: 1. Requirement R1, Part 1.2 a. ReliabilityFirst recommends further prescribing whom the Responsible Entity needs to communicate with. The phrase "... and other organizations needed for the event type..." in Part 1.2 essentially leaves it up to the Responsible Entity to determine (include in their process) whom they should communicate each applicable event to. ReliabilityFirst recommends added a fourth column under Attachment 1, which lists whom the Responsible Entity is required to communicate with, for each applicable event. 2. VSL for Requirement R2 a. Requirement R2 requires the Responsible Entity to "implement its event reporting Operating Plan" and does not require the entity to submit a report. For consistency with the requirement, ReliabilityFirst recommends modifying the VSLs to begin with the following type of

language: "The Responsible Entity implemented its event reporting Operating Plan more than 24 hours but..." This recommendation is based on the FERC Guideline 3, VSL assignment should be consistent with the corresponding requirement and should not expand on, nor detract from, what is required in the requirement.

Individual

Joe Petaski

Manitoba Hydro

No

(R1.1 and 1.2) It is unclear whether or not R1.1 and R1.2 require a separate recognition and communication process for each of the event types listed in Attachment 1 or if event types can be grouped as determined appropriate by the responsible entity given that identical processes will apply for multiple types of events. Manitoba Hydro suggests that wording is revised so that multiple event types can be addressed by a single process as deemed appropriate by the Responsible Entity. (R3) It is unclear whether or not R3 requires the testing of the communications process for each separate event type identified in Attachment 1. If so, this would be extremely onerous. Manitoba Hydro suggests that only unique communication processes (as identified by the Responsible Entity in R1.2) require an annual test and that testing should not be required for each type of event listed in Attachment 1. As well, Manitoba Hydro believes that testing the communications process alone is not as effective as also providing training to applicable personnel on the communications process. Manitoba Hydro suggests that R3 be revised to require annual training to applicable personnel on the communications process and that only 1 test per unique communications process be required annually.

Yes

Yes

Yes

Manitoba Hydro is voting negative on EOP-004-2 for the reasons identified in our response to Question 1. In addition, Manitoba Hydro has the following comments: (Background section) - The section has inconsistent references to EOP-004 (eg. EOP-004 and EOP-004-2 are used). Wording should be made consistent. (Background section) – The section references entities, and responsible entities. Suggest wording is made consistent and changed to Responsible Entities. (General comment) – References in the standard to 'Part 1.2' should be changed to R1.2 as it is unclear if Part 1.2 refers to, for example, R1.2 or part 1.2 'Evidence Retention'. (M4) –Please clarify what is meant by 'date change page'.

Individual

Michelle R. D'Antuono

Ingleside Cogeneration LP

Yes

Ingleside Cogeneration LP agrees that it is appropriate to test reporting communications on an annual basis, primarily to validate that phone numbers, email ids, and contact information is current. We appreciate the project team's elimination of the terms "exercise" and "drill", which we believe connotes a formalized planning and assessment process. An annual review of the Operating Plan implies a confirmation that linkages to sub-processes remain intact and that new learnings are captured. We also agree that it is appropriate only to require an updated Revision Level Control chart entry as evidence of compliance – it is very likely that no updates are required after the review is complete. In our view, both of these requirements are sufficient to assure an effective assessment of all facets of the Operating Plan. As such, we fully agree with the project team's decision to delete the requirement to update the plan within 90 days of a change. In most cases, our internal processes will address the updates much sooner, but there is no compelling reason to include it as an enforceable requirement.

Yes

Ingleside Cogeneration LP agrees with the removal of nearly all one hour reporting requirements. In our view there must be a valid contribution expected of the recipients of any reporting that takes place this early in the process. Any non-essential communications will impede the progress of the

front-line personnel attempting to resolve the issue at hand – which has to be the priority. Secondly, there is a risk that early reporting may include some speculation of the cause, which may be found to be incorrect as more information becomes available. Recipients must temper their reactions to account for this uncertainty. In fact, Ingleside Cogeneration LP recommends that the single remaining one-hour reporting scenario be eliminated. It essentially defers the reporting of a cyber security incident to CIP-008 anyways, and may even lead to a multiple violation of both Standards if exceeded.

Yes

Ingleside Cogeneration is encouraged by NERC's willingness to act as central data gathering point for event information. However, we see this only as a starting point. There are still multiple internal and external reporting demands that are similar to those captured in EOP-004-2 – examples include the DOE, RAPA (misoperations), EAWG (events analysis), and ES-ISAC (cyber security). Although we appreciate the difference in reporting needs expressed by each of these organizations, there are very powerful reporting applications available which capture a basic set of data and publish them in multiple desirable formats. We ask that NERC spearhead this initiative – as it is a natural part of the ERO function.

Ingleside Cogeneration LP strongly believes that LSEs that do not own BES assets should be excluded from the Applicability section of this standard.

Group

DECo

Kent Kujala

No

Should only have annual "review" requirement rather than test.

No

On pg 17 in the Rationale Box for EOP-004 Attachment 1: The set of terms is specific then includes the word ETC. Then further lists areas to exclude. Then on Pg 23 of document it includes train derailment near a transmission right of way and forced entry attempt into a substation facility as reportable. These conflict. Also see conflict when in pg 21 states the DOE OE417 would be excepted in lieu of the NERC form, but on the last pg it states the DOE OE417 should be attached to the NERC report indicating the NERC report is still required.

Yes

Requirement R3 for annual test specifically states that ERO is not included during test. Implies that local law enforcement or state law enforcement will be included in test. Hard to coordinate with many Local organizations in our area.

Individual

Tim Soles

Occidental Power Services, Inc.

No

There should be an exception for LSEs with no BES assets from having an Operating Plan and, therefore, from testing and review of such plan. These LSEs have no reporting responsibilities under Attachment 1 and, if they have nothing ever to report, why would they have to have an Operating Plan and have to test and review it? This places an undue burden on small entities that cannot impact the BES.

No

There are no requirements in Attachment 1 for LSEs without BES assets so these entities should not be in the Applicability section.

No

This section should reference the confidentiality requirements in the ROP and should have a statement about the system for collection and dissemination of disturbance reports being "subject to the confidentiality requirements of the NERC ROP."

OPSI continues to believe that LSEs that do not own BES assets should be excluded from the Applicability section of this standard. It is disingenuous of both the SDT and FERC to promote an



argument to support this inclusion such as that stated in Section 459 of Order 693 (and referred to by the SDT in their Consideration of Comments in the last posting). The fact is that no reportable disturbance can be caused by an "attack" on an LSE that does not own BES assets. The SDT has yet to point out such an event.

Individual

Alice Ireland

Xcel Energy

No

1) In R1.2, We understand what the drafting team had intended here. However, we are concerned that the way this requirement is drafted, using i.e., it could easily be interpreted to mean that you must notify all of those entities listed. Instead, we are suggesting that the requirement be rewritten to require entities to define in their Operating Plan the minimum organizations/entities that would need to be notified for applicable events. We believe this would remove any ambiguity and make it clear for both the registered entity and regional staff. We recommend the requirement read something like this: 1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to applicable internal and external organizations needed for the event type, as defined in the Responsible Entity's Operating Plan. 2) We also suggest that R3 be clarified as to whether communications to all organizations must be tested or just those applicable to the test event type/scenario.

No

1) The event Damage or destruction of a Facility appears to need 'qualifying'. Is this intended for only malicious intent? Otherwise, weather related or other operational events will often meet this criteria. For example adjustment in generation or changes in line limits to "avoid an Adverse Reliability Impact" could occur during a weather related outage. We suggest adjusting this event and criteria to clearly exclude certain items or identify what is included. 2) Also recommend placing the information in footnote 1 into the associated Threshold for Reporting column, and removing the footnote.

We believe such a tool would be useful, however we are indifferent as to if it is required to be established by the Rules of Procedure.

Xcel Energy appreciates the work of the drafting team and believes the current draft is an improvement over the existing standard. However, we would like to see the comments provided here and above addressed prior to submitting an AFFIRMATIVE vote. 1) Suggest enhancing the "Example of Reporting Process..." flowchart as follows: EVENT > Refer to Ops Plan for Event Reporting > Refer to Law Enforcement? > Yes/No > .... 2) Attachment 1 – in both the 1 hour and the 24 hour reporting they are qualified with "within x hours of recognition of the event". Is this the intent, so that if an entity recognizes at some point after an event that the time clock starts? 3) VSLs – R3 & R4 "Severe" should remove the "OR...", as this is redundant. Once an entity has exceeded the 3 calendar months, the Severe VSL is triggered. 4) The Guideline and Technical Basis page 22 should be corrected to read "The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting." 5) Also in the following section of the Guideline and Technical Basis (page 23) the third bullet item should be qualified to exclude copper theft: Examples of such events include: • Bolts removed from transmission line structures • Detection of cyber intrusion that meets criteria of CIP-008-3 or its successor standard • Forced intrusion attempt at a substation (excluding copper theft) • Train derailment near a transmission right-of-way • Destruction of Bulk Electric System equipment

Group

Duke Energy

Greg Rowland

No

Under R3, we agree with testing communications internally. Just as the ERO is excluded under R3, other external entities should also be excluded. External communications should be verified under R4.

No

(1)We disagree with reporting CIP-008 incidents under this standard. We agree with the one-hour notification timeframe, but believe it should be in CIP-008 to avoid double jeopardy. (2)Damage or

destruction of a Facility – Need clarity on how a vertically integrated entity must report. For example a GOP probably won't know if an IROL will be affected. Also, there shouldn't be multiple reports from different functional entities for the same event. Suggest splitting this table so that GO, GOP, DP only reports "Results from actual or suspected intentional human action". (3) Generation Loss – Need more clarity on the threshold for reporting. For example if we lose one 1000 MW generator at 6:00 am and another 1000 MW generator at 4:00 pm, is that a reportable event?

Yes

Group

Luminant

Brenda Hampton

Yes

No

Luminant appreciates the work of the DSR SDT to modify Attachment 1 to address the concerns of the stakeholders. However, we are concerned that the threshold for reporting a Generation Loss in the ERCOT interconnection established by this revision is set at  $\geq 1,000\text{MW}$ , which is not consistent with the level of single generation contingency used in ERCOT planning and operating studies. That level of contingency is currently set at the size of the largest generating unit in ERCOT, which is 1,375MW. For this reason, Luminant believes that the minimum threshold for reporting of a disturbance should be  $> 1,375\text{MW}$  for the ERCOT Interconnection.

Yes

Group

BC Hydro

Patricia Robertson

Yes

No

BC Hydro supports the revisions to EOP-004 and would vote Affirmative with the following change. Attachment 1 has a One Hour Reporting requirement. BC Hydro proposes a One Hour Notification with the Report submitted within a specified timeframe afterward.

Individual

Andrew Gallo

City of Austin dba Austin Energy

Yes

Austin Energy (AE) supports the requirements for (1) an annual test of the communications portion of the Operating Plan (R3) and (2) an annual review of the Operating Plan (R4); however, we offer a slight modification to the measures associated with those requirements. AE does not believe that records evidencing such test and reviews need to be time-stamped to adequately demonstrate compliance with the requirements. In each case, we recommend that the first sentence of M3 and M4 start with "Each Responsible Entity will have dated records to show that the annual ..."

Yes

Austin Energy makes the following comments: (1) Comment on the Background section titled "A Reporting Process Solution – EOP-004": This section includes the sentence, "Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state OR PROVINCIAL

OR LOCAL level law enforcement agency." (emphasis added) The corresponding flowchart includes a step, "Notification Protocol to State Agency Law Enforcement." Austin Energy requests that the SDT update the flowchart to match the language of the associated paragraph and include "state or provincial or local" agencies. (2) Comments on VSLs: Austin Energy recommends that the SDT amend the VSLs for R2 to include the "recognition of" events throughout. That is, update the R2 VSLs to state "... X hours after "recognizing" an event ..." in all locations where the phrase occurs. (3) Austin Energy has a concern with the inclusion of the word "damage" to the phrase "damage or destruction of a Facility." We agree that any "destruction" of a facility that meets any of the three criteria be a reportable event. However, if the Standard is going to include "damage," some objective definition for "damage" (that sets a floor) ought to be included. Much like the copper theft issue, we do not see the benefit of reporting to NERC vandalism that does not rise to a certain threshold (e.g. someone who takes a pot shot at an insulator) unless the damage has some tangible impact on the reliability of the BES or is an act of an orchestrated sabotage (e.g. removal of a bolt in a transmission structure). (4) Austin Energy voted to approve the revised Standard because it is an improvement over the existing Standard. In light of FERC's comments in Paragraph 81 of the Order approving the Find, Fix, Track and Report initiative, however, Austin Energy would propose that this Standard is the type of Standard that does not truly enhance reliability of the BES and is, instead, an administrative activity. As such, we recommend that NERC consider whether EOP-004-2 ought to be retired.

Group

Bonneville Power Administration

Chris Higgins

Yes

BPA believes that the annual testing and review as described in R3 is too cumbersome and unnecessary for entities with large footprints to inundate federal and local enforcement bodies such as the FBI for "only" testing and the documenting for auditing purposes. BPA suggests that testing be performed on a bi-annual or longer basis.

No

BPA believes that clarifying language should be added to transmission loss event. (Page 19) [a report should not be required if the number of elements is forced because of pre-designed or planned configuration. System studies have to take such a configuration into account possible wording could be. Unintentional loss of three or more Transmission Facilities (excluding successful automatic reclosing or planned operating configuration)] In addition, under the "Event" of Complete or partial loss of monitoring capability, BPA believes that "partial loss" is not sufficiently specific for BPA to write compliance operating procedures and suggest defining partial loss or removing it from the standard. Should the drafting team add clarifying language to remove "or partial loss" and address BPA's concerns on over emphasis on software tool to the operation of the system. BPA would change its negative position to affirmative.

Yes

BPA believes that the VSL should allow for amending the form after a NERC specified time period without penalty and suggests that a window of 48 hours be given to amend the form to make adjustments without needing to file a self report. Should the standard be revised to allow a time period for amending the form without having to file a self report, BPA would change its negative position to affirmative.

Individual

Thad Ness

American Electric Power

No

R3: How many different scenarios need to be tested? For example, reporting sabotage-related events might well be different than reporting reliability-related events such as those regarding loss of Transmission. While these examples might vary a great deal, other such scenarios may be very similar in nature in terms of communication procedures. Perhaps solely testing the most complex procedure would be sufficient. AEP agrees with the changes with R3 calling for an annual test provided the requirement R2 is modified to include the measure language "The annual test requirement is considered to be met if the responsible entity implements the communications process

in Part 1.2 for an actual event.” M3: While we agree that “the annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event”, we believe it would be preferable to include this text in R3 in addition to M3. Measures included in earlier standards (some of which are still enforced today) had little correlation to the requirement itself, and as a result, those measures were seldom referenced. M3: It would be unfair to assume that every piece of evidence required to prove compliance would be dated and time-stamped, so we recommend removing the text “dated and time-stamped” from the first sentence so that it reads “Each Responsible Entity will have records to show that the annual test of Part 1.2 was conducted.” The language regarding dating and time stamps in regards to “voice recordings and operating logs or other communication” is sufficient.

No

If CIP-008 is now out of scope within the requirements of this standard, any references to it should also be removed from Attachment 1. The Threshold for Reporting column on page 26 includes “Results from actual or suspected intentional human action.” This wording is too vague as many actions by their very nature are intentional. In addition, it should actually be used as a qualifying event rather than a threshold. We recommend removing it entirely from the Threshold column, and placing it in the Events column and also replacing the first row as follows: “Actual or suspected intentional human action with the goal of damage to, or destruction of, the Facility.” On page 27, the event “Any physical threat that could impact the operability of a Facility” is too vague and broad. Using the phrases “any physical threat” and “could impact” sets too high a bar on what would need to be reported. On page 28, for the event “Complete loss of off-site power to a nuclear generating plant (grid supply)”, TO and TOP should be removed and replaced by GOP.

Yes

While we have no objections at this point, we would like specific details on what our obligations would be as a result of these changes. For example, would the clearinghouse tool provide verifications that the report(s) had been received as well as forwarded? In addition, if DOE OE-417 is the form being submitted, would the NERC Reporting Clearinghouse forward that report to the DOE?

While we do not necessarily disagree with modifying this standard, we do have serious concerns with the possibility that Form OE-417 form would not also be modified to match any changes made to this standard. To the degree they would be different, this would create unnecessary confusion and burden on operators. If CIP-008 is now out of scope within the requirements of this standard, the task “reportable Cyber Security Incident” should be removed from Attachment 2.

Individual

Ed Davis

Entergy

No

The requirement for a “time stamped record” of annual review is unreasonable and unnecessary. A dated document showing that a review was performed should be sufficient.

Yes

Entergy does not agree with the Time Horizon for R2. The rationale for R2 contains phrases related to situational awareness and keeping people/agencies aware of the “current situation.” However, this standard is related to after the fact event reporting, not real-time reporting via RCIS, as discussed on page 6 of the red-lined standard. Therefore the time horizon for R2 should indicate that this is an after the fact requirement expected to be performed either in 1 hour or 24 hours after an event occurs, not in the operations assessment time frame. This change should also be made on page 15 of the redline in the Table of compliance elements for R2. Page 18 of the redline document contains a VSL for R2 which states that it will be considered a violation if the Responsible Entity submitted a report in the appropriate timeframe but failed to provide all of the required information. It has long been the practice to submit an initial report and provide additional information as it becomes available. On page 24 of the redlined document, this is included in the following “...and provide as much information as is available at the time of the notification to the ERO...” But the compliance elements table now imposes that if the entity fails to provide ALL required information at the time the initial report is required, the entity will be non compliant with the standard. This imposes an

unreasonable burden to the Reliability Entity. This language should be removed. The compliance element table for R3 and R4 make it a high or severe violation to be late on either the annual test or the annual review of the Operating plan for communication. While Entergy supports that periodically verifying the information in the plan and having a test of the operating plan have value, it does not necessarily impose additional risk to the BES to have a plan that exceeds its testing or review period by two to three months. This is an administrative requirement and the failure to test or review should be a lower or moderate VSL, which would be consistent with the actual risk imposed by a late test or review. On page 24 of the redlined draft, there is a statement that says "In such cases, the affected Responsible Entity shall notify parties per Requirement R1 and provide as much information as if available at the time of the notification..." Since R1 is the requirement to have a plan, and R2 is the requirement to implement the plan for applicable events, it seems that the reference in this section should be to Requirement R2, not Requirement R1.

Individual

Jack Stamper

Clark Public Utilities

Yes

No

I agree with all but one. The event is "Damage or destruction of a Facility" and the threshold for reportin is "Results from actual or suspected intentional human action." I understand and agree that destruction of a facility due to actual or suspected intentional human action should always be reported. However, I do not know what level of damage should be reported. Obviously the term "damage" is meant to signify an event that is less than destruction. As a result, damage could be extensive, minimal, or hardly noticeable. There needs to be some measure of what the damage entails if the standard is to contain a broad requirement for the reporting of damage intentionally caused by human action. Whether that measure is based on the actual impacts to the BES from the damage or whether the measure is based on the ability of the damaged equipment to continue to function at 100%, 50% or some capability would be acceptable but currently it is too open ended.

Yes

Individual

Tracy Richardson

Springfield Utility Board

Yes

- SUB supports the removal of Requirement 1, Part 1.4, as well the separation of Parts 1.3 and 1.5, agreeing that they are their own separate actions.
- The Draft 4 Version History still lists the term "Impact Event" rather than "Event".

Yes

- Spell out Requirement 1, rather than "parties per R1" in NOTE.
- On page 44, "Examples of such events include" should say, "include, but are not limited to".
- SUB appreciates clarification regarding events, particularly the discussion regarding "sabotage", and recommends listing and defining "Event" in Definitions and Terms Used in NERC Standards.
- The Guideline and Technical Basis provides clarity, and SUB agrees with the removal of "NERC Guideline: Threat and Incident Reporting".
- In the flow chart on page 9 there are parallel paths going from "Refer to Ops Plan for Reporting" to the 'Report Event to ERO, Reliability Coordinator' via both the Yes and No response. It seems like the yes/no decision should follow after "Refer to Ops Plan" for communication to law enforcement.

Yes

- SUB supports the new Section 812 being incorporated into the NERC ROP. This addition provides clarity for what is required by whom and takes away any possible ambiguity.

SUB appreciates the opportunity to provide comments. While Staff was concerned with the consolidation of CIP and non-CIP NERC Reliability Standards (as to how they'll be audited), the Project 2009-01 SDT has done an excellent job in providing clarification around identifying and reporting events, particularly related to the varying definitions of "sabotage".

Individual
Wayne Sipperly
New York Power Authority
No
Please see comments submitted by NPCC Regional Standards Committee (RSC).
No
Please see comments submitted by NPCC Regional Standards Committee (RSC).
Yes
Please see comments submitted by NPCC Regional Standards Committee (RSC).
Individual
David Thorne
Pepco Holdings Inc
Yes
Yes
No
This could create confusion. This new ROP section states that "... the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary." Standard Section R1.2 states "A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies." If NERC is going to be the "clearinghouse" forwarding reports to the RE and DOE, does that mean that the reporting entity only needs to make a single submission to NERC for distribution? If the reporting entity is required to make all notifications, per R1.2, what is the purpose of NERC's duplication of sending out reports? It would be very helpful to the reporting entities if R1.2 was revised to state that NERC would forward the event form to the RE and DOE and the reporting entity would only be responsible for providing notice verbally to its associated BA, TOP, RC, etc. as appropriate and for notifying appropriate law enforcement as required.
The SDT's efforts have resulted in a very good draft.
Group
Imperial Irrigation District (IID)
Jesus Sammy Alcaraz
Yes
Yes
Yes
Individual
Chris de Graffenried
Consolidated Edison Co. of NY, Inc.
No
Requirement R3: Following the sentence ending "in Part 1.2" add the following wording from the Measure to R3: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Requirement R4: Replace

the words "an annual review" with the words "a periodic review." Following the first sentence in R4 add: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years.

No

General comment regarding Attachment 1: SDT should strive to use identical language to event descriptions in the NERC Event Analysis Process and FERC OE-417. Creating a third set of event descriptions is not helpful to system operators. We recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible. Replace the Attachment 1 "NOTE" with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity's Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required. Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read, Results from actual or suspected intentional human action, excluding unintentional human errors. Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word "could" is hypothetical and therefore unverifiable and un-auditable. The word "impact" is undefined. Please delete this reporting requirement, or please provide a list of hypothetical "could impact" events, as well as a specific definition and method for determining a specific physical impact threshold for "could impact" events other than "any." Event: BES Emergency requiring public appeal for load reduction. Replace Event wording with language from #8 on OE-417 reporting form to eliminate reporting confusion. Following this sentence add, "This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event." Event: Complete or partial loss of monitoring capability Event wording: Delete the words "or partial" to conform the wording to NERC Event Analysis Process. Event: Transmission Loss Modify to BES Transmission Loss Event Generation Loss Modify to BES Generation Loss

Yes

Form EOP-004, Attachment 2: Event Reporting Form: Delete the Task words "or partial." Delete the Task words "physical threat that could impact the operability of a Facility." Make any changes to the VSL's necessary to align them with the reviewed wording provided above.

Individual

David Burke

Orange and Rockland Utilities, Inc.

No

Requirement R3: Following the sentence ending "in Part 1.2" add the following wording from the Measure to R3: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Requirement R4: Replace the words "an annual review" with the words "a periodic review." Following the first sentence in R4 add: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years.

No

General comment regarding Attachment 1: SDT should strive to use identical language to event descriptions in the NERC Event Analysis Process and FERC OE-417. Creating a third set of event descriptions is not helpful to system operators. We recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible. Replace the Attachment 1 "NOTE" with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity's Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required. Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read, Results from actual or suspected intentional human action, excluding unintentional human errors. Event: Any physical threat

that could impact the operability of a Facility This Event category should be deleted. The word "could" is hypothetical and therefore unverifiable and un-auditable. The word "impact" is undefined. Please delete this reporting requirement, or please provide a list of hypothetical "could impact" events, as well as a specific definition and method for determining a specific physical impact threshold for "could impact" events other than "any." Event: BES Emergency requiring public appeal for load reduction. Replace Event wording with language from #8 on OE-417 reporting form to eliminate reporting confusion. Following this sentence add, "This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event." Event: Complete or partial loss of monitoring capability Event wording: Delete the words "or partial" to conform the wording to NERC Event Analysis Process. Event: Transmission Loss Modify to BES Transmission Loss Event Generation Loss Modify to BES Generation Loss

Yes

Form EOP-004, Attachment 2: Event Reporting Form: Delete the Task words "or partial." Delete the Task words "physical threat that could impact the operability of a Facility." Make any changes to the VSL's necessary to align them with the reviewed wording provided above.

Individual

Larry Raczkowski

FirstEnergy Corp

Yes

FE agrees with the revision but has the following comments and suggestions: 1. We request clarity and guidance on R3 (See our comments in Question 4 for further consideration). Also, we suggest a change in the phrase "shall conduct an annual test" to "shall conduct a test each calendar year, not to exceed 15 calendar months between tests". This wording is consistent with other standards in development such as CIP Version 5. 2. In R4 we suggest a change in the phrase "shall conduct an annual review" to "shall conduct a review each calendar year, not to exceed 15 calendar months between reviews". This wording is consistent with other standards in development such as CIP Version 5.

No

FE requests the following changes be made to Attachment 1: 1. Pg. 19 / Event: "Voltage deviation on a Facility". The term "observes" for Entity with Reporting Responsibility be changed to "experiences". The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. 2. In "Threshold for Reporting", the language should be expanded to – plus or minus 10% "of nominal voltage" for greater than or equal to 15 continuous minutes. 3. Pg.20 /Event: "Complete or partial loss of monitoring capability". The term "partial" should be deleted from the event description to read as follows: Complete loss of monitoring capability and the reporting responsibility requirements to read "Each RC, BA, and TOP that experiences the complete loss of monitoring capability."

Yes

FE agrees but asks that the defined term "registered entities" in the second sentence be capitalized.

FE supports the standard and has the following additional comments and suggestions: 1. Guideline/Technical Basis Section – FE requests the SDT add specific guidance for each requirement. Much of the information in this section is either included, or should be included in the Background section of the standard. One example of guidance that would help is for Requirement R3 on how an entity could perform the annual test. The comment form for this posting has the following paragraph on pg. 2 which could be used as guidance for R3: "the annual test will include verification that communication information contained in the Operating Plan is correct. As an example, the annual update of the Operating Plan could include calling "others as defined in the Responsibility Entity's Operating Plan" (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity's Reliability Coordinator." 2. With regard to the statement in the comment form (pg 2 paragraph 7)"Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity's Reliability Coordinator.", requirement R3 only includes the ERO as an entity and should also include the Reliability Coordinator. 3. The measure M3 says that an entity can use an actual event as a test to meet R3. Does this mean just 1 actual event will meet R3,



or is the intent that all possible events per 1.2 are tested? Would like some clarity on this measure.
Individual
Linda Jacobson-Quinn
Farmington Electric Utility System
Yes
No
The reporting threshold for "Complete or partial loss of monitoring capability" should be modified to include the loss of additional equipment and not be limited to State Estimator and Contingency Analysis. Some options have been included: Affecting a BES control center for $\geq 30$ continuous minutes such that Real-Time monitoring tools are rendered inoperable. Affecting a BES control center for $\geq 30$ continuous minutes to the extent a Constrained Facility would not be identified or an Adverse Reliability Impact event could occur due to lack of monitoring capability. Affecting a BES control center for $\geq 30$ continuous minutes such that an Emergency would not be identified or ma
Yes
Individual
Michael Falvo
Independent Electricity System Operator
Yes
We concur with the changes as they provide better streamlining of the four key requirements, with enhanced clarity. However, we are unclear on the intent of Requirement R3, in particular the phrase "not including notification to the Electric Reliability Organization" which begs the question on whether or not the test requires notifying all the other entities as if it were a real event. This may create confusion in ensuring compliance and during audits. Suggest the SDT to review and modify this requirement as appropriate.
Yes
No
We are unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the proposal when the proposed addition is posted.
We do not agree with the MEDIUM VRF assigned to Requirement R4. Re stipulates a requirement to conduct an annual review of the event reporting Operating Plan in Requirement R1, which itself is assigned a VRF of LOWER. We are unable to rationalize why a subsequent review of a plan should have a higher reliability risk impact than the development of the plan itself. Hypothetically, if an entity doesn't develop a plan to begin with, then it will be assigned a LOWER VRF, and the entity will have no plan to review annually and hence it will not be deemed non-compliant with requirement R4. The entity can avoid being assessed violating a requirement with a MEDIUM VRF by not having the plan to begin with, for which the entity will be assessed violating a requirement with a LOWER VRF. We suggest changing the R4 VRF to LOWER.
Group
Southern Company Services
Antonio Grayson
No
There are approximately 17 event types for which Responsible Entities must have a process for communicating such events to the appropriate entities and R3 states that "The Responsible Entity shall conduct an annual test of the communications process". It is likely that the same communications process will be used to report multiple event types, so Southern suggest that the Responsible Entities conduct an annual test for each unique communications process. Southern suggest that this requirement be revised to state "Each Responsible Entity shall conduct an annual

test of each unique communications process addressed in R1.2". • In Attachment 1, for Event: "Damage or destruction of a Facility", SDT should consider removing "Results from actual or suspected intentional human action" from the "Threshold for Reporting" column. The basis for this suggestion is as follows: o The actual threshold should be measurable, similar to the thresholds specified for other events in Attachment 1. [Note: The first two thresholds identified (i.e., "Affects and IROL" and "Results in the need for actions to avoid an Adverse Reliability Impact") are measurable and sufficiently qualify which types of Facility damage should be reported.] o The determination of human intent is too subjective. Including this as a threshold will cause many events to be reported that otherwise may not need to be reported. (e.g., Vandalism and copper theft, while addressed under physical threats, is more appropriately classified as damage. These are generally intentional human acts and would qualify for reporting under the current guidance in Attachment 1. They may be excluded from reporting by the threshold criteria regarding IROLs and Adverse Reliability Impact, if the human intent threshold is removed.) o It may be more appropriate to address human intent in the event description as follows: "Damage or destruction of a Facility, whether from natural or human causes". Let the thresholds related to BES impact dictate the reporting requirement. • In Attachment 1, for Event: "Complete or partial loss of monitoring capability", SDT should consider changing the threshold criteria to state: "Affecting a BES control center for ≥ 30 continuous minutes such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable." There may be instances where the tools themselves are out of commission, but the control center personnel have sufficiently accurate models and alternate methods of performing the required analyses.

No

It appears that the SDT has incorporated the reporting requirements for CIP-008 "reportable Cyber Security Incidents"; however, the "recognition" requirements remain in CIP-008 Reliability Standard. Southern understands the desire to consolidate reporting requirements into a single standard, but it would be clearer for Cyber Security Incidents if both the recognition and reporting requirements were in one reliability standard and not spread across multiple standards. As it relates to the event type "Loss of Firm Load for > 15 minutes", Southern suggests that the SDT clarify if weather related loss of firm load is excluded from the reporting requirement. As it relates to the event type "Loss of all voice communication capability", Southern suggest that the SDT clarify if this means both primary and backup voice communication systems or just primary voice communication systems. Referring to "CIP-008-3 or its successor" in Requirement R1.1 is problematic. This arrangement results in a variable requirement for EOP-004-2 R1. The requirements in a particular version of a standard should be fixed and not variable. If exceptions to applicable events change, a revision should be made to EOP-004 to reflect the modified requirement.

Yes

Move the Background Section (pages 4-9) to the Guideline and Technical Basis section. They are not needed in the main body of the standard. Each "Entity with Reporting Responsibility" in the one-hour reporting table (p. 17) should be explicitly listed in the table, not pointed to another variable location. The criterion for "Threshold for Reporting" in the one-hour reporting table (p. 17) should be explicitly listed in the table, not pointed to another variable location. Please specify the voltage base against which the +/- 10% voltage deviation on a Facility is to be measured in the twenty-four hour reporting table (p. 19).

Individual

John Seelke

Public Service Enterprise Group

Yes

No

We agreed with most of the revisions. However, for the 24-hour reporting time frame portion of the EOP-004 Attachment 1: Reportable Event that starts on p. 18, we have these concerns: a. Why was "RC" left out in the first row? RC is in the second row that also addresses a "Facility." We believe that "RC" was inadvertently left out. b. In the first row, entities such as a BA, TO, GO, GOP, or DP would not know whether damage or destruction of one of its Facilities either "Affects an IROL (per FAC-014)" or "Results in the need for actions to avoid an Adverse Reliability Impact." FAC-014-2, R5.1.1 requires Reliability Coordinators provide information for each IROL on the "Identification and status of the

associated Facility (or group of Facilities) that is (are) critical to the derivation of the IROL” to entities that do NOT include the entities listed above. And frankly, those entities would not need to know. The reporting requirements associated with “Damage or destruction of a Facility” need to be changed so that the criteria for reporting by an entity whose Facilities experience damage or destruction does not rely upon information that the entity does not possess. c. A possible route to achieve the results in b. above is described below: i. All Facilities that are damaged or destroyed that “Results from actual or suspected intentional human action” would be reported to the ERO by the entity experiencing the damage or destruction. ii. All Facilities that are damaged or destroyed OTHER THAN THAT due to an “actual or suspected intentional human action” would be reported to the RC by the entity experiencing the damage or destruction. Based upon those reports, the RC would be required to report whether the reported damage or destruction of a Facility “Affects an IROL (per FAC-010)” or “Results in the need for actions to Avoid an Adverse Reliability Consequence.” (The RC may need to modify its data specifications in IRO-010-1a - Reliability Coordinator Data Specification and Collection - to specify outages due to “damage or destruction of a Facility.” We also note that “DP” is not included in IRO-010-1a, but “LSE” is included. DPs are required to also register as LSEs if they meet certain criteria. See the “Statement of Compliance Registry Criteria, Rev. 5.0”, p.7. For this reason, we suggest that DP be replaced with LSE in EOP-004-2.) d. To implement the changes in c. above, we suggest that the first row be divided into two rows: i. FIRST ROW: This would be like the existing first row on page 18, except “RC” would be added to the column for “Entity with Reporting Responsibility” and the only reporting threshold would be ““Results from actual or suspected intentional human action.” ii. SECOND ROW: The Event would be “Damage or destruction of a Facility of a BA, TO, TOP, GO, GOP, or LSE,” the Entity, the Reporting Responsibility would be “The RC that has the BA, TOP, GO, GOP, or LSE experiencing the damage or destruction in its area,” and the Threshold for Reporting would be “Affects an IROL (per FAC-010)” or “Results in the need for actions to avoid an Adverse Reliability Consequence.”

Yes

Group

Dominion

Connie Lowe

No

While Dominion believes these are positive changes, we are concerned that placing actual calls to each of the “other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies” may be seen by one or more of those called as a ‘nuisance call’. Given the intent is to insure validity of the contact information (phone number, email, etc), we suggest revising the standard language to support various forms of validation to include, documented send/receipt of email, documented verification of phone number (use of phone book, directory assistance, etc).

Yes

Comments: While Dominion agrees that the revisions are a much appreciated improvement, we are concerned that Attachment 1 does not explicitly contain the ‘entities which must be, at a minimum, notified. Attachment 2 appears to indicate that only the ERO and the Reliability Coordinator for the Entity with Reporting Responsibility need be informed. However, the background section indicates that the Entity with Reporting Responsibility is also expected to contact local law enforcement. We therefore suggest that Attachment 2 be modified to include local law enforcement. Page 26 redline; Attachment 1; Event – Damage or destruction of a Facility; Threshold for Reporting – Results from actual or suspected intentional human action; Dominion is concerned with the ambiguity that this could be interpreted as applying to distribution. Page 27 redline; Attachment 1; Event – Any physical threat that could impact the operability of a Facility; Dominion is concerned the word “could” is hypothetical and therefore unverifiable and un-auditable. The SDT could provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”

Yes

While Dominion supports this addition, we suggest adding to the sentence “NERC will establish a system to collect report forms as established for this section or reliability standard.....”

Dominion believes that the reporting of "Any physical threat that could impact the operability of a Facility" may overwhelm the Reliability Coordinator staff with little to no value since the event may have already passed. This specific event uses the phrase "operability of a Facility" yet "operability" is not defined and is therefore ambiguous. We do support the reporting to law enforcement and the ERO but do not generally support reporting events that have passed to the Reliability Coordinator. Attachment 2; section 4 Event Identification and Description: The type of events listed should match the events as they are exactly written in Attachment 1. As it is currently written, it leaves room for ambiguity. M3 – Dominion objects to having to provide additional supplemental evidence (i.e. operator logs), and the SDT maybe want to include a requirement for NERC to provide a confirmation that the report has been received.

Individual

Terry Harbour

MidAmerican Energy

No

See the NSRF comments. The real purpose of this requirement appears to be to assure operators are trained in the use of the procedure, process, or plan that assures proper notification. PER-005 already requires a systematic approach to training. Reporting to other affected entities is a PER-005 system operator task. Therefore this requirement already covered by PER-005 and is not required. Organizations are also required to test their response to events in accordance with CIP-008 R1.6. Therefore this requirement is covered by other standards and is not needed. Inclusion of this standard would place entities in a double or possible triple jeopardy. The SDT may need to expand M3 reporting options, by stating "... that the annual test of the communication process of 1.2 (e.g. communication via e-mail, fax, phone, ect) was conducted". R4 is an administrative requirement with little reliability value and should be deleted. It would likely be identified as a requirement that that should be eliminated as part of the request by FERC to identify strictly administrative requirements in FERC's recent order on FFTR.

No

Several modifications need to be made to Table 1 to enhance clarity and delete unnecessary or duplicate items. The stated reliability objective of EOP-004 and the drafting team is to reduce and prevent outages which could lead to cascading through reporting. It is understood that the EOP-004 Attachment 1 is to cover similar items to the DOE OE-417 form. Last, remember that FERC recently asked the question of what standards did not provide system reliability benefits. Those reports that cannot show a direct threat to a potential cascade need to be eliminated. Table 1 should always align with the cascade risk objectives and OE-417 where possible. Therefore Table 1 should be modified as follows: 1. Completely divorce CIP-008 from EOP-004. Constant changes, the introduction of new players such as DOE and DHS, and repeated congressional bills, make coordination with CIP-008 nearly impossible. Cyber security and operational performance under EOP-004 remain separate and different despite best efforts to combine the two concepts. 2. Modify R1.2 to state that ERO notification only is required for Table 1. This is similar to the DOE OE-417 notification. Notification of other entities is a best practice, not a mandatory NERC standard. If entities want to notify neighboring entities, they may do so as a best practice guideline. 3. Better clarity for communicating each of the applicable events listed in the EOP-004 Attachment 1 in accordance with the timeframes specified are needed. MidAmerican suggests a forth column be added to the table to clearly identify who must be notified within the specified time period or at a minimum, that R1.2 be revised to clearly state that only the ERO must be notified to comply with the standard. 4. Consolidate OE-417 concepts on physical attack and cyber events by consolidating OE-417 items 1, 2, 9 and 10 to: Verifiable, credible, and malicious physical damage (excluding natural weather events) to a BES generator, line, transformer, or bus that when reported requires an appropriate Reliability Coordinator or Balancing Authority to issue an Energy Emergency Alert Level 2 or higher. The whole attempt to discuss a NERC Facility and avoid adverse reliability impacts overreaches the fundamental principal or reporting for an emergency that could result in a cascade. 5. The wording "affects an IROL (per FAC-014)," is too vague and not measurable. Many facilities could affect an IROL, but fewer facilities if lost would cause an IROL. Change "affects" to "results in" 6. Recommend that Adverse Reliability Impact be deleted and be replaced with actual EEA 2 or EEA 3 level events. 7. The phrase "results from actual or suspected intentional human action" is vague and not measurable. This line item used the term "suspected" which relates to "sabotage". MidAmerican recommends that "Results from actual or suspected intentional human action" be deleted. If not deleted the phrase should be replaced with

"Results from verifiable, credible, and malicious human action intended to damage the BES." 8. Delete "Any physical threat..." as vague, and difficult to measure in a "perfect" zero defect audit environment, and as already covered by item 1 above. If not deleted, at a minimum replace "Any physical threat", with "physical attack" as being measureable and consistent with DOE OE-417. 9. With the use of "i.e." the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that "e.g." should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity. 10. The phrase "or partial loss of monitoring capability" is too vague and should be deleted. In addition, the 30 minute window is too short for EMS and IT staff to effectively be notified and troubleshoot systems before being subjected to a federal law requiring reporting and potential violations. The time frame should be consistent with the EOP-008 standard. If not deleted, replace with "Complete loss of SCADA affecting a BES control center for ≥ 60 continuous minutes such that analysis tools of State Estimator and/or Contingency Analysis are rendered inoperable. 11. Transmission loss should be deleted. The number of transmission elements out does not directly correlate to BES stability and cascading. For that reason alone, this item should be deleted or it would have already been included in the past EOP-004 standard. In addition, large footprints can have multiple storms or weather events resulting in normal system outages. This should not be a reportable event that deals with potential cascading. 12. Modify the threshold of "BES emergency requiring a public appeal..." to include, "Public appeal for a load reduction event resulting from a RC or BA implementing its emergency energy and capacity plans documented in EOP-001." Public appeals for conservation that aren't used to avoid capacity and energy emergencies should be clearly excluded. 13. Add a time threshold to complete loss of off-site power to a nuclear plant. Nuclear plants are to have backup diesel generation that last for a minimum amount of time. A threshold recognizing this 4 hour or longer window needs to be added such as complete loss of off-site power to a nuclear plant for more than 4 hours. Also see the NSRF comments.

No

See the NSRF comments. The NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC's crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)

See the NSRF comments.

Individual

Brenda Lyn Truhe

PPL Electric Utilities

Yes

Yes

PPL EU thanks the SDT for the changes made in this latest proposal. We feel our prior comments were addressed. Regarding the event 'Transmission Loss': For your consideration, please consider adding a footnote to the event 'Transmission Loss' such that weather events do not need to be reported. Also please consider including 'operation contrary to design' in the threshold language. E.g. consistent with the NERC Event Analysis table, the threshold would be, 'Unintentional loss, contrary to design, of three or more BES Transmission Facilities.'

Yes

We appreciate the inclusion of the Process Flowchart on Page 9 of the draft standard. We submit for your consideration, removing the line from the NO decision box to the 'Report Event to ERO, Reliability Coordinator' box. It seems if the event does not need reporting per the decision box, this line is not needed. For clarity in needed actions, please consider using a decision box following flowcharting standards such as, a decision box containing a question with a Yes and a No path. The decision box on 'Report to Law Enforcement ?' does not have a Yes or No. Perhaps, this decision box is misplaced, or is it intended to occur always and not have a different path with different actions? I.e. should it be a process box? Thank you for your work on this standard.

Individual

John Martinsen

Public Utility District No. 1 of Snohomish County
Yes
This is an excellent improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
This is an excellent improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
No
This type of activity and process is better suited to NAESBE than it is to NERC Compliance.
SNPD suggest moving these administrative activities to NAESB. R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB's domain? R2, R3 & R4: These are not appropriate for a Standard. If you don't annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn't need to pile on. Gerry Cauley and Mike Moon have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.
Individual
Russell A. Noble
Cowlitz County PUD
Yes
Yes
Yes
Cowlitz is pleased with changes made to account for the difficulties small entities have in regard to reporting time frames. Although Cowlitz is confident that the current draft is manageable for small entities, we propose that the resulting reports this Standard will generate will contain many insignificant events from the event types "Damage or destruction of a Facility," and "Any physical threat that could impact the operability of a Facility." In particular, examples would be limited target practice on insulators, car-pole accidents, and accidental contact from tree trimming or construction activities. Cowlitz suggests that at least a $\geq 100$ MW (200 MW would be better) and/or $\geq N-2$ impact threshold be established for these event types. Also, Cowlitz suggests the statement "results from actual or suspected intentional human action" be changed to "results from actual or suspected intentional human action to damage or destroy a Facility." A human action may be intentional which can result in damage to a facility, but the intent may have been of good standing, and not directed at the Facility. For example, the intent may have been to legally harvest a tree, or move equipment under a line. Cowlitz believes the above proposed changes would benefit the ERO, both in reduction of nuisance reports and possible violations over minimal to no impact BES events.
Group
SPP Standards Review Group
Robert Rhodes
No
There needs to be a more granular definition of which entities should be included in the annual testing requirement in R3. To clarify what must be tested we propose the following language to replace the last sentence in M3. The annual test requirement is considered to be met if the responsible entity implements any communications process in the Operating Plan during an actual event. If no actual event was reported during the year, at least one of the communication processes in the Operating Plan must be tested to satisfy the requirement. We do not believe the time-stamping requirement in M3 and M4 contribute to the reliability of the BES. A dated review should be sufficient.
No
To obtain an understanding of the drivers behind the events in Attachment 1, we would like to see where these events come from. If the events are required in standards, refer to them. If they are in

the existing event reporting list, indicate so. If they are coming from the EAP, let us know. We have a concern that, as it currently exists, Attachment 1 can increase our reporting requirements considerably. We also have concerns about what appears to be a lack of coordination between EAP reporting requirements and those contained in Attachment 1. For example, the EAP reporting requirement is for the complete loss of monitoring capability whereas Attachment 1 adds the requirement for reporting a partial loss of monitoring capability. It appears that some of the EAP reporting requirements are contained in Attachment 1. We have concerns that this is beyond the scope of the SAR and should not be incorporated in this standard. We have concern with several of the specific event descriptions as contained in Attachment 1: Damage or destruction of a Facility – We are comfortable with the proposed definition of Adverse Reliability Impact but have concerns with the existing definition of ARI. Any physical threat that could impact the operability of a Facility1 – We take exception to this event in that it goes beyond what is currently required in EOP-004-1, including DOE reporting requirements, and the EAP reporting requirements. We do not understand the need for this event type and object to the potential for excessive reporting required by such an event type. Additionally, we are concerned about the potential for multiple reporting of a single event. This same concern applies to several other events including Damage or destruction of a Facility, Loss of firm load for ≥ 15 minutes, System separation, etc. When multiple entities are listed as the Entity with Reporting Responsibility, Attachment 1 appears to require each entity in the hierarchy to submit a report. There should only be one report and it should be filed by the entity owning the event. The SDT addressed this issue in its last posting but the issue still remains and should be reviewed again. BES Emergency resulting in automatic firm load shedding – For some reason, not stipulated in the Consideration of Comments, the action word in the Entity with Reporting Responsibility was changed from ‘experiences’ to ‘implements’. We recommend changing it back to ‘experiences’. Automatic load shedding is not implemented. It does not require human intervention. It’s automatic. Voltage deviation on a Facility – Similar to the comment on automatic load shedding above, the action word was changed from ‘experiences’ to ‘observes’. We again recommend that it be changed back to ‘experiences’. Using observes obligates a TOP, who is able to see a portion of a neighboring TOP’s area, to submit a report if that TOP observed a voltage deviation in the neighboring TOP’s area. The only reporting entity in this event should be the TOP within whose area the voltage deviation occurred. Complete or partial loss of monitoring capability – Clarification on partial loss of monitoring capability and inoperable are needed. Also, the way the Threshold is written, it implies that a State Estimator and Contingency Analysis are required. To tone this down, insert the qualifier ‘such as’ in front of State Estimator.

No

We have two concerns about the proposed change to the RoP. One, we have concerns that our information and data will be circulated to an as yet undetermined audience which appears to be solely under NERC’s control. Secondly, there isn’t sufficient detail in the clearinghouse concept to support comments at this time.

The VRF for R1 is Lower which is fine. The issue is that R4, which is the review of the plan contained in R1, has a Medium VRF. We recommend moving the VRF of R4 to Lower. We recommend deleting the phrase ‘...supplemented by operator logs or other operating documentation...’ as found in the first sentence of M2. A much clearer reference is made to operator logs and other operating documentation in the second sentence. The duplication is unnecessary. What will happen with the accompanying information contained in the Background section in the draft standard? Will it be moved to the Guideline and Technical Basis at the end of the standard as the information contained in the text boxes? This is valuable information and should not be lost.

Group

Florida Municipal Power Agency

Frank Gaffney

No

First, FMPA believes the standard is much improved from the last posting and we thank the SDT or their hard work. Having said that, there are still a number of issues, mostly due to ambiguity in terms, which cause us to vote Negative. R3 and R4 should be combined into a single requirement with two subparts, one for annual testing, and another to incorporate lessons learned from the annual testing into the plan (as opposed to an annual review). The word “test” is ambiguous as used in R3, e.g., does a table top drill count as a “test”? Is the intent to “test” the plan, or “test” the phone

numbers, or what?
No
The bullet on “any physical threat” is un-measurable. What constitutes a “threat”? FMPA likes the language used in the comment form discussing this item concerning the judgment of the Responsible Entity, but, the way it is worded in Attachment 1 will mean the judgment of the Compliance Enforcement Authority, not the Responsible Entity. Presumably, the Responsible Entity will need to develop methods to identify physical threats in accordance with R1; hence, FMPA suggests rewording to: “Any physical threat recognized by the Responsible Entity through processes established in R1 bullet 1.1”. We understand this introduces circular logic, but, it also introduces the “judgment of the Responsible Entity” into the bullet. On the row of the table on voltage deviation, replace the word “observes” with “experiences”. It is possible for one TOP to “observe” a voltage deviation on another TOP’s system. It should be the responsibility of the TOP experiencing the voltage deviation on its system to report, not the one who “observes”. One the row on islanding, it does not make sense to report islanding for a system with load less than the loss of load metrics and we suggest using the same 300 MW threshold for a reporting threshold. One the row on generation loss, some clarification on what type of generation loss (especially in the time domain) would help it be more measurable, e.g., concurrent forced outages. One the row on transmission loss, the same clarity is important, e.g., three or more concurrent forced outages. On the row on loss of monitoring, while FMPA likes the threshold for “partial loss of monitoring capability” for those systems that have State Estimators, small BAs and TOPs will not need or have State Estimators and the reporting threshold becomes ambiguous. We suggest adding something like loss of monitoring for 25% of monitored points for those BAs and TOPs that do not have State Estimators.
Yes
In R1, bullet, it is a bit ambiguous whether the list of organizations to be communicated with is an exhaustive list (i.e.) or a list of examples (e.g.). The list is preceded by an “i.e.” which indicates the former, but includes an “or” which indicates the latter. We are interpreting this as meaning the list is exhaustive as separated by semi-colons, but that the last phrase separated by commas is a list of examples. Is this the correct interpretation? The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., “Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements”) so that changes to the RoP do not necessitate changes to the standard.
Group
LG&E and KU Services
Brent Ingebrigtsen
Yes
No
The SDT should consider more clearly defining the Threshold for Reporting for the Event: “Any physical threat that could impact the operability of a Facility” to only address those events that have an Adverse Reliability Impact. Some proposed language might be: “Threat to a Facility excluding weather related threats that could result in an Adverse Reliability Impact.” For those events specifically defined in the ERO Events Analysis Process, the SDT should consider revising the language to be more consistent with the language included in the ERO Events Analysis Process. Here is some recommended language: 1. EVENT: Transmission loss THRESHOLD FOR REPORTING: “Unintentional loss, contrary to design, of three or more BES Transmission Facilities (excluding successful automatic reclosing) caused by a common disturbance. 2. EVENT: “Complete or partial loss of monitoring capability” – could be revised to read “Complete loss of SCADA control or monitoring functionality” THRESHOLD FOR REPORTING: “Affecting a BES control center for ≥ 30 continuous minutes such that analysis tools (e.g. State Estimator, Contingency Analysis) are rendered inoperable”.
Yes
The Violation Severity Level for Requirement R2 should be revised to read “...hours after recognizing an event requiring reporting...” This will make the language in the VSL consistent with the language in



Attachment 1.
Individual
Thomas Washburn
FMPP
See FMPP's comments
Group
MRO NSRF
WILL SMITH
No
<p>R3 states: Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. R1.2 states: A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies. With the use of "i.e." the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that "e.g." should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity. R3 requires an annual test that would include notification of: "other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies." Since NERC sees no value in receiving these test notifications we are doubtful other entities identified in R1.2 would find them of value. The real purpose of this requirement appears to be to assure operators are trained in the use of the procedure, process, or plan that assures proper notification. PER-005 already requires a systematic approach to training. It is hard to comprehend an organization not identifying this as a Critical Task, and if they failed to identify it as a Critical Task that this would not be a violation. Therefore this requirement is not required. Furthermore organizations test their response to events in accordance with CIP-008 R1.6. Therefore this requirement is covered by other standards and is not needed. The SDT may need to address this within M3, by stating "... that the annual test of the communication process of 1.2 (e.g. communication via e-mail, fax, phone, etc) was conducted". R4 states: Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1. We question the value of requiring an annual review. If the Standard does not change, there seems little value in requiring an annual review. This appears to be an administrative requirement with little reliability value. It would likely be identified as a requirement that should be eliminated as part of the request by FERC to identify strictly administrative requirements in FERC's recent order on FFTR. We suggest it be eliminated.</p>
No
<p>R1.2 states: A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies. This implies not only does NERC need to be notified within the specified time period but that: "other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies." are also required to be notified within the time periods specified. We suggest a fourth column be added to the table to clearly identify who must be notified within the specified time period or that R1.2 be revised to clearly state that only NERC must be notified to comply with the standard. With the use of "i.e." the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that "e.g." should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity. Also with regards to Attachment 1, the following comments are provided: 1. Instead of referring to CIP-008 (in the 1 hour reporting section), quote the words from CIP-008, this will require coordination of future revisions but will assure clarity</p>

in reporting requirements. 2 Under "Damage or destruction of a Facility" a. The wording "affects an IROL (per FAC-014)," is too vague. Many facilities could affect an IROL, not as many if lost would cause an IROL. b. Adverse Reliability Impact is defined as: "The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection." There are an infinite number of routine events that result in the loss of generation plants due to inadvertent actions that somehow also damaged equipment. Any maintenance activity that damaged a piece of equipment that causes a unit to trip or results in a unit being taken off line in a controlled manner would now be reportable. This seems to be an excessive reporting requirement. Recommend that Adverse Reliability Impact be deleted and be replaced with actual EEA 2 or EEA 3 level events. c. The phrase "Results from actual or suspected intentional human action." This line item used the term "suspected" which relates to "sabotage". Recommend the following: Results from actual or malicious human action intended to damage the BES. 3. "Any physical threat that could impact the operability of a Facility1" The example provided by the drafting team of a train derailment exemplifies why this requirement should be deleted. A train derailment of a load of banana's more than likely would not threaten a nearby BES Facility. However a train carrying propane that derails carrying propane could even if it were 10 miles away. Whose calculation will be used to determine if an event could have impacted the asset? As worded there is too much ambiguity left to the auditor. We suggest the drafting team clarify by saying "Any event that requires the a BES site be evacuated for safety reasons" Furthermore if weather events are excluded, we are hard pressed to understand why this information is important enough to report to NERC. So barring an explanation of the purpose of this requirement, including why weather events would be excluded, we suggest the requirement be deleted. Please note that if you align this with "Physical attack" with #1 of the OE-417. This clearly states what the SDT is looking for. 4. The phrase "or partial loss of monitoring capability" is too vague. Further definitions of "inoperable" are required to assure consistent application of this requirement. Recommend that "Complete loss of SCADA affecting a BES control center for  $\geq 30$  continuous minutes such that analysis tools of State Estimator and/or Contingency Analysis are rendered inoperable. Or, Complete loss of the ability to perform a State Estimator or Contingency Analysis function, the threshold of 30 mins is too short. A 60 min threshold will align with EOP-008-1, R1.8. Since this is the time to implement the contingency back up control center plan. 5. Event: Voltage deviation on a Facility. ATC believes that the term "observes" for Entity with Reporting Responsibility be changed back to "experiences" as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. Also, for Threshold for Reporting, ATC believes the language should be expanded to - plus or minus 10% "of target voltage" for greater than or equal to 15 continuous minutes. 6. Event: Transmission loss. ATC recommends that Threshold for Reporting be changed to read "Unintentional loss of four, or more Transmission Facilities, excluding successful automatic reclosing, within 30 seconds of the first loss experienced and for 30 continuous minutes. Technical justification or Discussion for this recommended change: In the instance of a transformer-line-transformer, scenario commonly found close-in to Generating stations, consisting of 3 defined "facilities", 1 lightning strike can cause automatic unintentional loss by design. Increase the number of facilities to 4. In a normal shoulder season day, an entity may experience the unintentional loss of a 138kv line from storm activity, at point A in the morning, a loss of a 115kv line from a different storm 300 miles from point A in the afternoon, and a loss of 161kv line in the evening 500 miles from point A due to a failed component, if it is an entity of significant size. Propose some type of time constraint. Add time constraint as proposed, 30 seconds, other than automatic reclosing. In the event of dense lightning occurrence, the loss of multiple transmission facilities may occur over several minutes to several hours with no significant detrimental effect to the BES, as load will most certainly be affected (lost due to breaker activity on the much more exposed Distribution system) as well. Any additional loss after 30 seconds must take into account supplemental devices with intentional relay time delays, such as shunt capacitors, reactors, or load tap changers on transformers activating as designed, arresting system decay. In addition, Generator response after this time has significant impact. Please clarify or completely delete why this is included within this version when no basis has been give and it is not contained w3ithin the current enforceable version. 7. Modify the threshold of "BES emergency requiring a public appeal..." to include, "Public appear for a load reduction event resulting for a RC or BA implementing its emergency operators plans documented in EOP-001." The reason is that normal public appeals for conservation should be clearly excluded. 8. Add a time threshold to complete loss of off-site power to a nuclear plant. Nuclear plants are to have backup diesel generation that last for a minimum amount of time. A threshold recognizing this 4 hour or

longer window needs to be added such as complete loss of off-site power to a nuclear plant for more than 4 hours. 9. Delete "Transmission loss". The loss of a specific number of elements has no direct bearing on the risk of a system cascade. Faults and storms can easily result in "unintentional" the loss of multiple elements. This is a flawed concept and needs to be deleted

Yes

ATC believes that the NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC's crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)

R1 states: "Each Responsible Entity shall have an event reporting Operating Plan that includes:" The definition of Operating Plan is: "A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan." This appears to us to be too prescriptive and could be interpreted to require a series of documents to for reporting issues to NERC. We suggest the following wording: R1. Each Responsible Entity shall have document methodology(ies) or process(es) for: 1.1. Recognizing each of the applicable events listed in EOP-004 Attachment 1. 1.2. Reporting each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization. LES Comment: [R1] We are concerned by the significant amount of detail an entity would be required to contain within the Operating Plan as part of Requirement R1. Rather than specifying an entity must have a documented process for recognizing each of the events listed in EOP-004-2 Attachment 1, at a minimum, consider removing the term "process" in R1.1 and replacing with "guideline" to ensure operating personnel are not forced to adhere to a specific sequence of steps and still have the flexibility to exercise their own judgment. Section 5 of the standard (Background) should be moved to the Guideline and Technical Basis document. A background that long does not belong in the standard piece as it detracts from the intent of the standard itself.

Group

Progress Energy

Jim Eckelkamp

No

It should be clear that the Operating Plan can be multiple procedures. It is an unnecessary burden to have entities create a new document outlining the Operating Plan. Having to create a new Operating Plan would not improve reliability and would further burden limited resources. The annual testing required by R3 should be clarified. Do all communication paths need to be annually tested or just one path? An actual event may only utilize one communication 'leg' or 'path' and leave others untested and unutilized. Entities may have a corporate level procedure that 'hand-shakes' with more localized procedures that make up the entire Operating Plan. Must all communications processes be tested to fulfill the requirement? If an entity has 'an actual event' it is not necessarily true that their Operating Plan has been exercised completely, yet this one 'actual event' would satisfy M3 as written.

Within attachment 1 (Reportable Events) an exclusion is allowed for weather related threats. PGN recommends a more generic approach to include natural events such as forest fires, sink holes, etc. This would alleviate some reporting burdens in areas that are prone to these types of events.

Individual

Bob Thomas

Illinois Municipal Electric Agency

No

IMEA reluctantly (in recognition of the SDT's efforts and accomplishments to date) cast a Negative vote for this project primarily based on R3 because it is attempting to fix a problem that does not exist and impacts small entity resources in particular. IMEA is not aware of seeing any information regarding a trend, or even a single occurrence for that matter, in a failure to report an event due to

failure in reporting procedures. A small entity is less likely to experience a reportable event, and therefore is less likely to be able to take advantage of the provision in M3 to satisfy the annual testing through implementation of an actual event. If there is a problem that needs to be fixed, it would make much more sense to replace the language in R3 with a simple requirement for the RC, BA, IC, TSP, TOP, etc. to inform the TO, DP, LSE if there is a change in contact information for reporting an event. It is hard to believe that an RC, BA, IC, TSP, TOP, etc. is going to want to be annually handling numerous inquiries from entities regarding the accuracy of contact information. The impact of unnecessary requirements on entity resources, particularly small entities', is finally starting to get some meaningful attention at NERC and FERC. It would be a mistake to adopt another unnecessary requirement as currently specified in R3.

No

Illinois Municipal Electric Agency supports comments submitted by Florida Municipal Power Agency.

No

Illinois Municipal Electric Agency supports comments submitted by ATC.

Illinois Municipal Electric Agency supports comments submitted by Florida Municipal Power Agency.

Individual

Andrew Z. Pusztai

American Transmission Company, LLC

No

ATC recommends eliminating R4 altogether. If R3, the annual test, is conducted as part of the Operating Plan, R4 is merely administrative, and does not add value to reliability.

No

ATC is proposing changes to the following Events in Attachment 1: (Reference Clean Copy of the Standard) 1) Pg. 18/ Event: Any Physical threat that could impact the operability of a Facility. ATC is proposing a language change to the Threshold- "Meets Registered Entities criteria stated in its Event Reporting Operating Plan, in addition to excluding weather." 2) Pg. 19 / Event: Voltage deviation on a Facility. ATC believes that the term "observes" for Entity with Reporting Responsibility be changed back to "experiences" as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. Also, for Threshold for Reporting, ATC believes the language should be expanded to - plus or minus 10% "of target voltage" for greater than or equal to 15 continuous minutes. 3) Pg. 19/ Event: Transmission loss. ATC recommends that Threshold for Reporting be changed to read "Unintentional loss of four, or more Transmission Facilities, excluding successful automatic reclosing, within 30 seconds of the first loss experienced and for 30 continuous minutes. Technical justification or Discussion for this recommended change: In the instance of a transformer-line-transformer, scenario commonly found close-in to Generating stations, consisting of 3 defined "facilities", 1 lightning strike can cause automatic unintentional loss by design. Increase the number of facilities to 4. In a normal shoulder season day, an entity may experience the unintentional loss of a 138kv line from storm activity, at point A in the morning, a loss of a 115kv line from a different storm 300 miles from point A in the afternoon, and a loss of 161kv line in the evening 500 miles from point A due to a failed component, if it is an entity of significant size. Propose some type of time constraint. Add time constraint as proposed, 30 seconds, other than automatic reclosing. In the event of dense lightning occurrence, the loss of multiple transmission facilities may occur over several minutes to several hours with no significant detrimental effect to the BES, as load will most certainly be affected (lost due to breaker activity on the much more exposed Distribution system) as well. Any additional loss after 30 seconds must take into account supplemental devices with intentional relay time delays, such as shunt capacitors, reactors, or load tap changers on transformers activating as designed, arresting system decay. In addition, Generator response after this time has significant impact. 4) Pg.20 /Event: Complete or partial loss of monitoring capability. ATC recommends that the term "partial" be deleted from the event description. ATC recommends that the term "partial" be deleted for the Entity with Reporting Responsibility and changed to read: Each RC, BA, and TOP that experiences the complete loss of monitoring capability.

No

ATC believes that the NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC's crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary.

The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)

Individual

Brenda Frazer

Edison Mission Marketing & Trading, Inc.

Yes

Yes

Yes

No

Group

PPL Corporation NERC Registered Affiliates

Stephen J. Berger

Yes

No

1.) PPL Generation thanks the SDT for the changes made in this latest proposal. We feel our previous comments were addressed. PPL Generation offers the following additional comments. Regarding the event 'Transmission Loss': For your consideration, please consider adding a footnote to the event 'Transmission Loss' such that weather events do not need to be reported. Also please consider including operation contrary to design in the language and not just in the example. E.g. consistent with the NERC Event Analysis table, the threshold would be, 'Unintentional loss, contrary to design, of three or more BES Transmission Facilities.' 2.) PPL Generation proposes the following changes in Attachment 1 to the first entry in the "Threshold for Reporting" column to make it clear that independent GO/GOPs are required to act only within their sphere of operation and based on the information that is available to the GO/GOPs: Damage or destruction of a Facility that: Affects an IROL (per FAC-014, not applicable to GOs and GOPs) OR Results in the need for actions to avoid an Adverse Reliability Impact (not applicable to GOs and GOPs) OR Results from actual or suspected intentional human action (applicable to all).

Yes

We appreciate the inclusion of the Process Flowchart on Page 9 of the draft standard. We submit for your consideration, removing the line from the NO decision box to the 'Report Event to ERO, Reliability Coordinator' box. It seems if the event does not need reporting per the decision box, this line is not needed. The decision box on 'Report to Law Enforcement ?' does not have a Yes or No. Perhaps, this decision box is misplaced, or is it intended to occur always and not have a different path with different actions? Ie. should it be a process box? Thank you for your work on this standard.

Individual

Kenneth A Goldsmith

Alliant Energy

No

In the first Event for twenty four hour reporting, the last item in "Threshold for Reporting" should be revised to "Results from actual or suspected intentional malicious human action." An employee may be performing maintenance and make a mistake, which could impact the BES. In the second Event for twenty four hour reporting the event should be revised to "Any physical attack that could impact the operability of a Facility." Alliant Energy believes this is clearer and easier to measure.

Section 5 of the standard (Background) should be moved to the Guideline and Technical Basis

document. A background that long does not belong in the standard piece as it detracts from the intent of the standard itself.

Individual

Eric Salsbury

Consumers Energy

No

The term "Facility" seems to be much more broad and even more vague than the use of BES equipment. We recommend reverting back to use of BES equipment.

Group

Hydro One

Sasa Maljukan

No

In the Requirement R3, we suggest adding the following wording from Measure M3 to the end of R3 after the wording "in Part 1.2.": The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Statement "... not including notification to the ERO..." as it stands now is confusing. We suggest that this statement is either reworded (and explained in the Rational for this requirement) or outright removed for clarity purposes In the requirement R4, we suggest replacing the words "an annual review" with the words "a periodic review." Add the following to R4: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years. This does not preclude an annual review in an Entity's operating plan. The Entity will then be audited to its plan. If the industry approves a five (5) year periodic review 'cap,' and FERC disagrees, then FERC will have to issue a directive, state it reasons and provide justification for an annual review that is not arbitrary or capricious. Adding the one year "test" requirement adds to the administrative tracking burden and adds no reliability value. The table in the standard is clear regarding what events need to be reported. An auditor may want to see a test for "each" of the applicable events listed in EOP-004 Attachment 1. If the requirement for "an" annual test remains in the standard in R3, then it should be made clear that a test is not required for "each" of the applicable events listed in Attachment 1 (reference to R1.2.)

No

In the Attachment 1, language identical to event descriptions in the NERC Event Analysis Process and FERC OE-417 should be used. Creating a third set of event descriptions is not helpful to system operators. Recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible. The proposed "events" are subjective and will lead to confusion and questions as to what has to be reported. - Event: A reportable Cyber Security Incident. All reportable Cyber Security Incidents may not require "One Hour Reporting." A "one-size fits all" approach may not be appropriate for the reporting of all Cyber Security Incidents. The NERC "Security Guideline for the Electricity Sector: Threat and Incident Reporting" document provides time-frames for Cyber Security Incident Reporting. For example, a Cyber Security Compromise is recommended to be reported within one hour of detection, however, Information Theft or Loss is recommended to be reported within 48 hours. Recommend listing the Event as "A confirmed reportable Cyber Security Incident. The existing NERC "Security Guideline for the Electricity Sector: Threat and Incident Reporting" document uses reporting time-frames based on "detection" and "discovery." Recommend using the word confirmed because of the investigation time that may be required from the point of initial "detection" or "discovery" to the point of confirmation, when the compliance "time-clock" would start for the reporting requirement in EOP-004-2. - Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read: "Results from actual or suspected intentional human action, excluding unintentional human errors". - Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word "could" is hypothetical and therefore unverifiable and un-auditable. The word "impact" is undefined. Please delete this reporting requirement. or provide a list of hypothetical "could impact" events. as well as a

specific definition and method for determining a specific physical impact threshold for "could impact" events other than "any." - Event: BES Emergency requiring public appeal for load reduction. Replace wording in the Event column with language from #8 on the OE-417 Reporting Form to eliminate reporting confusion. Following this sentence add, "This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event." - Event: Complete or partial loss of monitoring capability Event wording: Delete the words "or partial" to conform the wording to the NERC Event Analysis Process. - Event: Transmission Loss Revise to BES Transmission Loss - Event: Generation Loss Revise to BES Generation Loss

No

The proposed new section does not contain specifics of the proposed system nor the interfacing outside of the system to support the report collecting.

The proposed standard is not consistent with NERC's new Risk Based Compliance Monitoring. - The performance based action to "implement its event reporting Operating Plan" on defined events, as required in R2, could be considered a valid requirement. However, the concern is that this requirement could be superseded by the NERC Events Analysis Process and existing OE-417 Reporting. - The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. However, controls should not be part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well-established process that has regulatory obligations. NERC enforcement of reporting is redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules. Form EOP-004, Attachment 2: Event Reporting Form: - Delete from the Task column the words "or partial". - Delete from the Task column the words "physical threat that could impact the operability of a Facility". VSL's may have to be revised to reflect revised wording. The standard as proposed is not supportive of Gerry Cauley's performance based standard initiative

Group

CenterPoint Energy

John Brockhan

No

CenterPoint Energy recommends that "and implement" be added after "Each Responsible Entity shall have" in Requirement R1. After such revision, Requirement R2 will not be needed as noted in previous comments submitted by the Company. CenterPoint Energy also believes that Requirement R3 is not needed as an annual review encompassing the elements of the test described in the draft is sufficient.

No

CenterPoint Energy appreciates the revisions made to Attachment 1 based on stakeholder feedback; however, the Company continues to have concerns regarding certain events and thresholds for reporting and offers the following recommendations. (1) CenterPoint Energy recommends the deletion of "per Requirement R1" in the "Note" under Attachment 1 as it contains a circular reference back to R1 which includes timeframes. (2) CenterPoint Energy maintains that a required 1 hour threshold for reporting of any event is unreasonable. CenterPoint Energy is confident that given dire circumstances Responsible Entities will act quickly on responding to and communication of any impending threat to the reliability of the Bulk Electric System. (3) For the event of "Damage or destruction of a Facility", CenterPoint Energy is concerned that the use of the term "suspected" is too broad and proposes that the SDT delete "suspected" and add "that causes an Adverse Reliability Impact..." to the threshold for reporting regarding human action. (4) CenterPoint Energy believes that the event, "Any physical threat that could impact the operability of a Facility" is too broad and should be deleted. Alternatively, CenterPoint Energy recommends that the SDT delete "could" or change the event description to "A physical incident that causes an Adverse Reliability Impact". Additionally, in footnote 1, the example of a train derailment uses the phrase "could have damaged". CenterPoint Energy is concerned that as beauty is the eye of the beholder, this phrase is open to interpretation and therefore recommends that the phrase, "causes an Adverse Reliability Impact" be incorporated into the description. (5) The Company proposes that the threshold for reporting the event, "BES Emergency requiring manual firm load shedding" is too low. It appears the SDT was attempting to align this threshold with the DOE reporting requirement. However, as the SDT stated above, there are several valid reasons why this should not be done: therefore, CenterPoint Energy recommends the threshold be revised to "Manual

firm load shedding  $\geq 300$  MW". (6) CenterPoint Energy also recommends a similar revision to the threshold for reporting associated with the "BES Emergency resulting in automatic firm load shedding" event. ("Firm load shedding  $\geq 300$  MW (via automatic under voltage or under frequency load shedding schemes, or SPS/RAS)") (7) CenterPoint Energy is uncertain of the event, "Loss of firm load for  $\geq 15$  minutes" and its fit with BES Emergency requiring manual firm load shedding or BES Emergency resulting in automatic firm load shedding. The Company believes that this event is already covered with manual firm load shedding and automatic firm load shedding and should therefore be deleted. (8) For the event of "System separation (islanding)", CenterPoint Energy believes that 100 MW is inconsequential and proposes 300 MW instead. (9) For "Generation loss", CenterPoint Energy suggests that the SDT add "only if multiple units" to the criteria of "1,000 MW for entities in the ERCOT or Quebec Interconnection". (10) Finally, CenterPoint Energy recommends that the SDT delete the term "partial" under the "Entity with Reporting Responsibility" for "Complete or partial loss of monitoring capability". The Company proposes revising the event description to "Loss of monitoring capability for  $> 30$  minutes that causes system analysis tools to be inoperable".

No

CenterPoint Energy does not agree with the SDT's proposed section 812. The proposal for NERC to establish a system that will "...forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations." is redundant with the draft Standard. Responsible entities are already required to report applicable events to NERC, applicable regional entities, registered entities, and appropriate governmental, law enforcement, and regulatory agencies. CenterPoint Energy believes if the SDT's intent is to require NERC to distribute these system event reports, then EOP-004-2 should be revised to require responsible entities to only report the event to NERC. As far as distribution to appropriate NERC departments, CenterPoint Energy believes that is an internal NERC matter and does not need to be included in the Rules of Procedure.

CenterPoint Energy proposes that the purpose be enhanced to reflect risk and response. For example, the purpose could read "To sustain and improve reliability of the Bulk Electric System by identifying common risks reported by Responsible Entities as a source of lessons learned." In the Background section under Law Enforcement Reporting, "the" should be added in front of "Bulk Electric System". Also under the Background section - "Present expectations of the industry under CIP-001-1a", CenterPoint Energy is not aware of any current annual requirements for CIP-001 and suggests that this section be revised to reflect that fact. CenterPoint Energy strongly believes that the Violation Severity Levels (VSL) should not be high or severe unless an Adverse Reliability Impact occurred. CenterPoint Energy is requesting that Requirement R2 be deleted and the phrase, "as a result of not implementing the plan/insufficient or untimely report, an Adverse Reliability Impact occurred" be added to the Requirement R1 VSL. Regarding the VSL for Requirement R4, the Violation Risk Factor should be "Lower" and read "the entity did not perform the annual test of the operating plan" as annual is to be defined by the entity or according to the CAN-0010.

Individual

Kirit Shah

Ameren

Yes

No

We appreciate the efforts of the DSR SDT and believe this latest Draft is greatly improved over the previous version. However, we propose the following suggestions: (1) The first Event category in Attachment 1 under 24 Hour Reporting is Applicable to GO and GOP entities. Yet the first 2 of 3 Thresholds for Reporting require data that is unobtainable for GO and GOP entities. Specifically, Events that "Affects an IROL (per FAC-014)" and "Results in the need for actions to avoid an Adverse Reliability Impact". We believe these thresholds, and the use of the NERC Glossary term Adverse Reliability Impact, clearly show the SDT's intent to limit reporting only to Events that have a major and significant reliability impact on the BES. GO or GOP does not have access to the wide-area view of the transmission system, making them to make this determination is impossible. As a result, we do not believe GO and GOP entities should have Reporting Responsibility for these types of Events. (2) For GO and GOP entities, the third Threshold is confusing as to which facilities in the plant it would be



applicable to; because the definition of "Facility" does not provide a clear guidance in that respect. For example, would a damage to ID fan qualify as a reportable event? (3) The second Event category in Attachment 1 under 24 Hour Reporting, "Any physical threat that could impact the operability of a Facility" is wide open to interpretation and thus impracticable to comply with. For example, a simple car accident that threatens any transmission circuit, whether it impacts the BES (as listed in the Threshold for the previous event in the table or any other measure) or not, is reportable. This list could become endless without the events having any substantial impact on the system. To continue this point, the Footnote 1 can also include, among many other examples, the following: (a) A wild fire near a generating plant, (b) Low river levels that might shut down a generating plant, (c) A crane that has partially collapsed near a generator switchyard, (d) Damage to a rail line into a coal plant, and/or (v) low gas pressure that might limit or stop operation of a natural gas generating plant. (4) The category, "Transmission Loss" is a concern also. If the meaning of Transmission Facility is included in the meaning of Facility as described in the event list, it may be acceptable; but, we still have a question how would a loss of a bus and the multiple radial element that may be connected to that bus would be treated? Also, how would a breaker failure affect this type of an event? The loss of a circuit is "intentional" (as opposed to Unintentional as listed in the threshold) for the failure of breaker, how will it be treated in counting three or more? We suggest a clarification for such types of scenarios. (5) Requirement R1.: 1.1 includes an exception from compliance with this Standard if there is a Cyber Security Incident according to CIP-008-3. However, note that the CIP-008-3 may not apply to all GO and GOP facilities. While the exception is warranted to eliminate duplicative event reporting plans, the language of this requirement is confusing as it does not clearly provides that message. (6) The second paragraph in Section C.1.1.2. Includes the phrases "...shall retain the current, document..." and "...the "date change page" from each version..." Is the "document" intended to be the Operating Plan? We do not see a defining reference in the text around this phrase; also, is a "date change page" mandatory for compliance with this Standard? We request additional clarification of wording in the Evidence Retention section of the Standard. (7) Page 19 / Event: Voltage deviation on a Facility: We believe that the term "observes" for Entity with Reporting Responsibility be changed back to "experiences" as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. In addition, for Threshold for Reporting, We believe the language should be expanded to - plus or minus 10%"of nominal voltage" for greater than or equal to 15 continuous minutes. (8) Page 20 /Event: Complete or partial loss of monitoring capability. We suggest to the SDT that the term "partial" be deleted from the event description. (9) We suggest to the SDT that the term "partial" be deleted for the Entity with Reporting Responsibility and changed to read: Each RC, BA, and TOP that experiences the complete loss of monitoring capability.

No

If the SDT keeps new Section 812 we suggest to the SDT a wording change for the second sentence, underlined: "Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC department for review. After review, the report will be forwarded to the applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary."

Individual

Howard Rulf

We Energies

Yes

No

Submitting reports to the ERO: NERC and all of the Regional Entities are the ERO. If I send a report to any Regional Entity (and not NERC), I have sent it to the ERO. Damage or Destruction of a Facility: A DP may not have a Facility by the NERC Glossary definition. All distribution is not a Facility. Did you mean to exclude all distribution? Any Physical threat that could impact the operability of a Facility: An RC does not have Facilities by the NERC Glossary definition. An RC will not have to report this. BES Emergency... Reporting Responsibility: If meeting the Reporting Threshold was due to a directive from the RC, who is the Initiating entity? Voltage deviation on a Facility Threshold for Reporting: 10% of what voltage? Nominal, rated, scheduled, design, actual at an instant?

No

Section 812 refers to the section as a standard and as a Procedure. That is not correct. Section 812 reads to me as if NERC (the system) will be forwarding everything specified anywhere in RoP 800.
Applicability: Change Electric Reliability Organisation to NERC or delete Regional Entity. The ERO is NERC and all the Regional Entities. R1.2: The ERO is NERC and all the REs. If I report to any one on the REs (only and not to NERC), I have reported to the ERO. Change ERO to NERC. M1 refers to R1.1 and R1.2 as Parts. It would be clearer to refer to them as requirements or sub-requirements. M2: Add a comma after "that the event was reported" and "supplemented by operator logs". It will be easier to read. R3: This should be clarified to state that no reporting will be done for the annual test, not just exclude the ERO. M4: An annual review will not be time stamped.
Group
SMUD & BANC
Joe Tarantino
We feel issues were addressed, but still have concern with 'damage'. We certainly support that any 'destruction' of a facility that meets any of the three criteria be a reportable issue. But 'damage', if it's going to be included should have some objective definition that sets a floor. Much like the copper theft issue, we don't see the benefit of reporting plain vandalism (gun-shot insulators results from actual or suspected intentional human action) to NERC unless the 'damage' has some tangible impact on the reliability of the system or are acts of an orchestrated sabotage (i.e. removal of bolt in a transmission structure).
Individual
Brian J Murphy
NextEra Energy Inc
No
NextEra Energy, Inc. (NextEra) does not agree that annual reviews and annual tests should be mandated via Reliability Standards; instead, NextEra believes it is more appropriate to require that the Operating Plan be up-to-date and reviewed/tested as the Responsible Entity deems necessary. These enhancements provide for a robust Operating Plan, without arbitrary deadlines for a review and testing. It also provides Responsible Entities of different sizes and configurations the flexibility to efficiently and effectively integrate compliance with operations. Thus, NextEra requests that R1 be revised to read: "Each Responsible Entity shall have an up-to-date event reporting Operating Plan that is tested and reviewed as the Responsible Entity deems necessary and includes: ...". Consistent with these changes NextEra also requests that R3 and R4 be deleted.
No
As stated in NextEra's past comments, we continue to be concerned that EOP-004-2 does not appropriately address actual sabotage that threatens the Bulk Electric System (BES) versus random acts that are isolated and pose no risk to the BES. Therefore, NextEra repeats a portion of its past comments below in the hope that the next revision of EOP-004-2 will more adequately address NextEra's concerns. Specifically, NextEra's requests that its definition of sabotage set forth below replace Attachment 1's "Damage and Destruction of Equipment" and "Any physical threat that could impact the operability of a Facility." In Order No. 693, FERC stated its interest in NERC revising CIP-001 to better define sabotage and requiring notification to the certain appropriate federal authorities, such as the Department of Homeland Security. FERC Order No. 693 at PP 461, 462, 467, 468, 471. NextEra has provided an approach that accomplishes FERC's objectives and remains within the framework of the drafting team, but also focuses the process of determining and reporting on only those sabotage acts that could affect other BES systems. Today, there are too many events that are being reported as sabotage to all parties in the Interconnection, when in reality these acts have no material affect or potential impact to other BES systems other than the one that experienced it. For example, while the drafting team notes the issue of copper theft is a localized act, there are other localized acts of sabotage that are committed by an individual, and these acts pose little, if any, impact or threat to other BES systems. Reporting sabotage that does not need to be sent to everyone does not add to the security or reliability of the BES. Relatedly, there is a need to clarify some of the current industry confusion on who should (and has the capabilities to) be reporting to a broader

audience of entities. Hence, the NextEra approach provides a clear definition of sabotage, as well as the process for determining and reporting sabotage. New Definition for Sabotage. Attempted or Actual Sabotage: an intentional act that attempts to or does destroy or damage BES equipment for the purpose of disrupting the operations of BES equipment, or the BES, and has a potential to materially threaten or impact the reliability of one or more BES systems (i.e., one act of sabotage on BES equipment is only reportable if it is determined to be part of a larger conspiracy to threaten the reliability of the Interconnection or more than one BES system).

Given that Responsible Entities are already required by other Reliability Standards to communicate threats to reliability to their Reliability Coordinator (RC), NextEra does not believe that EOP-004-2 is a Reliability Standard that promotes the reliability of the bulk power system, as envisioned by Section 215 of the Federal Power Act. Because an RC reporting requirement is already covered in other Standards, EOP-004-2 essentially is a reporting out requirement to the Regional Reliability Organization (RRO). NextEra does not agree that the reporting of events to the RROs should be subject to fines under the Reliability Standard regulatory framework. The reporting to RROs, as required by EOP-004-2, while informative and helpful for lessons learned, etc., is not necessary to address an immediate threat to reliability. In addition, NextEra does not believe it would be constructive to fine Responsible Entities for failure to report to a RRO within a mandated deadline during times when these entities are attempting to address potential sabotage on their system. NextEra would, therefore, prefer that the EOP-004-2 Standards Drafting Team be disbanded, and instead that EOP-004-2's reporting requirements be folded in to the event analysis reporting requirements. Therefore, NextEra requests that the new Section 812 be revised to include EOP-004-2 as a data request for lessons learn or for informational purposes only, and, also, for EOP-004-2 project to be disbanded.

Individual

Kathleen Goodman

ISO New England Inc

No

Due to the FERC mandate to assign VRFs/VSLs, we do not support using subrequirements and, instead, favor the use of bullets when the subrequirements are not standalone but rely on the parent requirement.

No

We unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the proposal when the proposed addition is posted.

We requests that the SDT post the following Alternative Proposal for Industry comments as required by the Standards Process to obtain Industry consensus and as permitted by FERC: An equally effective alternative is to withdraw this standard and to make the contents of the SDT's posted standard a NERC Guideline. a. This alternative is more in line with new NERC and FERC proposals b. This alternative retains the reporting format Comments 1. The FERC Order 693 directives regarding "sabotage" have already been addressed by the SDT (i.e. the concept was found outside the scope of NERC standards) 2. Current Industry actions already address the needs cited in the Order: a. Approved Reporting Processes already exists i. The Operating Committee's Event Analysis Process ii. Alert Reporting b. The Data already exists i. Reliability Coordinators Information System (which creates hundred if not thousands of "reports" per year) ii. The DOE's OE 417 Report itself provides part of the FERC discussed data 3. The proposed standard is not supportive of Gerry Cauley's performance based standard initiative or of FERC's offer to reduce procedural standards a. The proposed requirement is a process not an outcome i. The proposal is more focused on reporting and could divert the attention of reliability entities from addressing a situation to collecting data for a report b. The proposed "events" are subjective and if followed will create an unmanageable burden on NERC staff i. Reporting "damage" to facilities can be interpreted as anything from a dent in a generator to the total destruction of a transformer ii. The reporting requirements on all applicable entities will create more questions about differences between the reports of the various entities – rather than leading to conclusions about patterns among events that indicate a global threat iii.

Reporting any “physical threat” is too vague and subjective iv. Reporting “damage to a facility that affects an IROL” is subjective and can be seen to require reporting of damage on every facility in an interconnected area. v. Reporting “Partial loss of monitoring” is a data quality issue that can be anything from the loss of a single data point to the loss of an entire SCADA system vi. Testing the filling out of a Report does not make it easier to fill out the report later (moreover the reporting is already done often enough –see 2.b.i) c. The proposed requirements will create a disincentive to improving current Reporting practices (the more an entity designs into its own system the more it will be expected to do and the more likely it will be penalized for failing to comply) i. Annual reviews of the reporting practices fall into the same category, why have a detailed process to review when a simple one will suffice? 4. The proposed standard does not provide a feedback loop to either the data suppliers or to potentially impacted functional entities a. If the “wide area” data analysis indicates a threat, there is no requirement to inform the impacted entities b. As a BES reliability issue there is no performance indicators or metrics to show the value of this standard i. We recognize that specific incidents cannot be identified but if this is to be a reliability standard some information must be provided. A Guideline could be designed to address this concern. 5. The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring. a. The performance based action to report on defined events, as required in R2, could be considered a valid requirement. However we have concerns as noted in Bullet 3 above. The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. NERC is moving in the direction to assess entities’ controls, outside of the compliance enforcement arm. The industry is being informed that NERC Audit staff will conduct compliance audits based on the controls that the entity has implemented to ensure compliance. We are interested in supporting this effort and making it successful. However, if this is the direction NERC is moving, we should not be making controls part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. 6. For FERC-jurisdictional entities, NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting would be redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.

Group

ISO/RTO Standards Review Committee

Albert DiCaprio

No

The SRC offers comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see the latter part of the SRC’s response to Question 4 below for an SRC proposed alternative approach: Regarding the proposed posted requirements, without indicating support of those requirements, the SRC concurs with the changes as they provide better streamlining of the four key requirements, with enhanced clarity. However, we are unclear on the intent of Requirement R3, in particular the phrase “not including notification to the Electric Reliability Organization” which begs the question on whether or not the test requires notifying all the other entities as if it were a real event. This may create confusion in ensuring compliance and during audits. Suggest the SDT to review and modify this requirement as appropriate. Regarding part 1.2, the SRC requests that the text be terminated after the word “type” and before “i.e.” As written, the requirement does not allow for the entity to add/remove others as necessary. Please consider combining R3 and R4. These can be accomplished at the same time. The process should be evaluated to determine effectiveness when an exercise or test is conducted. The SDT is asked to review the proposal and to address the issue of requirements vs. bullets vs. sub-requirements. It is suggested that each requirement be listed independently, and that each sub-step be bulleted.

No

The SRC response to this question does not indicate support of the proposed requirement. Please see the latter part of the SRC’s response to Question 4 below for an SRC proposed alternative approach:

No

The SRC offers comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see the latter part of the SRC’s response to Question 4 below for an SRC proposed alternative approach: The SRC is unable to comment on the proposed new section as the section does not contain any

description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the proposal when the proposed addition is posted.

The SRC offers some other comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see below for an SRC proposed alternative approach: The SRC does not agree with the MEDIUM VRF assigned to Requirement R4. R4 is a requirement to conduct an annual review of the Event Reporting Operating Plan mandated in Requirement R1. R1 however is assigned a VRF of LOWER. We are unable to rationalize why a subsequent review of a plan should have a higher reliability risk impact than the development of the plan itself. Hypothetically, if an entity doesn't develop a plan to begin with, then it will be assigned a LOWER VRF, and the entity will have no plan to review annually and hence it will not be deemed non-compliant with requirement R4. The entity can avoid being assessed violating a requirement with a MEDIUM VRF by not having the plan to begin with, for which the entity will be assessed violating a requirement with a LOWER VRF. We suggest changing the R4 VRF to LOWER.

\*\*\*\*\* The SRC requests that the SDT post the following Alternative Proposal for Industry comments as required by the Standards Process to obtain Industry consensus and as permitted by FERC: An equally effective alternative is to withdraw this standard and to make the contents of the SDT's posted standard a NERC Guideline. a. This alternative is more in line with new NERC and FERC proposals b. This alternative retains the reporting format Comments 1. The FERC Order 693 directives regarding "sabotage" have already been addressed by the SDT (i.e. the concept was found outside the scope of NERC standards) 2. Current Industry actions already address the needs cited in the Order: a. Approved Reporting Processes already exists i. The Operating Committee's Event Analysis Process ii. Alert Reporting b. The Data already exists i. Reliability Coordinators Information System (which creates hundred if not thousands of "reports" per year) ii. The DOE's OE 417 Report itself provides part of the FERC discussed data 3. The proposed standard is not supportive of Gerry Cauley's performance based standard initiative or of FERC's offer to reduce procedural standards a. The proposed requirement is a process not an outcome i. The proposal is more focused on reporting and could divert the attention of reliability entities from addressing a situation to collecting data for a report b. The proposed "events" are subjective and if followed will create an unmanageable burden on NERC staff i. Reporting "damage" to facilities can be interpreted as anything from a dent in a generator to the total destruction of a transformer ii. The reporting requirements on all applicable entities will create more questions about differences between the reports of the various entities – rather than leading to conclusions about patterns among events that indicate a global threat iii. Reporting any "physical threat" is too vague and subjective iv. Reporting "damage to a facility that affects an IROL" is subjective and can be seen to require reporting of damage on every facility in an interconnected area. v. Reporting "Partial loss of monitoring" is a data quality issue that can be anything from the loss of a single data point to the loss of an entire SCADA system vi. Testing the filling out of a Report does not make it easier to fill out the report later (moreover the reporting is already done often enough –see 2.b.i) c. The proposed requirements will create a disincentive to improving current Reporting practices (the more an entity designs into its own system the more it will be expected to do and the more likely it will be penalized for failing to comply) i. Annual reviews of the reporting practices fall into the same category, why have a detailed process to review when a simple one will suffice? 4. The proposed standard does not provide a feedback loop to either the data suppliers or to potentially impacted functional entities a. If the "wide area" data analysis indicates a threat, there is no requirement to inform the impacted entities b. As a BES reliability issue there is no performance indicators or metrics to show the value of this standard i. The SRC recognizes that specific incidents cannot be identified but if this is to be a reliability standard some information must be provided. A Guideline could be designed to address this concern. 5. The proposed standard is not consistent with NERC's new Risk Based Compliance Monitoring. a. The performance based action to report on defined events, as required in R2, could be considered a valid requirement. However we have concerns as noted in Bullet 3 above. The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. NERC is moving in the direction to assess entities' controls, outside of the compliance enforcement arm. The industry is being informed that NERC Audit staff will conduct compliance audits based on the controls that the entity has implemented to ensure compliance. The SRC is interested in supporting this effort and making it successful. However, if this is the direction NERC is moving, we should not be making controls part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. 6. For FERC-jurisdictional

entities, NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting would be redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.

Individual

Mark B Thompson

Alberta Electric System Operator

The Alberta Electric System Operator will need to modify parts of this standard to fit the provincial model and current legislation when it develops the Alberta Reliability Standard.

Individual

Maggy Powell

Exelon Corporation and its affiliates

No

It's not clear that R3 and R4 need to be separated. Consider revising R3 to read: "Through use or testing, verify the operability of the plan on an annual basis" and dropping R4.

Yes

No

While we don't have any immediate objection to revising the Rules of Procedures (ROP) to allow for report collecting under Section 800 relative to the EOP-004 standard, the proposed language is unclear and confusing. Please consider the following revision: "812. NERC Reporting Clearinghouse NERC will establish a system to collect reporting forms as required for Section 800 or per FERC approved standards from any Registered Entities. NERC shall distribute the reports to the appropriate governmental, law enforcement, regulatory agencies as required per Section 800 or the applicable standard." Further, NERC should post ROP revisions along with a discussion justifying the revision for industry comment specific to the ROP. There may be significant implications to this revision beyond the efforts relative to EOP-004.

Thanks to the SDT. Significant progress was made in revising the proposed standard language. We appreciate the effort and have only a few remaining requests:

- We understand that CIP-008 dictates the 1-hour reporting obligation for Cyber Security Incidents and this iteration of EOP-004 delineates the CIP-008 requirements. Please confirm that per the exemption language in the CIP standards (as consistent with the March 10, 2011 FERC Order (docket # RM06-22-014) nuclear generating units are not subject to this reporting requirement.
- EOP-004 still lists "Generation Loss" as a 24 hour reporting criteria without any time threshold guidance for the generation loss. Exelon previously commented to the SDT (without the comment being addressed) that Generation Loss should provide some type of time threshold. If the 2000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? In considering clarification language, the SDT should review the BAL standards on the disturbance recovery period for appropriate timing for closeness of trips.
- The "physical threat that could impact" requirement remains vague and it's not clear the relevance of such information to NERC or the Regions. If a train derailment occurred near a generation facility (as stated in the footnote), are we to expect that NERC is going to send out a lesson learned with suggested corrective actions to protect generators from that occurring? The value in that event reporting criteria seems low. The requirement should be removed.
- The event concerning voltage deviation of +/- 10% does not specify which type of voltage. In response to this comment in the previous comment period, the SDT indicated that the entity could determine the type of voltage. It would be clearer to specify in the standard and avoid future interpretation at the audit level.
- As requested previously, for nuclear facilities, EOP-004 reporting should be coordinated with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security or cyber event. Please contact the NRC about this project to ensure that required communication and reporting in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the

potential to impact the BES does not create duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. Each nuclear generating site licensee must have an NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan (E-Plan). Exelon again asks that the proposed reporting process and flow chart be coordinated with the NRC to ensure it does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans. In the alternative, the EOP-004 language should include acceptance of NRC required reporting to meet the EOP-004 requirements. • The proposed standard notes that the text boxes will be moved to the Guideline and Technical Basis Section which we support. However, it's not clear whether all the information in the background section will remain part of the standard. If this section is to remain as proposed concerted revision is needed to ensure that the discussion language matches the requirement language. At present, it does not. For instance, the flow chart on page 9 indicates when to report to law enforcement while the requirements merely state that communications to law enforcement be addressed within the operating plan. • Exelon voted negative vote on this ballot due to the need for further clarification and reconciliation between NERC EOP-004 and the NRC.

Individual

Keith Morisette

Tacoma Power

Yes

Tacoma Power agrees with the requirement but would suggest removing all instances the word "Operating" from the Standard. The requirements should read, " Each Responsible Entity shall have an "Event Reporting Plan...". The term Operating in this context is confusing as there are many other "Operating Plans" for other defined emergencies. This standard is about "Reporting" and should be confined to that.

Yes

Tacoma Power supports the revisions. It appears that all agencies and entities are willing to support the use of the DOE Form OE-417 as the initial notification form (although EOP-004 does include their own reporting form as an attachment to the Standard). Tacoma is already using the OE-417 and distributing it to all applicable Entities and Agencies.

No

Tacoma Power disagrees with the requirement to perform annual testing of each communication plan. We do not see any added value in performing annual testing of each communication plan. There are already other Standard requirements to performing routine testing of communications equipment and emergency communications with other agencies. The "proof of compliance" to the Standard should be in the documentation of the reports filed for any qualifying event, within the specified timelines and logs or phone records that it was communicated per each specified communication plan.

Tacoma Power disagrees with the requirement to perform annual testing of each communication plan. We do not see any added value in performing annual testing of each communication plan. There are already other Standard requirements to performing routine testing of communications equipment and emergency communications with other agencies. The "proof of compliance" to the Standard should be in the documentation of the reports filed for any qualifying event, within the specified timelines and logs or phone records that it was communicated per each specified communication plan. Tacoma Power has none at this time. Thank you for considering our comments.

Individual

Dennis Sismaet

Seattle City Light

Yes

This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.

Yes

This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.

No

Seattle City Light follows MEAG and believes this type of activity and process is better suited to NAESBE than it is to NERC Compliance.
1) Seattle City Light follows MEAG and questions if these administrative activities better should be sent over to NAESB? R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB's domain? R2, R3 & R4: These are not appropriate for a Standard. If you don't annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn't need to pile on. Mike Moon and Jim Merlo have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain. 2) Seattle City Light finds that even though efforts were made to differentiate between sabotage vs. criminal damage, the difference still appears to be confusing. Sabotage clearly requires FBI notification, but criminal damage (i.e. copper theft, trespassing, equipment theft) is best handled by local law agencies. A key point on how to determine the difference is to always go with the evidence. If you have a hole in the fence and cut grounding wires, this would only require local law enforcement notification. If there is a deliberate attack on a utility's BES infrastructure for intent of sabotage and or terrorism--this is a FBI notification event. One area where a potential for confusion arises is with the term "intentional human action" in defining damage. Shooting insulators on a rural transmission tower is not generally sabotage, but removing bolts from the tower may well be. Seattle understands the difficulty in differentiating these two cases, for example, and supports the proposed Standard, but would encourage additional clarification in this one area.
Individual
Scott Miller
MEAG Power
Yes
This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
Yes
This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
No
This type of activity and process is better suited to NAESBE than it is to NERC Compliance.
Should these administrative activities be sent over to NAESB? R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB's domain? R2, R3 & R4: These are not appropriate for a Standard. If you don't annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn't need to pile on. Mike Moon and Jim Merlo have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.
Group
FirstEnergy
Sam Ciccone
While FE voted affirmative on this draft, upon further review we request clarification be made in the next draft of the standard regarding the applicability of the Nuclear Generator Operator. Per FE's previous comments, nuclear generator operators already have specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(s)(xi). We had asked that the DSR SDT contact the NRC about this project to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the



potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. In addition, EOP-004 must acknowledge that there may be NRC reporting forms that have the equivalent information contained in their Attachment 2. For what the NRC considers a Reportable Event, Nuclear plants are required to fill out NRC form 361 and/or form 366. We do not agree with the drafting team's response to ours and Exelon's comments that "The NRC does not fall under the jurisdiction of NERC and so therefore it is not within scope of this project." While the statement is correct, we believe that requirements should not conflict with or duplicate other regulatory requirements. We remain concerned that the standard with regard to Nuclear GOP applicability causes duplicative regulatory reporting with existing reporting requirements of the NRC. Therefore, we ask: 1. That NERC and the drafting team please investigate these issues further and revise the standard to clarify the scope for nuclear GOPs, and 2. For any reporting deemed in the scope for nuclear GOP after NERC's and the SDT's investigation per our request in #1 above, that the SDT consider the ability to utilize information from NRC reports as meeting the EOP-004-2 requirements similar to the allowance of using the DOE form as presently proposed.

Individual

Patrick Brown

Essential Power, LLC

1. As this Standard does not deal with real-time reporting or analysis, and is simply considered an after the fact reporting process, I question the need for the Standard at all. This is a process that could be handled through a change to the Rules of Procedure rather than through a Standard. Developing this process as a Reliability Standard is, in my opinion, contrary to the shift toward Reliability-Based Standards Development. 2. I do not believe that establishing a reporting requirement improves the reliability of the BES, as stated in the purpose statement. The reporting requirement, however, would improve situational awareness. I recommend the purpose statement be changed to reflect this, and included with the process in the NERC Rules of Procedure.

Individual

Gregory Campoli

New York Independent System Operator

The NYISO is part of and supports comments submitted by NPCC Reliability Standards Committee and the IRC Standards Review Committee. However the NYISO would also like to comment on the following items: o NERC has been proposing the future development of performance based standards, which is directly related to reliability performance. Requirement 2 of this standard is simply a reporting requirement. We believe that this does not fall into a category of a performance based standard. NERC has the ability to ask for reports on events through ROP provisions and now the new Event Analysis Process. It does not have to make it part of the compliance program. Some have indicated that need for timely reporting of cyber or sabotage events. The counter argument is that the requirement is reporting when confirmed which would delay any useful information to fend off a simultaneous threat. Also NERC has not provided any records of how previous timely (1 hour) reporting has mitigated reliability risks. o The NERC Event Analysis Process was recently approved by the NERC OC and is in place. This was the model program for reporting outside the compliance program that the industry was asking for. This should replace the need for EOP-004. o NERC has presented Risk Based Compliance Monitoring (RBCM) to the CCC, MRC, BOT and at Workshops. This involves audit teams monitoring an entities controls to ensure they have things in place to maintain compliance with reliability rules. The proposed EOP-004 has created requirements that are controls to requirement R2, which is to file a report on predefined incidents. The RBCM is being presented as the auditor will make determinations on the detail of the sampling for compliance based on the assessment of controls an entity has in place to maintain compliance. It is also noted that compliance will not be assessed against these controls. As the APS example for COM-002 is presented in the

Workshop slides, the issue is that EOP-004 R1, R3 and R4 are controls for reporting; 1) have a plan, 2) test the plan, and 3) review the plan. While R2 is the only actionable requirement. The NYISO believes that all reporting requirements have been met by OE-417 and EAP reporting requirements and that EOP-004 has served its time. At a minimum, the NYISO would suggest that EOP-004 be simplified to just R2 (reporting requirement) and the other requirements be placed at the end of the RSAW to demonstrate a culture of compliance as presented by NERC.

Individual

Don Schmit

Nebraska Public Power District

No

1. The following comments are in regard to Attachment 1: A. The row [Event] titled "Damage or destruction of Facility": 1. In column 3 [Threshold for Reporting], the word "Affect" is vague note the following concerns: i. Does "Affect" include a broken crossarm damaged without the Facility relaying out of service. This could be considered to have an "Affect" on the IROL. ii. Would the answer be different if the line relayed out of service and auto-reclosed (short interruption) for the same damaged crossarm? We need clarity from the SDT in order to know when a report is due. 2. For clarification: Who initiates the report when the IROL interfaces spans between multiple entities? We know of an IROL that has no less than four entities that operate Facilities within the interface. Who initiates the report of the IROL is affected? All? B. The row [Event] titled "Any physical threat that could impact the operability of a Facility": 1. In Column 1 [Event] change the word "threat" to "attack", this aligns with the OE-417 report. 2. In Column 3 [Threshold for Reporting], align the threshold with the OE-417 form. C. The row [Event] titled "Transmission loss", in column 3 [Threshold for Reporting], the defined term "Transmission Facilities" is too vague. There needs to be a more description such that an entity clearly understands when an event is reportable and for what equipment. We would recommend the definition used in the Event Reporting Field Trial: An unexpected outage, contrary to design, of three or more BES elements caused by a common disturbance. Excluding successful automatic reclosing. For example: a. The loss of a combination of NERC-defined Facilities. b. The loss of an entire generation station of three or more generators (aggregate generation of 500 MW to 1,999 MW); combined cycle units are represented as one unit. D. The row [Event] titled "Complete or partial loss of monitoring": 1. In column 1 [Event], delete the words "or partial". This is subjective without definition, delete. 2. Also in column 1 [Event], delete the word "monitoring" and replace with Supervisory Control and Data Acquisition (SCADA). SCADA is defined term that explicitly calls out in the definition "monitoring and control" and is understood by the industry as such. 3. In column 2 [Entity with Reporting Responsibility], delete the words "or partial"; also delete the word "monitoring" and replace with SCADA. 4. In column 3 [Threshold for Reporting], reword to state "Complete loss of SCADA affecting a BES control center for >= 30 continuous minutes".

Individual

David Revill

GTC

Yes

No

Page 17 & 18, One Hour Reporting and Twenty-four Hour Reporting: append the introductory statements with the following: "meeting the threshold for reporting" after recognition of the event. Example: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hours of recognition of the event meeting the threshold for reporting. Page 19, system separation (islanding); Clarify the intent of this threshold for reporting: Load >= 100 MW and any generation; or Load >= 100 MW and Generation >= 100 MW, or some combination of load and generation totaling 100 MW.

Yes

With the exception of the RC and company personnel, it appears this proposed section captures the

same reporting obligations and to the same entities via R1.2. Recommend adjustments to R1.2 such that reportable events are submitted to NERC, RC, and company personnel.

For R2, please clarify how an entity can demonstrate that no reportable events were experienced. GTC recommends an allowance for a letter of attestation within M2.

Individual

Scott Berry

Indiana Municipal Power Agency

No

IMPA does not believe that both R3 and R4 are necessary and they are redundant to a degree. Generally, when performing an annual review of a process or procedure, the call numbers for agencies or entities are verified to be up to date. Also, in R3, what does "test" mean. It could mean have different meanings to registered entities and to auditors which does not promote consistency among the industry. IMPA recommends going with an annual review of the process and having the telephone numbers verified that are in the event reporting Operating Plan. IMPA also believes that the local and federal law enforcement agencies would rather go with a verification of contact information over being besieged by "test" reports. The way R3 is written gives the appearance that the SDT did not want to overwhelm the ERO with all of the "test" reports from the registered entities (by excluding them from the test notification).

No

The event "any physical threat that could impact the operability of a Facility" is not measurable and can be interpreted many ways by entities or auditors. IMPA recommend incorporating language that let's this be the judgment of the registered entity only. On the "voltage deviation on a Facility", IMPA recommends that only the TOP the experiences a voltage deviation be the one responsible for reporting. For generation loss and transmission loss, IMPA believes that the amount of loss needs to be associated with a time period or event (concurrent forced outages).

no comment

For 1.2 under R1, is the SDT leaving it up to the registered entities do decide which organizations will be contacted for each event listed in attachment 1 or do all of those organization need to be contacted for each event listed in attachment 1? The requirement needs to clearly communicate this clarification and be independent of the rationale language. Auditors will go by the requirement and not the rationale for the requirement. For 1.1 under R1, does each event need its own process of recognition or can one process be used to cover all the applicable events? The requirement needs to clearly communicate this clarification and be independent of the rationale language. Auditors will go by the requirement and not the rationale for the requirement. For 1.2 under R1, company personnel is used as an example but in the rationale for R1, the third line uses operating personnel. IMPA recommends changing the example in 1.2 to operating personnel which is used in the current version of CIP-001.

Individual

Christine Hasha

ERCOT

No

ERCOT has joined the IRC comments on this project and offers these additional comments. ERCOT requests that the measure be updated to say "acceptable evidence may include". As written, the measure reads that there is only one way to comply with the requirement. The Standards should note "what" an entity is required to do and not prescribe the "how".

Yes

No

ERCOT has joined the IRC comments on this project.

ERCOT has joined the IRC comments on this project and offers these additional comments. ERCOT supports the alternative approach submitted by the IRC. ERCOT requests that time horizons be added for each of the requirements as have been with other recent Reliability Standards projects. With regards to Attachment 1, ERCOT requests the following changes: • Modify "Generation loss" from "≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection" to "≥ 1,100 MW for entities in the

ERCOT Interconnection" and "≥ 1,000 MW for entities in the Quebec Interconnection". This is consistent with the DCS threshold and eliminates possible operator confusion since DCSs event are reported in the ERCOT interconnection at 80% of single largest contingency which equates to 1100 MW. • Modify "Transmission loss" from "Unintentional loss of three or more Transmission Facilities (excluding successful automatic reclosing)" to "Inconsequential loss of three or more Transmission Facilities not part of a single rated transmission path (excluding successful automatic reclosing)." If a single line is comprised of 3 or more sections, this should not be part of what is reported here as it is intended to be when you have a single event trip of 3 or more transmission facilities that is not part of its intended design. • ERCOT requests review of footnote 1. The footnote does not seem appropriate in including an example of a control center as the definition of a BES facility does not include control centers.

Individual

Molly Devine

Idaho Power Co.

Yes

But this is going to require that we create a new Operating Plan with test procedures and revision history.

No

I think that the category "Damage or destruction of a Facility" is too ambiguous, and the Threshold for Reporting criteria does not help to clarify the question. Any loss of a facility may result in the need for actions to get to the new operating point, would this be a reportable disturbance?

No

No opinion

No

Individual

Rebecca Moore Darrah

MISO

Yes

No

No

MISO agrees with and adopts the Comments of the IRC on this issue.

Individual

Nathan Mitchell

American Public Power Association

Yes

APPA appreciates the SDT making these requirements clearer as requested in our comments on the previous draft standard.

No

APPA in our comments on the previous draft of EOP-004-2 requested relief for small entities from this reporting/documentation standard. APPA suggested setting a 300 MW threshold for some of the criteria in Attachment 1. This suggestion was not accepted by the SDT. However, the SDT is still directed by FERC to "consider whether separate, less burdensome requirements for smaller entities may be appropriate. Therefore, APPA requests that the SDT provide relief to small entities by providing separate requirements for small entities by requiring reporting only when one of the four criteria in DOE-OE-417 are met: 1. Actual physical attack, 2. Actual cyber attack, 3. Complete operational failure, or 4. Electrical System Separation. APPA recommends this information should be reported to the small entity's BA as allowed in the DOE-OE-417 joint filing process.

Yes

The SDT needs to provide some relief for the small entities in regards to the VSL in the compliance section. APPA believes there should be no High or Severe VSLs for this standard. This is a reporting/documentation standard and does not affect BES reliability at all. It is APPA's opinion that this standard should be removed from the mandatory and enforceable NERC Reliability Standards and turned over to a working group within the NERC technical committees. Timely reporting of this outage data is already mandatory under Section 13(b) of the Federal Energy Administration Act of 1974. There are already civil and criminal penalties for violation of that Act. This standard is a duplicative mandatory reporting requirement with multiple monetary penalties for US registered entities. If this standard is approved, NERC must address this duplication in their filing with FERC. This duplicative reporting and the differences in requirements between DOE-OE-417 and NERC EOP-004-2 require an analysis by FERC of the small entity impact as required by the Regulatory Flexibility of Act of 1980

Group

ACES Power Marketing Standards Collaborators

Jason Marshall

No

(1) We agree with removing Part 1.4 and we agree with a requirement to periodically review the event reporting Operating Plan. However we are not convinced the review of the Operating Plan needs to be conducted annually. The event reporting Operating Plan likely will not change frequently so a biannual review seems more appropriate. (2) We also do not believe that Requirement R3 is needed at all. Requirement R3 compels the responsible entity to test their Operating Plan annually. We do not see how testing an Operating Plan that is largely administrative in nature contributes to reliability. Given that the drafting team is obligated to address the FERC directive regarding periodic testing, we suggest the Operating Plan should be tested biannually. This would still meet the FERC directive requiring periodic testing.

No

The drafting team made a number of positive changes to Attachment 1. However, there are a few changes that have introduced new issues and there are a number of existing issues that have yet to be fully addressed. One of the existing issues is that the reporting requirements will result in duplicate reporting. Considering that one of the stated purposes is to eliminate redundancy, we do not see how the scope of the SAR can be considered to be met until all duplicate reporting is eliminated. More specifics on our concerns are provided in the following discussion. (1) In the "Damage or destruction of a Facility" event, the statement "Affects an IROL (per FAC-014)" in the "Threshold for Reporting" is ambiguous. What does it mean? If the loss of a Facility will have a 1 MW flow change on the Facilities to which the IROL applies, is this considered to have affected the IROL? We suggest a more direct statement that damage or destruction occurred on a Facility to which the IROL applies or to one of the Facilities that comprise an IROL contingency as identified in FAC-014-2 R5.1.3. Otherwise, there will continue to be ambiguity over what constitutes "affects". (2) In the "Damage or destruction of a Facility" event, the threshold regarding "intentional human action" is ambiguous and suffers from the same difficulties as defining sabotage. What constitutes intentional? How do we know something was intentional without a law enforcement investigation? This is the same issue that prevented the drafting team from defining sabotage. (3) In the "Damage or destruction of a Facility" and "Any physical threat that could impact the operability of a Facility" events, Distribution Provider should be removed. Per the Function Model, the Distribution Provider does not have any Facilities (line, generator, shunt compensator, transformer). The only Distribution Provider equipment that even resembles a Facility would be capacitors (i.e. shunt compensator) but they do not qualify because they are not Bulk Electric System Elements. (4) The "Any physical threat that could impact the operability of a Facility" event requires duplicate reporting. For example, if a large generating plant experiences such a threat, who should report the event? What if loss of the plant could cause capacity and energy shortages as well as transmission limits? The end result is that the RC, BA, TOP, GO and GOP could all end up submitting a report for the same event. For a given operating area, only one report should be required from one registered entity for each event. (5) The "Any physical threat that could impact the operability of a Facility" event should not apply to a single Facility but rather multiple Facilities which if lost would impact BES reliability. As written now, a train derailment near a single 138 kV transmission line or small generator with minimal reliability impact would require reporting. (6) The "BES Emergency resulting in automatic firm load shedding" should not apply to the DP. In the existing EOP-004 standard, Distribution Provider is not included and the load shed information still gets reported. (7) The "Voltage deviation on a Facility" event needs to be clarified that the TOP only

reports voltage deviations in its Transmission Operator Area. Because TOPs may view into other Transmission Operator Areas, it could technically be required to report another TOP's voltage deviation because one of its System Operators observed the neighboring TOP's voltage deviation. (8) For the "Loss of firm load greater than 15 minutes" event, the potential for duplicate reporting needs to be eliminated. Every time a DP experiences this event, the DP, TOP and BA all appear to be required to report since the DP is within both the Balancing Authority Area and Transmission Operator Area. Only one report is necessary and should be sent. Given that the existing EOP-004 standard does not include the DP, we suggest eliminating the DP to eliminate one level of duplicate reporting. (9) For the "System separation (islanding)" event, please remove DP. As long as any island remains viable, the Distribution Provider will not even be aware that an island occurred. It is not responsible for monitoring frequency or having a wide area view. (10) For the "System separation (islanding)" event, please remove BA. Because islanding and system separation, involve Transmission Facilities automatically being removed from service, this is largely a Transmission Operator issue. This position is further supported by the approval of system restoration standard (EOP-005-2) that gives the responsibility to restore the system to the TOP. (11) For the "System separation (islanding)" event, please eliminate duplicate reporting by clarifying that the RC should submit the report when more than one TOP is involved. If only one TOP is involved, then the single TOP can submit the report or the RC could agree to do it on their behalf. Only one report is necessary. (12) For the "Generation loss" event, duplicate reporting should be eliminated. It is not necessary for both the BA and GOP to submit two separate reports with nearly identical information. Only one entity should be responsible for reporting. (13) For the "Complete loss of off-site power to a nuclear generating plant", the associated GO or GOP should be required to report rather than the TO or TOP. Maintaining power to cooling systems is ultimately the responsibility of the nuclear plant operator. At the very least, TO should be removed because it is not an operating entity and loss of off-site power is an operational issue. If the TOP remains in the reporting responsibility, it should be clarified that it is only a TOP with an agreement pursuant to NUC-001. All of this is further complicated because NUC-001 was written for a non-specific transmission entity because there was no one functional entity from which the nuclear plant operator gets its off-site power. (14) For the "Complete or partial loss of monitoring capability", partial loss needs to be further clarified. Is loss of a single RTU a partial loss of monitoring capability? For a large RC is loss of ICCP to a single small TOP, considered a partial loss? We suggest as long as the entity has the ability to monitor their system through other means that the event should not be reported. For the loss of a single RTU, if the entity has a solving state estimator that provides estimates for the area impacted, the partial threshold loss would not be considered. If the entity has another entity (i.e. perhaps the RC is still receiving data for its TOP area, the RC can monitor for the TOP) that can monitor their system as a backup, the partial loss has not been met.

No

(1) It is not clear to us what is the driving need for the Rules of Procedure proposal. NERC is already collecting event and disturbance reports without memorializing the change in the Rules of Procedure. (2) The language potentially conflicts with other subsections in Section 800. For instance, the proposal says that the system will apply to collect report forms "for this section". This section would refer to Section 800. Section 800 covers NERC alerts and GADS. Electronic GADS (eGADS) already has been established to collect GADS data? Will this section cause NERC to have to incorporate eGADS into this report collection system? Incorporating NERC Alerts is also problematic because when reports are required as a result of a NERC alert, the report must be submitted through the NERC Alert system. (3) The statement that "a system to collect report forms as established for this section or standard" causes additional confusion regarding to which standards it applies. Does it only apply to this new EOP-004-2 or to all standards? If it applies to all standards, does this create a potential issue for CIP-008-3 R1.3 which requires reporting to the ES-ISAC and not this clearinghouse?

(1) IC, TSP, TO, GO, and DP should be all removed from the applicability of the standard. Previous versions of the standard did not apply to them and we see no reason to expand applicability to them. IC and TSP are not even mentioned in any of the "Entity with Reporting Responsibility" sections. For the sections that do not mention specific entities, IC and TSP would have no responsibility for any of the events. The TO and GO are not operating entities so the reporting should not apply to them. DP was not included in any previous versions of CIP-001 or EOP-004. Any information (such as load) that was necessary regarding DPs was always gathered by the BA or TOP and included in their reports. There is no indication that this process was not working and, therefore, it should not be changed.

Furthermore, including the DP potentially expands the standard outside of the Bulk Electric System which is contrary to recent statements that NERC Legal has made at the April 11 and 12, 2012 SC meeting. Their comments indicated the standards are written for the Bulk Electric System. What information does a DP have to report except load loss which can easily be reported by the BA or TOP? (2) Measure M2 needs to clarify an attestation is an acceptable form of evidence if there are no events. (3) The rationale box for R3 and R4 should be modified. It in essence states that updating the event reporting Operating Plan and testing it will assure that the BES remains secure. While these requirements might contribute to reliability, these two requirements collectively will not assure BES security and stability. (4) We disagree with the VSLs for Requirement R2. While the VSLs associated with late reporting for a 24-hour reporting requirement include four VSLs, the one-hour reporting requirement only includes three VSLs. There seems to be no justification for this inconsistency. Four VSLs should be written for the one-hour reporting requirement. (5) Reporting of reportable Cyber Security Incidents does not appear to be fully coordinated with version 5 of the CIP standards. For instance, EOP-004-2 R1, Part 1.2 requires a process for reporting events to external entities and CIP-008-5 Part 1.5 requires identifying external groups to which to communicate Reportable Cyber Security Incidents. Thus, it appears the Cyber Security Incident response plan in CIP-008-5 R1 and the event reporting Operating Plan in EOP-004-2 R1 will compel duplication of external reporting at least in the document of the Operating Plain and Reportable Cyber Security Incident response plan. This needs to be resolved. (6) In the effective date section of the implementation plan, the statement that the prior version of the standard remains in effect until the new version is accepted by all applicable regulatory authorities is not correct. In areas where regulatory approval is required, it will only remain in effect in the areas where the regulator has not approved it. (7) On page 6 in the background section, the statement attributing RCIS reporting to the TOP standards is not accurate. There is no requirement in the TOP standards to report events across RCIS. In fact, the only mention of RCIS in the standards occurs in EOP-002-3 and COM-001-1.1. (8) On page 6 in the background section, the first sentence of the third paragraph is not completely aligned with the purpose statement of the standard. The statement in the background section indicates that the reliability objective "is to prevent outages which could lead to Cascading by effectively reporting events". However, the purpose states that the goal is to improve reliability. We think it would make more sense for the reliability objective to match the purpose statement more closely. (9) On page 7 in the first paragraph, "industry facility" should be changed to "Facility".

Group

Seattle City Light

Pawel Krupa

Yes

This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.

Yes

This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.

No

Seattle City Light follows MEAG and believes this type of activity and process is better suited to NAESBE than it is to NERC Compliance.

1) Seattle City Light follows MEAG and questions if these administrative activities better should be sent over to NAESB? R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB's domain? R2, R3 & R4: These are not appropriate for a Standard. If you don't annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn't need to pile on. Mike Moon and Jim Merlo have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain. 2) Seattle City Light finds that even though efforts were made to differentiate between sabotage vs. criminal damage, the difference still appears to be confusing. Sabotage clearly requires FBI notification, but criminal damage (i.e. copper theft, trespassing, equipment theft) is best handled by local law agencies. A key point on how to determine the difference is to always go with the evidence. If you have a hole in the fence and cut grounding

wires, this would only require local law enforcement notification. If there is a deliberate attack on a utility's BES infrastructure for intent of sabotage and or terrorism--this is a FBI notification event. One area where a potential for confusion arises is with the term "intentional human action" in defining damage. Shooting insulators on a rural transmission tower is not generally sabotage, but removing bolts from the tower may well be. Seattle understands the difficulty in differentiating these two cases, for example, and supports the proposed Standard, but would encourage additional clarification in this one area.

Individual

Tony Kroskey

Brazos Electric Power Cooperative

No

Please see the comments submitted by ACES Power Marketing.

No

Please see the comments submitted by ACES Power Marketing.

No

Please see the comments submitted by ACES Power Marketing.

We thank the work of the SDT on this project. However, additional improvements should be made as described in the comments submitted by ACES Power Marketing.

Individual

Darryl Curtis

Oncor Electric Delivery

Yes

Yes

Yes

Oncor takes the position that the proposed objectives as prescribed in Project 2009-01 – Disturbance and Sabotage Reporting, is a "good" step forward. Currently, NERC reporting obligations related to disturbances occurs over multiple standards including CIP-001, EOP-004-1, TOP-007-0, CIP-008-3 and Event Analysis (EA). Oncor is especially pleased that the Event Analysis Working Group (EAWG) is actively working to find ways of streamlining the disturbance reporting process especially to agencies outside of NERC such as FERC, and state agencies. Oncor is in agreement that an addition to the NERC Rules of Procedure in section 800 to develop a Reporting Clearinghouse for disturbance events by the establishment of a system to collect report and then forward completed forms to various requesting agencies, is also a very positive step."

Individual

Denise Lietz

Puget Sound Energy, Inc.

Yes

This draft is a considerable improvement on the previous draft in terms of clarity and will be much easier for Responsible Entities to implement. Puget Sound Energy appreciates the drafting team's responsiveness to stakeholder's concerns and the opportunity to comment on the current draft. The drafting team should revise Requirement R2 to state that the "activation" of the Operating Plan is required only when an event occurs, instead of using the term "implement". "Implementation" could also refer to the activities such as distributing the plan to operating personnel and training operating personnel on the use of the plan. These activities are not triggered by any event and, since it is clear from the measure that this requirement is intended to apply only when there has been a reportable event, the requirement should be revised to state that as well. The drafting team should revise measure M2 to require reports to be "supplemented by operator logs or other reporting documentation" only "as necessary". In many cases, the report itself and time-stamped record of transmittal will be the only documents necessary to demonstrate compliance with requirement R2. Under Requirement R3, using an actual event as sufficient for meeting the requirement for conducting



an annual test would likely fall short of demonstrating compliance with the entire scope of the Operating Plan. R1.2 requires "a process for communicating EACH of the applicable events listed...". If the actual event is only one of many "applicable" events, is it sufficient to only exercise one process flow? If there is no actual event during the annual time-frame, do all the process flows then have to be exercised?

No

The Note at the beginning of Attachment 1 references notifying parties per Requirement R1; however, notification occurs in conjunction with Requirement R2. The term "Adverse Reliability Impact" is used in the threshold section of the event "Damage or destruction of a Facility". At this time, there are two definitions for that term in the NERC Glossary. The FERC-approved definition for this term is "The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection." If the drafting team instead means to use the definition that NERC approved on 8/4/2011 (as seems likely, since that definition more closely aligns with the severity level indicated by the other two threshold statements) then the definition should be included in the Implementation Plan as a prerequisite approval. In addition, would the threshold of "Results from actual or suspected intentional human action" include results from actual intentional human action which produced an accidental result, meaning, someone was intentionally doing some authorized action but unintentionally made a mistake, leading to damage of a facility? The event "Any physical threat that could impact the operability of a Facility" will require reporting for many events that have little or no significance to reliable operation of the Bulk Electric System. For example, a balloon lodged in a 115 kV transmission line is a "physical threat" that could definitely "impact the operability" of that Facility and, yet, will probably have little reliability impact. So, too, could a car-pole accident that causes a pole to lean, a leaning tree, or an unfortunately-located bird's nest. The drafting team should develop appropriate threshold language so that reporting is required only for events that do threaten the reliability of the Bulk Electric System. With respect to the event "Unplanned control center evacuation", the standard drafting team should include the term "complete" in the description and/or threshold statement to avoid having partial evacuations trigger the need to report.

The effective date language in the Implementation Plan is inconsistent with the effective date language in the proposed standard. In addition, the statement of effective date in the Implementation Plan is ambiguous – will EOP-004-2 be effective in accordance with the first paragraph or when it is "assigned an effective date" as stated in the second paragraph? All requirements should be assigned a Lower Violation Risk Factor. Medium risk factors require direct impact on the Bulk Electric System and the language there regarding "instability, separation, or cascading failures" is present to distinguish the Medium risk factor from the High risk factor. Since all of the requirements address after-the-fact reporting, there can be no direct impact on the Bulk Electric System. In addition, if having an Operating Plan under Requirement R1 is a Lower risk factor, then it does not make sense that reviewing that Operating Plan annually under Requirement R4 has a higher risk factor. The shift away from "the distracting element of motivation", i.e., removing "Sabotage" from the equation, runs the risk of focusing solely on what happened, how to fix it, and waiting for the next event to occur. That speaks to a reactive approach rather than a proactive one. There is a concern with the removal of the FBI from the reporting mix. Basically, the new standard will involve reporting a suspicious event or attack to local law enforcement and leaving it up to them to decide on reporting to the FBI. Depending on their evaluation, an event which is significant for a responsible entity might not rise to the priority level of the local law enforcement agency for them to report it to the FBI. While this might reduce the reporting requirements a bit, it might do so to the responsible entity's detriment. In Attachment 2 - item 4, would it be possible for the boxes be either alpha-sorted or sorted by priority? There is a disconnect between footnote 1 on page 18 (Don't report copper theft) and the Guideline section, which suggests reporting forced intrusion attempt at a substation. Also, in the section discussing the removal of sabotage, the Guideline mentions certain types of events that should be reported to NERC, DHS, FBI, etc., while that specificity with respect to entities has been removed from the reporting requirement.

Individual

Steve Alexanderson

Central Lincoln

No
The new language of R3 and R4 provide nothing to clarify the word "annual." We note that while a Compliance Application Notice was written on this, Central Lincoln believes that standards should be written so they do not rely on the continually changing CANs. CAN-0010 itself implies that "annual" should be defined within the standards themselves. We suggest: R3 Each Responsible Entity shall conduct a test of the communications process in R1 Part 1.2, not including notification to the Electric Reliability Organization, at least once per calendar year with no more than 15 calendar months between tests. R4 Each Responsible Entity shall conduct a review of the event reporting Operating Plan in Requirement R1. at least at least once per calendar year with no more than 15 calendar months between reviews.
No
1) We appreciate the changes made to reduce the short time reporting requirements. 2) We would like to point out that the 24 hour reporting threshold for "Damage or destruction of a Facility" resulting from intentional human action will still be non-proportional BES risk for certain events. The discovery of a gunshot 115 kV insulator will start the 24 hour clock running, no matter how busy the discoverer is performing restoration or other duties that are more important. The damage may have been done a year earlier, but upon discovery the report suddenly becomes the priority task. To hit the insulator, the shooter likely had to take aim and pull the trigger, so intent is at least suspected if not actual. And the voltage level ensures the insulator is part of a Facility. 3) We also note that the theft of in service copper is not a physical threat, it is actual damage. The reference to Footnote 1 should be relocated or copied to the cell above the one it resides in now. 4) We support the APPA comments regarding small entities.
Yes
Thank you for minimizing the number of necessary reports.
We agree with the comments provided by both PNGC and APPA.
We agree with the comments provided by both PNGC and APPA.
We agree with the comments provided by both PNGC and APPA.
Individual
Mauricio Guardado
Los Angeles Department of Water and Power
Yes
No
LADWP has the following comments: #1 - "Any physical threat that could impact the operability of a Facility" is still vague and "operability" is too low a threshold. There needs to be a potential impact to BES reliability. #2 - "Voltage Deviation on a Facility" I think the threshold definition needs to be more specific: Is it 10% from nominal? 10% from normal min/max operating tables/schedules? Another entities 10% might be different than mine. #3 - "Transmission Loss" The threshold of three facilities is still too vague. A generator and a transformer and a gen-tie are likely to have overlapping zones of protection that could routinely take out all three. The prospect of penalties would likely cause unneeded reporting.
LADWP does not have a comment on this question at this time
LADWP does not have any other comments at this time
Group
Arkansas Electric Cooperative Corporation
Philip Huff
No
AECC supports the comments submitted by ACES Power Marketing.
No
AECC supports the comments submitted by ACES Power Marketing.
No
AECC supports the comments submitted by ACES Power Marketing.

Group
Avista
Scott Kinney
Yes
Yes
In general the SDT has made significant improvements to Attachment 1. Avista does have a suggestion to further improve Attachment 1. In Attachment 1 under the 24 hour Reporting Matrix, the second event states "Any physical threat that could impact the operability of a Facility" and the Threshold for Reporting states "Threat to a Facility excluding weather related threats". This is extremely open ended. We suggest adding the following language to the Threshold for Reporting for Any Physical Threat: Threat to a facility that: Could affect an IROL (per FAC-014) OR Could result in the need for actions to avoid and Adverse Reliability Impact This new language would be consistent with the reporting threshold for a Damage event.
Group
PNGC Comment Group
Ron Sporseen
Yes
Yes
We agree with reservations. Our comments are below and we are seeking clarification of the Applicability section of the standard. We are voting "no" but if slight changes are made to the applicability section we will change our votes to "yes". NERC and FERC have expressed a willingness to address the compliance burden on smaller entities that pose minimal risk to the Bulk Electric System. The PNGC Comment Group understands the SDT's intent to categorize reportable events and achieve an Adequate Level of Reliability while also understanding the costs associated. Given the changes made by the SDT to Attachment 1, we believe you have gone a long way in alleviating the potential for needless reporting from small entities that does not support reliability. One remaining concern we have are potential reporting requirements in the Event types; "Damage or destruction of a Facility" and "Any physical threat that could impact the operability of a Facility". These two event types have the following threshold language; "Results from actual or suspected intentional human action" and "Threat to a Facility excluding weather related threats" respectively. We believe these two thresholds could lead to very small entities filing reports for events that really are not a threat to the BES or Reliability. Note: For vandalism, sabotage or suspected terrorism, even the smallest entities will file a police report and at that point local law enforcement will follow their terrorism reporting procedures if necessary, as you've rightly indicated in your "Law Enforcement Reporting" section. We believe extraneous reporting could be alleviated with a small tweak to the Applicability section for 4.1.9 to exclude the smallest Distribution Providers. As stated before, even if these very small entities are excluded from filing reports under EOP-004-2, threats to Facilities that they may have will still be reported to local law enforcement while not cluttering up the NERC/DOE reporting process for real threats to the BES. Our suggested change: 4.1.9. Distribution Provider: with peak load >= 200 MWs The PNGC Comment Group arrived at the 200 MWs threshold after reviewing Attachment 1, Event "Loss of firm load for >= 15 Minutes". We agree with the SDT's intent to exclude these small firm load losses from reporting through EOP-004-2. Another approach we could support is that taken by the Project 2008-06 SDT with respect to Distribution Provider Facilities: 4.2.2 Distribution Provider: One or more of the Systems or programs designed, installed, and operated for the protection or restoration of the BES: • A UFLS or UVLS System that is part of a Load shedding program required by a NERC or Regional Reliability Standard and that performs automatic Load shedding under a common control system, without human operator initiation, of 300 MW or more • A Special Protection System or Remedial Action Scheme where the Special Protection System or Remedial Action Scheme is required by a NERC or Regional Reliability Standard • A Protection System that applies to Transmission where the Protection System is required by a NERC or Regional Reliability Standard •

Each Cranking Path and group of Elements meeting the initial switching requirements from a Blackstart Resource up to and including the first interconnection point of the starting station service of the next generation unit(s) to be started. We're not advocating this exact language but rather the approach that narrows the focus to what is truly impactful to reliability while minimizing costs and needless compliance burden. One last issue we have is with the language in Attachment 1, Event "BES Emergency resulting in automatic firm load shedding." Under "Entity with Reporting Responsibility", you state that the DP or TOP that "implements" automatic load shedding of  $\geq 100$  MWs must report (Also please review the CIP threshold of 300 MWs as this may be a more appropriate threshold). We believe rather than specifying a DP or TOP report, it would be appropriate for the UFLS Program Owner to file the report per EOP-004-2. In our situation we have DPs that own UFLS relays that are part of the TOP's program and this could lead to confusing reporting requirements. Also we don't believe that an entity can "Implement" "Automatic" load shedding but this is purely a semantic issue.

Yes

We appreciate the hard work of the SDT.

Group

Colorado Springs Utilities

Jennifer Eckels

Yes

Yes

Yes

CSU is concerned with the word 'damage'. We support any 'destruction' of a facility that meets any of the three criteria be a reportable issue, but 'damage', if it's going to be included should have some objective definition that sets a baseline.

Individual

James Tucker

Deseret Power

Yes

No

The threshold for reporting is way too low. A gun shot insulator is not an act of terrorism... vandalism yes... and a car hit pole would be reportable on a 138 kv line. these seem to be too aggressive in reporting.

Yes

Group

National Rural Electric Cooperative Association (NRECA)

Barry Lawson

No

NRECA is concerned with the drafting team's proposal to add a new Section 812 to the NERC ROP. NRECA does not see the need for the drafting team to make such a proposal as it relates to the new EOP-004 that the drafting team is working on. The requirements in the draft standard clearly require what is necessary for this Event Reporting standard. NRECA requests that the drafting team withdraw its proposed ROP Section 812 from consideration. The proposed language is unclear to the point of not being able to understand who is being required to do what. Further, the language is styled in

more of a proposal, and not in the style of what would appropriately be included in the NERC ROP. Finally, the SDT has not adequately supported the need for such a modification to the NERC ROP. Without that support, NRECA is not able to agree with the need for this addition to the ROP. Again, NRECA requests that the drafting team withdraw its proposed ROP Section 812 from consideration.

Individual

Michael Gammon

Kansas City Power & Light

No

Requirement 3 requires a test of the communications in the operating plan. A test implies a simulation of the communications part of the operating plan by actual communications being conducted pursuant to the plan. It is not appropriate to burden agencies with testing of communications under a test environment. Recommend the drafting team consider a confirmation of the contact information with various agencies as the operations plan dictates.

No

For the event, "Damage or destruction of a Facility", the "Threshold for reporting" includes "Results from actual or suspected intentional human action". This is too broad and could include events such as damage to equipment resulting from stealing cooper or wire which has no intentional motivation to disrupt the reliability of the bulk electric system. Reports of this type to law enforcement and governmental agencies will quickly appear as noise and begin to be treated as noise. This may result in overlooking a report that deserves attention. Recommend the drafting team consider making this threshold conditional on the judgment by the entity on the human action intended to be a potential threat to the reliability of the bulk electric system. For the event, "Any physical threat that could impact the operability of a Facility", the same comment as above applies. The footnote states to include copper theft if the Facility operation is impacted. Again, it is recommended to make a report of this nature conditional on the judgment of the entity on the intent to be a potential threat to the reliability of the bulk electric system.

No

Rules stipulating the extent of how reported information will be treated by NERC is an important consideration, however, the proposed section 812 proposes to provide reports to other governmental agencies and regulatory bodies beyond that of NERC and FERC. NERC should be treating the event information reported to NERC as confidential and should not take it upon itself to distribute such information beyond the boundaries of the national interest at NERC and FERC.

The flowchart states, "Notification Protocol to State Agency Law Enforcement". Please correct this to, "Notification to State, Provincial, or Local Law Enforcement", to be consistent with the language in the background section part, "A Reporting Process Solution – EOP-004". Evidence Retention – it is not clear what the phrase "prior 3 calendar years" represents in the third paragraph of this section regarding data retention for requirements and measures for R2, R3, R4 and M2, M3, M4 respectively. Please clarify what this means. Is that different than the meaning of "since the last audit for 3 calendar years" for R1 and M1?

## Consideration of Comments

### Disturbance and Sabotage Reporting – Project 2009-01

The Disturbance and Sabotage Reporting Drafting Team thanks all commenters who submitted comments on the draft standard EOP-004-2. This standard was posted for a 30-day public comment period from April 25, 2012 through May 24, 2012. Stakeholders were asked to provide feedback on the standards and associated documents through a special electronic comment form. There were 87 sets of comments, including comments from approximately 210 different people from approximately 135 companies representing 9 of the 10 Industry Segments as shown in the table on the following pages.

All comments submitted may be reviewed in their original format on the standard's project page:

[http://www.nerc.com/filez/standards/Project2009-01\\_Disturbance\\_Sabotage\\_Reporting.html](http://www.nerc.com/filez/standards/Project2009-01_Disturbance_Sabotage_Reporting.html)

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President of Standards and Training, Herb Schrayshuen, at 404-446-2560 or at [herb.schrayshuen@nerc.net](mailto:herb.schrayshuen@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

---

<sup>1</sup> The appeals process is in the Standard Processes Manual:

[http://www.nerc.com/files/Appendix\\_3A\\_Standard\\_Processes\\_Manual\\_Rev%201\\_20110825.pdf](http://www.nerc.com/files/Appendix_3A_Standard_Processes_Manual_Rev%201_20110825.pdf)

**Summary Consideration:** The DSR SDT received several suggestions for improvement to the standard. As a result of these revisions, the DSR SDT is posting the standard for a second successive ballot period.

The DSR SDT has removed reporting of Cyber Security Incidents from EOP-004 and have asked the team developing CIP-008-5 to retain this reporting. With this revision, the Interchange Coordinator, Transmission Service Providers, Load-Serving Entity, Electric Reliability Organization and Regional Entity were removed as Responsible Entities.

Most of the language contained in the “Background” Section was moved to the “Guidelines and Technical Basis” Section. Minor language changes were made to the measures and the data retention section. Attachment 2 was revised to list events in the same order in which they appear in Attachment 1.

Requirement R1 was revised to include the Parts in the main body of the Requirement. The Measure and VSLs were updated accordingly.

Following review of the industry’s comments, the SDT has re-examined the FERC Directive in Order 693 and has dropped both R3 and R4, as they were written and established a new Requirement R3 to have the Registered Entity “validate” the contact information in the contact list(s) they may have for the events applicable to them. This validation needs to be performed each calendar year to ensure that the list(s) have current and up-to-date contact data.

- R3. Each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*

The SDT reviewed, discussed and updated Attachment 1 based on comments received for commenters, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Under the Event Column, the SDT starts to classify each type of an event by assigning an “Event” title. The DSRSDT then updated the “Entity with Reporting Responsibilities” column to simply state which entity has the responsibility to report if they experience an event. The last column, “Threshold for Reporting” is a bright line that, if reached, the entity needs to report that they experienced the applicable event per Requirement 1.

The DSR SDT proposed a revision to the NERC Rules of Procedure (Section 812). The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.

**Index to Questions, Comments, and Responses**

1. The DSR SDT has revised EOP-004-2 by removing Requirement 1, Part 1.4 and separating Parts 1.3 and 1.5 into new Requirements R3 and R4. Requirement R3 calls for an annual test of the communications portion of the Operating Plan and Requirement R4 requires an annual review of the Operating Plan. Do you agree with this revision? If not, please explain in the comment area below. .... 19
2. The DSR SDT made clarifying revisions to Attachment 1 based on stakeholder feedback. Do you agree with these revisions? If not, please explain in the comment area below. .... 46
3. The DSR SDT has proposed a new Section 812 to be incorporated into the NERC Rules of Procedure. Do you agree with the proposed addition? If not, please explain in the comment area below. .... 169
4. Do you have any other comment, not expressed in the questions above, for the DSR SDT? .... 183



**The Industry Segments are:**

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
1.	Group	Guy Zito	Northeast Power Coordinating Council												X
Additional Member	Additional Organization	Region	Segment Selection												
1.	Alan Adamson	New York State Reliability Council, LLC	NPCC	10											

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
2.	Greg Campoli	NewYork Independent System Operator	NPCC	2																
3.	Sylvain Clermont	Hydro-Quebec TransEnergie	NPCC	1																
4.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.	NPCC	1																
5.	Gerry Dunbar	Northeast Power Coordinating Council	NPCC	10																
6.	Mike Garton	Dominion Resources Services, Inc.	NPCC	5																
7.	Kathleen Goodman	ISO - New England	NPCC	2																
8.	Michael Jones	National Grid	NPCC	1																
9.	David Kiguel	Hydro One Networks Inc.	NPCC	1																
10.	Michael Lombardi	Northeast Utilities	NPCC	1																
11.	Randy MacDonald	New Brunswick Power Transmission	NPCC	9																
12.	Bruce Metruck	New York Power Authority	NPCC	6																
13.	Silvia Parada Mitchell	NextEra Energy, LLC	NPCC	5																
14.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10																
15.	Robert Pellegrini	The United Illuminating Company	NPCC	1																
16.	Si Truc Phan	Hydro-Quebec TransEnergie	NPCC	1																
17.	David Ramkalawan	Ontario Power Generation, Inc.	NPCC	5																

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
18.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC	3																
19.	Michael Schiavone	National Grid	NPCC	1																
20.	Wayne Sipperly	New York Power Authority	NPCC	5																
21.	Tina Teng	Independent Electricity System Operator	NPCC	2																
22.	Donald Weaver	New Brunswick System Operator	NPCC	2																
23.	Ben Wu	Orange and Rockland Utilities	NPCC	1																
2.	Group	Kent Kujala	DECo			X	X	X												
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Barbara Holland		RFC	3, 4, 5																
2.	Alexander Eizans		RFC	3, 4, 5																
3.	Group	Greg Rowland	Duke Energy		X		X		X	X										
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1.	Doug Hils	Duke Energy	RFC	1																
2.	Ed Ernst	Duke Energy	SERC	3																
3.	Dale Goodwine	Duke Energy	SERC	5																
4.	Greg Cecil	Duke Energy	RFC	6																
4.	Group	Brenda Hampton	Luminant							X										

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	Mike Laney	Luminant Generation Company, LLC		5									
5.	Group	Patricia Robertson	BC Hydro		X	X	X		X				
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	Venkatarmakrishnan Vinnakota	BC Hydro	WECC	2									
2.	Pat G. Harrington	BC Hydro	WECC	3									
3.	Clement Ma	BC Hydro	WECC	5									
6.	Group	Chris Higgins	Bonneville Power Administration		X		X		X	X			
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	James	Burns	WECC	1									
2.	John	Wylder	WECC	1									
3.	Kristy	Humphrey	WECC	1									
7.	Group	Jesus Sammy Alcaraz	Imperial Irrigation District (IID)		X		X	X	X	X			
<b>Additional Member</b>		<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>									
1.	Joel Fugett	IID	WECC	1, 3, 4, 5, 6									
2.	Cathy Bretz	IID	WECC	1, 3, 4, 5, 6									
8.	Group	Connie Lowe	Dominion		X		X		X	X			

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																																																	
			1	2	3	4	5	6	7	8	9	10																																								
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Michael Crowley</td> <td>SERC</td> <td></td> <td>1, 3, 5, 6</td> </tr> <tr> <td>2. Mike Garton</td> <td>NPCC</td> <td></td> <td>5, 6</td> </tr> <tr> <td>3. Randi Heise</td> <td>MRO</td> <td></td> <td>5</td> </tr> <tr> <td>4. Louis Slade</td> <td>RFC</td> <td></td> <td>5</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Michael Crowley	SERC		1, 3, 5, 6	2. Mike Garton	NPCC		5, 6	3. Randi Heise	MRO		5	4. Louis Slade	RFC		5																				
Additional Member	Additional Organization	Region	Segment Selection																																																	
1. Michael Crowley	SERC		1, 3, 5, 6																																																	
2. Mike Garton	NPCC		5, 6																																																	
3. Randi Heise	MRO		5																																																	
4. Louis Slade	RFC		5																																																	
9.	Group	Robert Rhodes	SPP Standards Review Group		X																																															
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Matt Bordelon</td> <td>CLECO Power</td> <td>SPP</td> <td>1, 3, 5</td> </tr> <tr> <td>2. Michelle Corley</td> <td>CLECO Power</td> <td>SPP</td> <td>1, 3, 5</td> </tr> <tr> <td>3. Gary Cox</td> <td>Southwestern Power Administration</td> <td>SPP</td> <td>1, 5</td> </tr> <tr> <td>4. Dan Lusk</td> <td>Xcel Energy</td> <td>SPP</td> <td>1, 3, 5, 6</td> </tr> <tr> <td>5. Stephen McGie</td> <td>City of Coffeyville</td> <td>SPP</td> <td>NA</td> </tr> <tr> <td>6. John Payne</td> <td>KEPCO</td> <td>SPP</td> <td>4</td> </tr> <tr> <td>7. Terri Pyle</td> <td>Oklahoma Gas &amp; Electric</td> <td>SPP</td> <td>1, 3, 5</td> </tr> <tr> <td>8. Sean Simpson</td> <td>Board of Public Utilities, City of McPherson, KS</td> <td>SPP</td> <td>NA</td> </tr> <tr> <td>9. Ashley Stringer</td> <td>Oklahoma Municipal Power Authority</td> <td>SPP</td> <td>4</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Matt Bordelon	CLECO Power	SPP	1, 3, 5	2. Michelle Corley	CLECO Power	SPP	1, 3, 5	3. Gary Cox	Southwestern Power Administration	SPP	1, 5	4. Dan Lusk	Xcel Energy	SPP	1, 3, 5, 6	5. Stephen McGie	City of Coffeyville	SPP	NA	6. John Payne	KEPCO	SPP	4	7. Terri Pyle	Oklahoma Gas & Electric	SPP	1, 3, 5	8. Sean Simpson	Board of Public Utilities, City of McPherson, KS	SPP	NA	9. Ashley Stringer	Oklahoma Municipal Power Authority	SPP	4
Additional Member	Additional Organization	Region	Segment Selection																																																	
1. Matt Bordelon	CLECO Power	SPP	1, 3, 5																																																	
2. Michelle Corley	CLECO Power	SPP	1, 3, 5																																																	
3. Gary Cox	Southwestern Power Administration	SPP	1, 5																																																	
4. Dan Lusk	Xcel Energy	SPP	1, 3, 5, 6																																																	
5. Stephen McGie	City of Coffeyville	SPP	NA																																																	
6. John Payne	KEPCO	SPP	4																																																	
7. Terri Pyle	Oklahoma Gas & Electric	SPP	1, 3, 5																																																	
8. Sean Simpson	Board of Public Utilities, City of McPherson, KS	SPP	NA																																																	
9. Ashley Stringer	Oklahoma Municipal Power Authority	SPP	4																																																	

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
10. Mike Swearingen	Tri-County Electric Cooperative	SPP 4												
11. Michael Veillon	CLECO Power	SPP 1, 3, 5												
12. Mark Wurm	Board of Public Utilities, City of McPherson, KS	SPP NA												
13. Jonathan Hayes	Southwest Power Pool	SPP 2												
14. Julie Lux	Westar Energy	SPP 1, 3, 5, 6												
15. Greg McAuley	Oklahoma Gas & Electric	SPP 1, 3, 5												
10. Group	Frank Gaffney	Florida Municipal Power Agency	X		X	X	X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Timothy Beyrle	City of New Smyrna Beach	FRCC 4												
2. Jim Howard	Lakeland Electric	FRCC 3												
3. Greg Woessner	Kissimmee Utility Authority	FRCC 3												
4. Lynne Mila	City of Clewiston	FRCC 3												
5. Joe Stonecipher	Beaches Energy Services	FRCC 1												
6. Cairo Vanegas	Fort Pierce Utility Authority	FRCC 4												
7. Randy Hahn	Ocala Utility Services	FRCC 3												
11. Group	Brent Ingebrigtsen	LG&E and KU Services	X		X		X	X						
No additional members listed.														

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
12.	Group	WILL SMITH	MRO NSRF	X	X	X	X	X	X				X
Additional Member		Additional Organization	Region	Segment Selection									
1.	MAHMOOD SAFI	OPPD	MRO	1, 3, 5, 6									
2.	CHUCK LAWRENCE	ATC	MRO	1									
3.	TOM WEBB	WPS	MRO	3, 4, 5, 6									
4.	JODI JENSON	WAPA	MRO	1, 6									
5.	KEN GOLDSMITH	ALTW	MRO	4									
6.	ALICE IRELAND	XCEL	MRO	1, 3, 5, 6									
7.	DAVE RUDOLPH	BEPC	MRO	1, 3, 5, 6									
8.	ERIC RUSKAMP	LES	MRO	1, 3, 5, 6									
9.	JOE DEPOORTER	MGE	MRO	3, 4, 5, 6									
10.	SCOTT NICKELS	RPU	MRO	4									
11.	TERRY HARBOUR	MEC	MRO	3, 5, 6, 1									
12.	MARIE KNOX	MISO	MRO	2									
13.	LEE KITTELSON	OTP	MRO	1, 3, 4, 5									
14.	SCOTT BOS	MPW	MRO	1, 3, 5, 6									

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
15. TONY EDDLEMAN	NPPD	MRO	1, 3, 5											
16. MIKE BRYTOWSKI	GRE	MRO	1, 3, 5, 6											
17. THERESA ALLARD	MPC	MRO	1, 3, 5, 6											
13. Group	Stephen J. Berger	PPL Corporation NERC Registered Affiliates						X	X					
Additional Member	Additional Organization	Region	Segment Selection											
1.	Annette Bannon	PPL Generation, LLC on Behalf of its NERC Registered Entities	RFC	5										
2.			WECC	5										
3.	Mark Heimbach	PPL EnergyPlus, LLC	MRO	6										
4.			NPCC	6										
5.			SERC	6										
6.			SPP	6										
7.			RFC	6										
8.			WECC	6										
14. Group	Joe Tarantino	SMUD & BANC		X		X	X	X	X					
Additional Member	Additional Organization	Region	Segment Selection											



Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
1. Kevin Smith	BANC	WECC	1																	
15. Group	Albert DiCaprio	ISO/RTO Standards Review Committee		X																
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1. Terry Bilke	MISO	RFC	2																	
2. Greg Campoli	NY ISO	NPCC	2																	
3. Gary DeShazo	CAISO	WECC	2																	
4. Matt Goldberg	ISO NE	NPCC	2																	
5. Kathleen Goodman	ISO NE	NPCC	2																	
6. Stephanie Monzon	PJM	RFC	2																	
7. Steve Myers	ERCOT	ERCOT	2																	
8. Bill Phillips	MSO	RFC	2																	
9. Don Weaver	NBSO	NPCC	2																	
10. Charles Yeung	SPP	SPP	2																	
16. Group	Sam Ciccone	FirstEnergy		X		X	X	X	X											
<b>Additional Member Additional Organization Region Segment Selection</b>																				
1. Bill Duge	FE	RFC																		

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																			
			1	2	3	4	5	6	7	8	9	10										
2. Doug Hohlbaugh	FE	RFC																				
17.	Group	Jason Marshall	ACES Power Marketing Standards Collaborators															X				
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>		<b>Segment Selection</b>																
1.	Bill Hutchison	Southern Illinois Power Cooperative		SERC	1																	
2.	Robert A. Thomasson	Big Rivers Electric Corporation		SERC	1																	
3.	Shari Heino	Brazos Electric Power Cooperative		ERCOT	1																	
4.	John Shaver	Arizona Electric Power Cooperative		WECC	4, 5																	
5.	John Shaver	Southwest Transmission Cooperative		WECC	1																	
6.	Michael Brytowski	Great River Energy		MRO	1, 3, 5, 6																	
7.	Scott Brame	North Carolina Electric Membership Corporation		SERC	1, 3, 4, 5																	
18.	Group	Pawel Krupa	Seattle City Light										X		X	X						
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>		<b>Segment Selection</b>																
1.	Pawel Krupa	Seattle City Light	WECC	1																		
2.	Dana Wheelock	Seattle City Light	WECC	3																		
3.	Hao Li	Seattle City Light	WECC	4																		
19.	Group	Scott Kinney	Avista										X		X		X					

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																																																									
			1	2	3	4	5	6	7	8	9	10																																																
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Ed Groce</td> <td>Avista Corp</td> <td>WECC</td> <td>5</td> </tr> <tr> <td>2. Bob Lafferty</td> <td>Avista Corp</td> <td>WECC</td> <td>3</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Ed Groce	Avista Corp	WECC	5	2. Bob Lafferty	Avista Corp	WECC	3																																				
Additional Member	Additional Organization	Region	Segment Selection																																																									
1. Ed Groce	Avista Corp	WECC	5																																																									
2. Bob Lafferty	Avista Corp	WECC	3																																																									
20.	Group	Ron Sporseen	PNGC Comment Group																																																									
<table border="1"> <thead> <tr> <th>Additional Member</th> <th>Additional Organization</th> <th>Region</th> <th>Segment Selection</th> </tr> </thead> <tbody> <tr> <td>1. Joe Jarvis</td> <td>Blachly-Lane Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>2. Dave Markham</td> <td>Central Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>3. Dave Hagen</td> <td>Clearwater Power Company</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>4. Roman Gillen</td> <td>Consumers Power Inc.</td> <td>WECC</td> <td>1, 3</td> </tr> <tr> <td>5. Roger Meader</td> <td>Coos-Curry Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>6. Bryan Case</td> <td>Fall River Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>7. Rick Crinklaw</td> <td>Lane Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>8. Annie Terracciano</td> <td>Northern Lights Inc.</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>9. Aleka Scott</td> <td>PNGC Power</td> <td>WECC</td> <td>4</td> </tr> <tr> <td>10. Heber Carpenter</td> <td>Raft River Rural Electric Cooperative</td> <td>WECC</td> <td>3</td> </tr> <tr> <td>11. Steve Eldrige</td> <td>Umatilla Electric Cooperative</td> <td>WECC</td> <td>1, 3</td> </tr> </tbody> </table>													Additional Member	Additional Organization	Region	Segment Selection	1. Joe Jarvis	Blachly-Lane Electric Cooperative	WECC	3	2. Dave Markham	Central Electric Cooperative	WECC	3	3. Dave Hagen	Clearwater Power Company	WECC	3	4. Roman Gillen	Consumers Power Inc.	WECC	1, 3	5. Roger Meader	Coos-Curry Electric Cooperative	WECC	3	6. Bryan Case	Fall River Electric Cooperative	WECC	3	7. Rick Crinklaw	Lane Electric Cooperative	WECC	3	8. Annie Terracciano	Northern Lights Inc.	WECC	3	9. Aleka Scott	PNGC Power	WECC	4	10. Heber Carpenter	Raft River Rural Electric Cooperative	WECC	3	11. Steve Eldrige	Umatilla Electric Cooperative	WECC	1, 3
Additional Member	Additional Organization	Region	Segment Selection																																																									
1. Joe Jarvis	Blachly-Lane Electric Cooperative	WECC	3																																																									
2. Dave Markham	Central Electric Cooperative	WECC	3																																																									
3. Dave Hagen	Clearwater Power Company	WECC	3																																																									
4. Roman Gillen	Consumers Power Inc.	WECC	1, 3																																																									
5. Roger Meader	Coos-Curry Electric Cooperative	WECC	3																																																									
6. Bryan Case	Fall River Electric Cooperative	WECC	3																																																									
7. Rick Crinklaw	Lane Electric Cooperative	WECC	3																																																									
8. Annie Terracciano	Northern Lights Inc.	WECC	3																																																									
9. Aleka Scott	PNGC Power	WECC	4																																																									
10. Heber Carpenter	Raft River Rural Electric Cooperative	WECC	3																																																									
11. Steve Eldrige	Umatilla Electric Cooperative	WECC	1, 3																																																									
			X		X	X				X																																																		

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
12. Marc Farmer	West Oregon Electric Cooperative	WECC 4												
13. Margaret Ryan	PNGC Power	WECC 8												
14. Stuart Sloan	Consumers Power Inc.	WECC 1												
21. Group	Jennifer Eckels	Colorado Springs Utilities	X		X		X	X						
<b>Additional Member Additional Organization Region Segment Selection</b>														
1. Lisa Rosintoski		WECC 6												
2. Charlie Morgan		WECC 3												
3. Paul Morland		WECC 1												
22. Individual	Janet Smith, Regulatory Affairs Supervisor	Arizona Public Service Company	X		X		X	X						
23. Individual	Antonio Grayson	Southern Company Services	X		X		X	X						
24. Individual	Jim Eckelkamp	Progress Energy	X		X		X	X						
25. Individual	Sasa Maljukan	Hydro One	X											
26. Individual	John Brockhan	CenterPoint Energy	X											
27. Individual	Philip Huff	Arkansas Electric Cooperative Corporation			X	X		X						
28. Individual	Barry Lawson	National Rural Electric Cooperative Association (NRECA)			X	X								
29. Individual	Brian Evans-Mongeon	Utility Services										X		
30. Individual	E Hahn	MWDSC	X											
31. Individual	Scott McGough	Georgia System Operations Corporation			X	X								
32. Individual	Don Jones	Texas Reliability Entity												X

Group/Individual		Commenter	Organization	Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
33.	Individual	Jonathan Appelbaum	United Illuminating Company	X											
34.	Individual	Dan Roethemeyer	Dynegy Inc.					X							
35.	Individual	Anthony Jablonski	ReliabilityFirst												X
36.	Individual	Joe Petaski	Manitoba Hydro	X		X		X	X						
37.	Individual	Michelle R. D'Antuono	Ingleside Cogeneration LP					X							
38.	Individual	Tim Soles	Occidental Power Services, Inc.			X			X						
39.	Individual	Alice Ireland	Xcel Energy	X		X		X	X						
40.	Individual	Andrew Gallo	City of Austin dba Austin Energy	X		X	X	X	X						
41.	Individual	Thad Ness	American Electric Power	X		X		X	X						
42.	Individual	Ed Davis	Entergy	X		X		X	X						
43.	Individual	Jack Stamper	Clark Public Utilities	X											
44.	Individual	Tracy Richardson	Springfield Utility Board			X									
45.	Individual	Wayne Sipperly	New York Power Authority	X		X		X	X						
46.	Individual	David Thorne	Pepco Holdings Inc	X		X									
47.	Individual	Chris de Graffenried	Consolidated Edison Co. of NY, Inc.	X		X		X	X						
48.	Individual	David Burke	Orange and Rockland Utilities, Inc.	X		X									
49.	Individual	Larry Raczkowski	FirstEnergy Corp	X		X	X	X	X						
50.	Individual	Linda Jacobson-Quinn	Farmington Electric Utility System			X									
51.	Individual	Michael Falvo	Independent Electricity System Operator		X										
52.	Individual	John Seelke	Public Service Enterprise Group	X		X		X	X						
53.	Individual	Terry Harbour	MidAmerican Energy	X		X		X	X						
54.	Individual	Brenda Lyn Truhe	PPL Electric Utilities	X											
55.	Individual	John Martinsen	Public Utility District No. 1 of Snohomish County	X		X	X	X	X						

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
56.	Individual	Russell A. Noble	Cowlitz County PUD			X	X	X						
57.	Individual	Thomas Washburn	FMPP						X					
58.	Individual	Bob Thomas	Illinois Municipal Electric Agency				X							
59.	Individual	Andrew Z. Puztai	Americian Transmission Company, LLC	X										
60.	Individual	Brenda Frazer	Edison Mission Marketing & Trading, Inc.	X				X						
61.	Individual	Kenneth A Goldsmith	Alliant Energy				X							
62.	Individual	Eric Salsbury	Consumers Energy			X	X	X						
63.	Individual	Kirit Shah	Ameren	X		X		X	X					
64.	Individual	Howard Rulf	We Energies			X	X	X						
65.	Individual	Brian J Murphy	NextEra Energy Inc	X		X		X	X					
66.	Individual	Kathleen Goodman	ISO New England Inc		X									
67.	Individual	Mark B Thompson	Alberta Electric System Operator		X									
68.	Individual	Maggy Powell	Exelon Corporation and its affiliates	X		X		X	X					
69.	Individual	Keith Morisette	Tacoma Power	X		X	X	X	X					
70.	Individual	Dennis Sismaet	Seattle City Light						X					
71.	Individual	Scott Miller	MEAG Power	X		X		X						
72.	Individual	Patrick Brown	Essential Power, LLC					X						
73.	Individual	Gregory Campoli	New York Independent System Operator		X									
74.	Individual	Don Schmit	Nebraska Public Power District	X		X		X						
75.	Individual	David Revill	GTC	X										
76.	Individual	Scott Berry	Indiana Municipal Power Agency				X							
77.	Individual	Christine Hasha	ERCOT		X									
78.	Individual	Molly Devine	Idaho Power Co.	X										
79.	Individual	Rebecca Moore Darrah	MISO		X									

Group/Individual		Commenter	Organization	Registered Ballot Body Segment									
				1	2	3	4	5	6	7	8	9	10
80.	Individual	Nathan Mitchell	American Public Power Association			X							
81.	Individual	Tony Kroskey	Brazos Electric Power Cooperative	X									
82.	Individual	Darryl Curtis	Oncor Electric Delivery	X									
83.	Individual	Denise Lietz	Puget Sound Energy, Inc.	X		X		X					
84.	Individual	Steve Alexanderson	Central Lincoln			X	X					X	
85.	Individual	Mauricio Guardado	Los Angeles Department of Water and Power	X		X		X	X				
86.	Individual	James Tucker	Deseret Power	X									
87.	Individual	Michael Gammon	Kansas City Power & Light	X		X		X	X				

1. The SDT has revised EOP-004-2 by removing Requirement 1, Part 1.4 and separating Parts 1.3 and 1.5 into new Requirements R3 and R4. Requirement R3 calls for an annual test of the communications portion of the Operating Plan and Requirement R4 requires an annual review of the Operating Plan. Do you agree with this revision? If not, please explain in the comment area below.

**Summary Consideration:** Following review of the industry’s comments, the SDT has re-examined the FERC Directive in Order 693 and has dropped both R3 and R4, as they were written and established a new Requirement R3 to have the Registered Entity “validate” the contact information in the contact list(s) they may have for the applicable events to their functional registration(s). This validation needs to be performed on a calendar year period to ensure that the list(s) have current and up-to-date contact data.

Organization	Yes or No	Question 1 Comment
Northeast Power Coordinating Council	No	<p>Regarding Requirement R3, add the following wording from Measure M3 to the end of R3 after the wording “in Part 1.2.”: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable.</p> <p>Regarding Requirement R4, replace the words “an annual review” with the words “a periodic review. “Add the following to R4: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years. This does not preclude an annual review in an Entity’s operating plan. The Entity will then be audited to its plan. If the industry approves a five (5) year periodic review ‘cap’, and FERC disagrees, then FERC will have to issue a directive, state its reasons and provide justification for an annual review that is not arbitrary or capricious. Adding the one year “test” requirement adds to the administrative tracking burden and adds no reliability value.</p>



Organization	Yes or No	Question 1 Comment
<p><b>Response: The SDT thanks you for your comment. The SDT has removed R4 and revised R3 that calls for the responsible entity to validate contact information contain in the Operating Plan each calendar year as described in Requirement R1. The “Annual review” is used to ensure that the event reporting Operating Plan is up to date. If an entity experiences an event, communication evidence from the event may be used to show compliance.</b></p>		
DECo	No	Should only have annual "review" requirement rather than test.
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		
Duke Energy	No	Under R3, we agree with testing communications internally. Just as the ERO is excluded under R3, other external entities should also be excluded. External communications should be verified under R4.
<p><b>Response: The SDT thanks you for your comment. Due to industry opposition, the SDT revised Requirement R3 to remove test to “validate” contact information contained in the Operating Plan. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.</b></p>		
Dominion	No	While Dominion believes these are positive changes, we are concerned that placing actual calls to each of the “other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies” may be seen by one or more of those called as a ‘nuisance call’. Given the intent is to insure validity of the contact information (phone number, email, etc), we suggest revising the standard language to support various forms of validation to include, documented send/receipt of email, documented verification of phone number (use of phone book, directory assistance, etc).
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b></p>		

Organization	Yes or No	Question 1 Comment
SPP Standards Review Group	No	<p>There needs to be a more granular definition of which entities should be included in the annual testing requirement in R3. To clarify what must be tested we propose the following language to replace the last sentence in M3. The annual test requirement is considered to be met if the responsible entity implements any communications process in the Operating Plan during an actual event. If no actual event was reported during the year, at least one of the communication processes in the Operating Plan must be tested to satisfy the requirement. We do not believe the time-stamping requirement in M3 and M4 contribute to the reliability of the BES. A dated review should be sufficient.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comments. The Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event. Time-stamping has been removed.</b></p>		
Florida Municipal Power Agency	No	<p>First, FMPA believes the standard is much improved from the last posting and we thank the SDT or their hard work. Having said that, there are still a number of issues, mostly due to ambiguity in terms, which cause us to vote Negative. R3 and R4 should be combined into a single requirement with two subparts, one for annual testing, and another to incorporate lessons learned from the annual testing into the plan (as opposed to an annual review).The word “test” is ambiguous as used in R3, e.g., does a table top drill count as a “test”? Is the intent to “test” the plan, or “test” the phone numbers, or what?</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b></p>		
MRO NSRF	No	<p>R3 states: Each Responsible Entity shall conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2. R1.2 states: A process for communicating each of the</p>

Organization	Yes or No	Question 1 Comment
		<p>applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies. With the use of "i.e." the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that "e.g." should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity. R3 requires and annual test that would include notification of:"other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies."Since NERC see no value in receiving these test notification we are doubtful other entities identified in R1.2 would find them of value. The real purpose of this requirement appears to be to assure operators are trained in the use of the procedure, process, or plan that assures proper notification. PER-005 already requires a systematic approach to training. It is hard to comprehend an organization not identifying this as a Critical Task, and if they failed to identify it as a Critical Task that this would not be a violation. Therefore this requirement is not required. Furthermore organizations test their response to events in accordance with CIP-008 R1.6. Therefore this requirement is covered by other standards and is not needed. The SDT may need to address this within M3, by stating "... that the annual test of the communication process of 1.2 (e.g. communication via e-mail, fax, phone, etc) was conducted".</p> <p>R4 states: Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1. We question the value of requiring an annual review. If the Standard does not change, there seems little value in requiring an annual review. This appears to be an administrative requirement with little reliability value. It would likely be identified as a requirement that that should be eliminated as part of the</p>

Organization	Yes or No	Question 1 Comment
		request by FERC to identify strictly administrative requirements in FERC's recent order on FFTR. We suggest it be eliminated.
<p><b>Response: The SDT thanks you for your comment. Requirement R3 called for test of all contact information contain. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p> <p><b>The annual review requirement was maintained to meet the intent of NERC Order 693, Paragraph 466. The Commission does not specify a review period, as suggested; rather, believes that the appropriate period should be determined through the ERO's Reliability Standards.</b></p> <p><b>"The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures."</b></p>		
ISO/RTO Standards Review Committee	No	<p>The SRC offers comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see the latter part of the SRC's response to Question 4 below for an SRC proposed alternative approach: Regarding the proposed posted requirements, without indicating support of those requirements, the SRC concurs with the changes as they provide better streamlining of the four key requirements, with enhanced clarity. However, we are unclear on the intent of Requirement R3, in particular the phrase "not including notification to the Electric Reliability Organization" which begs the question on whether or not the test requires notifying all the other entities as if it were a real event. This may create confusion in ensuring compliance and during audits. Suggest the SDT to review and modify this requirement as appropriate. Regarding part 1.2, the SRC requests that the text be terminated after the word "type" and before "i.e." As written, the requirement does not allow for the entity to add/remove others as necessary. Please consider combining R3 and R4.</p>

Organization	Yes or No	Question 1 Comment
		<p>These can be accomplished at the same time. The process should be evaluated to determine effectiveness when an exercise or test is conducted. The SDT is asked to review the proposal and to address the issue of requirements vs. bullets vs. sub-requirements. It is suggested that each requirement be listed independently, and that each sub-step be bulleted.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b></p>		
<p>ACES Power Marketing Standards Collaborators</p>	<p>No</p>	<p>(1) We agree with removing Part 1.4 and we agree with a requirement to periodically review the event reporting Operating Plan. However we are not convinced the review of the Operating Plan needs to be conducted annually. The event reporting Operating Plan likely will not change frequently so a biannual review seems more appropriate.</p> <p>(2) We also do not believe that Requirement R3 is needed at all. Requirement R3 compels the responsible entity to test their Operating Plan annually. We do not see how testing an Operating Plan that is largely administrative in nature contributes to reliability. Given that the drafting team is obligated to address the FERC directive regarding periodic testing, we suggest the Operating Plan should be tested biannually. This would still meet the FERC directive requiring periodic testing.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
<p>Southern Company Services</p>	<p>No</p>	<p>There are approximately 17 event types for which Responsible Entities must have a process for communicating such events to the appropriate entities and R3 states that “The Responsible Entity shall conduct an annual test of the communications process”. It is likely that the same communications process will be used to report multiple event types, so Southern suggest that</p>

Organization	Yes or No	Question 1 Comment
		<p>the Responsible Entities conduct an annual test for each unique communications process. Southern suggest that this requirement be revised to state “Each Responsible Entity shall conduct an annual test of each unique communications process addressed in R1.2”.</p> <ul style="list-style-type: none"> <li>o In Attachment 1, for Event: “Damage or destruction of a Facility”, SDT should consider removing “Results from actual or suspected intentional human action” from the “Threshold for Reporting” column. The basis for this suggestion is as follows: <ul style="list-style-type: none"> <li>o The actual threshold should be measurable, similar to the thresholds specified for other events in Attachment 1. [Note: The first two thresholds identified (i.e., “Affects and IROL” and “Results in the need for actions to avoid an Adverse Reliability Impact”) are measurable and sufficiently qualify which types of Facility damage should be reported.]</li> <li>o The determination of human intent is too subjective. Including this as a threshold will cause many events to be reported that otherwise may not need to be reported. (e.g., Vandalism and copper theft, while addressed under physical threats, is more appropriately classified as damage. These are generally intentional human acts and would qualify for reporting under the current guidance in Attachment 1. They may be excluded from reporting by the threshold criteria regarding IROLs and Adverse Reliability Impact, if the human intent threshold is removed.)</li> <li>o It may be more appropriate to address human intent in the event description as follows: “Damage or destruction of a Facility, whether from natural or human causes”. Let the thresholds related to BES impact dictate the reporting requirement.</li> <li>o In Attachment 1, for Event: “Complete or partial loss of monitoring capability”, SDT should consider changing the threshold criteria to state: “Affecting a BES control center for 30 continuous minutes such that analysis capability (State Estimator, Contingency Analysis) is rendered</li> </ul> </li> </ul>

Organization	Yes or No	Question 1 Comment
		<p>inoperable.” There may be instances where the tools themselves are out of commission, but the control center personnel have sufficiently accurate models and alternate methods of performing the required analyses.</p>
<p><b>Response:</b> The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your initial comment.</p> <p>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Under the Event Column, the SDT starts to classify each type of an event by assigning an “Event” title. The DSR SDT then updated the “Entity with Reporting Responsibilities” column to simply state what entity has the responsibility to report if they experience an event. The last column, “Threshold for Reporting” is a bright line that, if reached, the entity needs to report that they experienced the applicable event per Requirement 1.</p> <p><b>Damage or destruction of a Facility:</b></p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state;</p> <p><b>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</b></p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p>		

Organization	Yes or No	Question 1 Comment
Progress Energy	No	<p>It should be clear that the Operating Plan can be multiple procedures. It is an unnecessary burden to have entities create a new document outlining the Operating Plan. Having to create a new Operating Plan would not improve reliability and would further burden limited resources. The annual testing required by R3 should be clarified. Do all communication paths need to be annually tested or just one path? An actual event may only utilize one communication 'leg' or 'path' and leave others untested and utilized. Entities may have a corporate level procedure that 'hand-shakes' with more localized procedures that make up the entire Operating Plan. Must all communications processes be tested to fulfill the requirement? If an entity has 'an actual event' it is not necessarily true that their Operating Plan has been exercised completely, yet this one 'actual event' would satisfy M3 as written.</p>
<p><b>Response: The SDT thanks you for your comment. Regarding your initial comment on the need to create a new document, the SDT believes that a Registered Entity with a procedure under CIP-001 will be able to utilize that document as the starting point for the Operating Plan here. The SDT feels that many of the necessary components will already exist in that document and the Registered Entity should only need to edit it accordingly for the types of Events applicable to them. The SDT has made changes to the standard highlighted in your comment.</b></p>		
Hydro One	No	<p>In the Requirement R3, we suggest adding the following wording from Measure M3 to the end of R3 after the wording “in Part 1.2.”: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable.</p> <p>Statement “... not including notification to the ERO...” as it stands now is confusing. We suggest that this statement is either reworded (and explained in the Rational for this requirement) or outright removed for clarity purposes In the requirement R4, we suggest replacing the words “an annual</p>



Organization	Yes or No	Question 1 Comment
		<p>review” with the words “a periodic review.” Add the following to R4: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years. This does not preclude an annual review in an Entity’s operating plan. The Entity will then be audited to its plan. If the industry approves a five (5) year periodic review ‘cap,’ and FERC disagrees, then FERC will have to issue a directive, state it reasons and provide justification for an annual review that is not arbitrary or capricious. Adding the one year “test” requirement adds to the administrative tracking burden and adds no reliability value.</p> <p>The table in the standard is clear regarding what events need to be reported. An auditor may want to see a test for "each" of the applicable events listed in EOP-004 Attachment 1.If the requirement for "an" annual test remains in the standard in R3, then it should be made clear that a test is not required for "each" of the applicable events listed in Attachment 1 (reference to R1.2.)</p>
<p><b>Response: The SDT thanks you for your comment. Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004 Attachment 1. The SDT removed the Operating Plan Process from Requirement 1 and revised the measure to meet the communications of Requirement R1, “to implement an operating plan within the time frames specified in Attachment 1.” Requirement R3 called for test of all contact information contained. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
CenterPoint Energy	No	CenterPoint Energy recommends that “and implement” be added after “Each Responsible Entity shall have” in Requirement R1. After such revision, Requirement R2 will not be needed as noted in previous comments submitted by the Company.

Organization	Yes or No	Question 1 Comment
		CenterPoint Energy also believes that Requirement R3 is not needed as an annual review encompassing the elements of the test described in the draft is sufficient.
<p><b>Response: The SDT thanks you for your comment. The SDT considered the consolidation of the first and second requirements. However, since the requirements have the Registered Entity perform two distinct steps, a single requirement cannot be written to achieve multiple tasks. Each task must stand on its own and be judged singly.</b></p> <p><b>The annual review helps ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Arkansas Electric Cooperative Corporation	No	AECC supports the comments submitted by ACES Power Marketing.
<p><b>Response: The SDT thanks you for your comment. Please review the response directed to them.</b></p>		
MWDSC	No	Transmission Owners (TO) should not be included as a "Responsible Entity" for this or other requirements because the Operating Plan is usually prepared by the Transmission Operator (TOP). For TOs who are not also TOPs, there are usually delegation agreements. CIP-001 never directly applied to TOs.
<p><b>Response: The SDT thanks you for your comment. The SDT disagrees with your assessment, as the TOs are physical owners of the equipment that would be affected by this standard. As Owners of the equipment, they need to be reporting on what is happening to their equipment.</b></p>		
Manitoba Hydro	No	(R1.1 and 1.2) It is unclear whether or not R1.1 and R1.2 require a separate recognition and communication process for each of the event types listed in Attachment 1 or if event types can be grouped as determined appropriate by the responsible entity given that identical processes will apply for multiple types of events. Manitoba Hydro suggests that wording is revised so

Organization	Yes or No	Question 1 Comment
		<p>that multiple event types can be addressed by a single process as deemed appropriate by the Responsible Entity.</p> <p>(R3) It is unclear whether or not R3 requires the testing of the communications process for each separate event type identified in Attachment 1. If so, this would be extremely onerous. Manitoba Hydro suggests that only unique communication processes (as identified by the Responsible Entity in R1.2) require an annual test and that testing should not be required for each type of event listed in Attachment 1. As well, Manitoba Hydro believes that testing the communications process alone is not as effective as also providing training to applicable personnel on the communications process. Manitoba Hydro suggests that R3 be revised to require annual training to applicable personnel on the communications process and that only 1 test per unique communications process be required annually.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comments. Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004 Attachment 1. The SDT has attempted to clarify that it is the choice of the Registered Entity on whether one, or more than one, contact list(s) is needed for the differing types applicable to them. Depending upon your needs of who you have an obligation to report, you can elect to have one or multiple lists.</b></p> <p><b>Requirement R3 called for test of all contact information contained. The SDT deleted Requirement R4 based on stakeholder comments and revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Occidental Power Services, Inc.	No	<p>There should be an exception for LSEs with no BES assets from having an Operating Plan and, therefore, from testing and review of such plan. These LSEs have no reporting responsibilities under Attachment 1 and, if they have nothing ever to report, why would they have to have an Operating Plan and have to test and review it? This places an undue burden on small entities</p>

Organization	Yes or No	Question 1 Comment
		that cannot impact the BES.
<p><b>Response: The SDT thanks you for your comment. LSEs, as being applicable under the Cyber Security standards, were included in the applicability of this standard. Since the SDT is proposing to keep the Cyber Security reporting requirements in CIP-008, LSEs have been removed from the applicability of this standard. This action will not negate the LSE responsibilities under that standard and your comments will need to be addressed there.</b></p>		
Xcel Energy	No	<p>1) In R1.2, We understand what the drafting team had intended here. However, we are concerned that the way this requirement is drafted, using i.e., it could easily be interpreted to mean that you must notify all of those entities listed. Instead, we are suggesting that the requirement be rewritten to require entities to define in their Operating Plan the minimum organizations/entities that would need to be notified for applicable events. We believe this would remove any ambiguity and make it clear for both the registered entity and regional staff. We recommend the requirement read something like this: 1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to applicable internal and external organizations needed for the event type, as defined in the Responsible Entity's Operating Plan.</p> <p>2) We also suggest that R3 be clarified as to whether communications to all organizations must be tested or just those applicable to the test event type/scenario.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comments.</b></p>		
American Electric Power	No	R3: How many different scenarios need to be tested? For example, reporting sabotage-related events might well be different than reporting reliability-related events such as those regarding loss of Transmission. While these

Organization	Yes or No	Question 1 Comment
		<p>examples might vary a great deal, other such scenarios may be very similar in nature in terms of communication procedures. Perhaps solely testing the most complex procedure would be sufficient. AEP agrees with the changes with R3 calling for an annual test provided the requirement R2 is modified to include the measure language “The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event.”</p> <p>M3: While we agree that “the annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event”, we believe it would be preferable to include this text in R3 in addition to M3. Measures included in earlier standards (some of which are still enforced today) had little correlation to the requirement itself, and as a result, those measures were seldom referenced.</p> <p>M3: It would be unfair to assume that every piece of evidence required to prove compliance would be dated and time-stamped, so we recommend removing the text “dated and time-stamped” from the first sentence so that it reads “Each Responsible Entity will have records to show that the annual test of Part 1.2 was conducted.” The language regarding dating and time stamps in regards to “voice recordings and operating logs or other communication” is sufficient.</p>
<p><b>Response: The SDT thanks you for your comment. Based on stakeholder comments the SDT revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization. The SDT agrees with the point raised on time-stamping and has removed it from the standard.</b></p>		
Entergy	No	The requirement for a “time stamped record” of annual review is unreasonable and unnecessary. A dated document showing that a review was performed should be sufficient.

Organization	Yes or No	Question 1 Comment
<b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment. The SDT has removed time-stamping from the standard.</b>		
New York Power Authority	No	Please see comments submitted by NPCC Regional Standards Committee (RSC).
<b>Response: The SDT thanks you for your comment. Please review the response to the commenter.</b>		
Consolidated Edison Co. of NY, Inc.	No	Requirement R3: Following the sentence ending “in Part 1.2” add the following wording from the Measure to R3: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Requirement R4: Replace the words “an annual review” with the words “a periodic review.” Following the first sentence in R4 add: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years.
Orange and Rockland Utilities, Inc.	No	Requirement R3: Following the sentence ending “in Part 1.2” add the following wording from the Measure to R3: The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. This language must be in the Requirement to be considered during an audit. Measures are not auditable. Requirement R4: Replace the words “an annual review” with the words “a periodic review.” Following the first sentence in R4 add: The frequency of such periodic reviews shall be specified in the Operating Plan and the time between periodic reviews shall not exceed five (5) years.
<b>Response: The SDT thanks you for your comment. Based on stakeholder comments the SDT revised R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively</b>		

Organization	Yes or No	Question 1 Comment
<p>report events to assure situational awareness to the Electric Reliability Organization. The SDT considered various time frames for the action needed and felt that a calendar year was necessary due to the FERC Directive in Order 693 and to ensure that contact information remained useful in a timely manner.</p>		
MidAmerican Energy	No	<p>See the NSRF comments. The real purpose of this requirement appears to be to assure operators are trained in the use of the procedure, process, or plan that assures proper notification. PER-005 already requires a systematic approach to training. Reporting to other affected entities is a PER-005 system operator task. Therefore this requirement already covered by PER-005 and is not required. Organizations are also required to test their response to events in accordance with CIP-008 R1.6. Therefore this requirement is covered by other standards and is not needed. Inclusion of this standard would place entities in a double or possible triple jeopardy. The SDT may need to expand M3 reporting options, by stating "... that the annual test of the communication process of 1.2 (e.g. communication via e-mail, fax, phone, ect) was conducted".</p> <p>R4 is an administrative requirement with little reliability value and should be deleted. It would likely be identified as a requirement that that should be eliminated as part of the request by FERC to identify strictly administrative requirements in FERC's recent order on FFTR.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT asks you to review the response to that commenter. The SDT disagrees with your understanding of the real purpose. Reporting of events listed in Attachment 1 is necessary for personnel beyond the operators.</b></p> <p><b>The SDT deleted Requirement R4 based on stakeholder comments and revised Requirement R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Illinois Municipal Electric Agency	No	IMEA reluctantly (in recognition of the SDT's efforts and accomplishments to date) cast a Negative vote for this project primarily based on R3 because it is

Organization	Yes or No	Question 1 Comment
		<p>attempting to fix a problem that does not exist and impacts small entity resources in particular. IMEA is not aware of seeing any information regarding a trend, or even a single occurrence for that matter, in a failure to report an event due to failure in reporting procedures. A small entity is less likely to experience a reportable event, and therefore is less likely to be able to take advantage of the provision in M3 to satisfy the annual testing through implementation of an actual event. If there is a problem that needs to be fixed, it would make much more sense to replace the language in R3 with a simple requirement for the RC, BA, IC, TSP, TOP, etc. to inform the TO, DP, LSE if there is a change in contact information for reporting an event. It is hard to believe that an RC, BA, IC, TSP, TOP, etc. is going to want to be annually handling numerous inquiries from entities regarding the accuracy of contact information. The impact of unnecessary requirements on entity resources, particularly small entities', is finally starting to get some meaningful attention at NERC and FERC. It would be a mistake to adopt another unnecessary requirement as currently specified in R3.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised Requirement R3 to help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
<p>American Transmission Company, LLC</p>	<p>No</p>	<p>ATC recommends eliminating R4 altogether. If R3, the annual test, is conducted as part of the Operating Plan, R4 is merely administrative, and does not add value to reliability.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT deleted Requirement R4 based on stakeholder comments and revised Requirement R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
<p>NextEra Energy Inc</p>	<p>No</p>	<p>NextEra Energy, Inc. (NextEra) does not agree that annual reviews and</p>



Organization	Yes or No	Question 1 Comment
		<p>annual tests should be mandated via Reliability Standards; instead, NextEra believes it is more appropriate to require that the Operating Plan be up-to-date and reviewed/tested as the Responsible Entity deems necessary. These enhancements provide for a robust Operating Plan, without arbitrary deadlines for a review and testing. It also provides Responsible Entities of different sizes and configurations the flexibility to efficiently and effectively integrate compliance with operations.</p> <p>Thus, NextEra requests that R1 be revised to read: “Each Responsible Entity shall have an up-to-date event reporting Operating Plan that is tested and reviewed as the Responsible Entity deems necessary and includes: ...”. Consistent with these changes NextEra also requests that R3 and R4 be deleted.</p>
<p><b>Response: The SDT thanks you for your comment. While the SDT recognizes the simplicity that your comment would bring, it cannot be implemented in that manner. For auditability reasons, each task must be separate and distinct in order for the performance to be assessed. Alternatively, the SDT has re-constructed three distinct requirements that can be judged and evaluated on their own with compromising the others.</b></p>		
ISO New England Inc	No	Due to the FERC mandate to assign VRFs/VSLs, we do not support using subrequirements and, instead, favor the use of bullets when the subrequirements are not standalone but rely on the partent requirement.
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the language and removed all subrequirements.</b></p>		
Exelon Corporation and its affiliates	No	It’s not clear that R3 and R4 need to be separated. Consider revising R3 to read: “Through use or testing, verify the operability of the plan on an annual basis” and dropping R4.
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		

Organization	Yes or No	Question 1 Comment
Indiana Municipal Power Agency	No	<p>IMPA does not believe that both R3 and R4 are necessary and they are redundant to a degree. Generally, when performing an annual review of a process or procedure, the call numbers for agencies or entities are verified to be up to date. Also, in R3, what does “test” mean. It could mean have different meanings to registered entities and to auditors which does not promote consistency among the industry. IMPA recommends going with an annual review of the process and having the telephone numbers verified that are in the event reporting Operating Plan. IMPA also believes that the local and federal law enforcement agencies would rather go with a verification of contact information over being besieged by "test" reports. The way R3 is written gives the appearance that the SDT did not want to overwhelm the ERO with all of the "test" reports from the registered entities (by excluding them from the test notification).</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		
ERCOT	No	<p>ERCOT has joined the IRC comments on this project and offers these additional comments. ERCOT requests that the measure be updated to say “acceptable evidence may include”. As written, the measure reads that there is only one way to comply with the requirement. The Standards should note "what" an entity is required to do and not prescribe the "how".</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the standard highlighted in your comment.</b></p>		
Brazos Electric Power Cooperative	No	<p>Please see the comments submitted by ACES Power Marketing.</p>
<p><b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b></p>		
Central Lincoln	No	<p>The new language of R3 and R4 provide nothing to clarify the word “annual.” We note that while a Compliance Application Notice was written on this,</p>

Organization	Yes or No	Question 1 Comment
		<p>Central Lincoln believes that standards should be written so they do not rely on the continually changing CANs. CAN-0010 itself implies that “annual” should be defined within the standards themselves. We suggest: R3 Each Responsible Entity shall conduct a test of the communications process in R1 Part 1.2, not including notification to the Electric Reliability Organization, at least once per calendar year with no more than 15 calendar months between tests.R4 Each Responsible Entity shall conduct a review of the event reporting Operating Plan in Requirement R1. at least at least once per calendar year with no more than 15 calendar months between reviews.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment.</b></p>		
Kansas City Power & Light	No	<p>Requirement 3 requires a test of the communications in the operating plan. A test implies a simulation of the communications part of the operating plan by actual communications being conducted pursuant to the plan. It is not appropriate to burden agencies with testing of communications under a test environment. Recommend the drafting team consider a confirmation of the contact information with various agencies as the operations plan dictates.</p>
<p><b>Response: The SDT thanks you for your comment. SDT has made changes to the requirements highlighted in your comment.</b></p>		
Bonneville Power Administration	Yes	<p>BPA believes that the annual testing and review as described in R3 is too cumbersome and unnecessary for entities with large footprints to inundate federal and local enforcement bodies such as the FBI for “only” testing and the documenting for auditing purposes. BPA suggests that testing be performed on a bi-annual or longer basis.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirements highlighted in your comment; however, the SDT has decided that the period will be shorter than your suggestion based upon comments received from all parties.</b></p>		

Organization	Yes or No	Question 1 Comment
Seattle City Light	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Utility Services	Yes	While agreeing with the change, confusion may exist with the CAN that exists for the term "Annual". Utility Services suggests that the language be changed to "Every calendar year" or something equivalent. Given everything that transpired in the discussion on the term annual, using a different phrase may be advantageous.
<b>Response: The SDT thanks you for your comment. The SDT has made changes to the requirement highlighted in your comment.</b>		
United Illuminating Company	Yes	R3 should be clear that the annual test of the plan does not mean each communication path for each applicable event on an annual basis.
<b>Response: The SDT thanks you for your comment. Requirement R3 has been rewritten to address comments like yours and other industry members. While testing is no longer a part of the requirement, validating the contact information associated with each contact list for each applicable event type is.</b>		
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration LP agrees that it is appropriate to test reporting communications on an annual basis, primarily to validate that phone numbers, email ids, and contact information is current. We appreciate the project team’s elimination of the terms “exercise” and “drill”, which we believe connotes a formalized planning and assessment process. An annual review of the Operating Plan implies a confirmation that linkages to sub-processes remain intact and that new learnings are captured. We also agree that it is appropriate only to require an updated Revision Level Control chart entry as evidence of compliance - it is very likely that no updates are required after the review is complete. In our view, both of these requirements are sufficient to assure an effective assessment of all facets of

Organization	Yes or No	Question 1 Comment
		the Operating Plan. As such, we fully agree with the project team’s decision to delete the requirement to update the plan within 90 days of a change. In most cases, our internal processes will address the updates much sooner, but there is no compelling reason to include it as an enforceable requirement.
<b>Response: The SDT thanks you for your comment.</b>		
City of Austin dba Austin Energy	Yes	Austin Energy (AE) supports the requirements for (1) an annual test of the communications portion of the Operating Plan (R3) and (2) an annual review of the Operating Plan (R4); however, we offer a slight modification to the measures associated with those requirements. AE does not believe that records evidencing such test and reviews need to be time-stamped to adequately demonstrate compliance with the requirements. In each case, we recommend that the first sentence of M3 and M4 start with “Each Responsible Entity will have dated records to show that the annual ...”
<b>Response: The SDT thanks you for your comment. The SDT has removed the time-stamping provision in the standard.</b>		
Springfield Utility Board	Yes	<ul style="list-style-type: none"> <li>o SUB supports the removal of Requirement 1, Part 1.4, as well the separation of Parts 1.3 and 1.5, agreeing that they are their own separate actions.</li> <li>o The Draft 4 Version History still lists the term “Impact Event” rather than “Event”.</li> </ul>
<b>Response: The SDT thanks you for your comment. The SDT has made changes highlighted in your comment.</b>		
FirstEnergy Corp	Yes	<p>FE agrees with the revision but has the following comments and suggestions:</p> <ol style="list-style-type: none"> <li>1. We request clarity and guidance on R3 (See our comments in Question 4 for further consideration). Also, we suggest a change in the phrase “shall conduct an annual test” to “shall conduct a test each calendar year, not to exceed 15 calendar months between tests”. This wording is consistent with other</li> </ol>

Organization	Yes or No	Question 1 Comment
		<p>standards in development such as CIP Version 5.2.</p> <p>2. In R4 we suggest a change in the phrase “shall conduct an annual review” to “shall conduct a review each calendar year, not to exceed 15 calendar months between reviews”. This wording is consistent with other standards in development such as CIP Version 5.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT deleted Requirement R4 based on stakeholder comments and revised Requirement R3 so that each Responsible Entity shall validate all contact information contained in the Operating Plan per Requirement R1 each calendar year. Requirement R3 will help ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization.</b></p>		
Independent Electricity System Operator	Yes	<p>We concur with the changes as they provide better streamlining of the four key requirements, with enhanced clarity. However, we are unclear on the intent of Requirement R3, in particular the phrase “not including notification to the Electric Reliability Organization” which begs the question on whether or not the test requires notifying all the other entities as if it were a real event. This may create confusion in ensuring compliance and during audits. Suggest the SDT to review and modify this requirement as appropriate.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the standard’s language to address this concern.</b></p>		
Public Utility District No. 1 of Snohomish County	Yes	<p>This is an excellent improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.</p>
Seattle City Light	Yes	<p>This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.</p>
MEAG Power	Yes	<p>This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.</p>
<p><b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b></p>		

Organization	Yes or No	Question 1 Comment
Tacoma Power	Yes	Tacoma Power agrees with the requirement but would suggest removing all instances the word “Operating” from the Standard. The requirements should read, “ Each Responsible Entity shall have an “Event Reporting Plan...”.The term Operating in this context is confusing as there are many other “Operating Plans” for other defined emergencies. This standard is about “Reporting” and should be confined to that.
<p><b>Response: The SDT thanks you for your comment. The SDT has chosen to include “Operating” due to the definition in the NERC Glossary. The SDT believes Operating Plan clearly defines what is needed in this standard.</b></p>		
Idaho Power Co.	Yes	But this is going to require that we create a new Operating Plan with test procedures and revision history.
<p><b>Response: The SDT thanks you for your comment. The SDT believes that an existing procedure, that meets the requirements of CIP-001-2a, may well be the starting point for the Operating Plan in this standard, or could go a long way towards achieving the requirements in this standard. The SDT revised Requirement R3 to remove test to “validate” contact information contained in the Operating Plan. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.</b></p>		
American Public Power Association	Yes	APPA appreciates the SDT making these requirements clearer as requested in our comments on the previous draft standard.
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Puget Sound Energy, Inc.	Yes	This draft is a considerable improvement on the previous draft in terms of clarity and will be much easier for Responsible Entities to implement. Puget Sound Energy appreciates the drafting team’s responsiveness to stakeholder’s concerns and the opportunity to comment on the current draft. The drafting team should revise Requirement R2 to state that the “activation” of the Operating Plan is required only when an event occurs, instead of using the term “implement”. “Implementation” could also refer

Organization	Yes or No	Question 1 Comment
		<p>to the activities such as distributing the plan to operating personnel and training operating personnel on the use of the plan. These activities are not triggered by any event and, since it is clear from the measure that this requirement is intended to apply only when there has been a reportable event, the requirement should be revised to state that as well.</p> <p>The drafting team should revise measure M2 to require reports to be “supplemented by operator logs or other reporting documentation” only “as necessary”. In many cases, the report itself and time-stamped record of transmittal will be the only documents necessary to demonstrate compliance with requirement R2. Under Requirement R3, using an actual event as sufficient for meeting the requirement for conducting an annual test would likely fall short of demonstrating compliance with the entire scope of the Operating Plan. R1.2 requires "a process for communicating EACH of the applicable events listed....". If the actual event is only one of many "applicable" events, is it sufficient to only exercise one process flow? If there is no actual event during the annual time-frame, do all the process flows then have to be exercised?</p>
<p><b>Response: The SDT thanks you for your comment. The SDT appreciates the suggestion; however, to be consistent with other reliability standards, the SDT has elected to continue to use the word “Implement.” Your suggestion could end up creating confusion and misunderstandings since the context is not used elsewhere.</b></p> <p><b>The SDT has revised the language the requirements and measures as a result of your and other commenter’s remarks.</b></p>		
FMPP		See FMPP's comments
<p><b>Response: The SDT thanks you for your comment. Please review the response to the FMPP comments.</b></p>		



Organization	Yes or No	Question 1 Comment
Luminant	Yes	
BC Hydro	Yes	
Imperial Irrigation District (IID)	Yes	
LG&E and KU Services	Yes	
PPL Corporation NERC Registered Affiliates	Yes	
Avista	Yes	
PNGC Comment Group	Yes	
Colorado Springs Utilities	Yes	
Arizona Public Service Company	Yes	
Georgia System Operations Corporation	Yes	
Texas Reliability Entity	Yes	
Dynergy Inc.	Yes	
Clark Public Utilities	Yes	
Pepco Holdings Inc	Yes	
Farmington Electric Utility System	Yes	

Organization	Yes or No	Question 1 Comment
Public Service Enterprise Group	Yes	
PPL Electric Utilities	Yes	
Cowlitz County PUD	Yes	
Edison Mission Marketing & Trading, Inc.	Yes	
Ameren	Yes	
We Energies	Yes	
GTC	Yes	
MISO	Yes	
Oncor Electric Delivery	Yes	
Los Angeles Department of Water and Power	Yes	
Deseret Power	Yes	

2. The SDT made clarifying revisions to Attachment 1 based on stakeholder feedback. Do you agree with these revisions? If not, please explain in the comment area below.

**Summary Consideration:**

The SDT reviewed, discussed and updated Attachment 1 based on comments received for commenters, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Under the Event Column, the SDT starts to classify each type of an event by assigning an “Event” title. The DSR SDT then updated the “Entity with Reporting Responsibilities” column to simply state which entity has the responsibility to report if they experience an event. The last column, “Threshold for Reporting” is a bright line that, if reached, the entity needs to report that they experienced the applicable event per Requirement 1.

Organization	Yes or No	Question 2 Comment
Northeast Power Coordinating Council	No	<p>Regarding Attachment 1, language identical to event descriptions in the NERC Event Analysis Process and FERC OE-417 should be used. Creating a third set of event descriptions is not helpful to system operators. Recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>The following pertains to Attachment 1: Replace the Attachment 1 “NOTE” with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to</p>

Organization	Yes or No	Question 2 Comment
		<p>the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required.</p> <p><b>The SDT thanks you with your comment. First, the SDT believes that you intended the comment to address the “Note” on Attachment 2, not Attachment 1. The SDT does not believe that a hardcopy report is necessary if the organization has made voice contact.</b></p> <p>The proposed “events” are subjective and will lead to confusion and questions as to what has to be reported.</p> <p><b>The SDT disagrees and has established “events” to be reported based on bright line criteria. The events are consistent with previous versions of the CIP-001 and EOP-004 standards, as well as incidences being reporting to the DOE and EAP.</b></p> <p>Event: A reportable Cyber Security Incident. All reportable Cyber Security Incidents may not require “One Hour Reporting.” A “one-size fits all” approach may not be appropriate for the reporting of all Cyber Security Incidents. The NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document provides time-frames for Cyber Security Incident Reporting. For example, a Cyber Security Compromise is recommended to be reported within one hour of detection, however, Information Theft or Loss is recommended to be reported within 48 hours. Recommend listing the Event as “A confirmed reportable Cyber Security Incident. The existing NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document uses reporting time-frames based on “detection” and “discovery.” Recommend using the word confirmed because of the investigation time that may be required from the point of initial “detection” or “discovery” to the point of confirmation, when the compliance “time-clock” would start for the reporting requirement in EOP-004-2.</p> <p><b>The SDT is revising the standard to not contain reporting for Cyber Security incidents. Under the revisions, CIP-008-3 and successive versions will retain the</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>reporting requirements.</b></p> <p>Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read: Results from actual or suspected intentional human action, excluding unintentional human errors.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” now states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p>Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore</p>

Organization	Yes or No	Question 2 Comment
		<p>unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whomever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Event: BES Emergency requiring public appeal for load reduction. Replace wording in the Event column with language from #8 on the OE-417 Reporting Form to eliminate reporting confusion. Following this sentence add, “This shall exclude other public</p>

Organization	Yes or No	Question 2 Comment
		<p>appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.”</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is required to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>Event: Complete or partial loss of monitoring capability Event wording: Delete the words “or partial” to conform the wording to the NERC Event Analysis Process.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to “Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p> <p>Event: Transmission Loss Revise to BES Transmission Loss</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b>  <b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>Event: Generation Loss Revise to BES Generation Loss</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT</b></p>

Organization	Yes or No	Question 2 Comment
		<p>removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:  “Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection  OR  <math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”  The SDT believes that if an entity reaches this threshold, it needs to be reported and most likely this will be BES connected generation assets.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
DECo	No	<p>On pg 17 in the Rationale Box for EOP-004 Attachment 1: The set of terms is specific then includes the word ETC. Then further lists areas to exclude. Then on Pg 23 of document it includes train derailment near a transmission right of way and forced entry attempt into a substation facility as reportable. These conflict. Also see conflict when in pg 21 states the DOE OE417 would be excepted in lieu of the NERC form, but on the last pg it states the DOE OE417 should be attached to the NERC report indicating the NERC report is still required.</p>
<p><b>Response: The SDT thanks you for your comment. While the SDT would like to point out the “etc.” is the last word in the definition of Facility; the SDT has removed footnote 1 and the forced intrusion statement has been removed. The SDT has updated to remove the conflict of “attached to the NERC report...” The SDT agrees with your comments and have revised the standard to address these discrepancies.</b></p>		
Duke Energy	No	<p>(1)We disagree with reporting CIP-008 incidents under this standard. We agree with the one-hour notification timeframe, but believe it should be in CIP-008 to avoid double jeopardy.   <b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one-hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>(2)Damage or destruction of a Facility - Need clarity on how a vertically integrated</p>



Organization	Yes or No	Question 2 Comment
		<p>entity must report. For example a GOP probably won't know if an IROL will be affected. Also, there shouldn't be multiple reports from different functional entities for the same event. Suggest splitting this table so that GO, GOP, DP only reports "Results from actual or suspected intentional human action".</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of its Facility that results from actual or suspected intentional human action.</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the Facility was 'damaged or destroyed' intentionally by a human."</b></p> <p><b>This event was written to cover the increase of "Entity with Reporting Responsibility," and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being "suspected intentional human action." This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>(3)Generation Loss - Need more clarity on the threshold for reporting. For example if</p>

Organization	Yes or No	Question 2 Comment
		<p>we lose one 1000 MW generator at 6:00 am and another 1000 MW generator at 4:00 pm, is that a reportable event?</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b>≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Luminant	No	<p>Luminant appreciates the work of the SDT to modify Attachment 1 to address the concerns of the stakeholders. However, we are concerned that the threshold for reporting a Generation Loss in the ERCOT interconnection established by this revision is set at 1,000MW, which is not consistent with the level of single generation contingency used in ERCOT planning and operating studies. That level of contingency is currently set at the size of the largest generating unit in ERCOT, which is 1,375MW. For this reason, Luminant believes that the minimum threshold for reporting of a disturbance should be &gt; 1,375MW for the ERCOT Interconnection.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b>≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p><b>The SDT discussed this issue and believes that ERCOT could change contingency level in the future, and this event is also applicable to the Quebec Interconnection.</b></p>		

Organization	Yes or No	Question 2 Comment
BC Hydro	No	BC Hydro supports the revisions to EOP-004 and would vote Affirmative with the following change. Attachment 1 has a One Hour Reporting requirement. BC Hydro proposes a One Hour Notification with the Report submitted within a specified timeframe afterward.
<p><b>Response: The SDT thanks you for your comment. The SDT has removed all incidences involving one-hour reporting threshold; therefore, the SDT does not see the need to make this change.</b></p>		
Bonneville Power Administration	No	<p>BPA believes that clarifying language should be added to transmission loss event. (Page 19) [a report should not be required if the number of elements is forced because of pre-designed or planned configuration. System studies have to take such a configuration into account possible wording could be. Unintentional loss of three or more Transmission Facilities (excluding successful automatic reclosing or planned operating configuration)]</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>In addition, under the “Event” of Complete or partial loss of monitoring capability, BPA believes that “partial loss” is not sufficiently specific for BPA to write compliance operating procedures and suggest defining partial loss or removing it from the standard. Should the drafting team add clarifying language to remove “or partial loss” and address BPA’s concerns on over emphasis on software tool to the operation of the system. BPA would change its negative position to affirmative.</p> <p><b>The SDT has revised the language on this point in Attachment 1.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		

Organization	Yes or No	Question 2 Comment
SPP Standards Review Group	No	<p>To obtain an understanding of the drivers behind the events in Attachment 1, we would like to see where these events come from. If the events are required in standards, refer to them. If they are in the existing event reporting list, indicate so. If they are coming from the EAP, let us know. We have a concern that, as it currently exists, Attachment 1 can increase our reporting requirements considerably.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Reportable events should be similar, but not identical to the events reported to DOE or EAP.</b></p> <p>We also have concerns about what appears to be a lack of coordination between EAP reporting requirements and those contained in Attachment 1. For example, the EAP reporting requirement is for the complete loss of monitoring capability whereas Attachment 1 adds the requirement for reporting a partial loss of monitoring capability. It appears that some of the EAP reporting requirements are contained in Attachment 1. We have concerns that this is beyond the scope of the SAR and should not be incorporated in this standard.</p> <p><b>The SDT has revised the language on this point in Attachment 1. It should be noted that the EAP can use reports submitted under EOP-004-2 as the initial notification of an event that could be further addressed in the EAP.</b></p> <p>We have concern with several of the specific event descriptions as contained in Attachment 1:</p> <p>Damage or destruction of a Facility - We are comfortable with the proposed definition of Adverse Reliability Impact but have concerns with the existing definition of ARI.</p> <p>Any physical threat that could impact the operability of a Facility<sup>1</sup> - We take exception to this event in that it goes beyond what is currently required in EOP-004-1, including DOE reporting requirements, and the EAP reporting requirements. We do not understand the need for this event type and object to the potential for excessive</p>

Organization	Yes or No	Question 2 Comment
		<p>reporting required by such an event type. Additionally, we are concerned about the potential for multiple reporting of a single event. This same concern applies to several other events including Damage or destruction of a Facility, Loss of firm load for 15 minutes, System separation, etc. When multiple entities are listed as the Entity with Reporting Responsibility, Attachment 1 appears to require each entity in the hierarchy to submit a report. There should only be one report and it should be filed by the entity owning the event. The SDT addressed this issue in its last posting but the issue still remains and should be reviewed again.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>depth and breathe of system conditions based on the given event.</b></p> <p>BES Emergency resulting in automatic firm load shedding - For some reason, not stipulated in the Consideration of Comments, the action word in the Entity with Reporting Responsibility was changed from 'experiences' to 'implements'. We recommend changing it back to 'experiences'. Automatic load shedding is not implemented. It does not require human intervention. It's automatic. Voltage deviation on a Facility - Similar to the comment on automatic load shedding above, the action word was changed from 'experiences' to 'observes'. We again recommend that it be changed back to 'experiences'. Using observes obligates a TOP, who is able to see a portion of a neighboring TOP's area, to submit a report if that TOP observed a voltage deviation in the neighboring TOP's area. The only reporting entity in this event should be the TOP within whose area the voltage deviation occurred.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Automatic firm load shedding ≥ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)."</b></p> <p><b>This language clearly states that an entity reports if the threshold is reached.</b></p> <p>Complete or partial loss of monitoring capability - Clarification on partial loss of monitoring capability and inoperable are needed. Also, the way the Threshold is written, it implies that a State Estimator and Contingency Analysis are required. To tone this down, insert the qualifier 'such as' in front of State Estimator.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to "Complete loss of monitoring capabilities" for a RC, BA, or TOP when there is a complete loss of monitoring</b></p>

Organization	Yes or No	Question 2 Comment
		<p>capabilities for 30 continuous minutes where their State Estimator or Contingency Analysis is inoperable. This will only apply to an RC, BA, or TOP who have this capability to start with.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>Florida Municipal Power Agency</p>	<p>No</p>	<p>The bullet on “any physical threat” is un-measurable. What constitutes a “threat”? FMPA likes the language used in the comment form discussing this item concerning the judgment of the Responsible Entity, but, the way it is worded in Attachment 1 will mean the judgment of the Compliance Enforcement Authority, not the Responsible Entity. Presumably, the Responsible Entity will need to develop methods to identify physical threats in accordance with R1; hence, FMPA suggests rewording to: “Any physical threat recognized by the Responsible Entity through processes established in R1 bullet 1.1”. We understand this introduces circular logic, but, it also introduces the “judgment of the Responsible Entity” into the bullet.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b>  <b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or</b></p>

Organization	Yes or No	Question 2 Comment
		<p>activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event, unless it degrades the normal operation of a Facility.</p> <p>On the row of the table on voltage deviation, replace the word “observes” with “experiences”. It is possible for one TOP to “observe” a voltage deviation on another TOP’s system. It should be the responsibility of the TOP experiencing the voltage deviation on its system to report, not the one who “observes”. On the row on islanding, it does not make sense to report islanding for a system with load less than the loss of load metrics and we suggest using the same 300 MW threshold for a reporting threshold. On the row on generation loss, some clarification on what type of generation loss (especially in the time domain) would help it be more measurable, e.g., concurrent forced outages. On the row on transmission loss, the same clarity is important, e.g., three or more concurrent forced outages.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Automatic firm load shedding ≥ 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS).”</b></p> <p><b>This language clearly states that an entity reports if the threshold is reached.</b></p> <p>On the row on loss of monitoring, while FMPA likes the threshold for “partial loss of monitoring capability” for those systems that have State Estimators, small BAs and TOPs will not need or have State Estimators and the reporting threshold becomes ambiguous. We suggest adding something like loss of monitoring for 25% of monitored points for those BAs and TOPs that do not have State Estimators.</p>



Organization	Yes or No	Question 2 Comment
		<p>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to “Complete loss of monitoring capabilities” for a RC, BA, or TOP when there is a complete loss of monitoring capabilities for 30 continuous minutes where their State Estimator or Contingency Analysis is inoperable. This will only apply to an RC, BA, or TOP who have this capability to start with.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>LG&amp;E and KU Services</p>	<p>No</p>	<p>The SDT should consider more clearly defining the Threshold for Reporting for the Event: “Any physical threat that could impact the operability of a Facility” to only address those events that have an Adverse Reliability Impact. Some proposed language might be: “Threat to a Facility excluding weather related threats that could result in an Adverse Reliability Impact.” For those events specifically defined in the ERO Events Analysis Process, the SDT should consider revising the language to be more consistent with the language included in the ERO Events Analysis Process. Here is some recommended language:</p> <ol style="list-style-type: none"> <li>1. EVENT: Transmission loss THRESHOLD FOR REPORTING: “Unintentional loss, contrary to design, of three or more BES Transmission Facilities (excluding successful automatic reclosing) caused by a common disturbance.</li> </ol> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b>  <b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <ol style="list-style-type: none"> <li>2. EVENT: “Complete or partial loss of monitoring capability” - could be revised to read “Complete loss of SCADA control or monitoring functionality” THRESHOLD FOR REPORTING: “Affecting a BES control center for 30 continuous minutes such that analysis tools (e.g. State Estimator, Contingency Analysis) are rendered inoperable”.</li> </ol> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments</b></p>

Organization	Yes or No	Question 2 Comment
		<p>received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:  “Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
MRO NSRF	No	<p>R1.2 states: A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies. This implies not only does NERC need to be notified within the specified time period but that: “other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.” are also required to be notified within in the time periods specified. We suggest a forth column be added to the table to clearly identify who must be notified within the specified time period or that R1.2 be revised to clearly state that only NERC must be notified to comply with the standard. With the use of “i.e.” the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that “e.g.” should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity.</p> <p><b>The SDT has made the required change concerning replacing “i.e.” with “e.g.”</b></p> <p>Also with regards to Attachment 1, the following comments are provided:</p> <ol style="list-style-type: none"> <li>1. Instead of referring to CIP-008 (in the 1 hour reporting section), quote the words from CIP-008, this will require coordination of future revisions but will assure clarity in reporting requirements.</li> </ol> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>have remanded the one-hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>2. Under “Damage or destruction of a Facility” a. The wording “affects an IROL (per FAC-014),” is too vague. Many facilities could affect an IROL, not as many if lost would cause an IROL. b. Adverse Reliability Impact is defined as: “The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection.” There are an infinite number of routine events that result in the loss of generation plants due to inadvertent actions that somehow also damaged equipment. Any maintenance activity that damaged a piece of equipment that causes a unit to trip or results in a unit being taken off line in a controlled manner would now be reportable. This seems to be an excessive reporting requirement. Recommend that Adverse Reliability Impact be deleted and be replaced with actual EEA 2 or EEA 3 level events. c. The phrase “Results from actual or suspected intentional human action.” This line item used the term “suspected” which relates to “sabotage”. Recommend the following: Results from actual or malicious human action intended to damage the BES.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any</b></p>

Organization	Yes or No	Question 2 Comment
		<p>abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>3. “Any physical threat that could impact the operability of a Facility1”The example provided by the drafting team of a train derailment exemplifies why this requirement should be deleted. A train derailment of a load of banana’s more than likely would not threaten a nearby BES Facility. However a train carrying propane that derails carrying propane could even if it were 10 miles away. Whose calculation will be used to determine if an event could have impacted the asset? As worded there is too much ambiguity left to the auditor. We suggest the drafting team clarify by saying “Any event that requires the a BES site be evacuated for safety reasons”</p> <p>Furthermore if weather events are excluded, we are hard pressed to understand why this information is important enough to report to NERC. So barring an explanation of the purpose of this requirement, including why weather events would be excluded, we suggest the requirement be deleted. Please note that if you align this with “Physical attack” with #1 of the OE-417. This clearly states what the SDT is looking for.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:</p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>4. The phrase “or partial loss of monitoring capability” is too vague. Further definitions of “inoperable” are required to assure consistent application of this requirement. Recommend that “Complete loss of SCADA affecting a BES control center for 30 continuous minutes such that analysis tools of State Estimator and/or Contingency Analysis are rendered inoperable. Or, Complete loss of the ability to perform a State Estimator or Contingency Analysis function, the threshold of 30 mins is too short. A 60 min threshold will align with EOP-008-1, R1.8. Since this is the time to implement the contingency back up control center plan.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p> <p>5. Event: Voltage deviation on a Facility. ATC believes that the term “observes” for Entity with Reporting Responsibility be changed back to “experiences” as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. Also, for Threshold for Reporting, ATC believes the language should be expanded to - plus or minus 10% “of target voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>6. Event: Transmission loss. ATC recommends that Threshold for Reporting be changed to read “Unintentional loss of four, or more Transmission Facilities, excluding successful automatic reclosing, within 30 seconds of the first loss experienced and for 30 continuous minutes. Technical justification or Discussion for this recommended change: In the instance of a transformer-line-transformer, scenario commonly found close-in to Generating stations, consisting of 3 defined “facilities”, 1 lightning strike can cause automatic unintentional loss by design. Increase the number of facilities to 4. In a normal shoulder season day, an entity may experience the unintentional loss of a 138kv line from storm activity, at point A in the morning, a loss of a 115kv line from a different storm 300 miles from point A in the afternoon, and a loss of 161kv line in the evening 500 miles from point A due to a</p>

Organization	Yes or No	Question 2 Comment
		<p>failed component, if it is an entity of significant size. Propose some type of time constraint. Add time constraint as proposed, 30 seconds, other than automatic reclosing. In the event of dense lightning occurrence, the loss of multiple transmission facilities may occur over several minutes to several hours with no significant detrimental effect to the BES, as load will most certainly be affected (lost due to breaker activity on the much more exposed Distribution system) as well. Any additional loss after 30 seconds must take into account supplemental devices with intentional relay time delays, such as shunt capacitors, reactors, or load tap changers on transformers activating as designed, arresting system decay. In addition, Generator response after this time has significant impact. Please clarify or completely delete why this is included within this version when no basis has been give and it is not contained within the current enforceable version.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>7. Modify the threshold of “BES emergency requiring a public appeal...” to include, “Public appear for a load reduction event resulting for a RC or BA implementing its emergency operators plans documented in EOP-001.” The reason is that normal public appeals for conservation should be clearly excluded.</p> <p><b>The SDT disagrees since it is clearly stated that a report is required for “Public appeal for load reduction event.” The SDT has not discussed a reporting mechanism for “conservation.”</b></p> <p>8. Add a time threshold to complete loss of off-site power to a nuclear plant. Nuclear plants are to have backup diesel generation that last for a minimum amount of time. A threshold recognizing this 4 hour or longer window needs to be added</p>

Organization	Yes or No	Question 2 Comment
		<p>such as complete loss of off-site power to a nuclear plant for more than 4 hours.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.” As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</b></p> <p>9. Delete “Transmission loss”. The loss of a specific number of elements has no direct bearing on the risk of a system cascade. Faults and storms can easily result in “unintentional” the loss of multiple elements. This is a flawed concept and needs to be deleted</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p>
<b>Response: The SDT thanks you for your comment.</b>		
PPL Corporation NERC Registered Affiliates	No	<p>1.) PPL Generation thanks the SDT for the changes made in this latest proposal. We feel our previous comments were addressed. PPL Generation offers the following additional comments. Regarding the event ‘Transmission Loss’: For your consideration, please consider adding a footnote to the event ‘Transmission Loss’ such that weather events do not need to be reported. Also please consider including operation contrary to design in the language and not just in the example. E.g. consistent with the NERC Event Analysis table, the threshold would be, ‘Unintentional loss, contrary to design, of three or more</p>



Organization	Yes or No	Question 2 Comment
		<p>BES Transmission Facilities.’</p> <p>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</p> <p>The SDT has taken your comment into consideration and this threshold for reporting now states:  “Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).” The SDT has removed all footnotes within Attachment 1.</p> <p>2.) PPL Generation proposes the following changes in Attachment 1 to the first entry in the “Threshold for Reporting” column to make it clear that independent GO/GOPs are required to act only within their sphere of operation and based on the information that is available to the GO/GOPs: Damage or destruction of a Facility that: Affects an IROL (per FAC-014, not applicable to GOs and GOPs) OR Results in the need for actions to avoid an Adverse Reliability Impact (not applicable to GOs and GOPs) OR Results from actual or suspected intentional human action (applicable to all).</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any</p>

Organization	Yes or No	Question 2 Comment
		<p>abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within</p>

Organization	Yes or No	Question 2 Comment
		<p><b>their Operating Plan.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>ISO/RTO Standards Review Committee</p>	<p>No</p>	<p>The SRC response to this question does not indicate support of the proposed requirement. Please see the latter part of the SRC’s response to Question 4 below for an SRC proposed alternative approach:</p>
<p><b>Response: The SDT thanks you for your comment. Please review response to Question 4 comment.</b></p>		
<p>ACES Power Marketing Standards Collaborators</p>	<p>No</p>	<p>The drafting team made a number of positive changes to Attachment 1. However, there are a few changes that have introduced new issues and there are a number of existing issues that have yet to be fully addressed. One of the existing issues is that the reporting requirements will result in duplicate reporting. Considering that one of the stated purposes is to eliminate redundancy, we do not see how the scope of the SAR can be considered to be met until all duplicate reporting is eliminated.</p> <p><b>The SDT acknowledges that reporting of the same event will come from multiple parties. However, as the industry has learned from recent events, NERC needs to have perspectives from a variety of entities instead of just one party’s viewpoint. Reliability can be improved from learning how the differing parties see or experience the event. Sometimes, the differing perspectives have provided valuable insight on the true nature of the event. Therefore, the SDT believes that having multiple reports will aid reliability as we can learn from everyone’s experiences.</b></p>

Organization	Yes or No	Question 2 Comment
		<p>More specifics on our concerns are provided in the following discussion.</p> <p>(1) In the “Damage or destruction of a Facility” event, the statement “Affects an IROL (per FAC-014)” in the “Threshold for Reporting” is ambiguous. What does it mean? If the loss of a Facility will have a 1 MW flow change on the Facilities to which the IROL applies, is this considered to have affected the IROL? We suggest a more direct statement that damage or destruction occurred on a Facility to which the IROL applies or to one of the Facilities that comprise an IROL contingency as identified in FAC-014-2 R5.1.3. Otherwise, there will continue to be ambiguity over what constitutes “affects”.</p> <p>(2) In the “Damage or destruction of a Facility” event, the threshold regarding “intentional human action” is ambiguous and suffers from the same difficulties as defining sabotage. What constitutes intentional? How do we know something was intentional without a law enforcement investigation? This is the same issue that prevented the drafting team from defining sabotage.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to</b></p>

Organization	Yes or No	Question 2 Comment
		<p>prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within</p>

Organization	Yes or No	Question 2 Comment
		<p><b>their Operating Plan.</b></p> <p>(3) In the “Damage or destruction of a Facility” and “Any physical threat that could impact the operability of a Facility” events, Distribution Provider should be removed. Per the Function Model, the Distribution Provider does not have any Facilities (line, generator, shunt compensator, transformer). The only Distribution Provider equipment that even resembles a Facility would be capacitors (i.e. shunt compensator) but they do not qualify because they are not Bulk Electric System Elements.</p> <p><b>The SDT agrees that if a DP does not own or operate a Facility then this event would not be applicable to them. However, if a DP does experience an event such as those listed, then it is a reportable incident under this standard.</b></p> <p>(4) The “Any physical threat that could impact the operability of a Facility” event requires duplicate reporting. For example, if a large generating plant experiences such a threat, who should report the event? What if loss of the plant could cause capacity and energy shortages as well as transmission limits? The end result is that the RC, BA, TOP, GO and GOP could all end up submitting a report for the same event. For a given operating area, only one report should be required from one registered entity for each event.</p> <p><b>The SDT acknowledges that multiple reports could result from an event. If an entity experiences an applicable event type, then they required to report it. As previously stated, the industry can benefit from having such differing perspectives when events occur.</b></p> <p>(5) The “Any physical threat that could impact the operability of a Facility” event should not apply to a single Facility but rather multiple Facilities which if lost would impact BES reliability. As written now, a train derailment near a single 138 kV transmission line or small generator with minimal reliability impact would require reporting.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>(6) The “BES Emergency resulting in automatic firm load shedding” should not apply to the DP. In the existing EOP-004 standard, Distribution Provider is not included and the load shed information still gets reported.</p> <p>The SDT believes that the DP should be required to report “automatic firm load shedding...” to the ERO (and whoever else the entity wishes to inform per Requirement R1).</p> <p>(7) The “Voltage deviation on a Facility” event needs to be clarified that the TOP only reports voltage deviations in its Transmission Operator Area. Because TOPs may view</p>

Organization	Yes or No	Question 2 Comment
		<p>into other Transmission Operator Areas, it could technically be required to report another TOP's voltage deviation because one of its System Operators observed the neighboring TOP's voltage deviation.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Observed voltage deviation of <math>\pm</math> 10% of nominal voltage sustained for <math>\geq</math> 15 continuous minutes."</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(8) For the "Loss of firm load greater than 15 minutes" event, the potential for duplicate reporting needs to be eliminated. Every time a DP experiences this event, the DP, TOP and BA all appear to be required to report since the DP is within both the Balancing Authority Area and Transmission Operator Area. Only one report is necessary and should be sent. Given that the existing EOP-004 standard does not include the DP, we suggest eliminating the DP to eliminate one level of duplicate reporting.</p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(9) For the "System separation (islanding)" event, please remove DP. As long as any island remains viable, the Distribution Provider will not even be aware that an island occurred. It is not responsible for monitoring frequency or having a wide area view.</p>



Organization	Yes or No	Question 2 Comment
		<p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified.</p> <p><b>This event is now only applicable to RC, BA, and TOP.</b></p> <p>(10) For the “System separation (islanding)” event, please remove BA. Because islanding and system separation, involve Transmission Facilities automatically being removed from service, this is largely a Transmission Operator issue. This position is further supported by the approval of system restoration standard (EOP-005-2) that gives the responsibility to restore the system to the TOP. (11) For the “System separation (islanding)” event, please eliminate duplicate reporting by clarifying that the RC should submit the report when more than one TOP is involved. If only one TOP is involved, then the single TOP can submit the report or the RC could agree to do it on their behalf. Only one report is necessary.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified.</b></p> <p><b>This event is now only applicable to RC, BA, and TOP. The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(12) For the “Generation loss” event, duplicate reporting should be eliminated. It is not necessary for both the BA and GOP to submit two separate reports with nearly identical information. Only one entity should be responsible for reporting.</p> <p><b>The SDT understands that there may be several reports of a single event; and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>(13) For the “Complete loss of off-site power to a nuclear generating plant”, the</p>

Organization	Yes or No	Question 2 Comment
		<p>associated GO or GOP should be required to report rather than the TO or TOP. Maintaining power to cooling systems is ultimately the responsibility of the nuclear plant operator. At the very least, TO should be removed because it is not an operating entity and loss of off-site power is an operational issue. If the TOP remains in the reporting responsibility, it should be clarified that it is only a TOP with an agreement pursuant to NUC-001. All of this is further complicated because NUC-001 was written for a non-specific transmission entity because there was no one functional entity from which the nuclear plant operator gets it off-site power.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2.</b></p> <p><b>The SDT has taken your comment into consideration and this threshold for reporting now states:</b></p> <p><b>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.” As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</b></p> <p>(14) For the “Complete or partial loss of monitoring capability”, partial loss needs to be further clarified. Is loss of a single RTU a partial loss of monitoring capability? For a large RC is loss of ICCP to a single small TOP, considered a partial loss? We suggest as long as the entity has the ability to monitor their system through other means that the event should not be reported. For the loss of a single RTU, if the entity has a solving state estimator that provides estimates for the area impacted, the partial threshold loss would not be considered. If the entity has another entity (i.e. perhaps the RC is still receiving data for its TOP area, the RC can monitor for the TOP) that can monitor their system as a backup, the partial loss has not been met.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30</b></p>

Organization	Yes or No	Question 2 Comment
		<p>continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>Southern Company Services</p>	<p>No</p>	<p>It appears that the SDT has incorporated the reporting requirements for CIP-008 “reportable Cyber Security Incidents”; however, the “recognition” requirements remain in CIP-008 Reliability Standard. Southern understands the desire to consolidate reporting requirements into a single standard, but it would be clearer for Cyber Security Incidents if both the recognition and reporting requirements were in one reliability standard and not spread across multiple standards.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>As it relates to the event type “Loss of Firm Load for &gt; 15 minutes”, Southern suggests that the SDT clarify if weather related loss of firm load is excluded from the reporting requirement.</p> <p><b>The SDT believes that it is important to report this event based on the threshold regardless of the cause. This will give the ERO (and whoever else the entity wishes to inform per Requirement R1) a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>As it relates to the event type “Loss of all voice communication capability”, Southern suggest that the SDT clarify if this means both primary and backup voice communication systems or just primary voice communication systems.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</b></p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:  <b>“Complete loss of voice communications capabilities affecting a BES control center for 30 continuous minutes or more.”</b> The SDT intends “complete” to mean all capabilities, including back up capabilities.</p> <p>Referring to “CIP-008-3 or its successor” in Requirement R1.1 is problematic. This arrangement results in a variable requirement for EOP-004-2 R1. The requirements in a particular version of a standard should be fixed and not variable. If exceptions to applicable events change, a revision should be made to EOP-004 to reflect the modified requirement.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Hydro One	No	<p>In the Attachment 1, language identical to event descriptions in the NERC Event Analysis Process and FERC OE-417 should be used. Creating a third set of event descriptions is not helpful to system operators. Recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>The proposed “events” are subjective and will lead to confusion and questions as to what has to be reported. - Event: A reportable Cyber Security Incident. All reportable Cyber Security Incidents may not require “One Hour Reporting.” A “one-size fits all” approach may not be appropriate for the reporting of all Cyber Security</p>

Organization	Yes or No	Question 2 Comment
		<p>Incidents. The NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document provides time-frames for Cyber Security Incident Reporting. For example, a Cyber Security Compromise is recommended to be reported within one hour of detection, however, Information Theft or Loss is recommended to be reported within 48 hours. Recommend listing the Event as “A confirmed reportable Cyber Security Incident. The existing NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document uses reporting time-frames based on “detection” and “discovery.” Recommend using the word confirmed because of the investigation time that may be required from the point of initial “detection” or “discovery” to the point of confirmation, when the compliance “time-clock” would start for the reporting requirement in EOP-004-2.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement. Note that the existing NERC “Security Guideline for the Electricity Sector: Threat and Incident Reporting” document is a “guideline” to assist entities. It should not be confused with a mandatory and enforceable Reliability Standard.</b></p> <p>- Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read: “Results from actual or suspected intentional human action, excluding unintentional human errors”.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” not states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any</b></p>

Organization	Yes or No	Question 2 Comment
		<p>abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>- Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p>

Organization	Yes or No	Question 2 Comment
		<p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>- Event: BES Emergency requiring public appeal for load reduction. Replace wording in the Event column with language from #8 on the OE-417 Reporting Form to eliminate reporting confusion. Following this sentence add, “This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.”</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is require to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>- Event: Complete or partial loss of monitoring capability Event wording: Delete the words “or partial” to conform the wording to the NERC Event Analysis Process.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event now only applies to:</b>  <b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Event: Transmission Loss Revise to BES Transmission Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:  “Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</p> <p>Event: Generation Loss Revise to BES Generation Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:  “Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection  OR  ≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”  The SDT believes that if an entity reaches this threshold, it needs to be reported.</p>
<b>Response: The SDT thanks you for your comment.</b>		
CenterPoint Energy	No	CenterPoint Energy appreciates the revisions made to Attachment 1 based on stakeholder feedback; however, the Company continues to have concerns regarding certain events and thresholds for reporting and offers the following recommendations. (1) CenterPoint Energy recommends the deletion of "per Requirement R1" in the “Note” under Attachment 1 as it contains a circular reference back to R1 which includes timeframes.



Organization	Yes or No	Question 2 Comment
		<p>The SDT has updated Requirement R1 due to industry comments to read:  <b>“R1. Each Responsible Entity shall have an event reporting Operating Plan that includes communication protocol(s) for applicable events listed in, and within the time frames specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations based on the event type (e.g. the Regional Entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, governmental or provincial agencies).”</b></p> <p>(2) CenterPoint Energy maintains that a required 1 hour threshold for reporting of any event is unreasonable. CenterPoint Energy is confident that given dire circumstances Responsible Entities will act quickly on responding to and communication of any impending threat to the reliability of the Bulk Electric System.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>(3) For the event of “Damage or destruction of a Facility”, CenterPoint Energy is concerned that the use of the term “suspected” is too broad and proposes that the SDT delete "suspected" and add "that causes an Adverse Reliability Impact..." to the threshold for reporting regarding human action.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility</p>

Organization	Yes or No	Question 2 Comment
		<p><b>was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>(4) CenterPoint Energy believes that the event, “Any physical threat that could impact the operability of a Facility” is too broad and should be deleted. Alternatively, CenterPoint Energy recommends that the SDT delete “could” or change the event description to “A physical incident that causes an Adverse Reliability Impact”. Additionally, in footnote 1, the example of a train derailment uses the phrase “could have damaged”. CenterPoint Energy is concerned that as beauty is the eye of the beholder, this phrase is open to interpretation and therefore recommends that the phrase, “causes an Adverse Reliability Impact” be incorporated into the description.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event and footnote 1. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>(5) The Company proposes that the threshold for reporting the event, “BES Emergency requiring manual firm load shedding” is too low. It appears the SDT was attempting to align this threshold with the DOE reporting requirement. However, as the SDT stated above, there are several valid reasons why this should not be done; therefore, CenterPoint Energy recommends the threshold be revised to “Manual firm load shedding â%¥ 300 MW”.</p> <p><b>The SDT disagrees as this is currently enforceable within EOP-004-1.</b></p> <p>(6) CenterPoint Energy also recommends a similar revision to the threshold for reporting associated with the “BES Emergency resulting in automatic firm load shedding” event. (“Firm load shedding â%¥ 300 MW (via automatic under voltage or under frequency load shedding schemes, or SPS/RAS”)</p> <p><b>The SDT disagrees as we have aligned this with “manual firm load shedding.” As written a report will be required for load shedding of 100MW for automatic or manual actions.</b></p> <p>(7) CenterPoint Energy is uncertain of the event, “Loss of firm load for â%¥ 15 minutes” and its fit with BES Emergency requiring manual firm load shedding or BES Emergency resulting in automatic firm load shedding. The Company believes that this event is already covered with manual firm load shedding and automatic firm load shedding and should therefore be deleted.</p> <p><b>The SDT disagrees, as “Loss of firm load” is due to an action other than loss of load due to “automatic” or “manual” actions by the BA, TOP, or DP. The intent is to capture that load was loss by some other action. Note that this is a currently enforceable item within EOP-004-1.</b></p>

Organization	Yes or No	Question 2 Comment
		<p>(8) For the event of “System separation (islanding)”, CenterPoint Energy believes that 100 MW is inconsequential and proposes 300 MW instead.</p> <p><b>The SDT disagrees, as this has been vetted through the industry with very little negative feedback.</b></p> <p>(9) For “Generation loss”, CenterPoint Energy suggests that the SDT add "only if multiple units" to the criteria of “1,000 MW for entities in the ERCOT or Quebec Interconnection”.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b><math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p>(10) Finally, CenterPoint Energy recommends that the SDT delete the term “partial” under the “Entity with Reporting Responsibility” for “Complete or partial loss of monitoring capability”. The Company proposes revising the event description to "Loss of monitoring capability for &gt; 30 minutes that causes system analysis tools to be inoperable”.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or</b></p>

Organization	Yes or No	Question 2 Comment
		TOP who have this capability to start with.
<b>Response: The SDT thanks you for your comment.</b>		
Arkansas Electric Cooperative Corporation	No	AECC supports the comments submitted by ACES Power Marketing.
<b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b>		
MWDSC	No	See comment for question 1
<b>Response: The SDT thanks you for your comment. Please review the response to Question 1.</b>		
Georgia System Operations Corporation	No	See comments under no. 4 below.
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Texas Reliability Entity	No	<p>(1) In the Events Table, consider whether the item for “Voltage deviation on Facility” should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator or power system stabilizer) could have a similar impact on the BES as other reportable items. Note: We made this comment last time, and the SDT’s posted response was non-responsive to this concern.</p> <p><b>The SDT reviewed TRE’s comment and believe that our consideration of comments during that last posting clearly stated the SDT view correctly. We stated “The SDT disagrees with this comment. Attachment 1 is the minimum set of events that will be required to report and communicate per your Operating Plan will be aware of system conditions.” Further, we note that such events do not rise to the level of notification to the ERO. When events like the ones you mention occur, then entity has obligations to notify other parties according to reliability standards relating to that equipment. The NERC Standards Process Manual does allow TRE to apply for a variance if they have special concerns that GOPs should submit a report to the ERO.</b></p> <p>(2) In the Events Table, under Transmission Loss, the SDT indicated that reporting is triggered only if three or more Transmission Facilities operated by a single TOP are lost. What if four Facilities are lost, with two Facilities operated by each of two TOPs?</p>

Organization	Yes or No	Question 2 Comment
		<p>That is a larger event than three Facilities lost by one TOP, but there is no reporting requirement? Determining event status by facility ownership is not an appropriate measure. The reporting requirements should be based on the magnitude, duration, or impact of the event, and not on what entities own or operate the facilities.</p> <p>(3) In the Events Table, under Transmission Loss, the criteria “loss of three or more Transmission Facilities” is very indefinite and ambiguous. For example, how will bus outages be considered? Many entities consider a bus as a single “Facility,” but loss of a single bus may impact as many as six 345kV transmission lines and cause a major event. It is not clear if this type of event would be reportable under the listed event threshold? Is the single-end opening of a transmission line considered as a loss of a Facility under the reporting criteria?</p> <p>(4) Combinations of events should be reportable. For example, a single event resulting in the loss of two Transmission Facilities (line and transformer) and a 950 MW generator would not be reportable under this standard. But loss of two lines and a transformer, or a 1000 MW generator, would be reportable. It is important to capture all events that have significant impacts.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p><b>The SDT has reviewed Attachment 1 as a minimum level of reporting thresholds. There may be times where an entity may wish to report when a threshold has not been reached because of their experience with their system. EOP-004-2 does not prevent any entity from reporting any type of situation (event) at anytime. Note that the SDT has received industry feedback and it is not within scope of a results</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>based Standards concept to be very prescriptive in nature.</b></p> <p>(5) In the Events Table, under “Unplanned control center evacuation,” “Loss of all voice communication capability” and “Complete or partial loss of monitoring capability,” GOPs should be included. GOPs also operate control centers that are subject to these kinds of occurrences, with potentially major impacts to the BES. Note that large GOP control centers are classified as “High Impact” facilities in the CIP Version 5 standards, and a single facility can control more than 10,000 MW of generation.</p> <p><b>The SDT appreciates your suggestion; however, as we understand the point, it doesn’t apply continent-wide. The SDT has applied these events to RCs, BAs, and TOPs.</b></p> <p>(6) The “BES Emergency resulting in automatic firm load shedding” event row within Attachment 1 should include the BA as a responsible entity for reporting. Note that EOP-003-1 requires the BA to shed load in emergency situations (R1, R5 as examples), and any such occurrence should be reported.</p> <p><b>The SDT has reviewed your comment and would like to note that manual load shedding is only reportable if 100 MW or more is activated. Automatic load shedding is intended to be when a “relay” performs a breaker action that sheds load without human interaction and achieves a level of 100 MW or more.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Occidental Power Services, Inc.	No	There are no requirements in Attachment 1 for LSEs without BES assets so these entities should not be in the Applicability section.
<p><b>Response: The SDT thanks you for your comment. The LSE obligation in this standard was tied to applicability in CIP-008 for cyber incident reporting. Reporting under CIP-008 is no longer proposed to be a part of EOP-004-2 so this applicability has been removed. Please note that LSEs will be obligated to report under CIP-008 until that standard has been changed.</b></p>		
Xcel Energy	No	1) The event Damage or destruction of a Facility appears to need ‘qualifying’. Is this intended for only malicious intent? Otherwise, weather related or other operational events will often meet this criteria. For example adjustment in generation or changes



Organization	Yes or No	Question 2 Comment
		<p>in line limits to “avoid an Adverse Reliability Impact” could occur during a weather related outage. We suggest adjusting this event and criteria to clearly exclude certain items or identify what is included.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</p>

Organization	Yes or No	Question 2 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>2) Also recommend placing the information in footnote 1 into the associated Threshold for Reporting column, and removing the footnote.</p> <p><b>The SDT has removed the footnote per industry comments and concerns.</b></p>
<b>Response: The SDT thanks you for your comment.</b>		
American Electric Power	No	<p>If CIP-008 is now out of scope within the requirements of this standard, any references to it should also be removed from Attachment 1.</p> <p><b>The SDT has removed the one-hour reporting requirement as requested within</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>comments received.</b></p> <p>The Threshold for Reporting column on page 26 includes “Results from actual or suspected intentional human action.” This wording is too vague as many actions by their very nature are intentional. In addition, it should actually be used as a qualifying event rather than a threshold. We recommend removing it entirely from the Threshold column, and placing it in the Events column and also replacing the first row as follows: “Actual or suspected intentional human action with the goal of damage to, or destruction of, the Facility.”</p> <p>On page 27, the event “Any physical threat that could impact the operability of a Facility” is too vague and broad. Using the phrases “any physical threat” and “could impact” sets too high a bar on what would need to be reported. On page 28, for the event “Complete loss of off-site power to a nuclear generating plant (grid supply)”, TO and TOP should be removed and replaced by GOP.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Clark Public Utilities	No	<p>I agree with all but one. The event is "Damage or destruction of a Facility" and the threshold for reporting is "Results from actual or suspected intentional human action." I understand and agree that destruction of a facility due to actual or suspected intentional human action should always be reported. However, I do not know what level of damage should be reported. Obviously the term "damage" is meant to signify an event that is less than destruction. As a result, damage could be extensive, minimal, or hardly noticeable. There needs to be some measure of what the damage entails if the standard is to contain a broad requirement for the reporting of damage intentionally caused by human action. Whether that measure is based on the actual impacts to the BES from the damage or whether the measure is based on the ability of the damaged equipment to continue to function at 100%, 50% or some capability would be acceptable but currently it is too open ended.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p>		

Organization	Yes or No	Question 2 Comment
<p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).  The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>		
New York Power Authority	No	Please see comments submitted by NPCC Regional Standards Committee (RSC).
<p><b>Response: Thank you for your comment. Please see response to the comments.</b></p>		
Consolidated Edison Co. of NY, Inc.	No	<p>General comment regarding Attachment 1:SDT should strive to use identical language to event descriptions in the NERC Event Analysis Process and FERC OE-417. Creating a third set of event descriptions is not helpful to system operators. We recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>Replace the Attachment 1 “NOTE” with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required.</p>

Organization	Yes or No	Question 2 Comment
		<p><b>The SDT thanks you with your comment. First, the SDT believes that you intended the comment to address the “Note” on Attachment 2, not Attachment 1. The SDT does not believe that a hardcopy report is necessary if the organization has made voice contact.</b></p> <p>Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read, Results from actual or suspected intentional human action, excluding unintentional human errors.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” not states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>operations of each interconnection.</b></p> <p>Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or please provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Event: BES Emergency requiring public appeal for load reduction. Replace Event wording with language from #8 on OE-417 reporting form to eliminate reporting confusion. Following this sentence add, "This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is require to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>"Event: Complete or partial loss of monitoring capability Event wording: Delete the words "or partial" to conform the wording to NERC Event Analysis Process. Event: Transmission Loss Modify to BES Transmission Loss Event Generation Loss Modify to BES Generation Loss</p>
Orange and Rockland Utilities, Inc.	No	<p>General comment regarding Attachment 1: SDT should strive to use identical language to event descriptions in the NERC Event Analysis Process and FERC OE-417. Creating a third set of event descriptions is not helpful to system operators. We recommend aligning the Attachment 1 wording with that contained in Attachment 2, DOE Form OE-417 and the EAP whenever possible.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. Using identical terminology will be difficult to achieve as the DOE form and EAP have differing processes for identification of the reportable incidences. The SDT has tried to set up the reportable events in the standard to be as similar as possible to the other organizations without being tied to their specific</b></p>



Organization	Yes or No	Question 2 Comment
		<p><b>language. Attachment 2 has been modified to match the events types listed in Attachment 1.</b></p> <p>Replace the Attachment 1 “NOTE” with the following clarifying wording: NOTE: The Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator will accept the DOE OE-417 form in lieu of Attachment 2 if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422. Initial submittal by Voice within the reporting time frame is acceptable for all events when followed by a hardcopy submittal by Facsimile or e-mail as and if required.</p> <p><b>The SDT thanks you for your comment. First, the SDT believes that you intended the comment to address the “Note” on Attachment 2, not Attachment 1. The SDT does not believe that a hardcopy report is necessary if the organization has made voice contact.</b></p> <p>Event: Damage or destruction of a Facility Threshold for Reporting: revise language on third item to read, Results from actual or suspected intentional human action, excluding unintentional human errors.</p> <p><b>The SDT reviewed, discussed and updated “Damage and destruction of a Facility” based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. The new “threshold” not states:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could</b></p>

Organization	Yes or No	Question 2 Comment
		<p>adversely affect the reliability of the Bulk Electric System).</p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p>Event: Any physical threat that could impact the operability of a Facility This Event category should be deleted. The word “could” is hypothetical and therefore unverifiable and un-auditable. The word “impact” is undefined. Please delete this reporting requirement, or please provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Event: BES Emergency requiring public appeal for load reduction. Replace Event wording with language from #8 on OE-417 reporting form to eliminate reporting confusion. Following this sentence add, “This shall exclude other public appeals, e.g., made for weather, air quality and power market-related conditions, which are not made in response to a specific BES event.”</p> <p><b>The SDT disagrees with quantifying a use of public appeals reporting for different types of events. The important item here is that a public appeal was issued for load reduction. A report is require to inform the ERO (and whoever else the entity wishes to inform per Requirement R1) of your current status and provide them with the situational awareness of the status of your system.</b></p> <p>Event: Complete or partial loss of monitoring capability Event wording: Delete the words “or partial” to conform the wording to NERC Event Analysis Process.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or</b></p>

Organization	Yes or No	Question 2 Comment
		<p>TOP who have this capability to start with.</p> <p>Event: Transmission Loss Modify to BES Transmission Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</p> <p>Event Generation Loss Modify to BES Generation Loss</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</p> <p>OR</p> <p><math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
FirstEnergy Corp	No	<p>FE requests the following changes be made to Attachment 1:1. Pg. 19 / Event: “Voltage deviation on a Facility”. The term “observes” for Entity with Reporting Responsibility be changed to “experiences”. The burden should rest with the</p>

Organization	Yes or No	Question 2 Comment
		<p>initiating entity in consistency with other Reporting Responsibilities.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p>2. In “Threshold for Reporting”, the language should be expanded to - plus or minus 10% “of nominal voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>3. Pg.20 /Event: “Complete or partial loss of monitoring capability”. The term “partial” should be deleted from the event description to read as follows: Complete loss of monitoring capability and the reporting responsibility requirements to read “Each RC, BA, and TOP that experiences the complete loss of monitoring capability.”</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004</b></p>

Organization	Yes or No	Question 2 Comment
		<p>into EOP-004-2. This event is now written to state:</p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Farmington Electric Utility System	No	<p>The reporting threshold for “Complete or partial loss of monitoring capability” should be modified to include the loss of additional equipment and not be limited to State Estimator and Contingency Analysis. Some options have been included: Affecting a BES control center for 30 continuous minutes such that Real-Time monitoring tools are rendered inoperable. Affecting a BES control center for 30 continuous minutes to the extent a Constrained Facility would not be identified or an Adverse Reliability Impact event could occur due to lack of monitoring capability. Affecting a BES control center for 30 continuous minutes such that an Emergency would not be identified or ma</p>
<p><b>Response: The SDT thanks you for your comment. The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>		
Public Service Enterprise Group	No	<p>We agreed with most of the revisions. However, for the 24-hour reporting time frame portion of the EOP-004 Attachment 1: Reportable Event that starts on p. 18, we have these concerns: a. Why was “RC” left out in the first row? RC is in the second row that also addresses a “Facility.” We believe that “RC” was inadvertently</p>

Organization	Yes or No	Question 2 Comment
		<p>left out.</p> <p>b. In the first row, entities such as a BA, TO, GO, GOP, or DP would not know whether damage or destruction of one of its Facilities either “Affects an IROL (per FAC-014)” or “Results in the need for actions to avoid an Adverse Reliability Impact.” FAC-014-2, R5.1.1 requires Reliability Coordinators provide information for each IROL on the “Identification and status of the associated Facility (or group of Facilities) that is (are) critical to the derivation of the IROL” to entities that do NOT include the entities listed above. And frankly, those entities would not need to know. The reporting requirements associated with “Damage or destruction of a Facility” need to be changed so that the criteria for reporting by an entity whose Facilities experience damage or destruction does not rely upon information that the entity does not possess. c. A possible route to achieve the results in b. above is described below: i. All Facilities that are damaged or destroyed that “Results from actual or suspected intentional human action” would be reported to the ERO by the entity experiencing the damage or destruction. ii. All Facilities that are damaged or destroyed OTHER THAN THAT due to an “actual or suspected intentional human action” would be reported to the RC by the entity experiencing the damage or destruction. Based upon those reports, the RC would be required to report whether the reported damage or destruction of a Facility “Affects an IROL (per FAC-010)” or “Results in the need for actions to Avoid an Adverse Reliability Consequence.” (The RC may need to modify its data specifications in IRO-010-1a - Reliability Coordinator Data Specification and Collection - to specify outages due to “damage or destruction of a Facility.” We also note that “DP” is not included in IRO-010-1a, but “LSE” is included. DPs are required to also register as LSEs if they meet certain criteria. See the “Statement of Compliance Registry Criteria, Rev. 5.0”, p.7. For this reason, we suggest that DP be replaced with LSE in EOP-004-2.) d. To implement the changes in c. above, we suggest that the first row be divided into two rows: i. FIRST ROW: This would be like the existing first row on page 18, except “RC” would be added to the column for “Entity with Reporting Responsibility” and the only reporting threshold would be ““Results from actual or suspected intentional human action.” ii. SECOND ROW: The Event would be “Damage or destruction of a Facility of a BA, TO, TOP, GO,</p>

Organization	Yes or No	Question 2 Comment
		<p>GOP, or LSE,” the Entity, the Reporting Responsibility would be “The RC that has the BA, TOP, GO, GOP, or LSE experiencing the damage or destruction in its area,” and the Threshold for Reporting would be “Affects an IROL (per FAC-010)” or “Results in the need for actions to avoid an Adverse Reliability Consequence.”</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p><b>The SDT also developed another to read:</b></p>		



Organization	Yes or No	Question 2 Comment
		<p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p>
MidAmerican Energy	No	<p>Several modifications need to be made to Table 1 to enhance clarity and delete unnecessary or duplicate items. The stated reliability objective of EOP-004 and the drafting team is to reduce and prevent outages which could lead to cascading through reporting. It is understood that the EOP-004 Attachment 1 is to cover similar items to the DOE OE-417 form. Last, remember that FERC recently asked the question of what standards did not provide system reliability benefits. Those reports that cannot show a direct threat to a potential cascade need to be eliminated. Table 1 should always align with the cascade risk objectives and OE-417 where possible. Therefore Table 1 should be modified as follows:</p> <ol style="list-style-type: none"> <li>1. Completely divorce CIP-008 from EOP-004. Constant changes, the introduction of new players such as DOE and DHS, and repeated congressional bills, make coordination with CIP-008 nearly impossible. Cyber security and operational performance under EOP-004 remain separate and different despite best efforts to combine the two concepts.</li> </ol> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>2. Modify R1.2 to state that ERO notification only is required for Table 1. This is similar to the DOE OE-417 notification. Notification of other entities is a best practice, not a mandatory NERC standard. If entities want to notify neighboring entities, they may do so as a best practice guideline.</p> <p><b>The SDT has updated R1 based on comments received to read as:</b></p> <p><b>“R1. Each Responsible Entity shall have an event reporting Operating Plan that includes communication protocol(s) for applicable events listed in, and within the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations based on the event type (e.g. the Regional Entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, governmental or provincial agencies).”</b></p> <p>3. Better clarity for communicating each of the applicable events listed in the EOP-004 Attachment 1 in accordance with the timeframes specified are needed. MidAmerican suggests a forth column be added to the table to clearly identify who must be notified within the specified time period or at a minimum, that R1.2 be revised to clearly state that only the ERO must be notified to comply with the standard.</p> <p><b>The SDT disagrees but believes that per your Operating Plan contained in Requirement R1, an entity could take Attachment 1 and insert another column to assist whoever is designated to report an event within your company. The SDT does not want to be too prescriptive within Attachment 1.</b></p> <p>4. Consolidate OE-417 concepts on physical attack and cyber events by consolidating OE-417 items 1, 2, 9 and 10 to: Verifiable, credible, and malicious physical damage (excluding natural weather events) to a BES generator, line, transformer, or bus that when reported requires an appropriate Reliability Coordinator or Balancing Authority to issue an Energy Emergency Alert Level 2 or higher. The whole attempt to discuss a</p>

Organization	Yes or No	Question 2 Comment
		<p>NERC Facility and avoid adverse reliability impacts overreaches the fundamental principal or reporting for an emergency that could result in a cascade.</p> <p><b>The SDT disagrees since the OE-417 (and EAP) does not follow the ANSI process as NERC does in the Standards Development Process.</b></p> <p>5. The wording “affects an IROL (per FAC-014),” is too vague and not measurable. Many facilities could affect an IROL, but fewer facilities if lost would cause an IROL. Change “affects” to “results in”</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed”</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>6. Recommend that Adverse Reliability Impact be deleted and be replaced with actual EEA 2 or EEA 3 level events.</p> <p>The SDT has removed Adverse Reliability Impact based on industry feedback and rewrote the event:</p> <p>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are</p>

Organization	Yes or No	Question 2 Comment
		<p>required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>7. The phrase “results from actual or suspected intentional human action” is vague</p>

Organization	Yes or No	Question 2 Comment
		<p>and not measurable. This line item used the term “suspected” which relates to “sabotage”. MidAmerican recommends that “Results from actual or suspected intentional human action” be deleted. If not deleted the phrase should be replaced with “Results from verifiable, credible, and malicious human action intended to damage the BES.”</p> <p>8. Delete “Any physical threat...” as vague, and difficult to measure in a “perfect” zero defect audit environment, and as already covered by item 1 above. If not deleted, at a minimum replace “Any physical threat”, with “physical attack” as being measurable and consistent with DOE OE-417.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>9. With the use of “i.e.” the SDT is mandating that each other entity must be contacted. The NSRF believes that the SDT meant that “e.g.” should be used to provide examples. The SDT may wish to add another column to Attachment 1 to provide clarity.</p> <p><b>The SDT has made the required change concerning replacing “i.e.” with “e.g.”</b></p> <p>10. The phrase “or partial loss of monitoring capability” is too vague and should be deleted. In addition, the 30 minute window is too short for EMS and IT staff to effectively be notified and troubleshoot systems before being subjected to a federal law requiring reporting and potential violations. The time frame should be consistent with the EOP-008 standard. If not deleted, replace with “Complete loss of SCADA affecting a BES control center for 60 continuous minutes such that analysis tools of State Estimator and/or Contingency Analysis are rendered inoperable.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p> <p>11. Transmission loss should be deleted. The number of transmission elements out does not directly correlate to BES stability and cascading. For that reason alone, this</p>

Organization	Yes or No	Question 2 Comment
		<p>item should be deleted or it would have already been included in the past EOP-004 standard. In addition, large footprints can have multiple storms or weather events resulting in normal system outages. This should not be a reportable event that deals with potential cascading.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>12. Modify the threshold of “BES emergency requiring a public appeal...” to include, “Public appeal for a load reduction event resulting from a RC or BA implementing its emergency energy and capacity plans documented in EOP-001.” Public appeals for conservation that aren't used to avoid capacity and energy emergencies should be clearly excluded.</p> <p><b>The SDT disagrees as your request makes the event very prescriptive. The threshold is written to state: “Public appeal for load reduction event.” The SDT understands that there may be several reports of a single event and as the SDT has stated before, that this will give the ERO a better understanding of the depth and breathe of system conditions based on the given event.</b></p> <p>13. Add a time threshold to complete loss of off-site power to a nuclear plant. Nuclear plants are to have backup diesel generation that last for a minimum amount of time. A threshold recognizing this 4 hour or longer window needs to be added such as complete loss of off-site power to a nuclear plant for more than 4 hours.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT</b></p>



Organization	Yes or No	Question 2 Comment
		<p>removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.”</p> <p>As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</p> <p>Also see the NSRF comments.</p> <p>Please review the responses to that commenter.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Illinois Municipal Electric Agency	No	Illinois Municipal Electric Agency supports comments submitted by Florida Municipal Power Agency.
<p><b>Response: The SDT thanks you for your comment. Please review the responses to that commenter.</b></p>		
Americican Transmission Company, LLC	No	<p>ATC is proposing changes to the following Events in Attachment 1: (Reference Clean Copy of the Standard)</p> <p>1) Pg. 18/ Event: Any Physical threat that could impact the operability of a Facility. ATC is proposing a language change to the Threshold- “Meets Registered Entities criteria stated in its Event Reporting Operating Plan, in addition to excluding weather.”</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:</p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>2) Pg. 19 / Event: Voltage deviation on a Facility. ATC believes that the term “observes” for Entity with Reporting Responsibility be changed back to “experiences” as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. Also, for Threshold for Reporting, ATC believes the language should be expanded to - plus or minus 10% “of target voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</b></p>

Organization	Yes or No	Question 2 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Observed voltage deviation of <math>\pm 10\%</math> of nominal voltage sustained for <math>\geq 15</math> continuous minutes.”</p> <p>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</p> <p>3) Pg. 19/ Event: Transmission loss. ATC recommends that Threshold for Reporting be changed to read “Unintentional loss of four, or more Transmission Facilities, excluding successful automatic reclosing, within 30 seconds of the first loss experienced and for 30 continuous minutes. Technical justification or Discussion for this recommended change: In the instance of a transformer-line-transformer, scenario commonly found close-in to Generating stations, consisting of 3 defined “facilities”, 1 lightning strike can cause automatic unintentional loss by design. Increase the number of facilities to 4. In a normal shoulder season day, an entity may experience the unintentional loss of a 138kv line from storm activity, at point A in the morning, a loss of a 115kv line from a different storm 300 miles from point A in the afternoon, and a loss of 161kv line in the evening 500 miles from point A due to a failed component, if it is an entity of significant size. Propose some type of time constraint. Add time constraint as proposed, 30 seconds, other than automatic reclosing. In the event of dense lightning occurrence, the loss of multiple transmission facilities may occur over several minutes to several hours with no significant detrimental effect to the BES, as load will most certainly be affected (lost due to breaker activity on the much more exposed Distribution system) as well. Any additional loss after 30 seconds must take into account supplemental devices with intentional relay time delays, such as shunt capacitors, reactors, or load tap changers on transformers activating as designed, arresting system decay. In addition, Generator response after this time has significant impact.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with</p>

Organization	Yes or No	Question 2 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>4) Pg.20 /Event: Complete or partial loss of monitoring capability. ATC recommends that the term “partial” be deleted from the event description.ATC recommends that the term “partial” be deleted for the Entity with Reporting Responsibility and changed to read: Each RC, BA, and TOP that experiences the complete loss of monitoring capability.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Alliant Energy	No	<p>In the first Event for twenty four hour reporting, the last item in “Threshold for Reporting” should be revised to “Results from actual or suspected intentional malicious human action.” An employee may be performing maintenance and make a mistake, which could impact the BES. In the second Event for twenty four hour reporting the event should be revised to “Any physical attack that could impact the operability of a Facility.” Alliant Energy believes this is clearer and easier to measure.</p>

Organization	Yes or No	Question 2 Comment
<p>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the</p>		

Organization	Yes or No	Question 2 Comment
<p>situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>		
Consumers Energy	No	<p>The term "Facility" seems to be much more broad and even more vague than the use of BES equipment. We recommend reverting back to use of BES equipment.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT disagrees since BES is used within the definition of Facility. NERC defines Facility as: "A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)."</b></p>		
Ameren	No	<p>We appreciate the efforts of the SDT and believe this latest Draft is greatly improved over the previous version. However, we propose the following suggestions: (1) The first Event category in Attachment 1 under 24 Hour Reporting is Applicable to GO and GOP entities. Yet the first 2 of 3 Thresholds for Reporting require data that is unobtainable for GO and GOP entities. Specifically, Events that "Affects an IROL (per FAC-014)" and "Results in the need for actions to avoid an Adverse Reliability Impact". We believe these thresholds, and the use of the NERC Glossary term Adverse Reliability Impact, clearly show the SDT's intent to limit reporting only to Events that have a major and significant reliability impact on the BES. GO or GOP does not have access to the wide-area view of the transmission system, making them to make this determination is impossible. As a result, we do not believe GO and GOP entities should have Reporting Responsibility for these types of Events.</p> <p>(2) For GO and GOP entities, the third Threshold is confusing as to which facilities in the plant it would be applicable to; because the definition of "Facility" does not provide a clear guidance in that respect. For example, would a damage to ID fan qualify as a reportable event?</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</b></p>

Organization	Yes or No	Question 2 Comment
		<p>comments to state:</p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24</p>

Organization	Yes or No	Question 2 Comment
		<p>hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>(3) The second Event category in Attachment 1 under 24 Hour Reporting, "Any physical threat that could impact the operability of a Facility" is wide open to interpretation and thus impracticable to comply with. For example, a simple car accident that threatens any transmission circuit, whether it impacts the BES (as listed in the Threshold for the previous event in the table or any other measure) or not, is reportable. This list could become endless without the events having any substantial impact on the system. To continue this point, the Footnote 1 can also include, among many other examples, the following:(a) A wild fire near a generating plant, (b) Low river levels that might shut down a generating plant, (c) A crane that has partially collapsed near a generator switchyard, (d) Damage to a rail line into a coal plant, and/or (v) low gas pressure that might limit or stop operation of a natural gas generating plant.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT</b></p>



Organization	Yes or No	Question 2 Comment
		<p>removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p><b>"Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility."</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility's normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>(4) The category, "Transmission Loss" is a concern also. If the meaning of Transmission Facility is included in the meaning of Facility as described in the event list, it may be acceptable; but, we still have a question how would a loss of a bus and the multiple radial element that may be connected to that bus would be treated? Also, how would a breaker failure affect this type of an event? The loss of a circuit is</p>

Organization	Yes or No	Question 2 Comment
		<p>“intentional” (as opposed to Unintentional as listed in the threshold) for the failure of breaker, how will it be treated in counting three or more? We suggest a clarification for such types of scenarios.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>(5) Requirement R1.: 1.1 includes an exception from compliance with this Standard if there is a Cyber Security Incident according to CIP-008-3. However, note that the CIP-008-3 may not apply to all GO and GOP facilities. While the exception is warranted to eliminate duplicative event reporting plans, the language of this requirement is confusing as it does not clearly provides that message.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have proposed remanding the one hour event back to CIP-008.</b></p> <p>(6) The second paragraph in Section C.1.1.2. Includes the phrases “...shall retain the current, document...” and “...the “date change page” from each version...” Is the “document” intended to be the Operating Plan? We do not see a defining reference in the text around this phrase; also, is a “date change page” mandatory for compliance with this Standard? We request additional clarification of wording in the Evidence Retention section of the Standard.</p> <p>(7) Page 19 / Event: Voltage deviation on a Facility: We believe that the term “observes” for Entity with Reporting Responsibility be changed back to “experiences” as originally written. The burden should rest with the initiating entity in consistency with other Reporting Responsibilities. In addition, for Threshold for Reporting, We</p>

Organization	Yes or No	Question 2 Comment
		<p>believe the language should be expanded to - plus or minus 10%”of nominal voltage” for greater than or equal to 15 continuous minutes.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>(8) Page 20 /Event: Complete or partial loss of monitoring capability. We suggest to the SDT that the term “partial” be deleted from the event description.</p> <p>(9) We suggest to the SDT that the term “partial” be deleted for the Entity with Reporting Responsibility and changed to read: Each RC, BA, and TOP that experiences the complete loss of monitoring capability.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
We Energies	No	Submitting reports to the ERO: NERC and all of the Regional Entities are the ERO. If I

Organization	Yes or No	Question 2 Comment
		<p>send a report to any Regional Entity (and not NERC), I have sent it to the ERO.</p> <p><b>The SDT would like to point out the FERC has approved NERC to be the ERO. And the NERC has a delegation agreement with each Regional Entities. This Requirement R1 requires you send a report to the ERO (and whoever else the entity wishes to inform per Requirement R1 including the applicable regions if you are so obligated or its' your desire).</b></p> <p>Damage or Destruction of a Facility: A DP may not have a Facility by the NERC Glossary definition. All distribution is not a Facility. Did you mean to exclude all distribution?</p> <p><b>The SDT agrees that if a DP does not own or operate a Facility then this event would not be applicable to them.</b></p> <p>Any Physical threat that could impact the operability of a Facility: An RC does not have Facilities by the NERC Glossary definition. An RC will not have to report this. BES Emergency... Reporting Responsibility: If meeting the Reporting Threshold was due to a directive from the RC, who is the Initiating entity?</p> <p><b>The SDT agrees concerning the RC does not own a Facility and has removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>Voltage deviation on a Facility Threshold for Reporting: 10% of what voltage? Nominal, rated, scheduled, design, actual at an instant?</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</p> <p>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
NextEra Energy Inc	No	As stated in NextEra’s past comments, we continue to be concerned that EOP-004-2 does not appropriately address actual sabotage that threatens the Bulk Electric

Organization	Yes or No	Question 2 Comment
		<p>System (BES) versus random acts that are isolated and pose no risk to the BES. Therefore, NextEra repeats a portion of its past comments below in the hope that the next revision of EOP-004-2 will more adequately address NextEra’s concerns. Specifically, NextEra’s requests that its definition of sabotage set forth below replace Attachment 1’s “Damage and Destruction of Equipment” and “Any physical threat that could impact the operability of a Facility.” In Order No. 693, FERC stated its interest in NERC revising CIP-001 to better define sabotage and requiring notification to the certain appropriate federal authorities, such as the Department of Homeland Security. FERC Order No. 693 at PP 461, 462, 467, 468, 471. NextEra has provided an approach that accomplishes FERC’s objectives and remains within the framework of the drafting team, but also focuses the process of determining and reporting on only those sabotage acts that could affect other BES systems. Today, there are too many events that are being reported as sabotage to all parties in the Interconnection, when in reality these acts have no material affect or potential impact to other BES systems other than the one that experienced it. For example, while the drafting team notes the issue of copper theft is a localized act, there are other localized acts of sabotage that are committed by an individual, and these acts pose little, if any, impact or threat to other BES systems. Reporting sabotage that does not need to be sent to everyone does not add to the security or reliability of the BES. Relatedly, there is a need to clarify some of the current industry confusion on who should (and has the capabilities to) be reporting to a broader audience of entities. Hence, the NextEra approach provides a clear definition of sabotage, as well as the process for determining and reporting sabotage. New Definition for Sabotage. Attempted or Actual Sabotage: an intentional act that attempts to or does destroy or damage BES equipment for the purpose of disrupting the operations of BES equipment, or the BES, and has a potential to materially threaten or impact the reliability of one or more BES systems (i.e., one act of sabotage on BES equipment is only reportable if it is determined to be part of a larger conspiracy to threaten the reliability of the Interconnection or more than one BES system).</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has stated in our “Consideration of Issues and Directives – March 15,</b></p>		

Organization	Yes or No	Question 2 Comment
<p>2012” that was posted with the last posting stated:</p> <p>The SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of “event”. The SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p> <p>The SDT has discussed this with FERC Staff and we agree that sabotage could be a state of mind; and, therefore, the real issue: Was there an event or not?</p>		
ISO New England Inc	No	
<p><b>Response: The SDT thanks you for your participation.</b></p>		
Nebraska Public Power District	No	<p>1. The following comments are in regard to Attachment 1:A. The row [Event] titled “Damage or destruction of Facility”: 1. In column 3 [Threshold for Reporting], the word “Affect” is vague note the following concerns: i. Does “Affect” include a broken crossarm damaged without the Facility relaying out of service. This could be considered to have an “Affect” on the IROL. ii. Would the answer be different if the line relayed out of service and auto-reclosed (short interruption) for the same damaged crossarm? We need clarity from the SDT in order to know when a report is due.</p> <p>2. For clarification: Who initiates the report when the IROL interfaces spans between multiple entities? We know of an IROL that has no less that four entities that operate Facilities within the interface. Who initiates the report of the IROL is affected? All?</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</b></p>

Organization	Yes or No	Question 2 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p>



Organization	Yes or No	Question 2 Comment
		<p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>B. The row [Event] titled “Any physical threat that could impact the operability of a Facility”:1. In Column 1 [Event] change the word “threat” to “attack”, this aligns with the OE-417 report.2. In Column 3 [Threshold for Reporting], align the threshold with the OE-417 form.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p>

Organization	Yes or No	Question 2 Comment
		<p>Or</p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>C. The row [Event] titled “Transmission loss”, in column 3 [Threshold for Reporting], the defined term “Transmission Facilities” is too vague. There needs to be a more description such that an entity clearly understands when an event is reportable and for what equipment. We would recommend the definition used in the Event Reporting Field Trial: An unexpected outage, contrary to design, of three or more BES elements caused by a common disturbance. Excluding successful automatic reclosing. For example: a. The loss of a combination of NERC-defined Facilities. b. The loss of an entire generation station of three or more generators (aggregate generation of 500 MW to 1,999 MW); combined cycle units are represented as one unit.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry</b></p>

Organization	Yes or No	Question 2 Comment
		<p><b>comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p>D. The row [Event] titled “Complete or partial loss of monitoring”: 1. In column 1 [Event], delete the words “or partial”. This is subjective without definition, delete. 2. Also in column 1 [Event], delete the word “monitoring” and replace with Supervisory Control and Data Acquisition (SCADA). SCADA is defined term that explicitly calls out in the definition “monitoring and control” and is understood by the industry as such. 3. In column 2 [Entity with Reporting Responsibility], delete the words “or partial”; also delete the word “monitoring” and replace with SCADA. 4. In column 3 [Threshold for Reporting], reword to state “Complete loss of SCADA affecting a BES control center for <math>\geq</math> 30 continuous minutes”.</p> <p><b>The SDT reviewed, discussed and updated Attachment 1 based on comments received, FERC directives and what is required for combining CIP-001 and EOP-004 into EOP-004-2. This event is now written to state:</b></p> <p><b>“Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (State Estimator, Contingency Analysis) is rendered inoperable.” This will only apply to an RC, BA, or TOP who have this capability to start with.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
GTC	No	<p>Page 17 &amp; 18, One Hour Reporting and Twenty-four Hour Reporting: append the introductory statements with the following: “meeting the threshold for reporting” after recognition of the event. Example: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within twenty-four hours of recognition of the event meeting the threshold for reporting. Page 19, system separation (islanding); Clarify the intent of this threshold for reporting: Load <math>\geq</math> 100 MW and any generation; or Load <math>\geq</math> 100 MW and Generation</p>

Organization	Yes or No	Question 2 Comment
		>= 100 MW, or some combination of load and generation totaling 100 MW.
<p><b>Response: The SDT thanks you for your comment. The SDT has chosen not add the requested language as we believe the intent is understood that the time frames means from “meeting the threshold for reporting.” The SDT has revised the language regarding islanding and we believe it addresses your concern.</b></p>		
Indiana Municipal Power Agency	No	<p>The event "any physical threat that could impact the operability of a Facility" is not measurable and can be interpreted many ways by entities or auditors. IMPA recommend incorporating language that let's this be the judgment of the registered entity only.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or</b></p>

Organization	Yes or No	Question 2 Comment
		<p>activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>On the "voltage deviation on a Facility", IMPA recommends that only the TOP the experiences a voltage deviation be the one responsible for reporting.</p> <p><b>The SDT has made this change per comments received from the industry.</b></p> <p>For generation loss and transmission loss, IMPA believes that the amount of loss needs to be associated with a time period or event (concurrent forced outages).</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Idaho Power Co.	No	<p>I think that the category "Damage or destruction of a Facility" is too ambiguous, and the Threshold for Reporting criteria does not help to clarify the question. Any loss of a facility may result in the need for actions to get to the new operating point, would this be a reportable disturbance?</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency."</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
MISO	No	
American Public Power Association	No	<p>APPA in our comments on the previous draft of EOP-004-2 requested relief for small entities from this reporting/documentation standard. APPA suggested setting a 300 MW threshold for some of the criteria in Attachment 1. This suggestion was not accepted by the SDT. However, the SDT is still directed by FERC to “consider whether separate, less burdensome requirements for smaller entities may be appropriate. Therefore, APPA requests that the SDT provide relief to small entities by providing separate requirements for small entities by requiring reporting only when one of the four criteria in DOE-OE-417 are met: 1. Actual physical attack, 2. Actual cyber attack, 3. Complete operational failure, or 4. Electrical System Separation. APPA recommends this information should be reported to the small entity’s BA as allowed in the DOE-OE-417 joint filing process.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has taken your concerns into consideration (as directed by FERC) and believes that “small entities” will most likely not meet the thresholds for reporting since items are predicated on “Facilities” or they don’t meet the Threshold for reporting.</b></p>		
Brazos Electric Power Cooperative	No	Please see the comments submitted by ACES Power Marketing.

Organization	Yes or No	Question 2 Comment
<p><b>Response: The SDT thanks you for your comment. Please review the response to those comments.</b></p>		
<p>Puget Sound Energy, Inc.</p>	<p>No</p>	<p>The Note at the beginning of Attachment 1 references notifying parties per Requirement R1; however, notification occurs in conjunction with Requirement R2. The term “Adverse Reliability Impact” is used in the threshold section of the event “Damage or destruction of a Facility”. At this time, there are two definitions for that term in the NERC Glossary. The FERC-approved definition for this term is “The impact of an event that results in frequency-related instability; unplanned tripping of load or generation; or uncontrolled separation or cascading outages that affects a widespread area of the Interconnection.” If the drafting team instead means to use the definition that NERC approved on 8/4/2011 (as seems likely, since that definition more closely aligns with the severity level indicated by the other two threshold statements) then the definition should be included in the Implementation Plan as a prerequisite approval.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could</b></p>



Organization	Yes or No	Question 2 Comment
		<p><b>adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</b></p> <p>In addition, would the threshold of “Results from actual or suspected intentional human action” include results from actual intentional human action which produced an accidental result, meaning, someone was intentionally doing some authorized action but unintentionally made a mistake, leading to damage of a facility? The event “Any physical threat that could impact the operability of a Facility” will require reporting for many events that have little or no significance to reliable operation of the Bulk Electric System. For example, a balloon lodged in a 115 kV transmission line is a “physical threat” that could definitely “impact the operability” of that Facility and, yet, will probably have little reliability impact. So, too, could a car-pole accident that causes a pole to lean, a leaning tree, or an unfortunately-located bird’s nest. The drafting team should develop appropriate threshold language so that reporting is required only for events that do threaten the reliability of the Bulk Electric System.</p> <p><b>The SDT also developed another to read:</b></p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>With respect to the event “Unplanned control center evacuation”, the standard drafting team should include the term “complete” in the description and/or threshold statement to avoid having partial evacuations trigger the need to report.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Unplanned evacuation from BES control center facility for 30 continuous minutes or more.” The SDT does not believe the word “complete” needs to be added.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Central Lincoln	No	1) We appreciate the changes made to reduce the short time reporting requirements.

Organization	Yes or No	Question 2 Comment
		<p><b>The SDT has removed the one-hour reporting time frame, and all events are to be reported within 24 hours of recognition of the event.</b></p> <p>2) We would like to point out that the 24 hour reporting threshold for “Damage or destruction of a Facility” resulting from intentional human action will still be non-proportional BES risk for certain events. The discovery of a gunshot 115 kV insulator will start the 24 hour clock running, no matter how busy the discoverer is performing restoration or other duties that are more important. The damage may have been done a year earlier, but upon discovery the report suddenly becomes the priority task. To hit the insulator, the shooter likely had to take aim and pull the trigger, so intent is at least suspected if not actual. And the voltage level ensures the insulator is part of a Facility.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could</p>

Organization	Yes or No	Question 2 Comment
		<p>further define what a suspected intentional human action is within their Operating Plan.</p> <p>3) We also note that the theft of in service copper is not a physical threat, it is actual damage. The reference to Footnote 1 should be relocated or copied to the cell above the one it resides in now.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>4) We support the APPA comments regarding small entities.</p> <p>The SDT has taken your concerns into consideration (as directed by FERC) and believes that “small entities” will most likely not meet the thresholds for reporting</p>

Organization	Yes or No	Question 2 Comment
		since items are predicated on “Facilities.”
<b>Response: The SDT thanks you for your comment.</b>		
Los Angeles Department of Water and Power	No	<p>LADWP has the following comments:#1 - “Any physical threat that could impact the operability of a Facility” is still vague and “operability” is too low a threshold. There needs to be a potential impact to BES reliability.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed”</b></p>

Organization	Yes or No	Question 2 Comment
		<p>Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>#2 - “Voltage Deviation on a Facility” I think the threshold definition needs to be more specific: Is it 10% from nominal? 10% from normal min/max operating</p>

Organization	Yes or No	Question 2 Comment
		<p>tables/schedules? Another entities 10% might be different than mine.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>#3 - “Transmission Loss” The threshold of three facilities is still too vague. A generator and a transformer and a gen-tie are likely to have overlapping zones of protection that could routinely take out all three. The prospect of penalties would likely cause unneeded reporting.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Deseret Power	No	The threshold for reporting is way too low. A gun shot insulator is not an act of



Organization	Yes or No	Question 2 Comment
		terrorism... vandalism yes... and a car hit pole would be reportable on a 138 kv line. these seem to be too aggressive in reporting.
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p>		
Kansas City Power & Light	No	For the event, “Damage or destruction of a Facility”, the “Threshold for reporting” includes “Results from actual or suspected intentional human action”. This is too broad and could include events such as damage to equipment resulting from stealing cooper or wire which has no intentional motivation to disrupt the reliability of the bulk electric system. Reports of this type to law enforcement and governmental agencies will quickly appear as noise and begin to be treated as noise. This may result in overlooking a report that deserves attention. Recommend the drafting team consider making this threshold conditional on the judgment by the entity on the

Organization	Yes or No	Question 2 Comment
		<p>human action intended to be a potential threat to the reliability of the bulk electric system. For the event, “Any physical threat that could impact the operability of a Facility”, the same comment as above applies. The footnote states to include copper theft if the Facility operation is impacted. Again, it is recommended to make a report of this nature conditional on the judgment of the entity on the intent to be a potential threat to the reliability of the bulk electric system.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p> <p><b>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each</b></p>		

Organization	Yes or No	Question 2 Comment
		<p>interconnection.</p> <p>The SDT also developed another to read:</p> <p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
Dominion	Yes	<p>Comments: While Dominion agrees that the revisions are a much appreciated improvement, we are concerned that Attachment 1 does not explicitly contain the ‘entities which must be, at a minimum, notified.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified.</b></p> <p>Attachment 2 appears to indicate that only the ERO and the Reliability Coordinator for the Entity with Reporting Responsibility need be informed. However, the background section indicates that the Entity with Reporting Responsibility is also</p>

Organization	Yes or No	Question 2 Comment
		<p>expected to contact local law enforcement. We therefore suggest that Attachment 2 be modified to include local law enforcement.</p> <p><b>The SDT has adapted the language in Attachment 2 along the lines of your concern.</b></p> <p>Page 26 redline; Attachment 1; Event - Damage or destruction of a Facility; Threshold for Reporting - Results from actual or suspected intentional human action; Dominion is concerned with the ambiguity that this could be interpreted as applying to distribution. Page 27 redline; Attachment 1; Event - Any physical threat that could impact the operability of a Facility; Dominion is concerned the word “could” is hypothetical and therefore unverifiable and un-auditable.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</b></p> <p><b>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</b></p>

Organization	Yes or No	Question 2 Comment
		<p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within</p>

Organization	Yes or No	Question 2 Comment
		<p>their Operating Plan.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p> <p>The SDT could provide a list of hypothetical “could impact” events, as well as a specific definition and method for determining a specific physical impact threshold for “could impact” events other than “any.”</p>

Organization	Yes or No	Question 2 Comment
		The SDT cannot provide a list of hypothetical events, but will remind the entity that the Operating Plan that is required per Requirement R1 could contain a basis to report concerning your unique system equipment or configuration of your system.
<b>Response: The SDT thanks you for your comment.</b>		
Seattle City Light	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Avista	Yes	In general the SDT has made significant improvements to Attachment 1. Avista does have a suggestion to further improve Attachment 1. In Attachment 1 under the 24 hour Reporting Matrix, the second event states "Any physical threat that could impact the operability of a Facility" and the Threshold for Reporting states "Threat to a Facility excluding weather related threats". This is extremely open ended. We suggest adding the following language to the Threshold for Reporting for Any Physical Threat: Threat to a facility that: Could affect an IROL (per FAC-014) OR Could result in the need for actions to avoid and Adverse Reliability Impact This new language would be consistent with the reporting threshold for a Damage event.
<p><b>Response: The SDT thanks you for your comment. The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator</b></p>		

Organization	Yes or No	Question 2 Comment
		<p>Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT</p>



Organization	Yes or No	Question 2 Comment
<b>envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b>		
PNGC Comment Group	Yes	<p>We agree with reservations. Our comments are below and we are seeking clarification of the Applicability section of the standard. We are voting "no" but if slight changes are made to the applicability section we will change our votes to "yes". NERC and FERC have expressed a willingness to address the compliance burden on smaller entities that pose minimal risk to the Bulk Electric System. The PNGC Comment Group understands the SDT's intent to categorize reportable events and achieve an Adequate Level of Reliability while also understanding the costs associated. Given the changes made by the SDT to Attachment 1, we believe you have gone a long way in alleviating the potential for needless reporting from small entities that does not support reliability.</p> <p><b>The SDT has taken your concerns into consideration (as directed by FERC) and believes that "small entities" will most likely not meet the thresholds for reporting since items are predicated on "Facilities."</b></p> <p>One remaining concern we have are potential reporting requirements in the Event types; "Damage or destruction of a Facility" and "Any physical threat that could impact the operability of a Facility". These two event types have the following threshold language; "Results from actual or suspected intentional human action" and "Threat to a Facility excluding weather related threats" respectively. We believe these two thresholds could lead to very small entities filing reports for events that really are not a threat to the BES or Reliability.</p> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</b></p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p>

Organization	Yes or No	Question 2 Comment
		<p data-bbox="772 269 1885 378">“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p data-bbox="772 456 1885 643">This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p data-bbox="772 721 1885 984">This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p data-bbox="772 1062 1318 1094">The SDT also developed another to read:</p> <p data-bbox="772 1172 1766 1240">“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p data-bbox="772 1268 1871 1414">This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or</p>

Organization	Yes or No	Question 2 Comment
		<p><b>destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p>Note: For vandalism, sabotage or suspected terrorism, even the smallest entities will file a police report and at that point local law enforcement will follow their terrorism reporting procedures if necessary, as you’ve rightly indicated in your “Law Enforcement Reporting” section. We believe extraneous reporting could be alleviated with a small tweak to the Applicability section for 4.1.9 to exclude the smallest Distribution Providers. As stated before, even if these very small entities are excluded from filing reports under EOP-004-2, threats to Facilities that they may have will still be reported to local law enforcement while not cluttering up the NERC/DOE reporting process for real threats to the BES. Our suggested change:4.1.9. Distribution Provider: with peak load &gt;= 200 MWs. The PNGC Comment Group arrived at the 200 MWs threshold after reviewing Attachment 1, Event “Loss of firm load for &gt;= 15 Minutes”. We agree with the SDT’s intent to exclude these small firm load losses from reporting through EOP-004-2. Another approach we could support is that taken by the Project 2008-06 SDT with respect to Distribution Provider Facilities:4.2.2 Distribution Provider: One or more of the Systems or programs designed, installed, and operated for the protection or restoration of the BES:</p>

Organization	Yes or No	Question 2 Comment
		<p><b>The SDT has discussed this very issue and would like to point out that the Threshold for Reporting limits are the same as in the enforceable Reliability Standard, EOP-004-1. The SDT believes that small entities (200mw or less) would not be applicable to this event. The SDT has attempted to place these types of limits to reduce small entities from having these applicable reporting requirements.</b></p> <ul style="list-style-type: none"> <li>o A UFLS or UVLS System that is part of a Load shedding program required by a NERC or Regional Reliability Standard and that performs automatic Load shedding under a common control system, without human operator initiation, of 300 MW or more</li> <li>o A Special Protection System or Remedial Action Scheme where the Special Protection System or Remedial Action Scheme is required by a NERC or Regional Reliability Standard</li> <li>o A Protection System that applies to Transmission where the Protection System is required by a NERC or Regional Reliability Standard</li> <li>o Each Cranking Path and group of Elements meeting the initial switching requirements from a Blackstart Resource up to and including the first interconnection point of the starting station service of the next generation unit(s) to be started. We're not advocating this exact language but rather the approach that narrows the focus to what is truly impactful to reliability while minimizing costs and needless compliance burden. One last issue we have is with the language in Attachment 1, Event "BES Emergency resulting in automatic firm load shedding." Under "Entity with Reporting Responsibility", you state that the DP or TOP that "implements" automatic load shedding of &gt;= 100 MWs must report (Also please review the CIP threshold of 300 MWs as this may be a more appropriate threshold). We believe rather than specifying a DP or TOP report, it would be appropriate for the UFLS Program Owner to file the report per EOP-004-2. In our situation we have DPs that own UFLS relays that are part of the TOP's program and this could lead to confusing reporting requirements. Also we don't believe that an entity can "Implement" "Automatic" load shedding but this is purely a semantic issue.</li> </ul> <p><b>The SDT has updated Damage or destruction of a facility into 2 different thresholds: The SDT removed all language under "Entity with Reporting Responsibility" with</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p> <p>“Damage or destruction of its Facility that results from actual or suspected</p>

Organization	Yes or No	Question 2 Comment
		<p>intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
United Illuminating Company	Yes	<p>The phrasing of the event labeled as Event Damage or Destruction of a Facility may be improved in the Threshold for Reporting Column. Suggest the introduction sentence for this event should be phrased as Where the Damage or Destruction of a Facility: etc. The rationale for the change is that as written it is unclear if the list that follows is meant to modify the word Facilities or the overall introductory sentence. The confusion being caused by the word That. What is important to be reported is if a Facility is damaged and then an IROL is affected it should be reported, not that if a Facility is comprising an IROL Facility is damaged but there is no impact on the IROL.</p>

Organization	Yes or No	Question 2 Comment
		<p>The SDT has updated Damage or destruction of a facility into 2 different thresholds:</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT also developed another to read:</p>

Organization	Yes or No	Question 2 Comment
		<p><b>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</b></p> <p><b>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</b></p> <p><b>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</b></p> <p><b>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</b></p> <p><b>Second, the top of each table is the phrase Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event. This creates the requirement that the actual form is required to be transmitted to parties other than NERC/DOE. The suggested revision is Submit EOP-004 Attachment 2 or DOE-OE-417 report to NERC and/or DOE, and complete notification to other organizations identified pursuant to Requirement R1 Part 1.2 within one hour etc..</b></p> <p><b>The SDT has revised Attachment 2 heading to read “Use this form to report events. The Electric Reliability Organization will accept the DOE OE-417 form in lieu of this</b></p>



Organization	Yes or No	Question 2 Comment
		<p>form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> voice: 404-446-9780.” Based on industry comments.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Ingleside Cogeneration LP	Yes	<p>Ingleside Cogeneration LP agrees with the removal of nearly all one hour reporting requirements. In our view there must be a valid contribution expected of the recipients of any reporting that takes place this early in the process. Any non-essential communications will impede the progress of the front-line personnel attempting to resolve the issue at hand - which has to be the priority. Secondly, there is a risk that early reporting may include some speculation of the cause, which may be found to be incorrect as more information becomes available. Recipients must temper their reactions to account for this uncertainty. In fact, Ingleside Cogeneration LP recommends that the single remaining one-hour reporting scenario be eliminated. It essentially defers the reporting of a cyber security incident to CIP-008 anyways, and may even lead to a multiple violation of both Standards if exceeded.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT agrees and has removed the one-hour reporting requirement based on comments received.</b></p>		
Springfield Utility Board	Yes	<p>o Spell out Requirement 1, rather than “parties per R1” in NOTE. o On page 44, “Examples of such events include” should say, “include, but are not limited to”. o SUB appreciates clarification regarding events, particularly the discussion regarding “sabotage”, and recommends listing and defining “Event” in Definitions and Terms Used in NERC Standards.</p> <p><b>The SDT has stated in our “Consideration of Issues and Directives – March 15, 2012” that was posted with the last posting stated:</b></p> <p><b>The SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in</b></p>

Organization	Yes or No	Question 2 Comment
		<p>the definition. Attachment 1 is the de facto definition of “event.” The SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p> <p><b>The SDT has discussed this with FERC Staff and we agree that sabotage could be a state of mind and therefore the real issue was there an event or not.</b></p> <p>o The Guideline and Technical Basis provides clarity, and SUB agrees with the removal of “NERC Guideline: Threat and Incident Reporting”.</p> <p>o In the flow chart on page 9 there are parallel paths going from “Refer to Ops Plan for Reporting” to the ‘Report Event to ERO, Reliability Coordinator’ via both the Yes and No response. It seems like the yes/no decision should follow after “Refer to Ops Plan” for communication to law enforcement.</p> <p><b>The SDT has offered the flowchart as an example of how an entity could handle the notification to law enforcement agencies. There is no requirement to follow the flowchart. Entities are free to develop their own procedures based upon their needs to report.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
PPL Electric Utilities	Yes	<p>PPL EU thanks the SDT for the changes made in this latest proposal. We feel our prior comments were addressed. Regarding the event 'Transmission Loss': For your consideration, please consider adding a footnote to the event ‘Transmission Loss’ such that weather events do not need to be reported. Also please consider including 'operation contrary to design' in the threshold language. E.g. consistent with the</p>

Organization	Yes or No	Question 2 Comment
		NERC Event Analysis table, the threshold would be, 'Unintentional loss, contrary to design, of three or more BES Transmission Facilities.'
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing)."</b></p>		
Tacoma Power	Yes	Tacoma Power supports the revisions. It appears that all agencies and entities are willing to support the use of the DOE Form OE-417 as the initial notification form (although EOP-004 does include their own reporting form as an attachment to the Standard). Tacoma is already using the OE-417 and distributing it to all applicable Entities and Agencies.
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Seattle City Light	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<p><b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b></p>		
MEAG Power	Yes	This is a great improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.
<p><b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b></p>		
Public Utility District No. 1 of Snohomish County		This is an excellent improvement over the prior CIP and EOP versions. However, please see #4 for overall comment.

Organization	Yes or No	Question 2 Comment
<b>Response: The SDT thanks you for your comment. Please review the response to Question 4.</b>		
Imperial Irrigation District (IID)	Yes	
Colorado Springs Utilities	Yes	
Arizona Public Service Company	Yes	
Utility Services	Yes	
Dynergy Inc.	Yes	
Manitoba Hydro	Yes	
City of Austin dba Austin Energy	Yes	
Entergy	Yes	
Pepco Holdings Inc	Yes	
Independent Electricity System Operator	Yes	
Cowlitz County PUD	Yes	
Edison Mission Marketing & Trading, Inc.	Yes	
Exelon Corporation and its affiliates	Yes	

Organization	Yes or No	Question 2 Comment
ERCOT	Yes	
Oncor Electric Delivery	Yes	

3. The SDT has proposed a new Section 812 to be incorporated into the NERC Rules of Procedure. Do you agree with the proposed addition? If not, please explain in the comment area below.

**Summary Consideration:** The DSR SDT proposed a revision to the NERC Rules of Procedure (Section 812). The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.

Organization	Yes or No	Question 3 Comment
Northeast Power Coordinating Council	No	The proposed new section does not contain specifics of the proposed system nor the interfacing outside of the system to support the report collecting.
<p><b>Response:</b> The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</p>		
SPP Standards Review Group	No	We have two concerns about the proposed change to the RoP. One, we have concerns that our information and data will be circulated to an as yet undetermined audience which appears to be solely under NERC’s control. Secondly, there isn’t sufficient detail in the clearinghouse concept to support comments at this time.
<p><b>Response:</b> The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</p>		
ISO/RTO Standards Review Committee	No	The SRC offers comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see the latter part of the SRC’s response to Question 4 below for an SRC proposed alternative approach: The SRC is unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the

Organization	Yes or No	Question 3 Comment
		proposal when the proposed addition is posted.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
ACES Power Marketing Standards Collaborators	No	<p>(1) It is not clear to us what is the driving the need for the Rules of Procedure proposal. NERC is already collecting event and disturbance reports without memorializing the change in the Rules of Procedure. (2) The language potentially conflicts with other subsections in Section 800. For instance, the proposal says that the system will apply to collect report forms “for this section”. This section would refer to Section 800. Section 800 covers NERC alerts and GADS. Electronic GADS (eGADS) already has been established to collect GADS data? Will this section cause NERC to have to incorporate eGADS into this report collection system? Incorporating NERC Alerts is also problematic because when reports are required as a result of a NERC alert, the report must be submitted through the NERC Alert system.(3) The statement that “a system to collect report forms as established for this section or standard” causes additional confusion regarding to which standards it applies. Does it only apply to this new EOP-004-2 or to all standards? If it applies to all standards, does this create a potential issue for CIP-008-3 R1.3 which requires reporting to the ES-ISAC and not this clearinghouse?</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Seattle City Light	No	Seattle City Light follows MEAG and believes this type of activity and process is better suited to NAESBE than it is to NERC Compliance.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Hydro One	No	The proposed new section does not contain specifics of the proposed system nor the

Organization	Yes or No	Question 3 Comment
		interfacing outside of the system to support the report collecting.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
CenterPoint Energy	No	<p>CenterPoint Energy does not agree with the SDT’s proposed section 812. The proposal for NERC to establish a system that will “...forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary. This can include state, federal, and provincial organizations.” is redundant with the draft Standard. Responsible entities are already required to report applicable events to NERC, applicable regional entities, registered entities, and appropriate governmental, law enforcement, and regulatory agencies. CenterPoint Energy believes if the SDT’s intent is to require NERC to distribute these system event reports, then EOP-004-2 should be revised to require responsible entities to only report the event to NERC. As far as distribution to appropriate NERC departments, CenterPoint Energy believes that is an internal NERC matter and does not need to be included in the Rules of Procedure.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Arkansas Electric Cooperative Corporation	No	AECC supports the comments submitted by ACES Power Marketing.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
National Rural Electric Cooperative Association (NRECA)	No	<p>NRECA is concerned with the drafting team's proposal to add a new Section 812 to the NERC ROP. NRECA does not see the need for the drafting team to make such a proposal as it relates to the new EOP-004 that the drafting team is working on. The</p>



Organization	Yes or No	Question 3 Comment
		<p>requirements in the draft standard clearly require what is necessary for this Event Reporting standard. NRECA requests that the drafting team withdraw its proposed ROP Section 812 from consideration. The proposed language is unclear to the point of not being able to understand who is being required to do what. Further, the language is styled in more of a proposal, and not in the style of what would appropriately be included in the NERC ROP. Finally, the SDT has not adequately supported the need for such a modification to the NERC ROP. Without that support, NRECA is not able to agree with the need for this addition to the ROP. Again, NRECA requests that the drafting team withdraw its proposed ROP Section 812 from consideration.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Occidental Power Services, Inc.	No	<p>This section should reference the confidentiality requirements in the ROP and should have a statement about the system for collection and dissemination of disturbance reports being “subject to the confidentiality requirements of the NERC ROP.”</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Pepco Holdings Inc	No	<p>This could create confusion. This new ROP section states that “... the system shall then forward the report to the appropriate NERC departments, applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary.” Standard Section R1.2 states “A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.” If NERC is going to be the “clearinghouse” forwarding reports to the RE and DOE, does that mean that</p>

Organization	Yes or No	Question 3 Comment
		<p>the reporting entity only needs to make a single submission to NERC for distribution? If the reporting entity is required to make all notifications, per R1.2, what is the purpose of NERC's duplication of sending out reports? It would be very helpful to the reporting entities if R1.2 was revised to state that NERC would forward the event form to the RE and DOE and the reporting entity would only be responsible for providing notice verbally to its associated BA, TOP, RC, etc. as appropriate and for notifying appropriate law enforcement as required.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Independent Electricity System Operator	No	<p>We are unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the proposal when the proposed addition is posted.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
MidAmerican Energy	No	<p>See the NSRF comments. The NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC's crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Public Utility District No. 1 of Snohomish County	No	<p>This type of activity and process is better suited to NAESBE than it is to NERC Compliance.</p>

Organization	Yes or No	Question 3 Comment
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Illinois Municipal Electric Agency	No	Illinois Municipal Electric Agency supports comments submitted by ATC.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Americian Transmission Company, LLC	No	ATC believes that the NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC’s crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Ameren	No	If the SDT keeps new Section 812 we suggest to the SDT a wording change for the second sentence, underlined: “Upon receipt of the submitted report, the system shall then forward the report to the appropriate NERC department for review. After review, the report will be forwarded to the applicable regional entities, other designated registered entities, and to appropriate governmental, law enforcement, regulatory agencies as necessary.”
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
We Energies	No	Section 812 refers to the section as a standard and as a Procedure. That is not correct. Section 812 reads to me as if NERC (the system) will be forwarding everything

Organization	Yes or No	Question 3 Comment
		specified anywhere in RoP 800.
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Exelon Corporation and its affiliates	No	<p>While we don't have any immediate objection to revising the Rules of Procedures (ROP) to allow for report collecting under Section 800 relative to the EOP-004 standard, the proposed language is unclear and confusing. Please consider the following revision:"812. NERC Reporting Clearinghouse NERC will establish a system to collect reporting forms as required for Section 800 or per FERC approved standards from any Registered Entities. NERC shall distribute the reports to the appropriate governmental, law enforcement, regulatory agencies as required per Section 800 or the applicable standard."Further, NERC should post ROP revisions along with a discussion justifying the revision for industry comment specific to the ROP. There may be significant implications to this revision beyond the efforts relative to EOP-004.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Tacoma Power	No	<p>Tacoma Power disagrees with the requirement to perform annual testing of each communication plan. We do not see any added value in performing annual testing of each communication plan. There are already other Standard requirements to performing routine testing of communications equipment and emergency communications with other agencies.The "proof of compliance" to the Standard should be in the documentation of the reports filed for any qualifying event, within the specified timelines and logs or phone records that it was communicated per each specified communication plan.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		

Organization	Yes or No	Question 3 Comment
Seattle City Light	No	Seattle City Light follows MEAG and believes this type of activity and process is better suited to NAESBE than it is to NERC Compliance.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
MEAG Power	No	This type of activity and process is better suited to NAESBE than it is to NERC Compliance.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
ERCOT	No	ERCOT has joined the IRC comments on this project.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Idaho Power Co.	No	No opinion
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
MISO	No	MISO agrees with and adopts the Comments of the IRC on this issue.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Brazos Electric Power Cooperative	No	Please see the comments submitted by ACES Power Marketing.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports</b>		

Organization	Yes or No	Question 3 Comment
<b>to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Kansas City Power & Light	No	Rules stipulating the extent of how reported information will be treated by NERC is an important consideration, however, the proposed section 812 proposes to provide reports to other governmental agencies and regulatory bodies beyond that of NERC and FERC. NERC should be treating the event information reported to NERC as confidential and should not take it upon itself to distribute such information beyond the boundaries of the national interest at NERC and FERC.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Dominion	Yes	While Dominion supports this addition, we suggest adding to the sentence “NERC will establish a system to collect report forms as established for this section or reliability standard.....”
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
MRO NSRF	Yes	ATC believes that the NERC Rules of Procedure Section 807 already addresses the dissemination of Disturbance data, as does Appendix 8 Phase 1 with the activation of NERC’s crisis communication plan, and the ESISAC Concept of Operations. The addition of proposed Section 812 is not necessary. The Reliability Coordinator, through the use of the RCIS, would disseminate reliability notifications if it is in turn notified per R1.2. (As stated in the in the Clean copy of EOP-004-2)
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration is encouraged by NERC’s willingness to act as central data gathering point for event information. However, we see this only as a starting point.

Organization	Yes or No	Question 3 Comment
		<p>There are still multiple internal and external reporting demands that are similar to those captured in EOP-004-2 - examples include the DOE, RAPA (misoperations), EAWG (events analysis), and ES-ISAC (cyber security). Although we appreciate the difference in reporting needs expressed by each of these organizations, there are very powerful reporting applications available which capture a basic set of data and publish them in multiple desirable formats. We ask that NERC spearhead this initiative - as it is a natural part of the ERO function.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
American Electric Power	Yes	<p>While we have no objections at this point, we would like specific details on what our obligations would be as a result of these changes. For example, would the clearinghouse tool provide verifications that the report(s) had been received as well as forwarded? In addition, if DOE OE-417 is the form being submitted, would the NERC Reporting Clearinghouse forward that report to the DOE?</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
Springfield Utility Board	Yes	<p>o SUB supports the new Section 812 being incorporated into the NERC ROP. This addition provides clarity for what is required by whom and takes away any possible ambiguity.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
FirstEnergy Corp	Yes	<p>FE agrees but asks that the defined term “registered entities” in the second sentence be capitalized.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports</b></p>		

Organization	Yes or No	Question 3 Comment
<b>to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
GTC	Yes	With the exception of the RC and company personnel, it appears this proposed section captures the same reporting obligations and to the same entities via R1.2. Recommend adjustments to R1.2 such that reportable events are submitted to NERC, RC, and company personnel.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Central Lincoln	Yes	Thank you for minimizing the number of necessary reports.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Xcel Energy		We believe such a tool would be useful, however we are indifferent as to if it is required to be established by the Rules of Procedure.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
ISO New England Inc		We unable to comment on the proposed new section as the section does not contain any description of the proposed process or the interface requirements to support the report collecting system. We reserve judgment on this proposal and our right to comment on the proposal when the proposed addition is posted.
<b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b>		
Indiana Municipal Power Agency		no comment



Organization	Yes or No	Question 3 Comment
Los Angeles Department of Water and Power		LADWP does not have a comment on this question at this time
<p><b>Response: The SDT thanks you for your comment. The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.</b></p>		
DECo	Yes	
Duke Energy	Yes	
Luminant	Yes	
Bonneville Power Administration	Yes	
Imperial Irrigation District (IID)	Yes	
Florida Municipal Power Agency	Yes	
LG&E and KU Services	Yes	
PPL Corporation NERC Registered Affiliates	Yes	
PNGC Comment Group	Yes	
Colorado Springs Utilities	Yes	
Arizona Public Service Company	Yes	

Organization	Yes or No	Question 3 Comment
Southern Company Services	Yes	
Utility Services	Yes	
Georgia System Operations Corporation	Yes	
Manitoba Hydro	Yes	
Clark Public Utilities	Yes	
New York Power Authority	Yes	
Consolidated Edison Co. of NY, Inc.	Yes	
Orange and Rockland Utilities, Inc.	Yes	
Farmington Electric Utility System	Yes	
Public Service Enterprise Group	Yes	
PPL Electric Utilities	Yes	
Cowlitz County PUD	Yes	
Edison Mission Marketing & Trading, Inc.	Yes	

Organization	Yes or No	Question 3 Comment
American Public Power Association	Yes	
Oncor Electric Delivery	Yes	
Deseret Power	Yes	

4. Do you have any other comment, not expressed in the questions above, for the SDT?

**Summary Consideration:** The DSR SDT received several suggestions for improvement to the standard. The DSR SDT has removed reporting of Cyber Security Incidents from EOP-004 and have asked the team developing CIP-008-5 to retain this reporting. Most of the language contained in the “Background” Section was moved to the “Guidelines and Technical Basis” Section. Minor language changes were made to the measures and the data retention section. Attachment 2 was revised to list events in the same order in which they appear in Attachment 1.

Organization	Yes or No	Question 4 Comment
Texas Reliability Entity		<p>(1) The ERO and Regional Entities should not be included in the Applicability of this standard. The only justification given for including them was they are required to comply with CIP-008. CIP-008 contains its own reporting requirements, and no additional reliability benefit is provided by including ERO and Regional Entities in EOP-004. Furthermore, stated NERC policy is to avoid writing requirements that apply to the ERO and Regional Entities, and we do not believe there is any sufficient reason to deviate from that policy in this standard.</p> <p><b>The SDT is revising the standard to not contain reporting for Cyber Security Incidences. Under the revisions, CIP-008-3 and successive versions will retain the reporting requirements. The Applicability section has been revised to address this situation.</b></p> <p>(2) Under Compliance, in section 1.1, all the words in “Compliance Enforcement Authority” should be capitalized.</p> <p><b>The SDT agrees and has adopted this suggestion.</b></p> <p>(3) Under Evidence Retention, it is not sufficient to retain only the “date change page” from prior versions of the Plan. It is not unduly burdensome for the entity to retain all prior versions of its “event reporting Operating Plan” since the last audit, and it should be required to do so. (What purpose is supposed to be served by</p>

Organization	Yes or No	Question 4 Comment
		<p>retaining only the “date change pages”?)</p> <p><b>The SDT has revised the standard to require the retention of previous versions, not just the date change page.</b></p> <p>(4) The title of part F, “Interpretations,” is incorrect on page 23. Should perhaps be “Associated Documents.”</p> <p><b>The SDT has revised Part F and it now contains the Guidelines and Technical Basis.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>ACES Power Marketing Standards Collaborators</p>		<p>(1) IC, TSP, TO, GO, and DP should be all removed from the applicability of the standard. Previous versions of the standard did not apply to them and we see no reason to expand applicability to them. IC and TSP are not even mentioned in any of the “Entity with Reporting Responsibility” sections. For the sections that do not mention specific entities, IC and TSP would have no responsibility for any of the events. The TO and GO are not operating entities so the reporting should not apply to them. DP was not included in any previous versions of CIP-001 or EOP-004. Any information (such as load) that was necessary regarding DPs was always gathered by the BA or TOP and included in their reports. There is no indication that this process was not working and, therefore, it should not be changed. Furthermore, including the DP potentially expands the standard outside of the Bulk Electric System which is contrary to recent statements that NERC Legal has made at the April 11 and 12, 2012 SC meeting. Their comments indicated the standards are written for the Bulk Electric System. What information does a DP have to report except load loss which can easily be reported by the BA or TOP?</p> <p><b>The SDT disagrees with some of your suggestions. As the standard is to report events associated with physical assets, it is incumbent for the asset owners to file the reports associated with any events. Thus DP, TO, and GO were added to the Applicability of this standard. Their perspectives on events can be useful in evaluating situational awareness and providing NERC with information on lessons learned. Further, this standard limits reporting to BES Elements except where</b></p>

Organization	Yes or No	Question 4 Comment
		<p>noted. This is consistent with NERC and SC Standard Process design. Where this standard had included other functional registrations associated with the inclusion of CIP-008; those registrations have been removed from the standard.</p> <p>(2) Measure M2 needs to clarify an attestation is an acceptable form of evidence if there are no events.</p> <p><b>Registered Entities must determine how to best demonstrate they have met the performance obligation of a requirement. The use of an attestation statement is already permitted and recognized with the NERC Compliance Program if that is the best means of demonstrating your performance under the requirement. Auditors will then assess whether or not an attestation meets the requirement in one's audit. Attestations cannot be specifically permitted for use.</b></p> <p>(3) The rationale box for R3 and R4 should be modified. It in essence states that updating the event reporting Operating Plan and testing it will assure that the BES remains secure. While these requirements might contribute to reliability, these two requirements collectively will not assure BES security and stability.</p> <p><b>The SDT has revised the rationale box language based upon the changes it has made to the requirements. It should be noted that upon acceptance of the standard, the language in the rationale boxes are removed from the standard.</b></p> <p>(4) We disagree with the VSLs for Requirement R2. While the VSLs associated with late reporting for a 24-hour reporting requirement include four VSLs, the one-hour reporting requirement only includes three VSLs. There seems to be no justification for this inconsistency. Four VSLs should be written for the one-hour reporting requirement.</p> <p><b>As the standard has been revised to remove the one-hour reporting provision, your suggestion is moot.</b></p> <p>(5) Reporting of reportable Cyber Security Incidents does not appear to be fully coordinated with version 5 of the CIP standards. For instance, EOP-004-2 R1, Part 1.2 requires a process for reporting events to external entities and CIP-008-5 Part 1.5</p>

Organization	Yes or No	Question 4 Comment
		<p>requires identifying external groups to which to communicate Reportable Cyber Security Incidents. Thus, it appears the Cyber Security Incident response plan in CIP-008-5 R1 and the event reporting Operating Plan in EOP-004-2 R1 will compel duplication of external reporting at least in the document of the Operating Plain and Reportable Cyber Security Incident response plan. This needs to be resolved.</p> <p><b>While the SDT had worked this through with the other standard team to resolve this concern; it is now irrelevant, as reporting of Cyber Security Incidences are no longer part of EOP-004-2.</b></p> <p>(6) In the effective date section of the implementation plan, the statement that the prior version of the standard remains in effect until the new version is accepted by all applicable regulatory authorities is not correct. In areas where regulatory approval is required, it will only remain in effect in the areas where the regulator has not approved it.</p> <p><b>The SDT finds that the two statements are making the same point; that the new standard does not become enforceable until all regulatory authorities have approved it.</b></p> <p>(7) On page 6 in the background section, the statement attributing RCIS reporting to the TOP standards is not accurate. There is no requirement in the TOP standards to report events across RCIS. In fact, the only mention of RCIS in the standards occurs in EOP-002-3 and COM-001-1.1.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p> <p>(8) On page 6 in the background section, the first sentence of the third paragraph is not completely aligned with the purpose statement of the standard. The statement in the background section indicates that the reliability objective “is to prevent outages which could lead to Cascading by effectively reporting events”. However, the purpose states that the goal is to improve reliability. We think it would make more sense for the reliability objective to match the purpose statement more closely.</p> <p><b>The SDT has revised the Background section to match the standard’s purpose</b></p>

Organization	Yes or No	Question 4 Comment
		<p><b>statement.</b></p> <p>(9) On page 7 in the first paragraph, “industry facility” should be changed to “Facility”.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Seattle City Light		<p>1) Seattle City Light follows MEAG and questions if these administrative activities better should be sent over to NAESB? R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB’s domain? R2, R3 &amp; R4: These are not appropriate for a Standard. If you don’t annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn’t need to pile on. Mike Moon and Jim Merlo have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.</p> <p><b>The SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need. While it may be appropriate to have NAESB to adopt this obligation at some in the future, the SDT was charged with addressing deficiencies at this time. The SDT has removed all references to filing reports to DOE from the earlier versions. Today’s only reference provides for NERC’s acceptance of the use of their form when it is appropriate.</b></p> <p>2) Seattle City Light finds that even though efforts were made to differentiate between sabotage vs. criminal damage, the difference still appears to be confusing. Sabotage clearly requires FBI notification, but criminal damage (i.e. copper theft, trespassing, equipment theft) is best handled by local law agencies. A key point on how to determine the difference is to always go with the evidence. If you have a hole in the fence and cut grounding wires, this would only require local law enforcement</p>



Organization	Yes or No	Question 4 Comment
		<p>notification. If there is a deliberate attack on a utility’s BES infrastructure for intent of sabotage and or terrorism--this is a FBI notification event. One area where a potential for confusion arises is with the term “intentional human action” in defining damage. Shooting insulators on a rural transmission tower is not generally sabotage, but removing bolts from the tower may well be. Seattle understands the difficulty in differentiating these two cases, for example, and supports the proposed Standard, but would encourage additional clarification in this one area.</p> <p><b>The SDT appreciates the concern you raise. The SDT decided early that trying to set a definition for sabotage across the continent would be impossible as there are many differing viewpoints; particularly within the law enforcement agencies. There was consensus that even if we were able to set a definition, it may be consistent or recognized by other agencies. Therefore, the SDT decided to set event types that warranted reporting. Entities best know who they have to report to and under what considerations those reports need to be submitted. This is basis for this standard. The SDT wanted to provide entities with the result that was necessary but not prescribe how to do it. This concept has been embraced throughout this project. We believe that entities can create a single or multiple contact lists that have the right people being notified when an event type occurs. The SDT has revised the language on “intentional human action” in Attachment 1 in an attempt to provide you the clarification you requested.</b></p>
<p><b>Response: Thank you for your comment.</b></p>		
Essential Power, LLC		<p>1. As this Standard does not deal with real-time reporting or analysis, and is simply considered an after the fact reporting process, I question the need for the Standard at all. This is a process that could be handled through a change to the Rules of Procedure rather than through a Standard. Developing this process as a Reliability Standard is, in my opinion, contrary to the shift toward Reliability-Based Standards Development.2. I do not believe that establishing a reporting requirement improves the reliability of the BES, as stated in the purpose statement. The reporting requirement, however, would improve situational awareness. I recommend the</p>

Organization	Yes or No	Question 4 Comment
		purpose statement be changed to reflect this, and included with the process in the NERC Rules of Procedure.
<p><b>Response: The SDT thanks you for your comment. The SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need. The vast majority of commenters support the Purpose statement as written.</b></p>		
Georgia System Operations Corporation		<p>a) Reporting most of these items ...  o Does not "provide for reliable operation of the BES"  o Does not include "requirements for the operation of existing BES facilities"  o Is not necessary to "provide for reliable operation of the BES"... and is therefore not in accordance with the statutory and regulatory definitions of a Reliability Standard. They should not be in a Reliability Standard. Most of this is an administrative activity to provide information for NERC to perform some mandated analysis.</p> <p><b>The SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need.</b></p> <p>b) A reportable Cyber Security Incident: Delete this item from the table. It is covered in another standard and does not need to be duplicated in another standard.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p>c) Damage or destruction of a Facility: Entities MAY only need to slightly modify their existing CIP-001 Sabotage Reporting procedures from a compliance perspective of HAVING an Operating Plan but not from a perspective of complying with the Plan. A change from an entity reporting "sabotage" on "its" facilities (especially when the common understanding of CIP-001 is to report sabotage on facilities as "one might consider facilities in everyday discussions") to reporting "damage on its Facilities" (as defined in the Glossary) is a significant change. An operator does not know off the top of his head the definition of Facility or Element. He will not know for any particular electrical device whether or not reporting is required. Although the term is</p>

Organization	Yes or No	Question 4 Comment
		<p>useful for legal and regulatory needs, it is problematic for practical operational needs. This creates the need for a big change in guidance, training, and tools for an operator to know which pieces of equipment this applies to. There is the need to translate from NERC-ese to Operator-ese. Much more time is needed to implement. The third threshold ("Results from actual or suspected intentional human action") perpetuates the problem of knowing the human's intention. Also, what if the action was intended but the result was not intended? The third threshold is ambiguous and subject to interpretation. The original intent of this project was to get away from the problem of the term sabotage due to its ambiguity and subjectivity. This latest change reverses all of the work so far toward that original goal. Instead of the drafted language, change this item to reporting "Damage or destruction of a Facility and any involved human action" and use only the first two threshold criteria.</p> <p><b>The SDT has stated in our "Consideration of Issues and Directives – March 15, 2012" that was posted with the last posting stated:</b></p> <p><b>The SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of "event." The SDT considered the FERC directive to "further define sabotage" and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term "sabotage" is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</b></p> <p><b>The SDT has discussed this with FERC Staff and we agree that sabotage could be a</b></p>

Organization	Yes or No	Question 4 Comment
		<p>state of mind and therefore the real issue was there an event or not.</p> <p>The SDT also uses the NERC defined term of “Facility: A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”</p> <p>d) Any physical threat that could impact the operability of a Facility: See comment above about the term "Facility" and the need for a much longer implementation time.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to</p>

Organization	Yes or No	Question 4 Comment
		<p><b>operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>e) Transmission loss: This item is very unclear. What is meant by "loss?" Above, it says to report damage or destruction of a Facility. This says to report the loss of 3 Facilities. Is the intent here to report when there are 3 or more Facilities that are unintentionally and concurrently out of service for longer than a certain threshold of time? The intent should not be to include equipment failure? Three is very arbitrary. An entity with a very large footprint with a very large number of electrical devices is highly likely to have 3 out of service at one time. An entity with very few electrical devices is less likely to have 3. Delete the word Transmission. It is somewhat redundant. A Facility is BES Element. I believe all BES Elements are Transmission Facilities. A Facility operates as a single "electrical device." What if more than 3 downstream electrical devices are all concurrently out of service due to the failure of one upstream device? Would that meet the criteria? A situation meeting the criteria will be difficult to detect. Need better operator tools, specific procedures for this, training, and more implementation time.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state"</b></p> <p><b>"Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing)."</b></p> <p>f) The implementation plan says current version stays in effect until accepted by ALL regulatory authorities but it also says that the new version takes effect 12 months after the BOT or the APPLICABLE authorities accept it. It is possible that ONE regulatory authority will not accept it for 13 months and both versions will be in</p>

Organization	Yes or No	Question 4 Comment
		<p>effect. It is also possible for ALL regulatory authorities to accept it at the same time, the current version to no longer be in effect, but the new version will not be in effect for 12 months.</p> <p><b>The SDT intends for this standard to not become enforceable until all regulatory authorities have approved it. The SDT will work with NERC and others to ensure a timely enforcement period without overlap.</b></p>
<p><b>Response: Thank you for your comment.</b></p>		
We Energies		<p>Applicability: Change Electric Reliability Organization to NERC or delete Regional Entity. The ERO is NERC and all the Regional Entities.R1.2: The ERO is NERC and all the REs. If I report to any one on the REs (only and not to NERC), I have reported to the ERO. Change ERO to NERC. M1 refers to R1.1 and R1.2 as Parts. It would be clearer to refer to them as requirements or sub-requirements.</p> <p><b>The SDT is limited to listing functional registrations in the Applicability section. The applicable entities are the ERO and Regional Entity, not NERC. The SDT notes that the Applicability section has nothing to do with the reporting obligations. The Applicability section denotes who has obligations within the standard to report. The Applicability section has been revised in accordance with comments received on who needs to report on event types.</b></p> <p>M2: Add a comma after "that the event was reported" and "supplemented by operator logs". It will be easier to read.</p> <p><b>The SDT has revised the requirement and associated language.</b></p> <p>R3: This should be clarified to state that no reporting will be done for the annual test, not just exclude the ERO.</p> <p><b>The SDT has revised the requirement.</b></p> <p>M4: An annual review will not be time stamped.</p> <p><b>The SDT has removed the time-stamp provision.</b></p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>City of Austin dba Austin Energy</p>		<p>Austin Energy makes the following comments:</p> <p>(1) Comment on the Background section titled “A Reporting Process Solution - EOP-004”: This section includes the sentence, “Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state OR PROVINCIAL OR LOCAL level law enforcement agency.” (emphasis added) The corresponding flowchart includes a step, “Notification Protocol to State Agency Law Enforcement.” Austin Energy requests that the SDT update the flowchart to match the language of the associated paragraph and include “state or provincial or local” agencies.</p> <p><b>The SDT wishes to point out that the flowchart is an example only – it was not meant to show every permutation. The entity can choose to use the flowchart or develop one for their own use.</b></p> <p>(2) Comments on VSLs: Austin Energy recommends that the SDT amend the VSLs for R2 to include the "recognition of" events throughout. That is, update the R2 VSLs to state “... X hours after "recognizing" an event ...” in all locations where the phrase occurs.</p> <p><b>The DSR SDT believes the current language is sufficient as Table 1 clearly states that the reporting ‘clock’ starts after recognition of the event.</b></p> <p>(3) Austin Energy has a concern with the inclusion of the word "damage" to the phrase "damage or destruction of a Facility." We agree that any "destruction" of a facility that meets any of the three criteria be a reportable event. However, if the Standard is going to include "damage," some objective definition for "damage" (that sets a floor) ought to be included. Much like the copper theft issue, we do not see the benefit of reporting to NERC vandalism that does not rise to a certain threshold (e.g. someone who takes a pot shot at an insulator) unless the damage has some tangible impact on the reliability of the BES or is an act of an orchestrated sabotage (e.g.</p>

Organization	Yes or No	Question 4 Comment
		<p>removal of a bolt in a transmission structure).</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with</p>



Organization	Yes or No	Question 4 Comment
		<p>the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>(4) Austin Energy voted to approve the revised Standard because it is an improvement over the existing Standard. In light of FERC's comments in Paragraph 81 of the Order approving the Find, Fix, Track and Report initiative, however, Austin Energy would propose that this Standard is the type of Standard that does not truly</p>

Organization	Yes or No	Question 4 Comment
		<p>enhance reliability of the BES and is, instead, an administrative activity. As such, we recommend that NERC consider whether EOP-004-2 ought to be retired.</p> <p><b>The SDT appreciates the suggestion; however, we note that a standard cannot be retired prior to its effective and enforcement dates. Further, the SDT has been charged with addressing deficiencies that are present in current standards which the industry has determined to be needed through approval of the SAR. If the P81 process should ultimately decide to retire this standard, then the process will have made that decision. The SDT cannot presume that the P81 effort will become effective.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Bonneville Power Administration		<p>BPA believes that the VSL should allow for amending the form after a NERC specified time period without penalty and suggests that a window of 48 hours be given to amend the form to make adjustments without needing to file a self report. Should the standard be revised to allow a time period for amending the form without having to file a self report, BPA would change its negative position to affirmative.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT would like to point that a window is not needed as the standard requires a report at a 24-hour time frame which provides information on what is known at the time. The standard does not require any follow up or update report. If the entity wishes to file a follow up report, it can do so on its own. A self report should only be needed if the 24-hour report was not filed.</b></p>		
CenterPoint Energy		<p>CenterPoint Energy proposes that the purpose be enhanced to reflect risk and response. For example, the purpose could read “To sustain and improve reliability of the Bulk Electric System by identifying common risks reported by Responsible Entities as a source of lessons learned.” In the Background section under Law Enforcement Reporting, “the” should be added in front of “Bulk Electric System”. Also under the Background section - “Present expectations of the industry under CIP-001-1a”, CenterPoint Energy is not aware of any current annual requirements for CIP-001 and suggests that this section be revised to reflect that fact. CenterPoint Energy strongly</p>

Organization	Yes or No	Question 4 Comment
		<p>believes that the Violation Severity Levels (VSL) should not be high or severe unless an Adverse Reliability Impact occurred. CenterPoint Energy is requesting that Requirement R2 be deleted and the phrase, "as a result of not implementing the plan/insufficient or untimely report, an Adverse Reliability Impact occurred" be added to the Requirement R1 VSL. Regarding the VSL for Requirement R4, the Violation Risk Factor should be "Lower" and read "the entity did not perform the annual test of the operating plan" as annual is to be defined by the entity or according to the CAN-0010.</p>
<p><b>Response: The SDT thanks you for your comment. The vast majority of commenters support the Purpose statement as written. The missing 'the' has been added to the background section under 'Law Enforcement Reporting.' 'Annual' has been changed to 'These'. VSLs refer to how closely the entity met the requirements of the standard; it is the VRF that measures impact to reliability. The DSR SDT believes use of the high and severe VSLs is appropriate. R4 has been deleted along with its VRF/VSLs.</b></p>		
Cowlitz County PUD		<p>Cowlitz is pleased with changes made to account for the difficulties small entities have in regard to reporting time frames. Although Cowlitz is confident that the current draft is manageable for small entities, we propose that the resulting reports this Standard will generate will contain many insignificant events from the event types "Damage or destruction of a Facility," and "Any physical threat that could impact the operability of a Facility." In particular, examples would be limited target practice on insulators, car-pole accidents, and accidental contact from tree trimming or construction activities.</p> <p><b>The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>"Damage or destruction of a Facility within its Reliability Coordinator Area,</b></p>

Organization	Yes or No	Question 4 Comment
		<p>Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human</p>

Organization	Yes or No	Question 4 Comment
		<p>action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p> <p>Cowlitz suggests that at least a <math>\geq 100</math> MW (200 MW would be better) and/or <math>\geq N-2</math> impact threshold be established for these event types. Also, Cowlitz suggests the statement “results from actual or suspected intentional human action” be changed to “results from actual or suspected intentional human action to damage or destroy a Facility.” A human action may be intentional which can result in damage to a facility, but the intent may have been of good standing, and not directed at the Facility. For example, the intent may have been to legally harvest a tree, or move equipment under a line. Cowlitz believes the above proposed changes would benefit the ERO, both in reduction of nuisance reports and possible violations over minimal to no impact BES events.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and</p>

Organization	Yes or No	Question 4 Comment
		<p>identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</p> <p>Or</p> <p>Suspicious device or activity at a Facility</p> <p>Do not report copper theft unless it degrades normal operations of a Facility.”</p> <p>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Colorado Springs Utilities		<p>CSU is concerned with the word ‘damage’. We support any ‘destruction’ of a facility that meets any of the three criteria be a reportable issue, but ‘damage’, if it’s going to be included should have some objective definition that sets a baseline.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT removed all language under “Entity with Reporting Responsibility,”</b></p>		

Organization	Yes or No	Question 4 Comment
		<p>with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p>“Damage or destruction of its Facility that results from actual or suspected intentional human action.”</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1)</p>

Organization	Yes or No	Question 4 Comment
<p>the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>		
<p>Dominion</p>		<p>Dominion believes that the reporting of “Any physical threat that could impact the operability of a Facility4” may overwhelm the Reliability Coordinator staff with little to no value since the event may have already passed. This specific event uses the phrase “operability of a Facility” yet “operability” is not defined and is therefore ambiguous. We do support the reporting to law enforcement and the ERO but do not generally support reporting events that have passed to the Reliability Coordinator.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p>



Organization	Yes or No	Question 4 Comment
		<p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>Attachment 2; section 4 Event Identification and Description: The type of events listed should match the events as they are exactly written in Attachment 1. As it is currently written, it leaves room for ambiguity.</p> <p><b>The SDT agrees and has adopted your suggestion.</b></p> <p>M3 - Dominion objects to having to provide additional supplemental evidence (i.e. operator logs), and the SDT maybe want to include a requirement for NERC to provide a confirmation that the report has been received.</p> <p><b>The SDT believes that you are referring to M2. We have added “which may be” prior to “supplemented by operator logs,” indicating that this is optional. The SDT has opted not to develop a requirement for the ERO to provide receipt confirmation of a report.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Entergy		<p>Entergy does not agree with the Time Horizon for R2. The rationale for R2 contains phrases related to situational awareness and keeping people/agencies aware of the “current situation.” However, this standard is related to after the fact event reporting, not real-time reporting via RCIS, as discussed on page 6 of the red-lined standard. Therefore the time horizon for R2 should indicate that this is an after the</p>

Organization	Yes or No	Question 4 Comment
		<p>fact requirement expected to be performed either in 1 hour or 24 hours after an event occurs, not in the operations assessment time frame. This change should also be made on page 15 of the redline in the Table of compliance elements for R2. Page 18 of the redline document contains a VSL for R2 which states that it will be considered a violation if the Responsible Entity submitted a report in the appropriate timeframe but failed to provide all of the required information. It has long been the practice to submit an initial report and provide additional information as it becomes available. On page 24 of the redlined document, this is included in the following “...and provide as much information as is available at the time of the notification to the ERO...” But the compliance elements table now imposes that if the entity fails to provide ALL required information at the time the initial report is required, the entity will be non compliant with the standard. This imposes an unreasonable burden to the Reliability Entity. This language should be removed. The compliance element table for R3 and R4 make it a high or severe violation to be late on either the annual test or the annual review of the Operating plan for communication. While Entergy supports that periodically verifying the information in the plan and having a test of the operating plan have value, it does not necessarily impose additional risk to the BES to have a plan that exceeds its testing or review period by two to three months. This is an administrative requirement and the failure to test or review should be a lower or moderate VSL, which would be consistent with the actual risk imposed by a late test or review. On page 24 of the redlined draft, there is a statement that says “In such cases, the affected Responsible Entity shall notify parties per Requirement R1 and provide as much information as if available at the time of the notification...” Since R1 is the requirement to have a plan, and R2 is the requirement to implement the plan for applicable events, it seems that the reference in this section should be to Requirement R2, not Requirement R1.</p>
<p><b>Response: The SDT thanks you for your comment. There is no longer a requirement for this ‘two-step’ reporting. The initial report is the only report an entity must make. The note at the top of Attachment 1 is to give entities the flexibility to make a quick ‘something big just happened, but I don’t know the extent’ phone call, but realistically the reporting time frame is 24 hours which should give ample time to make one written report using OE-417 or Attachment 2. You will also notice that the amount of</b></p>		

Organization	Yes or No	Question 4 Comment
<p>information you must provide is minimal – the idea is that this is a trigger for NERC or the Event Analysis process and they will contact you if further details are required.</p> <p>VSLs refer to how closely the entity met the requirements of the standard; it is the VRF that measures impact to reliability. The DSRSDT believes use of the high and severe VSLs is appropriate. Also, R4 has been deleted along with its VRF/VSLs.</p>		
ERCOT		<p>ERCOT has joined the IRC comments on this project and offers these additional comments. ERCOT supports the alternative approach submitted by the IRC. ERCOT requests that time horizons be added for each of the requirements as have been with other recent Reliability Standards projects. With regards to Attachment 1, ERCOT requests the following changes:</p> <ul style="list-style-type: none"> <li>o Modify “Generation loss” from “≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection” to “≥ 1,100 MW for entities in the ERCOT Interconnection” and “≥ 1,000 MW for entities in the Quebec Interconnection”. This is consistent with the DCS threshold and eliminates possible operator confusion since DCSs event are reported in the ERCOT interconnection at 80% of single largest contingency which equates to 1100 MW.</li> </ul> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b>≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p><b>The NERC SPM does allow TRE to apply for a variance if they have special concerns that GOPs should submit a report to the ERO.</b></p>

Organization	Yes or No	Question 4 Comment
		<p>o Modify “Transmission loss” from “Unintentional loss of three or more Transmission Facilities (excluding successful automatic reclosing)” to “Inconsequential loss of three or more Transmission Facilities not part of a single rated transmission path (excluding successful automatic reclosing).” If a single line is comprised of 3 or more sections, this should not be part of what is reported here as it is intended to be when you have a single event trip of 3 or more transmission facilities that is not part of its intended design.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).”</b></p> <p><b>The NERC SPM does allow TRE to apply for a variance if they have special concerns that GOPs should submit a report to the ERO.</b></p> <p>o ERCOT requests review of footnote 1. The footnote does not seem appropriate in including an example of a control center as the definition of a BES facility does not include control centers.</p> <p><b>The SDT removed all foot notes within Attachment based on comments received.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
FirstEnergy Corp		<p>FE supports the standard and has the following additional comments and suggestions:1. Guideline/Technical Basis Section - FE requests the SDT add specific guidance for each requirement. Much of the information in this section is either included, or should be included in the Background section of the standard. One example of guidance that would help is for Requirement R3 on how an entity could</p>

Organization	Yes or No	Question 4 Comment
		<p>perform the annual test. The comment form for this posting has the following paragraph on pg. 2 which could be used as guidance for R3: “the annual test will include verification that communication information contained in the Operating Plan is correct. As an example, the annual update of the Operating Plan could include calling “others as defined in the Responsibility Entity’s Operating Plan” (see Part 1.2) to verify that their contact information is up to date. If any discrepancies are noted, the Operating Plan would be updated. Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator.”<sup>2</sup>. With regard to the statement in the comment form (pg 2 paragraph 7)“Note that there is no requirement to test the reporting of events to the Electric Reliability Organization and the Responsible Entity’s Reliability Coordinator.”, requirement R3 only includes the ERO as an entity and should also include the Reliability Coordinator.</p> <p>3. The measure M3 says that an entity can use an actual event as a test to meet R3. Does this mean just 1 actual event will meet R3, or is the intent that all possible events per 1.2 are tested? Would like some clarity on this measure.</p>
<p><b>Response: The SDT thanks you for your comment. The requirements have been revised and these revisions along with the ‘Rationale’ boxes should provide the clarity you seek.</b></p>		
<p>Indiana Municipal Power Agency</p>		<p>For 1.2 under R1, is the SDT leaving it up to the registered entities do decide which organizations will be contacted for each event listed in attachment 1 or do all of those organization need to be contacted for each event listed in attachment 1? The requirement needs to clearly communicate this clarification and be independent of the rationale language. Auditors will go by the requirement and not the rationale for the requirement. For 1.1 under R1, does each event need its own process of recognition or can one process be used to cover all the applicable events? The requirement needs to clearly communicate this clarification and be independent of the rationale language. Auditors will go by the requirement and not the rationale for the requirement. For 1.2 under R1, company personnel is used as an example but in the rationale for R1, the third line uses operating personnel. IMPA recommends</p>

Organization	Yes or No	Question 4 Comment
		changing the example in 1.2 to operating personnel which is used in the current version of CIP-001.
<p><b>Response: The SDT thanks you for your comment. The SDT does not believe that it has the ability (or desire) to programmatically prescribe whether entities have a single or multiple contact lists. Entities themselves know best who and under what conditions do reports need to be provided. Further, the industry in past comment periods, clearly indicated that they did not wish to have the SDT provide the “how.”</b></p>		
GTC		For R2, please clarify how an entity can demonstrate that no reportable events were experienced. GTC recommends an allowance for a letter of attestation within M2.
<p><b>Response: Thank you for your comment. Registered Entities must determine how to best demonstrate they have met the performance obligation of a requirement. The use of an attestation statement is already permitted and recognized with the NERC Compliance Program if that is the best means of demonstrating your performance under the requirement. Auditors will then assess whether or not an attestation meets the requirement in one's audit. Attestations cannot be specifically permitted for use.</b></p>		
Orange and Rockland Utilities, Inc.		Form EOP-004, Attachment 2: Event Reporting Form: Delete the Task words “or partial.” Delete the Task words “physical threat that could impact the operability of a Facility.” Make any changes to the VSL’s necessary to align them with the reviewed wording provided above.
Consolidated Edison Co. of NY, Inc.		Form EOP-004, Attachment 2: Event Reporting Form: Delete the Task words “or partial.” Delete the Task words “physical threat that could impact the operability of a Facility.” Make any changes to the VSL’s necessary to align them with the reviewed wording provided above.
<p><b>Response: The SDT thanks you for your comment. The SDT has updated Attachment 2 to reflect the events listed in Attachment 1.</b></p>		
NextEra Energy Inc		Given that Responsible Entities are already required by other Reliability Standards to communicate threats to reliability to their Reliability Coordinator (RC), NextEra does not believe that EOP-004-2 is a Reliability Standard that promotes the reliability of the bulk power system, as envisioned by Section 215 of the Federal Power Act.

Organization	Yes or No	Question 4 Comment
		<p>Because an RC reporting requirement is already covered in other Standards, EOP-004-2 essentially is a reporting out requirement to the Regional Reliability Organization (RRO). NextEra does not agree that the reporting of events to the RROs should be subject to fines under the Reliability Standard regulatory framework. The reporting to RROs, as required by EOP-004-2, while informative and helpful for lessons learned, etc., is not necessary to address an immediate threat to reliability. In addition, NextEra does not believe it would be constructive to fine Responsible Entities for failure to report to a RRO within a mandated deadline during times when these entities are attempting to address potential sabotage on their system. NextEra would, therefore, prefer that the EOP-004-2 Standards Drafting Team be disbanded, and instead that EOP-004-2's reporting requirements be folded in to the event analysis reporting requirements. Therefore, NextEra requests that the new Section 812 be revised to include EOP-004-2 as a data request for lessons learn or for informational purposes only, and, also, for EOP-004-2 project to be disbanded.</p>
<p><b>Response: The SDT thanks you for your comment. While the SDT appreciates your viewpoint, the SDT has been charged with addressing deficiencies identified in current standards. The SDT believes that the standard will provide NERC with the situational awareness it needs as well as providing the industry valuable information through lessons learned.</b></p>		
Illinois Municipal Electric Agency		Illinois Municipal Electric Agency supports comments submitted by Florida Municipal Power Agency.
<p><b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b></p>		
Florida Municipal Power Agency		<p>In R1, bullet, it is a bit ambiguous whether the list of organizations to be communicated with is an exhaustive list (i.e.) or a list of examples (e.g.). The list is preceded by an "i.e." which indicates the former, but includes an "or" which indicates the latter. We are interpreting this as meaning the list is exhaustive as separated by semi-colons, but that the last phrase separated by commas is a list of examples. Is this the correct interpretation?</p> <p><b>The SDT has made the required change concerning replacing "i.e." with "e.g."</b></p>

Organization	Yes or No	Question 4 Comment
		<p>The Rules of Procedure language for data retention (first paragraph of the Evidence Retention section) should not be included in the standard, but instead referred to within the standard (e.g., “Refer to Rules of Procedure, Appendix 4C: Compliance Monitoring and Enforcement Program, Section 3.1.4.2 for more retention requirements”) so that changes to the RoP do not necessitate changes to the standard.</p> <p><b>The language that you mention is part of the standard boilerplate and is included in all standards. The SDT has chosen to keep the language as is at this time.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Ingleside Cogeneration LP		<p>Ingleside Cogeneration LP strongly believes that LSEs that do not own BES assets should be excluded from the Applicability section of this standard.</p>
<p><b>Response: The SDT thanks you for your comment. The LSE obligation in this standard was tied to applicability in CIP-008 for cyber incident reporting. Reporting under CIP-008 is no longer part of EOP-004-2 so this applicability has been removed.</b></p>		
Los Angeles Department of Water and Power		<p>LADWP does not have any other comments at this time</p>
<p><b>Response: The SDT thanks you for your participation.</b></p>		
Manitoba Hydro		<p>Manitoba Hydro is voting negative on EOP-004-2 for the reasons identified in our response to Question 1. In addition, Manitoba Hydro has the following comments:(Background section) - The section has inconsistent references to EOP-004 (eg. EOP-004 and EOP-004-2 are used). Wording should be made consistent. (Background section) - The section references entities, and responsible entities. Suggest wording is made consistent and changed to Responsible Entities. (General comment) - References in the standard to ‘Part 1.2’ should be changed to R1.2 as it is unclear if Part 1.2 refers to, for example, R1.2 or part 1.2 ‘Evidence Retention’.</p>



Organization	Yes or No	Question 4 Comment
		(M4) -Please clarify what is meant by 'date change page'.
<p><b>Response: The SDT thanks you for your comment. The SDT appreciates the points you raise and we continually review the document to make sure the language is consistent and unambiguous.</b></p>		
Southern Company Services		<p>Move the Background Section (pages 4-9) to the Guideline and Technical Basis section. They are not needed in the main body of the standard.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p> <p>Each “Entity with Reporting Responsibility” in the one-hour reporting table (p. 17) should be explicitly listed in the table, not pointed to another variable location. The criterion for “Threshold for Reporting” in the one-hour reporting table (p. 17) should be explicitly listed in the table, not pointed to another variable location.</p> <p>Please specify the voltage base against which the +/- 10% voltage deviation on a Facility is to be measured in the twenty-four hour reporting table (p. 19).</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b></p> <p><b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Oncor Electric Delivery		Oncor takes the position that the proposed objectives as prescribed in Project 2009-01 - Disturbance and Sabotage Reporting, is a “good” step forward. Currently, NERC

Organization	Yes or No	Question 4 Comment
		reporting obligations related to disturbances occurs over multiple standards including CIP-001, EOP-004-1, TOP-007-0, CIP-008-3 and Event Analysis (EA). Oncor is especially pleased that the Event Analysis Working Group (EAWG) is actively working to find ways of streamlining the disturbance reporting process especially to agencies outside of NERC such as FERC, and state agencies. Oncor is in agreement that an addition to the NERC Rules of Procedure in section 800 to develop a Reporting Clearinghouse for disturbance events by the establishment of a system to collect report and then forward completed forms to various requesting agencies, is also a very positive step."
<p><b>Response: The SDT thanks you for your comment. The SDT would like to point out that the EAP is a voluntary program where the entity analyzes an issue or system condition. EOP-004-2 is a Reporting Standard where an entity informs the ERO (and whoever else per Requirement R1) of a current event. This will give other the situational awareness that their system may be degraded. Please refer to the Southwest Outage Report for more situational awareness issues that failed.</b></p>		
Occidental Power Services, Inc.		<p>OPSI continues to believe that LSEs that do not own BES assets should be excluded from the Applicability section of this standard.</p> <p>It is disingenuous of both the SDT and FERC to promote an argument to support this inclusion such as that stated in Section 459 of Order 693 (and referred to by the SDT in their Consideration of Comments in the last posting). The fact is that no reportable disturbance can be caused by an “attack” on an LSE that does not own BES assets. The SDT has yet to point out such an event.</p>
<p><b>Response: The SDT thanks you for your comment. The LSE obligation in this standard was tied to applicability in CIP-008 for cyber incident reporting. Reporting under CIP-008 is no longer part of EOP-004-2 so this applicability has been removed. The SDT notes that LSEs will still be subject to reporting under CIP-008 until such time they are removed from that standard.</b></p>		
New York Power Authority		Please see comments submitted by NPCC Regional Standards Committee (RSC).
<p><b>Response: The SDT thanks you for your comment. Please review the response to that commenter.</b></p>		
MRO NSRF		R1 states: “Each Responsible Entity shall have an event reporting Operating Plan that

Organization	Yes or No	Question 4 Comment
		<p>includes:”The definition of Operating Plan is:”A document that identifies a group of activities that may be used to achieve some goal. An Operating Plan may contain Operating Procedures and Operating Processes. A company-specific system restoration plan that includes an Operating Procedure for black-starting units, Operating Processes for communicating restoration progress with other entities, etc., is an example of an Operating Plan.” This appears to us to be too prescriptive and could be interpreted to require a series of documents to for reporting issues to NERC. We suggest the following wording: R1. Each Responsible Entity shall have document methodology(ies) or process(es) for: 1.1. Recognizing each of the applicable events listed in EOP-004 Attachment 1.1.2. Reporting each of the applicable events listed in EOP-004 Attachment 1 in accordance with the time framess specified in EOP-004 Attachment 1 to the Electric Reliability Organization. LES Comment: [R1] We are concerned by the significant amount of detail an entity would be required to contain within the Operating Plan as part of Requirement R1. Rather than specifying an entity must have a documented process for recognizing each of the events listed in EOP-004-2 Attachment 1, at a minimum, consider removing the term “process” in R1.1 and replacing with “guideline” to ensure operating personnel are not forced to adhere to a specific sequence of steps and still have the flexibility to exercise their own judgment. Section 5 of the standard (Background) should be moved to the Guideline and Technical Basis document. A background that long does not belong in the standard piece as it detracts from the intent of the standard itself.</p>
<p><b>Response: The SDT thanks you for your comment. The background and Guidelines and Technical Basis sections have been combined.</b></p>		
ReliabilityFirst		<p>ReliabilityFirst votes in the Affirmative for this standard because the standard further enhances reliability by clearing up confusion and ambiguity of reporting events which were previously reported under the EOP-004-1 and CIP-001-1 standards. Even though ReliabilityFirst votes in the Affirmative, we offer the following comments for consideration: 1. Requirement R1, Part 1.2a. ReliabilityFirst recommends further prescribing whom the Responsible Entity needs to communicate with. The phrase “...</p>

Organization	Yes or No	Question 4 Comment
		<p>and other organizations needed for the event type..." in Part 1.2 essentially leaves it up to the Responsible Entity to determine (include in their process) whom they should communicate each applicable event to. ReliabilityFirst recommends added a fourth column under Attachment 1, which lists whom the Responsible Entity is required to communicate with, for each applicable event. 2. VSL for Requirement R2a. Requirement R2 requires the Responsible Entity to "implement its event reporting Operating Plan" and does not require the entity to submit a report. For consistency with the requirement, ReliabilityFirst recommends modifying the VSLs to begin with the following type of language: "The Responsible Entity implemented its event reporting Operating Plan more than 24 hours but..." This recommendation is based on the FERC Guideline 3, VSL assignment should be consistent with the corresponding requirement and should not expand on, nor detract from, what is required in the requirement.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT believes that implementing your Operating Plan means that you report an event. Therefore the VSLs are entirely consistent with the requirement.</b></p>		
DECo		<p>Requirement R3 for annual test specifically states that ERO is not included during test. Implies that local law enforcement or state law enforcement will be included in test. Hard to coordinate with many Local organizations in our area.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the language in Requirement R3 and believes that the changes will address your suggestion.</b></p>		
Alliant Energy		<p>Section 5 of the standard (Background) should be moved to the Guideline and Technical Basis document. A background that long does not belong in the standard piece as it detracts from the intent of the standard itself.</p>
<p><b>Response: The SDT thanks you for your comment. The background and Guidelines and Technical Basis sections have been combined.</b></p>		

Organization	Yes or No	Question 4 Comment
MidAmerican Energy		See the NSRF comments.
<p><b>Response: The SDT thanks you for your participation. Please review the response to that commenter.</b></p>		
MEAG Power		<p>Should these administrative activities be sent over to NAESB? R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB’s domain? R2, R3 &amp; R4: These are not appropriate for a Standard. If you don’t annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn’t need to pile on. Mike Moon and Jim Merlo have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.</p>
Public Utility District No. 1 of Snohomish County		<p>SNPD suggest moving these administrative activities to NAESB. R1: There is merit in having a plan as identified in R1, but is this a need to support reliability or is it a business practice? Should it be in NAESB’s domain? R2, R3 &amp; R4: These are not appropriate for a Standard. If you don’t annually review the plan, will reliability be reduced and the BES be subject to instability, separation and cascading? If DOE needs a form filled out, fill it out and send it to DOE. NERC doesn’t need to pile on. Gerry Cauley and Mike Moon have been stressing results and risk based, actual performance based, event analysis, lessons learned and situational awareness. EOP-004 is primarily a business preparedness topic and identifies administrative procedures that belong in the NAESB domain.</p>
<p><b>Response: The SDT thanks you for your comment. SDT believes this standard is needed to provide Situational Awareness and can help in providing lessons learned to the industry. The SDT has revised the requirements to address this need. While it may be appropriate to have NAESB to adopt this obligation at some in the future, the SDT was charged with addressing deficiencies at this time. The SDT has removed all references to filing reports to DOE from the earlier versions. Today’s only reference provides for NERC’s acceptance of the use of their form when it is appropriate.</b></p>		

Organization	Yes or No	Question 4 Comment
Springfield Utility Board		SUB appreciates the opportunity to provide comments. While Staff was concerned with the consolidation of CIP and non-CIP NERC Reliability Standards (as to how they'll be audited), the Project 2009-01 SDT has done an excellent job in providing clarification around identifying and reporting events, particularly related to the varying definitions of "sabotage".
<b>Response: The SDT thanks you for your support.</b>		
Tacoma Power		Tacoma Power disagrees with the requirement to perform annual testing of each communication plan. We do not see any added value in performing annual testing of each communication plan. There are already other Standard requirements to performing routine testing of communications equipment and emergency communications with other agencies. The "proof of compliance" to the Standard should be in the documentation of the reports filed for any qualifying event, within the specified timelines and logs or phone records that it was communicated per each specified communication plan. Tacoma Power has none at this time. Thank you for considering our comments.
<b>Response: The SDT thanks you for your comment. The SDT has revised Requirement R3 and we believe that our changes address your suggestion.</b>		
Exelon Corporation and its affiliates		<p>Thanks to the SDT. Significant progress was made in revising the proposed standard language. We appreciate the effort and have only a few remaining requests:</p> <ul style="list-style-type: none"> <li>o We understand that CIP-008 dictates the 1-hour reporting obligation for Cyber Security Incidents and this iteration of EOP-004 delineates the CIP-008 requirements. Please confirm that per the exemption language in the CIP standards (as consistent with the March 10, 2011 FERC Order (docket # RM06-22-014) nuclear generating units are not subject to this reporting requirement.</li> </ul> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2</b></p>

Organization	Yes or No	Question 4 Comment
		<p><b>will not contain a one-hour reporting requirement.</b></p> <p>o EOP-004 still lists “Generation Loss” as a 24 hour reporting criteria without any time threshold guidance for the generation loss. Exelon previously commented to the SDT (without the comment being addressed) that Generation Loss should provide some type of time threshold. If the 2000 MW is from a combination of units in a single location, what is the time threshold for the combined unit loss? In considering clarification language, the SDT should review the BAL standards on the disturbance recovery period for appropriate timing for closeness of trips.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Total generation loss, within one minute, of <math>\geq 2,000</math> MW for entities in the Eastern or Western Interconnection</b></p> <p><b>OR</b></p> <p><b><math>\geq 1,000</math> MW for entities in the ERCOT or Quebec Interconnection.”</b></p> <p>o The “physical threat that could impact” requirement remains vague and it’s not clear the relevance of such information to NERC or the Regions. If a train derailment occurred near a generation facility (as stated in the footnote), are we to expect that NERC is going to send out a lesson learned with suggested corrective actions to protect generators from that occurring? The value in that event reporting criteria seems low. The requirement should be removed.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated</b></p>

Organization	Yes or No	Question 4 Comment
		<p>based on currently enforced Reliability Standards, FERC directives and industry comments to state:</p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b></p> <p><b>Or</b></p> <p><b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p> <p>o The event concerning voltage deviation of +/- 10% does not specify which type of voltage. In response to this comment in the previous comment period, the SDT indicated that the entity could determine the type of voltage. It would be clearer to specify in the standard and avoid future interpretation at the audit level.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p>



Organization	Yes or No	Question 4 Comment
		<p><b>“Observed voltage deviation of ± 10% of nominal voltage sustained for ≥ 15 continuous minutes.”</b>  <b>This language clearly states that if the threshold is met, the entity needs to submit a report within 24 hours.</b></p> <p>o As requested previously, for nuclear facilities, EOP-004 reporting should be coordinated with existing required notifications to the NRC and FBI as to not duplicate effort or add unnecessary burden on the part of a nuclear GO/GOP during a potential security or cyber event. Please contact the NRC about this project to ensure that required communication and reporting in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. Each nuclear generating site licensee must have an NRC approved Security Plan that outlines applicable notifications to the FBI. Depending on the severity of the security event, the nuclear licensee may initiate the Emergency Plan (E-Plan). Exelon again asks that the proposed reporting process and flow chart be coordinated with the NRC to ensure it does not conflict with existing expected NRC requirements and protocol associated with site specific Emergency and Security Plans. In the alternative, the EOP-004 language should include acceptance of NRC required reporting to meet the EOP-004 requirements.</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b>  <b>“Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement.”</b>  <b>As stated in this event Threshold, the TOP’s NIPR may have additional guidance concerning the complete loss of offsite power affecting a nuclear plant.</b></p>

Organization	Yes or No	Question 4 Comment
		<p>o The proposed standard notes that the text boxes will be moved to the Guideline and Technical Basis Section which we support. However, it's not clear whether all the information in the background section will remain part of the standard. If this section is to remain as proposed concerted revision is needed to ensure that the discussion language matches the requirement language. At present, it does not. For instance, the flow chart on page 9 indicates when to report to law enforcement while the requirements merely state that communications to law enforcement be addressed within the operating plan.</p> <p><b>The background sections will remain in the standard. The flowchart on Page 9 is an example only and may differ from your Operating Plan.</b></p> <p>o Exelon voted negative vote on this ballot due to the need for further clarification and reconciliation between NERC EOP-004 and the NRC.</p> <p><b>The SDT team does not believe that reporting under EOP-004 can in anyway 'conflicts' with any other reporting obligations that nuclear or any other type of GO/GOP may have. By allowing applicable entities to use the OE-417 form, the drafting team believes it has given industry reasonable accommodation to reduce duplicative reporting. The same is true for other agencies as well. If an entity submits to NERC the same that was submitted to the other regulatory agency, then this submission will be acceptable. Based on the historical frequency with which GO/GOPs report under the current EOP-004-1 the drafting team does not believe this places and inordinate burden on the applicable entities.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>Alberta Electric System Operator</p>		<p>The Alberta Electric System Operator will need to modify parts of this standard to fit the provincial model and current legislation when it develops the Alberta Reliability Standard.</p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		

Organization	Yes or No	Question 4 Comment
Puget Sound Energy, Inc.		<p>The effective date language in the Implementation Plan is inconsistent with the effective date language in the proposed standard.</p> <p><b>The SDT checked the language and found both to be identical.</b></p> <p>In addition, the statement of effective date in the Implementation Plan is ambiguous - will EOP-004-2 be effective in accordance with the first paragraph or when it is "assigned an effective date" as stated in the second paragraph?</p> <p><b>The second paragraph deals with EOP-004-1, the currently mandatory and enforceable standard.</b></p> <p>All requirements should be assigned a Lower Violation Risk Factor. Medium risk factors require direct impact on the Bulk Electric System and the language there regarding "instability, separation, or cascading failures" is present to distinguish the Medium risk factor from the High risk factor. Since all of the requirements address after-the-fact reporting, there can be no direct impact on the Bulk Electric System. In addition, if having an Operating Plan under Requirement R1 is a Lower risk factor, then it does not make sense that reviewing that Operating Plan annually under Requirement R4 has a higher risk factor.</p> <p><b>The SDT disagrees. Please review the VRF documentation that was posted with the standard for the analysis of the requirements.</b></p> <p>The shift away from "the distracting element of motivation", i.e., removing "Sabotage" from the equation, runs the risk of focusing solely on what happened, how to fix it, and waiting for the next event to occur. That speaks to a reactive approach rather than a proactive one. There is a concern with the removal of the FBI from the reporting mix. Basically, the new standard will involve reporting a suspicious event or attack to local law enforcement and leaving it up to them to decide on reporting to the FBI. Depending on their evaluation, an event which is significant for a responsible entity might not rise to the priority level of the local law enforcement agency for them to report it to the FBI. While this might reduce the reporting requirements a bit, it might do so to the responsible entity's detriment.</p>

Organization	Yes or No	Question 4 Comment
		<p><b>The Operating Plan developed by each responsible entity may indeed have certain event types reported directly to the FBI. It is up the entity to determine the appropriate notifications. Entities in Canada would not report anything to the FBI.</b></p> <p>In Attachment 2 - item 4, would it be possible for the boxes be either alpha-sorted or sorted by priority?</p> <p><b>The SDT has made changes to Attachment 2 to list the Events in order of their listing in Attachment 1.</b></p> <p>There is a disconnect between footnote 1 on page 18 (Don't report copper theft) and the Guideline section, which suggests reporting forced intrusion attempt at a substation.</p> <p><b>Forced Intrusion was removed from the Guidelines section. The SDT has deleted footnote 1 based on comments received from the industry, however, retained the concept in the event type "Physical threats to a Facility" as:</b></p> <p><b>"Do not report copper theft unless it degrades normal operation of a Facility."</b></p> <p>Also, in the section discussing the removal of sabotage, the Guideline mentions certain types of events that should be reported to NERC, DHS, FBI, etc., while that specificity with respect to entities has been removed from the reporting requirement.</p> <p><b>The SDT disagrees with your assessment on reporting. Entities know best to whom and what reporting obligations they have on the applicable event types. The SDT has learned that states vary in organization of their law enforcement agencies. As such it is impossible for the SDT to outline those obligations in a consistent and uniform manner. Entities can establish a single or multiple contact lists as needed for the different event types.</b></p>
<p><b>Response: The SDT thanks you for your comments.</b></p>		
Kansas City Power & Light		The flowchart states, "Notification Protocol to State Agency Law Enforcement".

Organization	Yes or No	Question 4 Comment
		<p>Please correct this to, “Notification to State, Provincial, or Local Law Enforcement”, to be consistent with the language in the background section part, “A Reporting Process Solution - EOP-004”.</p> <p>Evidence Retention - it is not clear what the phrase “prior 3 calendar years” represents in the third paragraph of this section regarding data retention for requirements and measures for R2, R3, R4 and M2, M3, M4 respectively. Please clarify what this means. Is that different than the meaning of “since the last audit for 3 calendar years” for R1 and M1?</p>
<p><b>Response: The SDT thanks you for your comment. The flowchart is an example only and was not meant to show every permutation. The evidence retention paragraph has been revised to reflect the ‘since last audit’ language.</b></p>		
United Illuminating Company		<p>The measures M3 and M4 require evidence to be dated and time stamped. The time stamp is excessive and provides no benefit. A dated document is sufficient. The measure M2 requires in addition to a record of the transmittal of the EOP-004 Attachment 2 form or DOE-417 form that an operator log or other operating documentation is provided. It is unclear why this supplemental evidence of operator logs is required. We are assuming that the additional operator logs or documentation is required to demonstrate that the communication was completed to organizations other than NERC and DOE of the event. If true then the measure should be clear on this topic. For communication to NERC and DOE use the EOP-004 Form or OE-417 form and retain the transmittal record. For communication to other organizations pursuant to R1 Part 1.2 evidence may include but not limited to, operator logs, transmittal record, attestations, or voice recordings.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has removed the time-stamp provision. The SDT agrees and adopts your suggestion.</b></p>		
New York Independent System Operator		<p>The NYISO is part of and supports comments submitted by NPCC Reliability Standards Committee and the IRC Standards Review Committee. However the NYISO would also like to comment on the following items: o NERC has been proposing the future</p>

Organization	Yes or No	Question 4 Comment
		<p>development of performance based standards, which is directly related to reliability performance. Requirement 2 of this standard is simply a reporting requirement. We believe that this does not fall into a category of a performance based standard. NERC has the ability to ask for reports on events through ROP provisions and now the new Event Analysis Process. It does not have to make it part of the compliance program. Some have indicated that need for timely reporting of cyber or sabotage events. The counter argument is that the requirement is reporting when confirmed which would delay any useful information to fend off a simultaneous threat. Also NERC has not provided any records of how previous timely (1 hour) reporting has mitigated reliability risks. o The NERC Event Analysis Process was recently approved by the NERC OC and is in place. This was the model program for reporting outside the compliance program that the industry was asking for. This should replace the need for EOP-004.o NERC has presented Risk Based Compliance Monitoring (RBCM) to the CCC, MRC, BOT and at Workshops. This involves audit teams monitoring an entities controls to ensure they have things in place to maintain compliance with reliability rules. The proposed EOP-004 has created requirements that are controls to requirement R2, which is to file a report on predefined incidents. The RBCM is being presented as the auditor will make determinations on the detail of the sampling for compliance based on the assessment of controls an entity has in place to maintain compliance. It is also noted that compliance will not be assessed against these controls. As the APS example for COM-002 is presented in the Workshop slides, the issue is that EOP-004 R1, R3 and R4 are controls for reporting; 1) have a plan, 2) test the plan, and 3) review the plan. While R2 is the only actionable requirement. The NYISO believes that all reporting requirements have been met by OE-417 and EAP reporting requirements and that EOP-004 has served its time. At a minimum, the NYISO would suggest that EOP-004 be simplified to just R2 (reporting requirement) and the other requirements be placed at the end of the RSAW to demonstrate a culture of compliance as presented by NERC.</p>
<p><b>Response: The SDT thanks you for your comment. Please review the responses to those commenters. The SDT appreciates your suggestion, however, most of your comment is beyond the scope of the SDT’s charge. The SDT would like to note your statement</b></p>		

Organization	Yes or No	Question 4 Comment
<p>on reporting requirements having been met by the OE-417 and EAP requirements. The SDT fails to see how NERC gains situational awareness and the opportunity to pass along lessons learned when the aforementioned reports are not forwarded to the appropriate ERO group. The SDT would also note that the ERO does not have access to the OE-417 filings unless they are provided and the EAP does not include reporting for some of the event types listed in Attachment 1. The SDT will forward your comment to appropriate officials for their consideration.</p>		
<p>Hydro One</p>		<p>The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring. - The performance based action to “implement its event reporting Operating Plan” on defined events, as required in R2, could be considered a valid requirement. However, the concern is that this requirement could be superseded by the NERC Events Analysis Process and existing OE-417 Reporting.- The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. However, controls should not be part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2.NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well-established process that has regulatory obligations. NERC enforcement of reporting is redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p> <p>The SDT appreciates your suggestion, however, most of your comment is beyond the scope of the SDT’s charge. The SDT would like to note your statement on reporting requirements having been met by the OE-417 and EAP requirements. This statement is not true for Canadian entities. The SDT fails to see how NERC gains situational awareness and the opportunity to pass along lessons learned when the aforementioned reports are not forwarded to the appropriate ERO group. The SDT would also note that the ERO does not have access to the OE-417 filings unless they are provided and the EAP does not include reporting for some of the event types listed in Attachment 1. The SDT will forward your comment to appropriate officials for their consideration.</p> <p>Form EOP-004, Attachment 2: Event Reporting Form: - Delete from the Task column</p>

Organization	Yes or No	Question 4 Comment
		<p>the words “or partial”.- Delete from the Task column the words “physical threat that could impact the operability of a Facility”.</p> <p><b>The SDT has proposed changes to the language within Attachment 2 which we believe corrects the point made.</b></p> <p>VSL’s may have to be revised to reflect revised wording. The standard as proposed is not supportive of Gerry Cauley’s performance based standard initiative</p> <p><b>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p> <p><b>“Physical threat to its Facility excluding weather related threat, which has the potential to degrade the normal operation of the Facility</b>  <b>Or</b>  <b>Suspicious device or activity at a Facility</b></p> <p><b>Do not report copper theft unless it degrades normal operations of a Facility.”</b></p> <p><b>This language gives the required guidance that if there is a physical threat that has the potential to degrade a Facility’s normal operation or a suspicious device or activity is discovered at a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility has a potential of not being able to operate as it is designed. The SDT also states that copper theft is not a reportable event unless it degrades the normal operation of a Facility.</b></p>



Organization	Yes or No	Question 4 Comment
<b>Response: The SDT thanks you for your comment.</b>		
Northeast Power Coordinating Council		<p>The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring. a. The performance based action to “implement its event reporting Operating Plan” on defined events, as required in R2, could be considered a valid requirement. However, the concern is that this requirement could be superseded by the NERC Events Analysis Process and existing OE-417 Reporting. b. The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. However, controls should not be part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting is redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p> <p><b>The SDT appreciates your suggestion however; most of your comment is beyond the scope of the SDT’s charge. The SDT would like to note your statement on reporting requirements having been met by the OE-417 and EAP requirements. This statement is not true for Canadian entities. The SDT fails to see how NERC gains situational awareness and the opportunity to pass along lessons learned when the aforementioned reports are not forwarded to the appropriate ERO group. The SDT would also note that the ERO does not have access to the OE-417 filings unless they are provided and the EAP does not include reporting for some of the event types listed in Attachment 1. The SDT will forward your comment to appropriate officials for their consideration.</b></p> <p>Form EOP-004, Attachment 2: Event Reporting Form: Delete from the Task column the words “or partial”. Delete from the Task column the words “physical threat that</p>

Organization	Yes or No	Question 4 Comment
		<p>could impact the operability of a Facility”.</p> <p><b>The SDT has proposed changes to the language within Attachment 2 which we believe corrects the point made.</b></p> <p>VSL’s may have to be revised to reflect revised wording.</p> <p><b>The SDT agrees and adopts your suggestion.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
<p>American Public Power Association</p>		<p>The SDT needs to provide some relief for the small entities in regards to the VSL in the compliance section. APPA believes there should be no High or Severe VSLs for this standard. This is a reporting/documentation standard and does not affect BES reliability at all. It is APPA’s opinion that this standard should be removed from the mandatory and enforceable NERC Reliability Standards and turned over to a working group within the NERC technical committees. Timely reporting of this outage data is already mandatory under Section 13(b) of the Federal Energy Administration Act of 1974. There are already civil and criminal penalties for violation of that Act. This standard is a duplicative mandatory reporting requirement with multiple monetary penalties for US registered entities. If this standard is approved, NERC must address this duplication in their filing with FERC. This duplicative reporting and the differences in requirements between DOE-OE-417 and NERC EOP-004-2 require an analysis by FERC of the small entity impact as required by the Regulatory Flexibility of Act of 1980</p>
<p><b>Response: The SDT thanks you for your comment. VSLs refer to how closely the entity met the requirements of the standard; it is the VRF that measures impact to reliability. The SDT believes use of the high and severe VSLs is appropriate. The SDT believes that size is not the important criteria in determining an impact on reliability. The reporting thresholds are based on the BES. No entity, including small entities is required to report on equipment that is not categorized as BES, which should give small entities relief from reporting on non-impactive assets.</b></p>		
<p>Pepco Holdings Inc</p>		<p>The SDT's efforts have resulted in a very good draft.</p>

Organization	Yes or No	Question 4 Comment
<b>Response: The SDT thanks you for your support.</b>		
ISO/RTO Standards Review Committee		<p>The SRC offers some other comments regarding the posted draft requirements; however, by so doing, the SRC does not indicate support of the proposed requirements. Following these comments, please see below for an SRC proposed alternative approach: The SRC does not agree with the MEDIUM VRF assigned to Requirement R4. R4 is a requirement to conduct an annual review of the Event Reporting Operating Plan mandated in Requirement R1. R1 however is assigned a VRF of LOWER. We are unable to rationalize why a subsequent review of a plan should have a higher reliability risk impact than the development of the plan itself. Hypothetically, if an entity doesn't develop a plan to begin with, then it will be assigned a LOWER VRF, and the entity will have no plan to review annually and hence it will not be deemed non-compliant with requirement R4. The entity can avoid being assessed violating a requirement with a MEDIUM VRF by not having the plan to begin with, for which the entity will be assessed violating a requirement with a LOWER VRF. We suggest changing the R4 VRF to LOWER.</p> <p><b>The SDT has revised the requirements and R4 has been deleted along with its VRF/VSL.</b></p> <p>The SRC requests that the SDT post the following Alternative Proposal for Industry comments as required by the Standards Process to obtain Industry consensus and as permitted by FERC: An equally effective alternative is to withdraw this standard and to make the contents of the SDT's posted standard a NERC Guideline.</p> <ol style="list-style-type: none"> <li>a. This alternative is more in line with new NERC and FERC proposals</li> <li>b. This alternative retains the reporting format</li> </ol> <p>Comments 1. The FERC Order 693 directives regarding "sabotage" have already been addressed by the SDT (i.e. the concept was found outside the scope of NERC standards)</p> <p>2. Current Industry actions already address the needs cited in the Order:</p>

Organization	Yes or No	Question 4 Comment
		<p>a. Approved Reporting Processes already exists i. The Operating Committee’s Event Analysis Process ii. Alert Reporting</p> <p>b. The Data already exists i. Reliability Coordinators Information System (which creates hundred if not thousands of “reports” per year) ii. The DOE’s OE 417 Report itself provides part of the FERC discussed data</p> <p>3. The proposed standard is not supportive of Gerry Cauley’s performance based standard initiative or of FERC’s offer to reduce procedural standards</p> <p>a. The proposed requirement is a process not an outcome i. The proposal is more focused on reporting and could divert the attention of reliability entities from addressing a situation to collecting data for a report</p> <p>b. The proposed “events” are subjective and if followed will create an unmanageable burden on NERC staff i. Reporting “damage” to facilities can be interpreted as anything from a dent in a generator to the total destruction of a transformer ii. The reporting requirements on all applicable entities will create more questions about differences between the reports of the various entities - rather than leading to conclusions about patterns among events that indicate a global threat iii. Reporting any “physical threat” is too vague and subjective iv. Reporting “damage to a facility that affects an IROL” is subjective and can be seen to require reporting of damage on every facility in an interconnected area.</p> <p>v. Reporting “Partial loss of monitoring” is a data quality issue that can be anything from the loss of a single data point to the loss of an entire SCADA system vi. Testing the filling out of a Report does not make it easier to fill out the report later (moreover the reporting is already done often enough -see 2.b.i)c. The proposed requirements will create a disincentive to improving current Reporting practices (the more an entity designs into its own system the more it will be expected to do and the more likely it will be penalized for failing to comply)i. Annual reviews of the reporting practices fall into the same category, why have a detailed process to review when a simple one will suffice?</p>

Organization	Yes or No	Question 4 Comment
		<p>4. The proposed standard does not provide a feedback loop to either the data suppliers or to potentially impacted functional entities a. If the “wide area” data analysis indicates a threat, there is no requirement to inform the impacted entities b. As a BES reliability issue there is no performance indicators or metrics to show the value of this standard i. The SRC recognizes that specific incidents cannot be identified but if this is to be a reliability standard some information must be provided. A Guideline could be designed to address this concern.</p> <p>5. The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring.</p> <p>a. The performance based action to report on defined events, as required in R2, could be considered a valid requirement. However we have concerns as noted in Bullet 3 above. The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. NERC is moving in the direction to assess entities’ controls, outside of the compliance enforcement arm. The industry is being informed that NERC Audit staff will conduct compliance audits based on the controls that the entity has implemented to ensure compliance. The SRC is interested in supporting this effort and making it successful. However, if this is the direction NERC is moving, we should not be making controls part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2.</p> <p>6. For FERC-jurisdictional entities, NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting would be redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT will bring this request to the attention of the SC for consideration as this request is beyond the scope of work identified in this project.</b></p>		
LG&E and KU Services		The Violation Severity Level for Requirement R2 should be revised to read “...hours

Organization	Yes or No	Question 4 Comment
		after recognizing an event requiring reporting..." This will make the language in the VSL consistent with the language in Attachment 1.
<b>Response: The SDT thanks you for your comment. The VSLs have been reviewed and revised based upon the revisions to the requirements.</b>		
SPP Standards Review Group		The VRF for R1 is Lower which is fine. The issue is that R4, which is the review of the plan contained in R1, has a Medium VRF. We recommend moving the VRF of R4 to Lower. We recommend deleting the phrase ‘...supplemented by operator logs or other operating documentation...’ as found in the first sentence of M2. A much clearer reference is made to operator logs and other operating documentation in the second sentence. The duplication is unnecessary. What will happen with the accompanying information contained in the Background section in the draft standard? Will it be moved to the Guideline and Technical Basis at the end of the standard as the information contained in the text boxes? This is valuable information and should not be lost.
<b>Response: The SDT thanks you for your comment. The SDT has revised the requirements and R4 has been deleted along with its VRF/VSL. The background has been moved to the Guidelines and Technical Basis section.</b>		
Utility Services		There are no other comments at this time.
<b>Response: The SDT thanks you for your participation.</b>		
Dynergy Inc.		Use of the term "Part x.x" throughout the Standard is somewhat confusing. I can't recall other Standards using that type of term. Suggest using the term "Requirement" instead.
<b>Response: The SDT thanks you for your comment. The standard has been rewritten and revised in accordance with your suggestion.</b>		
Central Lincoln		We agree with the comments provided by both PNGC and APPA.

Organization	Yes or No	Question 4 Comment
<p><b>Response: The SDT thanks you for your comment. Please review the responses to those commenters.</b></p>		
PNGC Comment Group		We appreciate the hard work of the SDT.
<p><b>Response: The SDT thanks you for your support.</b></p>		
PPL Corporation NERC Registered Affiliates		<p>We appreciate the inclusion of the Process Flowchart on Page 9 of the draft standard. We submit for your consideration, removing the line from the NO decision box to the 'Report Event to ERO, Reliability Coordinator' box. It seems if the event does not need reporting per the decision box, this line is not needed. The decision box on 'Report to Law Enforcement ?' does not have a Yes or No. Perhaps, this decision box is misplaced, or is it intended to occur always and not have a different path with different actions? I.e. should it be a process box? Thank you for your work on this standard.</p>
PPL Electric Utilities		<p>We appreciate the inclusion of the Process Flowchart on Page 9 of the draft standard. We submit for your consideration, removing the line from the NO decision box to the 'Report Event to ERO, Reliability Coordinator' box. It seems if the event does not need reporting per the decision box, this line is not needed. For clarity in needed actions, please consider using a decision box following flowcharting standards such as, a decision box containing a question with a Yes and a No path. The decision box on 'Report to Law Enforcement ?' does not have a Yes or No. Perhaps, this decision box is misplaced, or is it intended to occur always and not have a different path with different actions? I.e. should it be a process box? Thank you for your work on this standard.</p>
<p><b>Response: The SDT thanks you for your comment. The flowchart was provided as an example and guidance for entities to use if they so choose. Entities can elect to create their own flowchart based upon their needs.</b></p>		
Independent Electricity System Operator		We do not agree with the MEDIUM VRF assigned to Requirement R4. Re stipulates a requirement to conduct an annual review of the event reporting Operating Plan in

Organization	Yes or No	Question 4 Comment
		<p>Requirement R1, which itself is assigned a VRF of LOWER. We are unable to rationalize why a subsequent review of a plan should have a higher reliability risk impact than the development of the plan itself. Hypothetically, if an entity doesn't develop a plan to begin with, then it will be assigned a LOWER VRF, and the entity will have no plan to review annually and hence it will not be deemed non-compliant with requirement R4. The entity can avoid being assessed violating a requirement with a MEDIUM VRF by not having the plan to begin with, for which the entity will be assessed violating a requirement with a LOWER VRF. We suggest changing the R4 VRF to LOWER.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the requirements and R4 has been deleted along with its VRF/VSL.</b></p>		
SMUD & BANC		<p>We feel issues were addressed, but still have concern with 'damage'. We certainly support that any 'destruction' of a facility that meets any of the three criteria be a reportable issue. But 'damage', if it's going to be included should have some objective definition that sets a floor. Much like the copper theft issue, we don't see the benefit of reporting plain vandalism (gun-shot insulators results from actual or suspected intentional human action) to NERC unless the 'damage' has some tangible impact on the reliability of the system or are acts of an orchestrated sabotage (i.e. removal of bolt in a transmission structure).</p>
<p><b>Response: The SDT thanks you for comment. The SDT removed all language under "Entity with Reporting Responsibility," with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the "Threshold for Reporting" column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state:</b></p>		



Organization	Yes or No	Question 4 Comment
		<p>“Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in the need for actions to avoid a BES Emergency.”</p> <p>This language gives the required guidance of who has to report within its Area that results in need for actions to avoid a BES Emergency (as defined by NERC: Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System).</p> <p>This relates to either a completely destroyed Facility where an action is required to avoid a BES Emergency, or a Facility that is damaged to a point that actions are required to avoid a BES Emergency. By reporting either a “damaged or destroyed” Facility, within 24 hours, it will give the ERO (and whoever else the entity wishes to inform per R1) the situational awareness that the electrical system has been reconfigured or may need to be reconfigured, thus supporting reliable operations of each interconnection.</p> <p>The SDT removed all language under “Entity with Reporting Responsibility,” with the exception of entity(s) that are required to report an applicable event. The SDT removed this language so the entities within this column are clearly stated and identified. Under the “Threshold for Reporting” column, a bright line was updated based on currently enforced Reliability Standards, FERC directives and industry comments to state;</p> <p>Damage or destruction of its Facility that results from actual or suspected intentional human action.</p> <p>This language gives the required guidance that if there is actual intentional human action that damages or destroys a Facility, it is required to be reported within 24 hours, this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.</p> <p>This event was written to cover the increase of “Entity with Reporting Responsibility” and removing the RC since they do not own Facility(s).</p> <p>The SDT also included a second part of this event being “suspected intentional human action.” This language was required to give an entity the reporting responsibility to report to the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that they suspect that their Facility was damaged or destroyed by intentional human action. The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.</p>
ISO New England Inc		We requests that the SDT post the following Alternative Proposal for Industry

Organization	Yes or No	Question 4 Comment
		<p>comments as required by the Standards Process to obtain Industry consensus and as permitted by FERC: An equally effective alternative is to withdraw this standard and to make the contents of the SDT’s posted standard a NERC Guideline.a. This alternative is more in line with new NERC and FERC proposalsb. This alternative retains the reporting formatComments1. The FERC Order 693 directives regarding “sabotage” have already been addressed by the SDT (i.e. the concept was found outside the scope of NERC standards)2. Current Industry actions already address the needs cited in the Order:a. Approved Reporting Processes already existsi. The Operating Committee’s Event Analysis Processii. Alert Reporting b. The Data already existsi. Reliability Coordinators Information System (which creates hundred if not thousands of “reports” per year)ii. The DOE’s OE 417 Report itself provides part of the FERC discussed data3. The proposed standard is not supportive of Gerry Cauley’s performance based standard initiative or of FERC’s offer to reduce procedural standardsa. The proposed requirement is a process not an outcomei. The proposal is more focused on reporting and could divert the attention of reliability entities from addressing a situation to collecting data for a reportb. The proposed “events” are subjective and if followed will create an unmanageable burden on NERC staffi. Reporting “damage” to facilities can be interpreted as anything from a dent in a generator to the total destruction of a transformerii. The reporting requirements on all applicable entities will create more questions about differences between the reports of the various entities - rather than leading to conclusions about patterns among events that indicate a global threatiii. Reporting any “physical threat” is too vague and subjective iv. Reporting “damage to a facility that affects an IROL” is subjective and can be seen to require reporting of damage on every facility in an interconnected area.</p> <p>v. Reporting “Partial loss of monitoring” is a data quality issue that can be anything from the loss of a single data point to the loss of an entire SCADA system</p> <p>vi. Testing the filling out of a Report does not make it easier to fill out the report later (moreover the reporting is already done often enough -see 2.b.i)c. The proposed requirements will create a disincentive to improving current Reporting practices (the</p>

Organization	Yes or No	Question 4 Comment
		<p>more an entity designs into its own system the more it will be expected to do and the more likely it will be penalized for failing to comply)i. Annual reviews of the reporting practices fall into the same category, why have a detailed process to review when a simple one will suffice?4. The proposed standard does not provide a feedback loop to either the data suppliers or to potentially impacted functional entitiesa. If the “wide area” data analysis indicates a threat, there is no requirement to inform the impacted entitiesb. As a BES reliability issue there is no performance indicators or metrics to show the value of this standardi. We recognize that specific incidents cannot be identified but if this is to be a reliability standard some information must be provided. A Guideline could be designed to address this concern. 5. The proposed standard is not consistent with NERC’s new Risk Based Compliance Monitoring. a. The performance based action to report on defined events, as required in R2, could be considered a valid requirement. However we have concerns as noted in Bullet 3 above.The requirements laid out in R1, R3 and R4 are specific controls to ensure that the proposed requirement to report (R2) is carried out. NERC is moving in the direction to assess entities’ controls, outside of the compliance enforcement arm. The industry is being informed that NERC Audit staff will conduct compliance audits based on the controls that the entity has implemented to ensure compliance. We are interested in supporting this effort and making it successful. However, if this is the direction NERC is moving, we should not be making controls part of a compliance requirement. The only requirement proposed in this standard that is not a control is R2. 6. For FERC-jurisdictional entities, NERC does not need to duplicate the enforcement of reporting already imposed by the DOE. DOE-417 is a well established process that has regulatory obligations. NERC enforcement of reporting would be redundant. NERC has the ability to request copies of these reports without making them part of the Reliability Rules.</p>
<p><b>Response: The SDT thanks you for your comment. The SDT will bring this request to the attention of the SC for consideration as this request is beyond the scope of work identified in this project.</b></p>		
Brazos Electric Power		We thank the work of the SDT on this project. However, additional improvements

Organization	Yes or No	Question 4 Comment
Cooperative		should be made as described in the comments submitted by ACES Power Marketing.
<b>Response: The SDT thanks you for your comment. Please review the responses to that commenter.</b>		
FirstEnergy		<p>While FE voted affirmative on this draft, upon further review we request clarification be made in the next draft of the standard regarding the applicability of the Nuclear Generator Operator. Per FE's previous comments, nuclear generator operators already have specific regulatory requirements to notify the NRC for certain notifications to other governmental agencies in accordance with 10 CFR 50.72(b)(s)(xi). We had asked that the SDT contact the NRC about this project to ensure that existing communication and reporting that a licensee is required to perform in response to a radiological sabotage event (as defined by the NRC) or any incident that has impacted or has the potential to impact the BES does not create either duplicate reporting, conflicting reporting thresholds or confusion on the part of the nuclear generator operator. In addition, EOP-004 must acknowledge that there may be NRC reporting forms that have the equivalent information contained in their Attachment 2. For what the NRC considers a Reportable Event, Nuclear plants are required to fill out NRC form 361 and/or form 366. We do not agree with the drafting team's response to ours and Exelon's comments that "The NRC does not fall under the jurisdiction of NERC and so therefore it is not within scope of this project." While the statement is correct, we believe that requirements should not conflict with or duplicate other regulatory requirements. We remain concerned that the standard with regard to Nuclear GOP applicability causes duplicative regulatory reporting with existing reporting requirements of the NRC. Therefore, we ask:1. That NERC and the drafting team please investigate these issues further and revise the standard to clarify the scope for nuclear GOPs, and2. For any reporting deemed in the scope for nuclear GOP after NERC's and the SDT's investigation per our request in #1 above, that the SDT consider the ability to utilize information from NRC reports as meeting the EOP-004-2 requirements similar to the allowance of using the DOE form as presently proposed.</p>

Organization	Yes or No	Question 4 Comment
<p><b>Response: The SDT thanks you for your comment. The SDT team does not believe that reporting under EOP-004 can in anyway ‘conflicts’ with any other reporting obligations that nuclear or any other type of GO/GOP may have. By allowing applicable entities to use the OE-417 form, the drafting team believes it has given industry reasonable accommodation to reduce duplicative reporting. The same is true for other agencies as well. If an entity submits to NERC the same that was submitted to the other regulatory agency, then this submission will be acceptable. Based on the historical frequency with which GO/GOPs report under the current EOP-004-1 the drafting team does not believe this places and inordinate burden on the applicable entities.</b></p>		
American Electric Power		<p>While we do not necessarily disagree with modifying this standard, we do have serious concerns with the possibility that Form OE-417 form would not also be modified to match any changes made to this standard. To the degree they would be different, this would create unnecessary confusion and burden on operators.</p> <p><b>While we appreciate the point raised, the SDT does not have any authority with regard to the language contained within the DOE OE-417 form. The Department of Energy is responsible for the design and contents of the 417 form. As a part of the SDT’s work in this proposal, we met with and collaborated with the DOE staff responsible for the 417 form establish a common understanding of reportable events. We hope that if the DOE desires to make further changes, they will pass along information for consideration in a future NERC SAR.</b></p> <p>If CIP-008 is now out of scope within the requirements of this standard, the task “reportable Cyber Security Incident” should be removed from Attachment 2.</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Progress Energy		<p>Within attachment 1 (Reportable Events) an exclusion is allowed for weather related threats. PGN recommends a more generic approach to include natural events such as forest fires, sink holes, etc. This would alleviate some reporting burdens in areas that</p>

Organization	Yes or No	Question 4 Comment
		are prone to these types of events.
<p><b>Response: The SDT thanks you for your comment. The SDT has revised the language in accordance with your suggestion to “weather or natural disaster related threats”.</b></p>		
Xcel Energy		<p>Xcel Energy appreciates the work of the drafting team and believes the current draft is an improvement over the existing standard. However, we would like to see the comments provided here and above addressed prior to submitting an AFFIRMATIVE vote.1) Suggest enhancing the “Example of Reporting Process...” flowchart as follows: EVENT &gt; Refer to Ops Plan for Event Reporting &gt; Refer to Law Enforcement? &gt; Yes/No &gt; ....</p> <p><b>The SDT has provided the flowchart as an example and guidance for entities. Entities can choose to create their own version of the flowchart for use in their Operating Plan.</b></p> <p>2) Attachment 1 - in both the 1 hour and the 24 hour reporting they are qualified with “within x hours of recognition of the event”. Is this the intent, so that if an entity recognizes at some point after an event that the time clock starts?</p> <p><b>The SDT has discussed this issue with Project 2008-06, Cyber Security SDT and we have remanded the one hour event back to CIP-008. The next version of EOP-004-2 will not contain a one hour reporting requirement.</b></p> <p><b>The SDT envisions when the entity is made aware of an applicable event contained in Attachment 1, that they would report the event within 24 hours. Any entity could enhance their Operating Plan to describe as much detail as they wanted to provide to their employees as they see fit.</b></p> <p>3) VSLs - R3 &amp; R4 “Severe” should remove the “OR...”, as this is redundant. Once an entity has exceeded the 3 calendar months, the Severe VSL is triggered.</p> <p><b>The SDT has revised the requirements and accordingly the VSLs.</b></p> <p>4) The Guideline and Technical Basis page 22 should be corrected to read “The</p>

Organization	Yes or No	Question 4 Comment
		<p>changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting.”</p> <p><b>Response: Thank you for the grammatical correction.</b></p> <p>5) Also in the following section of the Guideline and Technical Basis (page 23) the third bullet item should be qualified to exclude copper theft: Examples of such events include:</p> <ul style="list-style-type: none"> <li>o Bolts removed from transmission line structures</li> <li>o Detection of cyber intrusion that meets criteria of CIP-008-3 or its successor standard</li> <li>o Forced intrusion attempt at a substation (excluding copper theft)</li> <li>o Train derailment near a transmission right-of-way</li> <li>o Destruction of Bulk Electric System equipment</li> </ul> <p><b>Response: Thank you for the correction; however, as a result of other changes made to the standard, the SDT is proposing to remove the third bulleted item from this list.</b></p>
<p><b>Response: The SDT thanks you for your comment.</b></p>		
Edison Mission Marketing & Trading, Inc.		No
Idaho Power Co.		No
Arizona Public Service Company		None

END OF REPORT

## Standard Development Timeline

---

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 15 – October 15, 2010).
6. Second Comment Period (Formal) (March 9 – April 8, 2011).
7. Third Comment Period and Initial Ballot (October 28 – December 12, 2011).
8. Fourth Comment Period and Successive Ballot (April 25 – May 24, 2012).

### Proposed Action Plan and Description of Current Draft

This is the fifth posting of the proposed standard in accordance with Results-Based Standards (RBS) criteria. The drafting team requests posting for a 30-day formal comment period concurrent with the formation of the ballot pool and the successive ballot.

### Future Development Plan

<b>Anticipated Actions</b>	<b>Anticipated Date</b>
Drafting team considers comments, makes conforming changes on fourth posting	June - August 2012
Fifth Comment/Ballot period	August – September 2012
Recirculation Ballot period	October 2012
Receive BOT approval	November 2012
File with regulatory authorities	December 2012



### Effective Dates

The first day of the first calendar quarter that is six months beyond the date that this standard is approved by applicable regulatory authorities. In those jurisdictions where regulatory approval is not required, the standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the NERC Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

### Version History

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting.	Revision to entire standard (Project 2009-01)

### **Definitions of Terms Used in Standard**

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## **A. Introduction**

- 1. Title:** Event Reporting
- 2. Number:** EOP-004-2
- 3. Purpose:** To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.

### **4. Applicability**

- 4.1. Functional Entities:** For the purpose of the Requirements and the EOP-004 Attachment 1 contained herein, the following functional entities will be collectively referred to as “Responsible Entity.”
  - 4.1.1.** Reliability Coordinator
  - 4.1.2.** Balancing Authority
  - 4.1.3.** Transmission Owner
  - 4.1.4.** Transmission Operator
  - 4.1.5.** Generator Owner
  - 4.1.6.** Generator Operator
  - 4.1.7.** Distribution Provider

### **5. Background:**

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient Bulk Electric System reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

## B. Requirements and Measures

- R1.** Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity's Reliability Coordinator, law enforcement, or governmental authority). [*Violation Risk Factor: Lower*] [*Time Horizon: Operations Planning*]
- M1.** Each Responsible Entity will have a dated event reporting Operating Plan that includes, but is not limited to the protocol(s) and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1 and in accordance with the entity responsible for reporting.

### Rationale for R1

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; e.g., Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC Events Analysis Program. These other parties use this information to promote reliability, develop a culture of reliability excellence, provide industry collaboration and promote a learning organization.

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective.

The communication protocol(s) could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information. An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.

**R2.** Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting. *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*

**M2.** Each Responsible Entity will have as evidence of reporting an event, copy of the completed EOP-004-2 Attachment 2 form or a DOE-OE-417 form; and evidence of submittal (e.g., operator log or other operating documentation, voice recording, electronic mail message, or confirmation of facsimile) demonstrating the event report was submitted within 24 hours of meeting the threshold for reporting. (R2)

**R3.** Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*

**M3.** Each Responsible Entity will have dated records to show that it validated all contact information contained in the Operating Plan each calendar year. Such evidence may include, but are not limited to, dated voice recordings and operating logs or other communication documentation. (R3)

### **Rationale for R2**

Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004-2 Attachment 1. By implementing the event reporting Operating Plan the Responsible Entity will assure situational awareness to the Electric Reliability Organization so that they may develop trends and prepare for a possible next event and mitigate the current event. This will assure that the BES remains secure and stable by mitigation actions that the Responsible Entity has within its function. By communicating events per the Operating Plan, the Responsible Entity will assure that people/agencies are aware of the current situation and they may prepare to mitigate current and further events.

### **Rationale for R3**

Requirement 3 calls for the Responsible Entity to validate the contact information contained in the Operating Plan each calendar year. This requirement helps ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.

## C. Compliance

### 1. Compliance Monitoring Process

#### 1.1 Compliance Enforcement Authority

The Regional Entity shall serve as the Compliance Enforcement Authority (CEA) unless the applicable entity is owned, operated, or controlled by the Regional Entity. In such cases the ERO or a Regional Entity approved by FERC or other applicable governmental authority shall serve as the CEA.

#### 1.2 Evidence Retention

The Responsible Entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

- Each Responsible Entity shall retain the current Operating Plan plus each version issued since the last audit for Requirements R1, and Measure M1.
- Each Responsible Entity shall retain evidence of compliance since the last audit for Requirements R2, R3 and Measure M2, M3.

If a Responsible Entity is found non-compliant, it shall keep information related to the non-compliance until mitigation is complete and approved or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

#### 1.3 Compliance Monitoring and Enforcement Processes:

Compliance Audit

Self-Certification

Spot Checking

Compliance Investigation

Self-Reporting

Complaint

#### 1.4 Additional Compliance Information

None

**Table of Compliance Elements**

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	Operations Planning	Lower	N/A	N/A	N/A	The Responsible Entity failed to have an event reporting Operating Plan.



R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R2	Operations Assessment	Medium	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 24 hours but less than or equal to 36 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to one entity identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 36 hours but less than or equal to 48 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to two entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours but less than or equal to 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to three entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to four or more entities identified in its event reporting Operating Plan within 24 hours.</p> <p>OR</p> <p>The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R3	Operations Planning	Medium	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by less than one calendar month.</p> <p>OR</p> <p>The Responsible Entity validated 75% or more of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by one calendar month or more but less than two calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 50% and less than 75% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by two calendar months or more but less than three calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 25% and less than 50% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by three calendar months or more.</p> <p>OR</p> <p>The Responsible Entity validated less than 25% of contact information contained in the Operating Plan.</p>

**D. Variances**

None.

**E. Interpretations**

None.

**F. References**

Guideline and Technical Basis (attached)

## EOP-004 - Attachment 1: Reportable Events

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R2 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: [systemawareness@nerc.net](mailto:systemawareness@nerc.net) or Voice: 404-446-9780.

### **Rationale Box for EOP-004 Attachment 1:**

The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:

“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”

The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

**EOP-004-2 — Event Reporting**

**Submit EOP-004 Attachment 2 (or DOE-OE-417) pursuant to Requirements R1 and R2.**

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Damage or destruction of a Facility	RC, BA, TOP	Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency.
Damage or destruction of a Facility	BA, TO, TOP, GO, GOP, DP	Damage or destruction of its Facility that results from actual or suspected intentional human action.
Physical threats to a Facility	BA, TO, TOP, GO, GOP, DP	Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility. OR Suspicious device or activity at a Facility. Do not report theft unless it degrades normal operation of a Facility.
Physical threats to a BES control center	RC, BA, TOP	Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center. OR Suspicious device or activity at a BES control center.
BES Emergency requiring public appeal for load reduction	Initiating entity is responsible for reporting	Public appeal for load reduction event.
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more.
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq$ 100 MW.

## EOP-004-2 — Event Reporting

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
BES Emergency resulting in automatic firm load shedding	DP, TOP	Automatic firm load shedding $\geq 100$ MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS).
Voltage deviation on a Facility	TOP	Observed within its area a voltage deviation of $\pm 10\%$ of nominal voltage sustained for $\geq 15$ continuous minutes.
IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)	RC	Operate outside the IROL for time greater than IROL $T_v$ (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only).
Loss of firm load	BA, TOP, DP	Loss of firm load for $\geq 15$ Minutes: $\geq 300$ MW for entities with previous year's demand $\geq 3,000$ MW OR $\geq 200$ MW for all other entities
System separation (islanding)	RC, BA, TOP	Each separation resulting in an island $\geq 100$ MW
Generation loss	BA, GOP	Total generation loss, within one minute, of $\geq 2,000$ MW for entities in the Eastern or Western Interconnection OR $\geq 1,000$ MW for entities in the ERCOT or Quebec Interconnection
Complete loss of off-site power to a nuclear generating plant (grid supply)	TO, TOP	Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement

## EOP-004-2 — Event Reporting

---

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Transmission loss	TOP	Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).
Unplanned BES control center evacuation	RC, BA, TOP	Unplanned evacuation from BES control center facility for 30 continuous minutes or more.
Complete loss of voice communication capability	RC, BA, TOP	Complete loss of voice communication capability affecting a BES control center for 30 continuous minutes or more.
Complete loss of monitoring capability	RC, BA, TOP	Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (i.e., State Estimator or Contingency Analysis) is rendered inoperable.

EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004 Attachment 2: Event Reporting Form</b>	
<p><b>Use this form to report events. The Electric Reliability Organization will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> voice: 404-446-9780.</b></p>	
<b>Task</b>	<b>Comments</b>
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:
3.	Did the event originate in your system?      Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
4.	<p style="text-align: center;"><b>Event Identification and Description:</b></p> <div style="display: flex;"> <div style="flex: 1;"> <p>(Check applicable box)</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> Damage or destruction of a Facility</li> <li><input type="checkbox"/> Physical Threat to a Facility</li> <li><input type="checkbox"/> Physical Threat to a control center</li> <li><input type="checkbox"/> BES Emergency:                             <ul style="list-style-type: none"> <li><input type="checkbox"/> public appeal for load reduction</li> <li><input type="checkbox"/> system-wide voltage reduction</li> <li><input type="checkbox"/> manual firm load shedding</li> <li><input type="checkbox"/> automatic firm load shedding</li> </ul> </li> <li><input type="checkbox"/> Voltage deviation on a Facility</li> <li><input type="checkbox"/> IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)</li> <li><input type="checkbox"/> Loss of firm load</li> <li><input type="checkbox"/> System separation</li> <li><input type="checkbox"/> Generation loss</li> <li><input type="checkbox"/> Complete loss of off-site power to a nuclear generating plant (grid supply)</li> <li><input type="checkbox"/> Transmission loss</li> <li><input type="checkbox"/> unplanned control center evacuation</li> <li><input type="checkbox"/> Complete loss of voice communication capability</li> <li><input type="checkbox"/> Complete loss of monitoring capability</li> </ul> </div> <div style="flex: 1; padding-left: 20px;">                     Written description (optional):                 </div> </div>

## Guideline and Technical Basis

### Summary of Key Concepts

The DSRSDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the Bulk Electric System
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1 pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. EOP-004 Attachment 1 covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.

The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time communication is achieved is covered in other standards. The proposed standard deals exclusively with after-the-fact reporting.

### Data Gathering

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have



experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### Law Enforcement Reporting

The reliability objective of EOP-004-2 is to improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### Stakeholders in the Reporting Process

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at a Facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### Present expectations of the industry under CIP-001-1a:

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. These requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, Responsible Entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the

number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**


A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

### **Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts**

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### Summary of Concepts and Assumptions:

##### ***The Standard:***

- Requires reporting of “events” that impact or may impact the reliability of the Bulk Electric System
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

##### **Discussion of Disturbance Reporting**

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (EOP-004 Attachment 1).

### **Discussion of Event Reporting**

There are situations worthy of reporting because they have the potential to impact reliability.

Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- Train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center)
- Destruction of Bulk Electric System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electric System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering necessary for event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for

reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in EOP-004 Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be sent to the NERC in lieu of entering that information on the NERC report.

## Standard Development Timeline

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April, 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 15 – October 15, 2010)
6. Second Comment Period (Formal) (March 9 – April 8, 2011)
7. Third Comment Period and Initial Ballot (October 28 – December 12, 2011)
- 7-8. Fourth Comment Period and Successive Ballot (April 25 – May 24, 2012).

### Proposed Action Plan and Description of Current Draft

This is the ~~fifth~~<sup>fourth</sup> posting of the proposed standard in accordance with Results-Based Criteria. The drafting team requests posting for a 30-day formal comment period concurrent with the formation of the ballot pool and the successive ballot.

### Future Development Plan

Anticipated Actions	Anticipated Date
Drafting team considers comments, makes conforming changes on <del>fourth</del> <sup>third</sup> posting	<del>June</del> <sup>January</sup> - <del>August</del> <sup>March</sup> 2012
Fourth Comment/Ballot period	<del>March</del> <sup>April</sup> - <del>September</del> <sup>August</sup> 2012
Recirculation Ballot period	<del>October</del> <sup>May</sup> 2012
Receive BOT approval	<del>November</del> <sup>June</sup> 2012
File with regulatory authorities	<del>December</del> <sup>August</sup> 2012

### Effective Dates

~~EOP-004-2 shall become effective on the~~ The first day of the ~~first third~~ calendar quarter ~~that is six months beyond the date that this standard is approved by~~ applicable regulatory ~~authorities~~ approval. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the ~~first third~~ calendar quarter ~~that is six months beyond the date this standard is approved by the~~ after NERC Board of Trustees approval, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

### Version History

Version	Date	Action	Change Tracking
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting. Retire CIP-008-3, Requirement 1, Part 1.3.	Revision to entire standard (Project 2009-01)



### Definitions of Terms Used in Standard

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## A. Introduction

1. **Title:** Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.
4. **Applicability**
  - 4.1. **Functional Entities: Within the context of EOP-004-2, the term “Responsible Entity” shall include the following entities as shown in EOP-004 Attachment 1:**
    - 4.1.1. Reliability Coordinator
    - 4.1.2. Balancing Authority
    - ~~4.1.3. Interchange Coordinator~~
    - ~~4.1.4. Transmission Service Provider~~
    - ~~4.1.5.4.1.3. Transmission Owner~~
    - ~~4.1.6.4.1.4. Transmission Operator~~
    - ~~4.1.7.4.1.5. Generator Owner~~
    - ~~4.1.8.4.1.6. Generator Operator~~
    - ~~4.1.9.4.1.7. Distribution Provider~~
    - ~~4.1.10. Load Serving Entity~~
    - ~~4.1.11. Electric Reliability Organization~~
    - ~~4.1.12. Regional Entity~~

## 5. Background:

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient Bulk Electric System reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC SC in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

### ~~Summary of Key Concepts~~

~~The DSRSDT identified the following principles to assist them in developing the standard:~~

- ~~• Develop a single form to report disturbances and events that threaten the reliability of the Bulk Electric System~~
- ~~• Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements~~
- ~~• Establish clear criteria for reporting~~
- ~~• Establish consistent reporting timelines~~
- ~~• Provide clarity around who will receive the information and how it will be used~~

~~During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.~~

~~The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1 pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. EOP-004 Attachment 1 covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.~~

~~The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting.~~

### ~~Data Gathering~~

~~The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.~~

### ~~Law Enforcement Reporting~~

~~The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.~~

### ~~Stakeholders in the Reporting Process~~

- ~~• Industry~~
- ~~• NERC (ERO), Regional Entity~~
- ~~• FERC~~
- ~~• DOE~~
- ~~• NRC~~
- ~~• DHS—Federal~~
- ~~• Homeland Security—State~~
- ~~• State Regulators~~
- ~~• Local Law Enforcement~~
- ~~• State or Provincial Law Enforcement~~
- ~~• FBI~~
- ~~• Royal Canadian Mounted Police (RCMP)~~

~~The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.~~

### ~~Present expectations of the industry under CIP-001-1a:~~

~~It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. Annual requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, responsible entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.~~

### ~~Coordination of Local and State Law Enforcement Agencies with the FBI~~

~~The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.~~

### ~~Coordination of Local and Provincial Law Enforcement Agencies with the RCMP~~


~~A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).~~

~~A Reporting Process Solution — EOP-004~~

~~A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.~~

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

## B. Requirements and Measures

**R1.** Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). ~~that includes:-~~ *[Violation Risk: Factor: Lower] [Time Horizon: Operations Planning]*

~~1.1. A process for recognizing each of the applicable events listed in EOP-004 Attachment 1 (except for Cyber Security Incidents characterized and classified according to the requirements in CIP-008-3 or its successor).~~

~~1.2. A process for communicating each of the applicable events listed in EOP-004 Attachment 1 in accordance with the timeframes specified in EOP-004 Attachment 1 to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity’s Reliability Coordinator; law enforcement, governmental or provincial agencies.~~

### Rationale for R1

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; i.e. Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC Events Analysis Program. These other parties use this information to promote reliability, develop a culture of reliability excellence, provide industry collaboration and promote a learning organization.

Every industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective.

~~Part 1.1 clarifies that entities must address each of the “applicable” events listed in EOP-004 Attachment 1. Not all responsible entities must address all events; e.g., some events are only applicable to the Reliability Coordinator. Part 1.1 acknowledges that Cyber Security Incidents are characterized and classified according to the requirements in CIP-008-3.~~

~~Part 1.2~~ The protocol(s) could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information.

An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.



**M1.** Each Responsible Entity will have a current, dated, event reporting Operating Plan that includes, but is not limited to the protocol(s), thresholds for reporting, and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1 and in accordance with the entity responsible for reporting~~which includes Parts 1.1—1.2.~~

**R2.** Each Responsible Entity shall report ~~implement its events per their reporting~~ Operating Plan within 24 hours of meeting an event type threshold for reporting for applicable events listed in EOP-004 Attachment 1, and in accordance with the timeframe specified in EOP-004 Attachment 1. [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]

**M2.** Each Responsible Entity will have as evidence of reporting an event, copy of the completed EOP-004-2 Attachment 2 form or a DOE-OE-417 form; and evidence of submittal (e.g., operator log or other operating documentation, voice recording, electronic mail message, or confirmation of facsimile) demonstrating the event report was submitted within 24 hours of meeting the threshold for reporting, for each event experienced, a dated copy of the completed EOP-004 Attachment 2 form or DOE form OE-417 report submitted for that event; and dated and time-stamped transmittal records to show that the event was reported supplemented by operator logs or other operating documentation. Other forms of evidence may include, but are not limited to, dated and time-stamped voice recordings and operating logs or other operating documentation for situations where filing a written report was not possible. (R2)

**R3.** Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year ~~conduct an annual test, not including notification to the Electric Reliability Organization, of the communications process in Part 1.2.~~ [Violation Risk Factor: Medium] [Time Horizon: Operations Planning]

### Rationale for R2

Each Responsible Entity must report and communicate events according to its Operating Plan after the fact based on the information in EOP-004 Attachment 1. By implementing the event reporting Operating Plan, the Responsible Entity will assure situational awareness to the Electric Reliability Organization and other organizations needed for the event type; i.e. the Regional Entity; company personnel; the Responsible Entity's Reliability Coordinator; law enforcement, governmental or provincial agencies as deemed necessary by the Registered Entity. By communicating events per the Operating Plan, the Responsible Entity will assure that people/agencies are aware of the current situation and they may prepare to mitigate current and further events.

### Rationale for R3 and R4

Requirements 3 and 4 calls for the Responsible Entity to validate the contact information contained in the Operating Plan each calendar year. This requirement helps ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event ~~annual test of the communications process in Part 1.2 as well as an annual review of the event reporting Operating Plan. These two requirements help ensure that the event reporting Operating Plan is up to date and entities will be effective in reporting events to assure situational awareness to the Electric Reliability Organization and their Reliability Coordinator. This will assure that the BES remains secure and stable by mitigation actions that the Reliability Coordinator has within its function.~~

~~M3. Each Responsible Entity will have dated records to show that it validated all contact information contained in the Operating Plan each calendar year. Such evidence may include, but are not limited to, dated voice recordings and operating logs or other communication documentation and time-stamped records to show that the annual test of Part 1.2 was conducted. Such evidence may include, but are not limited to, dated and time stamped voice recordings and operating logs or other communication documentation. The annual test requirement is considered to be met if the responsible entity implements the communications process in Part 1.2 for an actual event. (R3)~~

~~R4. Each Responsible Entity shall conduct an annual review of the event reporting Operating Plan in Requirement R1. *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*~~

~~M4. Each Responsible Entity will have dated and time-stamped records to show that the annual review of the event reporting Operating Plan was conducted. Such evidence may include, but are not limited to, the current document plus the ‘date change page’ from each version that was reviewed. (R4)~~

## C. Compliance

### 1. Compliance Monitoring Process

#### 1.1 Compliance Enforcement Authority

The Regional Entity shall serve as the Compliance ~~E~~enforcement ~~A~~authority (CEA) unless the applicable entity is owned, operated, or controlled by the Regional Entity. In such cases the ERO or a Regional ~~e~~Entity approved by FERC or other applicable governmental authority shall serve as the CEA.

~~For NERC, a third-party monitor without vested interest in the outcome for NERC shall serve as the Compliance Enforcement Authority.~~

#### 1.2 Evidence Retention

~~The [responsible entity] shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:~~

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to

provide other evidence to show that it was compliant for the full time period since the last audit.

- Each Responsible Entity shall retain the current Operating Plan plus each version issued since the last audit for Requirements R1, and Measure M1.
- Each Responsible Entity shall retain evidence of compliance since the last audit for Requirements R2, R3 and Measure M2, M3.

~~Each Responsible Entity shall retain the current, document plus the 'date change page' from each version issued since the last audit for Requirements R1, R4 and Measures M1, M4.~~

~~Each Responsible Entity shall retain evidence from prior 3 calendar years for Requirements R2, R3 and Measure M2, M3.~~

If a Registered Entity is found non-compliant, it shall keep information related to the non-compliance until mitigation is complete and approved or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

### **1.3 Compliance Monitoring and Enforcement Processes:**

Compliance Audit  
Self-Certification  
Spot Checking  
Compliance Investigation  
Self-Reporting  
Complaint

### **1.4 Additional Compliance Information**

None

Table of Compliance Elements

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	Operations Planning	Lower	N/A	N/A	<del>The Responsible Entity has an event reporting Operating Plan but failed to include one of Parts 1.1 through 1.2.</del> <u>N/A</u>	The Responsible Entity failed to include both Parts 1.1 and 1.2.
R2	Operations Assessment	Medium	<p>The Responsible Entity submitted a report <u>(e.g., written or verbal) to all required recipients</u> more than 24 hours but less than or equal to 36 hours after <u>meeting an event threshold for reporting an event</u> requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p>The Responsible Entity</p>	<p>The Responsible Entity submitted a report <u>(e.g., written or verbal) to all required recipients</u> more than 36 hours but less than or equal to 48 hours after <u>meeting an event threshold for reporting an event</u> requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p><u>The Responsible Entity failed to submit an event report (e.g., written or verbal) to</u></p>	<p>The Responsible Entity submitted a report <u>(e.g., written or verbal) to all required recipients</u> more than 48 hours but less than or equal to 60 hours after <u>meeting an event threshold for reporting an event</u> requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p><u>The Responsible Entity failed to submit an event report (e.g., written or verbal) to three entities identified</u></p>	<p>The Responsible Entity submitted a report <u>(e.g., written or verbal) to all required recipients</u> more than 60 hours after <u>meeting an event threshold for reporting an event</u> requiring reporting within 24 hours in EOP-004 Attachment 1.</p> <p>OR</p> <p><u>The Responsible Entity failed to submit an event report (e.g., written or verbal) to four or more entities identified in its event</u></p>

EOP-004-2 — Event Reporting

			submitted an <u>event report (e.g., written or verbal) to one entity identified in the event report Operating Plan within 24 hours. in the appropriate timeframe but failed to provide all of the required information.</u>	<u>two entities identified in its event reporting Operating Plan within 24 hours..The Responsible Entity submitted a report more than 1 hour but less than 2 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</u>	<u>in its event reporting Operating Plan within 24 hours.The Responsible Entity submitted a report in more than 2 hours but less than 3 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</u>	<u>reporting Operating Plan within 24 hours.The Responsible Entity submitted a report more than 3 hours after an event requiring reporting within 1 hour in EOP-004 Attachment 1.</u>  OR The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.
<b>R3</b>	Operations Planning	Medium	<u>The Responsible Entity validated all contact information contained in the Operating Plan but was late by less than one calendar month.</u>  OR <u>The Responsible Entity validated 75% or more of the contact information contained in the Operating Plan. The Responsible Entity performed the annual test of the</u>	<u>The Responsible Entity validated all contact information contained in the Operating Plan but was late by one calendar month or more but less than two calendar months.</u>  OR <u>The Responsible Entity validated 50% and less than 75% of the contact information contained in the Operating Plan.The Responsible Entity</u>	<u>The Responsible Entity validated all contact information contained in the Operating Plan but was late by two calendar months or more but less than three calendar months.</u>  OR <u>The Responsible Entity validated 25% and less than 50% of the contact information contained in the Operating Plan. The Responsible Entity</u>	<u>The Responsible Entity validated all contact information contained in the Operating Plan but was late by three calendar months or more.</u>  OR <u>The Responsible Entity validated less than 25% of contact information contained in the Operating Plan. The Responsible Entity performed the annual test of the</u>

			<del>communications process in Part 1.2 but was late by less than one calendar month.</del>	<del>performed the annual test of the communications process in Part 1.2 but was late by one calendar month or more but less than two calendar months.</del>	<del>performed the annual test of the communications process in Part 1.2 but was late by two calendar months or more but less than three calendar months.</del>	<del>communications process in Part 1.2 but was late by three calendar months or more. OR The Responsible Entity failed to perform the annual test of the communications process in Part 1.2.</del>
<b>R4</b>	Operations Planning	Medium	<del>The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by less than one calendar month.</del>	<del>The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by one calendar month or more but less than two calendar months.</del>	<del>The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by two calendar months or more but less than three calendar months.</del>	<del>The Responsible Entity performed the annual review of the event reporting Operating Plan but was late by three calendar months or more. OR The Responsible Entity failed to perform the annual review of the event reporting Operating Plan</del>

**D. Variances**  
None.

**E. Interpretations**  
None.

- F. References~~Interpretations~~  
Guideline and Technical Basis (attached).



## EOP-004 - Attachment 1: Reportable Events

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R1 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: [systemawareness@nerc.net](mailto:systemawareness@nerc.net) or Voice: 404-446-9780. ~~esisac@nerc.com, Facsimile: 609-452-9550, Voice: 609-452-1422.~~

**One Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirement R1, Part 1.2 within one hour of recognition of the event.**

Event	Entity with Reporting Responsibility	Threshold for Reporting
A reportable Cyber Security Incident.	Each Responsible Entity applicable under CIP-008-3 or its successor that experiences the Cyber Security Incident	That meets the criteria in CIP-008-3 or its successor

### Rationale Box for EOP-004 Attachment 1:

The DSR SDT used the defined term "Facility" to add clarity for several events listed in Attachment 1. A Facility is defined as:

"A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)"

The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

~~Twenty-four Hour Reporting: Submit EOP-004 Attachment 2 or DOE-OE-417 report to the parties identified pursuant to Requirements R1 and R2, Part 1.2 within twenty-four hours of recognition of the event.~~

Event	Entity with Reporting Responsibility	Threshold for Reporting
Damage or destruction of a Facility	<del>Each RC, BA, TO, TOP, GO, GOP, DP that experiences the damage or destruction of a Facility</del>	<p><del>Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency. Damage or destruction of a Facility that:</del></p> <p><del>Affects an IROL (per FAC-014)</del></p> <p><del>OR</del></p> <p><del>Results in the need for actions to avoid an Adverse Reliability Impact</del></p> <p><del>OR</del></p> <p><del>Results from actual or suspected intentional human action.</del></p>
<del>Damage or destruction of a Facility</del>	<del>BA, TO, TOP, GO, GOP, DP</del>	<del>Damage or destruction of its Facility that results from actual or suspected intentional human action.</del>
<del>Any physical threats to that could impact the operability of a Facility<sup>+</sup></del>	<del>Each RC, BA, TO, TOP, GO, GOP, DP that experiences the event</del>	<p><del>Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility.</del></p> <p><del>OR</del></p> <p><del>Suspicious device or activity at a Facility.</del></p> <p><del>Do not report theft unless it degrades normal operation of a</del></p>

<sup>+</sup>~~Examples include a train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center). Also report any suspicious device or activity at a Facility. Do not report copper theft unless it impacts the operability of a Facility.~~

**EOP-004-2 — Event Reporting**

Event	Entity with Reporting Responsibility	Threshold for Reporting
		<del>Facility. Threat to a Facility excluding weather related threats.</del>
<u>Physical threats to a BES control center</u>	<u>RC, BA, TOP</u>	<u>Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center.</u> <u>OR</u> <u>Suspicious device or activity at a BES control center.</u>
BES Emergency requiring public appeal for load reduction	Initiating entity is responsible for reporting	Public appeal for load reduction event
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq 100$ MW
BES Emergency resulting in automatic firm load shedding	<del>Each DP, or TOP that implements automatic load shedding</del>	<del>Automatic firm load shedding <math>\geq 100</math> MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS)</del>
Voltage deviation on a Facility	<del>Each TOP that observes the voltage deviation</del>	<u>Observed within its area a voltage deviation of <math>\pm 10\%</math> sustained for <math>\geq 15</math> continuous minutes</u>
IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)	<del>Each RC that experiences the IROL Violation (all Interconnections) or SOL violation for Major WECC Transfer Paths (WECC only)</del>	Operate outside the IROL for time greater than IROL $T_v$ (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only).
Loss of firm load <del>for <math>\geq 15</math> Minutes</del>	<del>Each BA, TOP, DP that experiences the loss of firm load</del>	<u>Loss of firm load for <math>\geq 15</math> Minutes:</u> <ul style="list-style-type: none"> <li>• <math>\geq 300</math> MW for entities with previous year's demand <math>\geq 3,000</math> MW</li> <li>• <math>\geq 200</math> MW for all other entities</li> </ul>

EOP-004-2 — Event Reporting

Event	Entity with Reporting Responsibility	Threshold for Reporting
System separation (islanding)	<del>Each RC, BA, TOP, DP that experiences the system separation</del>	Each separation resulting in an island <del>of generation and load</del> $\geq 100$ MW
Generation loss	<del>Each BA, GOP that experiences the generation loss</del>	<del>Total generation loss, within one minute, of</del> $\geq 2,000$ MW for entities in the Eastern or Western Interconnection <u>OR</u> $\geq 1,000$ MW for entities in the ERCOT or Quebec Interconnection
Complete loss of off-site power to a nuclear generating plant (grid supply)	<del>Each TO, TOP that experiences the complete loss of off-site power to a nuclear generating plant</del>	<del>Complete loss of off-site power a</del> Affecting a nuclear generating station per the Nuclear Plant Interface Requirement
Transmission loss	<del>Each TOP that experiences the transmission loss</del>	<del>Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance Unintentional loss of three or more Transmission Facilities</del> (excluding successful automatic reclosing)
Unplanned control center evacuation	<del>Each RC, BA, TOP that experiences the event</del>	Unplanned evacuation from BES control center facility for 30 minutes or more.
<del>Complete L</del> loss of <del>all</del> voice communication capability	<del>Each RC, BA, TOP that experiences the loss of all voice communication capability</del>	<del>Complete loss of voice communication capability a</del> Affecting a BES control center for $\geq 30$ continuous minutes
Complete <del>or partial</del> loss of monitoring capability	<del>Each RC, BA, TOP that experiences the complete or partial loss of monitoring capability</del>	<del>Complete loss of monitoring capability a</del> Affecting a BES control center for $\geq 30$ continuous minutes such that analysis tools ( <u>i.e.</u> , State Estimator <u>or</u> , Contingency Analysis) are rendered inoperable.

EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004 Attachment 2: Event Reporting Form</b>	
<p><b>Use this form to report events. The Electric Reliability Organization and the Responsible Entity's Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> voice: 404-446-9780 <a href="mailto:esisac@nerc.com">esisac@nerc.com</a>, Facsimile: 609-452-9550, voice: 609-452-1422.</b></p>	
Task	Comments
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:
3.	Did the event originate in your system?      Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
4.	<p style="text-align: center;"><b>Event Identification and Description:</b></p> <p>(Check applicable box)</p> <input type="checkbox"/> <u>Damage or destruction of a Facility</u> <input type="checkbox"/> <u>Physical Threat to a Facility</u> <input type="checkbox"/> <u>Physical Threat to a control center</u> <input type="checkbox"/> <u>BES Emergency:</u> <input type="checkbox"/> <u>public appeal for load reduction</u> <input type="checkbox"/> <u>systemwide voltage reduction</u> <input type="checkbox"/> <u>manual firm load shedding</u> <input type="checkbox"/> <u>automatic firm load shedding</u> <input type="checkbox"/> <u>Voltage deviation on a Facility</u> <input type="checkbox"/> <u>IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)</u> <input type="checkbox"/> <u>Loss of firm load</u> <input type="checkbox"/> <u>System separation</u> <input type="checkbox"/> <u>Generation loss</u> <input type="checkbox"/> <u>Complete loss of off-site power to a nuclear generating plant (grid supply)</u> <input type="checkbox"/> <u>Transmission loss</u> <input type="checkbox"/> <u>unplanned control center evacuation</u> <input type="checkbox"/> <u>Complete loss of voice communication capability</u> <input type="checkbox"/> <u>Complete loss of monitoring capability (Check applicable box)</u> <input checked="" type="checkbox"/> <u>public appeal</u>

**EOP-004 Attachment 2: Event Reporting Form**

Use this form to report events. The Electric Reliability Organization and the Responsible Entity's Reliability Coordinator will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: [systemawareness@nerc.net](mailto:systemawareness@nerc.net) voice: 404-446-9780 [esisac@nerc.com](mailto:esisac@nerc.com), Facsimile: 609-452-9550, voice: 609-452-1422.

Task	Comments
<ul style="list-style-type: none"> <li><input type="checkbox"/> <del>voltage reduction</del></li> <li><input type="checkbox"/> <del>manual firm load shedding</del></li> <li><input type="checkbox"/> <del>firm load shedding(undervoltage, underfrequency, SPS/RAS)</del></li> <li><input type="checkbox"/> <del>voltage deviation</del></li> <li><input type="checkbox"/> <del>IROL violation</del></li> <li><input type="checkbox"/> <del>loss of firm load</del></li> <li><input type="checkbox"/> <del>system separation (islanding)</del></li> <li><input type="checkbox"/> <del>generation loss</del></li> <li><input type="checkbox"/> <del>complete loss of off-site power to nuclear generating plant</del></li> <li><input type="checkbox"/> <del>transmission loss</del></li> <li><input type="checkbox"/> <del>damage or destruction of Facility</del></li> <li><input type="checkbox"/> <del>unplanned control center evacuation</del></li> <li><input type="checkbox"/> <del>loss of all voice communication capability</del></li> <li><input type="checkbox"/> <del>complete or partial loss of monitoring capability</del></li> <li><input type="checkbox"/> <del>physical threat that could impact the operability of a Facility</del></li> <li><input type="checkbox"/> <del>reportable Cyber Security Incident</del></li> </ul>	

## Guideline and Technical Basis

### Summary of Key Concepts

The DSRSDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the Bulk Electric System
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1 pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. EOP-004 Attachment 1 covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.

The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time reporting is achieved through the RCIS and is covered in other standards (e.g. the TOP family of standards). The proposed standard deals exclusively with after-the-fact reporting.

### Data Gathering

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have

experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### **Law Enforcement Reporting**

The reliability objective of EOP-004-2 is to prevent outages which could lead to Cascading by effectively reporting events. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical or cyber attack. The Standard is intended to reduce the risk of Cascading events. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### **Stakeholders in the Reporting Process**

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at an industry facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. Annual requirements, under the standard, of the industry have not been clear and have lead to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, responsible entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the



number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**


A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

**A Reporting Process Solution – EOP-004**

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standard deals exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### Summary of Concepts and Assumptions:

##### *The Standard:*

- Requires reporting of “events” that impact or may impact the reliability of the Bulk Electric System
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

#### **Discussion of Disturbance Reporting**

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (EOP-004 Attachment 1).

### Discussion of Event Reporting

There are situations worthy of reporting because they have the potential to impact reliability.

Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- ~~Detection of cyber intrusion that meets criteria of CIP-008-3 or its successor standard~~
- ~~Forced intrusion attempt at a substation~~
- Train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center) near a transmission right-of-way
- Destruction of Bulk Electric System equipment

### What about sabotage?

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electric System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### Potential Uses of Reportable Information

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering necessary for event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for

performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in EOP-004 Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be included or attached to the NERC report, in lieu of entering that information on the NERC report.

## Implementation Plan

### Project 2009-01 Disturbance and Sabotage Reporting

#### Implementation Plan for EOP-004-2 – Event Reporting

##### *Approvals Required*

EOP-004-2 – Event Reporting

##### *Prerequisite Approvals*

None

##### *Revisions to Glossary Terms*

None

##### *Applicable Entities*

Reliability Coordinator  
Balancing Authority  
Transmission Owner  
Transmission Operator  
Generator Owner  
Generator Operator  
Distribution Provider

##### *Conforming Changes to Other Standards*

None

##### *Effective Dates*

In those jurisdictions where regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months after applicable regulatory approval or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

*Retirements*

**EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting** should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.



## Implementation Plan

### Project 2009-01 Disturbance and Sabotage Reporting

#### Implementation Plan for EOP-004-2 – Event Reporting

##### *Approvals Required*

EOP-004-2 – Event Reporting

##### *Prerequisite Approvals*

None

##### *Revisions to Glossary Terms*

None

##### *Applicable Entities*

Reliability Coordinator  
Balancing Authority  
Transmission Owner  
Transmission Operator  
Generator Owner  
Generator Operator  
Distribution Provider

##### *Conforming Changes to Other Standards*

None

##### *Effective Dates*

In those jurisdictions where regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months after applicable regulatory approval or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities. ~~beyond the date that this standard is approved by applicable regulatory approval.~~ In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

*Retirements*

**EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting** should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.

# Unofficial Comment Form

## Project 2009-01 Disturbance and Sabotage Reporting

Please **DO NOT** use this form for submitting comments. Please use the [electronic form](#) to submit comments on the draft standard EOP-004-2. Comments must be submitted by **September 27, 2012**. If you have questions please contact [Stephen Crutchfield](#) by email or by telephone at (609) 651-9455.

### Background Information

EOP-004-2 was posted for a 30-day formal comment period and successive ballot from April 25 through May 24, 2011. The DSR SDT received suggestions from stakeholders to improve the readability and clarity of the requirements of the standard. The revisions that were made to the standard are summarized in the following paragraphs. As a result of these revisions, the DSR SDT is posting the standard for a second successive ballot period.

The DSR SDT has developed EOP-004-2 to replace the current mandatory and enforceable EOP-004-1 and CIP-001-2a standards, therefore, retiring both EOP-004-1 and CIP-002-2a. The reporting obligations under EOP-004-2 serve to provide input to the NERC Events Analysis Program. Analysis of events is not required under the proposed standard and any analysis or investigation will fall under the Event Analysis Program under the NERC Rules of Procedure.

The following changes were made as a result of comment received in the last formal comment period and successive ballot:

1. The DSR SDT has removed reporting of Cyber Security Incidents from EOP-004 and has asked the team developing CIP-008-5 to retain this reporting. With this revision, the Interchange Coordinator, Transmission Service Provides, Load-Serving Entity, Electric Reliability Organization and Regional Entity were removed as Responsible Entities.
2. Most of the language contained in the "Background" Section was moved to the "Guidelines and Technical Basis" Section. Minor language changes were made to the measures and the data retention section. Attachment 2 was revised to list events in the same order in which they appear in Attachment 1.
3. Requirement R1 was revised to include the Parts in the main body of the Requirement. The Measure and VSLs were updated accordingly.
4. Following review of the industry's comments, the SDT has re-examined the FERC Directive in Order 693 and has dropped both Requirement R4 and Requirement R5, and updated Requirement R3 to have the Registered Entity "validate" the contact information in the contact list(s) that they may have for the events applicable to them. This validation needs to be

performed each calendar year to ensure that the list(s) have current and up-to-date contact data.

- R3. Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. *[Violation Risk Factor: Medium]*  
*[Time Horizon: Operations Planning]"*
5. The SDT has also updated Attachment 1 based on comments received, FERC directives, and in consideration of what is required for combining CIP-001-2a and EOP-004-1 into EOP-004-2. Under the Event Column, the SDT starts to classify each type of an event by assigning an "Event Type" title. The DSR SDT then updated the "Entity with Reporting Responsibilities" column to simply state which entity has the responsibility to report if they experience an event. The last column, "Threshold for Reporting," is a bright line that, if reached, the entity needs to report that they experienced the applicable event per Requirement 1.
6. The DSR SDT had previously proposed a revision to the NERC Rules of Procedure (Section 812). The SDT has learned that NERC has started a new effort to forward event reports to applicable government authorities. As such, Section 812 is no longer needed and will be removed from this project.

## Questions

You do not have to answer all questions.

1. The DSR SDT has revised EOP-004-2 by combining Requirements R3 and R4 into a single requirement (Requirement R3) to, "... validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year." Do you agree with this revision? If not, please explain in the comment area below.

Yes

No

Comments:

2. The DSR SDT has revised the VSLs to reflect the language in the revised requirements. Do you agree with the proposed VRFs and VSLs? If not, please explain in the comment area below.

Yes

No

Comments:

3. Do you have any other comment, not expressed in the questions above, for the DSR SDT?

Comments:

## Project 2009-01 Disturbance and Sabotage Reporting Mapping Document

Translation of CIP-001-2a – Sabotage Reporting and EOP-004-1 – Disturbance Reporting into EOP-004-2 – Event Reporting

Standard: CIP-001-2a – Sabotage Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting
R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi site sabotage affecting larger portions of the Interconnection.	Moved into EOP-004-2, R1	R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i>
R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.	Moved into EOP-004-2, R1	R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i>

Standard: CIP-001-2a – Sabotage Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting
R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.	Moved into EOP-004-2, R1	R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i>
R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.	Moved into EOP-004-2, R1	R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i>

Standard: EOP-004-1 – Disturbance Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.	Retire this fill-in-the-blank requirement.  Replace with new reporting and analysis procedure developed by NERC EAWG.	The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.
R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.	Translated into EOP-004-2, R1 and the NERC Events Analysis Process	The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.
R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.	Translated into EOP-004-2, R2	R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</i>



Standard: EOP-004-1 – Disturbance Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until sometime after they occur shall be reported within 24 hours of being recognized.	Translated into EOP-004-2, R2	R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</i>
R3.2. Applicable reporting forms are provided in Attachments 022-1 and 022-2.	Retire – informational statement	

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
<p>R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.</p>	<p>Retire as a requirement. Added as a “Note” to EOP-004-Attachment1-Impact Events Table</p>	<p>NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R2 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> or Voice: 404-446-9780.</p>

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
<p>R3.4. If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
<p>R4. When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Impact Event and Disturbance Assessment, Analysis, and Reporting Comments
<p>R5. The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.</p>	<p>Retire this fill-in-the-blank requirement.</p> <p>Replace with new reporting procedure developed by NERC EAWG.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of impact events. The NERC EAWG is developing continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure.</p>
<p>Request for Interpretation of CIP-001-2a, R2: Please clarify what is meant by the term, “appropriate parties.” Moreover, who within the Interconnection hierarchy deems parties to be appropriate?</p>	<p>Retire the interpretation</p>	<p>Addressed in EOP-004-2, R1 by replacing the term, ‘appropriate parties’ with a broader, more specific list of specific entities to contact in Requirement R1.</p>

## Project 2009-01 Disturbance and Sabotage Reporting Consideration of Issues and Directives

Project 2009-01 Disturbance and Sabotage Reporting		
Issue or Directive	Source	Consideration of Issue or Directive
<p>"What is meant by: "establish contact with the FBI"? Is a phone number adequate? Many entities which call the FBI are referred back to the local authority. The AOT noted that on the FBI website it states to contact the local authorities. Is this a question for Homeland Security to deal with for us?"</p> <p>Establish communications contacts, as applicable with local FBI and RCMP officials. Some entities are very remote and the sheriff is the only local authority does the FBI still need to be contacted?</p> <p>Registered Entities have sabotage reporting processes and procedures in place but not all personnel has been trained.</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>The DSR SDT has been in contact with FBI staff and developed a notification flow chart for law enforcement as it pertains to EOP-004. The "Background" section of the standard outlines the reporting hierarchy that exists between local, state, provincial and federal law enforcement. The entity experiencing an event should notify the appropriate state or provincial law enforcement agency that will then coordinate with local law enforcement for investigation. These local, state and provincial agencies will coordinate with higher levels of law enforcement or other governmental agencies.</p>

<p>Question: How do you “and make the operator aware”</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>This has been removed from the standard. Requirement R1 requires that the entity has an Operating Plan for applicable events listed in Attachment 1.</p>
<p>How does this standard pertain to Load Serving Entities, LSE's.</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>LSE has been removed as an applicable entity as there are no applicable events.</p>
<p>We direct the ERO to explore ways to address these concerns – including central coordination of sabotage reports and a uniform reporting format – in developing modifications to the Reliability Standard with the appropriate governmental agencies that have levied the reporting requirements.</p>	<p>CIP-001-1; Order 693</p>	<p>See “Background” section of the standard as well as the “Guidelines and Technical Basis” section.</p>

<p>"Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event. Paragraph 461. Several commenters agree with the Commission's concern that the term "sabotage" should be defined. For the reasons stated in the NOPR, we direct that the ERO further define the term and provide guidance on triggering events that would cause an entity to report an event. However, we disagree with those commenters that suggest the term "sabotage" is so vague as to justify a delay in approval or the application of monetary penalties. As explained in the NOPR, we believe that the term sabotage is commonly understood and that common understanding should suffice in most instances.</p>	<p>CIP-001-1; Order 693</p>	<p>The DSR SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of "event". The DSR SDT considered the FERC directive to "further define sabotage" and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term "sabotage" is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p>
<p>The ERO should consider suggestions raised by commenters such as FirstEnergy and Xcel to define the specified period for reporting an incident beginning from when an event is discovered or suspected to be sabotage, and APPA's concerns regarding events at unstaffed or remote facilities, and triggering events occurring outside staffed hours at small entities.</p>	<p>CIP-001-1; Order 693</p>	<p>Attachment 1 defines the events which are to be reported under this standard. The required reporting is within 24 hours "of recognition of the event."</p>



<p>Modify CIP-001-1 1 to require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specific period of time, even if it is a preliminary report. Further, in the interim while the matter is being addressed by the Reliability Standards development process, we direct the ERO to provide advice to entities that have concerns about the reporting of particular circumstances as they arise.</p>	<p>CIP-001-1; Order 693</p>	<p>Per Requirement R1, the entity is to develop an Operating Plan which includes event reporting to law enforcement and governmental agencies. The DSR SDT has been in contact with NERC Situational Awareness and has been informed that all event reports received by NERC are being forwarded to FERC.</p>
<p>Consider the need for wider application of the standard. Consider whether separate, less burdensome requirements for smaller entities may be appropriate. Paragraph 458. The Commission acknowledges the concerns of the commenters about the applicability of CIP-001-1 to small entities and has addressed the concerns of small entities generally earlier in this Final Rule. Our approval of the ERO Compliance Registry criteria to determine which users, owners and operators are responsible for compliance addresses the concerns of APPA and others. 459. However, the Commission believes that there are specific reasons for applying this Reliability Standard to such entities, as discussed in the NOPR. APPA indicates that some small LSEs do not own or operate “hard assets” that are normally thought of as “at risk” to sabotage. The Commission is concerned that, an adversary might determine that a small LSE is the appropriate target when the adversary aims at a particular population or facility. Or an adversary may target a small user, owner or operator because it may have similar equipment or protections as a larger facility, that is, the adversary may use an attack against a smaller facility as a training “exercise.” {continued below}</p>	<p>CIP-001-1; Order 693</p>	<p>Attachment 1 defines the events which are to be reported under this standard. The applicable entities are also identified for each type of event. Each event is to be reported within 24 hours of recognition of the event.</p>

<p>The knowledge of sabotage events that occur at any facility (including small facilities) may be helpful to those facilities that are traditionally considered to be the primary targets of adversaries as well as to all members of the electric sector, the law enforcement community and other critical infrastructures. 460. For these reasons, the Commission remains concerned that a wider application of CIP-001-1 may be appropriate for Bulk Power System reliability. Balancing these concerns with our earlier discussion of the applicability of Reliability Standards to smaller entities, we will not direct the ERO to make any specific modification to CIP-001-1 to address applicability. However, we direct the ERO, as part of its Work Plan, to consider in the Reliability Standards development process, possible revisions to CIP-001-1 that address our concerns. Regarding the need for wider application of the Reliability Standard. Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns.</p>		
---	--	--

<p>The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures. At this time, the commission does not specify a review period as suggested by FirstEnergy and MRO and, rather, believes that the appropriate period should be determined through the ERO's Reliability Standards development process. However, the Commission directs that the ERO begin this process by considering a staggered schedule of annual testing of the procedures with modifications made when warranted formal review of the procedures every two or three years.</p>	<p>CIP-001-1; Order 693</p>	<p>The standard is responsive this directive with the following language in Requirement R3:</p> <p>R3. Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p>The DSR SDT envisions that this will include verification that contact information contained in the Operating Plan is correct. As an example, the annual validation could include calling others as defined in the Responsibility Entity's Operating Plan to verify that their contact information is correct and current. If any discrepancies are noted, the Operating Plan would be updated.</p>
--	---------------------------------	--

<p>Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality. Paragraph 451. A number of commenters agree with the Commission’s concern that the term sabotage” needs to be better defined and guidance provided on the triggering events that would cause an entity to report an event. FirstEnergy states that this definition should differentiate between cyber and physical sabotage and should exclude unintentional operator error. It advocates a threshold of materiality to exclude acts that do not threaten to reduce the ability to provide service or compromise safety and security. SoCal Edison states that clarification regarding the meaning of sabotage and the triggering event for reporting would be helpful and prevent over reporting.</p>	<p>CIP-001-1; Order 693</p>	<p>This addressed in Attachment 1. There are specific event types for both cyber and physical security with their respective report submittal requirements.</p>
--	---------------------------------	---

"Include a requirement to report a sabotage event to the proper government authorities. Develop the language to specifically implement this directive. Paragraph 467. CIP-001-1, Requirement R4, requires that each applicable entity establish communications contacts, as applicable, with the local FBI or Royal Canadian Mounted Police officials and develop reporting procedures as appropriate to its circumstances. The Commission in the NOPR expressed concern that the Reliability Standard does not require an applicable entity to actually contact the appropriate governmental or regulatory body in the event of sabotage. Therefore, the Commission proposed that NERC modify the Reliability Standard to require an applicable entity to "contact appropriate federal authorities, such as the Department of Homeland Security, in the event of sabotage within a specified period of time."212 468. As mentioned above, NERC and others object to the wording of the proposed directive as overly prescriptive and note that the reference to "appropriate federal authorities" fails to recognize the international application of the Reliability Standard. The example of the Department of Homeland Security as an "appropriate federal authority" was not intended to be an exclusive designation. Nonetheless, the Commission agrees that a reference to "federal authorities" could create confusion. Accordingly, we modify the direction in the NOPR and now direct the ERO to address our underlying concern regarding mandatory reporting of a sabotage event. The ERO's Reliability Standards development process should develop the language to implement this directive."

See "Guidelines and Technical Basis" section of Standard.

"A proposal discussed with FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Event EOP-004-2). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial level law enforcement agency. The state or provincial level law enforcement agency will coordinate with local law enforcement to investigate. If the state or provincial level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial level law enforcement agency will notify and coordinate with the FBI or the RCMP."

On March 4, 2008, NERC submitted a compliance filing in response to a December 20, 2007 Order, in which the Commission reversed a NERC decision to register three retail power marketers to comply with Reliability Standards applicable to load serving entities (LSEs) and directed NERC to submit a plan describing how it would address a possible “reliability gap” that NERC asserted would result if the LSEs were not registered. NERC’s compliance filing included the following proposal for a short-term plan and a long-term plan to address the potential gap:

- Short-term: Using a posting and open comment process, NERC will revise the registration criteria to define “Non-Asset Owning LSEs” as a subset of Load Serving Entities and will specify the reliability standards applicable to that subset.
- Longer-term: NERC will determine the changes necessary to terms and requirements in reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers and process them through execution of the three-year Reliability Standards Development Plan. In this revised Reliability Standards Development Plan, NERC is commencing the implementation of its stated long-term plan to address the issues surrounding accountability for loads served by retail marketers/suppliers.

The NERC Reliability Standards Development Procedure will be used to identify the changes necessary to terms and requirements in reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. Specifically, the following description has been incorporated into the scope for

CIP-001-1 and  
EOP-004 ORDER  
ON ELECTRIC  
RELIABILITY  
ORGANIZATION  
REGISTRY\_DETE  
RMINATIONS;  
ORDER ON  
COMPLIANCE  
FILING

The LSE is no longer an applicable entity, since no reportable event types in Attachment apply to an LSE. If an entity owns distribution assets, that entity will be registered as a Distribution Provider. Attachment 1 defines the timelines and events which are to be reported under this standard. The applicable entities are also identified for each type of event.

affected projects in this revised Reliability Standards Development Plan that includes a standard applicable to Load Serving Entities:  
Source: FERC's December 20, 2007 Order in Docket Nos. RC07-004-000, RC07-6-000, and RC07-7-000.

Issue: In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none own physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be followed.

Each drafting team responsible for reliability standards that are applicable to LSEs is to review and change as necessary, requirements in the reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:

- FERC's December 20, 2007 Order  
([http://www.nerc.com/files/LSE\\_decision\\_order.pdf](http://www.nerc.com/files/LSE_decision_order.pdf))
- NERC's March 4, 2008  
(<http://www.nerc.com/files/FinalFiledLSE3408.pdf>),
- FERC's April 4, 2008 Order  
(<http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf>), and
- NERC's July 31, 2008  
(<http://www.nerc.com/files/FinalFiled-compFiling-LSE-07312008.pdf>)

compliance filings to FERC on this subject.

<p>Object to multi-site requirement</p>	<p>Version 0 Team CIP-001-1</p>	<p>The Standard was revised for clarity. Attachment 1 defines the timelines and events which are to be reported under this standard. The applicable entities are also identified for each type of event.</p>
<p>Definition of sabotage required</p> <p>VRFs Team Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures.</p>	<p>Version 0 Team CIP-001-1</p>	<p>No definition for sabotage was developed. The DSR SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of “event”. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p>



<p>Coordination and follow up on lessons learned from event analyses          Consider adding to EOP-004 – Disturbance Reporting Proposed requirement: Regional Entities (REs) shall work together with Reliability Coordinators, Transmission Owners, and Generation Owners to develop an Event Analysis Process to prevent similar events from happening and follow up with the recommendations. This process shall be defined within the appropriate NERC Standard</p>	<p>Events Analysis Team Reliability Issue</p>	<p>The DSR SDT envisions EOP-004-2 to be a reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
<p>Consider changes to R1 and R3.4 to standardize the disturbance reporting requirements (requirements for disturbance reporting need to be added to this standard). Regions currently have procedures, but not in the form of a standard. The drafting team will need to review regional requirements to determine reporting requirements for the North American standard.</p>	<p>Fill in the Blank Team</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
<p>Can there be a violation without an event?</p>	<p>NERC Audit Observation Team</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. In the opinion of the DSR SDT, there cannot be a violation of Requirement R2 without an event. Since Requirement R1 calls for an Operating Plan, there can be a violation of R1 without an event.</p>

<p>Consider APPA’s concern about generator operators and LSEs analyzing performance of their equipment and provide data and information on the equipment to assist others with analysis. Paragraph 607. APPA is concerned about the scope of Requirement R2 because, in its opinion, Requirement R2 appears to impose an open-ended obligation on entities such as generation operators and LSEs that may have neither the data nor the tools to promptly analyze disturbances that could have originated elsewhere. APPA proposes that Requirement R2 be modified to require affected entities to promptly begin analyses to ensure timely reporting to NERC and DOE.</p>	<p>EOP-004-1 Order 693</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
<p>From: David Cook Sent: Wednesday, July 16, 2008 6:06 PM To: Rick Sergel; Dave Nevius; David A. Whiteley; Management Subject: RE: FERC request for DOE-417s</p> <p>I agree the real fix is to revise the EOP-004 standard. I agree that we can’t (and shouldn’t try) to do that by way of amendments to our Rules of Procedure. So we should include that fix in the standards work plan, do the best we can in the meantime to provide FERC with the 417s, and I’ll have the conversation with Joe McClelland about not being able to do what the Commission directed in Order 693 (i.e., change the standards by way of a change in the Rules of Procedure).</p> <p>David</p>	<p>EOP-004-1 Other</p>	<p>Per Requirement R1, the entity is to develop an Operating Plan which includes event reporting to law enforcement and governmental agencies. The DSR SDT has been in contact with NERC Situational Awareness and has been informed that all event reports received by NERC are being forwarded to FERC.</p>

<p>In response to a SAR submitted by Glenn Kaht of ReliabilityFirst: As part of a regional compliance violation investigation, a possible reliability gap was identified related to EOP-004-1 — Disturbance Reporting. The existing standard limits reporting of generation outages to just those outages associated with loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. This requirement has been interpreted as meaning that only generation outages that must be reported are those that occur with the loss of a bulk power transmission element. By not reporting large generation losses that occur without the loss of a bulk power transmission element, the industry is overlooking a potential opportunity to identify and learn from these losses.</p> <p>Specifically, Item 1 of Attachment 1 of EOP-004 requires the reporting of events if “The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:” The Standard then lists six different actions that may occur as a result of the event in order to be reportable. All six of these actions appear to be dependent on “The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations” in order for the event to be reportable. Some of these events may significantly impact the reliable operation of the bulk power system. Consider a revision to EOP-004-1 — Disturbance Reporting requiring a Generator Operator (GOP) that</p>	<p>Standards Committee Action From 01/13/2010</p>	<p>The DSR SDT has worked closely with the NERC EAWG to develop the event reporting requirements shown in Attachment 1. The EAWG and the DSR SDT considered this request and weighed it against reliability needs for reporting.</p>
---	---	--

experiences the loss of generation greater than 500 MW that results in modification of equipment (e.g. control systems, or Power Load Unbalancer (PLU)) to be a reportable event.		
too many reports, narrow requirement to RC	Version 0 Team	There is only one report required under this standard. An entity may submit the report using Attachment 2 or the DEO OE-417 report form.
How does this apply to generator operator?	Version 0 Team	See attachment 1 for specific generator operator applicability.

## Violation Risk Factor and Violation Severity Level Assignments

### Project 2009-01 – Disturbance and Sabotage Reporting

This document provides the drafting team's justification for assignment of violation risk factors (VRFs) and violation severity levels (VSLs) for each requirement in

#### EOP-004-2 — Event Reporting

Each primary requirement is assigned a VRF and a set of one or more VSLs. These elements support the determination of an initial value range for the Base Penalty Amount regarding violations of requirements in FERC-approved Reliability Standards, as defined in the ERO Sanction Guidelines.

#### Justification for Assignment of Violation Risk Factors in EOP-004-2

The Disturbance and Sabotage Reporting Standard Drafting Team applied the following NERC criteria when proposing VRFs for the requirements in EOP-004-2:

##### ***High Risk Requirement***

A requirement that, if violated, could directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures, or could hinder restoration to a normal condition.

##### ***Medium Risk Requirement***

A requirement that, if violated, could directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system. However, violation of a medium risk requirement is unlikely to lead to bulk electric system instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly and adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. However, violation of a medium risk requirement is unlikely, under emergency, abnormal, or restoration conditions anticipated by the preparations, to lead to bulk electric system instability, separation, or cascading failures, nor to hinder restoration to a normal condition.

***Lower Risk Requirement***

A requirement that is administrative in nature and a requirement that, if violated, would not be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system; or, a requirement that is administrative in nature and a requirement in a planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. A planning requirement that is administrative in nature.

The SDT also considered consistency with the FERC Violation Risk Factor Guidelines for setting VRFs:<sup>1</sup>

**Guideline (1) — Consistency with the Conclusions of the Final Blackout Report**

The Commission seeks to ensure that Violation Risk Factors assigned to Requirements of Reliability Standards in these identified areas appropriately reflect their historical critical impact on the reliability of the Bulk-Power System.

In the VSL Order, FERC listed critical areas (from the Final Blackout Report) where violations could severely affect the reliability of the Bulk-Power System:<sup>2</sup>

- Emergency operations
- Vegetation management
- Operator personnel training
- Protection systems and their coordination
- Operating tools and backup facilities
- Reactive power and voltage control
- System modeling and data exchange
- Communication protocol and facilities
- Requirements to determine equipment ratings
- Synchronized data recorders
- Clearer criteria for operationally critical facilities
- Appropriate use of transmission loading relief.

**Guideline (2) — Consistency within a Reliability Standard**

The Commission expects a rational connection between the sub-Requirement Violation Risk Factor assignments and the main Requirement Violation Risk Factor assignment.

<sup>1</sup> North American Electric Reliability Corp., 119 FERC ¶ 61,145, order on reh'g and compliance filing, 120 FERC ¶ 61,145 (2007) (“VRF Rehearing Order”).

<sup>2</sup> Id. at footnote 15.

### **Guideline (3) — Consistency among Reliability Standards**

The Commission expects the assignment of Violation Risk Factors corresponding to Requirements that address similar reliability goals in different Reliability Standards would be treated comparably.

### **Guideline (4) — Consistency with NERC’s Definition of the Violation Risk Factor Level**

Guideline (4) was developed to evaluate whether the assignment of a particular Violation Risk Factor level conforms to NERC’s definition of that risk level.

### **Guideline (5) — Treatment of Requirements that Co-mingle More Than One Obligation**

Where a single Requirement co-mingles a higher risk reliability objective and a lesser risk reliability objective, the VRF assignment for such Requirements must not be watered down to reflect the lower risk level associated with the less important objective of the Reliability Standard.

The following discussion addresses how the SDT considered FERC’s VRF Guidelines 2 through 5. The team did not address Guideline 1 directly because of an apparent conflict between Guidelines 1 and 4. Whereas Guideline 1 identifies a list of topics that encompass nearly all topics within NERC’s Reliability Standards and implies that these requirements should be assigned a “High” VRF, Guideline 4 directs assignment of VRFs based on the impact of a specific requirement to the reliability of the system. The SDT believes that Guideline 4 is reflective of the intent of VRFs in the first instance and therefore concentrated its approach on the reliability impact of the requirements.

#### ***VRF for EOP-004-2:***

There are three requirements in EOP-004-2. Requirement R1 was assigned a Lower VRF while Requirements R2 and R3 were assigned a Medium VRF.

#### ***VRF for EOP-004-2, Requirements R1:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The Requirement specifies which entities are required to have processes for recognition of events and for communicating with other entities. This Requirement is the only administrative Requirement within the Standard. The VRF is only applied at the Requirement level. FERC’s Guideline 3 — Consistency among Reliability Standards. This requirement calls for an entity to have processes for recognition of events and communicating with other entities. This requirement is administrative in nature and deals with the means to report events after the fact. All event reporting requirements in Attachment 1 are for 24 hours after recognition that an event has occurred. The current approved VRFs for EOP-004-1 are

all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program.

- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. Failure to have an event reporting Operating Plan is not likely to directly affect the electrical state or the capability of the bulk electric system. Development of the Operating Plan is a requirement that is administrative in nature and is in a planning time frame that, if violated, would not, under emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system.. Therefore this requirement was assigned a Lower VRF.
- FERC’s Guideline 5 — Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R1 contains only one objective which is to have an Operating Plan with two distinct processes. Since the requirement is to have an Operating Plan, only one VRF was assigned.

***VRF for EOP-004-2, Requirement R2:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to implement its Operating Plan and is assigned a Medium VRF. There is one other similar Requirement in this Standard which specifies an annual validation of the information contained in the Operating Plan (R3). Both of these Requirements are assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R2 is a requirement for entities to report events using the process for recognition of events per Attachment 1. Failure to report events within 24 hours is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not report events. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R2 mandates that Responsible Entities implement their Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to notify another entity of the event failure, but there is a slight chance that it could occur. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R2 addresses a single objective and has a single VRF.



**VRF for EOP-004-2, Requirement R3:**

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to perform an annual validation of the information contained in the Operating Plan and is assigned a Medium VRF. There is one other similar Requirement in this Standard which specifies that the Responsible Entity implement its Operating Plan (R2).. Both of these Requirements is assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R3 is a requirement for entities to perform an annual validation of the information contained of the information in the Operating Plan. Failure to perform an annual validation of the information contained in the Operating Plan is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not perform an annual test of the Operating Plan and it is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R3 mandates that Responsible Entities perform an annual validation of the information contained of the information in the Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to perform an annual test of the Operating Plan, but there is a slight chance that it could occur if the Operating Plan is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R3 addresses a single objective and has a single VRF.

**Justification for Assignment of Violation Severity Levels for EOP-004-2:**

In developing the VSLs for the EOP-004-2 standard, the SDT anticipated the evidence that would be reviewed during an audit, and developed its VSLs based on the noncompliance an auditor may find during a typical audit. The SDT based its assignment of VSLs on the following NERC criteria:

Lower	Moderate	High	Severe
<p>Missing a minor element (or a small percentage) of the required performance</p> <p>The performance or product measured has significant value as it almost meets the full intent of the requirement.</p>	<p>Missing at least one significant element (or a moderate percentage) of the required performance.</p> <p>The performance or product measured still has significant value in meeting the intent of the requirement.</p>	<p>Missing more than one significant element (or is missing a high percentage) of the required performance or is missing a single vital component.</p> <p>The performance or product has limited value in meeting the intent of the requirement.</p>	<p>Missing most or all of the significant elements (or a significant percentage) of the required performance.</p> <p>The performance measured does not meet the intent of the requirement or the product delivered cannot be used in meeting the intent of the requirement.</p>

FERC’s VSL guidelines are presented below, followed by an analysis of whether the VSLs proposed for each requirement in EOP-004-2 meet the FERC Guidelines for assessing VSLs:

**Guideline 1: Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance**

Compare the VSLs to any prior levels of non-compliance and avoid significant changes that may encourage a lower level of compliance than was required when levels of non-compliance were used.

**Guideline 2: Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties**

A violation of a “binary” type requirement must be a “Severe” VSL.

Do not use ambiguous terms such as “minor” and “significant” to describe noncompliant performance.

**Guideline 3: Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement**

VSLs should not expand on what is required in the requirement.

**Guideline 4: Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations**

. . . unless otherwise stated in the requirement, each instance of non-compliance with a requirement is a separate violation. Section 4 of the Sanction Guidelines states that assessing penalties on a per violation per day basis is the “default” for penalty calculations.

**VSLs for EOP-004-2 Requirements R1:**

R#	Compliance with NERC's VSL Guidelines	<p>Guideline 1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>Guideline 2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 3</p> <p>Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>Guideline 4</p> <p>Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>
<b>R1</b>	Meets NERC's VSL guidelines. The requirement calls for the entity to have an Operating Plan and is binary in nature. The VSL is therefore set to "Severe".	The proposed requirement is a revision of CIP-001-1, R1-R4, and EOP-004-1, R2. The Requirement has no Parts and is binary in nature. The binary VSL does not lower the current level of Compliance.	The proposed VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed binary VSL uses the same terminology as used in the associated requirement, and is, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R2:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R2</b>	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a revision of EOP-004-1, R3. There is only a Severe VSL for that requirement. However, the reporting of events is based on timing intervals listed in EOP-004 Attachment 1. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a report is not submitted, then the VSL is Severe. This maintains the current VSL.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R3:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
R3	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a new Requirement. The test of the Operating Plan is based on the calendar year. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a test is not performed, then the VSL is Severe.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

### A. Introduction

1. **Title:** **Sabotage Reporting**
2. **Number:** CIP-001-2a
3. **Purpose:** Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Transmission Owners (only in ERCOT Region).
  - 4.7. Generator Owners (only in ERCOT Region).
5. **Effective Date:** ERCOT Regional Variance will be effective the first day of the first calendar quarter after applicable regulatory approval.

### B. Requirements

- R1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- R2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- R3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- R4.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

### C. Measures

- M1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

Regional Reliability Organizations shall be responsible for compliance monitoring.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to verify compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Reliability Coordinator, Transmission Operator, Generator Operator, Distribution Provider, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

#### **1.4. Additional Compliance Information**

None.

### **2. Levels of Non-Compliance:**

**2.1. Level 1:** There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

- 2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).



- 2.1.2 Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).
- 2.1.3 Has not established communications contacts, as specified in R4.
- 2.2. **Level 2:** Not applicable.
- 2.3. **Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).
- 2.4. **Level 4:** Not applicable.

## **E. ERCOT Interconnection-wide Regional Variance**

### **Requirements**

- EA.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- EA.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- EA.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- EA.4.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall establish communications contacts with local Federal Bureau of Investigation (FBI) officials and develop reporting procedures as appropriate to their circumstances.

### **Measures**

- M.A.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement EA1.
- M.A.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements EA2 and EA3.
- M.A.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to, procedures, policies, a letter of understanding, communication records,

or other equivalent evidence that will be used to confirm that it has established communications contacts with the local FBI officials to communicate sabotage events (Requirement EA4).

**Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Enforcement Authority**

Regional Entity shall be responsible for compliance monitoring.

**1.2. Data Retention**

Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Amended
1	April 4, 2007	Regulatory Approval — Effective Date	New
1a	February 16, 2010	Added Appendix 1 — Interpretation of R2 approved by the NERC Board of Trustees	Addition
1a	February 2, 2011	Interpretation of R2 approved by FERC on February 2, 2011	Same addition
	June 10, 2010	TRE regional ballot approved variance	By Texas RE
	August 24, 2010	Regional Variance Approved by Texas RE Board of Directors	
2a	February 16, 2011	Approved by NERC Board of Trustees	

**Standard CIP-001-2a— Sabotage Reporting**

---

2a	August 2, 2011	FERC Order issued approving Texas RE Regional Variance	
----	----------------	--	--

Appendix 1

<b>Requirement Number and Text of Requirement</b>
<p><b>CIP-001-1:</b></p> <p><b>R2.</b> Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.</p>
<b>Question</b>
<p>Please clarify what is meant by the term, “appropriate parties.” Moreover, who within the Interconnection hierarchy deems parties to be appropriate?</p>
<b>Response</b>
<p>The drafting team interprets the phrase “appropriate parties in the Interconnection” to refer collectively to entities with whom the reporting party has responsibilities and/or obligations for the communication of physical or cyber security event information. For example, reporting responsibilities result from NERC standards IRO-001 Reliability Coordination — Responsibilities and Authorities, COM-002-2 Communication and Coordination, and TOP-001 Reliability Responsibilities and Authorities, among others. Obligations to report could also result from agreements, processes, or procedures with other parties, such as may be found in operating agreements and interconnection agreements.</p> <p>The drafting team asserts that those entities to which communicating sabotage events is appropriate would be identified by the reporting entity and documented within the procedure required in CIP-001-1 Requirement R2.</p> <p>Regarding “who within the Interconnection hierarchy deems parties to be appropriate,” the drafting team knows of no interconnection authority that has such a role.</p>

## A. Introduction

1. **Title:** **Disturbance Reporting**
2. **Number:** EOP-004-1
3. **Purpose:** Disturbances or unusual occurrences that jeopardize the operation of the Bulk Electric System, or result in system equipment damage or customer interruptions, need to be studied and understood to minimize the likelihood of similar events in the future.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Regional Reliability Organizations.
5. **Effective Date:** January 1, 2007

## B. Requirements

- R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.
- R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.
- R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.
  - R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until some time after they occur shall be reported within 24 hours of being recognized.
  - R3.2. Applicable reporting forms are provided in Attachments 1-EOP-004 and 2-EOP-004.
  - R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that

time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.

- R3.4.** If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.
- R4.** When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.
- R5.** The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.

### C. Measures

- M1.** The Regional Reliability Organization shall have and provide upon request as evidence, its current regional reporting procedure that is used to facilitate preparation of preliminary and final disturbance reports. (Requirement 1)
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, the preliminary report, computer printouts, operator logs, or other equivalent evidence that will be used to confirm that it prepared and delivered the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1.
- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to confirm that it provided information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours. (Requirement 3.3)

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

NERC shall be responsible for compliance monitoring of the Regional Reliability Organizations.

Regional Reliability Organizations shall be responsible for compliance monitoring of Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load-serving Entities.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Regional Reliability Organization shall have its current, in-force, regional reporting procedure as evidence of compliance. (Measure 1)

Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that is either involved in a Bulk Electric System disturbance or has a reportable incident shall keep data related to the incident for a year from the event or for the duration of any regional investigation, whichever is longer. (Measures 2 through 4)

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**1.4. Additional Compliance Information**

See Attachments:

- EOP-004 Disturbance Reporting Form
- Table 1 EOP-004

**2. Levels of Non-Compliance for a Regional Reliability Organization**

**2.1. Level 1:** Not applicable.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Not applicable.

**2.4. Level 4:** No current procedure to facilitate preparation of preliminary and final disturbance reports as specified in R1.

**3. Levels of Non-Compliance for a Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load- Serving Entity:**

**3.1. Level 1:** There shall be a level one non-compliance if any of the following conditions exist:

**3.1.1** Failed to prepare and deliver the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1

**3.1.2** Failed to provide disturbance information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours as specified in R3.3

**3.1.3** Failed to prepare a final report within 60 days as specified in R3.4

**3.2. Level 2:** Not applicable.

**3.3. Level 3:** Not applicable

**3.4. Level 4:** Not applicable.

**E. Regional Differences**

None identified.

**Version History**

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	May 23, 2005	Fixed reference to attachments 1-EOP-004-0 and 2-EOP-004-0, Changed chart title 1-FAC-004-0 to 1-EOP-004-0, Fixed title of Table 1 to read 1-EOP-004-0, and fixed font.	Errata
0	July 6, 2005	Fixed email in Attachment 1-EOP-004-0 from <a href="mailto:info@nerc.com">info@nerc.com</a> to <a href="mailto:esisac@nerc.com">esisac@nerc.com</a> .	Errata



0	July 26, 2005	Fixed Header on page 8 to read EOP-004-0	Errata
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised

## **Attachment 1-EOP-004 NERC Disturbance Report Form**

### **Introduction**

These disturbance reporting requirements apply to all Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load Serving Entities, and provide a common basis for all NERC disturbance reporting. The entity on whose system a reportable disturbance occurs shall notify NERC and its Regional Reliability Organization of the disturbance using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. Reports can be sent to NERC via email ([esisac@nerc.com](mailto:esisac@nerc.com)) by facsimile (609-452-9550) using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. If a disturbance is to be reported to the U.S. Department of Energy also, the responding entity may use the DOE reporting form when reporting to NERC. Note: All Emergency Incident and Disturbance Reports (Schedules 1 and 2) sent to DOE shall be simultaneously sent to NERC, preferably electronically at [esisac@nerc.com](mailto:esisac@nerc.com).

The NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports are to be made for any of the following events:

1. The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:
  - a. Modification of operating procedures.
  - b. Modification of equipment (e.g. control systems or special protection systems) to prevent reoccurrence of the event.
  - c. Identification of valuable lessons learned.
  - d. Identification of non-compliance with NERC standards or policies.
  - e. Identification of a disturbance that is beyond recognized criteria, i.e. three-phase fault with breaker failure, etc.
  - f. Frequency or voltage going below the under-frequency or under-voltage load shed points.
2. The occurrence of an interconnected system separation or system islanding or both.
3. Loss of generation by a Generator Operator, Balancing Authority, or Load-Serving Entity — 2,000 MW or more in the Eastern Interconnection or Western Interconnection and 1,000 MW or more in the ERCOT Interconnection.
4. Equipment failures/system operational actions which result in the loss of firm system demands for more than 15 minutes, as described below:
  - a. Entities with a previous year recorded peak demand of more than 3,000 MW are required to report all such losses of firm demands totaling more than 300 MW.
  - b. All other entities are required to report all such losses of firm demands totaling more than 200 MW or 50% of the total customers being supplied immediately prior to the incident, whichever is less.
5. Firm load shedding of 100 MW or more to maintain the continuity of the bulk electric system.

6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in:
  - a. Sustained voltage excursions equal to or greater than  $\pm 10\%$ , or
  - b. Major damage to power system components, or
  - c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance as defined by steps 1 through 5 above.
7. An Interconnection Reliability Operating Limit (IROL) violation as required in reliability standard TOP-007.
8. Any event that the Operating Committee requests to be submitted to Disturbance Analysis Working Group (DAWG) for review because of the nature of the disturbance and the insight and lessons the electricity supply and delivery industry could learn.

## NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report

Check here if this is an Interconnection Reliability Operating Limit (IROL) violation report.

1.	Organization filing report.		
2.	Name of person filing report.		
3.	Telephone number.		
4.	Date and time of disturbance. Date:(mm/dd/yy) Time/Zone:		
5.	Did the disturbance originate in your system?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
6.	Describe disturbance including: cause, equipment damage, critical services interrupted, system separation, key scheduled and actual flows prior to disturbance and in the case of a disturbance involving a special protection or remedial action scheme, what action is being taken to prevent recurrence.		
7.	Generation tripped.  MW Total List generation tripped		
8.	Frequency. Just prior to disturbance (Hz): Immediately after disturbance (Hz max.): Immediately after disturbance (Hz min.):		
9.	List transmission lines tripped (specify voltage level of each line).		
10.	Demand tripped (MW): Number of affected Customers:	FIRM	INTERRUPTIBLE

	Demand lost (MW-Minutes):		
11.	Restoration time.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		

## **Attachment 2-EOP-004**

### **U.S. Department of Energy Disturbance Reporting Requirements**

#### **Introduction**

The U.S. Department of Energy (DOE), under its relevant authorities, has established mandatory reporting requirements for electric emergency incidents and disturbances in the United States. DOE collects this information from the electric power industry on Form EIA-417 to meet its overall national security and Federal Energy Management Agency's Federal Response Plan (FRP) responsibilities. DOE will use the data from this form to obtain current information regarding emergency situations on U.S. electric energy supply systems. DOE's Energy Information Administration (EIA) will use the data for reporting on electric power emergency incidents and disturbances in monthly EIA reports. In addition, the data may be used to develop legislative recommendations, reports to the Congress and as a basis for DOE investigations following severe, prolonged, or repeated electric power reliability problems.

Every Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity must use this form to submit mandatory reports of electric power system incidents or disturbances to the DOE Operations Center, which operates on a 24-hour basis, seven days a week. All other entities operating electric systems have filing responsibilities to provide information to the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity when necessary for their reporting obligations and to file form EIA-417 in cases where these entities will not be involved. EIA requests that it be notified of those that plan to file jointly and of those electric entities that want to file separately.

Special reporting provisions exist for those electric utilities located within the United States, but for whom Reliability Coordinator oversight responsibilities are handled by electrical systems located across an international border. A foreign utility handling U.S. Balancing Authority responsibilities, may wish to file this information voluntarily to the DOE. Any U.S.-based utility in this international situation needs to inform DOE that these filings will come from a foreign-based electric system or file the required reports themselves.

Form EIA-417 must be submitted to the DOE Operations Center if any one of the following applies (see Table 1-EOP-004-0 — Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies):

1. Uncontrolled loss of 300 MW or more of firm system load for more than 15 minutes from a single incident.
2. Load shedding of 100 MW or more implemented under emergency operational policy.
3. System-wide voltage reductions of 3 percent or more.
4. Public appeal to reduce the use of electricity for purposes of maintaining the continuity of the electric power system.
5. Actual or suspected physical attacks that could impact electric power system adequacy or reliability; or vandalism, which target components of any security system. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.

6. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.
7. Fuel supply emergencies that could impact electric power system adequacy or reliability.
8. Loss of electric service to more than 50,000 customers for one hour or more.
9. Complete operational failure or shut-down of the transmission and/or distribution electrical system.

The initial DOE Emergency Incident and Disturbance Report (form EIA-417 – Schedule 1) shall be submitted to the DOE Operations Center within 60 minutes of the time of the system disruption. Complete information may not be available at the time of the disruption. However, provide as much information as is known or suspected at the time of the initial filing. If the incident is having a critical impact on operations, a telephone notification to the DOE Operations Center (202-586-8100) is acceptable, pending submission of the completed form EIA-417. Electronic submission via an on-line web-based form is the preferred method of notification. However, electronic submission by facsimile or email is acceptable.

An updated form EIA-417 (Schedule 1 and 2) is due within 48 hours of the event to provide complete disruption information. Electronic submission via facsimile or email is the preferred method of notification. Detailed DOE Incident and Disturbance reporting requirements can be found at: [http://www.eia.doe.gov/cneaf/electricity/page/form\\_417.html](http://www.eia.doe.gov/cneaf/electricity/page/form_417.html).

<b>Table 1-EOP-004-0</b>				
<b>Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies</b>				
<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Uncontrolled loss of Firm System Load	$\geq 300$ MW – 15 minutes or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>2</b>	Load Shedding	$\geq 100$ MW under emergency operational policy	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>3</b>	Voltage Reductions	3% or more – applied system-wide	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>4</b>	Public Appeals	Emergency conditions to reduce demand	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>5</b>	Physical sabotage, terrorism or vandalism	On physical security systems – suspected or real	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>6</b>	Cyber sabotage, terrorism or vandalism	If the attempt is believed to have or did happen	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>7</b>	Fuel supply emergencies	Fuel inventory or hydro storage levels $\leq 50\%$ of normal	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>8</b>	Loss of electric service	$\geq 50,000$ for 1 hour or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>9</b>	Complete operation failure of electrical system	If isolated or interconnected electrical systems suffer total electrical system collapse	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
All DOE EIA-417 Schedule 1 reports are to be filed within 60-minutes after the start of an incident or disturbance				
All DOE EIA-417 Schedule 2 reports are to be filed within 48-hours after the start of an incident or disturbance				



***All entities required to file a DOE EIA-417 report (Schedule 1 & 2) shall send a copy of these reports to NERC simultaneously, but no later than 24 hours after the start of the incident or disturbance.***

<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Loss of major system component	Significantly affects integrity of interconnected system operations	NERC Prelim Final report	24 hour 60 day
<b>2</b>	Interconnected system separation or system islanding	Total system shutdown Partial shutdown, separation, or islanding	NERC Prelim Final report	24 hour 60 day
<b>3</b>	Loss of generation	$\geq 2,000$ – Eastern Interconnection $\geq 2,000$ – Western Interconnection $\geq 1,000$ – ERCOT Interconnection	NERC Prelim Final report	24 hour 60 day
<b>4</b>	Loss of firm load $\geq 15$ -minutes	Entities with peak demand $\geq 3,000$ : loss $\geq 300$ MW All others $\geq 200$ MW or 50% of total demand	NERC Prelim Final report	24 hour 60 day
<b>5</b>	Firm load shedding	$\geq 100$ MW to maintain continuity of bulk system	NERC Prelim Final report	24 hour 60 day
<b>6</b>	System operation or operation actions resulting in:	<ul style="list-style-type: none"> <li>• Voltage excursions <math>\geq 10\%</math></li> <li>• Major damage to system components</li> <li>• Failure, degradation, or misoperation of SPS</li> </ul>	NERC Prelim Final report	24 hour 60 day
<b>7</b>	IROL violation	Reliability standard TOP-007.	NERC Prelim Final report	72 hour 60 day
<b>8</b>	As requested by ORS Chairman	Due to nature of disturbance & usefulness to industry (lessons learned)	NERC Prelim Final report	24 hour 60 day

All NERC Operating Security Limit and Preliminary Disturbance reports will be filed within 24 hours after the start of the incident. If an entity must file a DOE EIA-417 report on an incident, which requires a NERC Preliminary report, the Entity may use the DOE EIA-417 form for both DOE and NERC reports.

***Any entity reporting a DOE or NERC incident or disturbance has the responsibility to also notify its Regional Reliability Organization.***

# Standards Announcement

## Project 2009-01 Disturbance and Sabotage Reporting

Formal Comment Period Open: August 29 – September 27, 2012

Upcoming:

Successive Ballot and Non-binding Poll: September 18 – September 27, 2012

### [Now Available](#)

A formal comment period for **EOP-004-2 – Event Reporting** is open through **8 p.m. Eastern on Thursday, September 27, 2012**

The drafting team has made the following changes to the standard:

Most of the language contained in the “Background” Section was moved to the “Guidelines and Technical Basis” Section. Minor language changes were made to the measures and the data retention section. Attachment 2 was revised to list events in the same order in which they appear in Attachment 1.

Requirement R1 was revised to include the Parts in the main body of the Requirement. The Measure and VSLs were updated accordingly.

Following review of the industry’s comments, the SDT has re-examined the FERC Directive in Order 693 and has dropped both R3 and R4 as they were written and established a new Requirement R3 to have the Registered Entity “validate” the contact information in the contact list(s) they may have for the events applicable to them. This validation needs to be performed each calendar year to ensure that the list(s) have current and up-to-date contact data.

A redline version of EOP-004-2 is not posted because EOP-004-2 is a consolidation of CIP-001-2a and EOP-004-1. A redline version of EOP-004-2 would be difficult to follow so clean versions of CIP-001-2a and EOP-004-1 have been posted as a convenience.

### **Instructions for Commenting**

A formal comment period is open through **8 p.m. Eastern on Thursday, September 27, 2012**. Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the [project page](#).

**Please read carefully:** All stakeholders with comments (both members of the ballot pool as well as other stakeholders, including groups such as trade associations and committees) must submit comments through the [electronic comment form](#). During the ballot window, balloters who wish to submit comments with their ballot *may no longer enter comments on the balloting screen*, but may still enter the comments through the electronic comment form. **Balloters who wish to express support for comments submitted by another entity or group will have an opportunity to enter that information and are not required to answer any other questions.**

### Next Steps

A successive ballot of EOP-004-2 and non-binding poll of the associated VRFs and VSLs will be conducted beginning on Tuesday, September 18, 2012 through 8 p.m. Eastern on Thursday, September 27, 2012.

### Background

The DSR SDT has developed EOP-004-2 to replace the current mandatory and enforceable EOP-004-1 and CIP-001-1a standards. The reporting obligations under EOP-004-2 serve to provide input to the NERC Events Analysis Program. Analysis of events is not required under the proposed standard and any analysis or investigation will fall under the Event Analysis Program under the NERC Rules of Procedure.

Additional information is available on the [project page](#).

### Standards Process

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd. NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)

# Standards Announcement

## Project 2009-01 Disturbance and Sabotage Reporting

Formal Comment Period Open: August 29 – September 27, 2012

Upcoming:

Successive Ballot and Non-binding Poll: September 18 – September 27, 2012

### [Now Available](#)

A formal comment period for **EOP-004-2 – Event Reporting** is open through **8 p.m. Eastern on Thursday, September 27, 2012**

The drafting team has made the following changes to the standard:

Most of the language contained in the “Background” Section was moved to the “Guidelines and Technical Basis” Section. Minor language changes were made to the measures and the data retention section. Attachment 2 was revised to list events in the same order in which they appear in Attachment 1.

Requirement R1 was revised to include the Parts in the main body of the Requirement. The Measure and VSLs were updated accordingly.

Following review of the industry’s comments, the SDT has re-examined the FERC Directive in Order 693 and has dropped both R3 and R4 as they were written and established a new Requirement R3 to have the Registered Entity “validate” the contact information in the contact list(s) they may have for the events applicable to them. This validation needs to be performed each calendar year to ensure that the list(s) have current and up-to-date contact data.

A redline version of EOP-004-2 is not posted because EOP-004-2 is a consolidation of CIP-001-2a and EOP-004-1. A redline version of EOP-004-2 would be difficult to follow so clean versions of CIP-001-2a and EOP-004-1 have been posted as a convenience.

### **Instructions for Commenting**

A formal comment period is open through **8 p.m. Eastern on Thursday, September 27, 2012**. Please use this [electronic form](#) to submit comments. If you experience any difficulties in using the electronic form, please contact Monica Benson at [monica.benson@nerc.net](mailto:monica.benson@nerc.net). An off-line, unofficial copy of the comment form is posted on the [project page](#).

**Please read carefully:** All stakeholders with comments (both members of the ballot pool as well as other stakeholders, including groups such as trade associations and committees) must submit comments through the [electronic comment form](#). During the ballot window, balloters who wish to submit comments with their ballot *may no longer enter comments on the balloting screen*, but may still enter the comments through the electronic comment form. **Balloters who wish to express support for comments submitted by another entity or group will have an opportunity to enter that information and are not required to answer any other questions.**

### Next Steps

A successive ballot of EOP-004-2 and non-binding poll of the associated VRFs and VSLs will be conducted beginning on Tuesday, September 18, 2012 through 8 p.m. Eastern on Thursday, September 27, 2012.

### Background

The DSR SDT has developed EOP-004-2 to replace the current mandatory and enforceable EOP-004-1 and CIP-001-1a standards. The reporting obligations under EOP-004-2 serve to provide input to the NERC Events Analysis Program. Analysis of events is not required under the proposed standard and any analysis or investigation will fall under the Event Analysis Program under the NERC Rules of Procedure.

Additional information is available on the [project page](#).

### Standards Process

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd. NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)

# Standards Announcement

## Project 2009-01 Disturbance and Sabotage Reporting

### Successive Ballot and Non-Binding Poll Results

#### [Now Available](#)

A successive ballot of **EOP-004-2 – Event Reporting** and a non-binding poll of the associated VRFs/VSLs concluded on Thursday, September 27, 2012.

Voting statistics for each ballot are listed below, and the [Ballots Results](#) page provides a link to the detailed results.

#### Updated Results

Ballot Results	Non-binding Poll Results
Quorum: 78.54%	Quorum: 72.59%
Approval: 63.40%	Supportive Opinions: 63.05%

#### Next Steps

The drafting team is considering the comments received from the comment and ballot periods.

#### Background

The DSR SDT has developed EOP-004-2 to replace the current mandatory and enforceable EOP-004-1 and CIP-001-1a standards. The reporting obligations under EOP-004-2 serve to provide input to the NERC Events Analysis Program. Analysis of events is not required under the proposed standard and any analysis or investigation will fall under the Event Analysis Program under the NERC Rules of Procedure.

Additional information is available on the [project page](#).

**Standards Process**

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Process Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd. NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)

User Name

Password

Log in

Register

- Ballot Pools
- Current Ballots
- Ballot Results
- Registered Ballot Body
- Proxy Voters

Home Page

Ballot Results	
<b>Ballot Name:</b>	Project 2009-01 Successive Ballot DSR
<b>Ballot Period:</b>	9/18/2012 - 9/27/2012
<b>Ballot Type:</b>	Initial
<b>Total # Votes:</b>	333
<b>Total Ballot Pool:</b>	424
<b>Quorum:</b>	<b>78.54 % The Quorum has been reached</b>
<b>Weighted Segment Vote:</b>	63.40 %
<b>Ballot Results:</b>	<b>The drafting team will review comments received.</b>

Summary of Ballot Results									
Segment	Ballot Pool	Segment Weight	Affirmative		Negative		Abstain # Votes	No Vote	
			# Votes	Fraction	# Votes	Fraction			
1 - Segment 1.	104	1	46	0.622	28	0.378	10	20	
2 - Segment 2.	11	0.7	3	0.3	4	0.4	2	2	
3 - Segment 3.	108	1	45	0.57	34	0.43	8	21	
4 - Segment 4.	37	1	20	0.714	8	0.286	3	6	
5 - Segment 5.	91	1	44	0.698	19	0.302	7	21	
6 - Segment 6.	53	1	23	0.697	10	0.303	4	16	
7 - Segment 7.	0	0	0	0	0	0	0	0	
8 - Segment 8.	8	0.6	5	0.5	1	0.1	1	1	
9 - Segment 9.	4	0.2	0	0	2	0.2	0	2	
10 - Segment 10.	8	0.6	4	0.4	2	0.2	0	2	
<b>Totals</b>	<b>424</b>	<b>7.1</b>	<b>190</b>	<b>4.501</b>	<b>108</b>	<b>2.599</b>	<b>35</b>	<b>91</b>	

Individual Ballot Pool Results				
Segment	Organization	Member	Ballot	Comments
1	Ameren Services	Kirit Shah	Affirmative	
1	American Electric Power	Paul B. Johnson		
1	American Transmission Company, LLC	Andrew Z Pusztai	Negative	
1	Arizona Public Service Co.	Robert Smith	Affirmative	
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative	
1	Austin Energy	James Armke	Affirmative	
1	Avista Corp.	Scott J Kinney	Abstain	
1	Balancing Authority of Northern California	Kevin Smith	Affirmative	



1	Baltimore Gas & Electric Company	Gregory S Miller	Affirmative
1	BC Hydro and Power Authority	Patricia Robertson	Abstain
1	Beaches Energy Services	Joseph S Stonecipher	Negative
1	Black Hills Corp	Eric Egge	
1	Bonneville Power Administration	Donald S. Watkins	Negative
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey	Negative
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Negative
1	Central Maine Power Company	Joseph Turano Jr.	Affirmative
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Negative
1	Clark Public Utilities	Jack Stamper	Negative
1	Colorado Springs Utilities	Paul Morland	Affirmative
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Affirmative
1	CPS Energy	Richard Castrejana	Affirmative
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative
1	Dayton Power & Light Co.	Hertzel Shamash	
1	Deseret Power	James Tucker	
1	Dominion Virginia Power	Michael S Crowley	Negative
1	Duke Energy Carolina	Douglas E. Hils	Negative
1	East Kentucky Power Coop.	George S. Carruba	Negative
1	Empire District Electric Co.	Ralph F Meyer	Negative
1	Entergy Services, Inc.	Edward J Davis	
1	FirstEnergy Corp.	William J Smith	Affirmative
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton	Affirmative
1	Florida Power & Light Co.	Mike O'Neil	Negative
1	Gainesville Regional Utilities	Luther E. Fair	
1	Georgia Transmission Corporation	Jason Snodgrass	Affirmative
1	Grand River Dam Authority	James M Stafford	Affirmative
1	Great River Energy	Gordon Pietsch	
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Negative
1	Hydro One Networks, Inc.	Ajay Garg	Negative
1	Hydro-Quebec TransEnergie	Bernard Pelletier	
1	Idaho Power Company	Ronald D Schellberg	
1	Imperial Irrigation District	Tino Zaragoza	Abstain
1	International Transmission Company Holdings Corp	Michael Moltane	Affirmative
1	JEA	Ted Hobson	Affirmative
1	Kansas City Power & Light Co.	Michael Gammon	
1	Keys Energy Services	Stanley T Rzad	
1	Lakeland Electric	Larry E Watt	Affirmative
1	Lee County Electric Cooperative	John W Delucca	Affirmative
1	Lincoln Electric System	Doug Bantam	Affirmative
1	Los Angeles Department of Water & Power	Ly M Le	
1	Lower Colorado River Authority	Martyn Turner	Affirmative
1	Manitoba Hydro	Joe D Petaski	
1	MEAG Power	Danny Dees	Affirmative
1	MidAmerican Energy Co.	Terry Harbour	Affirmative
1	Minnkota Power Coop. Inc.	Richard Burt	Affirmative
1	National Grid	Saurabh Saksena	Affirmative
1	Nebraska Public Power District	Cole C Brodine	Negative
1	New Brunswick Power Transmission Corporation	Randy MacDonald	Negative
1	New York Power Authority	Arnold J. Schuff	
1	New York State Electric & Gas Corp.	Raymond P Kinney	
1	Northeast Utilities	David Boguslawski	Abstain
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative
1	NorthWestern Energy	John Canavan	Abstain
1	Ohio Valley Electric Corp.	Robert Matthey	Negative
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Negative
1	Omaha Public Power District	Doug Peterchuck	Affirmative
1	Oncor Electric Delivery	Brenda Pulis	Negative
1	Orlando Utilities Commission	Brad Chase	Abstain
1	PacifiCorp	Ryan Millard	Affirmative
1	PECO Energy	Ronald Schloendorn	Abstain
1	Platte River Power Authority	John C. Collins	Affirmative
1	Portland General Electric Co.	John T Walker	Affirmative
1	Potomac Electric Power Co.	David Thorne	Affirmative


1	PowerSouth Energy Cooperative	Larry D Avery	Affirmative
1	PPL Electric Utilities Corp.	Brenda L Truhe	Affirmative
1	Progress Energy Carolinas	Brett A. Koelsch	Abstain
1	Public Service Company of New Mexico	Laurie Williams	Abstain
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Affirmative
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel	Affirmative
1	Public Utility District No. 2 of Grant County	Kyle M. Hussey	
1	Puget Sound Energy, Inc.	Denise M Lietz	Negative
1	Raj Rana	Rajendrasinh D Rana	Abstain
1	Rochester Gas and Electric Corp.	John C. Allen	Affirmative
1	Sacramento Municipal Utility District	Tim Kelley	Affirmative
1	Salmon River Electric Cooperative	Kathryn J Spence	Affirmative
1	Salt River Project	Robert Kondziolka	Affirmative
1	Santee Cooper	Terry L Blackwell	Negative
1	SCE&G	Henry Delk, Jr.	
1	Seattle City Light	Pawel Krupa	Affirmative
1	Sho-Me Power Electric Cooperative	Denise Stevens	Affirmative
1	Sierra Pacific Power Co.	Rich Salgo	Affirmative
1	Snohomish County PUD No. 1	Long T Duong	Affirmative
1	South California Edison Company	Steven Mavis	Negative
1	Southern Company Services, Inc.	Robert A. Schaffeld	Negative
1	Southern Illinois Power Coop.	William Hutchison	
1	Southwest Transmission Cooperative, Inc.	James Jones	Negative
1	Sunflower Electric Power Corporation	Noman Lee Williams	Negative
1	Tampa Electric Co.	Beth Young	
1	Tennessee Valley Authority	Larry G Akens	Negative
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative
1	Tucson Electric Power Co.	John Tolo	
1	United Illuminating Co.	Jonathan Appelbaum	Affirmative
1	Westar Energy	Allen Klassen	Negative
1	Western Area Power Administration	Brandy A Dunn	Affirmative
1	Xcel Energy, Inc.	Gregory L Pieper	Negative
2	Alberta Electric System Operator	Mark B Thompson	Affirmative
2	BC Hydro	Venkataramakrishnan Vinnakota	Abstain
2	California ISO	Rich Vine	Abstain
2	Electric Reliability Council of Texas, Inc.	Charles B Manning	Affirmative
2	Independent Electricity System Operator	Barbara Constantinescu	Affirmative
2	ISO New England, Inc.	Kathleen Goodman	Negative
2	Midwest ISO, Inc.	Marie Knox	
2	New Brunswick System Operator	Alden Briggs	Negative
2	New York Independent System Operator	Gregory Campoli	
2	PJM Interconnection, L.L.C.	Tom Bowe	Negative
2	Southwest Power Pool, Inc.	Charles H. Yeung	Negative
3	AEP	Michael E Deloach	Negative
3	Alabama Power Company	Richard J. Mandes	Negative
3	Alameda Municipal Power	Douglas Draeger	Affirmative
3	Ameren Services	Mark Peters	Affirmative
3	American Public Power Association	Nathan Mitchell	Abstain
3	Anaheim Public Utilities Dept.	Kelly Nguyen	
3	APS	Steven Norris	Affirmative
3	Arkansas Electric Cooperative Corporation	Philip Huff	Affirmative
3	Atlantic City Electric Company	NICOLE BUCKMAN	Affirmative
3	BC Hydro and Power Authority	Pat G. Harrington	Abstain
3	Blachly-Lane Electric Co-op	Bud Tracy	Negative
3	Bonneville Power Administration	Rebecca Berdahl	Negative
3	Central Electric Cooperative, Inc. (Redmond, Oregon)	Dave Markham	Negative
3	Central Lincoln PUD	Steve Alexanderson	Negative
3	City of Alexandria	Michael Marcotte	
3	City of Austin dba Austin Energy	Andrew Gallo	Affirmative
3	City of Bartow, Florida	Matt Culverhouse	
3	City of Clewiston	Lynne Mila	Affirmative
3	City of Farmington	Linda R Jacobson	Affirmative
3	City of Garland	Ronnie C Hoeinghaus	Abstain
3	City of Green Cove Springs	Gregg R Griffin	Abstain
3	City of Palo Alto	Eric R Scott	Affirmative

3	City of Redding	Bill Hughes	Affirmative	
3	Clatskanie People's Utility District	Brian Fawcett		
3	Clearwater Power Co.	Dave Hagen	Negative	
3	Cleco Corporation	Michelle A Corley	Affirmative	
3	Colorado Springs Utilities	Charles Morgan	Affirmative	
3	ComEd	Bruce Krawczyk	Affirmative	
3	Consolidated Edison Co. of New York	Peter T Yost	Affirmative	
3	Constellation Energy	CJ Ingersoll	Abstain	
3	Consumers Energy	Richard Blumenstock	Affirmative	
3	Consumers Power Inc.	Roman Gillen	Negative	
3	Coos-Curry Electric Cooperative, Inc	Roger Meader	Negative	
3	Cowlitz County PUD	Russell A Noble	Negative	
3	CPS Energy	Jose Escamilla	Affirmative	
3	Delmarva Power & Light Co.	Michael R. Mayer	Affirmative	
3	Detroit Edison Company	Kent Kujala	Negative	
3	Dominion Resources Services	Michael F. Gildea	Negative	
3	Duke Energy Carolina	Henry Ernst-Jr	Abstain	
3	Entergy	Joel T Plessinger	Affirmative	
3	Fall River Rural Electric Cooperative	Bryan Case	Negative	
3	FirstEnergy Energy Delivery	Stephan Kern	Affirmative	
3	Florida Municipal Power Agency	Joe McKinney	Affirmative	
3	Florida Power Corporation	Lee Schuster	Negative	
3	Georgia Power Company	Anthony L Wilson	Negative	
3	Georgia Systems Operations Corporation	William N. Phinney	Affirmative	
3	Grays Harbor PUD	Wesley W Gray	Affirmative	
3	Great River Energy	Brian Glover	Negative	
3	Gulf Power Company	Paul C Caldwell	Negative	
3	Hydro One Networks, Inc.	David Kiguel	Negative	
3	Imperial Irrigation District	Jesus S. Alcaraz	Abstain	
3	JEA	Garry Baker		
3	Kansas City Power & Light Co.	Charles Locke		
3	Kissimmee Utility Authority	Gregory D Woessner		
3	Kootenai Electric Cooperative	Dave Kahly	Abstain	
3	Lakeland Electric	Norman D Harryhill		
3	Lane Electric Cooperative, Inc.	Rick Crinklaw	Negative	
3	Lincoln Electric System	Jason Fortik	Affirmative	
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Affirmative	
3	Louisville Gas and Electric Co.	Charles A. Freibert	Affirmative	
3	Manitoba Hydro	Greg C. Parent	Negative	
3	Manitowoc Public Utilities	Thomas E Reed	Affirmative	
3	MidAmerican Energy Co.	Thomas C. Mielnik	Affirmative	
3	Mississippi Power	Jeff Franklin	Negative	
3	Modesto Irrigation District	Jack W Savage		
3	Municipal Electric Authority of Georgia	Steven M. Jackson	Affirmative	
3	Muscatine Power & Water	John S Bos	Negative	
3	Nebraska Public Power District	Tony Eddleman	Negative	
3	New York Power Authority	Marilyn Brown		
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Affirmative	
3	North Carolina Electric Membership Corp.	Doug White		
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative	
3	Northern Lights Inc.	Jon Shelby	Negative	
3	Ocala Electric Utility	David Anderson	Affirmative	
3	Old Dominion Electric Coop.	Bill Watson		
3	Orange and Rockland Utilities, Inc.	David Burke	Affirmative	
3	Orlando Utilities Commission	Ballard K Mutters	Affirmative	
3	Owensboro Municipal Utilities	Thomas T Lyons	Negative	
3	Pacific Gas and Electric Company	John H Hagen	Affirmative	
3	PacifiCorp	Dan Zollner	Affirmative	
3	Platte River Power Authority	Terry L Baker	Affirmative	
3	PNM Resources	Michael Mertz		
3	Potomac Electric Power Co.	Robert Reuter	Affirmative	
3	Progress Energy Carolinas	Sam Waters		
3	Public Service Electric and Gas Co.	Jeffrey Mueller		
3	Public Utility District No. 1 of Benton County	Gloria Bender	Affirmative	
3	Public Utility District No. 1 of Clallam County	David Proebstel		
3	Puget Sound Energy, Inc.	Erin Apperson	Negative	
3	Raft River Rural Electric Cooperative	Heber Carpenter	Negative	

3	Rutherford EMC	Thomas M Haire	Negative
3	Sacramento Municipal Utility District	James Leigh-Kendall	Affirmative
3	Salt River Project	John T. Underhill	Affirmative
3	Santee Cooper	James M Poston	Negative
3	Seattle City Light	Dana Wheelock	Affirmative
3	Seminole Electric Cooperative, Inc.	James R Frauen	Affirmative
3	Snohomish County PUD No. 1	Mark Oens	Affirmative
3	South Carolina Electric & Gas Co.	Hubert C Young	
3	Southern California Edison Co.	David B Coher	
3	Southern Maryland Electric Coop.	Mark R Jones	
3	Tacoma Public Utilities	Travis Metcalfe	Negative
3	Tampa Electric Co.	Ronald L. Donahey	
3	Tennessee Valley Authority	Ian S Grant	Negative
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative
3	Umatilla Electric Cooperative	Steve Eldrige	Negative
3	Westar Energy	Bo Jones	Negative
3	Wisconsin Electric Power Marketing	James R Keller	Affirmative
3	Wisconsin Public Service Corp.	Gregory J Le Grave	
3	Xcel Energy, Inc.	Michael Ibold	Negative
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative
4	American Municipal Power	Kevin Koloini	Negative
4	Arkansas Electric Cooperative Corporation	Ronnie Frizzell	
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative
4	Central Lincoln PUD	Shamus J Gamache	Negative
4	City of Austin dba Austin Energy	Reza Ebrahimian	Affirmative
4	City of Clewiston	Kevin McCarthy	Affirmative
4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	Affirmative
4	City of Redding	Nicholas Zettel	Affirmative
4	City Utilities of Springfield, Missouri	John Allen	Affirmative
4	Consumers Energy	David Frank Ronk	Affirmative
4	Cowlitz County PUD	Rick Syring	Negative
4	Detroit Edison Company	Daniel Herring	Negative
4	Flathead Electric Cooperative	Russ Schneider	Negative
4	Florida Municipal Power Agency	Frank Gaffney	Affirmative
4	Fort Pierce Utilities Authority	Thomas Richards	
4	Georgia System Operations Corporation	Guy Andrews	Affirmative
4	Illinois Municipal Electric Agency	Bob C. Thomas	Affirmative
4	Imperial Irrigation District	Diana U Torres	
4	Indiana Municipal Power Agency	Jack Alvey	Affirmative
4	Integrus Energy Group, Inc.	Christopher Plante	Abstain
4	LaGen	Richard Comeaux	Abstain
4	Madison Gas and Electric Co.	Joseph DePoorter	Affirmative
4	North Carolina Electric Membership Corp.	Bob Beadle	
4	Northern California Power Agency	Tracy R Bibb	
4	Ohio Edison Company	Douglas Hohlbaugh	Affirmative
4	Oklahoma Municipal Power Authority	Ashley Stringer	Affirmative
4	Pacific Northwest Generating Cooperative	Aleka K Scott	Negative
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Affirmative
4	Sacramento Municipal Utility District	Mike Ramirez	Affirmative
4	Seattle City Light	Hao Li	Affirmative
4	South Mississippi Electric Power Association	Steven McElhanev	
4	Tacoma Public Utilities	Keith Morisette	Negative
4	West Oregon Electric Cooperative, Inc.	Marc M Farmer	Negative
4	White River Electric Association Inc.	Frank L. Sampson	Abstain
4	Wisconsin Energy Corp.	Anthony Jankowski	Affirmative
5	AEP Service Corp.	Brock Ondayko	Negative
5	AES Corporation	Leo Bernier	Affirmative
5	Amerenue	Sam Dwyer	Affirmative
5	Arizona Public Service Co.	Edward Cambridge	Affirmative
5	Avista Corp.	Edward F. Groce	Abstain
5	BC Hydro and Power Authority	Clement Ma	Abstain
5	Black Hills Corp	George Tatar	Abstain
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla	Abstain
5	Bonneville Power Administration	Francis J. Halpin	Negative

5	BrightSource Energy, Inc.	Chifong Thomas	Abstain	
5	Caithness Long Island, LLC	Jason M Moore		
5	Chelan County Public Utility District #1	John Yale		
5	City and County of San Francisco	Daniel Mason	Negative	
5	City of Austin dba Austin Energy	Jeanie Doty	Affirmative	
5	City of Redding	Paul A. Cummings	Affirmative	
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick		
5	City of Tallahassee	Brian Horton		
5	City Water, Light & Power of Springfield	Steve Rose	Affirmative	
5	Cogentrix Energy, Inc.	Mike D Hirst	Affirmative	
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative	
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Affirmative	
5	Constellation Power Source Generation, Inc.	Amir Y Hammad	Affirmative	
5	Consumers Energy Company	David C Greyerbiehl		
5	Cowlitz County PUD	Bob Essex	Negative	
5	CPS Energy	Robert Stevens	Affirmative	
5	Detroit Edison Company	Christy Wicke	Negative	
5	Dominion Resources, Inc.	Mike Garton	Negative	
5	Duke Energy	Dale Q Goodwine	Negative	
5	Dynegy Inc.	Dan Roethemeyer	Affirmative	
5	E.ON Climate & Renewables North America, LLC	Dana Showalter		
5	Edison Mission Energy	Ellen Oswald		
5	Electric Power Supply Association	John R Cashin	Abstain	
5	Exelon Nuclear	Michael Korchynsky	Abstain	
5	ExxonMobil Research and Engineering	Martin Kaufman		
5	FirstEnergy Solutions	Kenneth Dresner	Affirmative	
5	Florida Municipal Power Agency	David Schumann	Affirmative	
5	Great River Energy	Preston L Walsh		
5	Green Country Energy	Greg Froehling		
5	Imperial Irrigation District	Marcela Y Caballero		
5	Indeck Energy Services, Inc.	Rex A Roehl		
5	JEA	John J Babik	Affirmative	
5	Kissimmee Utility Authority	Mike Blough	Affirmative	
5	Lakeland Electric	James M Howard	Affirmative	
5	Liberty Electric Power LLC	Daniel Duff	Affirmative	
5	Lincoln Electric System	Dennis Florom	Affirmative	
5	Los Angeles Department of Water & Power	Kenneth Silver	Affirmative	
5	Lower Colorado River Authority	Tom Foreman	Affirmative	
5	Luminant Generation Company LLC	Mike Laney	Affirmative	
5	Manitoba Hydro	S N Fernando	Negative	
5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Affirmative	
5	MEAG Power	Steven Grego	Affirmative	
5	MidAmerican Energy Co.	Christopher Schneider		
5	Muscatine Power & Water	Mike Avesing	Negative	
5	Nebraska Public Power District	Don Schmit	Negative	
5	New York Power Authority	Gerald Mannarino		
5	NextEra Energy	Allen D Schriver	Negative	
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Negative	
5	Northern California Power Agency	Hari Modi		
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative	
5	Occidental Chemical	Michelle R DAntuono	Affirmative	
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative	
5	Orlando Utilities Commission	Richard K Kinias	Affirmative	
5	Pacific Gas and Electric Company	Richard J. Padilla		
5	PacifiCorp	Sandra L. Shaffer	Affirmative	
5	Platte River Power Authority	Roland Thiel	Affirmative	
5	Portland General Electric Co.	Gary L Tingley	Affirmative	
5	PowerSouth Energy Cooperative	Tim Hattaway	Negative	
5	PPL Generation LLC	Annette M Bannon	Affirmative	
5	Progress Energy Carolinas	Wayne Lewis		
5	PSEG Fossil LLC	Tim Kucey	Affirmative	
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative	
5	Puget Sound Energy, Inc.	Tom Flynn	Affirmative	
5	Sacramento Municipal Utility District	Bethany Hunter	Affirmative	
5	Salt River Project	William Alkema	Affirmative	

5	Santee Cooper	Lewis P Pierce	Negative	
5	Seattle City Light	Michael J. Haynes	Affirmative	
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins	Affirmative	
5	Siemens PTI	Edwin Cano		
5	Snohomish County PUD No. 1	Sam Nietfeld	Affirmative	
5	South Mississippi Electric Power Association	Jerry W Johnson		
5	Southern California Edison Co.	Denise Yaffe	Negative	
5	Southern Company Generation	William D Shultz	Negative	
5	Tampa Electric Co.	RJames Rocha	Affirmative	
5	Tenaska, Inc.	Scott M. Helyer	Affirmative	
5	Tennessee Valley Authority	David Thompson	Negative	
5	Tri-State G & T Association, Inc.	Barry Ingold	Affirmative	
5	U.S. Army Corps of Engineers	Melissa Kurtz	Affirmative	
5	Vandolah Power Company L.L.C.	Douglas A. Jensen		
5	Wisconsin Electric Power Co.	Linda Horn	Affirmative	
5	Wisconsin Public Service Corp.	Leonard Rentmeester		
5	Xcel Energy, Inc.	Liam Noailles	Negative	
6	ACES Power Marketing	Jason L Marshall	Abstain	
6	AEP Marketing	Edward P. Cox	Negative	
6	Ameren Energy Marketing Co.	Jennifer Richardson	Affirmative	
6	APS	Randy A. Young	Affirmative	
6	Arkansas Electric Cooperative Corporation	Keith Sugg		
6	Bonneville Power Administration	Brenda S. Anderson	Negative	
6	City of Austin dba Austin Energy	Lisa L Martin	Affirmative	
6	City of Redding	Marvin Briggs	Affirmative	
6	Cleco Power LLC	Robert Hirschak	Affirmative	
6	Colorado Springs Utilities	Lisa C Rosintoski		
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Affirmative	
6	Constellation Energy Commodities Group	Brenda L Powell	Affirmative	
6	Dominion Resources, Inc.	Louis S. Slade	Negative	
6	Duke Energy Carolina	Walter Yeager		
6	Entergy Services, Inc.	Terri F Benoit	Affirmative	
6	Exelon Power Team	Pulin Shah	Abstain	
6	FirstEnergy Solutions	Kevin Querry	Affirmative	
6	Florida Municipal Power Agency	Richard L. Montgomery	Affirmative	
6	Florida Municipal Power Pool	Thomas Washburn		
6	Florida Power & Light Co.	Silvia P. Mitchell	Abstain	
6	Imperial Irrigation District	Cathy Bretz	Abstain	
6	Kansas City Power & Light Co.	Jessica L Klinghoffer		
6	Lakeland Electric	Paul Shipps	Affirmative	
6	Lincoln Electric System	Eric Ruskamp	Affirmative	
6	Los Angeles Department of Water & Power	Brad Packer		
6	Luminant Energy	Brad Jones		
6	Manitoba Hydro	Daniel Prowse	Negative	
6	MidAmerican Energy Co.	Dennis Kimm	Negative	
6	New York Power Authority	William Palazzo		
6	North Carolina Municipal Power Agency #1	Matthew Schull	Affirmative	
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative	
6	Omaha Public Power District	David Ried	Affirmative	
6	Orlando Utilities Commission	Claston Augustus Sunanon		
6	PacifiCorp	Scott L Smith	Affirmative	
6	Platte River Power Authority	Carol Ballantine	Affirmative	
6	PPL EnergyPlus LLC	Mark A Heimbach		
6	Progress Energy	John T Sturgeon		
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Affirmative	
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen		
6	Sacramento Municipal Utility District	Diane Enderby	Affirmative	
6	Salt River Project	Steven J Hulet	Affirmative	
6	Santee Cooper	Michael Brown	Negative	
6	Seattle City Light	Dennis Sismaet	Affirmative	
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak		
6	Snohomish County PUD No. 1	William T Moojen	Affirmative	
6	South California Edison Company	Lujuanna Medina		
6	Southern Company Generation and Energy Marketing	John J. Ciza	Negative	
6	Tacoma Public Utilities	Michael C Hill	Negative	
6	Tampa Electric Co.	Benjamin F Smith II		



6	Tennessee Valley Authority	Marjorie S. Parsons	Negative	
6	Westar Energy	Grant L Wilkerson	Negative	
6	Western Area Power Administration - UGP Marketing	Peter H Kinney	Affirmative	
6	Xcel Energy, Inc.	David F. Lemmons		
8		James A Maenner	Affirmative	
8		Roger C Zaklukiewicz	Abstain	
8		Edward C Stein	Affirmative	
8	JDRJC Associates	Jim Cyrulewski	Affirmative	
8	Pacific Northwest Generating Cooperative	Margaret Ryan	Negative	
8	Power Energy Group LLC	Peggy Abbadini		
8	Utility Services, Inc.	Brian Evans-Mongeon	Affirmative	
8	Volkman Consulting, Inc.	Terry Volkman	Affirmative	
9	California Energy Commission	William M Chamberlain		
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	Negative	
9	National Association of Regulatory Utility Commissioners	Diane J. Barney	Negative	
9	New York State Department of Public Service	Thomas Dvorsky		
10	Midwest Reliability Organization	James D Burley		
10	New York State Reliability Council	Alan Adamson		
10	Northeast Power Coordinating Council	Guy V. Zito	Negative	
10	ReliabilityFirst Corporation	Anthony E Jablonski	Affirmative	
10	SERC Reliability Corporation	Carter B. Edge	Affirmative	
10	Southwest Power Pool RE	Emily Pennel	Negative	
10	Texas Reliability Entity, Inc.	Donald G Jones	Affirmative	
10	Western Electricity Coordinating Council	Steven L. Rueckert	Affirmative	

[Legal and Privacy](#)

404.446.2560 voice : 404.446.2595 fax

Atlanta Office: 3353 Peachtree Road, N.E. : Suite 600, North Tower : Atlanta, GA 30326

Washington Office: 1325 G Street, N.W. : Suite 600 : Washington, DC 20005-3801

 [Account Log-In/Register](#)

Copyright © 2012 by the North American Electric Reliability Corporation. : All rights reserved.  
A New Jersey Nonprofit Corporation

# Non-binding Poll Results

Project 2009-01: Disturbance and Sabotage Reporting

Non-binding Poll Results				
<b>Non-binding Poll Name:</b>	Project 2009-01 DSR Non-binding Poll			
<b>Poll Period:</b>	9/18/2012 - 9/27/2012			
<b>Total # Opinions:</b>	286			
<b>Total Ballot Pool:</b>	394			
<b>Summary Results:</b>	72.59% of those who registered to participate provided an opinion or an abstention; 63.05% of those who provided an opinion indicated support for the VRFs and VSLs.			
Individual Ballot Pool Results				
Segment	Organization	Member	Ballot	Comments
1	Ameren Services	Kirit Shah	Affirmative	
1	American Electric Power	Paul B. Johnson		
1	American Transmission Company, LLC	Andrew Z Puzstai	Abstain	
1	Arizona Public Service Co.	Robert Smith	Affirmative	
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative	
1	Avista Corp.	Scott J Kinney		
1	Balancing Authority of Northern California	Kevin Smith	Abstain	
1	Baltimore Gas & Electric Company	Gregory S Miller		
1	BC Hydro and Power Authority	Patricia Robertson	Abstain	
1	Beaches Energy Services	Joseph S Stonecipher	Negative	
1	Black Hills Corp	Eric Egge		
1	Bonneville Power Administration	Donald S. Watkins	Negative	
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey	Negative	
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Abstain	
1	Central Maine Power Company	Joseph Turano Jr.	Affirmative	
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Negative	
1	Clark Public Utilities	Jack Stamper	Negative	
1	Colorado Springs Utilities	Paul Morland	Affirmative	
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Affirmative	
1	CPS Energy	Richard Castrejano	Affirmative	
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative	
1	Dayton Power & Light Co.	Hertzel Shamash		
1	Deseret Power	James Tucker		
1	Dominion Virginia Power	Michael S Crowley	Negative	



1	Duke Energy Carolina	Douglas E. Hills	Negative	
1	East Kentucky Power Coop.	George S. Carruba	Negative	
1	Empire District Electric Co.	Ralph F Meyer	Negative	
1	Entergy Services, Inc.	Edward J Davis		
1	FirstEnergy Corp.	William J Smith	Affirmative	
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton	Negative	
1	Florida Power & Light Co.	Mike O'Neil	Negative	
1	Gainesville Regional Utilities	Luther E. Fair		
1	Georgia Transmission Corporation	Jason Snodgrass	Affirmative	
1	Grand River Dam Authority	James M Stafford	Affirmative	
1	Great River Energy	Gordon Pietsch		
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Negative	
1	Hydro One Networks, Inc.	Ajay Garg	Abstain	
1	Hydro-Quebec TransEnergie	Bernard Pelletier		
1	Idaho Power Company	Ronald D. Schellberg		
1	Imperial Irrigation District	Tino Zaragoza	Abstain	
1	International Transmission Company Holdings Corp	Michael Moltane	Abstain	
1	JEA	Ted Hobson	Affirmative	
1	Kansas City Power & Light Co.	Michael Gammon		
1	Keys Energy Services	Stanley T Rzad		
1	Lakeland Electric	Larry E Watt	Affirmative	
1	Lee County Electric Cooperative	John W Delucca	Affirmative	
1	Lincoln Electric System	Doug Bantam	Affirmative	
1	Los Angeles Department of Water & Power	Ly M Le		
1	Lower Colorado River Authority	Martyn Turner	Affirmative	
1	Manitoba Hydro	Joe D Petaski		
1	MEAG Power	Danny Dees	Affirmative	
1	MidAmerican Energy Co.	Terry Harbour	Negative	
1	Minnkota Power Coop. Inc.	Richard Burt	Affirmative	
1	National Grid	Saurabh Saksena	Affirmative	
1	Nebraska Public Power District	Cole C Brodine	Negative	
1	New Brunswick Power Transmission Corporation	Randy MacDonald	Abstain	
1	New York Power Authority	Arnold J. Schuff		
1	New York State Electric & Gas Corp.	Raymond P Kinney		
1	Northeast Utilities	David Boguslawski	Abstain	
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative	
1	NorthWestern Energy	John Canavan	Abstain	
1	Ohio Valley Electric Corp.	Robert Matthey	Negative	
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Negative	
1	Omaha Public Power District	Doug Peterchuck	Affirmative	
1	Oncor Electric Delivery	Brenda Pulis		
1	Orlando Utilities Commission	Brad Chase	Abstain	
1	PacifiCorp	Ryan Millard	Abstain	
1	PECO Energy	Ronald Schloendorn		

1	Platte River Power Authority	John C. Collins	Abstain	
1	Portland General Electric Co.	John T Walker	Affirmative	
1	PowerSouth Energy Cooperative	Larry D Avery	Negative	
1	PPL Electric Utilities Corp.	Brenda L Truhe	Affirmative	
1	Progress Energy Carolinas	Brett A. Koelsch	Abstain	
1	Public Service Company of New Mexico	Laurie Williams	Abstain	
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Abstain	
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel	Affirmative	
1	Puget Sound Energy, Inc.	Denise M Lietz	Negative	
1	Rochester Gas and Electric Corp.	John C. Allen	Affirmative	
1	Sacramento Municipal Utility District	Tim Kelley	Abstain	
1	Salmon River Electric Cooperative	Kathryn J Spence	Affirmative	
1	Salt River Project	Robert Kondziolka	Affirmative	
1	Santee Cooper	Terry L Blackwell	Negative	
1	SCE&G	Henry Delk, Jr.		
1	Seattle City Light	Pawel Krupa	Abstain	
1	Sho-Me Power Electric Cooperative	Denise Stevens	Affirmative	
1	Sierra Pacific Power Co.	Rich Salgo	Abstain	
1	Snohomish County PUD No. 1	Long T Duong	Affirmative	
1	South California Edison Company	Steven Mavis	Negative	
1	Southern Company Services, Inc.	Robert A. Schaffeld	Negative	
1	Southern Illinois Power Coop.	William Hutchison		
1	Southwest Transmission Cooperative, Inc.	James Jones	Negative	
1	Southwestern Power Administration	Angela L Summer	Abstain	
1	Sunflower Electric Power Corporation	Noman Lee Williams	Negative	
1	Tampa Electric Co.	Beth Young		
1	Tennessee Valley Authority	Larry G Akens	Abstain	
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative	
1	Tucson Electric Power Co.	John Tolo		
1	United Illuminating Co.	Jonathan Appelbaum	Affirmative	
1	Westar Energy	Allen Klassen	Negative	
1	Western Area Power Administration	Brandy A Dunn	Affirmative	
1	Xcel Energy, Inc.	Gregory L Pieper		
2	Alberta Electric System Operator	Mark B Thompson	Abstain	
2	BC Hydro	Venkataramakrishnan Vinnakota	Abstain	
2	California ISO	Rich Vine	Abstain	
2	Electric Reliability Council of Texas, Inc.	Charles B Manning		
2	Independent Electricity System Operator	Barbara Constantinescu	Negative	
2	Midwest ISO, Inc.	Marie Knox		
2	New Brunswick System Operator	Alden Briggs	Abstain	
2	New York Independent System Operator	Gregory Campoli		
2	PJM Interconnection, L.L.C.	Tom Bowe	Abstain	
2	Southwest Power Pool, Inc.	Charles H. Yeung		
3	AEP	Michael E Deloach	Negative	

3	Alabama Power Company	Richard J. Mandes		
3	Ameren Services	Mark Peters	Affirmative	
3	Anaheim Public Utilities Dept.	Kelly Nguyen		
3	APS	Steven Norris	Affirmative	
3	Arkansas Electric Cooperative Corporation	Philip Huff	Abstain	
3	BC Hydro and Power Authority	Pat G. Harrington	Abstain	
3	Bonneville Power Administration	Rebecca Berdahl	Negative	
3	Central Lincoln PUD	Steve Alexanderson	Abstain	
3	City of Austin dba Austin Energy	Andrew Gallo	Affirmative	
3	City of Bartow, Florida	Matt Culverhouse		
3	City of Clewiston	Lynne Mila	Affirmative	
3	City of Farmington	Linda R Jacobson	Affirmative	
3	City of Garland	Ronnie C Hoeinghaus	Abstain	
3	City of Green Cove Springs	Gregg R Griffin	Abstain	
3	City of Redding	Bill Hughes	Affirmative	
3	Clatskanie People's Utility District	Brian Fawcett		
3	Cleco Corporation	Michelle A Corley	Abstain	
3	Colorado Springs Utilities	Charles Morgan	Affirmative	
3	ComEd	Bruce Krawczyk		
3	Consolidated Edison Co. of New York	Peter T Yost	Affirmative	
3	Constellation Energy	CJ Ingersoll	Abstain	
3	Consumers Energy	Richard Blumenstock	Affirmative	
3	Cowlitz County PUD	Russell A Noble	Negative	
3	CPS Energy	Jose Escamilla	Affirmative	
3	Detroit Edison Company	Kent Kujala	Negative	
3	Dominion Resources Services	Michael F. Gildea		
3	Duke Energy Carolina	Henry Ernst-Jr	Abstain	
3	Entergy	Joel T Plessinger	Affirmative	
3	FirstEnergy Energy Delivery	Stephan Kern	Affirmative	
3	Florida Municipal Power Agency	Joe McKinney	Affirmative	
3	Florida Power Corporation	Lee Schuster	Negative	
3	Georgia Power Company	Anthony L Wilson		
3	Georgia Systems Operations Corporation	William N. Phinney	Affirmative	
3	Grays Harbor PUD	Wesley W Gray	Affirmative	
3	Great River Energy	Brian Glover	Negative	
3	Gulf Power Company	Paul C Caldwell	Negative	
3	Hydro One Networks, Inc.	David Kiguel	Abstain	
3	Imperial Irrigation District	Jesus S. Alcaraz	Abstain	
3	JEA	Garry Baker		
3	Kansas City Power & Light Co.	Charles Locke		
3	Kissimmee Utility Authority	Gregory D Woessner		
3	Kootenai Electric Cooperative	Dave Kahly	Abstain	
3	Lakeland Electric	Norman D Harryhill		
3	Lincoln Electric System	Jason Fortik	Affirmative	
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Affirmative	

3	Louisville Gas and Electric Co.	Charles A. Freibert		
3	Manitoba Hydro	Greg C. Parent	Negative	
3	Manitowoc Public Utilities	Thomas E Reed	Affirmative	
3	MidAmerican Energy Co.	Thomas C. Mielnik	Negative	
3	Mississippi Power	Jeff Franklin	Negative	
3	Modesto Irrigation District	Jack W Savage		
3	Municipal Electric Authority of Georgia	Steven M. Jackson	Affirmative	
3	Muscatine Power & Water	John S Bos	Negative	
3	Nebraska Public Power District	Tony Eddleman	Abstain	
3	New York Power Authority	Marilyn Brown		
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Affirmative	
3	North Carolina Electric Membership Corp.	Doug White		
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative	
3	Ocala Electric Utility	David Anderson	Affirmative	
3	Old Dominion Electric Coop.	Bill Watson		
3	Orange and Rockland Utilities, Inc.	David Burke	Affirmative	
3	Orlando Utilities Commission	Ballard K Mutters	Abstain	
3	Owensboro Municipal Utilities	Thomas T Lyons	Negative	
3	Pacific Gas and Electric Company	John H Hagen	Affirmative	
3	PacifiCorp	Dan Zollner	Abstain	
3	Platte River Power Authority	Terry L Baker	Abstain	
3	PNM Resources	Michael Mertz		
3	Potomac Electric Power Co.	Robert Reuter		
3	Progress Energy Carolinas	Sam Waters		
3	Public Service Electric and Gas Co.	Jeffrey Mueller		
3	Public Utility District No. 1 of Clallam County	David Proebstel		
3	Puget Sound Energy, Inc.	Erin Apperson	Negative	
3	Rutherford EMC	Thomas M Haire	Negative	
3	Sacramento Municipal Utility District	James Leigh-Kendall	Abstain	
3	Salt River Project	John T. Underhill	Affirmative	
3	Santee Cooper	James M Poston	Negative	
3	Seattle City Light	Dana Wheelock	Abstain	
3	Seminole Electric Cooperative, Inc.	James R Frauen	Affirmative	
3	Snohomish County PUD No. 1	Mark Oens	Affirmative	
3	South Carolina Electric & Gas Co.	Hubert C Young		
3	Southern Maryland Electric Coop.	Mark R Jones		
3	Tacoma Public Utilities	Travis Metcalfe	Negative	
3	Tampa Electric Co.	Ronald L Donahey		
3	Tennessee Valley Authority	Ian S Grant	Abstain	
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative	
3	Westar Energy	Bo Jones	Negative	
3	Xcel Energy, Inc.	Michael Ibold	Abstain	
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative	
4	American Municipal Power	Kevin Koloini	Negative	
4	Arkansas Electric Cooperative	Ronnie Frizzell		

	Corporation			
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative	
4	Central Lincoln PUD	Shamus J Gamache	Abstain	
4	City of Austin dba Austin Energy	Reza Ebrahimian	Affirmative	
4	City of Clewiston	Kevin McCarthy	Affirmative	
4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	Affirmative	
4	City of Redding	Nicholas Zettel	Affirmative	
4	City Utilities of Springfield, Missouri	John Allen	Affirmative	
4	Consumers Energy	David Frank Ronk	Affirmative	
4	Cowlitz County PUD	Rick Syring	Negative	
4	Detroit Edison Company	Daniel Herring	Negative	
4	Flathead Electric Cooperative	Russ Schneider	Negative	
4	Florida Municipal Power Agency	Frank Gaffney	Affirmative	
4	Fort Pierce Utilities Authority	Thomas Richards		
4	Georgia System Operations Corporation	Guy Andrews	Affirmative	
4	Illinois Municipal Electric Agency	Bob C. Thomas	Abstain	
4	Imperial Irrigation District	Diana U Torres		
4	Indiana Municipal Power Agency	Jack Alvey	Abstain	
4	Integrays Energy Group, Inc.	Christopher Plante	Abstain	
4	LaGen	Richard Comeaux	Abstain	
4	Madison Gas and Electric Co.	Joseph DePoorter	Affirmative	
4	Northern California Power Agency	Tracy R Bibb		
4	Ohio Edison Company	Douglas Hohlbaugh	Affirmative	
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative	
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Affirmative	
4	Sacramento Municipal Utility District	Mike Ramirez	Abstain	
4	Seattle City Light	Hao Li	Abstain	
4	South Mississippi Electric Power Association	Steven McElhanev		
4	Tacoma Public Utilities	Keith Morisette	Negative	
4	Wisconsin Energy Corp.	Anthony Jankowski	Affirmative	
5	AEP Service Corp.	Brock Ondayko	Negative	
5	AES Corporation	Leo Bernier	Affirmative	
5	Amerenue	Sam Dwyer	Affirmative	
5	Arizona Public Service Co.	Edward Cambridge	Affirmative	
5	Avista Corp.	Edward F. Groce	Abstain	
5	BC Hydro and Power Authority	Clement Ma	Abstain	
5	Black Hills Corp	George Tatar	Abstain	
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla	Abstain	
5	Bonneville Power Administration	Francis J. Halpin	Negative	
5	BrightSource Energy, Inc.	Chifong Thomas	Abstain	
5	Caithness Long Island, LLC	Jason M Moore		
5	Chelan County Public Utility District #1	John Yale		
5	City and County of San Francisco	Daniel Mason		

5	City of Austin dba Austin Energy	Jeanie Doty	Affirmative	
5	City of Redding	Paul A. Cummings	Affirmative	
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick		
5	City of Tallahassee	Brian Horton		
5	City Water, Light & Power of Springfield	Steve Rose	Affirmative	
5	Cleco Power	Stephanie Huffman	Abstain	
5	Cogentrix Energy, Inc.	Mike D Hirst	Negative	
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative	
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Affirmative	
5	Constellation Power Source Generation, Inc.	Amir Y Hammad		
5	Consumers Energy Company	David C Greyerbiehl		
5	Cowlitz County PUD	Bob Essex	Negative	
5	CPS Energy	Robert Stevens	Affirmative	
5	Detroit Edison Company	Christy Wicke	Negative	
5	Dominion Resources, Inc.	Mike Garton		
5	Duke Energy	Dale Q Goodwine	Negative	
5	Dynegy Inc.	Dan Roethemeyer	Affirmative	
5	E.ON Climate & Renewables North America, LLC	Dana Showalter		
5	Edison Mission Energy	Ellen Oswald		
5	Electric Power Supply Association	John R Cashin	Abstain	
5	Exelon Nuclear	Michael Korchynsky		
5	ExxonMobil Research and Engineering	Martin Kaufman		
5	FirstEnergy Solutions	Kenneth Dresner	Affirmative	
5	Florida Municipal Power Agency	David Schumann	Affirmative	
5	Gainesville Regional Utilities	Karen C Alford		
5	Great River Energy	Preston L Walsh		
5	Green Country Energy	Greg Froehling		
5	Imperial Irrigation District	Marcela Y Caballero		
5	Indeck Energy Services, Inc.	Rex A Roehl		
5	JEA	John J Babik	Affirmative	
5	Kissimmee Utility Authority	Mike Blough	Affirmative	
5	Lakeland Electric	James M Howard		
5	Liberty Electric Power LLC	Daniel Duff	Negative	
5	Lincoln Electric System	Dennis Florom	Affirmative	
5	Los Angeles Department of Water & Power	Kenneth Silver	Affirmative	
5	Lower Colorado River Authority	Tom Foreman	Abstain	
5	Luminant Generation Company LLC	Mike Laney	Affirmative	
5	Manitoba Hydro	S N Fernando	Negative	
5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Abstain	
5	MEAG Power	Steven Grego	Affirmative	
5	MidAmerican Energy Co.	Christopher Schneider		
5	Muscatine Power & Water	Mike Avesing	Negative	
5	Nebraska Public Power District	Don Schmit	Negative	

5	New York Power Authority	Gerald Mannarino		
5	NextEra Energy	Allen D Schriver	Negative	
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Negative	
5	Northern California Power Agency	Hari Modi		
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative	
5	Occidental Chemical	Michelle R DAntuono	Affirmative	
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative	
5	Orlando Utilities Commission	Richard K Kinas	Negative	
5	Pacific Gas and Electric Company	Richard J. Padilla		
5	PacifiCorp	Sandra L. Shaffer	Abstain	
5	Platte River Power Authority	Roland Thiel	Abstain	
5	Portland General Electric Co.	Gary L Tingley	Affirmative	
5	PowerSouth Energy Cooperative	Tim Hattaway	Negative	
5	PPL Generation LLC	Annette M Bannon	Affirmative	
5	Progress Energy Carolinas	Wayne Lewis		
5	PSEG Fossil LLC	Tim Kucey	Abstain	
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative	
5	Puget Sound Energy, Inc.	Tom Flynn	Affirmative	
5	Sacramento Municipal Utility District	Bethany Hunter	Abstain	
5	Salt River Project	William Alkema	Affirmative	
5	Santee Cooper	Lewis P Pierce	Negative	
5	Seattle City Light	Michael J. Haynes	Abstain	
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins	Affirmative	
5	Siemens PTI	Edwin Cano		
5	Snohomish County PUD No. 1	Sam Nietfeld	Affirmative	
5	South Mississippi Electric Power Association	Jerry W Johnson		
5	Southern California Edison Co.	Denise Yaffe	Negative	
5	Southern Company Generation	William D Shultz	Negative	
5	Tampa Electric Co.	RJames Rocha	Affirmative	
5	Tenaska, Inc.	Scott M. Helyer	Abstain	
5	Tennessee Valley Authority	David Thompson	Abstain	
5	Tri-State G & T Association, Inc.	Barry Ingold		
5	U.S. Army Corps of Engineers	Melissa Kurtz	Affirmative	
5	Vandolah Power Company L.L.C.	Douglas A. Jensen		
5	Xcel Energy, Inc.	Liam Noailles		
6	ACES Power Marketing	Jason L Marshall	Abstain	
6	AEP Marketing	Edward P. Cox	Negative	
6	Ameren Energy Marketing Co.	Jennifer Richardson	Affirmative	
6	APS	Randy A. Young	Affirmative	
6	Arkansas Electric Cooperative Corporation	Keith Sugg		
6	Bonneville Power Administration	Brenda S. Anderson	Negative	
6	City of Austin dba Austin Energy	Lisa L Martin	Affirmative	
6	City of Redding	Marvin Briggs	Affirmative	
6	Cleco Power LLC	Robert Hirschak	Abstain	

6	Colorado Springs Utilities	Lisa C Rosintoski		
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Affirmative	
6	Constellation Energy Commodities Group	Brenda Powell		
6	Dominion Resources, Inc.	Louis S. Slade	Abstain	
6	Duke Energy Carolina	Walter Yeager		
6	Entergy Services, Inc.	Terri F Benoit	Affirmative	
6	Exelon Power Team	Pulin Shah		
6	FirstEnergy Solutions	Kevin Querry	Affirmative	
6	Florida Municipal Power Agency	Richard L. Montgomery	Affirmative	
6	Florida Municipal Power Pool	Thomas Washburn		
6	Florida Power & Light Co.	Silvia P. Mitchell	Abstain	
6	Imperial Irrigation District	Cathy Bretz	Abstain	
6	Kansas City Power & Light Co.	Jessica L Klinghoffer		
6	Lakeland Electric	Paul Shipps	Affirmative	
6	Lincoln Electric System	Eric Ruskamp	Affirmative	
6	Los Angeles Department of Water & Power	Brad Packer		
6	Luminant Energy	Brad Jones		
6	Manitoba Hydro	Daniel Prowse	Negative	
6	MidAmerican Energy Co.	Dennis Kimm	Negative	
6	New York Power Authority	William Palazzo		
6	North Carolina Municipal Power Agency #1	Matthew Schull	Affirmative	
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative	
6	Omaha Public Power District	David Ried	Affirmative	
6	Orlando Utilities Commission	Claston Augustus Sunanon		
6	PacifiCorp	Scott L Smith	Abstain	
6	Platte River Power Authority	Carol Ballantine	Abstain	
6	PPL EnergyPlus LLC	Mark A Heimbach		
6	Progress Energy	John T Sturgeon		
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Abstain	
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen		
6	Sacramento Municipal Utility District	Diane Enderby	Abstain	
6	Salt River Project	Steven J Hulet	Affirmative	
6	Santee Cooper	Michael Brown	Negative	
6	Seattle City Light	Dennis Sismaet	Affirmative	
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak		
6	Snohomish County PUD No. 1	William T Moojen	Affirmative	
6	South California Edison Company	Lujuanna Medina		
6	Southern Company Generation and Energy Marketing	John J. Ciza	Negative	
6	Tacoma Public Utilities	Michael C Hill	Negative	
6	Tampa Electric Co.	Benjamin F Smith II		
6	Tennessee Valley Authority	Marjorie S. Parsons	Abstain	
6	Westar Energy	Grant L Wilkerson	Negative	
6	Western Area Power Administration -	Peter H Kinney	Affirmative	



	UGP Marketing			
6	Xcel Energy, Inc.	David F. Lemmons		
8		Roger C Zaklukiewicz	Abstain	
8		Edward C Stein	Affirmative	
8		James A Maenner	Affirmative	
8	APX	Michael Johnson	Affirmative	
8	JDRJC Associates	Jim Cyrulewski	Affirmative	
8	Power Energy Group LLC	Peggy Abbadini		
8	Utility Services, Inc.	Brian Evans-Mongeon	Abstain	
8	Volkman Consulting, Inc.	Terry Volkman	Affirmative	
9	California Energy Commission	William M Chamberlain		
9	Central Lincoln PUD	Bruce Lovelin		
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	Abstain	
10	Midwest Reliability Organization	James D Burley		
10	New York State Reliability Council	Alan Adamson		
10	Northeast Power Coordinating Council	Guy V. Zito	Negative	
10	ReliabilityFirst Corporation	Anthony E Jablonski	Affirmative	
10	SERC Reliability Corporation	Carter B. Edge	Abstain	
10	Southwest Power Pool RE	Emily Pannel	Negative	
10	Texas Reliability Entity, Inc.	Donald G Jones	Affirmative	
10	Western Electricity Coordinating Council	Steven L. Rueckert	Abstain	

**Individual or group. (56 Responses)**  
**Name (40 Responses)**  
**Organization (40 Responses)**  
**Group Name (16 Responses)**  
**Lead Contact (16 Responses)**  
**Question 1 (50 Responses)**  
**Question 1 Comments (51 Responses)**  
**Question 2 (41 Responses)**  
**Question 2 Comments (51 Responses)**  
**Question 3 (0 Responses)**  
**Question 3 Comments (51 Responses)**

Group
Northeast Power Coordinating Council
Guy Zito
Paragraph 81 efforts are underway to eliminate requirements that have little or no reliability benefit. This Standard only addresses documentation and has no impact on reliability.
Individual
Lee Layton
Blue Ridge EMC
No
See previous comments
No
R3 VSLs are silly.
Group
Arizona Public Service Company
Janet Smith, Regulatory Affairs Supervisor
Yes
Yes
No Additional Comments
Individual
Anthony Jablonski
ReliabilityFirst
Yes
Even though ReliabilityFirst votes in the Affirmative, we offer the following comment regarding Requirement R3 for consideration. ReliabilityFirst recommends changing the word "validate" to "verify" in Requirement R3. ReliabilityFirst believes not only does the entity need to validate contact information is correct, they should verify (i.e. authenticate though test) that the contact information is correct.
Yes
Even though ReliabilityFirst votes in the Affirmative, we offer the following comments for consideration regarding the VSLs: VSL for Requirement R2 – ReliabilityFirst questions whether there is justification for the gradation of VSLs out to 60 hours for the reporting an event. Without justification, ReliabilityFirst believes the timeframe should be shortened to eight hour increments with a severe VSL being more than 48 hours late. ReliabilityFirst believes that being more than a day late (24 hours) falls within the entity completely not meeting the intent of submitting the report with the required 24 hour timeframe.
Group
Southwest Power Pool Regional Entity
Emily Pannel
Yes

No
In R2, SPP RE does not understand why the VSLs are based on who was or was not contacted rather than when it was reported. An entity could decide to put only two entities in its Event Reporting Operating Plan. If the entity fails to submit an appropriate event report, it is open to a Severe VSL on the top set of VSLs but only a moderate on the lower set of VSLs. This seems to be a disconnect for applying the VSLs for the same facts and circumstances.
(1) SPP RE thinks the following Generation reporting threshold is unclear: "Total generation loss, within one minute, of $\geq 2,000$ MW for entities in the Eastern or Western Interconnection". What has to happen within one minute? It reads as if you have to make a report within one minute. If the intent is that a report has to be made within 24 hours if the loss is for more than one minute it should read, "Total generation loss $\geq 2,000$ MW for more than one minute for entities in the Eastern or Western Interconnection". What is the intent of the one minute requirement? (2) It appears per R1 that entities are no longer required to include Regional Entities in their reporting chains. SPP RE believes Regional Entities must be included in the reporting chain so they can fulfill their obligations under their delegation agreements. (3) SPP RE thinks this standard was changed substantially enough that it should have been opened for a new ballot pool.
Individual
Jonathan Appelbaum
The United Illuminating Company
Yes
No
Do not agree that the VRF for R3 is medium. Failure to Validate contact information will not likely lead to instability and Cascade. Reporting under EOP-004 is not an immediate action, and given a 24 hour reporting window a proper contact point can be identified on-the-fly. R2 is properly identified as the Medium VRF since a failure to report whether due to an improper Operating plan or improper contact list may lead to an BES cascade.
Group
PNGC Comment Group
Ron Sporseen
Yes
Yes
Comments: The PNGC Comment group remains concerned that the "Applicability" section will inadvertently subject Distribution Providers to requirements that they should be excluded from. Please consider the two examples below and note that we're talking about probably hundreds of small DPs being subject to these unnecessary requirements without any increase to the reliability of the BES. Example 1: Small DP with a peak load of 50 MWs. They have no BES Facilities and their system is radial. Even though this utility will never have a reporting requirement per Attachment A, they are still subject to R1 and R3 plus the associated compliance (read financial) risk for non-conformance. An easy fix to this issue would be for DPs without BES Facilities and with less than 200 MW annual peak load to be excluded in the Applicability section. Example 2: Small DP with a peak load of 50 MWs. Their only BES Facilities are two Automatic UFLS relays that are capable of shedding 15 MWs. DP's Host Balance Authority (HBA) has a peak load of 10,000 MWs, meaning their UFLS plan requires them to have the capacity to shed 3000 MWs should system conditions warrant. Is it the SDT's intent for this DP to have an Operating Plan in place for "damage", "destruction", or "physical threat" for these two relays that are capable of shedding only 15 MWs out of a 3000 MW HBA UFLS plan? The SDT set a 100 MW threshold for reporting of automatic UFLS load shedding so why have reporting requirements for the threat to 15 MWs worth of UFLS relays? Once again the easy fix is to modify the Applicability section. We suggest: 4.1.7. Distribution Provider: with $\geq 200$ MW annual peak load, or; $\geq 100$ MW Automatic firm load shedding
Individual
Russ Schneider
Flathead Electric Cooperative, Inc.
Individual
Oliver Burke
Energry Services, Inc. (Transmission)
Yes
Yes

Individual
Nazra Gladu
Manitoba Hydro
No
This seems like an administrative only requirement. It would be too difficult to validate or measure.
No
This seems like an administrative only requirement. It would be too difficult to validate or measure.
Does the Background, Guidelines and Technical Basis form part of the standard itself once published? Or are these just parts of the package that accompany the standard during circulation for comment? Compliance 1.2: The reference to Responsible Entity is bracketed and in lowercase. We are not clear why. VSLs, R1, Severe VSL: The words "in the event reporting Operating Plan" are missing from the end of this sentence. VSLs, R2, Lower VSL: The violation occurs if the Responsible Entity has submitted an event report to one entity whereas Moderate VSL, High VSL and Severe VSL, the level of severity of the VSL increases depending on the number of entities that the Responsible Entity fails to submit an event report to. The drafting here is not as precise as it should be. The way the Lower VSL is written, it will also be triggered when the Responsible Entity has complied with the requirement. For example, if the Responsible Entity is required to report an event to 5 entities, and it does, it will still mean that it has "submitted an event report to one entity identified in the event reporting (also, the 'ing' is missing on the Lower VSL reference)Operating Plan". It is also duplicative. For example, if the Responsible Entity submitted a report to only one entity, and failed to submit a report to 4 others, they fall under the Lower VSL and the Higher VSL (we are assuming in this case, the violation will be found to be the higher VSL). Perhaps what the drafting team intended to do was to make the Lower VSL, which the Responsible Entity failed to submit an event report...to one entity identified.... The Guidelines and Technical Basis contain a reference to R4 which no longer exists in the standard.
Individual
Steve Grega
Lewis County PUD
Yes
No
We are a small utility with little impact to the BES with a small hydro on the end of a 230kV line. CIP-001 requires us to contact the FBI who has repeatedly instructed us to call the local sheriff office. The sheriff office has instructed us to call 911 and they will contact the FBI as needed. Therefore, 911 is our only contact number and our plan if vandalism, property destruction or sabotage is to have a supervisor call 911 and report. I do not think calling 911 to confirm the contact number serves any propose. Our plan will be simple with not a lot detail. The drafting team should recognize the reality of small utilities and state the required plan may be simple and not follow the flowchart in the draft standard.
Individual
Steve Alexanderson P.E.
Central Lincoln
Yes
1) Central Lincoln must again point out the lack of proportionality for gunshot insulators and similar events under "Damage or destruction of a Facility." Please see our last set of comments. These incidents are fairly common in the west, and typically do not cause an immediate outage. They are generally discovered months after the fact, yet the discovery starts the 24 hour clock running as if the situation had suddenly changed. Prior SDT response: "... this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was "damaged or destroyed" intentionally by a human." There is already a great lag in awareness regarding the damaged insulator. Months or more can pass prior to discovery by the entity. We fail to see how it becomes so urgent upon discovery. Prior SDT response: "The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan." We do not share the SDT's vision. If an Operating Plan redefined suspected intentional human action so the act of preparing a gun for firing, aligning the sights on an insulator and pulling the trigger was not included, we believe the entity that operates under that plan would be found non-compliant under the language of this standard. We do not offer a simple change in text that will fix the problem, we are only pointing out the problem exists. Murphy dictates discovery will occur at the most inopportune time, which will be during an after hours outage on a stormy holiday weekend night when many employees are out of town and those that are available are already fully engaged. The entity is then faced with choosing to delay restoration or violating the standard. When proposing a zero defect event driven

requirement event driven such as this one, we ask the SDT to consider all possible scenarios in which the event may occur. 2) We note that Distribution Providers are listed in the Applicability Section. We also note that there is no requirement in the Statement of Compliance Registry Criteria for Distribution Providers to own or operate BES Facilities, own or operate UFLS or UVLS of 100 MW, or to have load exceeding 200 MW. DP's that cannot meet any of the thresholds of Attachment 1 would still need an Operating Plan under R1 and annually validate the possibly null contact list in its OP under R3. We suggest that DPs that cannot meet the thresholds of Attachment 1 be removed from the Applicability Section.

Group

Duke Energy

Greg Rowland

Yes

Duke Energy commends the excellent work of the Standard Drafting Team in incorporating previous comments into the current posted draft of the standard.

No

The Lower VSL for R3 should be clarified. The phrase "validated 75% or more" should be modified to say "validated at least 75% but less than 100%".

1) There are discrepancies between the red-lined EOP-004-2 and the Clean EOP-004-2 that were posted for this project. Our comments are based upon the Clean EOP-004-2. 2) Attachment 1 and Attachment 2 have the ERO email and phone number listed. If these ever change, does the standard have to go through the revision and balloting process again, or is there an easier way to incorporate such changes? 3) Attachment 1 – When an event occurs that meets the Threshold for Reporting, it's not clear whether all listed entities have to report or not. Several Event Types need this clarity added. For example, if a TOP loses voice communication capability, do both the TOP and RC have to report? 4) Attachment 1 – Damage or destruction of a Facility, applicable to BA, TO, TOP, GO, GOP, DP. The Threshold for Reporting should be further clarified by adding the sentence "Do not report theft or damage unless it degrades normal operation of a Facility." This would eliminate unnecessary reporting of copper theft or vandalism. 5) Attachment 1 – Physical threats to a Facility. The Threshold for Reporting should be modified by deleting the sentence "Do not report theft unless it degrades normal operation of a Facility". This sentence isn't needed here, and fits better with "Damage or destruction of a Facility" as noted in 4) above. 6) Attachment 1 – Transmission loss. This event type should be deleted because it is duplicated under TADS reporting and PRC-004 Protection System Misoperations reporting. 7) Attachment 1 – Unplanned BES control center evacuation, Complete loss of voice communication capability, and Complete loss of monitoring capability. The Threshold for Reporting on all three of these Event Types is 30 minutes, and should be extended to 2 hours, consistent with the transition time identified in EOP-008 "Loss of Control Center Functionality".

Individual

Jack Stamper

Clark Public Utilities

Yes

Yes

The SDT has not adequately addressed my comments from the last draft regarding damage or destruction of its facility that results from actual or suspected intentional human action. The SDT needs to limit what it means by damage. As an example, if someone breaks into a substation and paints graffiti on a breaker that is part of the BES, the breaker has been "damaged." However, the breaker's ability to function has not been compromised and there are no emergency actions that need to be taken. There is no reason for an emergency reporting procedure to require this to be reported. The SDT needs to add the same modifier for damage that it added in the previous event threshold for reporting. The reference for this type of damage should be as follows: Event: Damage or destruction of a Facility. Entity with Reporting Responsibility: BA, TO, TOP, GO, GOP, DP. Threshold for Reporting: Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency.

Individual

Russell A. Noble

Cowlitz PUD

Yes

Cowlitz approves of the improvement efforts on Attachment 1. However, Cowlitz must again point out the fallacy of potentially inundating the ERO with nuisance reporting of minor vandalism and accidental damage. For example, gunshot "target practice" of insulators and structures will apply under "Damage or destruction of a Facility." Such incidents are fairly common in the west, and typically do not cause an immediate outage. They are generally

discovered months or years after the fact, yet the discovery starts the 24 hour compliance clock running as if the urgency is just as important as a recent event. If there is already a great lag in awareness regarding the damaged Facility, Cowlitz fails to see how it becomes so urgent upon discovery.----- Again, Cowlitz points out the sentence structure "Damage or destruction of its Facility that results from actual or suspected intentional human action" does not restrict the human action as malicious or sabotage. "Intentional human action" could be innocent, such as a land owner attempting to fall a tree for fire wood. The intent was not to damage the Facility, but the "intentional human action" to obtain fire wood resulted in the damage of the Facility. This does not comport with prior SDT response: "... this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was 'damaged or destroyed' intentionally by a human." Therefore, if this is the SDT's intent Cowlitz suggests this change: Damage or destruction of its Facility that causes immediate impaired operation or loss of the Facility from suspected or actual malicious human intent. Do not report mischievous vandalism, as defined in the Operating Plan, where immediate loss of, or immediate impaired operation of the Facility has not occurred. ----- Prior SDT response: "The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan." Cowlitz does not share the SDT's vision. The Standard as written does not specifically address the ability to "further define" terms used in the Attachment. Past allowance of audit teams to allow registered entity definitions, e.g. "annual," was to address gaps in standards until the standards could be revised. If this is truly the intent of the SDT, then requirement R1 would need revision such as: "The Operating plan shall define what a suspected intentional human action is." Cowlitz respectfully requests that ambiguity be avoided.----- Cowlitz notes that Distribution Providers are listed in the Applicability Section with no qualifiers. Cowlitz points out that there is no requirement in the Statement of Compliance Registry Criteria for Distribution Providers to own or operate BES Facilities, own or operate UFLS or UVLS of 100 MW, or to have load exceeding 200 MW. DP's that cannot meet any of the thresholds of Attachment 1 would still need an Operating Plan under R1 and annually validate the possibly null contact list in its OP under R3. Cowlitz requests that DPs that cannot meet the thresholds of Attachment 1 be removed from the Applicability Section. Not doing so will increase compliance risk without any reliability return.

Group

Tacoma Public Utilities

Chang Choi

Yes

No

Regarding the Severe VSL for R1, the reference to "Parts 1.1 and 1.2" appears to be outdated. For R2, change "the Responsible Entity failed to submit an event report...to X entity(ies) within 24 hours" to "the Responsible Entity failed to submit an event report...to only X entity(ies) within 24 hours." (Add 'only.')

Why does the text "...but is not limited to..." in M1 have to be included? Does this mean that there are unwritten requirements that an auditor might look for? What if, in trying to validate contact information, contacts do not confirm their information? Regarding the Loss of firm load row in Attachment 1, an exception should be made for weather or natural disaster related threats in the Threshold for Reporting. Regarding the Transmission loss row in Attachment 1, it is not quite clear which types of BES Elements would meet the Threshold for Reporting. Is it just lines, buses, and transformers? What about reactive resources? What about generators that unexpectedly trip offline during a fault on the transmission system?

Individual

Chantel Haswell

Public Service Enterprise Group

Yes

Yes

None additional

Individual

Mike Hirst

Cogentrix Energy

Yes

No

The VRF for R2 should be "Lower" instead of "Medium" since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be "Lower" instead of "Medium" since it is an administrative requirement.

Overall: The standard makes good stride in eliminating the redundancy of CIP-001 and EOP-004. M1 States: "... and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1".

It is an unclear in the statement that the protocols go with Attachment 1 and entities to receive report are part of Attachment 2 While this draft is an improvement on the previous draft, the proposed R2 is unacceptable, and should be amended to, at a minimum, require reporting by the end of the next business day, instead of within 24 hours. Events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator's burden, which reduces the operator's effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. For some event types where in order to provide real time situational awareness over a wide area (for example coordinated sabotage event) it may be appropriate to have more timely reporting. If the intent of this standard is to address sabotage reporting there needs to be an understanding of the actions to be taken by those receiving the reports so the reporting entities can incorporate those actions into their plan. As a minimum, NERC should have a process in place to assess the reports and take appropriate actions. Attachment 1: Threshold for reporting should not be defined such that multiple reports would be required for the same event. For example, both the TOP and RC being required to report the outage of a transmission line. 2nd event type (Damage or destruction of a Facility): Add the following sentence to the Threshold for Reporting: "Do not report theft or damage unless it degrades normal operation of a Facility." 4th event type (Physical threats to a BES control center): The term "BES control center" needs to be clarified. 5th, 6th, and 7th event types: In instances where a reliability directive is issued, is the "initiating entity" the entity that issues the directive or the entity that carried out the directive. 9th event type (Voltage deviation on a Facility): Change "nominal" to "expected or scheduled." 15th event type (Transmission loss): It is not clear what is meant by "contrary to design." This is so broad that it could be interpreted as requiring reporting misoperations within the reporting time frame before even an initial investigation can begin. This needs to be clarified and tied to the impact on the reliability of the BES.

Individual  
 Dave Willis  
 Idaho Power Co.

Yes  
 Yes

Individual  
 Michelle R D'Antuono  
 Ingelside Cogeneration LP

Yes  
 Ingleside Cogeneration believes that an annual validation of contact information is sufficient for a reporting procedure. R2 provides sufficient impetus for Responsible Entities to keep their Operating plan current – as a missed report will lead to a violation. Furthermore, external agencies and law enforcement officials will be reluctant to participate in validation tests, as dozens of nearby BES entities will overwhelm them with such requests.

Yes

Individual  
 Howard Rulf  
 Wisconsin Electric Power company dba We Energies

Yes  
 Yes

Damage or destruction of a Facility, Damage or destruction of its Facility that results from actual or suspected intentional human action.: By the Functional Model, I do not believe the BA function has Facilities by the NERC Glossary definition.. This would not apply to a BA. The line above this would adequately cover BA reporting. Remove a BA from applicability for this line. Physical threats to a Facility: The BA function does not have Facilities. Remove a BA from applicability for this line. There could be a separate line for Physical Threats to a Facility within an RC, FOP, BA Area as there is for Damage or Destruction of a Facility. Voltage deviation on a Facility: Please specify what voltage this is, nominal, rated, etc. This should also be > 10% deviation. Exactly at 10% could be at the edge of an allowed range.

Group

Detroit Edison
Kent Kujala
No
The requirement is too prescriptive and difficult to document. Requirement should be for annual review of Operating Plan. This allows for entity to review plan and document this the same as other Standards that require annual review (i.e. annual review blocks on documents). The requirement as written is vague and difficult to document. Annual review of reporting process is already a requirement.
No
Under VSLs for R2- We disagree with the reporting time frames. Making the time requirement as soon as 24 hours puts this reporting requirement on the real time operators. Many of the situations listed in the EOP-004 attachment are not included in the OE-417 report. The Unofficial Comment Form states the reporting obligations serve to provide input to the NERC Event Analysis Program. This program has removed the 24 hour reporting requirement and changed it to 5 business days.
"Suspicious activity" and "suspicious device" should be eliminated from Attachment 1, Event types: 'Physical threats to a Facility' and 'Physical threat to a BES Control Center'. By including 'suspicious activity' in the standard, I believe the project team went outside of the scope of the project, which was intended to be a merger of the two standards. Regarding standard CIP 001, the threshold for reporting is "Disturbances or unusual occurrences, suspected or determined to be caused by sabotage....", as its title suggested: Sabotage Reporting. Suspicious activity, which is not defined by the standard, clearly has a much lower threshold than sabotage, or even suspected sabotage. The reporting requirement of 24 hours, also increases the burden on the entity to either rush to investigate and make a determination regarding suspicious activity in less than 24 hours, or not perform due diligence and report uninvestigated "suspicious" activity, which normally turns out to not be a "Physical Threat". Suspicious activity should be duly investigated by the entity, local law enforcement, or the FBI as appropriate; and then reported if it has been determined to be a physical threat, or cannot be explained. Reporting within 24 hours will devalue the information inputted, as most cases of suspicious activity are innocuous, and the standard lacks a process of follow up, which would remove the those incidents from intelligence databases. Regarding suspicious devices, determination is usually immediate, (in less than 24 hours), and then the device would be classified as either "sabotage" or "no threat". The standard is not clear whether suspicious devices still have to be reported, even if they are immediately determined as not a "Physical Threat to a Facility or BES Control Center." Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts states: The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting." Attachment 1 in existing EOP-004-1 is much easier to follow (specifies time requirement to file). Also R2 states DOE OE-417 may be utilized to file reports, however Standard time requirement for update report is 48 hours, OE-417 has changed time requirement on updated filing to 72 hours. Difference can cause confusion and possible penalties. The real time operator must focus on maintaining system reliability. Putting unnecessary reporting obligations on RT puts more importance on the reporting structure than on maintaining reliability. Let 8/5 support personnel perform the reporting tasks and keep the 24/7 on shift operators focusing on the BES.
Individual
Melissa Kurtz
US Army Corps of Engineers
Individual
David Jendras
Ameren Services
Yes
Yes
(1) This draft refers to a number of activities in the Operations Plan that each entity is to have on hand as the primary guide of actions to be taken when an event occurs. Although there is information related to the requirements that should be included in the Operations Plan, the drafting team has not defined a structure on the format, the minimum information to be included or the direct audience for the Operations Plan. In addition, there is no guidance on the disposition, distribution of the Operations Plan which is left to the entity to determine. We request that the drafting team provide a defined structure for entities concerning the development and implementation of the Operations Plan. (2) Page 14 (Attachment 2) – Voltage Deviation of a Facility – This appears to be a contradiction to VAR-001-2 R10 for TOP which states IROL events will be corrected within 30 minutes. We request the 15 minute reporting criteria be changed to also state 30 minutes. (3) Throughout Document – "Report to the ERO and Regional Entity" – NERC and DHS established the ES-ISAC as a confidential location to report all events that happen on the BES. As these events are of a Sabotage / Disturbance nature, they should all go through the ES-ISAC both as a single location for distribution, and as a best practice that the industry has started.



(4) There seems to be some differences between the red-line and clean versions which may need some clarification. For example, (a) In the redline version, the revision history box appears to indicate the inclusion of parts of CIP-008, and in the "Clean" version this has been removed from the revision history box. (b) The red-line version includes a drawing at two places versus once in the clean version. (c) The correlation between the clean and redline documents is not very clear and there appears to be gaps in the reporting and tracking framework structure.

Individual

Michael Falvo

Independent Electricity System Operator

Yes

IESO agrees that the intent of Requirement R3 to have the Registered Entities validate the contact information in the contact lists that they may have for the events applicable to them is achieved. IESO also agrees that the elimination of conducting an annual test of the communications process and review of the event reporting Operating Plan in merging the previous R3 and R4 into this new R3 will give entities an opportunity to develop a plan that suits its business needs.

No

We agree with the VRF for R2, but have a concern over the VRFs assigned to R1 (Lower) and R3 (Medium). Having an event reporting operating plan (R1) is a first step toward meeting the intent of this standard, annually validating it (R3) is a maintenance requirement which arguably can be regarded as equally important but its reliability risk impact for failure to comply should be no higher than having no plan to begin with. We therefore suggest that the VRFs for R1 and R3 be at least the same, or that R1's VRF be higher than that for R3.

The proposed implementation plan may conflict with Ontario regulatory practice respecting the effective date of the standard. It is suggested that this conflict be removed by: Moving the last part ", or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities." to right after "this standard is approved by applicable regulatory approval" in the Effective Dates Section on P.2 of the draft standard, and the proposed Implementation Plan.

Individual

RoLynda Shumpert

South Carolina Electric and Gas

Yes

Yes

Has the drafting team considered how reports from R2 tie in with reports required by the NERC Event Analysis process? It appears that reporting deadlines conflict between the two. The SDT should clarify that the event types "Damage or Destruction" listed in attachment 1 do not pertain to "cyber events", to avoid duplication of the CIP-008 requirements.

Individual

David Revill

Georgia Transmission Corporation

Yes

Yes

GTC recommends a minor change to Attachment 2 associated with the complete loss of off-site power to nuclear generating plant. NUC-001-2 R9.3.5 describes provisions for restoration of off-site power and applies to both the Nuclear Plant Generator Operator and the applicable Transmission Entities. To maintain consistency, GTC recommends modification to this row in EOP-004-2 Attachment 2 such that the "Nuclear Plant Generator Operator" is the Responsible Entity with reporting responsibility. (A TO may not have visibility to all off-site power resources for a nuclear generating plant if multiple TO's are providing off-site power.) At a minimum, GTC recommends if the SDT believes the TO and TOP should remain involved, these entities should be limited to "TO and TOP that are responsible for providing services related to Nuclear Plant Interface Requirements (NPIRs)" which is also consistent with NUC-001-2.

Group

Southern Company

Antonio Grayson

Yes

No

The VRF for R2 should be "Lower" instead of "Medium" since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be "Lower" instead of "Medium" since it is an administrative requirement. In addition we suggest that the VSL for R1 should have a lower level VSL for an Operating Plan that may have one event type missing from the Operating Plan.

Event Type Entity with Reporting Responsibility Threshold for Reporting SOCO Comment Damage or destruction of a Facility RC, BA, TOP Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area, excluding weather or natural disaster related threats, that results in actions to avoid a BES Emergency. Damage or destruction of a Facility BA, TO, TOP, GO, GOP, DP Damage or destruction of its Facility that results from actual or suspected intentional human action. Do not report damage unless it degrades normal operation of a Facility. How does the SDT define "intentional human action?" Further, how is the phrase "suspected intentional human action" defined? This phrase is very broad. Is "intentional human action" identified as actions intended to damage facilities or does it include accidental actions by individuals? For example, if a person accidentally shot insulators off of a 230 kV line resulting in damage, would that be considered reportable "intentional human action?" In addition, what is that actual trigger for reporting? Does it require that the action has been discovered or is it from the time the event occurs? Further, 24 hours is a very brief time period -- how is an entity to conduct an investigation within that time period to determine if damage or destruction could have resulted from "actual or suspected" human action and also determine if it could have been "intentional"? In Southern's cases, and likely in other entities case, operating personnel submit the reports to the regulatory entities for events that fall under this standard. Southern is concerned, that the threshold for reporting for "Damage or destruction of a Facility" and "Physical threats to a Facility" is so broad that numerous reports would need to be filed that 1) may be a result of something that does not pose harm to reliability and should not be of interest to the regulators, and 2) would introduce additional burden to operating personnel that are monitoring the system every moment of the day. With the current proposed "Threshold for Reporting", the reporting requirement would hamper the ability of system operating personnel to perform their core real-time system operator tasks which would harm reliability. Physical threats to a Facility BA, TO, TOP, GO, GOP, DP Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility. OR Suspicious device or activity at a Facility. Do not report theft unless it degrades normal operation of a Facility. Please provide some clarity as to what is considered suspicious activity. For example, would someone taking a photo of a BES substation fall into this category? Please provide examples of what may be considered suspicious activity and how NERC and others may use this information and what actions they would take as a result of receiving this information. In addition, what is that actual trigger for reporting? Is it when the threat is discovered or from when it should have or could have been discovered? Further, 24 hours is a very brief time period -- how is an entity to conduct an investigation within that time period in order to determine if the physical threat has the potential to degrade the normal operation of the Facility or that the "suspicious activity"? Physical threats to a BES control center RC, BA, TOP Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center. OR Suspicious device or activity at a BES control center. BES Emergency requiring public appeal for load reduction Initiating entity is responsible for reporting. Public appeal for load reduction event. It is unclear which entity would be responsible for reporting this event. For example, if the RC/TOP/BA were to identify the need to do this and instruct an LSE to issue the public appeal, who would report the event? BES Emergency requiring system-wide voltage reduction Initiating entity is responsible for reporting System wide voltage reduction of 3% or more. It is unclear which entity would be responsible for reporting this event. For example, if the RC were to identify the need to do this and instruct a TOP to reduce voltage, who would report the event? BES Emergency requiring manual firm load shedding Initiating entity is responsible for reporting Manual firm load shedding  $\geq 100$  MW. BES Emergency resulting in automatic firm load shedding DP, TOP Automatic firm load shedding  $\geq 100$  MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS). Voltage deviation on a Facility TOP Observed within its area a voltage deviation of  $\pm 10\%$  of nominal voltage sustained for  $\geq 15$  continuous minutes. Please change "nominal" to "expected" or "scheduled" IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only) RC Operate outside the IROL for time greater than IROL Tv (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only). Loss of firm load BA, TOP, DP Loss of firm load due to equipment failures/system operational actions for  $\geq 15$  Minutes:  $\geq 300$  MW for entities with previous year's demand  $\geq 3,000$  MW OR  $\geq 200$  MW for all other entities This should not be as a result of weather or natural disasters. System separation (islanding) RC, BA, TOP Each separation resulting in an island  $\geq 100$  MW Generation loss BA, GOP Total generation loss, within one minute, of  $\geq 2,000$  MW for entities in the Eastern or Western Interconnection OR  $\geq 1,000$  MW for entities in the ERCOT or Quebec Interconnection Complete loss of off-site power to a nuclear generating plant (grid supply) TO, TOP Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement Transmission loss TOP Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing). Unplanned BES control center evacuation RC, BA, TOP Unplanned evacuation from BES control center facility for 30 continuous minutes or more. Complete loss of voice communication capability RC, BA, TOP Complete loss of voice communication capability affecting a BES control center for 30 continuous minutes or more. Complete loss of monitoring capability RC. BA. TOP Complete loss of monitoring capability affecting a BES control center for 30

continuous minutes or more such that analysis capability (i.e., State Estimator or Contingency Analysis) is rendered inoperable. Guideline and Technical Basis Comments In the Summary of Key Concepts section of the Guideline and Technical Basis, the DSR SDT explains that the proposed Standard does not include any real-time operating notifications for events listed in Attachment 1. The DSR SDT should consider language in the Standard which codifies this approach. Southern Company notes that the proposed standard does not mention any exclusion of real-time notification. The Law Enforcement Reporting section of the Guideline and Technical Basis unintentionally expands on the purpose of the Standard by stating that "The Standard is intended to reduce the risk of Cascading events." The stated purpose of the Standard is "To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities." The phrase in the Guideline should be removed or modified in order to avoid any uncertainty about the Standard's purpose. The DSR SDT should consider integrating the content of the Concept Paper into the Guideline and Technical Basis. Presently, the Concept Paper appears as an add-on at the end of the document. When the Concept Paper existed as a stand-alone document, various segments such as "Introduction" and "Summary of Concepts and Assumptions" were helpful to stakeholders and standards developers. The revised merged document in the present draft does not need two separate sections addressing concepts nor does it need an introduction at the midway point. Additionally, two other areas are either duplicative or contribute to ambiguity within the supplemental information. First, it is not clear that the segment on Concepts and Assumptions includes any actual assumptions. The section should be modified or deleted to address this concern. Second, the segment entitled 'What about sabotage?' seems to contain topics similar to those on the first page of the Guideline. Again, the DSR SDT should consider integrating all of the necessary information into a more comprehensive document.

Individual

Andrew Gallo

City of Austin dba Austin Energy

Yes

Yes

(1) City of Austin dba Austin Energy (AE) requests that the SDT clarify whether R3 requires that each Registered Entity subject to EOP-004-2 verify NERC's contact information each year. It appears this would be overly burdensome for NERC to respond to individual requests. (2) AE also asks that NERC's fax number be included in the contact information at the beginning of Attachment 1 and at the Event Reporting Form in Attachment 2. NERC included the fax number as a viable contact method in its recent NERC Alert notifying the industry of the changed information. (3) AE requests that the SDT increase the threshold for reporting loss of firm load to  $\geq 300$  MW for all entities to align the reporting threshold with the OE-417 threshold. Otherwise, smaller entities would have to report firm load losses between 200 and 299 MW to NERC but not to the DOE. This could be administratively confusing to those responsible for reporting. (4) Attachment 1 lists the threshold for reporting generation loss at  $\geq 1,000$  MW for the ERCOT Interconnection. ERCOT planning is based on a single contingency of 1,375 MW. For this reason, AE believes the minimum threshold for a disturbance should be greater than the single contingency amount of  $>1,375$  MW for the ERCOT Interconnection.

Individual

Andrew Z.Pusztai

American Transmission Company

Yes

Yes A. ATC requests that the Standards Drafting Team address the following concerns and clarifications in Attachment 1: a.) Reporting event #14 in Attachment 1, is duplicative with respect to Nuclear Reliability Standard NUC-001-2.1 R 9.4.4. Reporting event #14 requires entities to report to NERC a "Complete loss of off-site power to a nuclear generating plant" while Nuclear Reliability Standard NUC-001-2.1 R9.4.4., i.e. includes "Provisions for supplying information necessary to report to government agencies, as related to Nuclear Plant Interface Requirements (NPIRs)". In addition, ATC believes the reporting related to event #14 in Attachment 1 is not a "reliability" issue, and more appropriately covered under Standard NUC-001 as a "Nuclear Safety Shutdown" issue. Therefore, ATC recommends that Item #14 in Attachment 1 of EOP-004-2 be deleted. b.) In Attachment 1, reporting event #2, i.e. Damage or destruction of a Facility" could obligate an entity to report any loss of copper grounds either on a T-Line or grounds associated with a transformer or breakers. ATC believes this does not rise to a reporting level such as NERC. ATC believes that additional qualifying language similar to reporting item #1 be incorporated into the threshold and read as follows: "Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency." c.) In Attachment 1, reporting event #3 i.e. "Physical threats to a Facility" needs clarification since a physical threat needs to be actual and confirmed so that the TO or TOP repositions the system. In addition, the SDT needs to clarify what the phrase "normal operations" means. Is this a ratings issue? Or a result in how the Operator operates the system. d.) In Attachment 1, reporting event #3 threshold i.e. "Suspicious device or activity at a Facility" needs clarification to

determine when it raises to the level of reporting. These words could be interpreted in several different ways. In addition, ATC believe that language needs to be added that the threat causes the reporting entity to change to an abnormal operating state. ATC recommends the threshold be revised to read: "Suspicious device or activity at a Facility with the potential to degrade the normal operation of the Facility". e.) In Attachment 1, the term "Initiating entity" is used three times for reporting events and needs to be clearly defined or reworded. Is it the entity that identifies the needs of a Public Appeal or the entity that makes the public appeal the initiating entity? The Standard needs to be clear on who has the responsibility as the "initiating" party, especially when multiple parties may be involved. ATC recommends the following: 1) For public appeal, under Entity with Reporting Responsibility; it is the "entity that issues a public appeal to the public" 2) For system wide voltage reduction, under Entity with Reporting Responsibility; it is the "entity that activates a voltage reduction" 3) For manual load shedding, under Entity with Reporting Responsibility; it is the "entity that activates manual load shedding" f.) In Attachment 1, reporting event #15 i.e. "Transmission Loss", the threshold includes the phrase "contrary to design". ATC recommends this be clarified to read "contrary to protection system design". B. In EOP-004-2 Requirement 2/ Measure 2 both have the following language: "Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting." ATC recommends adding "upon recognition" as a starting point to the 24 hour reporting requirement. This would be revised to read: "Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of an event type threshold"

Group

SERC OC Standards Review Group

Gerry Beckerle

Yes

No

The VRF for R2 should be "Lower" instead of "Medium" since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be "Lower" instead of "Medium" since it is an administrative requirement.

While this draft is an improvement on the previous draft, the proposed R2 is unacceptable, and should be amended to, at a minimum, require reporting by the end of the next business day, instead of within 24 hours. Events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator's burden, which reduces the operator's effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. For some event types where in order to provide real time situational awareness over a wide area (for example coordinated sabotage event) it may be appropriate to have more timely reporting. If the intent of this standard is to address sabotage reporting there needs to be an understanding of the actions to be taken by those receiving the reports so the reporting entities can incorporate those actions into their plan. As a minimum, NERC should have a process in place to assess the reports and take appropriate actions. Attachment 1: Threshold for reporting should not be defined such that multiple reports would be required for the same event. For example, both the TOP and RC being required to report the outage of a transmission line. 2nd event type (Damage or destruction of a Facility): Add the following sentence to the Threshold for Reporting: "Do not report theft or damage unless it degrades normal operation of a Facility." 4th event type (Physical threats to a BES control center): The term "BES control center" needs to be clarified. 5th, 6th, and 7th event types: In instances where a reliability directive is issued, is the "initiating entity" the entity that issues the directive or the entity that carried out the directive. 9th event type (Voltage deviation on a Facility): Change "nominal" to "expected or scheduled." 15th event type (Transmission loss): It is not clear what is meant by "contrary to design." This is so broad that it could be interpreted as requiring reporting misoperations within the reporting time frame before even an initial investigation can begin. This needs to be clarified and tied to the impact on the reliability of the BES. The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review Group only and should not be construed as the position of SERC Reliability Corporation, its board, or its officers.

Group

FirstEnergy

Larry Raczkowski

Yes

Yes

FirstEnergy Corp (FE) appreciates the work done by the SDT by incorporating the comments and revisions from the previous draft. FE would like to see the time parameters in Requirement 3 and Measure 3 to be changed from "each calendar year" to "at least once every 12 months". This is similar to the wording that is being used in the CIP standards

Individual
Don Schmit
Nebraska Public Power Disstrict
Group
Dominion
Mike Garton
Yes
Dominion supports the combination of Requirements R3 and R4 into a single requirement (Requirement R3), although we remain concerned that validation requiring a phone call could be perceived as a nuisance by that entity.
Dominion reads Requirement R1 as explicitly requiring only the inclusion of reporting to the ERO in the Operating Plan. We acknowledge that the requirement also contains additional entities in parenthesis which infers the inclusion of a larger group (and which appears to be supported by the rationale box). Dominion suggests the SDT explicitly state which entities, at a minimum, be included, for reporting, in the Operating Plan. We suggest adding a column to Attachment 1 and including entities to which the event must be reported. As an examples; • All event types should include local law enforcement • Events for which the BA, RC, TOP bear responsibility should probably also be reported to the regional entity • Events for which the Facility Owner bears responsibility should probably also be reported to the respective BA and TOP, who would in turn determine whether to notify their respective RC. The RC would in turn determine if additional entities need to be contacted Requirement R2 establishes a 24 hour reporting threshold; however, the "NOTE" provided on Attachment 1 seems to contradict Requirement 2 and could therefore lead to compliance issues. Dominion suggests that Requirement R2 be revised to agree with the "NOTE" on Attachment 1. For example, Requirement R2 could be reworded as: Except as noted on Attachment 1, Each Responsible Entity shall... Also under the "NOTE" in Attachment 1, why has the facsimile number for the ERO been removed? The DOE still provides a facsimile number for reporting. Attachment 2: Event Reporting Form #4; need to update the below to reflect the same naming convention of the events in Attachment 1, the "t" should not be capitalized in Physical Threat and add an 's' behind threat. Add (islanding) behind System separation and capitalize the 'U' in unplanned control center evacuation.
Group
MRO NSRF
WILL SMITH
Yes
The NSRF requests that the SDT address the following concerns and clarifications in Attachment 1; 1) Please explore redundancy reporting event Item #14; Complete loss of off-site power to a nuclear generating plant with obligations of NUC-001-2.1 R9.4.4."Provisions for supplying information necessary to report to government agencies, as related to NPIRs." The NSRF understands the importance concerning safety issues with a nuclear plant. A multiple unit coal facility may have a larger reliability impact to the BES than a nuclear plant. The SDT is stating that the fuel source is a reporting issue, not the reliability of a plant loosing off sight power. Recommend that this item be deleted. 2) Item 2 in Attachment 1 would obligate an entity to report any loss of (copper) grounds either on a T-Line or grounds associated with a transformer or breakers and that this level of reporting should not rise to the NERC level. Believes that additional qualifying language similar to Item 1 be incorporated into the threshold and read as follows: "Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency." 3) Item 3 Attachment 1 needs clarification since a physical threat needs to be actual and confirmed so that the TO or TOP repositions the system. In addition, the SDT needs to clarify what the phrase "normal operations" means. (Is this a ratings issue? or a result in how the System Operator operates the system.) 4) Item 3 should provide clarification as to "Suspicious device or activity at a Facility" to determine when threshold raises to the level of reporting. We are concerned that, based on an Auditors perception, these words could be interpreted in several different ways. In addition, we believe that language needs to be included that the threat causes the reporting entity to change to an abnormal operating state. This situation could be interpreted differently by the auditor or the entity at the time of the event. Recommend the following language: "Suspicious device or activity at a Facility with the potential to degrade the normal operation of the Facility". This language is similar to the first threshold. 5) The term Initiating entity is used three times within Attachment 1 and needs to be more clearly defined or reworded. Is it the entity that identifies the needs of a Public Appeal or the entity that makes the public appeal the initiating entity? The word "initiating" does not provide clarity but only provides uncertainty to the industry. The Standard needs to be clear on who has the responsibility as the "initiating". Recommend the following: a. For public appeal, under Entity with Reporting Responsibility; "entity that issues a public appeal to the public" b. For system wide voltage reduction, under Entity with Reporting Responsibility; "entity that activates a voltage reduction" c. For manual load shedding, under Entity with Reporting Responsibility; "entity that activates manual load shedding" 6) The NSRF recommends transmission loss to read as : "contrary to protection svstem desian" found in threshold for reporting within the Attachment for

a Transmission loss event. In Requirement 2/ Measure 2, recommend adding "upon recognition of " as a starting point to the 24 hour reporting requirement, within the threshold of reporting where perceived threats are the threshold, or transmission loss, when contrary to design is determined.

Individual

Terry Harbour

MidAmerican Energy

Yes

No

Change the VRFs / VSLs to match suggested changes in Question 3

Yes. 1) MidAmerican Energy agrees with and supports MRO NSRF comments. 2) Add additional wording to clearly provide for compliance when events are found more than 24 hours after an event. Add the following to the end of R2. Add, Events not identified until sometime later after they occurred shall be reported within 24 hours. 3) In R3 add "external" for R3 to read Validate "external" contact information. 4) In EOP-004-2 Attachment 1 – the wording "Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency" is not specific or measureable and therefore ambiguous. Zero defect standards which carry penalties must be specific. Please reword to "Intentional human action to destroy a NERC BES facility whose loss could result in actions to avoid a BES Emergency". This clearly aligns with the EOP-004 intent of sabotage and emergency reporting. EOP-004 should not report on unexpected conditions such as when a system operator attempts to reclose a line during a storm believing the line tripped for a temporary fault due to debris, when in fact the fault was permanent and damaged a transformer.

Individual

Kathleen Goodman

ISO New England Inc.

Individual

d mason

City and County of San Francisco - Hetch Hetchy Water and Power

No

Measure M3 specifically identifies two types of acceptable compliance evidence: Voice Recording and Log entries. Specifying only these two forms of evidence creates a risk that some auditors will reject other forms of R3 compliance evidence which are equally valid, such as emails or written call records. Although M3 states that acceptable evidence is not limited to Voice Recordings or Log Entries, we have concern that other methods of complying with R3 may not be accepted.

Individual

Tracy Richardson

Springfield Utility Board

Yes

Yes

Individual

Rich Salgo

NV Energy

No

Without further clarification of what is expected by "validate all contact information" I cannot support this requirement. On the surface, "validate" appears to be acceptable terminology, as it means to me a review of the contact names and contact information (perhaps cell #, home phone, text address, email address, etc) that would be evidenced through an attestation of completion of review along with records showing the updates made to the contact information pursuant to the review. However, when the Measure is considered, it refers to evidence such as operator logs, voice recordings, etc. This seems to indicate that the expectation is that each contact is tested, by dialing, texting, emailing, etc with some sort of confirmation that each contact was successful. If this is what is necessary to satisfy the "validate" requirement, I believe it is excessive, burdensome and unnecessary. I suggest modification of the Measure language to clearly allow for an entity to demonstrate compliance by a showing that it reviewed the contact information and made changes as deemed necessary by its review, and to remove the reference to operator logs and voice recordings as the evidence of measure.

Aside from the comment referring to the new R3 and the term "validate", I applaud the SDT for the improvements made in the remainder of the Standard. This is a much simpler and straightforward approach to meeting the directives in this project and greatly simplifies the processes necessary on the part of the registered entities.
Individual
Thad Ness
American Electric Power
No
In the spirit of Paragraph 81 efforts, we request the removal of R3 as it is solely administrative in nature, existing only to support R2. This is more of an internal control and does not appear to rise to the level of being an industry-wide requirement. In addition, having two requirements rather than one increases the likelihood of being found non-compliant for multiple requirements rather than a single requirement.
No
In the spirit of Paragraph 81 efforts, we request the removal of R1. R1 is administrative in nature, existing only to support R2. Reporting an event externally might necessitate the need for a plan/procedure/policy/job aide, but requiring it is an overreach. Having two requirements rather than one increases the likelihood of being found non-compliant for multiple requirements rather than a single requirement. The Paragraph 81 project team has already recommended removing the requirement to have contact information with law enforcement from CIP-001 R4. Notwithstanding our comments above, we recommend removing the phrase "and other organizations..." from R1. If this requirement is to remain, it needs to be very specific regarding who needs to be included in the reporting. R2 – We recommend removing "per their Operating Plan" from R2 so it reads "Each Responsible Entity shall report events within 24 hours of meeting an event type threshold for reporting." If an entity deviates from its plan but still meets the intent of the requirement (e.g. reporting to NERC with 24 hours), this could be viewed as a finding of non-compliance. We need to get away from "compliance for compliance's sake", and focus solely on those efforts which will benefit the reliability of the BES. Attachment 1 Page 13, Row 1 (Clean Version): This is too open-ended and would likely lead to voluminous reporting. As it currently reads, "Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency" could bring all copper thefts into scope. Thefts should not need to be reported unless the theft results in reliability concerns as specified by other criteria or parameters in Attachment 1. Attachment 1 Page 13, Row 2 (Clean Version): The threshold "Damage or destruction of its Facility that results from actual or suspected intentional human action" should be eliminated entirely. For the event Damage or destruction of a Facility, the threshold for reporting is set too low. Attachment 1 Page 13, Row 3 (Clean Version): We suggest modifying the text to read "Do not report theft... unless the theft results in reliability concerns as specified by other criteria or parameters in Attachment 1." Attachment 1 Page 14, Row 4 (Clean Version): Regarding "Loss of Firm Load", we suggest making it clear that the MW threshold is an aggregate value for those entities whose TOP is responsible for multiple operating companies or legal entities. In addition, is it necessary to include the DP as an entity with reporting responsibility? Its inclusion could create confusion by further segmenting the established threshold. Attachment 1 Page 15, Row 1 (Clean Version): Including "Transmission loss" as currently drafted would result in much more reporting than is necessary or warranted. As currently drafted, it could bring more events into scope than intended, especially for larger entities. EOP-004 Attachment 2: Event Reporting Form: AEP remains concerned that industry would be required to report similar information to multiple Federal entities, in this case to both NERC (Attachment 2) and the DOE (OE-417). In addition, the reporting requirements are not clear for every kind of event as to which entity the reports must be forwarded to, and it is unclear how information would be passed to other entities as necessary. EOP-004 Attachment 2: Event Reporting Form: This form is a further example of mixing security concepts with operational concepts. Not only is not advisable, it does not serve the interests of either concept.
Individual
Charles Yeung
Southwest Power Pool RTO
Yes
No
We question the reliability benefits of this requirement.
Individual
Nathan Mitchell
American Public Power Association
Yes

Yes
As stated in our comments on the previous draft: It is APPA's opinion that this standard should be removed from the mandatory and enforceable NERC Reliability Standards and turned over to a working group within the NERC technical committees. Timely reporting of this outage data is already mandatory under Section 13(b) of the Federal Energy Administration Act of 1974. There are already civil and criminal penalties for violation of that Act. This standard is a duplicative mandatory reporting requirement with multiple monetary penalties for US registered entities. If this standard is approved, NERC must address this duplication in their filing with FERC. This duplicative reporting and the differences in requirements between DOE-OE-417 and NERC EOP-004-2 require an analysis by FERC of the small entity impact as required by the Regulatory Flexibility of Act of 1980
Group
Bonneville Power Administration
Chris Higgins
Yes
BPA agrees with the revision and recognizes that it will involve a large amount of validation workload for entities with a large footprint.
No
BPA does not agree with the VRFs and VSLs. BPA believes that the violation levels for administrative errors are too high. For more information, please reference comments to question #3.
The proposed standard does not have any oral reporting option for system operators and thus appears to be administrative in nature. Due to this and the fact that administrative staff are not available on weekends, the "24 hour" reporting requirements should be modified to "Next Business Day" to allow for weekend delays in reporting. BPA believes that there are too many minor events that have to be reported within 24 hours. Reporting during the next business day would suffice. Some examples include: A 115 shunt capacitor bank failure for the first event type does not seem important enough to require reporting within 24 hours just because action has to be taken to raise generation or switching of line. A failure of a line tower that has proper protective action to clear the line and also has automatic (SPS) to properly protect as designed the BES system (a good normal practice) from overloads or voltage issues does not seem important enough to require reporting within 24 hours either.
Individual
Don Jones
Texas Reliability Entity
Yes
No
(1) VSLs for R1 should have a lower level VSL if the event reporting Operating Plan fails to include one or more of the event types listed in Attachment 1. (2) VSL for R1 is incorrectly stated as there are no "parts" to R1.
(A) Regional Entity should be capitalized in R1. (B) COMMENTS ON ATTACHMENT 1: In the previous comment period on this Standard, Texas RE submitted comments that we feel were not adequately addressed. There were several responses to comments regarding the Events Table that need deeper review and consideration: (1) In the Events Table, under Transmission Loss, the SDT indicated that reporting is triggered only if three or more Transmission Facilities operated by a single TOP are lost. Also, generators that are lost as a result of transmission loss events must be included when counting Facilities. As Texas RE indicated in previous comments to this Standard, determining event reporting requirements by the entity that owns/operates the facility is not an appropriate measure. If the industry wants to learn from events, these types of issues must be addressed. Including the RC as one of the Entity(s) with Reporting Responsibility may alleviate this concern. The RC would have overall view of the system and could provide the reports on multi-element events where the elements are owned/operated by different entities. For the SDT to believe that "There may be times where an entity may wish to report when a threshold has not been reached because of their experience with their system" is worthy to note but falls short of the reliability implications caused by those entities that will not report. The industry needs to learn from events and failure to report will facilitate failure to learn. (2) In the Events Table, under Transmission Loss, there has been considerable discussion recently within the Events Analysis Subcommittee (EAS) regarding the definition of the phrase "contrary to design." The EAS is currently working on possible guidelines to interpret this event type. The SDT may want to consider including the EAS language into the Guidelines and Technical Basis for this Standard. (3) In the Events Table, under "Unplanned BES Control Center evacuation" and "Complete loss of voice communication capability," and "Complete loss of monitoring capability," GOPs should be included. GOPs also operate control centers that would be subject to these kinds of occurrences. As Texas RE indicated in previous comments to this Standard, in CIP-002-5 Attachment 1 there is a "High Impact Rating" for the following: "1.4 Each Control Center, backup Control Center, and associated data centers used to perform the functional obligations of the Generation Operator that includes control 1) for generation equal to or greater than an aggregate of 1500 MW in a single Interconnection or 2) that includes control of one or more of the generation assets that meet criteria 2.3, 2.6, and 2.9." In the ERCOT Region, we experienced an event where a GOP control



center lost an ICCP link that carried real-time information regarding its generation fleet (over 10,000 MWs). Without inclusion of the GOP here the event may not get recorded. While it was a "virtual" loss, the impact to the BES through generation control actions could be significant and the event should be reported and analyzed. For the GOP control centers that do exist, the reporting of such events should be a requirement. Based on the minimum of these two examples, why would the SDT NOT include GOP as being applicable? (4) In the Events Table, under "BES Emergency requiring public appeal for load reduction," the definition of Emergency is "Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities...." Is it the intent of the SDT to exclude public appeals issued in anticipation of a possible emergency, before a BES Emergency is officially declared? (5) In the Events Table, under "BES Emergency resulting in automatic firm load shedding," the SDT may want to consider including the RC as one of the Entity(s) with Reporting Responsibility. The RC would have overall view of the system and should provide the reports on events where the multiple entities may be involved. We have UVLS schemes in our region where the total MW shed is greater than 100 MW, but the individual TOP MW shed is less than 100 MW. (6) In the Events Table, consider whether the item for "Voltage deviation on Facility" should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator or power system stabilizer) could have a similar impact on the BES as other reportable items. Note: We made this comment last time, and the SDT's posted response was non-responsive to this concern. The SDT noted "Further, we note that such events do not rise to the level of notification to the ERO" but the SDT failed to recognize that "Voltage deviation on a Facility" does exactly that - notifies the ERO but from a TOP perspective only. Texas RE is trying to establish the correct Responsible Entity for reporting "Voltage deviation on a Facility" (in this case a generator regardless of the cause and other obligations the owner may have with other Reliability Standards).

Individual

Christine Hasha

ERCOT

Yes

ERCOT considers replacing R3 and R4 with the new R3 is an improvement and we thank the drafting team for making the change.

No

Since EOP-004 is related to ex-post reporting, which has nothing to do with operational or planning risk, this is an administrative requirement and, accordingly, the VRFs should all be Low. This would mean lowering the VRF for R2 and R3 to Low. The third component of the Severe VSL for R2 is more severe than the other two components. In an attempt to be more consistent across all the VSLs, we propose the following for the High VSL for R2: The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours after meeting an event threshold for reporting. OR The Responsible Entity failed to submit an event report (e.g., written or verbal) to three or more entities identified in its event reporting Operating Plan within 24 hours. ERCOT proposes that the first two components of the Severe VSL for R2 be deleted and replaced with: The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.

As a general matter, this standard imposes an ex-post reporting obligation. Consistent with the ongoing P 81 standard review/elimination effort, this standard is arguably a candidate for elimination under the principles guiding that effort. The obligation proposed in the standards are better suited for inclusion in the Rules of Procedure or as a guideline because they are strictly administrative in nature. To the extent the SDT continues to pursue this effort, ERCOT offers the following additional comments. ERCOT has commented on the listing in the Entity with Reporting Responsibility column of Attachment 1. Consistent with those prior comments, the current version still fails to adequately create a bright line threshold for particular events. For example, in the Transmission loss event, although the TOP is listed, there is no direction regarding which TOP is required to file the event report. Is it the TOP in whose TOP area the loss occurred or is it a neighboring TOP who observes the loss? Clearly, the responsibility for reporting lies with the host system, but that responsibility is not clearly designated. There are several other similar events where there is no bright line. We suggest that the drafting team return the deleted language to the Entity with Reporting Responsibility column in those instances where the current version fails to provide a bright line in the Threshold column. Regarding multiple reports for a single event, that aspect of the proposed draft should be revised to only require a single report. While additional information may be available from others, let the Event Analysis team perform their function. This would eliminate the redundant reporting that is currently required as the standard is written. ERCOT requests that the reference to "cyber attack" be removed from the Guideline and Technical Basis section of the document since all reporting of cyber events has been removed from the standard and retained in CIP-008.

Individual

Denise M. Lietz

Puget Sound Energy Inc.

Yes

Puget Sound Energy appreciates the Standard Drafting Team's work to streamline and clarify the proposed

standard. In addition, we understand that the Standard Drafting Team faces a significant challenge in developing workable thresholds for reporting under this standard. Unfortunately, Puget Sound Energy cannot support the proposed standard because the reporting thresholds remain too vague and, thus, too broad - especially those related to damage or destruction of a Facility and those related to physical threats. The first four events listed on Attachment 1 are not brightline rules, because they each involve significant elements of judgment and interpretation. An example of our concern relates to the phrase "... that results from actual or suspected intentional human action." Puget Sound Energy, like many regulated entities, is staffed only with System Operators at night and on weekends. As a result, the 24-hour reporting requirement necessarily requires the System Operators to submit the required reports. So, how is a System Operator going to judge whether a human action is "intentional"? As a result, it will be necessary to report any event in which human action is involved because there is no way for a System Operator to know for sure whether the action is intentional or not. And, regulated entities will need to instruct their System Operators to make such reports, because the failure to submit a report of even one event listed in EOP-004 Attachment 1 is assigned a severe VSL under the proposed standard. We believe that the proposed threshold language will likely result in a flood of event reports that will not improve situation awareness.

Group

CenterPoint Energy

Daniela Hammons

No

CenterPoint Energy supports the concept of combining Requirements R3 and R4; however, the Company still prefers an annual review requirement which would include validating the contact information and content of the Operating Plan overall. Therefore, CenterPoint Energy recommends the following revised language for Requirement R3: "Each Responsible Entity shall review and update the Operating Plan at least every 15 months." The Company also suggests that the Measure be worded as follows: "Evidence may include, but is not limited to dated documentation reflecting changes to the Operating Plan including updated contact information if necessary."

No

CenterPoint Energy suggests that the phrase "which caused a negative impact to the Bulk Electric System" be added to each Violation Severity Level. For example, the wording would appear as follows: "The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 24 hours but less than or equal to 36 hours after meeting an event threshold for reporting which caused a negative impact to the Bulk Electric System". Additionally or alternatively, the Company proposes that the above phrase be added to the Threshold(s) for Reporting in Attachment 1 to focus on events that have an impact or effect on the Bulk Electric System.

CenterPoint Energy appreciates the revisions made to the draft Standard based on stakeholder feedback and believes that the changes made are positive overall. However, the Company recommends the additional changes noted below for a favorable vote. In the Rationale for R1, CenterPoint Energy recommends that the 2nd sentence in the 1st paragraph be revised as follows, "In addition, these event reports may serve as input to the NERC Events Analysis Program.", as not all events listed in Attachment 1 will serve as input in to the NERC Events Analysis Program. CenterPoint Energy also proposes that the Standard Drafting Team (SDT) add "There cannot be a violation of Requirement R2 without an event." as noted in the Consideration of Issues and Directives to the Requirement. For Attachment 1, CenterPoint Energy recommends the following revisions: CenterPoint Energy continues to be concerned that the uses of the terms "suspicious" and "suspected" are too broad. The Company proposes that the SDT remove the terms from the Thresholds for Reporting or add "which caused a negative impact to the Bulk Electric System" or "that causes an Adverse Reliability Impact..." to each phrase where the terms are used. CenterPoint Energy proposes that the threshold for reporting the event, "BES Emergency requiring manual firm load shedding" is too low. It appears the SDT was attempting to align this threshold with the DOE reporting requirement. However, as the SDT has stated, there are several valid reasons why this should not be done. Therefore, CenterPoint Energy recommends the threshold be revised to "Manual firm load shedding  $\geq$  300 MW". CenterPoint Energy also recommends a similar revision to the threshold for reporting associated with the "BES Emergency resulting in automatic firm load shedding" event. ("Firm load shedding  $\geq$  300 MW (via automatic under voltage or under frequency load shedding schemes, or SPS/RAS)") For the event of "System separation (islanding)", CenterPoint Energy believes that 100 MW is inconsequential and proposes 300 MW instead. For "Generation loss", CenterPoint Energy suggests that the SDT add "only if multiple units" to the criteria of "1,000 MW for entities in the ERCOT or Quebec Interconnection".

Individual

Maggy Powell

Exelon Corporation and its affiliates

Yes

No

R2 VSLs - By measuring the amount of time taken to report and the number of entities to receive the report, the VSLs track more with size and location than with a failure to report. For instance, an entity failing to report at all to

one entity would be deemed a lower VSL while an entity reporting to many, but failing to report to three entities would be deemed a high VSL. R3 VSL – The severe VSLs do not seem commensurate to oversight. A three month delay in validating that phone numbers are correct, for phone numbers that are accurate, does not track with a severe infraction.

Thanks to the drafting team for all the work on this revision. Significant progress was made, though Exelon has some remaining comments: • It's not clear why the team separated 'Damage or destruction of a Facility' into two rows. Please advise. • Damage or destruction of a Facility - The threshold for "damage or destruction of a Facility" is too open-ended without qualifying the device or activity as "confirmed". Event reporting for nuclear generating units are initiated when an incident such as tampering is "confirmed". EOP-004 should include some threshold of proof for a reason to believe that no other possibility exists for "damage or destruction of a facility" event other than actual or suspected intentional human action. • Physical threats to a Facility – Reporting of every "suspicious activity" such as photographing equipment or site could result in an unwieldy volume of reports and dilute the data from depicting quality insight. For example, nuclear generating units are required to report all unauthorized and/or suspicious activity to the NRC. Please confirm that the intent of this threshold for notification would include all unauthorized and/or suspicious activity. • Physical threats to a BES control center – please confirm that reporting responsibility falls to the RC, BA, TOP and not GOs. In addition, please confirm that by use of the lower case "control center" other definitions in development through other standards development projects (e.g. CIP version 5) and that may be added to the NERC Glossary will not apply until formally vetted in a future EOP-004 standards development project. • Loss of firm load – "Loss of firm load for ≥ 15 Minutes: ≥ 300 MW for entities with previous year's demand ≥ 3,000 MW". Please clarify whether the team intends for this to apply to a single event a loss of more than 300 MW due to non-concurrent multiple distribution outages that total > 300MW. • Generation loss – Exelon appreciates the timing clarification added to the generation loss threshold. The phrase "within one minute" should also be included in the threshold for the ERCOT and Quebec Interconnections to read: "Total generation loss, within one minute, of ≥ 2,000 MW for entities in the Eastern or Western Interconnection OR Total generation loss, within one minute, of ≥ 1,000 MW for entities in the ERCOT or Quebec Interconnection" • The Law Enforcement Reporting section in the Guideline and Technical Basis states: "The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of the BES from malicious physical or cyber attack." Since CIP-008 now covers reporting of cyber incidents the reference to cyber should be removed.

Group

SPP Standards Review Group

Robert Rhodes

Yes

We feel that replacing R3 and R4 with the new R3 is an improvement and we thank the drafting team for making the change.

No

Since EOP-004 is about after-the-fact reporting, we suggest that all the VRFs be Lower. This would mean lowering R2 and R3 from Medium. The third component of the Severe VSL for R2 is more severe than the other two components. In an attempt to be more consistent across all the VSLs, we propose the following for the High VSL for R2: The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours after meeting an event threshold for reporting. OR The Responsible Entity failed to submit an event report (e.g., written or verbal) to three or more entities identified in its event reporting Operating Plan within 24 hours. We propose the following, deleting the first two components as shown in the current draft, for the Severe VSL for R2: The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.

We have made previous comments in the past regarding the listing in the Entity with Reporting Responsibility column of Attachment 1. While we concur with some of the changes that the drafting team has made regarding the addition of a bright line in the Threshold for Reporting column, there remain events where there is no line at all. For example, in the Transmission loss event, the TOP is listed and there is no distinction regarding which TOP is required to file the event report. Is it the TOP in whose TOP area the loss occurred or is it a neighboring TOP who observes the loss. Clearly, the responsibility for reporting lies with the host system. There are several other similar events where the bright line is non-existent and needs to be added. We suggest that the drafting team return the deleted language to the Entity with Reporting Responsibility column in those instances where the bright line has not been added in the Threshold column. Regarding multiple reports for a single event, we again believe that only a single report should be required. While additional information may be available from others, let the Event Analysis personnel do their job investigating an event and eliminate any redundant reporting that is currently required as the standard is written. If not, this standard, if approved, would then appear to be a likely candidate for Phase 2 of the Paragraph 81 project.

Individual

Christina Bigelow

Midwest Independent Transmission System Operator, Inc.

Yes

No

MISO agrees with the comments submitted by the SERC Operating Committee that the VRFs for R2 and R3 should be "Lower" instead of "Medium," since these are administrative requirements. MISO further respectfully suggests that implementing another standard that requires reporting every incident identified in a plan within 24 hours and that classifies failure to do so a "Severe" violation, will likely cause entities to limit the scope of their plans. NERC, therefore, would not receive information that appears unimportant to a single entity but could be important in the context of similar events across the country.

MISO respectfully submits that several of the thresholds for reporting in EOP-004 – Attachment 1 should be modified to clarify when the reporting obligation is triggered, and to ensure that entities are reporting events of the type and significance intended. In particular, MISO focuses on the following draft thresholds in EOP-004 – Attachment 1: • The requirement that an entity report when "[d]amage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency." A BES Emergency is defined as "Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System." RCs and BAs take actions each and every day to "avoid a BES Emergency." At the time of those actions, they are reacting to conditions that their operating personnel are observing on the BES. There is no way for an RC or a BA to discern whether the conditions to which they reacted resulted from the "damage or destruction of a Facility" and there is no requirement for Transmission Operators and/or Owners to report "damage or destruction of a Facility" to their BA or RC. Accordingly, RCs and BAs will likely, often not be sufficiently informed to determine if their actions require them to submit a report. Responsible entities are likely to expend significant time and resources reporting daily operations and actions routinely taken to respond to observed BES conditions as they present themselves. These actions may be in response to congestion, equipment outages, relay malfunctions, etc. Whether or not the initiating factor was "damage to or destruction of a Facility" will often be an unknown factor and – even if such is known – the genesis of that damage and/or what constitutes damage (as discussed below) present further potential for confusion and over-reporting. Nonetheless, the lack of clarity in the standard is likely to result in some RCs and BAs preparing reports whether or not they definitely ascertain the underlying cause for the system conditions that prompted them to take actions "to avoid a BES Emergency." The preparation and submission of such reports, in many cases, will not facilitate the stated objective of this standard, which is the improvement of the reliability of the Bulk Electric System. In addition, with respect to damage or destruction of a Facility, it is debatable as to what would be considered "damage." For example, would an improper repair or outage that results in damage to a Facility that requires a more extended repair or outage be deemed "damage" to that Facility under this standard? These ambiguities will likely result in significant over-reporting, over-burdening responsible entities, and inundating Regional Entities and NERC with information that is not useful for the purpose of facilitating the reliable operation of the Bulk Electric System. These effects would undermine the express purpose of the standard and the potential value of information if the reporting obligations are appropriately defined, assigned, and scoped. For these reasons, MISO recommends that the SDT revise the standard to: (1) remove the requirement for RCs and BAs to report the "damage or destruction of a Facility" as it is redundant of the immediately subsequent requirement, (2) to remove reporting responsibility from BAs to report the "damage or destruction of a Facility" as this obligation is more properly placed with the TO, TOP, GO, GOP, and DP, and (3) provide guidance to the remaining responsible entities, TO, TOP, GO, GOP, and DP, regarding when "damage" to a Facility should be reported, e.g., an illustrative list of the types of "damage" that would yield information and/or trends that would facilitate the improvement of the reliability of the BES. • The requirement to report "[p]hysical threats to a Facility" and/or "[p]hysical threats to a BES Control Center" With respect to physical threats to Facilities or BES Control Centers, what is considered a "physical threat" and/or a "suspicious device or activity"? Is a crank call count that the building is on fire a physical threat? Is the return of a disgruntled employee suspicious? MISO understands and supports the reporting and analysis of threats and even certain types of suspicious activities, etc. It is merely concerned that the reporting threshold expressed in this standard will result in the reporting of substantial amounts of data that will not facilitate the improvement of the reliability of the BES and that the volume of reports may delay or otherwise obscure the detection of notable trends. Accordingly, MISO recommends that the SDT revise the standard to: (1) require the reporting only of substantial physical threats that are likely to have an adverse impact on the reliable operation of the Bulk Electric System, and (2) to provide an illustrative list of the types of "suspicious activity or devices" as guidance to responsible entities. • Timing of reports Finally, MISO respectfully suggests that NERC re-assess the timing requirements as related to the objectives expressed within this standard. MISO believes that NERC should clarify that its "situational awareness" staff will review submitted information to determine whether there are indications of possible coordinated attack and to quickly inform responsible entities that there are signals of possible coordinated attack. This clarification could be made in the standard, or the standard could describe the process that NERC staff will use. Unless such review and information is provided, the need that the standard attempts to address will not be fully met. Conversely, many of the events listed in Attachment A that require reporting do not need to be reported within 24 hours and would not offer significant benefit or value if reported within that time period as NERC and Regional Entities primarily utilize such information to capture metrics or perform after-the-fact events analysis. Accordingly, MISO respectfully suggests that, while performing analysis to determine clarifications that would result in the appropriate definition, assignment, and scope of reporting obligations, NERC should also examine the events and identify those events for which a longer time period for reporting would be suitable. This would significantly reduce the administrative burden on responsible entities and likely result in more comprehensive, rigorous, and beneficial reporting.

Group
ACES Power Marketing Standards Collaborators
Jason Marshall
No
<p>We believe that the revision to R3 and elimination of R4 are great improvements to the standard as a lot of the unnecessary burdens have been removed. However, Requirement R3 is still not needed, has several issues with it and should be eliminated. (1) While validating contact information annually in a reporting plan makes sense, it does not rise to level of importance of requiring sanctions for failure to do so. Furthermore, it does nothing to assure reliability. Shortly after the contact information has been updated, it could change. This does not mean that validation should be more frequent but simply that is an unnecessary administrative burden. If contact information changes, the registered entity will have to find it. For reliability purposes, why does it matter if they do this in the 24-hour reporting period after the event or annually before the event? (2) Requirement R3 is administrative and is not consistent with the recent direction that NERC and FERC have taken toward compliance. Violations of this requirement are likely to be candidates for FFT treatment and this is exactly the kind of requirement that FERC invited NERC to propose for retirement in Paragraph 81 of the order approving the FFT process. Furthermore, it appears to meet at least two criteria (Administrative and periodic updates) that the Paragraph 81 drafting team has proposed to use to identify candidate requirements for retirement. The requirement is also not consistent with the direction NERC has taken on internal controls. How is an auditor reviewing that contact information has been updated in an Operating Plan forward looking or for that matter beneficial to reliability? Imagine a registered entity fails to update their contact information but still reports an event within the 24 hour reporting time frame to the appropriate parties. They are in technical violation of R3 but have met the spirit of the standard. (3) Requirement R3 is not a results-based requirement. It simply compels a registered entity "how to" meet reporting deadlines. Certainly, if a registered entity has current contact information on hand, it will be easier to notify appropriate parties of events quickly. However, it does limit a registered entity's ability to identify its own unique and possibly better way to meet a requirement. "How to" requirements prevent unique and superior solutions.</p>
No
<p>Because R3 is administrative, the VRF should be Lower. The requirement simply compels that that registered entity update a document which is purely administrative.</p>
<p>(1) For the first "Damage or destruction of a Facility" event in Attachment 1, the threshold for reporting should be modified. The threshold for reporting would only include damage or destruction that necessitates the need for action to prevent an Emergency. It does not include if an Emergency actually occurs. Based on the definition of Emergency which states that it is an "abnormal system condition that requires... action to prevent or limit", we think the threshold should be changed to "Damage or destruction of a Facility... that results in a BES Emergency". Per the definition, the Emergency is what necessitates action which is what the threshold appeared to be focused on. (2) In the second "Damage or destruction of a Facility" event in Attachment 1, the threshold regarding "intentional human action" is ambiguous and suffers from the same difficulties as defining sabotage. What constitutes intentional? How do we know something was intentional without a law enforcement investigation? If a car runs into a transmission tower, was this an accident or intentional human action? It could be either. This appears to be the same issue that prevented the drafting team from defining sabotage. (3) Under the "Physical threats to a BES control center" event in Attachment 1, the event should very clearly define if this applies to backup control centers or not. (4) Under the "Complete loss of off-site power to a nuclear generating plant (grid supply)" event" in Attachment 1, the entity with reporting responsibility is not coordinated with NUC-001. NUC-001 used the term transmission entity to mean an entity that is responsible for providing NPIR services. They did not use only TOP because there are other entities that provide this service. Please coordinate the "Entity with Reporting Responsibility" with that standard. (5) We continue to believe that the draft standard has not satisfied the complete scope of the SAR regarding elimination of redundancy. The draft standard will continue to require redundant reporting by various entities. For instance, under the event "Loss of Firm Load" in Attachment 1, the DP, TOP, and BA all are required to report. The response to our last set of comments regarding this issue was that "the industry can benefit from having such differing perspectives when events occur". This response seems to confuse event analysis with event reporting. The purpose of the standard is to simply report that an event happened. In fact, the reporting form only requires the submitting entity to report the type of event. The description of what happened is optional. What additional perspectives could be gained from having multiple registered entities in the same electrical footprint report that an event happened. If the purpose is to analyze the event, this is covered in the events analysis process. Furthermore, once NERC becomes aware of the event they have the authority to request data and information from other registered entities. Please eliminate the duplicate reporting requirements. Other events that may require duplicate reporting include: Damage or destruction of a Facility, Physical threats to a Facility, BES Emergency resulting in automatic firm load shedding, Loss of firm load, System separation, Generation loss, and Complete loss of off-site power to a nuclear generating plant. (6) In the second "Damage or destruction of a Facility" event and "Physical Threats to a Facility" events, Distribution Provider should be removed. The Distribution Provider does not have any Facilities which is defined as "a set of electrical equipment that operates as a single Bulk Electric System Element". The DP's transformers interconnecting to the BES are not Facilities and the latest NERC BOT definition explicitly does not include them in Inclusion I1. If a DP did own Facilities, it would be registered as a TO or GO. Inclusion of the DP will compel the DP to provide evidence that it does not have Facilities which is an unnecessary compliance burden that does not support reliability. (7)</p>

The "BES Emergency resulting in automatic firm load shedding" should not apply to the DP. In the existing EOP-004 standard, Distribution Provider is not included and the load shed information still gets reported. (8) For the "Voltage deviation on a Facility" event in Attachment 1, we suggest changing "area" in the threshold for reporting to "Transmission Operator Area" as it is a defined term. (9) For the "System separation (islanding)" event, please remove BA. Because islanding and system separation, involve Transmission Facilities automatically being removed from service, this is largely a Transmission Operator issue. This position is further supported by the approval of system restoration standard (EOP-005-2) that gives the responsibility to restore the system to the TOP. (10) The response to our comments requesting that Measure 2 specifically identify that attestations are acceptable forms of evidence to indicate that no events have occurred indicated that the measure cannot permit use of attestations. Other standards that have been recently approved by the board specifically permit the use of attestations. FAC-003-2 M1 and M2, TOP-001-2 M1-M11 and TOP-003-2 M5 all permit the use of attestations. We ask that the drafting team to reconsider including a specific reference that an attestation is acceptable to indicate no event has occurred given these new facts. (11) In requirement R1, we suggest changing "in accordance with EOP-004-2 Attachment 1" to "to report events identified in EOP-004-2 Attachment 1". It makes more sense since the attachment is a list of events that require reporting. The other language sounds like additional requirements will be established in Attachment 1.

Individual

Scott Berry

Indiana Municipal Power Agency

Yes

IMPA agrees with the removal of a "test" and going with a validation requirement for the contact information in the Operating Plan.

no comment

On page 6 of 23 of the draft standard document, second paragraph under Rationale for R1, the SDT uses the words "Every industry participant that owns or operates elements or devices on the grid has a formal or informal process..." The use of these words implies that this requirement and others in this standard may apply to every industry entity regardless if they are a registered entity or not. IMPA understands that standards can only apply to entities that are registered with NERC, but we still prefer to see different wording in this sentence. IMPA recommends using "Every registered entity that owns or operates elements or devices on the grid has a formal or informal process..." Another concern is on pages 18, 19, and 20 of 23. It is not clear what exactly is required of a registered entity and the law enforcement reporting process. IMPA understands it is up to the entity to decide just how its event reporting Operating Plan is made up and who is contacted for the events in attachment 1. These pages are confusing when it comes to the listing of stakeholders in the reporting process on page 18 of 23 and then when the SDT states that an entity may just notify the state or provincial or local level law enforcement agency. The SDT needs to clarify that the listing of stakeholders on page 18 of 23 is just a suggestive listing and that if the entity so decides per its reporting Operating Plan that notification of the local law enforcement agency is sufficient (the thought that the local law enforcement agency can coordinate with additional law enforcement agencies if it sees the need). The requirement to contact the FBI in CIP-001 is not a requirement in EOP-004-2 unless the registered entity puts that requirement in its event reporting Operating Plan. As a clarification, in the Background section's second paragraph, it should read "retiring both EOP-004-1 and CIP-001-2a" as opposed to CIP-002-2a as written above in this comment document.

Individual

Darryl Curtis

Oncor Electric Delivery

Yes

No

Oncor suggest the following additions to VSL language for R1 to align more closely with the measures described in M1 Lower VSL - Entity has one applicable event type not properly identified in its event reporting Operating Plan High VSL - Entity has more than one applicable event type not properly identified in its event reporting Operating Plan Severe VSL - The Responsible Entity failed to have an event reporting Operating Plan

For reporting consistency, under the Event Type labeled "Generation Loss", in Appendix 1 of EOP-004-2, Oncor recommends that the reporting threshold of 1,000 KW for the ERCOT Interconnection be raised to 1,400 MW to match the 1,000 MW level in the current version of the ERO Event Analysis Program. Under the Event Type labeled "Damage or Destruction of a Facility", Appendix 1, with the threshold that states, "Damage or destruction of its Facility that results from actual or suspected intentional human action", Oncor suggest the addition of the following language to address intentional human action that is theft in nature but is not intended to disrupt the normal operation of the BES: "Do not report theft unless it degrades the normal operation of a Facility."

Individual

Tony Kroskey

Brazos Electric Power Cooperative, Inc.

Individual
Alice Ireland
Xcel Energy
Yes
No
<p>The VSLs for column for R2 provide a range of severity based on the number of contacts made (or not made) but this seems to be arbitrarily defined. A smaller entity may only have two or three contacts so missing one or more here may be a much higher risk than for a larger utility that may have ten or more contacts. The VSLs should be drafted to include percentages instead of whole numbers. The Lower VSL column for R3 states, "...OR The Responsible Entity validated 75% or more of the contact information contained in the operating plan." This could be interpreted that even someone completed 100% (which is more than 75%) a low VSL could be assigned. This VSL should be drafted in similar fashion to the Moderate, High and Severe VSLs and include a range (i.e. less than 100% but more than 75%).</p>
<p>In attachment one, the "Threshold for Reporting" under Damage or Destruction of a Facility appears to closely follow the definition of sabotage that EOP-004-2 says it is trying to do away with. This definition should be drafted to better correlate with the other physical threats and include the language, "which has the potential to degrade the normal operation of the Facility". Additionally in Attachment 1, both the Physical threats to a Facility and Physical threats to a BES control center include the wording, "Suspicious device or activity...". What constitutes suspicious activity? With no definition this interpretation is left to the Entity which is again something the DSR SDT says they would like to eliminate. Lastly, in the Guideline and Technical Basis section, under A Reporting Process Solution – EOP-004 it states, "A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP." This appears to be in direct conflict with the Rationale for R1 which states, "An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement." CIP-001-2a required "communication contacts, as applicable, with local Federal Bureau of Investigation (FBI)..." so if the CIP-001-2a procedure is included this does not seem to meet the requirements of the operating plan required under EOP-004-2. Also, if the intent of the Operating Plan is to include all local law enforcement and not FBI the operating plan would become very detailed and when validated annually as required in R3, this becomes very burdensome on an entity.</p>

# Meeting Results

Project 2009-01

Memo to NERC Project Ballot Body for Recirculation Ballot

October 15, 2012

The Disturbance and Sabotage Reporting standard drafting team has opted to pursue a recirculation ballot for EOP-004-2 after making a few clarifications to the Guidelines and Technical Basis section to address stakeholder concerns raised during the second successive ballot.

**Distribution Providers** – Some concerns were raised with respect to applicability of the standard to all Distribution Providers. The concerns relate to DPs that do not own BES Facilities. While these entities would not have any events to report under R2, they would still be applicable under R1 and R3. The team discussed this issue and has addressed this concern with additional language in the Guidelines and Technical Basis section of the standard.

**Duplicative Reporting** – If an entity is registered as an RC, BA and TOP, they should only have to submit a single report. The team discussed and has addressed this concern with additional language in the Guidelines and Technical Basis section of the standard. With regards to the concern regarding multiple entities submitting a report for the same event, the team does not see this as being an issue for industry and will not make any further revisions to address this.

Other issues were raised by stakeholders and a discussion of those is below:

**Paragraph 81** – On March 15, 2012, FERC issued an order on NERC's Find, Fix and Track process, and in Paragraph 81 ("P81"), invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission's request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired.

In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2.

Phase 2 of the Paragraph 81 project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. Until such time, CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is, and subject to the Compliance Monitoring and Enforcement Program.



**Reporting** – Some comments were submitted regarding the reporting burden of this standard. The revised standard combines two standards into one and removes the analysis portion of the current mandatory and enforceable standards (EOP-004-1 and CIP-001-2a). The analysis provisions will be addressed in the NERC Events Analysis Program upon approval of EOP-004-2. This revised standard involves notification only and does not require any investigation or analysis.

**Attachment 1 comments** – Many suggestions were made regarding the events listed in Attachment 1. The team has reviewed all of these comments and determined that they would be substantive changes by definition. The team has elected to move forward to recirculation ballot (which precludes substantive revisions to the standard) therefore, these suggestions cannot be incorporated at this time. These comments will be entered into the NERC Issues data base for consideration when the standard is reviewed during the required periodic review cycle.

# Consideration of Comments

## Project 2009-01 Disturbance Sabotage and Reporting

The Project 2009-01 Drafting Team thanks all commenters who submitted comments on Draft 5 of EOP-004-2. The standard was posted for a 30-day public comment period from August 29, through September 27, 2012. Stakeholders were asked to provide feedback on the standard and associated documents through a special electronic comment form. There were 56 sets of comments, including comments from approximately 181 different people from approximately 125 companies, representing 9 of the 10 Industry Segments as shown in the table on the following pages.

All comments submitted may be reviewed in their original format on the standard's [project page](#).

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process! If you feel there has been an error or omission, you can contact the Vice President and Director of Standards, Mark Lauby, at 404-446-2560 or at [mark.lauby@nerc.net](mailto:mark.lauby@nerc.net). In addition, there is a NERC Reliability Standards Appeals Process.<sup>1</sup>

### Summary Consideration:

The Disturbance and Sabotage Reporting standard drafting team has opted to pursue a recirculation ballot for EOP-004-2 after making a few clarifications to the Guidelines and Technical Basis section to address stakeholder concerns raised during the second successive ballot:

- Distribution Providers – Some concerns were raised with respect to applicability of the standard to all Distribution Providers. The concerns relate to DPs that do not own BES Facilities. While these entities would not have any events to report under R2, they would still be applicable under R1 and R3. The team discussed this issue and has addressed this concern with additional language in the Guidelines and Technical Basis Section of the standard as follows:

#### “Distribution Provider Applicability Discussion

The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have

<sup>1</sup> The appeals process is in the Standard Processes Manual: [http://www.nerc.com/files/Appendix\\_3A\\_StandardsProcessesManual\\_20120131.pdf](http://www.nerc.com/files/Appendix_3A_StandardsProcessesManual_20120131.pdf)

any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more than 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.”

- **Duplicative Reporting** – If an entity is registered as an RC, BA and TOP, they should only have to submit a single report. The team discussed and has addressed this concern with additional language in the Guidelines and Technical Basis Section of the standard as follows:

“Multiple Reports for a Single Organization

For entities that have multiple registrations, the DSR SDT intends that these entities will only have to submit one report for any individual event. For example, if an entity is registered as a Reliability Coordinator, Balancing Authority and Transmission Operator, the entity would only submit one report for a particular event rather submitting three reports as each individual registered entity.”

With regards to the concern regarding multiple entities submitting a report for the same event, the team does not see this as being an issue for industry and will not make any further revisions to address this.

Other issues were raised by stakeholders and a discussion of those is below:

- **24 Hour Reporting** – Several stakeholders had concerns regarding the 24 hour reporting requirement. Commenters suggest that events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator’s burden, which reduces the operator’s effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. To this end, the DSR SDT has added clarifying language to R2 as follows:

R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). *[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]*

- Paragraph 81** – On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 of that order (“P81”), invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program.
- Reporting** – Some comments were submitted regarding the reporting burden of this standard. The revised standard combines two standards into one and removes the analysis portion of the current mandatory and enforceable standards (EOP-004-1 and CIP-001-2a). The analysis provisions will be addressed in the NERC Events Analysis Program upon approval of EOP-004-2. This revised standard involves notification only and does not require any investigation or analysis.
- Attachment 1 comments** – Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. . The team has elected to move forward to recirculation ballot.
- Violation Risk Factors** - Many stakeholders had concerns with the VRFs for R2 and R3 being assigned as “medium”. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower

the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.

- **Violation Severity Levels** - Other stakeholders suggested revision to the VSLs for Requirement R1 based on if the event reporting Operating Plan fails to include one or more of the event types listed in Attachment 1. The SDT agrees and has revised the VSLs for R1 as follows:

Lower: The Responsible Entity had an Operating Plan, but failed to include one applicable event type.

Moderate: The Responsible Entity had an Operating Plan, but failed to include two applicable event types.

High: The Responsible Entity had an Operating Plan, but failed to include three applicable event types.

Severe: The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types OR the Responsible Entity failed to have an event reporting Operating Plan.

**Index to Questions, Comments, and Responses**

- 1. The DSR SDT has revised EOP-004-2 by combining Requirements R3 and R4 into a single requirement (Requirement R3) to, “... validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year.” Do you agree with this revision? If not, please explain in the comment area below. ....15
- 2. The DSR SDT has revised the VSLs to reflect the language in the revised requirements. Do you agree with the proposed VRFs and VSLs? If not, please explain in the comment area below.....25
- 3. Do you have any other comment, not expressed in the questions above, for the DSR SDT?.....37

**The Industry Segments are:**

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
1.	Group	Guy Zito	Northeast Power Coordinating Council											X
Additional Member		Additional Organization		Region	Segment Selection									
1.	Alan Adamson	New York State Reliability Council, LLC		NPCC	10									
2.	Carmen Agavrioloai	Independent Electricity System Operator		NPCC	2									
3.	Greg Campoli	New York Independent System Operator		NPCC	2									
4.	Sylvain Clermont	Hydro-Quebec TransEnergie		NPCC	1									
5.	Chris de Graffenried	Consolidated Edison Co. of New York, Inc.		NPCC	1									
6.	Gerry Dunbar	Northeast Power Coordinating Council		NPCC	10									
7.	Mike Garton	Dominion Resources Services, Inc.		NPCC	5									
8.	Kathleen Goodman	ISO - New England		NPCC	2									

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																			
			1	2	3	4	5	6	7	8	9	10										
9.	Michael Jones	National Grid	NPCC	1																		
10.	David Kiguel	Hydro One Networks Inc.	NPCC	1																		
11.	Michael Lombardi	Northeast Utilities	NPCC	1																		
12.	Randy MacDonald	New Brunswick Power Transmission	NPCC	9																		
13.	Bruce Metruck	New York Power Authority	NPCC	6																		
14.	Silvia Parada Mitchell	NextEra Energy, LLC	NPCC	5																		
15.	Lee Pedowicz	Northeast Power Coordinating Council	NPCC	10																		
16.	Robert Pellegrini	The United Illuminating Company	NPCC	1																		
17.	Si-Truc Phan	Hydro-Quebec TransEnergie	NPCC	1																		
18.	David Ramkalawan	Ontario Power Generation, Inc.	NPCC	5																		
19.	Brian Robinson	Utility Services	NPCC	8																		
20.	Michael Schiavone	National Grid	NPCC	1																		
21.	Wayne Sipperly	New York Power Authority	NPCC	5																		
22.	Donald Weaver	New Brunswick System Operator	NPCC	2																		
23.	Ben Wu	Orange and Rockland Utilities	NPCC	1																		
24.	Peter Yost	Consolidated Edison Co. of New York, Inc.	NPCC	3																		
2.	Group	Ron Sporseen	PNGC Comment Group										X		X	X				X		
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																		
1.	Joe Jarvis	Blachly-Lane Electric Cooperative	WECC	3																		
2.	Dave Markham	Central Electric Cooperative	WECC	3																		
3.	Dave Hagen	Clearwater Power Company	WECC	3																		
4.	Roman Gillen	Consumer's Power Inc.	WECC	1, 3																		
5.	Roger Meader	Coos-Curry Electric Cooperative	WECC	3																		
6.	Bryan Case	Fall River Electric Cooperative	WECC	3																		
7.	Rick Crinklaw	Lane Electric Cooperative	WECC	3																		
8.	Annie Terracciano	Northern Lights Inc.	WECC	3																		
9.	Aleka Scott	PNGC Power	WECC	4																		
10.	Heber Carpenter	Raft River Electric Cooperative	WECC	3																		
11.	Steve Eldrige	Umatilla Electric Cooperative	WECC	1, 3																		
12.	Marc Farmer	West Oregon Electric Cooperative	WECC	4																		



Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
13.	Margaret Ryan	PNGC Power	WECC	8																
14.	Rick Paschall	PNGC Power	WECC	3																
3.	Group	Greg Rowland	Duke Energy		X		X		X	X										
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>															
1.	Doug Hils	Duke Energy	RFC	1																
2.	Lee Schuster	Duke Energy	FRCC	3																
3.	Dale Goodwine	Duke Energy	SERC	5																
4.	Greg Cecil	Duke Energy	RFC	6																
4.	Group	Chang Choi	Tacoma Public Utilities		X		X	X	X	X										
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>															
1.	Chang Choi	City of Tacoma	WECC	1																
2.	Travis Metcalfe	Tacoma Public Utilities	WECC	3																
3.	Keith Morisette	Tacoma Public Utilities	WECC	4																
4.	Chris Mattson	Tacoma Power	WECC	5																
5.	Michael Hill	Tacoma Public Utilities	WECC	6																
5.	Group	Kent Kujala	Detroit Edison				X	X	X											
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>															
1.	Alexander Eizans		RFC	3, 4, 5																
2.	Barbara Holland		RFC	3, 4, 5																
3.	Jeffrey DePriest		RFC	3, 4, 5																
6.	Group	Gerry Beckerle	SERC OC Standards Review Group		X		X													
<b>Additional Member</b>		<b>Additional Organization</b>		<b>Region</b>	<b>Segment Selection</b>															
1.	Roger Powers	City of Springfield, IL - CWLP	SERC	1, 3																
2.	Dan Roethemeyer	Dynegy	SERC	5																
3.	Melinda Montgomery	Entergy	SERC	1, 3, 6																
4.	Terry Bilke	MISO	SERC	2																
5.	Scott Brame	NCEMC	SERC	4, 1, 3, 5																
6.	William Berry	OMU	SERC	3, 5																

Group/Individual	Commenter	Organization		Registered Ballot Body Segment											
				1	2	3	4	5	6	7	8	9	10		
7. Tim Hattaway	PowerSouth	SERC	1, 5												
8. Brett Koelsch	Progress Energy Carolinas	SERC	1, 3, 5, 6												
9. Vicky Budreau	SCPSA	SERC	1, 3, 5, 6												
10. Gary Hutson	SMEPA	SERC	1, 3, 5, 6												
11. Marsha Morgan	Southern Co. Services	SERC	1, 5												
12. Randy Hubbert	Southern Co. Services	SERC	1, 5												
13. Joel Wise	TVA	SERC	1, 3, 5, 6												
14. Stuart Goza	TVA	SERC	1, 3, 5, 6												
15. Jim Case	Entergy	SERC	1, 3, 6												
16. Mike Bryson	PJM	SERC	2												
17. Mike Hirst	Cogentrix	SERC	5												
7. Group	Larry Raczkowski	FirstEnergy		X		X	X	X	X						
<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>												
1. William J Smith	FirstEnergy Corp	RFC	1												
2. Stephan Kern	FirstEnergy Energy Delivery	RFC	3												
3. Douglas Hohlbaugh	Ohio Edison Company	RFC	4												
4. Kenneth Dresner	FirstEnergy Solutions	RFC	5												
5. Kevin Query	FirstEnergy Solutions	RFC	6												
8. Group	Mike Garton	Dominion		X		X	X	X							
<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>												
1. Louis Slade	Dominion Resources Services, Inc.	RFC	5, 6												
2. Randi Heise	Dominion Resources Services, Inc.	MRO	5, 6												
3. Connie Lowe	Dominion Resources Services, Inc.	NPCC	5, 6												
4. Mike Crowley	Virginia Electric and Power Company	SERC	1, 3, 5, 6												
9. Group	WILL SMITH	MRO NSRF		X	X	X	X	X	X						
<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>												

Group/Individual	Commenter	Organization	Registered Ballot Body Segment																	
			1	2	3	4	5	6	7	8	9	10								
1.	CHUCK LAWRENCE	ATC	MRO	1																
2.	TOM BREENE	WPS	MRO	3, 4, 5, 6																
3.	JODI JENSON	WAPA	MRO	1, 6																
4.	KEN GOLDSMITH	ALTW	MRO	4																
5.	ALICE IRELAND	XCEL/NSP	MRO	1, 3, 5, 6																
6.	DAVE RUDOLPH	BEPC	MRO	1, 3, 5, 6																
7.	ERIC RUSKAMP	LES	MRO	1, 3, 5, 6																
8.	JOE DEPOORTER	MGE	MRO	3, 4, 5, 6																
9.	SCOTT NICKELS	RPU	MRO	4																
10.	TERRY HARBOUR	MEC	MRO	1, 3, 5, 6																
11.	MARIE KNOX	MISO	MRO	2																
12.	LEE KITTELSON	OTP	MRO	1, 3, 5																
13.	SCOTT BOS	MPW	MRO	1, 3, 5																
14.	TONY EDDLEMAN	NPPD	MRO	1, 3, 5																
15.	MIKE BRYTOWSKI	GRE	MRO	1, 3, 5, 6																
16.	DAN INMAN	MPC	MRO	1, 3, 5, 6																
10.	Group	Chris Higgins	Bonneville Power Administration		X		X		X	X										
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																
1.	Jim Burns	BPA, Technical Operations	WECC	1																
2.	Fran Halpin	BPA, Duty Scheduling	WECC	5																
3.	Erika Doot	BPA, Generation Support	WECC	3, 5, 6																
4.	John Wylder	BPA, Transmission	WECC	1																
5.	Deanna Phillips	BPA, FERC Compliance	WECC	1, 3, 5, 6																
6.	Russell Funk	BPA, Transmission	WECC	1																
11.	Group	Robert Rhodes	SPP Standards Review Group			X														
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>																
1.	John Allen	City Utilities of Springfield	SPP	1, 4																
2.	Doug Callison	Grand River Dam Authority	SPP	1, 3, 5																
3.	Jonathan Hayes	Southwest Power Pool	SPP	2																
4.	Bo Jones	Westar Energy	SPP	1, 3, 5, 6																

Group/Individual	Commenter	Organization	Registered Ballot Body Segment											
			1	2	3	4	5	6	7	8	9	10		
5.	Allen Klassen	Westar Energy	SPP	1, 3, 5, 6										
6.	Tiffany Lake	Westar Energy	SPP	1, 3, 5, 6										
7.	Tara Lightner	Sunflower Electric Power Corporation	SPP	1										
8.	Kyle McMenamin	Xcel Energy	SPP	1, 3, 5, 6										
9.	Jerry McVey	Sunflower Electric Power Corporation	SPP	1										
10.	Fred Meyer	Empire District Electric Company	SPP	1										
11.	Terri Pyle	Oklahoma Gas & Electric Company	SPP	1, 3, 5										
12.	Don Schmit	Nebraska Public Power District	MRO	1, 3, 5										
13.	Katie Shea	Westar Energy	SPP	1, 3, 5, 6										
14.	Sean Simpson	Board of Public Utilities, City of McPherson	SPP	NA										
15.	Bryan Taggart	Westar Energy	SPP	1, 3, 5, 6										
16.	Mark Wurm	Board of Public Utilities, City of McPherson	SPP	NA										
12.	Group	Jason Marshall	ACES Power Marketing Standards Collaborators								X			
	<b>Additional Member</b>	<b>Additional Organization</b>	<b>Region</b>	<b>Segment Selection</b>										
1.	Susan Sosbe	Wabash Valley Power Association	RFC	3										
2.	Clem Cassmeyer	Western Farmers Electric Cooperative	SPP	1, 5										
3.	Megan Wagner	Sunflower Electric Power Corporation	SPP	1										
4.	Scott Brame	North Carolina Electric Membership Corporation	SERC	1, 3, 4, 5										
5.	Bob Solomon	Hoosier Energy	RFC	1										
6.	Robert Thomasson	Big Rivers Electric Corporation	SERC											
7.	Shari Heino	Brazos Electric Power Cooperative	ERCOT	1, 5										
8.	John Shaver	Arizona Electric Power Cooperative	WECC	4, 5										
9.	John Shaver	Southwest Transmission Cooperative	WECC	1										
10.	Mohan Sachdeva	Buckeye Power	RFC	3, 4										
11.	Michael Brytowski	Great River Energy	MRO	1, 3, 5, 6										
13.	Individual	Janet Smith, Regulatory Affairs Supervisor	Arizona Public Service Company		X		X		X	X				
14.	Individual	Emily Pannel	Southwest Power Pool Regional Entity											X

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
15.	Individual	Antonio Grayson	Southern Company	X		X		X	X					
16.	Individual	Daniela Hammons	CenterPoint Energy	X										
17.	Individual	Lee Layton	Blue Ridge EMC	X		X								
18.	Individual	Anthony Jablonski	ReliabilityFirst											X
19.	Individual	Jonathan Appelbaum	The United Illuminating Company	X										
20.	Individual	Russ Schneider	Flathead Electric Cooperative, Inc.			X	X							
21.	Individual	Oliver Burke	Entergy Services, Inc. (Transmission)	X										
22.	Individual	Nazra Gladu	Manitoba Hydro	X		X		X	X					
23.	Individual	Steve Grega	Lewis County PUD	X				X						
24.	Individual	Steve Alexanderson P.E.	Central Lincoln			X	X						X	
25.	Individual	Jack Stamper	Clark Public Utilities	X										
26.	Individual	Russell A. Noble	Cowlitz PUD			X	X	X						
27.	Individual	Chantel Haswell	Public Service Enterprise Group	X		X		X	X					
28.	Individual	Mike Hirst	Cogentrix Energy					X						
29.	Individual	Dave Willis	Idaho Power Co.	X		X								
30.	Individual	Michelle R D'Antuono	Ingelside Cogeneration LP					X						
31.	Individual	Howard Rulf	Wisconsin Electric Power company dba We Energies			X	X	X						
32.	Individual	Melissa Kurtz	US Army Corps of Engineers					X						
33.	Individual	David Jendras	Ameren Services	X		X		X	X					
34.	Individual	Michael Falvo	Independent Electricity System Operator		X									
35.	Individual	RoLynda Shumpert	South Carolina Electric and Gas	X		X		X	X					
36.	Individual	David Revill	Georgia Transmission Corporation	X										
37.	Individual	Andrew Gallo	City of Austin dba Austin Energy	X		X	X	X	X					
38.	Individual	Andrew Z.Pusztai	american Transmission Company	X										

Group/Individual		Commenter	Organization	Registered Ballot Body Segment										
				1	2	3	4	5	6	7	8	9	10	
39.	Individual	Don Schmit	Nebraska Public Power Disstrict	X		X		X						
40.	Individual	Terry Harbour	MidAmerican Energy	X		X		X	X					
41.	Individual	Kathleen Goodman	ISO New England Inc.		X									
42.	Individual	d mason	City and County of San Francisco - Hetch Hetchy Water and Power					X						
43.	Individual	Tracy Richardson	Springfield Utility Board			X								
44.	Individual	Rich Salgo	NV Energy	X		X		X						
45.	Individual	Thad Ness	American Electric Power	X		X		X	X					
46.	Individual	Charles Yeung	Southwest Power Pool RTO		X									
47.	Individual	Nathan Mitchell	American Public Power Association			X	X							
48.	Individual	Don Jones	Texas Reliability Entity											X
49.	Individual	Christine Hasha	ERCOT		X									
50.	Individual	Denise M. Lietz	Puget Sound Energy Inc.	X		X		X						
51.	Individual	Maggy Powell	Exelon Corporation and its affiliates	X		X		X	X					
52.	Individual	Christina Bigelow	Midwest Independent Transmission System Operator, Inc.		X									
53.	Individual	Scott Berry	Indiana Municipal Power Agency				X							
54.	Individual	Darryl Curtis	Oncor Electric Delivery	X										
55.	Individual	Tony Kroskey	Brazos Electric Power Cooperative, Inc.	X										
56.	Individual	Alice Ireland	Xcel Energy	X		X		X	X					

If you wish to express support for another entity’s comments without entering any additional comments, you may do so here.

Organization	Supporting Comments of “Entity Name”
PNGC Comment Group	Central Lincoln PUD
Blue Ridge EMC	R3 is another example of a "paper chase", creating (or rather continuing) an administrative burden for the utility. The standard should only require that the entity have a plan and the accountability should be "did the entity follow the plan when needed, including proving that the appropriate contacts were made?"
<p><b>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. Also, if the information in the plan is out of date, then the plan will not be effective.</b></p>	
Flathead Electric Cooperative, Inc.	Central Lincoln
US Army Corps of Engineers	MRO NSRF
Nebraska Public Power District	Midwest Reliability Organization (MRO) NERC Standards Review Forum (NSRF); AND Southwest Power Pool RTO
MidAmerican Energy	MidAmerican supports the MRO NSRF comments
ISO New England Inc.	NPCC

1. The DSR SDT has revised EOP-004-2 by combining Requirements R3 and R4 into a single requirement (Requirement R3) to, “... validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year.” Do you agree with this revision? If not, please explain in the comment area below.

**Summary Consideration:** The majority of stakeholders agree with the combination of R3 and R4 and with the new language of R3 to “validate” the contact information. A few commenters suggested that Requirement R3 is administrative and should be removed under the provisions of “Paragraph 81”. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program.

Organization	Yes or No	Question 1 Comment
CenterPoint Energy	No	CenterPoint Energy supports the concept of combining Requirements R3 and R4; however, the Company still prefers an annual review requirement which would include validating the contact information and content of the Operating Plan overall. Therefore, CenterPoint Energy recommends the following revised language for Requirement R3: “Each Responsible Entity shall review and update the Operating Plan at least every 15 months.” The Company also suggests that the Measure be worded as follows: “Evidence may include, but is not limited to dated documentation reflecting changes to the Operating Plan including updated contact information if necessary.”



Organization	Yes or No	Question 1 Comment
<p>Response: Thank you for your comment. The SDT appreciates the suggestion on validating the content of the Operating Plan, but at this time, we feel that the step is not necessary to meet the directive from FERC Order 693. As to the comment on extending the review period to 15 months, following much discussion and review of the industry comments, we are staying with the language as proposed.</p>		
<p>American Electric Power</p>	<p>No</p>	<p>In the spirit of Paragraph 81 efforts, we request the removal of R3 as it is solely administrative in nature, existing only to support R2. This is more of an internal control and does not appear to rise to the level of being an industry-wide requirement. In addition, having two requirements rather than one increases the likelihood of being found non-compliant for multiple requirements rather than a single requirement.</p>
<p>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. , CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</p>		
<p>City and County of San Francisco - Hetch Hetchy Water and Power</p>	<p>No</p>	<p>Measure M3 specifically identifies two types of acceptable compliance evidence: Voice Recording and Log entries. Specifying only these two forms of evidence creates a risk that some auditors will reject other forms of R3 compliance evidence which are equally valid, such as emails or written call records. Although M3 states that acceptable evidence is not limited to Voice Recordings or Log Entries, we have concern that other</p>

Organization	Yes or No	Question 1 Comment
		methods of complying with R3 may not be accepted.
<p>Response: Thank you for your comment. The SDT believes that the phrase “may include, but are not limited to” addresses your concern. The SDT will present your comment to the NERC Compliance staff in an effort to inform audit staffs on what evidence is permissible.</p>		
Blue Ridge EMC	No	See previous comments
<p>Response: Thank you for previous comments. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. Also, if the information in the plan is out of date, then the plan will not be effective.</p>		
Detroit Edison	No	<p>The requirement is too prescriptive and difficult to document. Requirement should be for annual review of Operating Plan. This allows for entity to review plan and document this the same as other Standards that require annual review (i.e. annual review blocks on documents).The requirement as written is vague and difficult to document. Annual review of reporting process is already a requirement.</p>
<p>Response: Thank you for your comments. While the SDT appreciates the view that the Operating Plan should be reviewed annually, the SDT feels that the requirement only needs to address the validity of the contact information contained within the Operating Plan in order to meet the FERC directive in Order 693. If the entity is aware of changes within its operations that would make a more extensive review advisable, it can choose to do so; but where there have been no significant changes to an entity’s operations in the last year, ensuring the validity of the contact information should be sufficient.</p>		
Manitoba Hydro	No	This seems like an administrative only requirement. It would be too difficult to validate or measure.
<p>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. The measure calls for an entity to have “dated records to show that it validated all contact information contained in the Operating Plan each calendar year. Such evidence may include, but are not limited to, dated voice recordings and operating logs or other communication documentation.” The SDT does not believe that this is an administrative</p>		

Organization	Yes or No	Question 1 Comment
<p>requirement because, if the information in the Operating Plan is out of date, then the plan will not be effective.</p>		
<p>ACES Power Marketing Standards Collaborators</p>	<p>No</p>	<p>We believe that the revision to R3 and elimination of R4 are great improvements to the standard as a lot of the unnecessary burdens have been removed. However, Requirement R3 is still not needed, has several issues with it and should be eliminated. (1) While validating contact information annually in a reporting plan makes sense, it does not rise to level of importance of requiring sanctions for failure to do so. Furthermore, it does nothing to assure reliability. Shortly after the contact information has been updated, it could change. This does not mean that validation should be more frequent but simply that is an unnecessary administrative burden. If contact information changes, the registered entity will have to find it. For reliability purposes, why does it matter if they do this in the 24-hour reporting period after the event or annually before the event? (2) Requirement R3 is administrative and is not consistent with the recent direction that NERC and FERC have taken toward compliance. Violations of this requirement are likely to be candidates for FFT treatment and this is exactly the kind of requirement that FERC invited NERC to propose for retirement in Paragraph 81 of the order approving the FFT process. Furthermore, it appears to meet at least two criteria (Administrative and periodic updates) that the Paragraph 81 drafting team has proposed to use to identify candidate requirements for retirement. The requirement is also not consistent with the direction NERC has taken on internal controls. How is an auditor reviewing that contact information has been updated in an Operating Plan forward looking or for that matter beneficial to reliability? Imagine a registered entity fails to update their contact information but still reports an event within the 24 hour reporting time frame to the appropriate parties. They are in technical violation of R3 but have met the spirit of the standard. (3) Requirement R3 is not a results-based requirement. It simply compels a registered entity “how to” meet reporting deadlines. Certainly, if a</p>

Organization	Yes or No	Question 1 Comment
		<p>registered entity has current contact information on hand, it will be easier to notify appropriate parties of events quickly. However, it does limit a registered entity's ability to identify its own unique and possibly better way to meet a requirement. "How to" requirements prevent unique and superior solutions.</p>
<p><b>Response:</b> Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. The SDT does not believe that this is an administrative requirement because, if the information in the Operating Plan is out of date, then the plan will not be effective.</p> <p>On March 15, 2012, FERC issued an order on NERC's Find, Fix and Track process and in paragraph 81 ("P81") invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission's request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</p>		
NV Energy	No	<p>Without further clarification of what is expected by "validate all contact information" I cannot support this requirement. On the surface, "validate" appears to be acceptable terminology, as it means to me a review of the contact names and contact information (perhaps cell #, home phone, text address, email address, etc) that would be evidenced through an attestation of completion of review along with records showing the updates made to the contact information pursuant to the review. However, when the Measure is considered, it refers to evidence such as operator logs, voice recordings, etc. This seems to indicate that the</p>

Organization	Yes or No	Question 1 Comment
		<p>expectation is that each contact is tested, by dialing, texting, emailing, etc with some sort of confirmation that each contact was successful. If this is what is necessary to satisfy the "validate" requirement, I believe it is excessive, burdensome and unnecessary. I suggest modification of the Measure language to clearly allow for an entity to demonstrate compliance by a showing that it reviewed the contact information and made changes as deemed necessary by its review, and to remove the reference to operator logs and voice recordings as the evidence of measure.</p>
<p><b>Response: Thank you for your comment. The SDT agrees with your comment and views your direction as being consistent with the standard’s intent. The SDT will submit your comment to NERC Compliance staff for their consideration. The SDT intends for operator logs and voice recordings to be acceptable as evidence, but not the only acceptable evidence. The use of the language “such as” in the measure indicates this.</b></p>		
Bonneville Power Administration	Yes	BPA agrees with the revision and recognizes that it will involve a large amount of validation workload for entities with a large footprint.
<p><b>Response: Thank you for your comment.</b></p>		
Dominion	Yes	<p>Dominion supports the combination of Requirements R3 and R4 into a single requirement (Requirement R3), although we remain concerned that validation requiring a phone call could be perceived as a nuisance by that entity.</p>
<p><b>Response: Thank you for your comment. The SDT appreciates this concern but feels that the requirement is necessary to address the FERC directive in the Order 693. The SDT does not believe that validation of the contact information will be a nuisance. If the information in the Operating Plan is out of date, then the plan will not be effective.</b></p>		
Duke Energy	Yes	<p>Duke Energy commends the excellent work of the Standard Drafting Team in incorporating previous comments into the current posted draft of the</p>

Organization	Yes or No	Question 1 Comment
		standard.
<b>Response: Thank you for your comment.</b>		
ERCOT	Yes	ERCOT considers replacing R3 and R4 with the new R3 is an improvement and we thank the drafting team for making the change.
<b>Response: Thank you for your comment.</b>		
ReliabilityFirst	Yes	Even though ReliabilityFirst votes in the Affirmative, we offer the following comment regarding Requirement R3 for consideration. ReliabilityFirst recommends changing the word “validate” to “verify” in Requirement R3. ReliabilityFirst believes not only does the entity need to validate contact information is correct, they should verify (i.e. authenticate though test) that the contact information is correct.
<b>Response: Thank you for your comment. The SDT feels that the action you define is consistent with our intent.</b>		
Independent Electricity System Operator	Yes	IESO agrees that the intent of Requirement R3 to have the Registered Entities validate the contact information in the contact lists that they may have for the events applicable to them is achieved. IESO also agrees that the elimination of conducting an annual test of the communications process and review of the event reporting Operating Plan in merging the previous R3 and R4 into this new R3 will give entities an opportunity to develop a plan that suits its business needs.
<b>Response: Thank you for your comment.</b>		
Indiana Municipal Power Agency	Yes	IMPA agrees with the removal of a “test” and going with a validation requirement for the contact information in the Operating Plan.

Organization	Yes or No	Question 1 Comment
<b>Response: Thank you for your comment.</b>		
Ingleside Cogeneration LP	Yes	Ingleside Cogeneration believes that an annual validation of contact information is sufficient for a reporting procedure. R2 provides sufficient impetus for Responsible Entities to keep their Operating plan current - as a missed report will lead to a violation. Furthermore, external agencies and law enforcement officials will be reluctant to participate in validation tests, as dozens of nearby BES entities will overwhelm them with such requests.
<b>Response: Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. If the information in the Operating Plan is out of date, then the plan will not be effective.</b>		
SPP Standards Review Group	Yes	We feel that replacing R3 and R4 with the new R3 is an improvement and we thank the drafting team for making the change.
<b>Response: Thank you for your support.</b>		
PNGC Comment Group	Yes	
Tacoma Public Utilities	Yes	
SERC OC Standards Review Group	Yes	
FirstEnergy	Yes	
MRO NSRF	Yes	
Arizona Public Service Company	Yes	
Southwest Power Pool Regional Entity	Yes	

Organization	Yes or No	Question 1 Comment
Southern Company	Yes	
The United Illuminating Company	Yes	
Entergy Services, Inc. (Transmission)	Yes	
Lewis County PUD	Yes	
Central Lincoln	Yes	
Clark Public Utilities	Yes	
Cowlitz PUD	Yes	
Public Service Enterprise Group	Yes	
Cogentrix Energy	Yes	
Idaho Power Co.	Yes	
Wisconsin Electric Power company dba We Energies	Yes	
Ameren Services	Yes	
South Carolina Electric and Gas	Yes	
Georgia Transmission Corporation	Yes	
City of Austin dba Austin Energy	Yes	
american Transmission Company	Yes	



Organization	Yes or No	Question 1 Comment
MidAmerican Energy	Yes	
Springfield Utility Board	Yes	
Southwest Power Pool RTO	Yes	
American Public Power Association	Yes	
Texas Reliability Entity	Yes	
Puget Sound Energy Inc.	Yes	
Exelon Corporation and its affiliates	Yes	
Midwest Independent Transmission System Operator, Inc.	Yes	
Oncor Electric Delivery	Yes	
Xcel Energy	Yes	

2. The DSR SDT has revised the VSLs to reflect the language in the revised requirements. Do you agree with the proposed VRFs and VSLs? If not, please explain in the comment area below.

**Summary Consideration:** Many stakeholders had concerns with the VRFs for R2 and R3 being assigned as “medium”. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.

Other stakeholders suggested revision to the VSLs for Requirement R1 based on if the event reporting Operating Plan fails to include one or more of the event types listed in Attachment 1. The SDT agrees and has added the following VSLs to R1, in addition to the language that was previously included in the “Severe” VSL:

**Lower:** The Responsible Entity had an Operating Plan, but failed to include one applicable event type.

**Moderate:** The Responsible Entity had an Operating Plan, but failed to include two applicable event types.

**High:** The Responsible Entity had an Operating Plan, but failed to include three applicable event types.

**Severe:** The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.

Organization	Yes or No	Question 2 Comment
Detroit Edison	No	Under VSLs for R2- We disagree with the reporting time frames. Making the time requirement as soon as 24 hours puts this reporting requirement on the real time operators. Many of the situations listed in the EOP-004 attachment are not included in the OE-417 report. The Unofficial Comment Form states the reporting obligations serve to provide input to the NERC Event Analysis Program. This program has removed the 24 hour reporting requirement and

Organization	Yes or No	Question 2 Comment
		changed it to 5 business days.
<p>Response: Thank you for your comments. The reporting obligation under this standard is to provide notification of events to NERC Situation Awareness group. The SDT, in consultation with the DOE and NERC Events Analysis group, have recognized the where there is duplication of reporting and provided for the common use of the different group’s forms. This standard is not a replacement or substitution for any other obligations to other agencies. However, the SDT recognizes the concern with having real time operations staff submitting the report. To this end, the DSR SDT has added clarifying language to R2 as follows:</p> <p style="padding-left: 40px;"><b>R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</b></p>		
Texas Reliability Entity	No	(1) VSLs for R1 should have a lower level VSL if the event reporting Operating Plan fails to include one or more of the event types listed in Attachment 1. (2) VSL for R1 is incorrectly stated as there are no “parts” to R1.
<p>Response: Thank you for your comment. 1) The SDT agrees and has added the following VSLs for R1, in addition to the language that was previously included in the “Severe” VSL:</p> <p style="padding-left: 40px;"><b>Lower: The Responsible Entity had an Operating Plan, but failed to include one applicable event type.</b></p> <p style="padding-left: 40px;"><b>Moderate: The Responsible Entity had an Operating Plan, but failed to include two applicable event types.</b></p> <p style="padding-left: 40px;"><b>High: The Responsible Entity had an Operating Plan, but failed to include three applicable event types.</b></p> <p style="padding-left: 40px;"><b>Severe: The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.</b></p> <p>2) This was correct in the clean version of the standard.</p>		
ACES Power Marketing Standards Collaborators	No	Because R3 is administrative, the VRF should be Lower. The requirement simply compels that that registered entity update a document which is purely administrative.
<p>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a</p>		

Organization	Yes or No	Question 2 Comment
<p>is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Bonneville Power Administration	No	<p>BPA does not agree with the VRFs and VSLs. BPA believes that the violation levels for administrative errors are too high. For more information, please reference comments to question #3.</p>
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF. Please see the response to your question 3 comments.</p>		
CenterPoint Energy	No	<p>CenterPoint Energy suggests that the phrase “which caused a negative impact to the Bulk Electric System” be added to each Violation Severity Level. For example, the wording would appear as follows: “The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 24 hours but less than or equal to 36 hours after meeting an event threshold for reporting which caused a negative impact to the Bulk Electric System”. Additionally or alternatively, the Company proposes that the above phrase be added to the Threshold(s) for Reporting in Attachment 1 to focus on events that have an impact or effect on the Bulk Electric System.</p>
<p><b>Response:</b> Thank you for your comment. The SDT does not believe such a change is necessary. Each event type listed is applicable to BES reliability.</p>		

Organization	Yes or No	Question 2 Comment
MidAmerican Energy	No	Change the VRFs / VSLs to match suggested changes in Question 3
<p><b>Response:</b> Thank you for your comment. The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. Please see the response to your question 3 comments.</p>		
The United Illuminating Company	No	Do not agree that the VRF for R3 is medium. Failure to Validate contact information will not likely lead to instability and Cascade. Reporting under EOP-004 is not an immediate action, and given a 24 hour reporting window a proper contact point can be identified on-the-fly. R2 is properly identified as the Medium VRF since a failure to report whether due to an improper Operating plan or improper contact list may lead to a BES cascade.
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Southwest Power Pool Regional Entity	No	In R2, SPP RE does not understand why the VSLs are based on who was or was not contacted rather than when it was reported. An entity could decide to put only two entities in its Event Reporting Operating Plan. If the entity fails to submit an appropriate event report, it is open to a Severe VSL on the top set of VSLs but only a moderate on the lower set of VSLs. This seems to be a disconnect for applying the VSLs for the same facts and circumstances.
<p><b>Response:</b> Thank you for your comment. The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. The VSLs were written based on two potential failures to meet the requirement. The first is based on the time the report was submitted while the second was based on the entity submitting the report within 24 hours but not to all applicable entities.</p>		

Organization	Yes or No	Question 2 Comment
Midwest Independent Transmission System Operator, Inc.	No	MISO agrees with the comments submitted by the SERC Operating Committee that the VRFs for R2 and R3 should be “Lower” instead of “Medium,” since these are administrative requirements. MISO further respectfully suggests that implementing another standard that requires reporting every incident identified in a plan within 24 hours and that classifies failure to do so a “Severe” violation, will likely cause entities to limit the scope of their plans. NERC, therefore, would not receive information that appears unimportant to a single entity but could be important in the context of similar events across the country.
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p> <p>The SDT does not agree with your second comment and believes that entities will report the appropriate events.</p>		
Oncor Electric Delivery	No	Oncor suggest the following additions to VSL language for R1 to align more closely with the measures described in M1Lower VSL - Entity has one applicable event type not properly identified in its event reporting Operating Plan. High VSL - Entity has more than one applicable event type not properly identified in its event reporting Operating Plan. Severe VSL - The Responsible Entity failed to have an event reporting Operating Plan
<p><b>Response:</b> Thank you for your comment. Based on comments from you and others, we have added the following VSLs for R1, in addition to the language that was previously included in the “Severe” VSL:</p> <p><b>Lower:</b> The Responsible Entity had an Operating Plan, but failed to include one applicable event type.</p>		

Organization	Yes or No	Question 2 Comment
<p><b>Moderate: The Responsible Entity had an Operating Plan, but failed to include two applicable event types.</b></p> <p><b>High: The Responsible Entity had an Operating Plan, but failed to include three applicable event types.</b></p> <p><b>Severe: The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.</b></p>		
Exelon Corporation and its affiliates	No	<p>R2 VSLs - By measuring the amount of time taken to report and the number of entities to receive the report, the VSLs track more with size and location than with a failure to report. For instance, an entity failing to report at all to one entity would be deemed a lower VSL while an entity reporting to many, but failing to report to three entities would be deemed a high VSL.</p> <p>R3 VSL - The severe VSLs do not seem commensurate to oversight. A three month delay in validating that phone numbers are correct, for phone numbers that are accurate, does not track with a severe infraction.</p>
<p><b>Response: Thank you for your comment. The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. The SDT will forward your suggestions to NERC for future consideration of the VSL language.</b></p>		
Blue Ridge EMC	No	R3 VSLs are silly.
<p><b>Response: Thank you for your comment. The SDT followed the NERC guidelines for setting the appropriate VSLs.</b></p>		
Tacoma Public Utilities	No	<p>Regarding the Severe VSL for R1, the reference to “Parts 1.1 and 1.2” appears to be outdated. For R2, change “the Responsible Entity failed to submit an event report...to X entity(ies) within 24 hours” to “the Responsible Entity failed to submit an event report...to only X entity(ies) within 24 hours.” (Add ‘only.’)</p>
<p><b>Response: Thank you for your comment. The SDT agrees with your first suggestion and this was correct in the clean version of the standard that was posted. Your second suggestion will be forwarded to NERC for future consideration.</b></p>		

Organization	Yes or No	Question 2 Comment
SPP Standards Review Group	No	<p>Since EOP-004 is about after-the-fact reporting, we suggest that all the VRFs be Lower. This would mean lowering R2 and R3 from Medium.</p> <p>The third component of the Severe VSL for R2 is more severe than the other two components. In an attempt to be more consistent across all the VSLs, we propose the following for the High VSL for R2: The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours after meeting an event threshold for reporting. OR The Responsible Entity failed to submit an event report (e.g., written or verbal) to three or more entities identified in its event reporting Operating Plan within 24 hours. We propose the following, deleting the first two components as shown in the current draft, for the Severe VSL for R2: The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p> <p>The VSLs were written to account for tardiness of reports, for failing to report to certain entities and for not submitting a report at all. The investigators will apply the appropriate VSL based on the type of violation found.</p>		
ERCOT	No	<p>Since EOP-004 is related to ex-post reporting, which has nothing to do with operational or planning risk, this is an administrative requirement and, accordingly, the VRFs should all be Low. This would mean lowering the VRF for R2 and R3 to Low.</p> <p>The third component of the Severe VSL for R2 is more severe than the other two components. In an attempt to be more consistent across all the VSLs, we</p>



Organization	Yes or No	Question 2 Comment
		<p>propose the following for the High VSL for R2: The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours after meeting an event threshold for reporting. OR The Responsible Entity failed to submit an event report (e.g., written or verbal) to three or more entities identified in its event reporting Operating Plan within 24 hours. ERCOT proposes that the first two components of the Severe VSL for R2 be deleted and replaced with: The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>
<p><b>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</b></p> <p><b>The VSLs were written to account for tardiness of reports, for failing to report to certain entities and for not submitting a report at all. The investigators will apply the appropriate VSL based on the type of violation found.</b></p>		
Duke Energy	No	<p>The Lower VSL for R3 should be clarified. The phrase “validated 75% or more” should be modified to say “validated at least 75% but less than 100%”.</p>
<p><b>Response: Thank you for your comment. The SDT agrees and has made the correction.</b></p>		
SERC OC Standards Review Group	No	<p>The VRF for R2 should be “Lower” instead of “Medium” since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be “Lower” instead of “Medium” since it is an administrative requirement.</p>
<p><b>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC</b></p>		

Organization	Yes or No	Question 2 Comment
<p>Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Southern Company	No	<p>The VRF for R2 should be “Lower” instead of “Medium” since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be “Lower” instead of “Medium” since it is an administrative requirement. In addition we suggest that the VSL for R1 should have a lower level VSL for an Operating Plan that may have one event type missing from the Operating Plan.</p>
<p>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Cogentrix Energy	No	<p>The VRF for R2 should be “Lower” instead of “Medium” since it is administrative which involves reporting events to entities not identified in the Functional Model that have operating responsibilities listed. The VRF for R3 should also be “Lower” instead of “Medium” since it is an administrative requirement.</p>
<p>Response: Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a</p>		

Organization	Yes or No	Question 2 Comment
<p>is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Xcel Energy	No	<p>The VSLs for column for R2 provide a range of severity based on the number of contacts made (or not made) but this seems to be arbitrarily defined. A smaller entity may only have two or three contacts so missing one or more here may be a much higher risk than for a larger utility that may have ten or more contacts. The VSLs should be drafted to include percentages instead of whole numbers. The Lower VSL column for R3 states, “...OR The Responsible Entity validated 75% or more of the contact information contained in the operating plan.” This could be interpreted that even someone completed 100% (which is more than 75%) a low VSL could be assigned. This VSL should be drafted in similar fashion to the Moderate, High and Severe VSLs and include a range (i.e. less than 100% but more than 75%).</p>
<p><b>Response:</b> Thank you for your comment. The SDT followed the NERC guidelines for VRFs and VSLs in setting the appropriate levels. The SDT will forward your suggestions to NERC for future consideration.</p>		
Manitoba Hydro	No	<p>This seems like an administrative only requirement. It would be too difficult to validate or measure.</p>
<p><b>Response:</b> Thank you for your comment. Please see the response to your comment in question 1.</p>		
Independent Electricity System Operator	No	<p>We agree with the VRF for R2, but have a concern over the VRFs assigned to R1 (Lower) and R3 (Medium). Having an event reporting operating plan (R1) is a first step toward meeting the intent of this standard, annually validating it (R3) is a maintenance requirement which arguably can be regarded as equally important but its reliability risk impact for failure to comply should be no higher</p>

Organization	Yes or No	Question 2 Comment
		than having no plan to begin with. We therefore suggest that the VRFs for R1 and R3 be at least the same, or that R1’s VRF be higher than that for R3.
<p><b>Response:</b> Thank you for your comment. The SDT developed the VRFs based on existing, FERC Approved VRFs and NERC Guidelines for establishment of VRFs. EOP-004-2 is a result of merging CIP-001-2a and EOP-004-1. Each requirement in CIP-001-2a is assigned a “Medium” VRF. The requirements of CIP-001-2a map to EOP-004-2 Requirements R1 and R2. Having an Operating Plan (EOP-004-2, R1) merits a “Lower” VRF. The reporting of events contained in the Operating Plan required under Requirement R1 is mandated under Requirement R2 (which maps from CIP-001-2a, R2). The SDT cannot “lower the bar” on an existing VRF per NERC and FERC guidelines. Further, since R3 requires validation of the contact information in the Operating Plan, it is also assigned a “Medium” VRF.</p>		
Southwest Power Pool RTO	No	We question the reliability benefits of this requirement.
<p><b>Response:</b> Thank you for your comment. Requirement R3 is in direct response to a FERC directive in Order 693 and as such, the SDT included this provision. If the information in the Operating Plan is out of date, then the plan will not be effective.</p>		
Lewis County PUD	No	
American Electric Power	No	
<p><b>Response:</b> Thank you for your participation.</p>		
ReliabilityFirst	Yes	<p>Even though ReliabilityFirst votes in the Affirmative, we offer the following comments for consideration regarding the VSLs: VSL for Requirement R2 - ReliabilityFirst questions whether there is justification for the gradation of VSLs out to 60 hours for the reporting an event. Without justification, ReliabilityFirst believes the timeframe should be shortened to eight hour increments with a severe VSL being more than 48 hours late. ReliabilityFirst believes that being more than a day late (24 hours) falls within the entity completely not meeting the intent of submitting the report with the required 24 hour timeframe.</p>
<p><b>Response:</b> Response: Thank you for your comment. The SDT followed the NERC guidelines for VRFs and VSLs in setting the</p>		

Organization	Yes or No	Question 2 Comment
appropriate levels.		
PNGC Comment Group	Yes	
FirstEnergy	Yes	
Arizona Public Service Company	Yes	
Entergy Services, Inc. (Transmission)	Yes	
Clark Public Utilities	Yes	
Public Service Enterprise Group	Yes	
Idaho Power Co.	Yes	
Ingelside Cogeneration LP	Yes	
Wisconsin Electric Power company dba We Energies	Yes	
Ameren Services	Yes	
South Carolina Electric and Gas	Yes	
Georgia Transmission Corporation	Yes	
City of Austin dba Austin Energy	Yes	
Springfield Utility Board	Yes	
American Public Power Association	Yes	

3. Do you have any other comment, not expressed in the questions above, for the DSR SDT?

**Summary Consideration:** Most stakeholders who responded to this question provide comments suggesting specific revisions to the requirements or to the event types listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.

Organization	Question 3 Comment
Detroit Edison	<p>"Suspicious activity" and "suspicious device" should be eliminated from Attachment 1, Event types: 'Physical threats to a Facility' and 'Physical threat to a BES Control Center'. By including 'suspicious activity' in the standard, I believe the project team went outside of the scope of the project, which was intended to be a merger of the two standards. Regarding standard CIP 001, the threshold for reporting is "Disturbances or unusual occurrences, suspected or determined to be caused by sabotage....", as its title suggested: Sabotage Reporting. Suspicious activity, which is not defined by the standard, clearly has a much lower threshold than sabotage, or even suspected sabotage. The reporting requirement of 24 hours, also increases the burden on the entity to either rush to investigate and make a determination regarding suspicious activity in less than 24 hours, or not perform due diligence and report uninvestigated "suspicious" activity, which normally turns out to not be a "Physical Threat". Suspicious activity should be duly investigated by the entity, local law enforcement, or the FBI as appropriate; and then reported if it has been determined to be a physical threat, or cannot be explained. Reporting within 24 hours will devalue the information inputted, as most cases of suspicious activity are innocuous, and the standard lacks a process of follow up, which would remove the those incidents from intelligence databases. Regarding suspicious devices, determination is usually immediate, (in less than 24 hours), and then the device would be classified as either "sabotage" or "no threat". The standard is not clear whether suspicious devices still have to be reported, even if they are immediately determined as not a "Physical Threat to a Facility or BES Control Center." Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-</p>

Organization	Question 3 Comment
	<p>01) - Reporting Concepts states: The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002- Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting." Attachment 1 in existing EOP-004-1 is much easier to follow (specifies time requirement to file). Also R2 states DOE OE-417 may be utilized to file reports, however Standard time requirement for update report is 48 hours, OE-417 has changed time requirement on updated filing to 72 hours. Difference can cause confusion and possible penalties. The real time operator must focus on maintaining system reliability. Putting unnecessary reporting obligations on RT puts more importance on the reporting structure than on maintaining reliability. Let 8/5 support personnel perform the reporting tasks and keep the 24/7 on shift operators focusing on the BES.</p>
<p><b>Response: Thank you for the comment. The SDT disagrees with your position on the inclusion of suspicious activities. Suspicious activities are events and notification of such events is a part of the existing and CIP-001 and EOP-004 standards. Reporting under EOP-004 is for notification purposes only. The standard does not require any analysis of events and does not require any follow up reports as you suggest.</b></p>	
<p>City of Austin dba Austin Energy</p>	<p>(1) City of Austin dba Austin Energy (AE) requests that the SDT clarify whether R3 requires that each Registered Entity subject to EOP-004-2 verify NERC’s contact information each year. It appears this would be overly burdensome for NERC to respond to individual requests. (2) AE also asks that NERC’s fax number be included in the contact information at the beginning of Attachment 1 and at the Event Reporting Form in Attachment 2. NERC included the fax number as a viable contact method in its recent NERC Alert notifying the industry of the changed information. (3) AE requests that the SDT increase the threshold for reporting loss of firm load to approximately 300 MW for all entities to align the reporting threshold with the OE-417 threshold. Otherwise, smaller entities would have to report firm load losses between 200 and 299 MW to NERC but not to the DOE. This could be administratively confusing to those responsible for reporting. (4) Attachment 1 lists the threshold for reporting generation loss at approximately 1,000MW for the ERCOT Interconnection. ERCOT planning is based on a single contingency of 1,375MW. For this reason, AE believes the minimum threshold for a</p>

Organization	Question 3 Comment
	<p>disturbance should be greater than the single contingency amount of &gt;1,375MW for the ERCOT Interconnection.</p>
<p><b>Response: Thank you for your comment. The SDT does not feel it is necessary to specific how the validation occurs and has left this to the entity to determine how to do this. The SDT agrees with the inclusion of the fax number. The SDT will forward the other suggestions to NERC for future consideration. However, it should be noted that these suggestions have not been adopted due to consistency with other standards.</b></p>	
<p>ACES Power Marketing Standards Collaborators</p>	<p>(1) For the first “Damage or destruction of a Facility” event in Attachment 1, the threshold for reporting should be modified. The threshold for reporting would only include damage or destruction that necessitates the need for action to prevent an Emergency. It does not include if an Emergency actually occurs. Based on the definition of Emergency which states that it is an “abnormal system condition that requires... action to prevent or limit”, we think the threshold should be changed to “Damage or destruction of a Facility... that results in a BES Emergency”. Per the definition, the Emergency is what necessitates action which is what the threshold appeared to be focused on. (2) In the second “Damage or destruction of a Facility” event in Attachment 1, the threshold regarding “intentional human action” is ambiguous and suffers from the same difficulties as defining sabotage. What constitutes intentional? How do we know something was intentional without a law enforcement investigation? If a car runs into a transmission tower, was this an accident or intentional human action? It could be either. This appears to be the same issue that prevented the drafting team from defining sabotage.(3) Under the “Physical threats to a BES control center” event in Attachment 1, the event should very clearly define if this applies to backup control centers or not. (4) Under the “Complete loss of off-site power to a nuclear generating plant (grid supply)” event” in Attachment 1, the entity with reporting responsibility is not coordinated with NUC-001. NUC-001 used the term transmission entity to mean an entity that is responsible for providing NPIR services. They did not use only TOP because there are other entities that provide this service. Please coordinate the “Entity with Reporting Responsibility” with that standard. (5) We continue to believe that the draft standard has not satisfied the complete scope of the SAR regarding elimination of redundancy. The draft standard will continue to require redundant reporting by various entities. For instance, under the event “Loss of Firm Load” in Attachment</p>



Organization	Question 3 Comment
	<p>1, the DP, TOP, and BA all are required to report. The response to our last set of comments regarding this issue was that “the industry can benefit from having such differing perspectives when events occur”. This response seems to confuse event analysis with event reporting. The purpose of the standard is to simply report that an event happened. In fact, the reporting form only requires the submitting entity to report the type of event. The description of what happened is optional. What additional perspectives could be gained from having multiple registered entities in the same electrical footprint report that an event happened. If the purpose is to analyze the event, this is covered in the events analysis process. Furthermore, once NERC becomes aware of the event they have the authority to request data and information from other registered entities. Please eliminate the duplicate reporting requirements. Other events that may require duplicate reporting include: Damage or destruction of a Facility, Physical threats to a Facility, BES Emergency resulting in automatic firm load shedding, Loss of firm load, System separation, Generation loss, and Complete loss of off-site power to a nuclear generating plant.(6) In the second “Damage or destruction of a Facility” event and “Physical Threats to a Facility” events, Distribution Provider should be removed. The Distribution Provider does not have any Facilities which is defined as “a set of electrical equipment that operates as a single Bulk Electric System Element”. The DP’s transformers interconnecting to the BES are not Facilities and the latest NERC BOT definition explicitly does not include them in Inclusion I1. If a DP did own Facilities, it would be registered as a TO or GO. Inclusion of the DP will compel the DP to provide evidence that it does not have Facilities which is an unnecessary compliance burden that does not support reliability. (7) The “BES Emergency resulting in automatic firm load shedding” should not apply to the DP. In the existing EOP-004 standard, Distribution Provider is not included and the load shed information still gets reported. (8) For the “Voltage deviation on a Facility” event in Attachment 1, we suggest changing “area” in the threshold for reporting to “Transmission Operator Area” as it is a defined term. (9) For the “System separation (islanding)” event, please remove BA. Because islanding and system separation, involve Transmission Facilities automatically being removed from service, this is largely a Transmission Operator issue. This position is further supported by the approval of system restoration standard (EOP-005-2) that gives the responsibility to restore the system to the TOP. (10) The response to our comments requesting that Measure 2 specifically identify that attestations are</p>

Organization	Question 3 Comment
	<p>acceptable forms of evidence to indicate that no events have occurred indicated that the measure cannot permit use of attestations. Other standards that have been recently approved by the board specifically permit the use of attestations. FAC-003-2 M1 and M2, TOP-001-2 M1-M11 and TOP-003-2 M5 all permit the use of attestations. We ask that the drafting team to reconsider including a specific reference that an attestation is acceptable to indicate no event has occurred given these new facts. (11) In requirement R1, we suggest changing “in accordance with EOP-004-2 Attachment 1” to “to report events identified in EOP-004-2 Attachment 1”. It makes more sense since the attachment is a list of events that require reporting. The other language sounds like additional requirements will be established in Attachment 1.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Southwest Power Pool Regional Entity</p>	<p>(1) SPP RE thinks the following Generation reporting threshold is unclear: "Total generation loss, within one minute, of ¥ 2,000 MW for entities in the Eastern or Western Interconnection". What has to happen within one minute? It reads as if you have to make a report within one minute. If the intent is that a report has to be made within 24 hours if the loss is for more than one minute it should read, "Total generation loss ¥ 2,000 MW for more than one minute for entities in the Eastern or Western Interconnection". What is the intent of the one minute requirement?</p> <p>(2) It appears per R1 that entities are no longer required to include Regional Entities in their reporting chains. SPP RE believes Regional Entities must be included in the reporting chain so they can fulfill their obligations under their delegation agreements.</p> <p>(3) SPP RE thinks this standard was changed substantially enough that it should have been opened for a new ballot pool.</p>

Organization	Question 3 Comment
	<p>Response: Thank you for comment. 1) The intent of the “one minute” language is to avoid having to report when a generator has a slow run back rather than a sudden loss. Typically, a unit will trip instantly and the loss will be clear. Other times, the generation will slowly decline and the SDT does not intend for this to be reported. The reporting requirement is to submit a report for an applicable event within 24 hours. 2) Entities are required to report to the ERO only and may submit reports to others, including the RE. The SDT envisions the reports generated through EOP-004-2 act as an input to the Events Analysis Process which includes participation by the Regional Entity. 3) The SDT followed the standards development process which allows significant revision to the standards as long as it proceeds to a successive ballot. The NERC Standard Processes Manual clearly states that a ballot pool stays in place until balloting is completed on a standard. On occasion, the Standards Committee has determined that it is necessary to form a new ballot pool for a project because the ballot pool has been in place for several years and many of the original ballot pool members are no longer available to vote, but this is not the normal practice.</p>
<p>Ameren Services</p>	<p>(1) This draft refers to a number of activities in the Operations Plan that each entity is to have on hand as the primary guide of actions to be taken when an event occurs. Although there is information related to the requirements that should be included in the Operations Plan, the drafting team has not defined a structure on the format, the minimum information to be included or the direct audience for the Operations Plan. In addition, there is no guidance on the disposition, distribution of the Operations Plan which is left to the entity to determine. We request that the drafting team provide a defined structure for entities concerning the development and implementation of the Operations Plan.</p> <p>(2) Page 14 (Attachment 2) - Voltage Deviation of a Facility - This appears to be a contradiction to VAR-001-2 R10 for TOP which states IROL events will be corrected within 30 minutes. We request the 15 minute reporting criteria be changed to also state 30 minutes.</p> <p>(3) Throughout Document - "Report to the ERO and Regional Entity" - NERC and DHS established the ES-ISAC as a confidential location to report all events that happen on the BES. As these events are of a Sabotage / Disturbance nature, they should all go through the ES-ISAC both as a single location for distribution, and as a best practice that the industry has started.</p> <p>(4) There seems to be some differences between the red-line and clean versions which may need some clarification. For example, (a) In the redline version, the revision history box appears to indicate the inclusion of parts of CIP-008, and in the “Clean” version this has been</p>

Organization	Question 3 Comment
	<p>removed from the revision history box. (b) The red-line version includes a drawing at two places versus once in the clean version. (c) The correlation between the clean and redline documents is not very clear and there appears to be gaps in the reporting and tracking framework structure.</p>
<p><b>Response: Thank you for comment. 1)-3) Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot. 4) In removing tables and diagrams, the redline version tends to show both the old and new with only a red line down the side of the page. The clean version of the standard is the final version.</b></p>	
<p>Texas Reliability Entity</p>	<p>(A) Regional Entity should be capitalized in R1. (B) COMMENTS ON ATTACHMENT 1:In the previous comment period on this Standard, Texas RE submitted comments that we feel were not adequately addressed. There were several responses to comments regarding the Events Table that need deeper review and consideration:(1) In the Events Table, under Transmission Loss, the SDT indicated that reporting is triggered only if three or more Transmission Facilities operated by a single TOP are lost. Also, generators that are lost as a result of transmission loss events must be included when counting Facilities. As Texas RE indicated in previous comments to this Standard, determining event reporting requirements by the entity that owns/operates the facility is not an appropriate measure. If the industry wants to learn from events, these types of issues must be addressed. Including the RC as one of the Entity(s) with Reporting Responsibility may alleviate this concern. The RC would have overall view of the system and could provide the reports on multi-element events where the elements are owned/operated by different entities. For the SDT to believe that “There may be times where an entity may wish to report when a threshold has not been reached because of their experience with their system” is worthy to note but falls short of the reliability implications caused by those entities that will not report. The industry needs to learn from events and failure to report will facilitate failure to learn.</p> <p>(2) In the Events Table, under Transmission Loss, there has been considerable discussion</p>

Organization	Question 3 Comment
	<p>recently within the Events Analysis Subcommittee (EAS) regarding the definition of the phrase “contrary to design.” The EAS is currently working on possible guidelines to interpret this event type. The SDT may want to consider including the EAS language into the Guidelines and Technical Basis for this Standard.</p> <p>(3) In the Events Table, under “Unplanned BES Control Center evacuation” and “Complete loss of voice communication capability,” and “Complete loss of monitoring capability,” GOPs should be included. GOPs also operate control centers that would be subject to these kinds of occurrences. As Texas RE indicated in previous comments to this Standard, in CIP-002-5 Attachment 1 there is a “High Impact Rating” for the following: “1.4 Each Control Center, backup Control Center, and associated data centers used to perform the functional obligations of the Generation Operator that includes control 1) for generation equal to or greater than an aggregate of 1500 MW in a single Interconnection or 2) that includes control of one or more of the generation assets that meet criteria 2.3, 2.6, and 2.9.” In the ERCOT Region, we experienced an event where a GOP control center lost an ICCP link that carried real-time information regarding its generation fleet (over 10,000 MWs). Without inclusion of the GOP here the event may not get recorded. While it was a “virtual” loss, the impact to the BES through generation control actions could be significant and the event should be reported and analyzed. For the GOP control centers that do exist, the reporting of such events should be a requirement. Based on the minimum of these two examples, why would the SDT NOT include GOP as being applicable?</p> <p>(4) In the Events Table, under “BES Emergency requiring public appeal for load reduction,” the definition of Emergency is “Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities....” Is it the intent of the SDT to exclude public appeals issued in anticipation of a possible emergency, before a BES Emergency is officially declared?</p> <p>(5) In the Events Table, under “BES Emergency resulting in automatic firm load shedding,” the SDT may want to consider including the RC as one of the Entity(s) with Reporting Responsibility. The RC would have overall view of the system and should provide the reports on events where the multiple entities may be involved. We have UVLS schemes in our region</p>

Organization	Question 3 Comment
	<p>where the total MW shed is greater than 100 MW, but the individual TOP MW shed is less than 100 MW.</p> <p>(6) In the Events Table, consider whether the item for “Voltage deviation on Facility” should also be applicable to GOPs, because a loss of voltage control at a generator (e.g. failure of an automatic voltage regulator or power system stabilizer) could have a similar impact on the BES as other reportable items. Note: We made this comment last time, and the SDT’s posted response was non-responsive to this concern. The SDT noted “Further, we note that such events do not rise to the level of notification to the ERO” but the SDT failed to recognize that “Voltage deviation on a Facility” does exactly that - notifies the ERO but from a TOP perspective only. Texas RE is trying to establish the correct Responsible Entity for reporting “Voltage deviation on a Facility” (in this case a generator regardless of the cause and other obligations the owner may have with other Reliability Standards).</p>
<p><b>Response: Thank you for comment. A) The SDT agrees and has made the correction. B) Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Central Lincoln</p>	<p>1) Central Lincoln must again point out the lack of proportionality for gunshot insulators and similar events under “Damage or destruction of a Facility.” Please see our last set of comments. These incidents are fairly common in the west, and typically do not cause an immediate outage. They are generally discovered months after the fact, yet the discovery starts the 24 hour clock running as if the situation had suddenly changed. Prior SDT response: “... this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was “damaged or destroyed” intentionally by a human.” There is already a great lag in awareness regarding the damaged insulator. Months or more can pass prior to discovery by the entity. We fail to see how it becomes so urgent upon discovery. Prior SDT response: “The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.”We do not share the SDT’s</p>

Organization	Question 3 Comment
	<p>vision. If an Operating Plan redefined suspected intentional human action so the act of preparing a gun for firing, aligning the sights on an insulator and pulling the trigger was not included, we believe the entity that operates under that plan would be found non-compliant under the language of this standard. We do not offer a simple change in text that will fix the problem, we are only pointing out the problem exists. Murphy dictates discovery will occur at the most inopportune time, which will be during an after hours outage on a stormy holiday weekend night when many employees are out of town and those that are available are already fully engaged. The entity is then faced with choosing to delay restoration or violating the standard. When proposing a zero defect event driven requirement event driven such as this one, we ask the SDT to consider all possible scenarios in which the event may occur.</p> <p>2) We note that Distribution Providers are listed in the Applicability Section. We also note that there is no requirement in the Statement of Compliance Registry Criteria for Distribution Providers to own or operate BES Facilities, own or operate UFLS or UVLS of 100 MW, or to have load exceeding 200 MW. DP’s that cannot meet any of the thresholds of Attachment 1 would still need an Operating Plan under R1 and annually validate the possibly null contact list in its OP under R3. We suggest that DPs that cannot meet the thresholds of Attachment 1 be removed from the Applicability Section.</p>
<p><b>Response: Thank you for comment. 1) Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p><b>2) To your suggestion on DPs, the SDT has clarified, in the Guidelines and Technical Basis Section of the standard, that DPs who do not meet the threshold reporting requirements can conduct an annual review of the threshold requirements and be exempted from R1 and R3 for that period. Once the DP has met the threshold reporting requirements, they will then have to comply with the standard.</b></p> <p><b>“Distribution Provider Applicability Discussion</b></p> <p><b>The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not</b></p>	

Organization	Question 3 Comment
	<p>all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more that 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.”</p>
<p>Duke Energy</p>	<ol style="list-style-type: none"> <li>1) There are discrepancies between the red-lined EOP-004-2 and the Clean EOP-004-2 that were posted for this project. Our comments are based upon the Clean EOP-004-2.</li> <li>2) Attachment 1 and Attachment 2 have the ERO email and phone number listed. If these ever change, does the standard have to go through the revision and balloting process again, or is there an easier way to incorporate such changes?</li> <li>3) Attachment 1 - When an event occurs that meets the Threshold for Reporting, it’s not clear whether all listed entities have to report or not. Several Event Types need this clarity added. For example, if a TOP loses voice communication capability, do both the TOP and RC have to report?</li> <li>4) Attachment 1 - Damage or destruction of a Facility, applicable to BA, TO, TOP, GO, GOP, DP. The Threshold for Reporting should be further clarified by adding the sentence “Do not report theft or damage unless it degrades normal operation of a Facility.” This would eliminate unnecessary reporting of copper theft or vandalism.</li> <li>5) Attachment 1 - Physical threats to a Facility. The Threshold for Reporting should be modified by deleting the sentence “Do not report theft unless it degrades normal operation of a Facility”. This sentence isn’t needed here, and fits better with “Damage or destruction of a Facility” as noted in 4) above.</li> <li>6) Attachment 1 - Transmission loss. This event type should be deleted because it is duplicated</li> </ol>



Organization	Question 3 Comment
	<p>under TADS reporting and PRC-004 Protection System Misoperations reporting.</p> <p>7) Attachment 1 - Unplanned BES control center evacuation, Complete loss of voice communication capability, and Complete loss of monitoring capability. The Threshold for Reporting on all three of these Event Types is 30 minutes, and should be extended to 2 hours, consistent with the transition time identified in EOP-008 “Loss of Control Center Functionality”.</p>
<p><b>Response:</b> Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
<p>ERCOT</p>	<p>As a general matter, this standard imposes an ex-post reporting obligation. Consistent with the ongoing P 81 standard review/elimination effort, this standard is arguably a candidate for elimination under the principles guiding that effort. The obligation proposed in the standards are better suited for inclusion in the Rules of Procedure or as a guideline because they are strictly administrative in nature.</p> <p><b>Response:</b> On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-</p>

Organization	Question 3 Comment
	<p><b>004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</b></p> <p>To the extent the SDT continues to pursue this effort, ERCOT offers the following additional comments. ERCOT has commented on the listing in the Entity with Reporting Responsibility column of Attachment 1. Consistent with those prior comments, the current version still fails to adequately create a bright line threshold for particular events. For example, in the Transmission loss event, although the TOP is listed, there is no direction regarding which TOP is required to file the event report. Is it the TOP in whose TOP area the loss occurred or is it a neighboring TOP who observes the loss? Clearly, the responsibility for reporting lies with the host system, but that responsibility is not clearly designated. There are several other similar events where there is no bright line. We suggest that the drafting team return the deleted language to the Entity with Reporting Responsibility column in those instances where the current version fails to provide a bright line in the Threshold column. Regarding multiple reports for a single event, that aspect of the proposed draft should be revised to only require a single report. While additional information may be available from others, let the Event Analysis team perform their function. This would eliminate the redundant reporting that is currently required as the standard is written.</p> <p><b>Response: Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p>ERCOT requests that the reference to “cyber attack” be removed from the Guideline and Technical Basis section of the document since all reporting of cyber events has been removed from the standard and retained in CIP-008.</p> <p><b>Response: This correction has been made.</b></p>

Organization	Question 3 Comment
<p><b>Response: Thank you for comment. Please see responses above.</b></p>	
<p>American Public Power Association</p>	<p>As stated in our comments on the previous draft: It is APPA’s opinion that this standard should be removed from the mandatory and enforceable NERC Reliability Standards and turned over to a working group within the NERC technical committees. Timely reporting of this outage data is already mandatory under Section 13(b) of the Federal Energy Administration Act of 1974. There are already civil and criminal penalties for violation of that Act. This standard is a duplicative mandatory reporting requirement with multiple monetary penalties for US registered entities. If this standard is approved, NERC must address this duplication in their filing with FERC. This duplicative reporting and the differences in requirements between DOE-OE-417 and NERC EOP-004-2 require an analysis by FERC of the small entity impact as required by the Regulatory Flexibility of Act of 1980</p>
<p><b>Response: Thank you for the comment. The SDT does not believe that there is duplicative reporting. The reports that you mention do not go to NERC under the FPA. We will forward your suggestion to NERC for consideration in the preparation of the filing for approval.</b></p>	
<p>NV Energy</p>	<p>Aside from the comment referring to the new R3 and the term "validate", I applaud the SDT for the improvements made in the remainder of the Standard. This is a much simpler and straightforward approach to meeting the directives in this project and greatly simplifies the processes necessary on the part of the registered entities.</p>
<p><b>Response: Thank you for your comment.</b></p>	
<p>CenterPoint Energy</p>	<p>CenterPoint Energy appreciates the revisions made to the draft Standard based on stakeholder feedback and believes that the changes made are positive overall. However, the Company recommends the additional changes noted below for a favorable vote. In the Rationale for R1, CenterPoint Energy recommends that the 2nd sentence in the 1st paragraph be revised as follows, “In addition, these event reports may serve as input to the NERC Events Analysis Program.”, as not all events listed in Attachment 1 will serve as input in to the NERC Events Analysis Program. CenterPoint Energy also proposes that the Standard Drafting Team (SDT)</p>

Organization	Question 3 Comment
	<p>add "There cannot be a violation of Requirement R2 without an event." as noted in the Consideration of Issues and Directives to the Requirement. For Attachment 1, CenterPoint Energy recommends the following revisions: CenterPoint Energy continues to be concerned that the uses of the terms “suspicious” and “suspected” are too broad. The Company proposes that the SDT remove the terms from the Thresholds for Reporting or add “which caused a negative impact to the Bulk Electric System” or “that causes an Adverse Reliability Impact...” to each phrase where the terms are used. CenterPoint Energy proposes that the threshold for reporting the event, “BES Emergency requiring manual firm load shedding” is too low. It appears the SDT was attempting to align this threshold with the DOE reporting requirement. However, as the SDT has stated, there are several valid reasons why this should not be done. Therefore, CenterPoint Energy recommends the threshold be revised to “Manual firm load shedding â%¥ 300 MW”. CenterPoint Energy also recommends a similar revision to the threshold for reporting associated with the “BES Emergency resulting in automatic firm load shedding” event. (“Firm load shedding â%¥ 300 MW (via automatic under voltage or under frequency load shedding schemes, or SPS/RAS”) For the event of “System separation (islanding)”, CenterPoint Energy believes that 100 MW is inconsequential and proposes 300 MW instead. For “Generation loss”, CenterPoint Energy suggests that the SDT add "only if multiple units" to the criteria of “1,000 MW for entities in the ERCOT or Quebec Interconnection”.</p>
<p><b>Response:</b> Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
<p>PNGC Comment Group</p>	<p>Comments: The PNGC Comment group remains concerned that the “Applicability” section will inadvertently subject Distribution Providers to requirements that they should be excluded from. Please consider the two examples below and note that we’re talking about probably hundreds of small DPs being subject to these unnecessary requirements without any increase to the reliability of the BES. Example 1: Small DP with a peak load of 50 MWs. They have no</p>

Organization	Question 3 Comment
	<p>BES Facilities and their system is radial. Even though this utility will never have a reporting requirement per Attachment A, they are still subject to R1 and R3 plus the associated compliance (read financial) risk for non-conformance. An easy fix to this issue would be for DPs without BES Facilities and with less than 200 MW annual peak load to be excluded in the Applicability section. Example 2: Small DP with a peak load of 50 MWs. Their only BES Facilities are two Automatic UFLS relays that are capable of shedding 15 MWs. DP's Host Balance Authority (HBA) has a peak load of 10,000 MWs, meaning their UFLS plan requires them to have the capacity to shed 3000 MWs should system conditions warrant. Is it the SDT's intent for this DP to have an Operating Plan in place for "damage", "destruction", or "physical threat" for these two relays that are capable of shedding only 15 MWs out of a 3000 MW HBA UFLS plan? The SDT set a 100 MW threshold for reporting of automatic UFLS load shedding so why have reporting requirements for the threat to 15 MWs worth of UFLS relays? Once again the easy fix is to modify the Applicability section. We suggest: 4.1.7. Distribution Provider: with &gt;= 200 MW annual peak load, or;&gt;= 100 MW Automatic firm load shedding</p>
<p><b>Response:</b> Thank you for comment. To your suggestion on DPs, the SDT has clarified, in the Guidelines and Technical Basis of the Standard, that DPs who do not meet the threshold reporting requirements can conduct an annual review of the threshold requirements and be exempted from R1 and R3 for that period. Once the DP has met the threshold reporting requirements, they will then have to comply with the standard.</p> <p><b>"Distribution Provider Applicability Discussion</b></p> <p>The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the "Threshold for Reporting" for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more that 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan</p>	

Organization	Question 3 Comment
<p>to comply with the requirements of the standard.”</p>	
<p>Cowlitz PUD</p>	<p>Cowlitz approves of the improvement efforts on Attachment 1. However, Cowlitz must again point out the fallacy of potentially inundating the ERO with nuisance reporting of minor vandalism and accidental damage. For example, gunshot “target practice” of insulators and structures will apply under “Damage or destruction of a Facility.” Such incidents are fairly common in the west, and typically do not cause an immediate outage. They are generally discovered months or years after the fact, yet the discovery starts the 24 hour compliance clock running as if the urgency is just as important as a recent event. If there is already a great lag in awareness regarding the damaged Facility, Cowlitz fails to see how it becomes so urgent upon discovery.-----Again, Cowlitz points out the sentence structure “Damage or destruction of its Facility that results from actual or suspected intentional human action” does not restrict the human action as malicious or sabotage. “Intentional human action” could be innocent, such as a land owner attempting to fall a tree for fire wood. The intent was not to damage the Facility, but the “intentional human action” to obtain fire wood resulted in the damage of the Facility. This does not comport with prior SDT response: “... this will give the ERO (and whoever else the entity wishes to inform per Requirement R1) the situational awareness that the Facility was ‘damaged or destroyed’ intentionally by a human.” Therefore, if this is the SDT’s intent Cowlitz suggests this change: Damage or destruction of its Facility that causes immediate impaired operation or loss of the Facility from suspected or actual malicious human intent. Do not report mischievous vandalism, as defined in the Operating Plan, where immediate loss of, or immediate impaired operation of the Facility has not occurred. -----Prior SDT response: “The SDT envisions that entities could further define what a suspected intentional human action is within their Operating Plan.” Cowlitz does not share the SDT’s vision. The Standard as written does not specifically address the ability to “further define” terms used in the Attachment. Past allowance of audit teams to allow registered entity definitions, e.g. “annual,” was to address gaps in standards until the standards could be revised. If this is truly the intent of the SDT, then requirement R1 would need revision such as: “The Operating plan shall define what a suspected intentional human action is.” Cowlitz respectfully requests that ambiguity be avoided.----- Cowlitz notes that Distribution Providers are listed in the Applicability Section with no qualifiers. Cowlitz</p>

Organization	Question 3 Comment
	<p>points out that there is no requirement in the Statement of Compliance Registry Criteria for Distribution Providers to own or operate BES Facilities, own or operate UFLS or UVLS of 100 MW, or to have load exceeding 200 MW. DP’s that cannot meet any of the thresholds of Attachment 1 would still need an Operating Plan under R1 and annually validate the possibly null contact list in its OP under R3. Cowlitz requests that DPs that cannot meet the thresholds of Attachment 1 be removed from the Applicability Section. Not doing so will increase compliance risk without any reliability return.</p>
<p><b>Response:</b> Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p> <p>To your suggestion on DPs, the SDT has clarified, in the Guidelines and Technical Basis Section of the Standard, that DPs who do not meet the threshold reporting requirements can conduct an annual review of the threshold requirements and be exempted from R1 and R3 for that period. Once the DP has met the threshold reporting requirements, they will then have to comply with the standard.</p> <p>“Distribution Provider Applicability Discussion</p> <p>The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more that 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.”</p>	
Wisconsin Electric Power company	Damage or destruction of a Facility, Damage or destruction of its Facility that results from

Organization	Question 3 Comment
dba We Energies	<p>actual or suspected intentional human action.: By the Functional Model, I do not believe the BA function has Facilities by the NERC Glossary definition. This would not apply to a BA. The line above this would adequately cover BA reporting. Remove a BA from applicability for this line.</p> <p>Physical threats to a Facility: The BA function does not have Facilities. Remove a BA from applicability for this line. There could be a separate line for Physical Threats to a Facility within an RC, FOP, BA Area as there is for Damage or Destruction of a Facility. Voltage deviation on a Facility: Please specify what voltage this is, nominal, rated, etc. This should also be &gt; 10% deviation. Exactly at 10% could be at the edge of an allowed range.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
Manitoba Hydro	<p>Does the Background, Guidelines and Technical Basis form part of the standard itself once published? Or are these just parts of the package that accompany the standard during circulation for comment?</p> <p><b>The background, guidance and technical basis will remain with the standard and provides clarification on the SDT’s intent and direction</b></p> <p>Compliance 1.2: The reference to Responsible Entity is bracketed and in lowercase. We are not clear why.</p> <p><b>This was corrected in the clean version.</b></p> <p>VSLs, R1, Severe VSL: The words "in the event reporting Operating Plan" are missing from the end of this sentence.</p> <p><b>This was corrected in the clean version.</b></p>



Organization	Question 3 Comment
	<p>VSLs, R2, Lower VSL: The violation occurs if the Responsible Entity has submitted an event report to one entity whereas Moderate VSL, High VSL and Severe VSL, the level of severity of the VSL increases depending on the number of entities that the Responsible Entity fails to submit an event report to. The drafting here is not as precise as it should be. The way the Lower VSL is written, it will also be triggered when the Responsible Entity has complied with the requirement. For example, if the Responsible Entity is required to report an event to 5 entities, and it does, it will still mean that it has "submitted an event report to one entity identified in the event reporting (also, the 'ing' is missing on the Lower VSL reference)Operating Plan". It is also duplicative. For example, if the Responsible Entity submitted a report to only one entity, and failed to submit a report to 4 others, they fall under the Lower VSL and the Higher VSL (we are assuming in this case, the violation will be found to be the higher VSL). Perhaps what the drafting team intended to do was to make the Lower VSL, which the Responsible Entity failed to submit an event report...to one entity identified....</p> <p><b>The SDT followed the NERC guidelines for VSLs in setting the appropriate levels. The VSLs were written based on two potential failures to meet the requirement. The first is based on the time the report was submitted while the second was based on the entity submitting the report within 24 hours but not to all applicable entities. If a violation is determined, it will be for either being late with the report or for not submitting the report to everyone. The appropriate VSL will be applied ONLY if a violation is found.</b></p> <p>The Guidelines and Technical Basis contain a reference to R4 which no longer exists in the standard.</p> <p><b>This reference has been removed.</b></p>
<p><b>Response: Thank you for comment. Please see responses above.</b></p>	
<p>Dominion</p>	<p>Dominion reads Requirement R1 as explicitly requiring only the inclusion of reporting to the ERO in the Operating Plan. We acknowledge that the requirement also contains additional entities in parenthesis which infers the inclusion of a larger group (and which appears to be supported by the rationale box). Dominion suggests the SDT explicitly state which entities, at a minimum, be included, for reporting, in the Operating Plan. We suggest adding a column to</p>

Organization	Question 3 Comment
	<p>Attachment 1 and including entities to which the event must be reported. As an examples; o All event types should include local law enforcement o Events for which the BA, RC, TOP bear responsibility should probably also be reported to the regional entity o Events for which the Facility Owner bears responsibility should probably also be reported to the respective BA and TOP, who would in turn determine whether to notify their respective RC. The RC would in turn determine if additional entities need to be contacted. Requirement R2 establishes a 24 hour reporting threshold; however, the “NOTE” provided on Attachment 1 seems to contradict Requirement 2 and could therefore lead to compliance issues. Dominion suggests that Requirement R2 be revised to agree with the “NOTE” on Attachment 1. For example, Requirement R2 could be reworded as: Except as noted on Attachment 1, Each Responsible Entity shall...Also under the “NOTE” in Attachment 1, why has the facsimile number for the ERO been removed? The DOE still provides a facsimile number for reporting. Attachment 2: Event Reporting Form #4; need to update the below to reflect the same naming convention of the events in Attachment 1, the “t” should not be capitalized in Physical Threat and add an ‘s’ behind threat. Add (islanding) behind System separation and capitalize the ‘U’ in unplanned control center evacuation.</p>
	<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>
<p>Southern Company</p>	<p><b>NOTE: The SDT received assistance from Southern Company personnel in parsing these comments as show below. As submitted, the formatting of the original comments was lost and very difficult for the SDT to read and understand.</b></p> <p>Event Type Entity with Reporting Responsibility Threshold for Reporting SOCO Comment:</p> <p><b>Damage or destruction of a Facility</b> RC, BA, TOP Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area, excluding weather or natural disaster related threats, that results in actions to avoid a BES</p>

Organization	Question 3 Comment
	<p>Emergency. – No Comment</p> <p><b>Damage or destruction of a Facility</b> BA, TO, TOP, GO, GOP, DP Damage or destruction of its Facility that results from actual or suspected intentional human action.:</p> <p>Do not report damage unless it degrades normal operation of a Facility.</p> <p>How does the SDT define “intentional human action?” Further, how is the phrase “suspected intentional human action” defined? This phrase is very broad. Is “intentional human action” identified as actions intended to damage facilities or does it include accidental actions by individuals? For example, if a person accidentally shot insulators off of a 230 kV line resulting in damage, would that be considered reportable “intentional human action?”</p> <p>In addition, what is that actual trigger for reporting? Does it require that the action has been discovered or is it from the time the event occurs? Further, 24 hours is a very brief time period -- how is an entity to conduct an investigation within that time period to determine if damage or destruction could have resulted from “actual or suspected” human action and also determine if it could have been “intentional”?</p> <p>In Southern’s cases, and likely in other entities case, operating personnel submit the reports to the regulatory entities for events that fall under this standard. Southern is concerned, that the threshold for reporting for “Damage or destruction of a Facility” and “Physical threats to a Facility” is so broad that numerous reports would need to be filed that 1) may be a result of something that does not pose harm to reliability and should not be of interest to the regulators, and 2) would introduce additional burden to operating personnel that are monitoring the system every moment of the day. With the current proposed “Threshold for Reporting”, the reporting requirement would hamper the ability of system operating personnel to perform their core real-time system operator tasks which would harm reliability.</p> <p><b>Physical threats to a Facility</b> BA, TO, TOP, GO, GOP, DP Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility. OR Suspicious device or activity at a Facility. Do not report theft</p>

Organization	Question 3 Comment
	<p>unless it degrades normal operation of a Facility.</p> <p>Please provide some clarity as to what is considered suspicious activity. For example, would someone taking a photo of a BES substation fall into this category? Please provide examples of what may be considered suspicious activity and how NERC and others may use this information and what actions they would take as a result of receiving this information.</p> <p>In addition, what is that actual trigger for reporting? Is it when the threat is discovered or from when it should have or could have been discovered? Further, 24 hours is a very brief time period -- how is an entity to conduct an investigation within that time period in order to determine if the physical threat has the potential to degrade the normal operation of the Facility or that the “suspicious activity”?</p> <p><b>Physical threats to a BES control center</b> RC, BA, TOP Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center. OR Suspicious device or activity at a BES control center. – No Comment</p> <p><b>BES Emergency requiring public appeal for load reduction</b> Initiating entity is responsible for reporting. Public appeal for load reduction event.</p> <p>It is unclear which entity would be responsible for reporting this event. For example, if the RC/TOP/BA were to identify the need to do this and instruct an LSE to issue the public appeal, who would report the event?</p> <p><b>BES Emergency requiring system-wide voltage reduction</b> Initiating entity is responsible for reporting System wide voltage reduction of 3% or more.</p> <p>It is unclear which entity would be responsible for reporting this event. For example, if the RC were to identify the need to do this and instruct a TOP to reduce voltage, who would report the event?</p> <p><b>BES Emergency requiring manual firm load shedding</b> Initiating entity is responsible for reporting Manual firm load shedding ≥ 100 MW. – No Comment</p>

Organization	Question 3 Comment
	<p><b>BES Emergency resulting in automatic firm load shedding</b> DP, TOP Automatic firm load shedding <math>\hat{\approx}</math> 100 MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS). – No Comment</p> <p><b>Voltage deviation on a Facility</b> TOP Observed within its area a voltage deviation of <math>\pm</math> 10% of nominal voltage sustained for <math>\geq</math> 15 continuous minutes. Please change “nominal” to “expected” or “scheduled”</p> <p><b>IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)</b> RC Operate outside the IROL for time greater than IROL Tv (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only). – No Comment</p> <p><b>Loss of firm load</b> BA, TOP, DP Loss of firm load due to equipment failures/system operational actions for <math>\geq</math> 15 Minutes: <math>\geq</math> 300 MW for entities with previous year’s demand <math>\geq</math> 3,000 MW OR <math>\geq</math> 200 MW for all other entities This should not be as a result of weather or natural disasters.</p> <p><b>System separation(islanding)</b> RC, BA, TOP Each separation resulting in an island <math>\hat{\approx}</math> 100 MW – No Comment</p> <p><b>Generation loss</b> BA, GOP Total generation loss, within one minute, of <math>\hat{\approx}</math> 2,000 MW for entities in the Eastern or Western Interconnection OR <math>\hat{\approx}</math> 1,000 MW for entities in the ERCOT or Quebec Interconnection – No Comment</p> <p><b>Complete loss of off-site power to a nuclear generating plant (grid supply)</b> TO, TOP Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement – No Comment</p> <p><b>Transmission loss</b> TOP Unexpected loss, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing). – No Comment</p> <p><b>Unplanned BES control center evacuation</b> RC, BA, TOP Unplanned evacuation from BES control center facility for 30 continuous minutes or more. – No Comment</p>

Organization	Question 3 Comment
	<p><b>Complete loss of voice communication capability</b> RC, BA, TOP Complete loss of voice communication capability affecting a BES control center for 30 continuous minutes or more. – No Comment</p> <p><b>Complete loss of monitoring capability</b> RC, BA, TOP Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (i.e., State Estimator or Contingency Analysis) is rendered inoperable. – No Comment</p> <p><b>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b> Guideline and Technical Basis Comments</p> <p>In the Summary of Key Concepts section of the Guideline and Technical Basis, the DSR SDT explains that the proposed Standard does not include any real-time operating notifications for events listed in Attachment 1. The DSR SDT should consider language in the Standard which codifies this approach. Southern Company notes that the proposed standard does not mention any exclusion of real-time notification.</p> <p><b>Response: The SDT does not believe that this revision is necessary as the requirement R2 clearly states that events are to be reported within 24 hours.</b></p> <p>The Law Enforcement Reporting section of the Guideline and Technical Basis unintentionally expands on the purpose of the Standard by stating that “The Standard is intended to reduce the risk of Cascading events.” The stated purpose of the Standard is “To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.” The phrase in the Guideline should be removed or modified in order to avoid any uncertainty about the Standard’s purpose.</p> <p><b>Response: The SDT has made the requested clarification to the Guidelines and Technical Basis section.</b></p>

Organization	Question 3 Comment
	<p>The DSR SDT should consider integrating the content of the Concept Paper into the Guideline and Technical Basis. Presently, the Concept Paper appears as an add-on at the end of the document. When the Concept Paper existed as a stand-alone document, various segments such as “Introduction” and “Summary of Concepts and Assumptions” were helpful to stakeholders and standards developers. The revised merged document in the present draft does not need two separate sections addressing concepts nor does it need an introduction at the midway point. Additionally, two other areas are either duplicative or contribute to ambiguity within the supplemental information. First, it is not clear that the segment on Concepts and Assumptions includes any actual assumptions. The section should be modified or deleted to address this concern. Second, the segment entitled ‘What about sabotage?’ seems to contain topics similar to those on the first page of the Guideline. Again, the DSR SDT should consider integrating all of the necessary information into a more comprehensive document.</p> <p><b>Response: The SDT has chosen to leave these sections in tact because it helps convey the development process as well as the information about the team’s insights.</b></p>
<p><b>Response: Thank you for comment. Please see responses above.</b></p>	
FirstEnergy	<p>FirstEnergy Corp (FE) appreciates the work done by the SDT by incorporating the comments and revisions from the previous draft. FE would like to see the time parameters in Requirement 3 and Measure 3 to be changed from “each calendar year” to “at least once every 12 months”. This is similar to the wording that is being used in the CIP standards</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
Oncor Electric Delivery	<p>For reporting consistency, under the Event Type labeled “Generation Loss”, in Appendix 1 of EOP-004-2, Oncor recommends that the reporting threshold of 1,000 KW for the ERCOT Interconnection be raised to 1,400 MW to match the 1,000 MW level in the current version of</p>

Organization	Question 3 Comment
	<p>the ERO Event Analysis Program.</p> <p>Under the Event Type labeled “Damage or Destruction of a “Facility”, Appendix 1, with the threshold that states, “ Damage or destruction of its Facility that results from actual or suspected intentional human action”, Oncor suggest the addition of the following language to address intentional human action that is theft in nature but is not intended to disrupt the normal operation of the BES: “Do not report theft unless it degrades the normal operation of a Facility.”</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Georgia Transmission Corporation</p>	<p>GTC recommends a minor change to Attachment 2 associated with the complete loss of off-site power to nuclear generating plant. NUC-001-2 R9.3.5 describes provisions for restoration of off-site power and applies to both the Nuclear Plant Generator Operator and the applicable Transmission Entities. To maintain consistency, GTC recommends modification to this row in EOP-004-2 Attachment 2 such that the “Nuclear Plant Generator Operator” is the Responsible Entity with reporting responsibility. (A TO may not have visibility to all off-site power resources for a nuclear generating plant if multiple TO’s are providing off-site power.)At a minimum, GTC recommends if the SDT believes the TO and TOP should remain involved, these entities should be limited to “TO and TOP that are responsible for providing services related to Nuclear Plant Interface Requirements (NPIRs)” which is also consistent with NUC-001-2.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	



Organization	Question 3 Comment
South Carolina Electric and Gas	<p>Has the drafting team considered how reports from R2 tie in with reports required by the NERC Event Analysis process? It appears that reporting deadlines conflict between the two. The SDT should clarify that the event types "Damage or Destruction" listed in attachment 1 do not pertain to "cyber events", to avoid duplication of the CIP-008 requirements.</p>
<p><b>Response: Thank you for comment. Reporting under this standard is for the notification of events to the NERC Situation Awareness Group. Reports in this standard can be the initial reports for the EA group, but are not designed to address the balance of the EA program. The SDT had removed the cyber security obligations in this draft.</b></p>	
Xcel Energy	<p>In attachment one, the “Threshold for Reporting” under Damage or Destruction of a Facility appears to closely follow the definition of sabotage that EOP-004-2 says it is trying to do away with. This definition should be drafted to better correlate with the other physical threats and include the language, “which has the potential to degrade the normal operation of the Facility”.</p> <p>Additionally in Attachment 1, both the Physical threats to a Facility and Physical threats to a BES control center include the wording, “Suspicious device or activity...”. What constitutes suspicious activity? With no definition this interpretation is left to the Entity which is again something the DSR SDT says they would like to eliminate.</p> <p>Lastly, in the Guideline and Technical Basis section, under A Reporting Process Solution - EOP-004 it states, “A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.” This appears to be in direct conflict with the Rationale for R1 which states, “An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.”</p>

Organization	Question 3 Comment
	<p>CIP-001-2a required “communication contacts, as applicable, with local Federal Bureau of Investigation (FBI)...” so if the CIP-001-2a procedure is included this does not seem to meet the requirements of the operating plan required under EOP-004-2. Also, if the intent of the Operating Plan is to include all local law enforcement and not FBI the operating plan would become very detailed and when validated annually as required in R3, this becomes very burdensome on an entity.</p>
<p><b>Response: Thank you for comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>American Electric Power</p>	<p>In the spirit of Paragraph 81 efforts, we request the removal of R1. R1 is administrative in nature, existing only to support R2. Reporting an event externally might necessitate the need for a plan/procedure/policy/job aide, but requiring it is an overreach. Having two requirements rather than one increases the likelihood of being found non-compliant for multiple requirements rather than a single requirement. The Paragraph 81 project team has already recommended removing the requirement to have contact information with law enforcement from CIP-001 R4. Notwithstanding our comments above, we recommend removing the phrase “and other organizations...” from R1. If this requirement is to remain, it needs to be very specific regarding who needs to be included in the reporting.R2 –</p> <p>We recommend removing “per their Operating Plan” from R2 so it reads “Each Responsible Entity shall report events within 24 hours of meeting an event type threshold for reporting.” If an entity deviates from its plan but still meets the intent of the requirement (e.g. reporting to NERC with 24 hours), this could be viewed as a finding of non-compliance. We need to get away from “compliance for compliance’s sake”, and focus solely on those efforts which will benefit the reliability of the BES.</p> <p>Attachment 1 Page 13, Row 1 (Clean Version): This is too open-ended and would likely lead to voluminous reporting. As it currently reads, “Damage or destruction of a Facility within its</p>

Organization	Question 3 Comment
	<p>Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency” could bring all copper thefts into scope. Thefts should not need to be reported unless the theft results in reliability concerns as specified by other criteria or parameters in Attachment 1.</p> <p>Attachment 1 Page 13, Row 2 (Clean Version): The threshold “Damage or destruction of its Facility that results from actual or suspected intentional human action” should be eliminated entirely. For the event Damage or destruction of a Facility, the threshold for reporting is set too low.</p> <p>Attachment 1 Page 13, Row 3 (Clean Version): We suggest modifying the text to read “Do not report theft... unless the theft results in reliability concerns as specified by other criteria or parameters in Attachment 1.”</p> <p>Attachment 1 Page 14, Row 4 (Clean Version): Regarding “Loss of Firm Load”, we suggest making it clear that the MW threshold is an aggregate value for those entities whose TOP is responsible for multiple operating companies or legal entities. In addition, is it necessary to include the DP as an entity with reporting responsibility? Its inclusion could create confusion by further segmenting the established threshold.</p> <p>Attachment 1 Page 15, Row 1 (Clean Version): Including “Transmission loss” as currently drafted would result in much more reporting than is necessary or warranted. As currently drafted, it could bring more events into scope than intended, especially for larger entities.</p> <p>EOP-004 Attachment 2: Event Reporting Form: AEP remains concerned that industry would be required to report similar information to multiple Federal entities, in this case to both NERC (Attachment 2) and the DOE (OE-417). In addition, the reporting requirements are not clear for every kind of event as to which entity the reports must be forwarded to, and it is unclear how information would be passed to other entities as necessary.</p> <p>EOP-004 Attachment 2: Event Reporting Form: This form is a further example of mixing security concepts with operational concepts. Not only is not advisable, it does not serve the interests of either concept.</p>

Organization	Question 3 Comment
	<p>Response: Thank you for your comment. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration. As the Paragraph 81 efforts are beyond the scope of this project, the SDT can only pass along your suggestion to that project team for action there.</p> <p>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>
<p>Midwest Independent Transmission System Operator, Inc.</p>	<p>MISO respectfully submits that several of the thresholds for reporting in EOP-004 - Attachment 1 should be modified to clarify when the reporting obligation is triggered, and to ensure that entities are reporting events of the type and significance intended. In particular, MISO focuses on the following draft thresholds in EOP-004 - Attachment 1:</p> <ul style="list-style-type: none"> <li>o The requirement that an entity report when “[d]amage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency.” A BES Emergency is defined as “Any abnormal system condition that requires automatic or immediate manual action to prevent or limit the failure of transmission facilities or generation supply that could adversely affect the reliability of the Bulk Electric System.” RCs and BAs take actions each and every day to “avoid a BES Emergency.” At the time of those actions, they are reacting to conditions that their operating personnel are observing on the</li> </ul>

Organization	Question 3 Comment
	<p>BES. There is no way for an RC or a BA to discern whether the conditions to which they reacted resulted from the “damage or destruction of a Facility” and there is no requirement for Transmission Operators and/or Owners to report “damage or destruction of a Facility” to their BA or RC. Accordingly, RCs and BAs will likely, often not be sufficiently informed to determine if their actions require them to submit a report. Responsible entities are likely to expend significant time and resources reporting daily operations and actions routinely taken to respond to observed BES conditions as they present themselves. These actions may be in response to congestion, equipment outages, relay malfunctions, etc. Whether or not the initiating factor was “damage to or destruction of a Facility” will often be an unknown factor and - even if such is known - the genesis of that damage and/or what constitutes damage (as discussed below) present further potential for confusion and over-reporting. Nonetheless, the lack of clarity in the standard is likely to result in some RCs and BAs preparing reports whether or not they definitely ascertain the underlying cause for the system conditions that prompted them to take actions “to avoid a BES Emergency.” The preparation and submission of such reports, in many cases, will not facilitate the stated objective of this standard, which is the improvement of the reliability of the Bulk Electric System. In addition, with respect to damage or destruction of a Facility, it is debatable as to what would be considered “damage.” For example, would an improper repair or outage that results in damage to a Facility that requires a more extended repair or outage be deemed “damage” to that Facility under this standard? These ambiguities will likely result in significant over-reporting, over-burdening responsible entities, and inundating Regional Entities and NERC with information that is not useful for the purpose of facilitating the reliable operation of the Bulk Electric System. These effects would undermine the express purpose of the standard and the potential value of information if the reporting obligations are appropriately defined, assigned, and scoped. For these reasons, MISO recommends that the SDT revise the standard to: (1) remove the requirement for RCs and BAs to report the “damage or destruction of a Facility” as it is redundant of the immediately subsequent requirement, (2) to remove reporting responsibility from BAs to report the “damage or destruction of a Facility” as this obligation is more properly placed with the TO, TOP, GO , GOP, and DP, and (3) provide guidance to the remaining responsible entities, TO, TOP, GO , GOP, and DP, regarding when “damage” to a Facility should be reported, e.g., an illustrative list of the types of “damage” that would yield information and/or trends that</p>

Organization	Question 3 Comment
	<p>would facilitate the improvement of the reliability of the BES.</p> <p>o The requirement to report “[p]hysical threats to a Facility” and/or “[p]hysical threats to a BES Control Center” With respect to physical threats to Facilities or BES Control Centers, what is considered a “physical threat” and/or a “suspicious device or activity”? Is a crank call count that the building is on fire a physical threat? Is the return of a disgruntled employee suspicious? MISO understands and supports the reporting and analysis of threats and even certain types of suspicious activities, etc. It is merely concerned that the reporting threshold expressed in this standard will result in the reporting of substantial amounts of data that will not facilitate the improvement of the reliability of the BES and that the volume of reports may delay or otherwise obscure the detection of notable trends. Accordingly, MISO recommends that the SDT revise the standard to: (1) require the reporting only of substantial physical threats that are likely to have an adverse impact on the reliable operation of the Bulk Electric System, and (2) to provide an illustrative list of the types of “suspicious activity or devices” as guidance to responsible entities.</p> <p>o Timing of reports Finally, MISO respectfully suggests that NERC re-assess the timing requirements as related to the objectives expressed within this standard. MISO believes that NERC should clarify that its “situational awareness” staff will review submitted information to determine whether there are indications of possible coordinated attack and to quickly inform responsible entities that there are signals of possible coordinated attack. This clarification could be made in the standard, or the standard could describe the process that NERC staff will use. Unless such review and information is provided, the need that the standard attempts to address will not be fully met. Conversely, many of the events listed in Attachment A that require reporting do not need to be reported within 24 hours and would not offer significant benefit or value if reported within that time period as NERC and Regional Entities primarily utilize such information to capture metrics or perform after-the-fact events analysis. Accordingly, MISO respectfully suggests that, while performing analysis to determine clarifications that would result in the appropriate definition, assignment, and scope of reporting obligations, NERC should also examine the events and identify those events for which a longer time period for reporting would be suitable. This would significantly reduce the administrative burden on responsible entities and likely result in more comprehensive,</p>

Organization	Question 3 Comment
	<p>rigorous, and beneficial reporting.</p>
	<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>
<p>Indiana Municipal Power Agency</p>	<p>On page 6 of 23 of the draft standard document, second paragraph under Rationale for R1, the SDT uses the words “Every industry participant that owns or operates elements or devices on the grid has a formal or informal process...” The use of these words implies that this requirement and others in this standard may apply to every industry entity regardless if they are a registered entity or not. IMPA understands that standards can only apply to entities that are registered with NERC, but we still prefer to see different wording in this sentence. IMPA recommends using “Every registered entity that owns or operates elements or devices on the grid has a formal or informal process...”</p> <p><b>We have revised “industry participants” to Registered Entity”.</b></p> <p>Another concern is on pages 18, 19, and 20 of 23. It is not clear what exactly is required of a registered entity and the law enforcement reporting process. IMPA understands it is up to the entity to decide just how its event reporting Operating Plan is made up and who is contacted for the events in attachment 1. These pages are confusing when it comes to the listing of stakeholders in the reporting process on page 18 of 23 and then when the SDT states that an entity may just notify the state or provincial or local level law enforcement agency. The SDT needs to clarify that the listing of stakeholders on page 18 of 23 is just a suggestive listing and that if the entity so decides per its reporting Operating Plan that notification of the local law enforcement agency is sufficient (the thought that the local law enforcement agency can coordinate with additional law enforcement agencies if it sees the need). The requirement to contact the FBI in CIP-001 is not a requirement in EOP-004-2 unless the registered entity puts that requirement in its event reporting Operating Plan.</p> <p><b>The information on law enforcement in the Guidelines and Technical Basis section is</b></p>

Organization	Question 3 Comment
	<p>designed to provide <i>one</i> example of how an entity <i>could</i> report to law enforcement. It is not intended to be the <i>only</i> possible way.</p> <p>As a clarification, in the Background section’s second paragraph, it should read “retiring both EOP-004-1 and CIP-001-2a” as opposed to CIP-002-2a as written above in this comment document.</p> <p><b>We have searched the comment form and cannot find this.</b></p>
<p><b>Response: Thank you for your comment. Please see responses above.</b></p>	
<p>Cogentrix Energy</p>	<p>Overall: The standard makes good stride in eliminating the redundancy of CIP-001 and EOP-004. M1 States: “... and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1”. It is unclear in the statement that the protocols go with Attachment 1 and entities to receive report are part of Attachment 2. While this draft is an improvement on the previous draft, the proposed R2 is unacceptable, and should be amended to, at a minimum, require reporting by the end of the next business day, instead of within 24 hours. Events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator’s burden, which reduces the operator’s effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. For some event types where in order to provide real time situational awareness over a wide area (for example coordinated sabotage event) it may be appropriate to have more timely reporting. If the intent of this standard is to address sabotage reporting there needs to be an understanding of the actions to be taken by those receiving the reports so the reporting entities can incorporate those actions into their plan. As a minimum, NERC should have a process in place to assess the reports and take appropriate actions.</p> <p>Attachment 1: Threshold for reporting should not be defined such that multiple reports would be required for the same event. For example, both the TOP and RC being required to report</p>



Organization	Question 3 Comment
	<p>the outage of a transmission line.</p> <p>2nd event type (Damage or destruction of a Facility): Add the following sentence to the Threshold for Reporting: “Do not report theft or damage unless it degrades normal operation of a Facility.”</p> <p>4th event type (Physical threats to a BES control center): The term “BES control center” needs to be clarified.</p> <p>5th, 6th, and 7th event types: In instances where a reliability directive is issued, is the “initiating entity” the entity that issues the directive or the entity that carried out the directive.</p> <p>9th event type (Voltage deviation on a Facility): Change “nominal” to “expected or scheduled.”</p> <p>15th event type (Transmission loss): It is not clear what is meant by “contrary to design.” This is so broad that it could be interpreted as requiring reporting misoperations within the reporting time frame before even an initial investigation can begin. This needs to be clarified and tied to the impact on the reliability of the BES.</p>
<p><b>Response:</b> Thank you for your comment. The full Measure M1 states: “Each Responsible Entity will have a dated event reporting Operating Plan that includes, but is not limited to the protocol(s) and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1 and in accordance with the entity responsible for reporting.” It is expected that the Operating Plan will contain the entities to which a report will be submitted. The Measure indicates evidence needs to be provided showing that these entities received the event report. The protocol(s) refer to the Operating Plan and could include any procedures for identification of events as well as communicating to other entities.</p> <p>In response to your suggestion on Requirement R2, the DSR SDT has added clarifying language to R2 as follows:</p> <p><b>R2.</b> Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</p> <p>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation</p>	

Organization	Question 3 Comment
ballot.	
Northeast Power Coordinating Council	Paragraph 81 efforts are underway to eliminate requirements that have little or no reliability benefit. This Standard only addresses documentation and has no impact on reliability.
<p><b>Response:</b> Thank you for your comment. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the Paragraph 81 efforts are beyond the scope of this project, the SDT can only pass along your suggestion to that project team for action there.</p>	
Puget Sound Energy Inc.	<p>Puget Sound Energy appreciates the Standard Drafting Team's work to streamline and clarify the proposed standard. In addition, we understand that the Standard Drafting Team faces a significant challenge in developing workable thresholds for reporting under this standard. Unfortunately, Puget Sound Energy cannot support the proposed standard because the reporting thresholds remain too vague and, thus, too broad - especially those related to damage or destruction of a Facility and those related to physical threats. The first four events listed on Attachment 1 are not brightline rules, because they each involve significant elements of judgment and interpretation. An example of our concern relates to the phrase "... that results from actual or suspected intentional human action." Puget Sound Energy, like many regulated entities, is staffed only with System Operators at night and on weekends. As a result, the 24-hour reporting requirement necessarily requires the System Operators to submit the required reports. So, how is a System Operator going to judge whether a human action is "intentional"? As a result, it will be necessary to report any event in which human action is</p>

Organization	Question 3 Comment
	<p>involved because there is no way for a System Operator to know for sure whether the action is intentional or not. And, regulated entities will need to instruct their System Operators to make such reports, because the failure to submit a report of even one event listed in EOP-004 Attachment 1 is assigned a severe VSL under the proposed standard. We believe that the proposed threshold language will likely result in a flood of event reports that will not improve situation awareness.</p>
	<p><b>Response:</b> Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p> <p>In response to your concern on the 24-hour reporting requirement, the DSR SDT has added clarifying language to R2 as follows:</p> <p><b>R2. Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). [Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</b></p>
<p>Exelon Corporation and its affiliates</p>	<p>Thanks to the drafting team for all the work on this revision. Significant progress was made, though Exelon has some remaining comments:</p> <ul style="list-style-type: none"> <li>o It’s not clear why the team separated ‘Damage or destruction of a Facility’ into two rows. Please advise.</li> </ul> <p><b>Response:</b> The first row applies to the RC, which may not own any Facilities but has them under their operational control. This event applies to damage or destruction whereby the RC, TOP or BA has to take action to avoid a BES Emergency. The second row is simply damage or destruction of a Facility. It is expected that this second type of event would not be severe enough to have to take action to avoid a BES Emergency.</p> <ul style="list-style-type: none"> <li>o Damage or destruction of a Facility - The threshold for "damage or destruction of a Facility"</li> </ul>

Organization	Question 3 Comment
	<p>is too open-ended without qualifying the device or activity as “confirmed”. Event reporting for nuclear generating units are initiated when an incident such as tampering is "confirmed". EOP-004 should include some threshold of proof for a reason to believe that no other possibility exists for "damage or destruction of a facility" event other than actual or suspected intentional human action.</p> <p><b>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p>o Physical threats to a Facility - Reporting of every “suspicious activity” such as photographing equipment or site could result in an unwieldy volume of reports and dilute the data from depicting quality insight. For example, nuclear generating units are required to report all unauthorized and/or suspicious activity to the NRC. Please confirm that the intent of this threshold for notification would include all unauthorized and/or suspicious activity.</p> <p><b>The SDT concurs that the intent of the threshold for notification would include all unauthorized and/or suspicious activity.</b></p> <p>o Physical threats to a BES control center - please confirm that reporting responsibility falls to the RC, BA, TOP and not GOs. In addition, please confirm that by use of the lower case “control center” other definitions in development through other standards development projects (e.g. CIP version 5) and that may be added to the NERC Glossary will not apply until formally vetted in a future EOP-004 standards development project.</p> <p><b>The entities listed for this event type are the RC, BA and TOP only. No other entities are applicable for this event type. If the lower case “control center” is replaced by a definition developed in future standards actions, a change to EOP-004-2 to use the defined term would require notice to the industry and a ballot of the revised standard in some manner. The DSR</b></p>

Organization	Question 3 Comment
	<p><b>SDT does not have control over how that would be accomplished.</b></p> <ul style="list-style-type: none"> <li>o Loss of firm load - “Loss of firm load for 15 Minutes: 300 MW for entities with previous year’s demand 3,000 MW”. Please clarify whether the team intends for this to apply to a single event a loss of more than 300 MW due to non-concurrent multiple distribution outages that total &gt; 300MW.</li> </ul> <p><b>This event relates to a single incident of the loss of firm load.</b></p> <ul style="list-style-type: none"> <li>o Generation loss - Exelon appreciates the timing clarification added to the generation loss threshold. The phrase “within one minute” should also be included in the threshold for the ERCOT and Quebec Interconnections to read: “Total generation loss, within one minute, of 2,000 MW for entities in the Eastern or Western Interconnection OR Total generation loss, within one minute, of 1,000 MW for entities in the ERCOT or Quebec Interconnection”</li> </ul> <p><b>The phrase “within one minute” applies to everything listed in the event. To clarify this, we have inserted a colon after the word “of” and moved “≥ 2,000 MW for entities in the Eastern or Western Interconnection” down one line.</b></p> <ul style="list-style-type: none"> <li>o The Law Enforcement Reporting section in the Guideline and Technical Basis states: "The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of the BES from malicious physical or cyber attack." Since CIP-008 now covers reporting of cyber incidents the reference to cyber should be removed.</li> </ul> <p><b>We have made the correction in your last point regarding “cyber attacks” and have removed it from the Guidelines and Technical Basis section.</b></p>
<p><b>Response: Thank you for your comment. Please see responses embedded above.</b></p>	
<p>MRO NSRF</p>	<p>The NSRF requests that the SDT address the following concerns and clarifications in Attachment 1;</p> <ul style="list-style-type: none"> <li>1) Please explore redundancy reporting event Item #14; Complete loss of off-site power to a</li> </ul>

Organization	Question 3 Comment
	<p>nuclear generating plant with obligations of NUC-001-2.1 R9.4.4."Provisions for supplying information necessary to report to government agencies, as related to NPIRs." The NSRF understands the importance concerning safety issues with a nuclear plant. A multiple unit coal facility may have a larger reliability impact to the BES than a nuclear plant. The SDT is stating that the fuel source is a reporting issue, not the reliability of a plant loosing off sight power. Recommend that this item be deleted.</p> <p>2) Item 2 in Attachment 1 would obligate an entity to report any loss of (copper) grounds either on a T-Line or grounds associated with a transformer or breakers and that this level of reporting should not rise to the NERC level. Believes that additional qualifying language similar to Item 1 be incorporated into the threshold and read as follows:"Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency."</p> <p>3) Item 3 Attachment 1 needs clarification since a physical threat needs to be actual and confirmed so that the TO or TOP repositions the system. In addition, the SDT needs to clarify what the phrase "normal operations" means. (Is this a ratings issue? or a result in how the System Operator operates the system.)</p> <p>4) Item 3 should provide clarification as to "Suspicious device or activity at a Facility" to determine when threshold raises to the level of reporting. We are concerned that, based on an Auditors perception, these words could be interpreted in several different ways. In addition, we believe that language needs to be included that the threat causes the reporting entity to change to an abnormal operating state. This situation could be interpreted differently by the auditor or the entity at the time of the event. Recommend the following language: "Suspicious device or activity at a Facility with the potential to degrade the normal operation of the Facility". This language is similar to the first threshold.</p> <p>5) The term Initiating entity is used three times within Attachment 1 and needs to be more clearly defined or reworded. Is it the entity that identifies the needs of a Public Appeal or the entity that makes the public appeal the initiating entity? The word "initiating" does not provide clarity but only provides uncertainty to the industry. The Standard needs to be clear on who has the responsibility as the "initiating". Recommend the following: a. For public</p>

Organization	Question 3 Comment
	<p>appeal, under Entity with Reporting Responsibility; “entity that issues a public appeal to the public” b. For system wide voltage reduction, under Entity with Reporting Responsibility; “entity that activates a voltage reduction” c. For manual load shedding, under Entity with Reporting Responsibility; “entity that activates manual load shedding”</p> <p>6) The NSRF recommends transmission loss to read as: “contrary to protection system design” found in threshold for reporting within the Attachment for a Transmission loss event.</p> <p>7) In Requirement 2/ Measure 2, recommend adding “upon recognition of “ as a starting point to the 24 hour reporting requirement, within the threshold of reporting where perceived threats are the threshold, or transmission loss, when contrary to design is determined.</p>
<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p> <p><b>7) This was the intent of the drafting team and we have made this clarification to R2 and M2.</b></p>	
<p>Independent Electricity System Operator</p>	<p>The proposed implementation plan may conflict with Ontario regulatory practice respecting the effective date of the standard. It is suggested that this conflict be removed by: Moving the last part “, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.” to right after “this standard is approved by applicable regulatory approval” in the Effective Dates Section on P.2 of the draft standard, and the proposed Implementation Plan.</p>
<p><b>Response: Thank you for your comment. The SDT used the standard language provide by NERC Legal and intended to address all of the jurisdictions in which the standard may become enforceable. We will refer your suggestion to NERC Legal for consideration in the preparation of the filing.</b></p>	
<p>Bonneville Power Administration</p>	<p>The proposed standard does not have any oral reporting option for system operators and thus appears to be administrative in nature. Due to this and the fact that administrative staff are</p>

Organization	Question 3 Comment
	<p>not available on weekends, the “24 hour” reporting requirements should be modified to “Next Business Day” to allow for weekend delays in reporting. BPA believes that there are too many minor events that have to be reported within 24 hours. Reporting during the next business day would suffice. Some examples include: A 115 shunt capacitor bank failure for the first event type does not seem important enough to require reporting within 24 hours just because action has to be taken to raise generation or switching of line. A failure of a line tower that has proper protective action to clear the line and also has automatic (SPS) to properly protect as designed the BES system (a good normal practice) from overloads or voltage issues does not seem important enough to require reporting within 24 hours either.</p>
<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>Clark Public Utilities</p>	<p>The SDT has not adequately addressed my comments from the last draft regarding damage or destruction of its facility that results from actual or suspected intentional human action. The SDT needs to limit what it means by damage. As an example, if someone breaks into a substation and paints graffiti on a breaker that is part of the BES, the breaker has been "damaged." However, the breaker's ability to function has not been compromised and there are no emergency actions that need to be taken. There is no reason for an emergency reporting procedure to require this to be reported. The SDT needs to add the same modifier for damage that it added in the previous event threshold for reporting. The reference for this type of damage should be as follows: Event: Damage or destruction of a Facility. Entity with Reporting Responsibility: BA, TO, TOP, GO, GOP, DP. Threshold for Reporting: Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency.</p>
<p><b>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has</b></p>	



Organization	Question 3 Comment
<p>reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
<p>Lewis County PUD</p>	<p>We are a small utility with little impact to the BES with a small hydro on the end of a 230kV line. CIP-001 requires us to contact the FBI who has repeatedly instructed us to call the local sheriff office. The sheriff office has instructed us to call 911 and they will contact the FBI as needed. Therefore, 911 is our only contact number and our plan if vandalism, property destruction or sabotage is to have a supervisor call 911 and report. I do not think calling 911 to confirm the contact number serves any propose. Our plan will be simple with not a lot detail. The drafting team should recognize the reality of small utilities and state the required plan may be simple and not follow the flowchart in the draft standard.</p>
<p><b>Response:</b> Thank you for your comment. The SDT did recognize your circumstances and set the requirements to provide the flexibility to address the diversity of entities to which the standard is intended to apply.</p>	
<p>SPP Standards Review Group</p>	<p>We have made previous comments in the past regarding the listing in the Entity with Reporting Responsibility column of Attachment 1. While we concur with some of the changes that the drafting team has made regarding the addition of a bright line in the Threshold for Reporting column, there remain events where there is no line at all. For example, in the Transmission loss event, the TOP is listed and there is no distinction regarding which TOP is required to file the event report. Is it the TOP in whose TOP area the loss occurred or is it a neighboring TOP who observes the loss. Clearly, the responsibility for reporting lies with the host system. There are several other similar events where the bright line is non-existent and needs to be added. We suggest that the drafting team return the deleted language to the Entity with Reporting Responsibility column in those instances where the bright line has not been added in the Threshold column. Regarding multiple reports for a single event, we again believe that only a single report should be required. While additional information may be available from others, let the Event Analysis personnel do their job investigating an event and eliminate any redundant reporting that is currently required as the standard is written.</p> <p>If not, this standard, if approved, would then appear to be a likely candidate for Phase 2 of the</p>

Organization	Question 3 Comment
	Paragraph 81 project.
	<p>Response: Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot. On March 15, 2012, FERC issued an order on NERC’s Find, Fix and Track process and in paragraph 81 (“P81”) invited NERC and other entities to propose to remove from Commission-approved Reliability Standards unnecessary or redundant requirements. In response to P81 and the Commission’s request for comments to be coordinated, during June and July 2012, various industry stakeholders, Trade Associations, staff from NERC and staff from the NERC Regions jointly discussed consensus criteria and an initial list of Reliability Standard requirements that appeared to easily satisfy the criteria, and, thus, could be retired. In Phase 1 of the Paragraph 81 effort, only two of the requirements (in total) from CIP-001 and EOP-004 met the initial threshold for being included in the P81 Project. Both of these requirements will also be retired by EOP-004-2. Phase 2 of the Paragraph 81 Project will evaluate all NERC Reliability Standards, including any modifications to EOP-004-2. CIP-001-2a and EOP-004-1 are mandatory and enforceable NERC Reliability Standards. If EOP-004-2 is not approved by the industry, those standards will remain as is and subject to the Compliance Monitoring and Enforcement Program. As the SDT is moving forward with a Recirculation Ballot, your suggestions will be forwarded to NERC for future consideration.</p>
SERC OC Standards Review Group	<p>While this draft is an improvement on the previous draft, the proposed R2 is unacceptable, and should be amended to, at a minimum, require reporting by the end of the next business day, instead of within 24 hours. Events or situations affecting real time reliability to the system already are required to be reported to appropriate Functional Entities that have the responsibility to take action. Adding one more responsibility to system operators increases the operator’s burden, which reduces the operator’s effectiveness when operating the system. Care should be given when placing additional responsibility on the system operators. Allowing reporting at the end of the next business day gives operators the flexibility to allow support staff to assist with after-the-fact reporting requirements. For some event types where in order to provide real time situational awareness over a wide area (for example coordinated sabotage event) it may be appropriate to have more timely reporting .If the intent of this standard is to address sabotage reporting there needs to be an understanding of the actions to be taken by those receiving the reports so the reporting entities can incorporate those actions into their</p>

Organization	Question 3 Comment
	<p>plan. As a minimum, NERC should have a process in place to assess the reports and take appropriate actions.</p> <p>Attachment 1: Threshold for reporting should not be defined such that multiple reports would be required for the same event. For example, both the TOP and RC being required to report the outage of a transmission line.</p> <p>2nd event type (Damage or destruction of a Facility): Add the following sentence to the Threshold for Reporting: “Do not report theft or damage unless it degrades normal operation of a Facility.”</p> <p>4th event type (Physical threats to a BES control center): The term “BES control center” needs to be clarified.</p> <p>5th, 6th, and 7th event types: In instances where a reliability directive is issued, is the “initiating entity” the entity that issues the directive or the entity that carried out the directive.</p> <p>9th event type (Voltage deviation on a Facility): Change “nominal” to “expected or scheduled.”</p> <p>15th event type (Transmission loss): It is not clear what is meant by “contrary to design.” This is so broad that it could be interpreted as requiring reporting misoperations within the reporting time frame before even an initial investigation can begin. This needs to be clarified and tied to the impact on the reliability of the BES. The comments expressed herein represent a consensus of the views of the above named members of the SERC OC Standards Review Group only and should not be construed as the position of SERC Reliability Corporation, its board, or its officers.</p>
<p><b>Response:</b> Thank you for your comment. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p>	
Tacoma Public Utilities	Why does the text “...but is not limited to...” in M1 have to be included? Does this mean that

Organization	Question 3 Comment
	<p>there are unwritten requirements that an auditor might look for? What if, in trying to validate contact information, contacts do not confirm their information?</p> <p>Regarding the Loss of firm load row in Attachment 1, an exception should be made for weather or natural disaster related threats in the Threshold for Reporting.</p> <p>Regarding the Transmission loss row in Attachment 1, it is not quite clear which types of BES Elements would meet the Threshold for Reporting. Is it just lines, buses, and transformers? What about reactive resources? What about generators that unexpectedly trip offline during a fault on the transmission system?</p>
<p><b>Response: Thank you for your comment. In Measure M1 the text “but is not limited to” is intended to provide flexibility for each entity to determine, based on its assets and unique situation, to develop an Operating Plan that appropriately supports reliability. Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
MidAmerican Energy	<p>Yes. 1) MidAmerican Energy agrees with and supports MRO NSRF comments.</p> <p>2) Add additional wording to clearly provide for compliance when events are found more than 24 hours after an event. Add the following to the end of R2. Add, Events not identified until sometime later after they occurred shall be reported within 24 hours.</p> <p>3) In R3 add "external" for R3 to read Validate "external" contact information.</p> <p>4) In EOP-004-2 Attachment 1 - the wording “Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency” is not specific or measureable and therefore ambiguous. Zero defect standards which carry penalties must be specific. Please reword to "Intentional human action to destroy a NERC BES facility whose loss could result in actions to avoid a BES Emergency". This clearly aligns with the EOP-004 intent of sabotage and emergency reporting. EOP-004 should not report on unexpected conditions such as when a system operator attempts to reclose a line</p>

Organization	Question 3 Comment
	<p>during a storm believing the line tripped for a temporary fault due to debris, when in fact the fault was permanent and damaged a transformer.</p>
<p><b>Response: Thank you for your comment. See response to MRO NSF comments.</b></p> <p><b>Many suggestions were made regarding the language of certain events listed in Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</b></p>	
<p>american Transmission Company</p>	<p>Yes A. ATC requests that the Standards Drafting Team address the following concerns and clarifications in Attachment 1:</p> <p>a.) Reporting event #14 in Attachment 1, is duplicative with respect to Nuclear Reliability Standard NUC-001-2.1 R 9.4.4. Reporting event #14 requires entities to report to NERC a “Complete loss of off-site power to a nuclear generating plant” while Nuclear Reliability Standard NUC-001-2.1 R9.4.4., i.e. includes “Provisions for supplying information necessary to report to government agencies, as related to Nuclear Plant Interface Requirements (NPIRs)”. In addition, ATC believes the reporting related to event #14 in Attachment 1 is not a “reliability” issue, and more appropriately covered under Standard NUC-001 as a “Nuclear Safety Shutdown” issue. Therefore, ATC recommends that Item #14 in Attachment 1 of EOP-004-2 be deleted.</p> <p>b.) In Attachment 1, reporting event #2, i.e. “Damage or destruction of a Facility” could obligate an entity to report any loss of copper grounds either on a T-Line or grounds associated with a transformer or breakers. ATC believes this does not rise to a reporting level such as NERC. ATC believes that additional qualifying language similar to reporting item #1 be incorporated into the threshold and read as follows: “Damage or destruction of its Facility that results from actual or suspected intentional human action that results in actions to avoid a BES Emergency.”</p> <p>c.) In Attachment 1, reporting event #3 i.e. “Physical threats to a Facility” needs clarification</p>

Organization	Question 3 Comment
	<p>since a physical threat needs to be actual and confirmed so that the TO or TOP repositions the system. In addition, the SDT needs to clarify what the phrase “normal operations” means. Is this a ratings issue? Or a result in how the Operator operates the system.</p> <p>d.) In Attachment 1, reporting event #3 threshold i.e. “Suspicious device or activity at a Facility” needs clarification to determine when it raises to the level of reporting. These words could be interpreted in several different ways. In addition, ATC believe that language needs to be added that the threat causes the reporting entity to change to an abnormal operating state. ATC recommends the threshold be revised to read: “Suspicious device or activity at a Facility with the potential to degrade the normal operation of the Facility”.</p> <p>e.) In Attachment 1, the term “Initiating entity” is used three times for reporting events and needs to be clearly defined or reworded. Is it the entity that identifies the needs of a Public Appeal or the entity that makes the public appeal the initiating entity? The Standard needs to be clear on who has the responsibility as the “initiating” party, especially when multiple parties may be involved. ATC recommends the following:1) For public appeal, under Entity with Reporting Responsibility; it is the “entity that issues a public appeal to the public”2) For system wide voltage reduction, under Entity with Reporting Responsibility; it is the “entity that activates a voltage reduction”3) For manual load shedding, under Entity with Reporting Responsibility; it is the “entity that activates manual load shedding”</p> <p>f.) In Attachment 1, reporting event #15 i.e. “Transmission Loss”, the threshold includes the phrase “contrary to design”. ATC recommends this be clarified to read “contrary to protection system design”.</p> <p>B. In EOP-004-2 Requirement 2/ Measure 2 both have the following language:”Each Responsible Entity shall report events per their Operating Plan within 24 hours of meeting an event type threshold for reporting.” ATC recommends adding “upon recognition” as a starting point to the 24 hour reporting requirement. This would be revised to read: “Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of an event type threshold”</p>

**Response: Thank you for your comment. A) Many suggestions were made regarding the language of certain events listed in**

Organization	Question 3 Comment
	<p>Attachment 1. Most of these comments are about a single event type and were made by only one stakeholder. The team has reviewed all of these comments. In several cases, the same or a similar suggestion was made on an earlier draft, and the team considered it at that time. The SDT believes that stakeholder consensus has been achieved regarding these event types. The team has elected to move forward to recirculation ballot.</p> <p>B) This was the intent of the drafting team and we have made this clarification to R2 and M2.</p>

END OF REPORT

## Standard Development Timeline

---

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 15 – October 15, 2010).
6. Second Comment Period (Formal) (March 9 – April 8, 2011).
7. Third Comment Period and Initial Ballot (October 28 – December 12, 2011).
8. Fourth Comment Period and Successive Ballot (April 25 – May 24, 2012).

### Proposed Action Plan and Description of Current Draft

This is the fifth posting of the proposed standard in accordance with Results-Based Standards (RBS) criteria. The drafting team requests posting for a 30-day formal comment period concurrent with the formation of the ballot pool and the successive ballot.

### Future Development Plan

<b>Anticipated Actions</b>	<b>Anticipated Date</b>
Drafting team considers comments, makes conforming changes on fourth posting	June - August 2012
Fifth Comment/Ballot period	August – September 2012
Recirculation Ballot period	October 2012
Receive BOT approval	November 2012
File with regulatory authorities	December 2012



### Effective Dates

The first day of the first calendar quarter that is six months beyond the date that this standard is approved by applicable regulatory authorities. In those jurisdictions where regulatory approval is not required, the standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the NERC Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

### Version History

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting.	Revision to entire standard (Project 2009-01)

### **Definitions of Terms Used in Standard**

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

## A. Introduction

1. **Title:** Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.
4. **Applicability**
  - 4.1. **Functional Entities:** For the purpose of the Requirements and the EOP-004 Attachment 1 contained herein, the following functional entities will be collectively referred to as “Responsible Entity.”
    - 4.1.1. Reliability Coordinator
    - 4.1.2. Balancing Authority
    - 4.1.3. Transmission Owner
    - 4.1.4. Transmission Operator
    - 4.1.5. Generator Owner
    - 4.1.6. Generator Operator
    - 4.1.7. Distribution Provider

## 5. Background:

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient Bulk Electric System reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

## B. Requirements and Measures

**R1.** Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the Regional Entity, company personnel, the Responsible Entity's Reliability Coordinator, law enforcement, or governmental authority). [*Violation Risk Factor: Lower*] [*Time Horizon: Operations Planning*]

**M1.** Each Responsible Entity will have a dated event reporting Operating Plan that includes, but is not limited to the protocol(s) and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1 and in accordance with the entity responsible for reporting.

### **Rationale for R1**

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; e.g., Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC Events Analysis Program. These other parties use this information to promote reliability, develop a culture of reliability excellence, provide industry collaboration and promote a learning organization.

Every Registered Entity that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective.

The communication protocol(s) could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information. An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.

**R2.** Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time).  
*[Violation Risk Factor: Medium]*  
*[Time Horizon: Operations Assessment]*

**M2.** Each Responsible Entity will have as evidence of reporting an event, copy of the completed EOP-004-2 Attachment 2 form or a DOE-OE-417 form; and evidence of submittal (e.g., operator log or other operating documentation, voice recording, electronic mail message, or confirmation of facsimile) demonstrating the event report was submitted within 24 hours of recognition of meeting the threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). (R2)

**R3.** Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. *[Violation Risk Factor: Medium]* *[Time Horizon: Operations Planning]*

**M3.** Each Responsible Entity will have dated records to show that it validated all contact information contained in the Operating Plan each calendar year. Such evidence may include, but are not limited to, dated voice recordings and operating logs or other communication documentation. (R3)

### **Rationale for R2**

Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004-2 Attachment 1. By implementing the event reporting Operating Plan the Responsible Entity will assure situational awareness to the Electric Reliability Organization so that they may develop trends and prepare for a possible next event and mitigate the current event. This will assure that the BES remains secure and stable by mitigation actions that the Responsible Entity has within its function. By communicating events per the Operating Plan, the Responsible Entity will assure that people/agencies are aware of the current situation and they may prepare to mitigate current and further events.

### **Rationale for R3**

Requirement 3 calls for the Responsible Entity to validate the contact information contained in the Operating Plan each calendar year. This requirement helps ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.

## C. Compliance

### 1. Compliance Monitoring Process

#### 1.1 Compliance Enforcement Authority

The Regional Entity shall serve as the Compliance Enforcement Authority (CEA) unless the applicable entity is owned, operated, or controlled by the Regional Entity. In such cases the ERO or a Regional Entity approved by FERC or other applicable governmental authority shall serve as the CEA.

#### 1.2 Evidence Retention

The Responsible Entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

- Each Responsible Entity shall retain the current Operating Plan plus each version issued since the last audit for Requirements R1, and Measure M1.
- Each Responsible Entity shall retain evidence of compliance since the last audit for Requirements R2, R3 and Measure M2, M3.

If a Responsible Entity is found non-compliant, it shall keep information related to the non-compliance until mitigation is complete and approved or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

#### 1.3 Compliance Monitoring and Enforcement Processes:

Compliance Audit

Self-Certification

Spot Checking

Compliance Investigation

Self-Reporting

Complaint

#### 1.4 Additional Compliance Information

None

**Table of Compliance Elements**

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	Operations Planning	Lower	The Responsible Entity had an Operating Plan, but failed to include one applicable event type.	The Responsible Entity had an Operating Plan, but failed to include two applicable event types.	The Responsible Entity had an Operating Plan, but failed to include three applicable event types.	The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.  OR The Responsible Entity failed to have an event reporting Operating Plan.



R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R2	Operations Assessment	Medium	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 24 hours but less than or equal to 36 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to one entity identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 36 hours but less than or equal to 48 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to two entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours but less than or equal to 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to three entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to four or more entities identified in its event reporting Operating Plan within 24 hours.</p> <p>OR</p> <p>The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R3	Operations Planning	Medium	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by less than one calendar month.</p> <p>OR</p> <p>The Responsible Entity validated 75% but less than 100% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by one calendar month or more but less than two calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 50% and less than 75% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by two calendar months or more but less than three calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 25% and less than 50% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by three calendar months or more.</p> <p>OR</p> <p>The Responsible Entity validated less than 25% of contact information contained in the Operating Plan.</p>

**D. Variances**

None.

**E. Interpretations**

None.

**F. References**

Guideline and Technical Basis (attached)

## EOP-004 - Attachment 1: Reportable Events

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R2 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: [systemawareness@nerc.net](mailto:systemawareness@nerc.net), Facsimile 404-446-9770 or Voice: 404-446-9780.

### **Rationale Box for EOP-004 Attachment 1:**

The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:

“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”

The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

**EOP-004-2 — Event Reporting**

**Submit EOP-004 Attachment 2 (or DOE-OE-417) pursuant to Requirements R1 and R2.**

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Damage or destruction of a Facility	RC, BA, TOP	Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency.
Damage or destruction of a Facility	BA, TO, TOP, GO, GOP, DP	Damage or destruction of its Facility that results from actual or suspected intentional human action.
Physical threats to a Facility	BA, TO, TOP, GO, GOP, DP	Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility. OR Suspicious device or activity at a Facility. Do not report theft unless it degrades normal operation of a Facility.
Physical threats to a BES control center	RC, BA, TOP	Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center. OR Suspicious device or activity at a BES control center.
BES Emergency requiring public appeal for load reduction	Initiating entity is responsible for reporting	Public appeal for load reduction event.
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more.
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq$ 100 MW.

## EOP-004-2 — Event Reporting

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
BES Emergency resulting in automatic firm load shedding	DP, TOP	Automatic firm load shedding $\geq 100$ MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS).
Voltage deviation on a Facility	TOP	Observed within its area a voltage deviation of $\pm 10\%$ of nominal voltage sustained for $\geq 15$ continuous minutes.
IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)	RC	Operate outside the IROL for time greater than IROL $T_v$ (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only).
Loss of firm load	BA, TOP, DP	Loss of firm load for $\geq 15$ Minutes: $\geq 300$ MW for entities with previous year's demand $\geq 3,000$ MW OR $\geq 200$ MW for all other entities
System separation (islanding)	RC, BA, TOP	Each separation resulting in an island $\geq 100$ MW
Generation loss	BA, GOP	Total generation loss, within one minute, of : $\geq 2,000$ MW for entities in the Eastern or Western Interconnection OR $\geq 1,000$ MW for entities in the ERCOT or Quebec Interconnection
Complete loss of off-site power to a nuclear generating plant (grid supply)	TO, TOP	Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement

## EOP-004-2 — Event Reporting

---

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Transmission loss	TOP	Unexpected loss within its area, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).
Unplanned BES control center evacuation	RC, BA, TOP	Unplanned evacuation from BES control center facility for 30 continuous minutes or more.
Complete loss of voice communication capability	RC, BA, TOP	Complete loss of voice communication capability affecting a BES control center for 30 continuous minutes or more.
Complete loss of monitoring capability	RC, BA, TOP	Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (i.e., State Estimator or Contingency Analysis) is rendered inoperable.

EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004 Attachment 2: Event Reporting Form</b>	
Use this form to report events. The Electric Reliability Organization will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> , Facsimile 404-446-9770 or voice: 404-446-9780.	
<b>Task</b>	<b>Comments</b>
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:
3.	Did the event originate in your system?      Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
4.	<b>Event Identification and Description:</b>
(Check applicable box) <input type="checkbox"/> Damage or destruction of a Facility <input type="checkbox"/> Physical Threat to a Facility <input type="checkbox"/> Physical Threat to a control center <input type="checkbox"/> BES Emergency: <input type="checkbox"/> public appeal for load reduction <input type="checkbox"/> system-wide voltage reduction <input type="checkbox"/> manual firm load shedding <input type="checkbox"/> automatic firm load shedding <input type="checkbox"/> Voltage deviation on a Facility <input type="checkbox"/> IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only) <input type="checkbox"/> Loss of firm load <input type="checkbox"/> System separation <input type="checkbox"/> Generation loss <input type="checkbox"/> Complete loss of off-site power to a nuclear generating plant (grid supply) <input type="checkbox"/> Transmission loss <input type="checkbox"/> unplanned control center evacuation <input type="checkbox"/> Complete loss of voice communication capability <input type="checkbox"/> Complete loss of monitoring capability	Written description (optional):

## Guideline and Technical Basis

### **Distribution Provider Applicability Discussion**

The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more than 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.

### **Multiple Reports for a Single Organization**

For entities that have multiple registrations, the DSR SDT intends that these entities will only have to submit one report for any individual event. For example, if an entity is registered as a Reliability Coordinator, Balancing Authority and Transmission Operator, the entity would only submit one report for a particular event rather than submitting three reports as each individual registered entity.

### **Summary of Key Concepts**

The DSR SDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the Bulk Electric System
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as



events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1 pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. EOP-004 Attachment 1 covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.

The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time communication is achieved is covered in other standards. The proposed standard deals exclusively with after-the-fact reporting.

### Data Gathering

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### Law Enforcement Reporting

The reliability objective of EOP-004-2 is to improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical attack. The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### Stakeholders in the Reporting Process

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE
- NRC

- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at a Facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. These requirements, under the standard, of the industry have not been clear and have led to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, Responsible Entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**

A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial


law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

### **Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts**

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### Summary of Concepts and Assumptions:

##### ***The Standard:***

- Requires reporting of “events” that impact or may impact the reliability of the Bulk Electric System
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

##### **Discussion of Disturbance Reporting**

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (EOP-004 Attachment 1).

### **Discussion of Event Reporting**

There are situations worthy of reporting because they have the potential to impact reliability.

Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- Train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center)
- Destruction of Bulk Electric System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electric System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering necessary for event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for

reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in EOP-004 Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be sent to the NERC in lieu of entering that information on the NERC report.

## Standard Development Timeline

---

*This section is maintained by the drafting team during the development of the standard and will be removed when the standard becomes effective.*

### Development Steps Completed

1. SC approved SAR for initial posting (April 2009).
2. SAR posted for comment (April 22 – May 21, 2009).
3. SC authorized moving the SAR forward to standard development (September 2009).
4. Concepts Paper posted for comment (March 17 – April 16, 2010).
5. Initial Informal Comment Period (September 15 – October 15, 2010).
6. Second Comment Period (Formal) (March 9 – April 8, 2011).
7. Third Comment Period and Initial Ballot (October 28 – December 12, 2011).
8. Fourth Comment Period and Successive Ballot (April 25 – May 24, 2012).

### Proposed Action Plan and Description of Current Draft

This is the fifth posting of the proposed standard in accordance with Results-Based Standards (RBS) criteria. The drafting team requests posting for a 30-day formal comment period concurrent with the formation of the ballot pool and the successive ballot.

### Future Development Plan

<b>Anticipated Actions</b>	<b>Anticipated Date</b>
Drafting team considers comments, makes conforming changes on fourth posting	June - August 2012
Fifth Comment/Ballot period	August – September 2012
Recirculation Ballot period	October 2012
Receive BOT approval	November 2012
File with regulatory authorities	December 2012



### Effective Dates

The first day of the first calendar quarter that is six months beyond the date that this standard is approved by applicable regulatory authorities. In those jurisdictions where regulatory approval is not required, the standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the NERC Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.

### Version History

Version	Date	Action	Change Tracking
2		Merged CIP-001-2a Sabotage Reporting and EOP-004-1 Disturbance Reporting into EOP-004-2 Event Reporting; Retire CIP-001-2a Sabotage Reporting and Retired EOP-004-1 Disturbance Reporting.	Revision to entire standard (Project 2009-01)

### Definitions of Terms Used in Standard

*This section includes all newly defined or revised terms used in the proposed standard. Terms already defined in the Reliability Standards Glossary of Terms are not repeated here. New or revised definitions listed below become approved when the proposed standard is approved. When the standard becomes effective, these defined terms will be removed from the individual standard and added to the Glossary.*

None

*When this standard has received ballot approval, the text boxes will be moved to the Guideline and Technical Basis Section.*

### A. Introduction

1. **Title:** Event Reporting
2. **Number:** EOP-004-2
3. **Purpose:** To improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities.
4. **Applicability**
  - 4.1. **Functional Entities:** For the purpose of the Requirements and the EOP-004 Attachment 1 contained herein, the following functional entities will be collectively referred to as “Responsible Entity.”
    - 4.1.1. Reliability Coordinator
    - 4.1.2. Balancing Authority
    - 4.1.3. Transmission Owner
    - 4.1.4. Transmission Operator
    - 4.1.5. Generator Owner
    - 4.1.6. Generator Operator
    - 4.1.7. Distribution Provider

### 5. Background:

NERC established a SAR Team in 2009 to investigate and propose revisions to the CIP-001 and EOP-004 Reliability Standards. The team was asked to consider the following:

1. CIP-001 could be merged with EOP-004 to eliminate redundancies.
2. Acts of sabotage have to be reported to the DOE as part of EOP-004.
3. Specific references to the DOE form need to be eliminated.
4. EOP-004 had some ‘fill-in-the-blank’ components to eliminate.

The development included other improvements to the standards deemed appropriate by the drafting team, with the consensus of stakeholders, consistent with establishing high quality, enforceable and technically sufficient Bulk Electric System reliability standards.

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009.

The DSR SDT developed a concept paper to solicit stakeholder input regarding the proposed reporting concepts that the DSR SDT had developed. The posting of the concept paper sought comments from stakeholders on the “road map” that will be used by the DSR SDT in updating or revising CIP-001 and EOP-004. The concept paper provided stakeholders the background information and thought process of the DSR SDT. The DSR SDT has reviewed the existing standards, the SAR, issues from the NERC issues database and FERC Order 693 Directives in order to determine a prudent course of action with respect to revision of these standards.

## B. Requirements and Measures

**R1.** Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the ~~R~~regional ~~E~~ntity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). [*Violation Risk Factor: Lower*] [*Time Horizon: Operations Planning*]

**M1.** Each Responsible Entity will have a dated event reporting Operating Plan that includes, but is not limited to the protocol(s) and each organization identified to receive an event report for event types specified in EOP-004-2 Attachment 1 and in accordance with the entity responsible for reporting.

### Rationale for R1

The requirement to have an Operating Plan for reporting specific types of events provides the entity with a method to have its operating personnel recognize events that affect reliability and to be able to report them to appropriate parties; e.g., Regional Entities, applicable Reliability Coordinators, and law enforcement and other jurisdictional agencies when so recognized. In addition, these event reports are an input to the NERC Events Analysis Program. These other parties use this information to promote reliability, develop a culture of reliability excellence, provide industry collaboration and promote a learning organization.

Every ~~Registered Entity~~industry participant that owns or operates elements or devices on the grid has a formal or informal process, procedure, or steps it takes to gather information regarding what happened when events occur. This requirement has the Responsible Entity establish documentation on how that procedure, process, or plan is organized. This documentation may be a single document or a combination of various documents that achieve the reliability objective. The communication protocol(s) could include a process flowchart, identification of internal and external personnel or entities to be notified, or a list of personnel by name and their associated contact information. An existing procedure that meets the requirements of CIP-001-2a may be included in this Operating Plan along with other processes, procedures or plans to meet this requirement.

**R2.** Each Responsible Entity shall report events per their Operating Plan within 24 hours of recognition of meeting an event type threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time).  
*[Violation Risk Factor: Medium]*  
*[Time Horizon: Operations Assessment]*

**M2.** Each Responsible Entity will have as evidence of reporting an event, copy of the completed EOP-004-2 Attachment 2 form or a DOE-OE-417 form; and evidence of submittal (e.g., operator log or other operating documentation, voice recording, electronic mail message, or confirmation of facsimile)

demonstrating the event report was submitted within 24 hours of recognition of meeting the threshold for reporting or by the end of the next business day if the event occurs on a weekend (which is recognized to be 4 PM local time on Friday to 8 AM Monday local time). (R2)

**R3.** Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. *[Violation Risk Factor: Medium]* *[Time Horizon: Operations Planning]*

**M3.** Each Responsible Entity will have dated records to show that it validated all contact information contained in the Operating Plan each calendar year. Such evidence may include, but are not limited to, dated voice recordings and operating logs or other communication documentation. (R3)

### Rationale for R2

Each Responsible Entity must report and communicate events according to its Operating Plan based on the information in EOP-004-2 Attachment 1. By implementing the event reporting Operating Plan the Responsible Entity will assure situational awareness to the Electric Reliability Organization so that they may develop trends and prepare for a possible next event and mitigate the current event. This will assure that the BES remains secure and stable by mitigation actions that the Responsible Entity has within its function. By communicating events per the Operating Plan, the Responsible Entity will assure that people/agencies are aware of the current situation and they may prepare to mitigate current and further events.

### Rationale for R3

Requirement 3 calls for the Responsible Entity to validate the contact information contained in the Operating Plan each calendar year. This requirement helps ensure that the event reporting Operating Plan is up to date and entities will be able to effectively report events to assure situational awareness to the Electric Reliability Organization. If an entity experiences an actual event, communication evidence from the event may be used to show compliance with the validation requirement for the specific contacts used for the event.

## C. Compliance

### 1. Compliance Monitoring Process

#### 1.1 Compliance Enforcement Authority

The Regional Entity shall serve as the Compliance Enforcement Authority (CEA) unless the applicable entity is owned, operated, or controlled by the Regional Entity. In such cases the ERO or a Regional Entity approved by FERC or other applicable governmental authority shall serve as the CEA.

#### 1.2 Evidence Retention

The Responsible Entity shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

- Each Responsible Entity shall retain the current Operating Plan plus each version issued since the last audit for Requirements R1, and Measure M1.
- Each Responsible Entity shall retain evidence of compliance since the last audit for Requirements R2, R3 and Measure M2, M3.

If a Responsible Entity is found non-compliant, it shall keep information related to the non-compliance until mitigation is complete and approved or for the duration specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

#### 1.3 Compliance Monitoring and Enforcement Processes:

Compliance Audit

Self-Certification

Spot Checking

Compliance Investigation

Self-Reporting

Complaint

#### 1.4 Additional Compliance Information

None

Table of Compliance Elements

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R1	Operations Planning	Lower	<u>The Responsible Entity had an Operating Plan, but failed to include one applicable event type. N/A</u>	<u>The Responsible Entity had an Operating Plan, but failed to include two applicable event types. N/A</u>	<u>The Responsible Entity had an Operating Plan, but failed to include three applicable event types. N/A</u>	<u>The Responsible Entity had an Operating Plan, but failed to include four or more applicable event types.</u>  <u>OR</u> The Responsible Entity failed to have an event reporting Operating Plan.



R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R2	Operations Assessment	Medium	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 24 hours but less than or equal to 36 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to one entity identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 36 hours but less than or equal to 48 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to two entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 48 hours but less than or equal to 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to three entities identified in its event reporting Operating Plan within 24 hours.</p>	<p>The Responsible Entity submitted an event report (e.g., written or verbal) to all required recipients more than 60 hours after meeting an event threshold for reporting.</p> <p>OR</p> <p>The Responsible Entity failed to submit an event report (e.g., written or verbal) to four or more entities identified in its event reporting Operating Plan within 24 hours.</p> <p>OR</p> <p>The Responsible Entity failed to submit a report for an event in EOP-004 Attachment 1.</p>

R #	Time Horizon	VRF	Violation Severity Levels			
			Lower VSL	Moderate VSL	High VSL	Severe VSL
R3	Operations Planning	Medium	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by less than one calendar month.</p> <p>OR</p> <p>The Responsible Entity validated 75% <u>but less than 100% <del>or more</del></u> of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by one calendar month or more but less than two calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 50% and less than 75% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by two calendar months or more but less than three calendar months.</p> <p>OR</p> <p>The Responsible Entity validated 25% and less than 50% of the contact information contained in the Operating Plan.</p>	<p>The Responsible Entity validated all contact information contained in the Operating Plan but was late by three calendar months or more.</p> <p>OR</p> <p>The Responsible Entity validated less than 25% of contact information contained in the Operating Plan.</p>

**D. Variances**

None.

**E. Interpretations**

None.

**F. References**

Guideline and Technical Basis (attached)

## EOP-004 - Attachment 1: Reportable Events

NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report within the timing in the table below. In such cases, the affected Responsible Entity shall notify parties per Requirement R2 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: [systemawareness@nerc.net](mailto:systemawareness@nerc.net), [Facsimile 404-446-9770](tel:404-446-9770) or Voice: 404-446-9780.

### **Rationale Box for EOP-004 Attachment 1:**

The DSR SDT used the defined term “Facility” to add clarity for several events listed in Attachment 1. A Facility is defined as:

“A set of electrical equipment that operates as a single Bulk Electric System Element (e.g., a line, a generator, a shunt compensator, transformer, etc.)”

The DSR SDT does not intend the use of the term Facility to mean a substation or any other facility (not a defined term) that one might consider in everyday discussions regarding the grid. This is intended to mean ONLY a Facility as defined above.

**EOP-004-2 — Event Reporting**

**Submit EOP-004 Attachment 2 (or DOE-OE-417) pursuant to Requirements R1 and R2.**

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Damage or destruction of a Facility	RC, BA, TOP	Damage or destruction of a Facility within its Reliability Coordinator Area, Balancing Authority Area or Transmission Operator Area that results in actions to avoid a BES Emergency.
Damage or destruction of a Facility	BA, TO, TOP, GO, GOP, DP	Damage or destruction of its Facility that results from actual or suspected intentional human action.
Physical threats to a Facility	BA, TO, TOP, GO, GOP, DP	Physical threat to its Facility excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the Facility. OR Suspicious device or activity at a Facility. Do not report theft unless it degrades normal operation of a Facility.
Physical threats to a BES control center	RC, BA, TOP	Physical threat to its BES control center, excluding weather or natural disaster related threats, which has the potential to degrade the normal operation of the control center. OR Suspicious device or activity at a BES control center.
BES Emergency requiring public appeal for load reduction	Initiating entity is responsible for reporting	Public appeal for load reduction event.
BES Emergency requiring system-wide voltage reduction	Initiating entity is responsible for reporting	System wide voltage reduction of 3% or more.
BES Emergency requiring manual firm load shedding	Initiating entity is responsible for reporting	Manual firm load shedding $\geq$ 100 MW.

## EOP-004-2 — Event Reporting

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
BES Emergency resulting in automatic firm load shedding	DP, TOP	Automatic firm load shedding $\geq 100$ MW (via automatic undervoltage or underfrequency load shedding schemes, or SPS/RAS).
Voltage deviation on a Facility	TOP	Observed within its area a voltage deviation of $\pm 10\%$ of nominal voltage sustained for $\geq 15$ continuous minutes.
IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only)	RC	Operate outside the IROL for time greater than IROL $T_v$ (all Interconnections) or Operate outside the SOL for more than 30 minutes for Major WECC Transfer Paths (WECC only).
Loss of firm load	BA, TOP, DP	Loss of firm load for $\geq 15$ Minutes: $\geq 300$ MW for entities with previous year's demand $\geq 3,000$ MW OR $\geq 200$ MW for all other entities
System separation (islanding)	RC, BA, TOP	Each separation resulting in an island $\geq 100$ MW
Generation loss	BA, GOP	Total generation loss, within one minute, of $\geq 2,000$ MW for entities in the Eastern or Western Interconnection OR $\geq 1,000$ MW for entities in the ERCOT or Quebec Interconnection
Complete loss of off-site power to a nuclear generating plant (grid supply)	TO, TOP	Complete loss of off-site power affecting a nuclear generating station per the Nuclear Plant Interface Requirement

## EOP-004-2 — Event Reporting

---

Event Type	Entity with Reporting Responsibility	Threshold for Reporting
Transmission loss	TOP	Unexpected loss within its area, contrary to design, of three or more BES Elements caused by a common disturbance (excluding successful automatic reclosing).
Unplanned BES control center evacuation	RC, BA, TOP	Unplanned evacuation from BES control center facility for 30 continuous minutes or more.
Complete loss of voice communication capability	RC, BA, TOP	Complete loss of voice communication capability affecting a BES control center for 30 continuous minutes or more.
Complete loss of monitoring capability	RC, BA, TOP	Complete loss of monitoring capability affecting a BES control center for 30 continuous minutes or more such that analysis capability (i.e., State Estimator or Contingency Analysis) is rendered inoperable.

EOP-004 - Attachment 2: Event Reporting Form

<b>EOP-004 Attachment 2: Event Reporting Form</b>	
<p>Use this form to report events. The Electric Reliability Organization will accept the DOE OE-417 form in lieu of this form if the entity is required to submit an OE-417 report. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> , <b>Facsimile 404-446-9770</b> <b>or</b> voice: 404-446-9780.</p>	
Task	Comments
1.	Entity filing the report include: Company name: Name of contact person: Email address of contact person: Telephone Number: Submitted by (name):
2.	Date and Time of recognized event. Date: (mm/dd/yyyy) Time: (hh:mm) Time/Zone:
3.	Did the event originate in your system?      Yes <input type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/>
4.	<b>Event Identification and Description:</b>
(Check applicable box) <input type="checkbox"/> Damage or destruction of a Facility <input type="checkbox"/> Physical Threat to a Facility <input type="checkbox"/> Physical Threat to a control center <input type="checkbox"/> BES Emergency: <input type="checkbox"/> public appeal for load reduction <input type="checkbox"/> system-wide voltage reduction <input type="checkbox"/> manual firm load shedding <input type="checkbox"/> automatic firm load shedding <input type="checkbox"/> Voltage deviation on a Facility <input type="checkbox"/> IROL Violation (all Interconnections) or SOL Violation for Major WECC Transfer Paths (WECC only) <input type="checkbox"/> Loss of firm load <input type="checkbox"/> System separation <input type="checkbox"/> Generation loss <input type="checkbox"/> Complete loss of off-site power to a nuclear generating plant (grid supply) <input type="checkbox"/> Transmission loss <input type="checkbox"/> unplanned control center evacuation <input type="checkbox"/> Complete loss of voice communication capability <input type="checkbox"/> Complete loss of monitoring capability	Written description (optional):

## Guideline and Technical Basis

### Distribution Provider Applicability Discussion

The DSR SDT has included Distribution Providers (DP) as an applicable entity under this standard. The team realizes that not all DPs will own BES Facilities and will not meet the “Threshold for Reporting” for any event listed in Attachment 1. These DPs will not have any reports to submit under Requirement R2. However, these DPs will be responsible for meeting Requirements R1 and R3. The DSR SDT does not intend for these entities to have a detailed Operating Plan to address events that are not applicable to them. In this instance, the DSR SDT intends for the DP to have a very simple Operating Plan that includes a statement that there are no applicable events in Attachment 1 (to meet R1) and that the DP will review the list of events in Attachment 1 each year (to meet R3). The team does not think this will be a burden on any entity as the development and annual validation of the Operating Plan should not take more than 30 minutes on an annual basis. If a DP discovers applicable events during the annual review, it is expected that the DP will develop a more detailed Operating Plan to comply with the requirements of the standard.

### Multiple Reports for a Single Organization

For entities that have multiple registrations, the DSR SDT intends that these entities will only have to submit one report for any individual event. For example, if an entity is registered as a Reliability Coordinator, Balancing Authority and Transmission Operator, the entity would only submit one report for a particular event rather submitting three reports as each individual registered entity.

### Summary of Key Concepts

The DSR SDT identified the following principles to assist them in developing the standard:

- Develop a single form to report disturbances and events that threaten the reliability of the Bulk Electric System
- Investigate other opportunities for efficiency, such as development of an electronic form and possible inclusion of regional reporting requirements
- Establish clear criteria for reporting
- Establish consistent reporting timelines
- Provide clarity around who will receive the information and how it will be used

During the development of concepts, the DSR SDT considered the FERC directive to “further define sabotage”. There was concern among stakeholders that a definition may be ambiguous and subject to interpretation. Consequently, the DSR SDT decided to eliminate the term sabotage from the standard. The team felt that it was almost impossible to determine if an act or event was sabotage or vandalism without the intervention of law enforcement. The DSR SDT felt that attempting to define sabotage would result in further ambiguity with respect to reporting events. The term “sabotage” is no longer included in the standard. The events listed in EOP-004 Attachment 1 were developed to provide guidance for reporting both actual events as well as



events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.

The types of events that are required to be reported are contained within EOP-004 Attachment 1. The DSR SDT has coordinated with the NERC Events Analysis Working Group to develop the list of events that are to be reported under this standard. EOP-004 Attachment 1 pertains to those actions or events that have impacted the Bulk Electric System. These events were previously reported under EOP-004-1, CIP-001-1 or the Department of Energy form OE-417. EOP-004 Attachment 1 covers similar items that may have had an impact on the Bulk Electric System or has the potential to have an impact and should be reported.

The DSR SDT wishes to make clear that the proposed Standard does not include any real-time operating notifications for the events listed in EOP-004 Attachment 1. Real-time communication is achieved is covered in other standards. The proposed standard deals exclusively with after-the-fact reporting.

### Data Gathering

The requirements of EOP-004-1 require that entities “promptly analyze Bulk Electric System disturbances on its system or facilities” (Requirement R2). The requirements of EOP-004-2 specify that certain types of events are to be reported but do not include provisions to analyze events. Events reported under EOP-004-2 may trigger further scrutiny by the ERO Events Analysis Program. If warranted, the Events Analysis Program personnel may request that more data for certain events be provided by the reporting entity or other entities that may have experienced the event. Entities are encouraged to become familiar with the Events Analysis Program and the NERC Rules of Procedure to learn more about with the expectations of the program.

### Law Enforcement Reporting

The reliability objective of EOP-004-2 is to improve the reliability of the Bulk Electric System by requiring the reporting of events by Responsible Entities. Certain outages, such as those due to vandalism and terrorism, may not be reasonably preventable. These are the types of events that should be reported to law enforcement. Entities rely upon law enforcement agencies to respond to and investigate those events which have the potential to impact a wider area of the BES. The inclusion of reporting to law enforcement enables and supports reliability principles such as protection of Bulk Electric System from malicious physical ~~or cyber~~ attack. ~~The Standard is intended to reduce the risk of Cascading events.~~ The importance of BES awareness of the threat around them is essential to the effective operation and planning to mitigate the potential risk to the BES.

### Stakeholders in the Reporting Process

- Industry
- NERC (ERO), Regional Entity
- FERC
- DOE

- NRC
- DHS – Federal
- Homeland Security- State
- State Regulators
- Local Law Enforcement
- State or Provincial Law Enforcement
- FBI
- Royal Canadian Mounted Police (RCMP)

The above stakeholders have an interest in the timely notification, communication and response to an incident at a Facility. The stakeholders have various levels of accountability and have a vested interest in the protection and response to ensure the reliability of the BES.

### **Present expectations of the industry under CIP-001-1a:**

It has been the understanding by industry participants that an occurrence of sabotage has to be reported to the FBI. The FBI has the jurisdictional requirements to investigate acts of sabotage and terrorism. The CIP-001-1-1a standard requires a liaison relationship on behalf of the industry and the FBI or RCMP. These requirements, under the standard, of the industry have not been clear and have led to misunderstandings and confusion in the industry as to how to demonstrate that the liaison is in place and effective. As an example of proof of compliance with Requirement R4, Responsible Entities have asked FBI Office personnel to provide, on FBI letterhead, confirmation of the existence of a working relationship to report acts of sabotage, the number of years the liaison relationship has been in existence, and the validity of the telephone numbers for the FBI.

### **Coordination of Local and State Law Enforcement Agencies with the FBI**

The Joint Terrorism Task Force (JTTF) came into being with the first task force being established in 1980. JTTFs are small cells of highly trained, locally based, committed investigators, analysts, linguists, SWAT experts, and other specialists from dozens of U.S. law enforcement and intelligence agencies. The JTTF is a multi-agency effort led by the Justice Department and FBI designed to combine the resources of federal, state, and local law enforcement. Coordination and communications largely through the interagency National Joint Terrorism Task Force, working out of FBI Headquarters, which makes sure that information and intelligence flows freely among the local JTTFs. This information flow can be most beneficial to the industry in analytical intelligence, incident response and investigation. Historically, the most immediate response to an industry incident has been local and state law enforcement agencies to suspected vandalism and criminal damages at industry facilities. Relying upon the JTTF coordination between local, state and FBI law enforcement would be beneficial to effective communications and the appropriate level of investigative response.

### **Coordination of Local and Provincial Law Enforcement Agencies with the RCMP**

A similar law enforcement coordination hierarchy exists in Canada. Local and Provincial law enforcement coordinate to investigate suspected acts of vandalism and sabotage. The Provincial


law enforcement agency has a reporting relationship with the Royal Canadian Mounted Police (RCMP).

### **A Reporting Process Solution – EOP-004**

A proposal discussed with the FBI, FERC Staff, NERC Standards Project Coordinator and the SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Reportable Events). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial or local level law enforcement agency. The state or provincial or local level law enforcement agency will coordinate with law enforcement with jurisdiction to investigate. If the state or provincial or local level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial or local level law enforcement agency will notify and coordinate with the FBI or the RCMP.

Example of Reporting Process including Law Enforcement

Entity Experiencing An Event in Attachment 1



\* Canadian entities will follow law enforcement protocols applicable in their jurisdictions

### Disturbance and Sabotage Reporting Standard Drafting Team (Project 2009-01) - Reporting Concepts

#### Introduction

The SAR for Project 2009-01, Disturbance and Sabotage Reporting was moved forward for standard drafting by the NERC Standards Committee in August of 2009. The Disturbance and Sabotage Reporting Standard Drafting Team (DSR SDT) was formed in late 2009 and has developed updated standards based on the SAR.

The standards listed under the SAR are:

- CIP-001 — Sabotage Reporting
- EOP-004 — Disturbance Reporting

The changes do not include any real-time operating notifications for the types of events covered by CIP-001 and EOP-004. The real-time reporting requirements are achieved through the RCIS and are covered in other standards (e.g. EOP-002-Capacity and Energy Emergencies). These standards deal exclusively with after-the-fact reporting.

The DSR SDT has consolidated disturbance and sabotage event reporting under a single standard. These two components and other key concepts are discussed in the following sections.

#### Summary of Concepts and Assumptions:

##### *The Standard:*

- Requires reporting of “events” that impact or may impact the reliability of the Bulk Electric System
- Provides clear criteria for reporting
- Includes consistent reporting timelines
- Identifies appropriate applicability, including a reporting hierarchy in the case of disturbance reporting
- Provides clarity around of who will receive the information

#### Discussion of Disturbance Reporting

Disturbance reporting requirements existed in the previous version of EOP-004. The current approved definition of Disturbance from the NERC Glossary of Terms is:

1. An unplanned event that produces an abnormal system condition.
2. Any perturbation to the electric system.
3. The unexpected change in ACE that is caused by the sudden failure of generation or interruption of load.

Disturbance reporting requirements and criteria were in the previous EOP-004 standard and its attachments. The DSR SDT discussed the reliability needs for disturbance reporting and developed the list of events that are to be reported under this standard (EOP-004 Attachment 1).

### **Discussion of Event Reporting**

There are situations worthy of reporting because they have the potential to impact reliability.

Event reporting facilitates industry awareness, which allows potentially impacted parties to prepare for and possibly mitigate any associated reliability risk. It also provides the raw material, in the case of certain potential reliability threats, to see emerging patterns.

Examples of such events include:

- Bolts removed from transmission line structures
- Train derailment adjacent to a Facility that either could have damaged a Facility directly or could indirectly damage a Facility (e.g. flammable or toxic cargo that could pose fire hazard or could cause evacuation of a control center)
- Destruction of Bulk Electric System equipment

### ***What about sabotage?***

One thing became clear in the DSR SDT's discussion concerning sabotage: everyone has a different definition. The current standard CIP-001 elicited the following response from FERC in FERC Order 693, paragraph 471 which states in part: “. . . *the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process: (1) further define sabotage and provide guidance as to the triggering events that would cause an entity to report a sabotage event.*”

Often, the underlying reason for an event is unknown or cannot be confirmed. The DSR SDT believes that by reporting material risks to the Bulk Electric System using the event categorization in this standard, it will be easier to get the relevant information for mitigation, awareness, and tracking, while removing the distracting element of motivation.

Certain types of events should be reported to NERC, the Department of Homeland Security (DHS), the Federal Bureau of Investigation (FBI), and/or Provincial or local law enforcement. Other types of events may have different reporting requirements. For example, an event that is related to copper theft may only need to be reported to the local law enforcement authorities.

### ***Potential Uses of Reportable Information***

Event analysis, correlation of data, and trend identification are a few potential uses for the information reported under this standard. The standard requires Functional entities to report the incidents and provide known information at the time of the report. Further data gathering necessary for event analysis is provided for under the Events Analysis Program and the NERC Rules of Procedure. Other entities (e.g. – NERC, Law Enforcement, etc) will be responsible for performing the analyses. The [NERC Rules of Procedure \(section 800\)](#) provide an overview of the responsibilities of the ERO in regards to analysis and dissemination of information for

reliability. Jurisdictional agencies (which may include DHS, FBI, NERC, RE, FERC, Provincial Regulators, and DOE) have other duties and responsibilities.

### **Collection of Reportable Information or “One stop shopping”**

The DSR SDT recognizes that some regions require reporting of additional information beyond what is in EOP-004. The DSR SDT has updated the listing of reportable events in EOP-004 Attachment 1 based on discussions with jurisdictional agencies, NERC, Regional Entities and stakeholder input. There is a possibility that regional differences still exist.

The reporting required by this standard is intended to meet the uses and purposes of NERC. The DSR SDT recognizes that other requirements for reporting exist (e.g., DOE-417 reporting), which may duplicate or overlap the information required by NERC. To the extent that other reporting is required, the DSR SDT envisions that duplicate entry of information should not be necessary, and the submission of the alternate report will be acceptable to NERC so long as all information required by NERC is submitted. For example, if the NERC Report duplicates information from the DOE form, the DOE report may be sent to the NERC in lieu of entering that information on the NERC report.

## Implementation Plan

### Project 2009-01 Disturbance and Sabotage Reporting

#### Implementation Plan for EOP-004-2 – Event Reporting

##### *Approvals Required*

EOP-004-2 – Event Reporting

##### *Prerequisite Approvals*

None

##### *Revisions to Glossary Terms*

None

##### *Applicable Entities*

Reliability Coordinator  
Balancing Authority  
Transmission Owner  
Transmission Operator  
Generator Owner  
Generator Operator  
Distribution Provider

##### *Conforming Changes to Other Standards*

None

##### *Effective Dates*

In those jurisdictions where regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months after applicable regulatory approval or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities. In those jurisdictions where no regulatory approval is required, this standard shall become effective on the first day of the first calendar quarter that is six months beyond the date this standard is approved by the Board of Trustees, or as otherwise made effective pursuant to the laws applicable to such ERO governmental authorities.



*Retirements*

**EOP-004-1 – Disturbance Reporting and CIP-001-2a – Sabotage Reporting** should be retired at midnight of the day immediately prior to the Effective Date of EOP-004-2 in the particular jurisdiction in which the new standard is becoming effective.

## Project 2009-01 Disturbance and Sabotage Reporting Mapping Document

Translation of CIP-002-2a – Sabotage Reporting and EOP-004-1 – Disturbance Reporting into EOP-004-2 – Event Reporting

Standard: CIP-001-2a – Sabotage Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Event Reporting
R1. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi site sabotage affecting larger portions of the Interconnection.	Moved into EOP-004-2, R1	<p>R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i></p> <p>The specific list of events shown in Attachment 1 provides the Responsible Entity with clarity of what is required to be reported under this standard.</p>

Standard: CIP-001-2a – Sabotage Reporting

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Event Reporting
<p>R2. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.</p>	<p>Moved into EOP-004-2, R1 and R2.</p>	<p>R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i></p> <p>R2. Each Responsible Entity shall implement its event reporting Operating Plan within 24 hours of meeting an event type threshold for reporting. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</i></p> <p>These requirements specify that the Responsible Entity must have an Operating Plan for reporting events listed in Attachment 1 to the necessary parties, including law enforcement. NERC Situational Awareness has an operating protocol to forward all event reports (for events that occur within the United States) to FERC.</p>

Standard: CIP-001-2a – Sabotage Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Event Reporting
R3. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.	Moved into EOP-004-2, R1	R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i>  This requirement specifies that the Responsible Entity must have an Operating Plan for reporting events listed in Attachment 1 to the necessary parties, including law enforcement.
R4. Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.	Moved into EOP-004-2, R1	R1. Each Responsible Entity shall have an event reporting Operating Plan in accordance with EOP-004-2 Attachment 1 that includes the protocol(s) for reporting to the Electric Reliability Organization and other organizations (e.g., the regional entity, company personnel, the Responsible Entity’s Reliability Coordinator, law enforcement, or governmental authority). <i>[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]</i>  These requirements specify that the Responsible Entity must have an Operating Plan for reporting events listed in Attachment 1 to the necessary parties, including law enforcement.

Standard: EOP-004-1 – Disturbance Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Event Reporting
R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.	Retire this fill-in-the-blank requirement.  Replace with new reporting and analysis procedure developed by NERC EAWG.	The requirements of EOP-004-2 specify that an entity must report certain types of events. The NERC EAWG has developed continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure, Section 800.
R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.	The NERC Events Analysis Process	The requirements of EOP-004-2 specify that an entity must report certain types of events. The NERC EAWG has developed continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure, Section 800.
R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.	Translated into EOP-004-2, R2	R2. Each Responsible Entity shall implement its event reporting Operating Plan within 24 hours of meeting an event type threshold for reporting. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</i>  The requirements of EOP-004-2 specify that an entity must report certain types of events.

Standard: EOP-004-1 – Disturbance Reporting		
Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Event Reporting
R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load-Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until sometime after they occur shall be reported within 24 hours of being recognized.	Translated into EOP-004-2, R2	R2. Each Responsible Entity shall implement its event reporting Operating Plan within 24 hours of meeting an event type threshold for reporting. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Assessment]</i>  The requirements of EOP-004-2 specify that an entity must report certain types of events.
R3.2. Applicable reporting forms are provided in Attachments 022-1 and 022-2.	Retire – informational statement	

**Standard: EOP-004-1 – Disturbance Reporting**

Requirement in Approved Standard	Translation to New Standard or Other Action	Proposed Language in EOP-004-2 - Event Reporting
<p>R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.</p>	<p>Retire as a requirement. Added as a “Note” to EOP-004-Attachment1-Events Table</p>	<p>NOTE: Under certain adverse conditions (e.g. severe weather, multiple events) it may not be possible to report the damage caused by an event and issue a written Event Report. In such cases, the affected Responsible Entity shall notify parties per Requirement R2 and provide as much information as is available at the time of the notification. Submit reports to the ERO via one of the following: e-mail: <a href="mailto:systemawareness@nerc.net">systemawareness@nerc.net</a> or Voice: 404-446-9780.</p>

<b>Standard: EOP-004-1 – Disturbance Reporting</b>		
<b>Requirement in Approved Standard</b>	<b>Translation to New Standard or Other Action</b>	<b>Proposed Language in EOP-004-2 - Event Reporting</b>
<p>R3.4. If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.</p>	<p>Retire this fill-in-the-blank requirement.</p>	<p>The requirements of EOP-004-2 specify that an entity must report certain types of events. The NERC EAWG has developed continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure, Section 800.</p>



<b>Standard: EOP-004-1 – Disturbance Reporting</b>		
<b>Requirement in Approved Standard</b>	<b>Translation to New Standard or Other Action</b>	<b>Proposed Language in EOP-004-2 - Event Reporting</b>
R4. When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load-Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.	Retire this fill-in-the-blank requirement.	The requirements of EOP-004-2 specify that an entity must report certain types of events. The NERC EAWG has developed continent wide reporting and analysis guidelines applicable under the NERC Rules of Procedure, Section 800.

## Project 2009-01 Disturbance and Sabotage Reporting Consideration of Issues and Directives

Project 2009-01 Disturbance and Sabotage Reporting		
Issue or Directive	Source	Consideration of Issue or Directive
<p>"What is meant by: "establish contact with the FBI"? Is a phone number adequate? Many entities which call the FBI are referred back to the local authority. The AOT noted that on the FBI website it states to contact the local authorities. Is this a question for Homeland Security to deal with for us?"</p> <p>Establish communications contacts, as applicable with local FBI and RCMP officials. Some entities are very remote and the sheriff is the only local authority does the FBI still need to be contacted?</p> <p>Registered Entities have sabotage reporting processes and procedures in place but not all personnel has been trained.</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>The DSR SDT has been in contact with FBI staff and developed a notification flow chart for law enforcement as it pertains to EOP-004. The "Background" section of the standard outlines the reporting hierarchy that exists between local, state, provincial and federal law enforcement. The entity experiencing an event should notify the appropriate state or provincial law enforcement agency that will then coordinate with local law enforcement for investigation. These local, state and provincial agencies will coordinate with higher levels of law enforcement or other governmental agencies.</p>

<p>Question: How do you “and make the operator aware”</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>This has been removed from the standard. Requirement R1 requires that the entity has an Operating Plan for applicable events listed in Attachment 1.</p>
<p>How does this standard pertain to Load Serving Entities, LSE's.</p>	<p>CIP-001-1 NERC Audit Observation Team</p>	<p>LSE has been removed as an applicable entity as there are no applicable events.</p>
<p>Order No. 693 at Paragraph 469. We direct the ERO to explore ways to address these concerns – including central coordination of sabotage reports and a uniform reporting format – in developing modifications to the Reliability Standard with the appropriate governmental agencies that have levied the reporting requirements.</p>	<p>CIP-001-1; Order 693 at P 469</p>	<p>See “Background” section of the standard as well as the “Guidelines and Technical Basis” section.</p>

<p>"Define "sabotage" and provide guidance on triggering events that would cause an entity to report an event.</p> <p>Order No. 693 at Paragraph 461. Several commenters agree with the Commission's concern that the term "sabotage" should be defined. For the reasons stated in the NOPR, we direct that the ERO further define the term and provide guidance on triggering events that would cause an entity to report an event. However, we disagree with those commenters that suggest the term "sabotage" is so vague as to justify a delay in approval or the application of monetary penalties. As explained in the NOPR, we believe that the term sabotage is commonly understood and that common understanding should suffice in most instances.</p>	<p>CIP-001-1; Order 693 at P 461</p>	<p>The DSR SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of "event". The DSR SDT considered the FERC directive to "further define sabotage" and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term "sabotage" is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p>
<p>Order No. 693 at Paragraph 470. The ERO should consider suggestions raised by commenters such as FirstEnergy and Xcel to define the specified period for reporting an incident beginning from when an event is discovered or suspected to be sabotage, and APPA's concerns regarding events at unstaffed or remote facilities, and triggering events occurring outside staffed hours at small entities.</p>	<p>CIP-001-1; Order 693 at P 470</p>	<p>Attachment 1 defines the events which are to be reported under this standard. The required reporting is within 24 hours "of recognition of the event."</p>

Order No. 693 at Paragraph 461. Modify CIP-001-1 1 to require an applicable entity to contact appropriate governmental authorities in the event of sabotage within a specific period of time, even if it is a preliminary report. Further, in the interim while the matter is being addressed by the Reliability Standards development process, we direct the ERO to provide advice to entities that have concerns about the reporting of particular circumstances as they arise.

CIP-001-1;  
Order 693 at P  
461

Per Requirement R1, the entity is to develop an Operating Plan which includes event reporting to law enforcement and governmental agencies. The DSR SDT has been in contact with NERC Situational Awareness and has been informed that all event reports received by NERC are being forwarded to FERC.

<p>Consider the need for wider application of the standard. Consider whether separate, less burdensome requirements for smaller entities may be appropriate.</p> <p>Order No. 693 at Paragraph 458. The Commission acknowledges the concerns of the commenters about the applicability of CIP-001-1 to small entities and has addressed the concerns of small entities generally earlier in this Final Rule. Our approval of the ERO Compliance Registry criteria to determine which users, owners and operators are responsible for compliance addresses the concerns of APPA and others.</p> <p>Order No. 693 at Paragraph 459. However, the Commission believes that there are specific reasons for applying this Reliability Standard to such entities, as discussed in the NOPR. APPA indicates that some small LSEs do not own or operate “hard assets” that are normally thought of as “at risk” to sabotage. The Commission is concerned that, an adversary might determine that a small LSE is the appropriate target when the adversary aims at a particular population or facility. Or an adversary may target a small user, owner or operator because it may have similar equipment or protections as a larger facility, that is, the adversary may use an attack against a smaller facility as a training “exercise.” {continued below}</p>	<p>CIP-001-1; Order 693 at PP 458-60</p>	<p>Attachment 1 defines the events which are to be reported under this standard. The applicable entities are also identified for each type of event. Each event is to be reported within 24 hours of recognition of the event.</p>
--	--	--

The knowledge of sabotage events that occur at any facility (including small facilities) may be helpful to those facilities that are traditionally considered to be the primary targets of adversaries as well as to all members of the electric sector, the law enforcement community and other critical infrastructures.

Order No. 693 at Paragraph 460. For these reasons, the Commission remains concerned that a wider application of CIP-001-1 may be appropriate for Bulk Power System reliability. Balancing these concerns with our earlier discussion of the applicability of Reliability Standards to smaller entities, we will not direct the ERO to make any specific modification to CIP-001-1 to address applicability. However, we direct the ERO, as part of its Work Plan, to consider in the Reliability Standards development process, possible revisions to CIP-001-1 that address our concerns. Regarding the need for wider application of the Reliability Standard. Further, when addressing such applicability issues, the ERO should consider whether separate, less burdensome requirements for smaller entities may be appropriate to address these concerns.

<p>Order No. 693 at Paragraph 466.</p> <p>The Commission affirms the NOPR directive and directs the ERO to incorporate a periodic review or updating of the sabotage reporting procedures and for the periodic testing of the sabotage reporting procedures. At this time, the commission does not specify a review period as suggested by FirstEnergy and MRO and, rather, believes that the appropriate period should be determined through the ERO's Reliability Standards development process. However, the Commission directs that the ERO begin this process by considering a staggered schedule of annual testing of the procedures with modifications made when warranted formal review of the procedures every two or three years.</p>	<p>CIP-001-1; Order 693 at P 466</p>	<p>The standard is responsive this directive with the following language in Requirement R3:</p> <p>R3. Each Responsible Entity shall validate all contact information contained in the Operating Plan pursuant to Requirement R1 each calendar year. <i>[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]</i></p> <p>The DSR SDT envisions that this will include verification that contact information contained in the Operating Plan is correct. As an example, the annual validation could include calling others as defined in the Responsibility Entity's Operating Plan to verify that their contact information is correct and current. If any discrepancies are noted, the Operating Plan would be updated.</p>
---	--	--



<p>Consider FirstEnergy’s suggestions to differentiate between cyber and physical security sabotage and develop a threshold of materiality.</p> <p>Order No. 693 at Paragraph 451. A number of commenters agree with the Commission’s concern that the term sabotage” needs to be better defined and guidance provided on the triggering events that would cause an entity to report an event. FirstEnergy states that this definition should differentiate between cyber and physical sabotage and should exclude unintentional operator error. It advocates a threshold of materiality to exclude acts that do not threaten to reduce the ability to provide service or compromise safety and security. SoCal Edison states that clarification regarding the meaning of sabotage and the triggering event for reporting would be helpful and prevent over reporting.</p>	<p>CIP-001-1; Order 693 at P 451, 467-68</p>	<p>This is addressed in Attachment 1. There are specific event types for physical security with report submittal requirements. Cyber security is addressed in the CIP version 5 standards.</p>
<p>471. As explained in the NOPR, while the Commission has identified concerns regarding CIP-001-1, we believe that the proposal serves an important purpose in ensuring that operating entities properly respond to sabotage events to minimize the adverse impact on the Bulk-Power System. Accordingly, the Commission approves Reliability Standard CIP-001-1 as mandatory and enforceable. In addition, pursuant to section 215(d)(5) of the FPA and § 39.5(f) of our regulations, the Commission directs the ERO to develop the following modifications to the Reliability Standard through the Reliability Standards development process:... (2) specify baseline requirements regarding what issues should be addressed in the procedures for recognizing sabotage events and making personnel aware of such events;</p>	<p>CIP-001-1; Order 693 at P 471</p>	<p>This is addressed in Requirement R1 and Attachment 1. There are specific event types for physical security report submittal requirements. Cyber security is addressed in the CIP version 5 standards.</p>

"Include a requirement to report a sabotage event to the proper government authorities. Develop the language to specifically implement this directive.

Order No. 693 at Paragraph 467. CIP-001-1, Requirement R4, requires that each applicable entity establish communications contacts, as applicable, with the local FBI or Royal Canadian Mounted Police officials and develop reporting procedures as appropriate to its circumstances. The Commission in the NOPR expressed concern that the Reliability Standard does not require an applicable entity to actually contact the appropriate governmental or regulatory body in the event of sabotage. Therefore, the Commission proposed that NERC modify the Reliability Standard to require an applicable entity to "contact appropriate federal authorities, such as the Department of Homeland Security, in the event of sabotage within a specified period of time."

Order No. 693 at Paragraph 468. As mentioned above, NERC and others object to the wording of the proposed directive as overly prescriptive and note that the reference to "appropriate federal authorities" fails to recognize the international application of the Reliability Standard. The example of the Department of Homeland Security as an "appropriate federal authority" was not intended to be an exclusive designation. Nonetheless, the Commission agrees that a reference to "federal authorities" could create confusion. Accordingly, we modify the direction in the NOPR and now direct the ERO to address our underlying concern regarding mandatory reporting of a sabotage event. The ERO's Reliability Standards development process should develop the language to implement this directive."

See "Guidelines and Technical Basis" section of Standard.

"A proposal discussed with FBI, FERC Staff, NERC Standards Project Coordinator and SDT Chair is reflected in the flowchart below (Reporting Hierarchy for Event EOP-004-2). Essentially, reporting an event to law enforcement agencies will only require the industry to notify the state or provincial level law enforcement agency. The state or provincial level law enforcement agency will coordinate with local law enforcement to investigate. If the state or provincial level law enforcement agency decides federal agency law enforcement or the RCMP should respond and investigate, the state or provincial level law enforcement agency will notify and coordinate with the FBI or the RCMP."

At present NERC Situational Awareness staff forwards applicable event reports to FERC. This only includes reports for events that are subject to FERC jurisdiction (i.e. – US entities).

On March 4, 2008, NERC submitted a compliance filing in response to a December 20, 2007 Order, in which the Commission reversed a NERC decision to register three retail power marketers to comply with Reliability Standards applicable to load serving entities (LSEs) and directed NERC to submit a plan describing how it would address a possible “reliability gap” that NERC asserted would result if the LSEs were not registered.

Compliance Filing of NERC in Response to December 20, 2007 Order in Docket Nos. RC07-4-000, RC07-6-000, RC07-7-000 (March 4, 2008).

NERC’s compliance filing included the following proposal for a short-term plan and a long-term plan to address the potential gap:

- Short-term: Using a posting and open comment process, NERC will revise the registration criteria to define “Non-Asset Owning LSEs” as a subset of Load Serving Entities and will specify the reliability standards applicable to that subset.
- Longer-term: NERC will determine the changes necessary to terms and requirements in reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers and process them through execution of the three-year Reliability Standards Development Plan. In this revised Reliability Standards Development Plan, NERC is commencing the implementation of its stated long-term plan to address the issues surrounding accountability for loads served by retail marketers/suppliers.

The NERC Reliability Standards Development Procedure will be used to identify the changes necessary to terms and requirements in reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. Specifically, the following description has been incorporated into the scope for

CIP-001-1 and EOP-004  
*Direct Energy Services, LLC, et al.*, 121 FERC ¶ 61,274 (2007)

The LSE is no longer an applicable entity, since no reportable event types in Attachment apply to an LSE. If an entity owns distribution assets, that entity will be registered as a Distribution Provider. Attachment 1 defines the timelines and events which are to be reported under this standard. The applicable entities are also identified for each type of event.

affected projects in this revised Reliability Standards Development Plan that includes a standard applicable to Load Serving Entities:  
Source: *Direct Energy Services, LLC, et al.*, 121 FERC ¶ 61,274 (2007)

Issue: In FERC's December 20, 2007 Order, the Commission reversed NERC's Compliance Registry decisions with respect to three load serving entities in the ReliabilityFirst (RFC) footprint. The distinguishing feature of these three LSEs is that none own physical assets. Both NERC and RFC assert that there will be a "reliability gap" if retail marketers are not registered as LSEs. To avoid a possible gap, a consistent, uniform approach to ensure that appropriate Reliability Standards and associated requirements are applied to retail marketers must be followed.

Each drafting team responsible for reliability standards that are applicable to LSEs is to review and change as necessary, requirements in the reliability standards to address the issues surrounding accountability for loads served by retail marketers/suppliers. For additional information see:

- FERC's December 20, 2007 Order  
([http://www.nerc.com/files/LSE\\_decision\\_order.pdf](http://www.nerc.com/files/LSE_decision_order.pdf))
- NERC's March 4, 2008  
(<http://www.nerc.com/files/FinalFiledLSE3408.pdf>),
- FERC's April 4, 2008 Order  
(<http://www.nerc.com/files/AcceptLSECompFiling-040408.pdf>), and
- NERC's July 31, 2008  
(<http://www.nerc.com/files/FinalFiled-compFiling-LSE-07312008.pdf>)

compliance filings to FERC on this subject.

<p>Object to multi-site requirement</p>	<p>Version 0 Team CIP-001-1</p>	<p>The Standard was revised for clarity. Attachment 1 defines the timelines and events which are to be reported under this standard. The applicable entities are also identified for each type of event.</p>
<p>Definition of sabotage required</p> <p>VRFs Team Adequate procedures will insure it is unlikely to lead to bulk electric system instability, separation, or cascading failures.</p>	<p>Version 0 Team CIP-001-1</p>	<p>No definition for sabotage was developed. The DSR SDT has not proposed a definition for inclusion in the NERC Glossary because it is impractical to define every event that should be reported without listing them in the definition. Attachment 1 is the de facto definition of “event”. The DSR SDT considered the FERC directive to “further define sabotage” and decided to eliminate the term sabotage from the standard. The team felt that without the intervention of law enforcement after the fact, it was almost impossible to determine if an act or event was that of sabotage or merely vandalism. The term “sabotage” is no longer included in the standard and therefore it is inappropriate to attempt to define it. The events listed in Attachment 1 provide guidance for reporting both actual events as well as events which may have an impact on the Bulk Electric System. The DSR SDT believes that this is an equally effective and efficient means of addressing the FERC Directive.</p>

<p>Coordination and follow up on lessons learned from event analyses          Consider adding to EOP-004 – Disturbance Reporting Proposed requirement: Regional Entities (REs) shall work together with Reliability Coordinators, Transmission Owners, and Generation Owners to develop an Event Analysis Process to prevent similar events from happening and follow up with the recommendations. This process shall be defined within the appropriate NERC Standard.</p>	<p>Events Analysis Team Reliability Issue</p>	<p>The DSR SDT envisions EOP-004-2 to be a reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
<p>Consider changes to R1 and R3.4 to standardize the disturbance reporting requirements (requirements for disturbance reporting need to be added to this standard). Regions currently have procedures, but not in the form of a standard. The drafting team will need to review regional requirements to determine reporting requirements for the North American standard.</p>	<p>Fill in the Blank Team</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
<p>Can there be a violation without an event?</p>	<p>NERC Audit Observation Team</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. In the opinion of the DSR SDT, there cannot be a violation of Requirement R2 without an event. Since Requirement R1 calls for an Operating Plan, there can be a violation of R1 without an event.</p>

<p>Consider APPA’s concern about generator operators and LSEs analyzing performance of their equipment and provide data and information on the equipment to assist others with analysis.</p> <p>Order No. 693 at Paragraph 607. APPA is concerned about the scope of Requirement R2 because, in its opinion, Requirement R2 appears to impose an open-ended obligation on entities such as generation operators and LSEs that may have neither the data nor the tools to promptly analyze disturbances that could have originated elsewhere. APPA proposes that Requirement R2 be modified to require affected entities to promptly begin analyses to ensure timely reporting to NERC and DOE.</p> <p>Order No. 693 at Paragraph 612. Requirement R2 of the Reliability Standard requires reliability coordinators, balancing authorities, transmission operators, generator operators and LSEs to promptly analyze disturbances on their system or facilities. APPA is concerned that generator operators and LSEs may be unable to promptly analyze disturbances, particularly those disturbances that may have originated outside of their systems, as they may have neither the data nor the tools required for such analysis. The Commission understands APPA’s concern and believes that, at a minimum, generator operators and LSEs should analyze the performance of their equipment and provide the data and information on their equipment to assist others with their analyses. The Commission directs the ERO to consider this concern in future revisions to the Reliability Standard through the Reliability Standards development process.</p>	<p>EOP-004-1 Order 693 at PP 607, 612</p>	<p>The DSR SDT envisions EOP-004-2 to be a continent-wide reporting standard. Any follow up investigation or analysis falls under the purview of the NERC Events Analysis Program under the NERC Rules of Procedure.</p>
---	---	--

FERC request for DOE-417s	EOP-004-1 Other	Per Requirement R1, the entity is to develop an Operating Plan which includes event reporting to law enforcement and governmental agencies. The DSR SDT has been in contact with NERC Situational Awareness and has been informed that all event reports received by NERC are being forwarded to FERC.
---------------------------	--------------------	--



## Violation Risk Factor and Violation Severity Level Assignments

### Project 2009-01 – Disturbance and Sabotage Reporting

This document provides the drafting team’s justification for assignment of violation risk factors (VRFs) and violation severity levels (VSLs) for each requirement in

#### EOP-004-2 — Event Reporting

Each primary requirement is assigned a VRF and a set of one or more VSLs. These elements support the determination of an initial value range for the Base Penalty Amount regarding violations of requirements in FERC-approved Reliability Standards, as defined in the ERO Sanction Guidelines.

#### Justification for Assignment of Violation Risk Factors in EOP-004-2

The Disturbance and Sabotage Reporting Standard Drafting Team applied the following NERC criteria when proposing VRFs for the requirements in EOP-004-2:

##### ***High Risk Requirement***

A requirement that, if violated, could directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly cause or contribute to bulk electric system instability, separation, or a cascading sequence of failures, or could place the bulk electric system at an unacceptable risk of instability, separation, or cascading failures, or could hinder restoration to a normal condition.

##### ***Medium Risk Requirement***

A requirement that, if violated, could directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system. However, violation of a medium risk requirement is unlikely to lead to bulk electric system instability, separation, or cascading failures; or, a requirement in a planning time frame that, if violated, could, under emergency, abnormal, or restorative conditions anticipated by the preparations, directly and adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. However, violation of a medium risk requirement is unlikely, under emergency, abnormal, or restoration conditions anticipated by the preparations, to lead to bulk electric system instability, separation, or cascading failures, nor to hinder restoration to a normal condition.

***Lower Risk Requirement***

A requirement that is administrative in nature and a requirement that, if violated, would not be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system; or, a requirement that is administrative in nature and a requirement in a planning time frame that, if violated, would not, under the emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system. A planning requirement that is administrative in nature.

The SDT also considered consistency with the FERC Violation Risk Factor Guidelines for setting VRFs:<sup>1</sup>

**Guideline (1) — Consistency with the Conclusions of the Final Blackout Report**

The Commission seeks to ensure that Violation Risk Factors assigned to Requirements of Reliability Standards in these identified areas appropriately reflect their historical critical impact on the reliability of the Bulk-Power System.

In the VSL Order, FERC listed critical areas (from the Final Blackout Report) where violations could severely affect the reliability of the Bulk-Power System:<sup>2</sup>

- Emergency operations
- Vegetation management
- Operator personnel training
- Protection systems and their coordination
- Operating tools and backup facilities
- Reactive power and voltage control
- System modeling and data exchange
- Communication protocol and facilities
- Requirements to determine equipment ratings
- Synchronized data recorders
- Clearer criteria for operationally critical facilities
- Appropriate use of transmission loading relief.

**Guideline (2) — Consistency within a Reliability Standard**

The Commission expects a rational connection between the sub-Requirement Violation Risk Factor assignments and the main Requirement Violation Risk Factor assignment.

<sup>1</sup> North American Electric Reliability Corp., 119 FERC ¶ 61,145, order on reh'g and compliance filing, 120 FERC ¶ 61,145 (2007) (“VRF Rehearing Order”).

<sup>2</sup> Id. at footnote 15.

### **Guideline (3) — Consistency among Reliability Standards**

The Commission expects the assignment of Violation Risk Factors corresponding to Requirements that address similar reliability goals in different Reliability Standards would be treated comparably.

### **Guideline (4) — Consistency with NERC’s Definition of the Violation Risk Factor Level**

Guideline (4) was developed to evaluate whether the assignment of a particular Violation Risk Factor level conforms to NERC’s definition of that risk level.

### **Guideline (5) — Treatment of Requirements that Co-mingle More Than One Obligation**

Where a single Requirement co-mingles a higher risk reliability objective and a lesser risk reliability objective, the VRF assignment for such Requirements must not be watered down to reflect the lower risk level associated with the less important objective of the Reliability Standard.

The following discussion addresses how the SDT considered FERC’s VRF Guidelines 2 through 5. The team did not address Guideline 1 directly because of an apparent conflict between Guidelines 1 and 4. Whereas Guideline 1 identifies a list of topics that encompass nearly all topics within NERC’s Reliability Standards and implies that these requirements should be assigned a “High” VRF, Guideline 4 directs assignment of VRFs based on the impact of a specific requirement to the reliability of the system. The SDT believes that Guideline 4 is reflective of the intent of VRFs in the first instance and therefore concentrated its approach on the reliability impact of the requirements.

#### ***VRF for EOP-004-2:***

There are three requirements in EOP-004-2. Requirement R1 was assigned a Lower VRF while Requirements R2 and R3 were assigned a Medium VRF.

#### ***VRF for EOP-004-2, Requirements R1:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. The Requirement specifies which entities are required to have processes for recognition of events and for communicating with other entities. This Requirement is the only administrative Requirement within the Standard. The VRF is only applied at the Requirement level. FERC’s Guideline 3 — Consistency among Reliability Standards. This requirement calls for an entity to have processes for recognition of events and communicating with other entities. This requirement is administrative in nature and deals with the means to report events after the fact. All event reporting requirements in Attachment 1 are for 24 hours after recognition that an event has occurred. The current approved VRFs for EOP-004-1 are

all lower with the exception of Requirement R2 which is a requirement to analyze events. This standard relates only to reporting events. The analysis portion is addressed through the NERC Rules of Procedure and the Events Analysis Program.

- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. Failure to have an event reporting Operating Plan is not likely to directly affect the electrical state or the capability of the bulk electric system. Development of the Operating Plan is a requirement that is administrative in nature and is in a planning time frame that, if violated, would not, under emergency, abnormal, or restorative conditions anticipated by the preparations, be expected to adversely affect the electrical state or capability of the bulk electric system, or the ability to effectively monitor, control, or restore the bulk electric system.. Therefore this requirement was assigned a Lower VRF.
- FERC’s Guideline 5 — Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R1 contains only one objective which is to have an Operating Plan with two distinct processes. Since the requirement is to have an Operating Plan, only one VRF was assigned.

***VRF for EOP-004-2, Requirement R2:***

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to implement its Operating Plan and is assigned a Medium VRF. There is one other similar Requirement in this Standard which specifies an annual validation of the information contained in the Operating Plan (R3). Both of these Requirements are assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R2 is a requirement for entities to report events using the process for recognition of events per Attachment 1. Failure to report events within 24 hours is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not report events. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R2 mandates that Responsible Entities implement their Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to notify another entity of the event failure, but there is a slight chance that it could occur. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R2 addresses a single objective and has a single VRF.

**VRF for EOP-004-2, Requirement R3:**

- FERC’s Guideline 2 — Consistency within a Reliability Standard. This Requirement calls for the Responsible Entity to perform an annual validation of the information contained in the Operating Plan and is assigned a Medium VRF. There is one other similar Requirement in this Standard which specifies that the Responsible Entity implement its Operating Plan (R2).. Both of these Requirements is assigned a Medium VRF.
- FERC’s Guideline 3 — Consistency among Reliability Standards. EOP-004-2, Requirement R3 is a requirement for entities to perform an annual validation of the information contained of the information in the Operating Plan. Failure to perform an annual validation of the information contained in the Operating Plan is not likely to “directly affect the electrical state or the capability of the bulk electric system, or the ability to effectively monitor and control the bulk electric system.” However, violation of a medium risk requirement should also be “unlikely to lead to bulk electric system instability, separation, or cascading failures...” Such an instance could occur if personnel do not perform an annual test of the Operating Plan and it is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 4 — Consistency with NERC’s Definition of a VRF. EOP-004-2, Requirement R3 mandates that Responsible Entities perform an annual validation of the information contained of the information in the Operating Plan. Bulk power system instability, separation, or cascading failures are not likely to occur due to a failure to perform an annual test of the Operating Plan, but there is a slight chance that it could occur if the Operating Plan is out of date or contains erroneous information. Therefore, this requirement was assigned a Medium VRF.
- FERC’s Guideline 5 - Treatment of Requirements that Co-mingle More Than One Objective. EOP-004-2, Requirement R3 addresses a single objective and has a single VRF.

**Justification for Assignment of Violation Severity Levels for EOP-004-2:**

In developing the VSLs for the EOP-004-2 standard, the SDT anticipated the evidence that would be reviewed during an audit, and developed its VSLs based on the noncompliance an auditor may find during a typical audit. The SDT based its assignment of VSLs on the following NERC criteria:

Lower	Moderate	High	Severe
<p>Missing a minor element (or a small percentage) of the required performance</p> <p>The performance or product measured has significant value as it almost meets the full intent of the requirement.</p>	<p>Missing at least one significant element (or a moderate percentage) of the required performance.</p> <p>The performance or product measured still has significant value in meeting the intent of the requirement.</p>	<p>Missing more than one significant element (or is missing a high percentage) of the required performance or is missing a single vital component.</p> <p>The performance or product has limited value in meeting the intent of the requirement.</p>	<p>Missing most or all of the significant elements (or a significant percentage) of the required performance.</p> <p>The performance measured does not meet the intent of the requirement or the product delivered cannot be used in meeting the intent of the requirement.</p>

FERC’s VSL guidelines are presented below, followed by an analysis of whether the VSLs proposed for each requirement in EOP-004-2 meet the FERC Guidelines for assessing VSLs:

**Guideline 1: Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance**

Compare the VSLs to any prior levels of non-compliance and avoid significant changes that may encourage a lower level of compliance than was required when levels of non-compliance were used.

**Guideline 2: Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties**

A violation of a “binary” type requirement must be a “Severe” VSL.

Do not use ambiguous terms such as “minor” and “significant” to describe noncompliant performance.

**Guideline 3: Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement**

VSLs should not expand on what is required in the requirement.

**Guideline 4: Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations**

. . . unless otherwise stated in the requirement, each instance of non-compliance with a requirement is a separate violation. Section 4 of the Sanction Guidelines states that assessing penalties on a per violation per day basis is the “default” for penalty calculations.

**VSLs for EOP-004-2 Requirements R1:**

R#	Compliance with NERC's VSL Guidelines	<p>Guideline 1</p> <p>Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance</p>	<p>Guideline 2</p> <p>Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties</p> <p>Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent</p> <p>Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language</p>	<p>Guideline 3</p> <p>Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement</p>	<p>Guideline 4</p> <p>Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations</p>
<b>R1</b>	Meets NERC's VSL guidelines. The requirement calls for the entity to have an Operating Plan and is binary in nature. The VSL is therefore set to "Severe".	The proposed requirement is a revision of CIP-001-1, R1-R4, and EOP-004-1, R2. The Requirement has no Parts and is binary in nature. The binary VSL does not lower the current level of Compliance.	The proposed VSL does not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed binary VSL uses the same terminology as used in the associated requirement, and is, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.



**VSLs for EOP-004-2 Requirement R2:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
<b>R2</b>	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a revision of EOP-004-1, R3. There is only a Severe VSL for that requirement. However, the reporting of events is based on timing intervals listed in EOP-004 Attachment 1. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a report is not submitted, then the VSL is Severe. This maintains the current VSL.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

**VSLs for EOP-004-2 Requirement R3:**

R#	Compliance with NERC's VSL Guidelines	Guideline 1 Violation Severity Level Assignments Should Not Have the Unintended Consequence of Lowering the Current Level of Compliance	Guideline 2 Violation Severity Level Assignments Should Ensure Uniformity and Consistency in the Determination of Penalties  Guideline 2a: The Single Violation Severity Level Assignment Category for "Binary" Requirements Is Not Consistent  Guideline 2b: Violation Severity Level Assignments that Contain Ambiguous Language	Guideline 3 Violation Severity Level Assignment Should Be Consistent with the Corresponding Requirement	Guideline 4 Violation Severity Level Assignment Should Be Based on A Single Violation, Not on A Cumulative Number of Violations
R3	Meets NERC's VSL guidelines. There is an incremental aspect to the violation and the VSLs follow the guidelines for incremental violations.	The proposed requirement is a new Requirement. The test of the Operating Plan is based on the calendar year. Based on the VSL Guidance, the DSR SDT developed four VSLs based on tardiness of the submittal of the report. If a test is not performed, then the VSL is Severe.	The proposed VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.	The proposed VSLs use the same terminology as used in the associated requirement, and are, therefore, consistent with the requirement.	The VSLs are based on a single violation and not cumulative violations.

### A. Introduction

1. **Title:** **Sabotage Reporting**
2. **Number:** CIP-001-2a
3. **Purpose:** Disturbances or unusual occurrences, suspected or determined to be caused by sabotage, shall be reported to the appropriate systems, governmental agencies, and regulatory bodies.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Transmission Owners (only in ERCOT Region).
  - 4.7. Generator Owners (only in ERCOT Region).
5. **Effective Date:** ERCOT Regional Variance will be effective the first day of the first calendar quarter after applicable regulatory approval.

### B. Requirements

- R1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- R2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- R3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- R4.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall establish communications contacts, as applicable, with local Federal Bureau of Investigation (FBI) or Royal Canadian Mounted Police (RCMP) officials and develop reporting procedures as appropriate to their circumstances.

### C. Measures

- M1.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement 1
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements 2 and 3.

- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to procedures, policies, a letter of understanding, communication records, or other equivalent evidence that will be used to confirm that it has established communications contacts with the applicable, local FBI or RCMP officials to communicate sabotage events (Requirement 4).

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

Regional Reliability Organizations shall be responsible for compliance monitoring.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to verify compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Reliability Coordinator, Transmission Operator, Generator Operator, Distribution Provider, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

#### **1.4. Additional Compliance Information**

None.

### **2. Levels of Non-Compliance:**

**2.1. Level 1:** There shall be a separate Level 1 non-compliance, for every one of the following requirements that is in violation:

- 2.1.1** Does not have procedures for the recognition of and for making its operating personnel aware of sabotage events (R1).

- 2.1.2 Does not have procedures or guidelines for the communication of information concerning sabotage events to appropriate parties in the Interconnection (R2).
- 2.1.3 Has not established communications contacts, as specified in R4.
- 2.2. **Level 2:** Not applicable.
- 2.3. **Level 3:** Has not provided its operating personnel with sabotage response procedures or guidelines (R3).
- 2.4. **Level 4:** Not applicable.

## **E. ERCOT Interconnection-wide Regional Variance**

### **Requirements**

- EA.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the recognition of and for making their operating personnel aware of sabotage events on its facilities and multi-site sabotage affecting larger portions of the Interconnection.
- EA.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.
- EA.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall provide its operating personnel with sabotage response guidelines, including personnel to contact, for reporting disturbances due to sabotage events.
- EA.4.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall establish communications contacts with local Federal Bureau of Investigation (FBI) officials and develop reporting procedures as appropriate to their circumstances.

### **Measures**

- M.A.1.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request a procedure (either electronic or hard copy) as defined in Requirement EA1.
- M.A.2.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request the procedures or guidelines that will be used to confirm that it meets Requirements EA2 and EA3.
- M.A.3.** Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have and provide upon request evidence that could include, but is not limited to, procedures, policies, a letter of understanding, communication records,

or other equivalent evidence that will be used to confirm that it has established communications contacts with the local FBI officials to communicate sabotage events (Requirement EA4).

**Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Enforcement Authority**

Regional Entity shall be responsible for compliance monitoring.

**1.2. Data Retention**

Each Reliability Coordinator, Balancing Authority, Transmission Owner, Transmission Operator, Generator Owner, Generator Operator, and Load Serving Entity shall have current, in-force documents available as evidence of compliance as specified in each of the Measures.

If an entity is found non-compliant the entity shall keep information related to the non-compliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Amended
1	April 4, 2007	Regulatory Approval — Effective Date	New
1a	February 16, 2010	Added Appendix 1 — Interpretation of R2 approved by the NERC Board of Trustees	Addition
1a	February 2, 2011	Interpretation of R2 approved by FERC on February 2, 2011	Same addition
	June 10, 2010	TRE regional ballot approved variance	By Texas RE
	August 24, 2010	Regional Variance Approved by Texas RE Board of Directors	
2a	February 16, 2011	Approved by NERC Board of Trustees	

**Standard CIP-001-2a— Sabotage Reporting**

---

2a	August 2, 2011	FERC Order issued approving Texas RE Regional Variance	
----	----------------	--	--

Appendix 1

<b>Requirement Number and Text of Requirement</b>
<p><b>CIP-001-1:</b></p> <p><b>R2.</b> Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load Serving Entity shall have procedures for the communication of information concerning sabotage events to appropriate parties in the Interconnection.</p>
<b>Question</b>
<p>Please clarify what is meant by the term, “appropriate parties.” Moreover, who within the Interconnection hierarchy deems parties to be appropriate?</p>
<b>Response</b>
<p>The drafting team interprets the phrase “appropriate parties in the Interconnection” to refer collectively to entities with whom the reporting party has responsibilities and/or obligations for the communication of physical or cyber security event information. For example, reporting responsibilities result from NERC standards IRO-001 Reliability Coordination — Responsibilities and Authorities, COM-002-2 Communication and Coordination, and TOP-001 Reliability Responsibilities and Authorities, among others. Obligations to report could also result from agreements, processes, or procedures with other parties, such as may be found in operating agreements and interconnection agreements.</p> <p>The drafting team asserts that those entities to which communicating sabotage events is appropriate would be identified by the reporting entity and documented within the procedure required in CIP-001-1 Requirement R2.</p> <p>Regarding “who within the Interconnection hierarchy deems parties to be appropriate,” the drafting team knows of no interconnection authority that has such a role.</p>



## A. Introduction

1. **Title:** **Disturbance Reporting**
2. **Number:** EOP-004-1
3. **Purpose:** Disturbances or unusual occurrences that jeopardize the operation of the Bulk Electric System, or result in system equipment damage or customer interruptions, need to be studied and understood to minimize the likelihood of similar events in the future.
4. **Applicability**
  - 4.1. Reliability Coordinators.
  - 4.2. Balancing Authorities.
  - 4.3. Transmission Operators.
  - 4.4. Generator Operators.
  - 4.5. Load Serving Entities.
  - 4.6. Regional Reliability Organizations.
5. **Effective Date:** January 1, 2007

## B. Requirements

- R1. Each Regional Reliability Organization shall establish and maintain a Regional reporting procedure to facilitate preparation of preliminary and final disturbance reports.
- R2. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall promptly analyze Bulk Electric System disturbances on its system or facilities.
- R3. A Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity experiencing a reportable incident shall provide a preliminary written report to its Regional Reliability Organization and NERC.
  - R3.1. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity shall submit within 24 hours of the disturbance or unusual occurrence either a copy of the report submitted to DOE, or, if no DOE report is required, a copy of the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report form. Events that are not identified until some time after they occur shall be reported within 24 hours of being recognized.
  - R3.2. Applicable reporting forms are provided in Attachments 1-EOP-004 and 2-EOP-004.
  - R3.3. Under certain adverse conditions, e.g., severe weather, it may not be possible to assess the damage caused by a disturbance and issue a written Interconnection Reliability Operating Limit and Preliminary Disturbance Report within 24 hours. In such cases, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall promptly notify its Regional Reliability Organization(s) and NERC, and verbally provide as much information as is available at that

time. The affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall then provide timely, periodic verbal updates until adequate information is available to issue a written Preliminary Disturbance Report.

- R3.4.** If, in the judgment of the Regional Reliability Organization, after consultation with the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity in which a disturbance occurred, a final report is required, the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity shall prepare this report within 60 days. As a minimum, the final report shall have a discussion of the events and its cause, the conclusions reached, and recommendations to prevent recurrence of this type of event. The report shall be subject to Regional Reliability Organization approval.
- R4.** When a Bulk Electric System disturbance occurs, the Regional Reliability Organization shall make its representatives on the NERC Operating Committee and Disturbance Analysis Working Group available to the affected Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, or Load Serving Entity immediately affected by the disturbance for the purpose of providing any needed assistance in the investigation and to assist in the preparation of a final report.
- R5.** The Regional Reliability Organization shall track and review the status of all final report recommendations at least twice each year to ensure they are being acted upon in a timely manner. If any recommendation has not been acted on within two years, or if Regional Reliability Organization tracking and review indicates at any time that any recommendation is not being acted on with sufficient diligence, the Regional Reliability Organization shall notify the NERC Planning Committee and Operating Committee of the status of the recommendation(s) and the steps the Regional Reliability Organization has taken to accelerate implementation.

### C. Measures

- M1.** The Regional Reliability Organization shall have and provide upon request as evidence, its current regional reporting procedure that is used to facilitate preparation of preliminary and final disturbance reports. (Requirement 1)
- M2.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load-Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, the preliminary report, computer printouts, operator logs, or other equivalent evidence that will be used to confirm that it prepared and delivered the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1.
- M3.** Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that has a reportable incident shall have and provide upon request evidence that could include, but is not limited to, operator logs, voice recordings or transcripts of voice recordings, electronic communications, or other equivalent evidence that will be used to confirm that it provided information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours. (Requirement 3.3)

## **D. Compliance**

### **1. Compliance Monitoring Process**

#### **1.1. Compliance Monitoring Responsibility**

NERC shall be responsible for compliance monitoring of the Regional Reliability Organizations.

Regional Reliability Organizations shall be responsible for compliance monitoring of Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load-serving Entities.

#### **1.2. Compliance Monitoring and Reset Time Frame**

One or more of the following methods will be used to assess compliance:

- Self-certification (Conducted annually with submission according to schedule.)
- Spot Check Audits (Conducted anytime with up to 30 days notice given to prepare.)
- Periodic Audit (Conducted once every three years according to schedule.)
- Triggered Investigations (Notification of an investigation must be made within 60 days of an event or complaint of noncompliance. The entity will have up to 30 days to prepare for the investigation. An entity may request an extension of the preparation period and the extension will be considered by the Compliance Monitor on a case-by-case basis.)

The Performance-Reset Period shall be 12 months from the last finding of non-compliance.

#### **1.3. Data Retention**

Each Regional Reliability Organization shall have its current, in-force, regional reporting procedure as evidence of compliance. (Measure 1)

Each Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and/or Load Serving Entity that is either involved in a Bulk Electric System disturbance or has a reportable incident shall keep data related to the incident for a year from the event or for the duration of any regional investigation, whichever is longer. (Measures 2 through 4)

If an entity is found non-compliant the entity shall keep information related to the noncompliance until found compliant or for two years plus the current year, whichever is longer.

Evidence used as part of a triggered investigation shall be retained by the entity being investigated for one year from the date that the investigation is closed, as determined by the Compliance Monitor,

The Compliance Monitor shall keep the last periodic audit report and all requested and submitted subsequent compliance records.

**1.4. Additional Compliance Information**

See Attachments:

- EOP-004 Disturbance Reporting Form
- Table 1 EOP-004

**2. Levels of Non-Compliance for a Regional Reliability Organization**

**2.1. Level 1:** Not applicable.

**2.2. Level 2:** Not applicable.

**2.3. Level 3:** Not applicable.

**2.4. Level 4:** No current procedure to facilitate preparation of preliminary and final disturbance reports as specified in R1.

**3. Levels of Non-Compliance for a Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator, and Load- Serving Entity:**

**3.1. Level 1:** There shall be a level one non-compliance if any of the following conditions exist:

**3.1.1** Failed to prepare and deliver the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports to NERC within 24 hours of its recognition as specified in Requirement 3.1

**3.1.2** Failed to provide disturbance information verbally as time permitted, when system conditions precluded the preparation of a report in 24 hours as specified in R3.3

**3.1.3** Failed to prepare a final report within 60 days as specified in R3.4

**3.2. Level 2:** Not applicable.

**3.3. Level 3:** Not applicable

**3.4. Level 4:** Not applicable.

**E. Regional Differences**

None identified.

**Version History**

Version	Date	Action	Change Tracking
0	April 1, 2005	Effective Date	New
0	May 23, 2005	Fixed reference to attachments 1-EOP-004-0 and 2-EOP-004-0, Changed chart title 1-FAC-004-0 to 1-EOP-004-0, Fixed title of Table 1 to read 1-EOP-004-0, and fixed font.	Errata
0	July 6, 2005	Fixed email in Attachment 1-EOP-004-0 from <a href="mailto:info@nerc.com">info@nerc.com</a> to <a href="mailto:esisac@nerc.com">esisac@nerc.com</a> .	Errata

0	July 26, 2005	Fixed Header on page 8 to read EOP-004-0	Errata
0	August 8, 2005	Removed “Proposed” from Effective Date	Errata
1	November 1, 2006	Adopted by Board of Trustees	Revised

## **Attachment 1-EOP-004 NERC Disturbance Report Form**

### **Introduction**

These disturbance reporting requirements apply to all Reliability Coordinators, Balancing Authorities, Transmission Operators, Generator Operators, and Load Serving Entities, and provide a common basis for all NERC disturbance reporting. The entity on whose system a reportable disturbance occurs shall notify NERC and its Regional Reliability Organization of the disturbance using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. Reports can be sent to NERC via email ([esisac@nerc.com](mailto:esisac@nerc.com)) by facsimile (609-452-9550) using the NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report forms. If a disturbance is to be reported to the U.S. Department of Energy also, the responding entity may use the DOE reporting form when reporting to NERC. Note: All Emergency Incident and Disturbance Reports (Schedules 1 and 2) sent to DOE shall be simultaneously sent to NERC, preferably electronically at [esisac@nerc.com](mailto:esisac@nerc.com).

The NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Reports are to be made for any of the following events:

1. The loss of a bulk power transmission component that significantly affects the integrity of interconnected system operations. Generally, a disturbance report will be required if the event results in actions such as:
  - a. Modification of operating procedures.
  - b. Modification of equipment (e.g. control systems or special protection systems) to prevent reoccurrence of the event.
  - c. Identification of valuable lessons learned.
  - d. Identification of non-compliance with NERC standards or policies.
  - e. Identification of a disturbance that is beyond recognized criteria, i.e. three-phase fault with breaker failure, etc.
  - f. Frequency or voltage going below the under-frequency or under-voltage load shed points.
2. The occurrence of an interconnected system separation or system islanding or both.
3. Loss of generation by a Generator Operator, Balancing Authority, or Load-Serving Entity — 2,000 MW or more in the Eastern Interconnection or Western Interconnection and 1,000 MW or more in the ERCOT Interconnection.
4. Equipment failures/system operational actions which result in the loss of firm system demands for more than 15 minutes, as described below:
  - a. Entities with a previous year recorded peak demand of more than 3,000 MW are required to report all such losses of firm demands totaling more than 300 MW.
  - b. All other entities are required to report all such losses of firm demands totaling more than 200 MW or 50% of the total customers being supplied immediately prior to the incident, whichever is less.
5. Firm load shedding of 100 MW or more to maintain the continuity of the bulk electric system.

6. Any action taken by a Generator Operator, Transmission Operator, Balancing Authority, or Load-Serving Entity that results in:
  - a. Sustained voltage excursions equal to or greater than  $\pm 10\%$ , or
  - b. Major damage to power system components, or
  - c. Failure, degradation, or misoperation of system protection, special protection schemes, remedial action schemes, or other operating systems that do not require operator intervention, which did result in, or could have resulted in, a system disturbance as defined by steps 1 through 5 above.
7. An Interconnection Reliability Operating Limit (IROL) violation as required in reliability standard TOP-007.
8. Any event that the Operating Committee requests to be submitted to Disturbance Analysis Working Group (DAWG) for review because of the nature of the disturbance and the insight and lessons the electricity supply and delivery industry could learn.

## NERC Interconnection Reliability Operating Limit and Preliminary Disturbance Report

Check here if this is an Interconnection Reliability Operating Limit (IROL) violation report.

1.	Organization filing report.		
2.	Name of person filing report.		
3.	Telephone number.		
4.	Date and time of disturbance. Date:(mm/dd/yy) Time/Zone:		
5.	Did the disturbance originate in your system?	Yes <input type="checkbox"/> No <input type="checkbox"/>	
6.	Describe disturbance including: cause, equipment damage, critical services interrupted, system separation, key scheduled and actual flows prior to disturbance and in the case of a disturbance involving a special protection or remedial action scheme, what action is being taken to prevent recurrence.		
7.	Generation tripped.  MW Total List generation tripped		
8.	Frequency. Just prior to disturbance (Hz): Immediately after disturbance (Hz max.): Immediately after disturbance (Hz min.):		
9.	List transmission lines tripped (specify voltage level of each line).		
10.	Demand tripped (MW): Number of affected Customers:	FIRM	INTERRUPTIBLE



	Demand lost (MW-Minutes):		
11.	Restoration time.	INITIAL	FINAL
	Transmission:		
	Generation:		
	Demand:		

## **Attachment 2-EOP-004**

### **U.S. Department of Energy Disturbance Reporting Requirements**

#### **Introduction**

The U.S. Department of Energy (DOE), under its relevant authorities, has established mandatory reporting requirements for electric emergency incidents and disturbances in the United States. DOE collects this information from the electric power industry on Form EIA-417 to meet its overall national security and Federal Energy Management Agency's Federal Response Plan (FRP) responsibilities. DOE will use the data from this form to obtain current information regarding emergency situations on U.S. electric energy supply systems. DOE's Energy Information Administration (EIA) will use the data for reporting on electric power emergency incidents and disturbances in monthly EIA reports. In addition, the data may be used to develop legislative recommendations, reports to the Congress and as a basis for DOE investigations following severe, prolonged, or repeated electric power reliability problems.

Every Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity must use this form to submit mandatory reports of electric power system incidents or disturbances to the DOE Operations Center, which operates on a 24-hour basis, seven days a week. All other entities operating electric systems have filing responsibilities to provide information to the Reliability Coordinator, Balancing Authority, Transmission Operator, Generator Operator or Load Serving Entity when necessary for their reporting obligations and to file form EIA-417 in cases where these entities will not be involved. EIA requests that it be notified of those that plan to file jointly and of those electric entities that want to file separately.

Special reporting provisions exist for those electric utilities located within the United States, but for whom Reliability Coordinator oversight responsibilities are handled by electrical systems located across an international border. A foreign utility handling U.S. Balancing Authority responsibilities, may wish to file this information voluntarily to the DOE. Any U.S.-based utility in this international situation needs to inform DOE that these filings will come from a foreign-based electric system or file the required reports themselves.

Form EIA-417 must be submitted to the DOE Operations Center if any one of the following applies (see Table 1-EOP-004-0 — Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies):

1. Uncontrolled loss of 300 MW or more of firm system load for more than 15 minutes from a single incident.
2. Load shedding of 100 MW or more implemented under emergency operational policy.
3. System-wide voltage reductions of 3 percent or more.
4. Public appeal to reduce the use of electricity for purposes of maintaining the continuity of the electric power system.
5. Actual or suspected physical attacks that could impact electric power system adequacy or reliability; or vandalism, which target components of any security system. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.

6. Actual or suspected cyber or communications attacks that could impact electric power system adequacy or vulnerability.
7. Fuel supply emergencies that could impact electric power system adequacy or reliability.
8. Loss of electric service to more than 50,000 customers for one hour or more.
9. Complete operational failure or shut-down of the transmission and/or distribution electrical system.

The initial DOE Emergency Incident and Disturbance Report (form EIA-417 – Schedule 1) shall be submitted to the DOE Operations Center within 60 minutes of the time of the system disruption. Complete information may not be available at the time of the disruption. However, provide as much information as is known or suspected at the time of the initial filing. If the incident is having a critical impact on operations, a telephone notification to the DOE Operations Center (202-586-8100) is acceptable, pending submission of the completed form EIA-417. Electronic submission via an on-line web-based form is the preferred method of notification. However, electronic submission by facsimile or email is acceptable.

An updated form EIA-417 (Schedule 1 and 2) is due within 48 hours of the event to provide complete disruption information. Electronic submission via facsimile or email is the preferred method of notification. Detailed DOE Incident and Disturbance reporting requirements can be found at: [http://www.eia.doe.gov/cneaf/electricity/page/form\\_417.html](http://www.eia.doe.gov/cneaf/electricity/page/form_417.html).

<b>Table 1-EOP-004-0</b>				
<b>Summary of NERC and DOE Reporting Requirements for Major Electric System Emergencies</b>				
<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Uncontrolled loss of Firm System Load	$\geq 300$ MW – 15 minutes or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>2</b>	Load Shedding	$\geq 100$ MW under emergency operational policy	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>3</b>	Voltage Reductions	3% or more – applied system-wide	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>4</b>	Public Appeals	Emergency conditions to reduce demand	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>5</b>	Physical sabotage, terrorism or vandalism	On physical security systems – suspected or real	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>6</b>	Cyber sabotage, terrorism or vandalism	If the attempt is believed to have or did happen	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>7</b>	Fuel supply emergencies	Fuel inventory or hydro storage levels $\leq 50\%$ of normal	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>8</b>	Loss of electric service	$\geq 50,000$ for 1 hour or more	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
<b>9</b>	Complete operation failure of electrical system	If isolated or interconnected electrical systems suffer total electrical system collapse	EIA – Sch-1 EIA – Sch-2	1 hour 48 hour
All DOE EIA-417 Schedule 1 reports are to be filed within 60-minutes after the start of an incident or disturbance				
All DOE EIA-417 Schedule 2 reports are to be filed within 48-hours after the start of an incident or disturbance				

***All entities required to file a DOE EIA-417 report (Schedule 1 & 2) shall send a copy of these reports to NERC simultaneously, but no later than 24 hours after the start of the incident or disturbance.***

<b>Incident No.</b>	<b>Incident</b>	<b>Threshold</b>	<b>Report Required</b>	<b>Time</b>
<b>1</b>	Loss of major system component	Significantly affects integrity of interconnected system operations	NERC Prelim Final report	24 hour 60 day
<b>2</b>	Interconnected system separation or system islanding	Total system shutdown Partial shutdown, separation, or islanding	NERC Prelim Final report	24 hour 60 day
<b>3</b>	Loss of generation	$\geq 2,000$ – Eastern Interconnection $\geq 2,000$ – Western Interconnection $\geq 1,000$ – ERCOT Interconnection	NERC Prelim Final report	24 hour 60 day
<b>4</b>	Loss of firm load $\geq 15$ -minutes	Entities with peak demand $\geq 3,000$ : loss $\geq 300$ MW All others $\geq 200$ MW or 50% of total demand	NERC Prelim Final report	24 hour 60 day
<b>5</b>	Firm load shedding	$\geq 100$ MW to maintain continuity of bulk system	NERC Prelim Final report	24 hour 60 day
<b>6</b>	System operation or operation actions resulting in:	<ul style="list-style-type: none"> <li>• Voltage excursions <math>\geq 10\%</math></li> <li>• Major damage to system components</li> <li>• Failure, degradation, or misoperation of SPS</li> </ul>	NERC Prelim Final report	24 hour 60 day
<b>7</b>	IROL violation	Reliability standard TOP-007.	NERC Prelim Final report	72 hour 60 day
<b>8</b>	As requested by ORS Chairman	Due to nature of disturbance & usefulness to industry (lessons learned)	NERC Prelim Final report	24 hour 60 day

All NERC Operating Security Limit and Preliminary Disturbance reports will be filed within 24 hours after the start of the incident. If an entity must file a DOE EIA-417 report on an incident, which requires a NERC Preliminary report, the Entity may use the DOE EIA-417 form for both DOE and NERC reports.

***Any entity reporting a DOE or NERC incident or disturbance has the responsibility to also notify its Regional Reliability Organization.***

# Standards Announcement

## Project 2009-01 Disturbance and Sabotage Reporting

Recirculation Ballot and Non-Binding Poll Open Through 8 p.m. Friday,  
November 2, 2012

### Now Available

A recirculation ballot of **EOP-004-2 – Event Reporting** and a non-binding poll of the associated VRFs/VSLs is open through **8 p.m. Eastern on Friday, November 2, 2012**

After considering stakeholder comments from the formal comment period and successive ballot that ended on September 27, 2012, the drafting team made no substantive changes to the Requirements of the standard, but did make a clarifying change to Requirement R2 concerning the 24-hour reporting obligation to provide flexibility for support staff to assist with after-the-fact reporting. In addition, the team provided clarification in the Guideline and Technical Basis concerning how the standard is intended to apply to Distribution Providers who do not own BES Facilities, and to clarify that entities registered for multiple functions will only need to submit a single report of an individual event.

Finally, in response to stakeholder comments, the drafting team has revised the VSLs for Requirement R1 to provide gradation in the VSL for failure to incorporate one or more event types in the entity's Operating Plan. **NOTE: Although the drafting team was not required to conduct an additional non-binding poll of the VSLs, they would like to gauge industry support for the VSLs as modified, and therefore, a non-binding poll of the VRFs and VSLs is being conducted in conjunction with the recirculation ballot.**

### **Instructions**

In the recirculation ballot, votes are counted by exception. Only members of the ballot pool may cast a ballot; all ballot pool members may change their previously cast votes. A ballot pool member who failed to cast a ballot during the last ballot window may cast a ballot in the recirculation ballot window. If a ballot pool member does not participate in the recirculation ballot, that member's vote cast in the previous ballot will be carried over as that member's vote in the recirculation ballot.

Members of the ballot pools associated with this project may log in and submit their votes and opinions for the standard and VSL changes by clicking [here](#).

**Next Steps**

The drafting team plans to submit EOP-004-2 to the Board of Trustees for adoption in November and then file the adopted standard with the appropriate regulatory authorities.

**Background**

The DSR SDT has developed EOP-004-2 to replace the current mandatory and enforceable EOP-004-1 and CIP-001-1a standards. The reporting obligations under EOP-004-2 serve to provide input to the NERC Events Analysis Program. Analysis of events is not required under the proposed standard and any analysis or investigation will fall under the Event Analysis Program under the NERC Rules of Procedure.

Additional information is available on the [project page](#).

**Standards Process**

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.

*For more information or assistance, please contact Monica Benson,  
Standards Development Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd. NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)

# Standards Announcement

## Project 2009-01 Disturbance and Sabotage Reporting

### Recirculation Ballot and Non-Binding Poll Results

#### [Now Available](#)

A recirculation ballot of **EOP-004-2 – Event Reporting** and a non-binding poll of the associated VRFs/VSLs concluded on Monday, November 5, 2012.

Voting statistics for each ballot are listed below, and the [Ballots Results](#) page provides a link to the detailed results.

Approval	Non-binding Poll Results
Quorum: 85.14%	Quorum: 78.93%
Approval: 71.39%	Supportive Opinions: 71.04%

#### Next Steps

The standard will be presented to the Board of Trustees for adoption and then filed with the appropriate regulatory authorities.

#### Background

The DSR SDT has developed EOP-004-2 to replace the current mandatory and enforceable EOP-004-1 and CIP-001-2a standards. The reporting obligations under EOP-004-2 serve to provide input to the NERC Events Analysis Program. Analysis of events is not required under the proposed standard and any analysis or investigation will fall under the Event Analysis Program under the NERC Rules of Procedure.

Additional information is available on the [project page](#).

#### Standards Process

The [Standard Processes Manual](#) contains all the procedures governing the standards development process. The success of the NERC standards development process depends on stakeholder participation. We extend our thanks to all those who participate.



*For more information or assistance, please contact Monica Benson,  
Standards Development Administrator, at [monica.benson@nerc.net](mailto:monica.benson@nerc.net) or at 404-446-2560.*

North American Electric Reliability Corporation  
3353 Peachtree Rd. NE  
Suite 600, North Tower  
Atlanta, GA 30326  
404-446-2560 | [www.nerc.com](http://www.nerc.com)

User Name

Password

Log in

Register

- Ballot Pools
- Current Ballots
- Ballot Results
- Registered Ballot Body
- Proxy Voters

Home Page

Ballot Results	
<b>Ballot Name:</b>	Project 2009-01 DSR Recirculation Ballot October 2012_in
<b>Ballot Period:</b>	10/24/2012 - 11/5/2012
<b>Ballot Type:</b>	Initial
<b>Total # Votes:</b>	361
<b>Total Ballot Pool:</b>	424
<b>Quorum:</b>	<b>85.14 % The Quorum has been reached</b>
<b>Weighted Segment Vote:</b>	71.39 %
<b>Ballot Results:</b>	<b>The Standard has Passed</b>

Summary of Ballot Results									
Segment	Ballot Pool	Segment Weight	Affirmative		Negative		Abstain # Votes	No Vote	
			# Votes	Fraction	# Votes	Fraction			
1 - Segment 1.	104	1	57	0.704	24	0.296	9	14	
2 - Segment 2.	11	0.8	4	0.4	4	0.4	2	1	
3 - Segment 3.	108	1	58	0.674	28	0.326	8	14	
4 - Segment 4.	37	1	22	0.759	7	0.241	3	5	
5 - Segment 5.	91	1	53	0.757	17	0.243	6	15	
6 - Segment 6.	53	1	30	0.789	8	0.211	5	10	
7 - Segment 7.	0	0	0	0	0	0	0	0	
8 - Segment 8.	8	0.7	6	0.6	1	0.1	0	1	
9 - Segment 9.	4	0.3	2	0.2	1	0.1	0	1	
10 - Segment 10.	8	0.6	4	0.4	2	0.2	0	2	
<b>Totals</b>	<b>424</b>	<b>7.4</b>	<b>236</b>	<b>5.283</b>	<b>92</b>	<b>2.117</b>	<b>33</b>	<b>63</b>	

Individual Ballot Pool Results				
Segment	Organization	Member	Ballot	Comments
1	Ameren Services	Kirit Shah	Negative	
1	American Electric Power	Paul B. Johnson		
1	American Transmission Company, LLC	Andrew Z Pusztai	Affirmative	
1	Arizona Public Service Co.	Robert Smith	Affirmative	
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative	
1	Austin Energy	James Armke	Affirmative	
1	Avista Corp.	Scott J Kinney	Affirmative	
1	Balancing Authority of Northern California	Kevin Smith	Affirmative	

1	Baltimore Gas & Electric Company	Gregory S Miller	Affirmative
1	BC Hydro and Power Authority	Patricia Robertson	Abstain
1	Beaches Energy Services	Joseph S Stonecipher	Negative
1	Black Hills Corp	Eric Egge	
1	Bonneville Power Administration	Donald S. Watkins	Affirmative
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey	Negative
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Negative
1	Central Maine Power Company	Joseph Turano Jr.	Affirmative
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Affirmative
1	Clark Public Utilities	Jack Stamper	Negative
1	Colorado Springs Utilities	Paul Morland	Affirmative
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Affirmative
1	CPS Energy	Richard Castrejana	Affirmative
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative
1	Dayton Power & Light Co.	Hertzel Shamash	
1	Deseret Power	James Tucker	
1	Dominion Virginia Power	Michael S Crowley	Negative
1	Duke Energy Carolina	Douglas E. Hils	Negative
1	East Kentucky Power Coop.	George S. Carruba	Negative
1	Empire District Electric Co.	Ralph F Meyer	Affirmative
1	Entergy Services, Inc.	Edward J Davis	
1	FirstEnergy Corp.	William J Smith	Affirmative
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton	Affirmative
1	Florida Power & Light Co.	Mike O'Neil	Negative
1	Gainesville Regional Utilities	Luther E. Fair	
1	Georgia Transmission Corporation	Jason Snodgrass	Affirmative
1	Grand River Dam Authority	James M Stafford	Affirmative
1	Great River Energy	Gordon Pietsch	Negative
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Negative
1	Hydro One Networks, Inc.	Ajay Garg	Negative
1	Hydro-Quebec TransEnergie	Bernard Pelletier	Affirmative
1	Idaho Power Company	Ronald D Schellberg	
1	Imperial Irrigation District	Tino Zaragoza	Abstain
1	International Transmission Company Holdings Corp	Michael Moltane	Affirmative
1	JEA	Ted Hobson	Affirmative
1	Kansas City Power & Light Co.	Michael Gammon	
1	Keys Energy Services	Stanley T Rzad	Affirmative
1	Lakeland Electric	Larry E Watt	Affirmative
1	Lee County Electric Cooperative	John W Delucca	Affirmative
1	Lincoln Electric System	Doug Bantam	Affirmative
1	Los Angeles Department of Water & Power	Ly M Le	
1	Lower Colorado River Authority	Martyn Turner	Affirmative
1	Manitoba Hydro	Joe D Petaski	Negative
1	MEAG Power	Danny Dees	Affirmative
1	MidAmerican Energy Co.	Terry Harbour	Affirmative
1	Minnkota Power Coop. Inc.	Richard Burt	Affirmative
1	National Grid	Saurabh Saksena	Affirmative
1	Nebraska Public Power District	Cole C Brodine	Negative
1	New Brunswick Power Transmission Corporation	Randy MacDonald	Negative
1	New York Power Authority	Arnold J. Schuff	Affirmative
1	New York State Electric & Gas Corp.	Raymond P Kinney	
1	Northeast Utilities	David Boguslawski	Abstain
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative
1	NorthWestern Energy	John Canavan	Abstain
1	Ohio Valley Electric Corp.	Robert Matthey	Negative
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Negative
1	Omaha Public Power District	Doug Peterchuck	Affirmative
1	Oncor Electric Delivery	Brenda Pulis	Negative
1	Orlando Utilities Commission	Brad Chase	Abstain
1	PacifiCorp	Ryan Millard	Affirmative
1	PECO Energy	Ronald Schloendorn	Abstain
1	Platte River Power Authority	John C. Collins	Affirmative
1	Portland General Electric Co.	John T Walker	Affirmative
1	Potomac Electric Power Co.	David Thorne	Affirmative

1	PowerSouth Energy Cooperative	Larry D Avery	Affirmative
1	PPL Electric Utilities Corp.	Brenda L Truhe	Affirmative
1	Progress Energy Carolinas	Brett A. Koelsch	Abstain
1	Public Service Company of New Mexico	Laurie Williams	Abstain
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Affirmative
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel	Affirmative
1	Public Utility District No. 2 of Grant County	Kyle M. Hussey	
1	Puget Sound Energy, Inc.	Denise M Lietz	Negative
1	Raj Rana	Rajendrasinh D Rana	Abstain
1	Rochester Gas and Electric Corp.	John C. Allen	Affirmative
1	Sacramento Municipal Utility District	Tim Kelley	Affirmative
1	Salmon River Electric Cooperative	Kathryn J Spence	Affirmative
1	Salt River Project	Robert Kondziolka	Affirmative
1	Santee Cooper	Terry L Blackwell	Negative
1	SCE&G	Henry Delk, Jr.	
1	Seattle City Light	Pawel Krupa	Affirmative
1	Sho-Me Power Electric Cooperative	Denise Stevens	Affirmative
1	Sierra Pacific Power Co.	Rich Salgo	Affirmative
1	Snohomish County PUD No. 1	Long T Duong	Affirmative
1	South California Edison Company	Steven Mavis	Negative
1	Southern Company Services, Inc.	Robert A. Schaffeld	Negative
1	Southern Illinois Power Coop.	William Hutchison	Negative
1	Southwest Transmission Cooperative, Inc.	James Jones	Affirmative
1	Sunflower Electric Power Corporation	Noman Lee Williams	Affirmative
1	Tampa Electric Co.	Beth Young	
1	Tennessee Valley Authority	Larry G Akens	Affirmative
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative
1	Tucson Electric Power Co.	John Tolo	
1	United Illuminating Co.	Jonathan Appelbaum	Affirmative
1	Westar Energy	Allen Klassen	Negative
1	Western Area Power Administration	Brandy A Dunn	Affirmative
1	Xcel Energy, Inc.	Gregory L Pieper	Affirmative
2	Alberta Electric System Operator	Mark B Thompson	Affirmative
2	BC Hydro	Venkataramakrishnan Vinnakota	Abstain
2	California ISO	Rich Vine	Abstain
2	Electric Reliability Council of Texas, Inc.	Charles B Manning	Affirmative
2	Independent Electricity System Operator	Barbara Constantinescu	Affirmative
2	ISO New England, Inc.	Kathleen Goodman	Negative
2	Midwest ISO, Inc.	Marie Knox	Affirmative
2	New Brunswick System Operator	Alden Briggs	Negative
2	New York Independent System Operator	Gregory Campoli	
2	PJM Interconnection, L.L.C.	Tom Bowe	Negative
2	Southwest Power Pool, Inc.	Charles H. Yeung	Negative
3	AEP	Michael E DeLoach	Negative
3	Alabama Power Company	Richard J. Mandes	Negative
3	Alameda Municipal Power	Douglas Draeger	Affirmative
3	Ameren Services	Mark Peters	Negative
3	American Public Power Association	Nathan Mitchell	Affirmative
3	Anaheim Public Utilities Dept.	Kelly Nguyen	
3	APS	Steven Norris	Affirmative
3	Arkansas Electric Cooperative Corporation	Philip Huff	Affirmative
3	Atlantic City Electric Company	NICOLE BUCKMAN	Affirmative
3	BC Hydro and Power Authority	Pat G. Harrington	Abstain
3	Blachly-Lane Electric Co-op	Bud Tracy	Negative
3	Bonneville Power Administration	Rebecca Berdahl	Affirmative
3	Central Electric Cooperative, Inc. (Redmond, Oregon)	Dave Markham	Negative
3	Central Lincoln PUD	Steve Alexanderson	Affirmative
3	City of Alexandria	Michael Marcotte	
3	City of Austin dba Austin Energy	Andrew Gallo	Affirmative
3	City of Bartow, Florida	Matt Culverhouse	
3	City of Clewiston	Lynne Mila	Affirmative
3	City of Farmington	Linda R Jacobson	Affirmative
3	City of Garland	Ronnie C Hoeinghaus	Abstain
3	City of Green Cove Springs	Gregg R Griffin	Affirmative
3	City of Palo Alto	Eric R Scott	Affirmative


3	City of Redding	Bill Hughes	Affirmative	
3	Clatskanie People's Utility District	Brian Fawcett		
3	Clearwater Power Co.	Dave Hagen	Negative	
3	Cleco Corporation	Michelle A Corley	Affirmative	
3	Colorado Springs Utilities	Charles Morgan	Affirmative	
3	ComEd	Bruce Krawczyk	Affirmative	
3	Consolidated Edison Co. of New York	Peter T Yost	Affirmative	
3	Constellation Energy	CJ Ingersoll	Abstain	
3	Consumers Energy	Richard Blumenstock	Affirmative	
3	Consumers Power Inc.	Roman Gillen	Negative	
3	Coos-Curry Electric Cooperative, Inc	Roger Meader	Negative	
3	Cowlitz County PUD	Russell A Noble	Negative	
3	CPS Energy	Jose Escamilla	Affirmative	
3	Delmarva Power & Light Co.	Michael R. Mayer	Affirmative	
3	Detroit Edison Company	Kent Kujala	Negative	
3	Dominion Resources Services	Michael F. Gildea	Negative	
3	Duke Energy Carolina	Henry Ernst-Jr	Abstain	
3	Entergy	Joel T Plessinger	Affirmative	
3	Fall River Rural Electric Cooperative	Bryan Case	Negative	
3	FirstEnergy Energy Delivery	Stephan Kern	Affirmative	
3	Florida Municipal Power Agency	Joe McKinney	Affirmative	
3	Florida Power Corporation	Lee Schuster	Negative	
3	Georgia Power Company	Anthony L Wilson	Negative	
3	Georgia Systems Operations Corporation	William N. Phinney	Affirmative	
3	Grays Harbor PUD	Wesley W Gray	Affirmative	
3	Great River Energy	Brian Glover	Negative	
3	Gulf Power Company	Paul C Caldwell	Negative	
3	Hydro One Networks, Inc.	David Kiguel	Negative	
3	Imperial Irrigation District	Jesus S. Alcaraz	Abstain	
3	JEA	Garry Baker		
3	Kansas City Power & Light Co.	Charles Locke	Affirmative	
3	Kissimmee Utility Authority	Gregory D Woessner	Affirmative	
3	Kootenai Electric Cooperative	Dave Kahly	Abstain	
3	Lakeland Electric	Norman D Harryhill		
3	Lane Electric Cooperative, Inc.	Rick Crinklaw	Negative	
3	Lincoln Electric System	Jason Fortik	Affirmative	
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Affirmative	
3	Louisville Gas and Electric Co.	Charles A. Freibert	Affirmative	
3	Manitoba Hydro	Greg C. Parent	Negative	
3	Manitowoc Public Utilities	Thomas E Reed	Affirmative	
3	MidAmerican Energy Co.	Thomas C. Mielnik	Affirmative	
3	Mississippi Power	Jeff Franklin	Negative	
3	Modesto Irrigation District	Jack W Savage	Affirmative	
3	Municipal Electric Authority of Georgia	Steven M. Jackson	Affirmative	
3	Muscatine Power & Water	John S Bos	Affirmative	
3	Nebraska Public Power District	Tony Eddleman	Negative	
3	New York Power Authority	Marilyn Brown	Affirmative	
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Affirmative	
3	North Carolina Electric Membership Corp.	Doug White	Affirmative	
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative	
3	Northern Lights Inc.	Jon Shelby	Negative	
3	Ocala Electric Utility	David Anderson	Affirmative	
3	Old Dominion Electric Coop.	Bill Watson		
3	Orange and Rockland Utilities, Inc.	David Burke	Affirmative	
3	Orlando Utilities Commission	Ballard K Mutters	Affirmative	
3	Owensboro Municipal Utilities	Thomas T Lyons	Negative	
3	Pacific Gas and Electric Company	John H Hagen	Affirmative	
3	PacifiCorp	Dan Zollner	Affirmative	
3	Platte River Power Authority	Terry L Baker	Affirmative	
3	PNM Resources	Michael Mertz	Abstain	
3	Potomac Electric Power Co.	Robert Reuter	Affirmative	
3	Progress Energy Carolinas	Sam Waters		
3	Public Service Electric and Gas Co.	Jeffrey Mueller		
3	Public Utility District No. 1 of Benton County	Gloria Bender	Affirmative	
3	Public Utility District No. 1 of Clallam County	David Proebstel		
3	Puget Sound Energy, Inc.	Erin Apperson	Negative	
3	Raft River Rural Electric Cooperative	Heber Carpenter	Negative	

3	Rutherford EMC	Thomas M Haire	Affirmative
3	Sacramento Municipal Utility District	James Leigh-Kendall	Affirmative
3	Salt River Project	John T. Underhill	Affirmative
3	Santee Cooper	James M Poston	Negative
3	Seattle City Light	Dana Wheelock	Affirmative
3	Seminole Electric Cooperative, Inc.	James R Frauen	Affirmative
3	Snohomish County PUD No. 1	Mark Oens	Affirmative
3	South Carolina Electric & Gas Co.	Hubert C Young	
3	Southern California Edison Co.	David B Coher	
3	Southern Maryland Electric Coop.	Mark R Jones	
3	Tacoma Public Utilities	Travis Metcalfe	Affirmative
3	Tampa Electric Co.	Ronald L. Donahey	
3	Tennessee Valley Authority	Ian S Grant	Affirmative
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative
3	Umatilla Electric Cooperative	Steve Eldrige	Negative
3	Westar Energy	Bo Jones	Negative
3	Wisconsin Electric Power Marketing	James R Keller	Affirmative
3	Wisconsin Public Service Corp.	Gregory J Le Grave	Abstain
3	Xcel Energy, Inc.	Michael Ibold	Affirmative
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative
4	American Municipal Power	Kevin Koloini	Negative
4	Arkansas Electric Cooperative Corporation	Ronnie Frizzell	
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative
4	Central Lincoln PUD	Shamus J Gamache	Negative
4	City of Austin dba Austin Energy	Reza Ebrahimian	Affirmative
4	City of Clewiston	Kevin McCarthy	Affirmative
4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	Affirmative
4	City of Redding	Nicholas Zettel	Affirmative
4	City Utilities of Springfield, Missouri	John Allen	Affirmative
4	Consumers Energy	David Frank Ronk	Affirmative
4	Cowlitz County PUD	Rick Syring	Negative
4	Detroit Edison Company	Daniel Herring	Negative
4	Flathead Electric Cooperative	Russ Schneider	Negative
4	Florida Municipal Power Agency	Frank Gaffney	Affirmative
4	Fort Pierce Utilities Authority	Thomas Richards	
4	Georgia System Operations Corporation	Guy Andrews	Affirmative
4	Illinois Municipal Electric Agency	Bob C. Thomas	Affirmative
4	Imperial Irrigation District	Diana U Torres	
4	Indiana Municipal Power Agency	Jack Alvey	Affirmative
4	Integrus Energy Group, Inc.	Christopher Plante	Abstain
4	LaGen	Richard Comeaux	Abstain
4	Madison Gas and Electric Co.	Joseph DePoorter	Affirmative
4	North Carolina Electric Membership Corp.	Bob Beadle	Affirmative
4	Northern California Power Agency	Tracy R Bibb	
4	Ohio Edison Company	Douglas Hohlbaugh	Affirmative
4	Oklahoma Municipal Power Authority	Ashley Stringer	Affirmative
4	Pacific Northwest Generating Cooperative	Aleka K Scott	Negative
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Affirmative
4	Sacramento Municipal Utility District	Mike Ramirez	Affirmative
4	Seattle City Light	Hao Li	Affirmative
4	South Mississippi Electric Power Association	Steven McElhaney	
4	Tacoma Public Utilities	Keith Morisette	Affirmative
4	West Oregon Electric Cooperative, Inc.	Marc M Farmer	Negative
4	White River Electric Association Inc.	Frank L. Sampson	Abstain
4	Wisconsin Energy Corp.	Anthony Jankowski	Affirmative
5	AEP Service Corp.	Brock Ondayko	Negative
5	AES Corporation	Leo Bernier	Affirmative
5	Amerenue	Sam Dwyer	Negative
5	Arizona Public Service Co.	Edward Cambridge	Affirmative
5	Avista Corp.	Edward F. Groce	Affirmative
5	BC Hydro and Power Authority	Clement Ma	Abstain
5	Black Hills Corp	George Tatar	Affirmative
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla	Abstain
5	Bonneville Power Administration	Francis J. Halpin	Affirmative

5	BrightSource Energy, Inc.	Chifong Thomas	Abstain	
5	Caithness Long Island, LLC	Jason M Moore		
5	Chelan County Public Utility District #1	John Yale		
5	City and County of San Francisco	Daniel Mason	Negative	
5	City of Austin dba Austin Energy	Jeanie Doty	Affirmative	
5	City of Redding	Paul A. Cummings	Affirmative	
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick	Affirmative	
5	City of Tallahassee	Brian Horton		
5	City Water, Light & Power of Springfield	Steve Rose	Affirmative	
5	Cogentrix Energy, Inc.	Mike D Hirst	Affirmative	
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative	
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Affirmative	
5	Constellation Power Source Generation, Inc.	Amir Y Hammad	Affirmative	
5	Consumers Energy Company	David C Greyerbiehl	Affirmative	
5	Cowlitz County PUD	Bob Essex	Negative	
5	CPS Energy	Robert Stevens	Affirmative	
5	Detroit Edison Company	Christy Wicke	Negative	
5	Dominion Resources, Inc.	Mike Garton	Negative	
5	Duke Energy	Dale Q Goodwine	Negative	
5	Dynegy Inc.	Dan Roethemeyer	Affirmative	
5	E.ON Climate & Renewables North America, LLC	Dana Showalter		
5	Edison Mission Energy	Ellen Oswald		
5	Electric Power Supply Association	John R Cashin	Abstain	
5	Exelon Nuclear	Michael Korchynsky	Abstain	
5	ExxonMobil Research and Engineering	Martin Kaufman		
5	FirstEnergy Solutions	Kenneth Dresner	Affirmative	
5	Florida Municipal Power Agency	David Schumann	Affirmative	
5	Great River Energy	Preston L Walsh	Negative	
5	Green Country Energy	Greg Froehling		
5	Imperial Irrigation District	Marcela Y Caballero		
5	Indeck Energy Services, Inc.	Rex A Roehl		
5	JEA	John J Babik	Affirmative	
5	Kissimmee Utility Authority	Mike Blough	Affirmative	
5	Lakeland Electric	James M Howard	Affirmative	
5	Liberty Electric Power LLC	Daniel Duff	Negative	
5	Lincoln Electric System	Dennis Florom	Affirmative	
5	Los Angeles Department of Water & Power	Kenneth Silver	Affirmative	
5	Lower Colorado River Authority	Tom Foreman	Affirmative	
5	Luminant Generation Company LLC	Mike Laney	Affirmative	
5	Manitoba Hydro	S N Fernando	Negative	
5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Affirmative	
5	MEAG Power	Steven Grego	Affirmative	
5	MidAmerican Energy Co.	Christopher Schneider		
5	Muscatine Power & Water	Mike Avesing	Affirmative	
5	Nebraska Public Power District	Don Schmit	Negative	
5	New York Power Authority	Gerald Mannarino	Affirmative	
5	NextEra Energy	Allen D Schriver	Negative	
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Affirmative	
5	Northern California Power Agency	Hari Modi		
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative	
5	Occidental Chemical	Michelle R DAntuono	Affirmative	
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative	
5	Orlando Utilities Commission	Richard K Kinias	Affirmative	
5	Pacific Gas and Electric Company	Richard J. Padilla	Affirmative	
5	PacifiCorp	Sandra L. Shaffer	Affirmative	
5	Platte River Power Authority	Roland Thiel	Affirmative	
5	Portland General Electric Co.	Gary L Tingley	Affirmative	
5	PowerSouth Energy Cooperative	Tim Hattaway	Negative	
5	PPL Generation LLC	Annette M Bannon	Affirmative	
5	Progress Energy Carolinas	Wayne Lewis		
5	PSEG Fossil LLC	Tim Kucey	Affirmative	
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative	
5	Puget Sound Energy, Inc.	Tom Flynn	Affirmative	
5	Sacramento Municipal Utility District	Bethany Hunter	Affirmative	
5	Salt River Project	William Alkema	Affirmative	

5	Santee Cooper	Lewis P Pierce	Negative	
5	Seattle City Light	Michael J. Haynes	Affirmative	
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins	Affirmative	
5	Siemens PTI	Edwin Cano		
5	Snohomish County PUD No. 1	Sam Niefeld	Affirmative	
5	South Mississippi Electric Power Association	Jerry W Johnson		
5	Southern California Edison Co.	Denise Yaffe	Negative	
5	Southern Company Generation	William D Shultz	Negative	
5	Tampa Electric Co.	RJames Rocha	Affirmative	
5	Tenaska, Inc.	Scott M. Helyer	Affirmative	
5	Tennessee Valley Authority	David Thompson	Affirmative	
5	Tri-State G & T Association, Inc.	Barry Ingold	Affirmative	
5	U.S. Army Corps of Engineers	Melissa Kurtz	Affirmative	
5	Vandolah Power Company L.L.C.	Douglas A. Jensen		
5	Wisconsin Electric Power Co.	Linda Horn	Affirmative	
5	Wisconsin Public Service Corp.	Leonard Rentmeester	Abstain	
5	Xcel Energy, Inc.	Liam Noailles	Affirmative	
6	ACES Power Marketing	Jason L Marshall	Abstain	
6	AEP Marketing	Edward P. Cox	Negative	
6	Ameren Energy Marketing Co.	Jennifer Richardson	Negative	
6	APS	Randy A. Young	Affirmative	
6	Arkansas Electric Cooperative Corporation	Keith Sugg		
6	Bonneville Power Administration	Brenda S. Anderson	Affirmative	
6	City of Austin dba Austin Energy	Lisa L Martin	Affirmative	
6	City of Redding	Marvin Briggs	Affirmative	
6	Cleco Power LLC	Robert Hirschak	Affirmative	
6	Colorado Springs Utilities	Lisa C Rosintoski		
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Affirmative	
6	Constellation Energy Commodities Group	Brenda L Powell	Affirmative	
6	Dominion Resources, Inc.	Louis S. Slade	Negative	
6	Duke Energy Carolina	Walter Yeager		
6	Entergy Services, Inc.	Terri F Benoit	Affirmative	
6	Exelon Power Team	Pulin Shah	Abstain	
6	FirstEnergy Solutions	Kevin Querry	Affirmative	
6	Florida Municipal Power Agency	Richard L. Montgomery	Affirmative	
6	Florida Municipal Power Pool	Thomas Washburn	Affirmative	
6	Florida Power & Light Co.	Silvia P. Mitchell	Abstain	
6	Imperial Irrigation District	Cathy Bretz	Abstain	
6	Kansas City Power & Light Co.	Jessica L Klinghoffer	Affirmative	
6	Lakeland Electric	Paul Shipps	Affirmative	
6	Lincoln Electric System	Eric Ruskamp	Affirmative	
6	Los Angeles Department of Water & Power	Brad Packer		
6	Luminant Energy	Brad Jones	Affirmative	
6	Manitoba Hydro	Daniel Prowse	Negative	
6	MidAmerican Energy Co.	Dennis Kimm	Negative	
6	New York Power Authority	William Palazzo	Affirmative	
6	North Carolina Municipal Power Agency #1	Matthew Schull	Affirmative	
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative	
6	Omaha Public Power District	David Ried	Affirmative	
6	Orlando Utilities Commission	Claston Augustus Sunanon		
6	PacifiCorp	Scott L Smith	Affirmative	
6	Platte River Power Authority	Carol Ballantine	Affirmative	
6	PPL EnergyPlus LLC	Mark A Heimbach		
6	Progress Energy	John T Sturgeon		
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Affirmative	
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen		
6	Sacramento Municipal Utility District	Diane Enderby	Affirmative	
6	Salt River Project	Steven J Hulet	Affirmative	
6	Santee Cooper	Michael Brown	Negative	
6	Seattle City Light	Dennis Sismaet	Affirmative	
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak		
6	Snohomish County PUD No. 1	William T Moojen	Affirmative	
6	South California Edison Company	Lujuanna Medina	Abstain	
6	Southern Company Generation and Energy Marketing	John J. Ciza	Negative	
6	Tacoma Public Utilities	Michael C Hill	Affirmative	
6	Tampa Electric Co.	Benjamin F Smith II		





6	Tennessee Valley Authority	Marjorie S. Parsons	Affirmative
6	Westar Energy	Grant L Wilkerson	Negative
6	Western Area Power Administration - UGP Marketing	Peter H Kinney	Affirmative
6	Xcel Energy, Inc.	David F Lemmons	Affirmative
8		Edward C Stein	Affirmative
8		Roger C Zaklukiewicz	Affirmative
8		James A Maenner	Affirmative
8	JDRJC Associates	Jim Cyrulewski	Affirmative
8	Pacific Northwest Generating Cooperative	Margaret Ryan	Negative
8	Power Energy Group LLC	Peggy Abbadini	
8	Utility Services, Inc.	Brian Evans-Mongeon	Affirmative
8	Volkman Consulting, Inc.	Terry Volkman	Affirmative
9	California Energy Commission	William M Chamberlain	
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	Negative
9	National Association of Regulatory Utility Commissioners	Diane J. Barney	Affirmative
9	New York State Department of Public Service	Thomas G. Dvorsky	Affirmative
10	Midwest Reliability Organization	James D Burley	
10	New York State Reliability Council	Alan Adamson	
10	Northeast Power Coordinating Council	Guy V. Zito	Negative
10	ReliabilityFirst Corporation	Anthony E Jablonski	Affirmative
10	SERC Reliability Corporation	Carter B. Edge	Affirmative
10	Southwest Power Pool RE	Emily Pannel	Negative
10	Texas Reliability Entity, Inc.	Donald G Jones	Affirmative
10	Western Electricity Coordinating Council	Steven L. Rueckert	Affirmative

[Legal and Privacy](#)

404.446.2560 voice : 404.446.2595 fax

Atlanta Office: 3353 Peachtree Road, N.E. : Suite 600, North Tower : Atlanta, GA 30326

Washington Office: 1325 G Street, N.W. : Suite 600 : Washington, DC 20005-3801

[Account Log-In/Register](#)

Copyright © 2012 by the North American Electric Reliability Corporation. : All rights reserved.  
A New Jersey Nonprofit Corporation

# Non-binding Poll Results

Project 2009-01

Non-binding Poll Results	
<b>Non-binding Poll Name:</b>	Project 2009-01 Non-binding Poll DSR
<b>Poll Period:</b>	10/24/2012 - 11/5/2012
<b>Total # Opinions:</b>	311
<b>Total Ballot Pool:</b>	394
<b>Summary Results:</b>	78.93% of those who registered to participate provided an opinion for an abstention; 71.04% of those who provided an opinion indicated support for the VRFs and VSLs.

Individual Ballot Pool Results				
Segment	Organization	Member	Opinions	Comments
1	Ameren Services	Kirit Shah	Abstain	
1	American Electric Power	Paul B. Johnson		
1	American Transmission Company, LLC	Andrew Z Pusztai	Abstain	
1	Arizona Public Service Co.	Robert Smith	Affirmative	
1	Associated Electric Cooperative, Inc.	John Bussman	Affirmative	
1	Avista Corp.	Scott J Kinney	Affirmative	
1	Balancing Authority of Northern California	Kevin Smith	Abstain	
1	Baltimore Gas & Electric Company	Gregory S Miller		
1	BC Hydro and Power Authority	Patricia Robertson	Abstain	
1	Beaches Energy Services	Joseph S Stonecipher	Negative	
1	Black Hills Corp	Eric Egge		
1	Bonneville Power Administration	Donald S. Watkins	Affirmative	
1	Brazos Electric Power Cooperative, Inc.	Tony Kroskey	Negative	
1	CenterPoint Energy Houston Electric, LLC	John Brockhan	Abstain	
1	Central Maine Power Company	Joseph Turano Jr.	Affirmative	
1	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Chang G Choi	Affirmative	
1	Clark Public Utilities	Jack Stamper	Negative	
1	Colorado Springs Utilities	Paul Morland	Affirmative	
1	Consolidated Edison Co. of New York	Christopher L de Graffenried	Affirmative	
1	CPS Energy	Richard Castrejana	Affirmative	
1	Dairyland Power Coop.	Robert W. Roddy	Affirmative	
1	Dayton Power & Light Co.	Hertzel Shamash		
1	Deseret Power	James Tucker		
1	Dominion Virginia Power	Michael S Crowley	Abstain	
1	Duke Energy Carolina	Douglas E. Hills	Negative	
1	East Kentucky Power Coop.	George S. Carruba	Negative	
1	Empire District Electric Co.	Ralph F Meyer	Affirmative	

1	Entergy Services, Inc.	Edward J Davis		
1	FirstEnergy Corp.	William J Smith	Affirmative	
1	Florida Keys Electric Cooperative Assoc.	Dennis Minton	Negative	
1	Florida Power & Light Co.	Mike O'Neil	Negative	
1	Gainesville Regional Utilities	Luther E. Fair		
1	Georgia Transmission Corporation	Jason Snodgrass	Affirmative	
1	Grand River Dam Authority	James M Stafford	Affirmative	
1	Great River Energy	Gordon Pietsch	Negative	
1	Hoosier Energy Rural Electric Cooperative, Inc.	Bob Solomon	Negative	
1	Hydro One Networks, Inc.	Ajay Garg	Abstain	
1	Hydro-Quebec TransEnergie	Bernard Pelletier	Affirmative	
1	Idaho Power Company	Ronald D. Schellberg		
1	Imperial Irrigation District	Tino Zaragoza	Abstain	
1	International Transmission Company Holdings Corp	Michael Moltane	Abstain	
1	JEA	Ted Hobson	Affirmative	
1	Kansas City Power & Light Co.	Michael Gammon		
1	Keys Energy Services	Stanley T Rzac	Affirmative	
1	Lakeland Electric	Larry E Watt	Affirmative	
1	Lee County Electric Cooperative	John W Delucca	Affirmative	
1	Lincoln Electric System	Doug Bantam	Affirmative	
1	Los Angeles Department of Water & Power	Ly M Le		
1	Lower Colorado River Authority	Martyn Turner	Affirmative	
1	Manitoba Hydro	Joe D Petaski	Negative	
1	MEAG Power	Danny Dees	Affirmative	
1	MidAmerican Energy Co.	Terry Harbour	Affirmative	
1	Minnkota Power Coop. Inc.	Richard Burt	Affirmative	
1	National Grid	Saurabh Saksena	Affirmative	
1	Nebraska Public Power District	Cole C Brodine	Negative	
1	New Brunswick Power Transmission Corporation	Randy MacDonald	Abstain	
1	New York Power Authority	Arnold J. Schuff	Affirmative	
1	New York State Electric & Gas Corp.	Raymond P Kinney		
1	Northeast Utilities	David Boguslawski	Abstain	
1	Northern Indiana Public Service Co.	Kevin M Largura	Affirmative	
1	NorthWestern Energy	John Canavan	Abstain	
1	Ohio Valley Electric Corp.	Robert Matthey	Negative	
1	Oklahoma Gas and Electric Co.	Marvin E VanBebber	Negative	
1	Omaha Public Power District	Doug Peterchuck	Affirmative	
1	Oncor Electric Delivery	Brenda Pulis		
1	Orlando Utilities Commission	Brad Chase	Abstain	
1	PacifiCorp	Ryan Millard	Abstain	
1	PECO Energy	Ronald Schloendorn		
1	Platte River Power Authority	John C. Collins	Abstain	
1	Portland General Electric Co.	John T Walker	Affirmative	
1	PowerSouth Energy Cooperative	Larry D Avery	Negative	

1	PPL Electric Utilities Corp.	Brenda L Truhe	Affirmative	
1	Progress Energy Carolinas	Brett A. Koelsch	Abstain	
1	Public Service Company of New Mexico	Laurie Williams	Abstain	
1	Public Service Electric and Gas Co.	Kenneth D. Brown	Abstain	
1	Public Utility District No. 1 of Okanogan County	Dale Dunckel	Affirmative	
1	Puget Sound Energy, Inc.	Denise M Lietz	Negative	
1	Rochester Gas and Electric Corp.	John C. Allen	Affirmative	
1	Sacramento Municipal Utility District	Tim Kelley	Abstain	
1	Salmon River Electric Cooperative	Kathryn J Spence	Affirmative	
1	Salt River Project	Robert Kondziolka	Affirmative	
1	Santee Cooper	Terry L Blackwell	Negative	
1	SCE&G	Henry Delk, Jr.		
1	Seattle City Light	Pawel Krupa	Abstain	
1	Sho-Me Power Electric Cooperative	Denise Stevens	Affirmative	
1	Sierra Pacific Power Co.	Rich Salgo	Abstain	
1	Snohomish County PUD No. 1	Long T Duong	Affirmative	
1	South California Edison Company	Steven Mavis	Negative	
1	Southern Company Services, Inc.	Robert A. Schaffeld	Negative	
1	Southern Illinois Power Coop.	William Hutchison	Negative	
1	Southwest Transmission Cooperative, Inc.	James Jones	Affirmative	
1	Southwestern Power Administration	Angela L Summer	Abstain	
1	Sunflower Electric Power Corporation	Noman Lee Williams	Affirmative	
1	Tampa Electric Co.	Beth Young		
1	Tennessee Valley Authority	Larry G Akens	Abstain	
1	Tri-State G & T Association, Inc.	Tracy Sliman	Affirmative	
1	Tucson Electric Power Co.	John Tolo		
1	United Illuminating Co.	Jonathan Appelbaum	Affirmative	
1	Westar Energy	Allen Klassen	Negative	
1	Western Area Power Administration	Brandy A Dunn	Affirmative	
1	Xcel Energy, Inc.	Gregory L Pieper		
2	Alberta Electric System Operator	Mark B Thompson	Abstain	
2	BC Hydro	Venkataramkrishnan Vinnakota	Abstain	
2	California ISO	Rich Vine	Abstain	
2	Electric Reliability Council of Texas, Inc.	Charles B Manning		
2	Independent Electricity System Operator	Barbara Constantinescu	Affirmative	
2	Midwest ISO, Inc.	Marie Knox	Affirmative	
2	New Brunswick System Operator	Alden Briggs	Abstain	
2	New York Independent System Operator	Gregory Campoli		
2	PJM Interconnection, L.L.C.	Tom Bowe	Abstain	
2	Southwest Power Pool, Inc.	Charles H. Yeung		
3	AEP	Michael E Deloach	Negative	
3	Alabama Power Company	Richard J. Mandes		
3	Ameren Services	Mark Peters	Abstain	
3	Anaheim Public Utilities Dept.	Kelly Nguyen		
3	APS	Steven Norris	Affirmative	

3	Arkansas Electric Cooperative Corporation	Philip Huff	Abstain	
3	BC Hydro and Power Authority	Pat G. Harrington	Abstain	
3	Bonneville Power Administration	Rebecca Berdahl	Affirmative	
3	Central Lincoln PUD	Steve Alexanderson	Abstain	
3	City of Austin dba Austin Energy	Andrew Gallo	Affirmative	
3	City of Bartow, Florida	Matt Culverhouse		
3	City of Clewiston	Lynne Mila	Affirmative	
3	City of Farmington	Linda R Jacobson	Affirmative	
3	City of Garland	Ronnie C Hoeinghaus	Abstain	
3	City of Green Cove Springs	Gregg R Griffin	Affirmative	
3	City of Redding	Bill Hughes	Affirmative	
3	Clatskanie People's Utility District	Brian Fawcett		
3	Cleco Corporation	Michelle A Corley	Negative	
3	Colorado Springs Utilities	Charles Morgan	Affirmative	
3	ComEd	Bruce Krawczyk		
3	Consolidated Edison Co. of New York	Peter T Yost	Affirmative	
3	Constellation Energy	CJ Ingersoll	Abstain	
3	Consumers Energy	Richard Blumenstock	Affirmative	
3	Cowlitz County PUD	Russell A Noble	Negative	
3	CPS Energy	Jose Escamilla	Affirmative	
3	Detroit Edison Company	Kent Kujala	Negative	
3	Dominion Resources Services	Michael F. Gildea		
3	Duke Energy Carolina	Henry Ernst-Jr	Abstain	
3	Entergy	Joel T Plessinger	Affirmative	
3	FirstEnergy Energy Delivery	Stephan Kern	Affirmative	
3	Florida Municipal Power Agency	Joe McKinney	Affirmative	
3	Florida Power Corporation	Lee Schuster	Negative	
3	Georgia Power Company	Anthony L Wilson		
3	Georgia Systems Operations Corporation	William N. Phinney	Affirmative	
3	Grays Harbor PUD	Wesley W Gray	Affirmative	
3	Great River Energy	Brian Glover	Negative	
3	Gulf Power Company	Paul C Caldwell	Negative	
3	Hydro One Networks, Inc.	David Kiguel	Abstain	
3	Imperial Irrigation District	Jesus S. Alcaraz	Abstain	
3	JEA	Garry Baker		
3	Kansas City Power & Light Co.	Charles Locke	Affirmative	
3	Kissimmee Utility Authority	Gregory D Woessner	Affirmative	
3	Kootenai Electric Cooperative	Dave Kahly	Abstain	
3	Lakeland Electric	Norman D Harryhill		
3	Lincoln Electric System	Jason Fortik	Abstain	
3	Los Angeles Department of Water & Power	Daniel D Kurowski	Affirmative	
3	Louisville Gas and Electric Co.	Charles A. Freibert		
3	Manitoba Hydro	Greg C. Parent	Negative	
3	Manitowoc Public Utilities	Thomas E Reed	Affirmative	
3	MidAmerican Energy Co.	Thomas C. Mielnik	Negative	
3	Mississippi Power	Jeff Franklin	Negative	

3	Modesto Irrigation District	Jack W Savage	Affirmative	
3	Municipal Electric Authority of Georgia	Steven M. Jackson	Affirmative	
3	Muscatine Power & Water	John S Bos	Affirmative	
3	Nebraska Public Power District	Tony Eddleman	Abstain	
3	New York Power Authority	Marilyn Brown	Affirmative	
3	Niagara Mohawk (National Grid Company)	Michael Schiavone	Affirmative	
3	North Carolina Electric Membership Corp.	Doug White	Affirmative	
3	Northern Indiana Public Service Co.	William SeDoris	Affirmative	
3	Ocala Electric Utility	David Anderson	Affirmative	
3	Old Dominion Electric Coop.	Bill Watson		
3	Orange and Rockland Utilities, Inc.	David Burke	Affirmative	
3	Orlando Utilities Commission	Ballard K Muters	Abstain	
3	Owensboro Municipal Utilities	Thomas T Lyons	Negative	
3	Pacific Gas and Electric Company	John H Hagen	Affirmative	
3	PacifiCorp	Dan Zollner	Abstain	
3	Platte River Power Authority	Terry L Baker	Abstain	
3	PNM Resources	Michael Mertz	Abstain	
3	Potomac Electric Power Co.	Robert Reuter		
3	Progress Energy Carolinas	Sam Waters		
3	Public Service Electric and Gas Co.	Jeffrey Mueller		
3	Public Utility District No. 1 of Clallam County	David Proebstel		
3	Puget Sound Energy, Inc.	Erin Apperson	Negative	
3	Rutherford EMC	Thomas M Haire	Affirmative	
3	Sacramento Municipal Utility District	James Leigh-Kendall	Abstain	
3	Salt River Project	John T. Underhill	Affirmative	
3	Santee Cooper	James M Poston	Negative	
3	Seattle City Light	Dana Wheelock	Abstain	
3	Seminole Electric Cooperative, Inc.	James R Frauen	Affirmative	
3	Snohomish County PUD No. 1	Mark Oens	Affirmative	
3	South Carolina Electric & Gas Co.	Hubert C Young		
3	Southern Maryland Electric Coop.	Mark R Jones		
3	Tacoma Public Utilities	Travis Metcalfe	Affirmative	
3	Tampa Electric Co.	Ronald L Donahey		
3	Tennessee Valley Authority	Ian S Grant	Abstain	
3	Tri-State G & T Association, Inc.	Janelle Marriott	Affirmative	
3	Westar Energy	Bo Jones	Negative	
3	Xcel Energy, Inc.	Michael Ibold	Abstain	
4	Alliant Energy Corp. Services, Inc.	Kenneth Goldsmith	Affirmative	
4	American Municipal Power	Kevin Koloini	Negative	
4	Arkansas Electric Cooperative Corporation	Ronnie Frizzell		
4	Blue Ridge Power Agency	Duane S Dahlquist	Affirmative	
4	Central Lincoln PUD	Shamus J Gamache	Abstain	
4	City of Austin dba Austin Energy	Reza Ebrahimian	Affirmative	
4	City of Clewiston	Kevin McCarthy	Affirmative	

4	City of New Smyrna Beach Utilities Commission	Tim Beyrle	Affirmative	
4	City of Redding	Nicholas Zettel	Affirmative	
4	City Utilities of Springfield, Missouri	John Allen	Affirmative	
4	Consumers Energy	David Frank Ronk	Affirmative	
4	Cowlitz County PUD	Rick Syring	Negative	
4	Detroit Edison Company	Daniel Herring	Negative	
4	Flathead Electric Cooperative	Russ Schneider	Negative	
4	Florida Municipal Power Agency	Frank Gaffney	Affirmative	
4	Fort Pierce Utilities Authority	Thomas Richards		
4	Georgia System Operations Corporation	Guy Andrews	Affirmative	
4	Illinois Municipal Electric Agency	Bob C. Thomas	Abstain	
4	Imperial Irrigation District	Diana U Torres		
4	Indiana Municipal Power Agency	Jack Alvey	Abstain	
4	Integritys Energy Group, Inc.	Christopher Plante	Abstain	
4	LaGen	Richard Comeaux	Abstain	
4	Madison Gas and Electric Co.	Joseph DePoorter	Abstain	
4	Northern California Power Agency	Tracy R Bibb		
4	Ohio Edison Company	Douglas Hohlbaugh	Affirmative	
4	Public Utility District No. 1 of Douglas County	Henry E. LuBean	Affirmative	
4	Public Utility District No. 1 of Snohomish County	John D Martinsen	Affirmative	
4	Sacramento Municipal Utility District	Mike Ramirez	Abstain	
4	Seattle City Light	Hao Li	Abstain	
4	South Mississippi Electric Power Association	Steven McElhaney		
4	Tacoma Public Utilities	Keith Morisette	Affirmative	
4	Wisconsin Energy Corp.	Anthony Jankowski	Affirmative	
5	AEP Service Corp.	Brock Ondayko	Negative	
5	AES Corporation	Leo Bernier	Affirmative	
5	Amerenue	Sam Dwyer	Abstain	
5	Arizona Public Service Co.	Edward Cambridge	Affirmative	
5	Avista Corp.	Edward F. Groce	Affirmative	
5	BC Hydro and Power Authority	Clement Ma	Abstain	
5	Black Hills Corp	George Tatar	Affirmative	
5	Boise-Kuna Irrigation District/dba Lucky peak power plant project	Mike D Kukla	Abstain	
5	Bonneville Power Administration	Francis J. Halpin	Affirmative	
5	BrightSource Energy, Inc.	Chifong Thomas	Abstain	
5	Caithness Long Island, LLC	Jason M Moore		
5	Chelan County Public Utility District #1	John Yale		
5	City and County of San Francisco	Daniel Mason		
5	City of Austin dba Austin Energy	Jeanie Doty	Affirmative	
5	City of Redding	Paul A. Cummings	Affirmative	
5	City of Tacoma, Department of Public Utilities, Light Division, dba Tacoma Power	Max Emrick	Affirmative	

5	City of Tallahassee	Brian Horton		
5	City Water, Light & Power of Springfield	Steve Rose	Affirmative	
5	Cleco Power	Stephanie Huffman	Negative	
5	Cogentrix Energy, Inc.	Mike D Hirst	Negative	
5	Colorado Springs Utilities	Jennifer Eckels	Affirmative	
5	Consolidated Edison Co. of New York	Wilket (Jack) Ng	Affirmative	
5	Constellation Power Source Generation, Inc.	Amir Y Hammad		
5	Consumers Energy Company	David C Greyerbiehl	Affirmative	
5	Cowlitz County PUD	Bob Essex	Negative	
5	CPS Energy	Robert Stevens	Affirmative	
5	Detroit Edison Company	Christy Wicke	Negative	
5	Dominion Resources, Inc.	Mike Garton	Abstain	
5	Duke Energy	Dale Q Goodwine	Negative	
5	Dynegy Inc.	Dan Roethemeyer	Affirmative	
5	E.ON Climate & Renewables North America, LLC	Dana Showalter		
5	Edison Mission Energy	Ellen Oswald		
5	Electric Power Supply Association	John R Cashin	Abstain	
5	Exelon Nuclear	Michael Korchynsky		
5	ExxonMobil Research and Engineering	Martin Kaufman		
5	FirstEnergy Solutions	Kenneth Dresner	Affirmative	
5	Florida Municipal Power Agency	David Schumann	Affirmative	
5	Gainesville Regional Utilities	Karen C Alford		
5	Great River Energy	Preston L Walsh	Negative	
5	Green Country Energy	Greg Froehling		
5	Imperial Irrigation District	Marcela Y Caballero		
5	Indeck Energy Services, Inc.	Rex A Roehl		
5	JEA	John J Babik	Affirmative	
5	Kissimmee Utility Authority	Mike Blough	Affirmative	
5	Lakeland Electric	James M Howard		
5	Liberty Electric Power LLC	Daniel Duff	Negative	
5	Lincoln Electric System	Dennis Florom	Abstain	
5	Los Angeles Department of Water & Power	Kenneth Silver	Affirmative	
5	Lower Colorado River Authority	Tom Foreman	Abstain	
5	Luminant Generation Company LLC	Mike Laney	Affirmative	
5	Manitoba Hydro	S N Fernando	Negative	
5	Massachusetts Municipal Wholesale Electric Company	David Gordon	Abstain	
5	MEAG Power	Steven Grego	Affirmative	
5	MidAmerican Energy Co.	Christopher Schneider		
5	Muscatine Power & Water	Mike Avesing	Affirmative	
5	Nebraska Public Power District	Don Schmit	Negative	
5	New York Power Authority	Gerald Mannarino	Affirmative	
5	NextEra Energy	Allen D Schriver	Negative	
5	North Carolina Electric Membership Corp.	Jeffrey S Brame	Affirmative	



5	Northern California Power Agency	Hari Modi		
5	Northern Indiana Public Service Co.	William O. Thompson	Affirmative	
5	Occidental Chemical	Michelle R DAntuono	Affirmative	
5	Omaha Public Power District	Mahmood Z. Safi	Affirmative	
5	Orlando Utilities Commission	Richard K Kinan	Negative	
5	Pacific Gas and Electric Company	Richard J. Padilla	Affirmative	
5	PacifiCorp	Sandra L. Shaffer	Abstain	
5	Platte River Power Authority	Roland Thiel	Abstain	
5	Portland General Electric Co.	Gary L Tingley	Affirmative	
5	PowerSouth Energy Cooperative	Tim Hattaway	Negative	
5	PPL Generation LLC	Annette M Bannon	Affirmative	
5	Progress Energy Carolinas	Wayne Lewis		
5	PSEG Fossil LLC	Tim Kucey	Abstain	
5	Public Utility District No. 1 of Lewis County	Steven Grega	Negative	
5	Puget Sound Energy, Inc.	Tom Flynn	Affirmative	
5	Sacramento Municipal Utility District	Bethany Hunter	Abstain	
5	Salt River Project	William Alkema	Affirmative	
5	Santee Cooper	Lewis P Pierce	Negative	
5	Seattle City Light	Michael J. Haynes	Abstain	
5	Seminole Electric Cooperative, Inc.	Brenda K. Atkins	Affirmative	
5	Siemens PTI	Edwin Cano		
5	Snohomish County PUD No. 1	Sam Nietfeld	Affirmative	
5	South Mississippi Electric Power Association	Jerry W Johnson		
5	Southern California Edison Co.	Denise Yaffe	Negative	
5	Southern Company Generation	William D Shultz	Negative	
5	Tampa Electric Co.	RJames Rocha	Affirmative	
5	Tenaska, Inc.	Scott M. Helyer	Abstain	
5	Tennessee Valley Authority	David Thompson	Abstain	
5	Tri-State G & T Association, Inc.	Barry Ingold		
5	U.S. Army Corps of Engineers	Melissa Kurtz	Affirmative	
5	Vandolah Power Company L.L.C.	Douglas A. Jensen		
5	Xcel Energy, Inc.	Liam Noailles		
6	ACES Power Marketing	Jason L Marshall	Abstain	
6	AEP Marketing	Edward P. Cox	Negative	
6	Ameren Energy Marketing Co.	Jennifer Richardson	Abstain	
6	APS	Randy A. Young	Affirmative	
6	Arkansas Electric Cooperative Corporation	Keith Sugg		
6	Bonneville Power Administration	Brenda S. Anderson	Affirmative	
6	City of Austin dba Austin Energy	Lisa L Martin	Affirmative	
6	City of Redding	Marvin Briggs	Affirmative	
6	Cleco Power LLC	Robert Hirchak	Negative	
6	Colorado Springs Utilities	Lisa C Rosintoski		
6	Consolidated Edison Co. of New York	Nickesha P Carrol	Affirmative	
6	Constellation Energy Commodities Group	Brenda Powell		
6	Dominion Resources, Inc.	Louis S. Slade	Abstain	

6	Duke Energy Carolina	Walter Yeager		
6	Entergy Services, Inc.	Terri F Benoit	Abstain	
6	Exelon Power Team	Pulin Shah		
6	FirstEnergy Solutions	Kevin Querry	Affirmative	
6	Florida Municipal Power Agency	Richard L. Montgomery	Affirmative	
6	Florida Municipal Power Pool	Thomas Washburn	Abstain	
6	Florida Power & Light Co.	Silvia P. Mitchell	Abstain	
6	Imperial Irrigation District	Cathy Bretz	Abstain	
6	Kansas City Power & Light Co.	Jessica L Klinghoffer	Affirmative	
6	Lakeland Electric	Paul Shipps	Affirmative	
6	Lincoln Electric System	Eric Ruskamp	Affirmative	
6	Los Angeles Department of Water & Power	Brad Packer		
6	Luminant Energy	Brad Jones	Affirmative	
6	Manitoba Hydro	Daniel Prowse	Negative	
6	MidAmerican Energy Co.	Dennis Kimm	Negative	
6	New York Power Authority	William Palazzo	Affirmative	
6	North Carolina Municipal Power Agency #1	Matthew Schull	Affirmative	
6	Northern Indiana Public Service Co.	Joseph O'Brien	Affirmative	
6	Omaha Public Power District	David Ried	Affirmative	
6	Orlando Utilities Commission	Claston Augustus Sunanon		
6	PacifiCorp	Scott L Smith	Abstain	
6	Platte River Power Authority	Carol Ballantine	Abstain	
6	PPL EnergyPlus LLC	Mark A Heimbach		
6	Progress Energy	John T Sturgeon		
6	PSEG Energy Resources & Trade LLC	Peter Dolan	Abstain	
6	Public Utility District No. 1 of Chelan County	Hugh A. Owen		
6	Sacramento Municipal Utility District	Diane Enderby	Abstain	
6	Salt River Project	Steven J Hulet	Affirmative	
6	Santee Cooper	Michael Brown	Negative	
6	Seattle City Light	Dennis Sismaet	Affirmative	
6	Seminole Electric Cooperative, Inc.	Trudy S. Novak		
6	Snohomish County PUD No. 1	William T Moojen	Affirmative	
6	South California Edison Company	Lujuanna Medina	Abstain	
6	Southern Company Generation and Energy Marketing	John J. Ciza	Negative	
6	Tacoma Public Utilities	Michael C Hill	Affirmative	
6	Tampa Electric Co.	Benjamin F Smith II		
6	Tennessee Valley Authority	Marjorie S. Parsons	Abstain	
6	Westar Energy	Grant L Wilkerson	Negative	
6	Western Area Power Administration - UGP Marketing	Peter H Kinney	Affirmative	
6	Xcel Energy, Inc.	David F. Lemmons		
8		Roger C Zaklukiewicz	Affirmative	
8		James A Maenner	Affirmative	

8		Edward C Stein	Affirmative	
8	APX	Michael Johnson	Affirmative	
8	JDRJC Associates	Jim Cyrulewski	Affirmative	
8	Power Energy Group LLC	Peggy Abbadini		
8	Utility Services, Inc.	Brian Evans-Mongeon	Abstain	
8	Volkman Consulting, Inc.	Terry Volkman	Affirmative	
9	California Energy Commission	William M Chamberlain		
9	Central Lincoln PUD	Bruce Lovelin		
9	Commonwealth of Massachusetts Department of Public Utilities	Donald Nelson	Abstain	
10	Midwest Reliability Organization	James D Burley		
10	New York State Reliability Council	Alan Adamson		
10	Northeast Power Coordinating Council	Guy V. Zito	Negative	
10	ReliabilityFirst Corporation	Anthony E Jablonski	Affirmative	
10	SERC Reliability Corporation	Carter B. Edge	Abstain	
10	Southwest Power Pool RE	Emily Pannel	Negative	
10	Texas Reliability Entity, Inc.	Donald G Jones	Abstain	
10	Western Electricity Coordinating Council	Steven L. Rueckert	Abstain	

## **Exhibit G**

Standard Drafting Team Roster for NERC Standards Development Project 2009-01

**Project 2009-01 Disturbance and Sabotage Reporting  
Drafting Team**

Name and Title	Company and Address	Contact Info	Bio
<p>Brian Evans-Mongeon – Chair</p>	<p>Utility Services 25 Crossroad Suite 201 Waterbury, VT 05676</p>	<p>802-552-4022 Brian.Evans-Mongeon@utilityservices.com</p>	<p><b>Work Experience</b> Brian organized and created Utility Services in 2007 and has been working with registered entities on NERC related activities since that time. Prior to this, he worked for Vermont Public Power Supply Authority and Green Mountain Power Corporation in power supply, transmission, system operations, and distribution activities. Tasks have included contract negotiations, administration of tariffs and rates, coordination with transmission providers, and reporting of operational and reliability considerations.</p> <p><b>NERC and NPCC Specific Activities</b> While not a registered entity, Utility Services works with the staffs of Registered Entities to ensure compliance and consistency of the standards and requirements. Presently, Utility Services works with 70 Registered Entities with over 150 functional registrations throughout all 8 NERC regions. Within the regions, Utility Services is a Member of NPCC, RFC, FRCC, MRO, and WECC. Brian has served in a number of committees, task forces, and working groups regionally and nationally; including regional standards for Disturbance Monitoring and Under Frequency Load Shedding, Disturbance and Sabotage Reporting, defining the Bulk Electric System, and the NERC CIPC Compliance and Enforcement Input WG (CEIWG)</p> <p><b>Education</b> Brian has an Associates degree in Electric/Electronic Technology from Vermont Technical College and a Bachelors of Science in Business Administration from the University of Vermont.</p>
<p>Joseph DePoorter – Vice-Chair</p>	<p>Madison Gas and Electric Company 133 South Blair St., Madison, Wisconsin 53703</p>	<p>608-252-1599, jdepoorter@mge.com</p>	<p>Joseph DePoorter is the Director of NERC Compliance and Generation Operations and joined Madison Gas and Electric Company (MGE) in the spring of 2001 after retiring from the United States Marine Corps. Joe started at MGE as a Distribution Operator and becoming NERC Certified (RA) in January of 2003. Joe then became a System Operator where duties were under the auspice of a Control Area. MGE then started to enter into agreements with the Midwest ISO and Joe assisted</p>

			<p>the real-operations component for MGE. In March of 2007, Joe became the Manager of Reliability Compliance, focusing on the upcoming enforceable NERC Standards. Joe has lead three on sight compliance audits (from the MRO), is the Chair of the MRO NERC Standards Review Forum, Chair of the MRO Performance and Risk Oversight Subcommittee and the Vice Chair of Project 2009-01.</p>
<p>Michelle Draxton</p> <p>Security Manager - Generation</p> <p>Corporate Security Operations - Client Services</p>	<p>Exelon Corporation 300 Exelon Way Suite 320 Kennett Square, PA 19348</p>	<p>Office: 610.765.6942</p> <p>Mobile: 410.474.2993</p> <p><a href="mailto:michelle.draxton@exeloncorp.com">michelle.draxton@exeloncorp.com</a></p>	<p>Michelle Draxton joined the Constellation Energy Group (CEG)/Exelon Corporation in 1991 (CEG merged with the Exelon Corporation in 2012), following a short career in Education. During Michelle's 21 years with the company, she spent the first ten (10) years of her career working in Project Controls; Project Management and Long Range Scheduling &amp; Cost Control (supporting shutdown safety scheduling); and the Diesel Upgrade Project. She was a Nuclear Security Training Specialist/ Nuclear Supervisor for the Security Access &amp; Fitness Duty Program, ensuring compliance with Nuclear Regulatory Commission (NRC) and Nuclear Energy Institute (NEI) regulations/guidelines. When CE merged with Nigra Mohawk - Nine Mile Point Nuclear Facility and the Rochester Gas Electric - Ginna Nuclear Station, Michelle performed strategic alignment between the three nuclear facilities maintenance-training program and leadership programs as a Senior Organizational Development and Training Consultant.</p> <p>Michelle has been with Corporate and Information security for 11 years. In 2007/2008, Michelle led a cross-functional team to implement the initial NERC Critical Infrastructure Protection (CIP) Cyber Security Governance/Program and the Security Awareness Program for CEG. Michelle currently manages a team of security specialists who ensure compliance with the organization's policies and procedures, as well as protect the personnel and assets of generation facilities within the U.S. and Canada. Michelle organizes and coordinates investigations involving allegations of criminal matters, fraud, computer crimes, intellectual property and other security issues with her team and develops risk assessments and security plans to ensure compliance with multiple federal regulatory bodies.</p>
<p>Jimmy Hartmann</p>	<p>Electric Reliability Council of Texas</p>	<p>512-248-6986 <a href="mailto:jhartmann@ercot.c">jhartmann@ercot.c</a></p>	<p>Jimmy Hartmann is currently the Supervisor of System Operations for the Electric Reliability</p>

	<p>(ERCOT) 2705 West Lake Dr. Taylor, Texas 76574</p>	<p>om</p>	<p>Council of Texas, Inc (ERCOT). Overall, Jimmy has more than thirty years of combined experience in the Energy industry. His experiences include power plant operations, power marketing and system operations. In his twelve years of service to ERCOT, Jimmy has served in many capacities including System Operator, Outage Coordinator and a Shift Supervisor, all of which are responsible for ensuring the reliability of the ERCOT interconnection. Jimmy currently holds certifications as a NERC Reliability Coordinator and as an ERCOT System Operator. Prior to ERCOT, Jimmy was employed at South Texas Electric Cooperative, Inc for five years working as a System Operator, Wholesale Marketing Specialist/Energy Trader and a Lead System Operator responsible for making and carry through decisions that were required to operate their system during normal and adverse conditions. Prior to STEC, Jimmy was employed at San Miguel Electric Cooperative, Inc working at a 440MW Lignite Fired Power Plant where he also had a multitude of operational responsibilities spanning over a fourteen year period.</p>
<p>Robert D. Canada</p>	<p>North American Electric Reliability Corporation 3353 Peachtree Rd Suite 600 North Tower Atlanta, GA 30326,</p>	<p>Office 404-446-9709 Cell 770-608-5666  bob.canada@nerc.net</p>	<p>Bob Canada has been with NERC since October 2011 as a NERC Standards Specialist and is the Critical Infrastructure Protection Committee Secretary. He was with Southern Company for 29 years and served as a Business Assurance Principal focused on systematic approach to operational resiliency and physical security. He worked to coordinate and achieve a consistent corporate security strategy, policy and “all hazards” response for the four operating companies – Georgia Power, Alabama Power, Gulf Power and Mississippi Power. Canada served twice in a leadership capacity as Chairman for the Edison Electric Institute’s (EEI) Security Committee, which is the electric industry lobbyist in Washington D.C. Here he assisted with strategic work on security issues facing the electric industry such as a response to 9/11 and the many federal guidelines for regulatory agencies. Canada established the first Georgia Emergency Management Agency liaison on behalf of the Southern Company and Georgia Power with the State of Georgia to coordinate utility response during emergencies and disaster response. He served the Southeastern Reliability Council (SERC) for four years as Chairman of the Critical Infrastructure Protection Committee and presently represents SERC on the North American Electric Reliability Corporation’s (NERC) Critical</p>

			<p>Infrastructure Committee (CIPC) as the physical security representative and voting member. Other responsibilities included directing the Georgia Power and Southern Company Olympic planning efforts and implementation of physical security surveys and protective countermeasures to ensure the continuity and mitigation of threats to the 1996 Olympic Games. He consulted with Federal, state and local law enforcement agencies to protect the electrical infrastructure in Georgia and Metropolitan Atlanta. Canada served on the Atlanta Committee for the Olympic Games as a corporate security liaison to the utilities in Georgia. He presently serves as Vice Chair on the NERC CIPC Executive Committee and has served on the Electricity Sector Coordinating Council interfacing on policy level decision making processes with Department of Homeland Security (DHS) and the Department of Energy for initiatives and protective programs such as the Energy Sector's National Infrastructure Protection Plan. Honors included The Security Executive Council Magazine's "Most Influential" in the electric utility for 2011.</p>
<p>Brian Harrell CPP Critical Infrastructure Department</p>	<p>North American Electric Reliability Corporation 3353 Peachtree Rd Suite 600 North Tower Atlanta, GA 30326</p>	<p>(609) 651-0671 <a href="mailto:Brian.Harrell@nerc.net">Brian.Harrell@nerc.net</a></p>	<p>Brian Harrell is the Manager of CIP Standards, Training, and Awareness for NERC. In this capacity he is responsible for managing ERO-wide critical infrastructure protection standards initiatives and assisting in the development of the overall CIP program strategy.</p> <p>Harrell has 15 years of experience in the security industry serving in organizations such as law enforcement, the military and corporate security, among others. Most recently, he served as the Manager of Critical Infrastructure Protection for SERC Reliability Corporation, where he oversaw all security- and CIP reliability-related matters for the Region. Prior to joining SERC, Harrell was the Sector Security Specialist for the Infrastructure Security Compliance Division at the U.S. Department of Homeland Security. He specialized in securing high risk critical infrastructures and Continuity of Operations (COOP) for the Department of Homeland Security. Brian also served in the U.S. Marine Corps as an Anti-Terrorism and Force Protection Instructor.</p> <p>Harrell has a M.A. from Central Michigan University and a B.A. from Hawaii Pacific University. He is also board certified in security management.</p>
<p>Scott Mix</p>	<p>North American</p>	<p>215-853-8204 <a href="mailto:scott.mix@nerc.net">scott.mix@nerc.net</a></p>	<p>Mr. Scott R. Mix, CISSP, joined NERC in October 2006 following more than 25 years of experience</p>



<p>CIP Technical Manager</p>	<p>Electric Reliability Corporation 1325 G Street NW, Suite 600 Washington, DC 20005</p>	<p>t</p>	<p>working in various facets of the electricity industry, including as a consultant with KEMA, Inc., Infrastructure Security Manager with the Electric Power Research Institute (EPRI), Senior Security Analyst at the PJM Interconnection, and more than ten years with Leeds &amp; Northrup Co. as a programmer/analyst and systems architect. For more than ten years, he has focused on the areas of Computer and Infrastructure Security for the Electricity Sector. At NERC, he is responsible for Critical Infrastructure Protection issues, primarily as they relate to Real Time and Control System Security, and the development of the revisions to the NERC CIP Standards. He has also been the NERC Staff Facilitator for the Critical Infrastructure Protection Committee (CIPC) and several of its working groups and task forces, and a member of the Electricity Sector Information Sharing and Analysis Center (ES-ISAC) Staff.</p> <p>Throughout his career, Mr. Mix has worked closely with numerous industry and government organizations, including NERC's Critical Infrastructure Protection Committee (CIPC) and its working teams, and is the former convener of the Control System Security Working Group, has been an active and vocal observer to the NERC Cyber Security Standards Version 1 Drafting Team (and the NERC 1200 process before that), and is a former member of the OASIS "How" Working Group. He has also worked with the Department of Energy, the Department of Homeland Security, the FBI's National Infrastructure Protection Center, and the Federal Energy Regulatory Commission dealing with specific Electric Sector Security Issues. He has organized and presented at numerous industry symposia, both domestically and internationally. He has been a member and chapter secretary of the Philadelphia Chapter of InfraGard, is a member of the ISA and has participated in the ISA100 standards activities, and is a member of the IEEE as well as its Computer Society, Power Engineering Society, and Standards Association. He is a Certified Information Systems Security Professional (CISSP).</p> <p>Mr. Mix is a graduate of the Bloomsburg University of Pennsylvania with a Bachelor of Science degree in Computer &amp; Information Science and Chemistry.</p>
<p>Stephen Crutchfield Standards Development</p>	<p>North American Electric Reliability Corporation 3353 Peachtree Rd</p>	<p>609-651-9455 Stephen.crutchfield@nerc.net</p>	<p>Stephen Crutchfield is the NERC Staff Coordinator for Project 2009-01, Disturbance and Sabotage Reporting. Stephen began his career with NERC in May 2007. Prior to joining NERC, Stephen was a</p>

Coordinator	Suite 600 North Tower Atlanta, GA 30326		<p>Project Manager with Shaw Energy Delivery Services, managing engineering and construction projects in the substation and transmission line fields. Stephen's background also includes experience with PJM as Manager of RTO Integration, working on the operations and markets integration of new members (AEP, ComEd, Dayton, Dominion and Duquesne) into PJM and southern seams operations issues with Progress Energy, Duke and TVA. Stephen also helped lead the team that was developing GridSouth in the dual roles of Organization Architect and Manager of Customer Support. Prior to GridSouth, Stephen was the Manager of Power System Operations Training at Progress Energy where he spent over 10 years training System Operators and Engineers. Overall, Stephen was with Progress Energy for 16 years.</p> <p>Stephen received his Bachelor of Arts in Physics from the University of Virginia and Masters of Science in Electrical Engineering from North Carolina State University. Stephen also holds a Master of Science in Management degree, also from North Carolina State University.</p>
-------------	--	--	---