Form Approved OMB No. 0920-1011 Exp. Date 03/31/2017

Legionella Environmental Assessment Form

Public reporting burden of this collection of information is estimated to average 120 minutes per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. An agency may not conduct or sponsor, and a person is not required to respond to a collection of information unless it displays a currently valid OMB control number. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing this burden to CDC/ATSDR Reports Clearance Officer; 1600 Clifton Road NE, MS D-74 Atlanta, Georgia 30333; ATTN: PRA (0920-1011)

# Legionella Environmental Assessment Form

## **HOW TO USE THIS FORM**

This form enables public health officials to gain a thorough understanding of a facility's water systems and assist facility management with minimizing the risk of legionellosis. It can be used along with epidemiologic information to determine whether to conduct *Legionella* environmental sampling and to develop a sampling plan. The assessment should be performed on-site by an epidemiologist and an environmental health specialist with knowledge of the ecology of *Legionella*. Keep in mind that conditions promoting *Legionella* amplification include water stagnation, warm temperatures (77-108°F or 25-42°C), availability of organic matter, and lack of residual disinfectant such as chlorine. For training and information, please visit CDC's legionellosis resources webpage at: <a href="http://www.cdc.gov/legionella/outbreak-toolkit/">http://www.cdc.gov/legionella/outbreak-toolkit/</a>.

Complete the form in as much detail as possible. Do not leave sections blank; if a question does not apply, write "N/A". If a question applies but cannot be answered, explain why. Where applicable, specify the units of measurement being used (e.g., ppm). Completion of the form may take several hours.

ğ-

#### **BEFORE ARRIVING ON SITE**

- Request the attendance of the lead facility manager as well as others who have a detailed knowledge of the facility's water systems, such as a facility engineer or industrial hygienist.
- **D** Request that they have maintenance logs and blueprints available for the meeting.
- Bring a plastic bottle, thermometer, pH test kit, and a chlorine test kit that can detect a wide range of residual disinfectant (<1 ppm for potable water and up to 10 ppm for whirlpool spas).</p>
- □ If the epidemiologic information available suggests a particular source (e.g., whirlpool spa, cooling tower), request that they shut it down (but do not drain or disinfect) in order to stop transmission.

# INSTRUCTIONS FOR MEASURING WATER PARAMETERS IN THE PREMISE PLUMBING (TABLE P. 8)

It is very important to measure and document the current physical and chemical characteristics of the potable water, as this can help determine whether conditions are likely to support *Legionella* amplification.

**STEP 1:** Plan a sampling strategy that incorporates all central hot water heaters/boilers and various points along each loop of the potable water system. For example, if the facility has one loop serving all occupant rooms, an occupant room near (proximal) the central hot water heater and another at the farthest point (distal) of the loop should be sampled.

STEP 2: For each sampling point (e.g., tap in an occupant room):

- a. Turn on the hot water tap. Collect the first 50 ml from the tap. Measure the free chlorine residual and pH. Document the findings in the table on p. 8. Note: If there is no residual chlorine in the hot water, measure it in the cold water. Note: Total chlorine should be measured instead of free chlorine if the method of disinfection is not chlorine (e.g., monochloramine).
- b. Allow the hot water tap to run until it is as hot as it will get. Collect 50 ml and measure the temperature. Document the temperature and the time it took to reach the maximum temperature.

National Center for Immunization and Respiratory Diseases Division of Bacterial Diseases



#### LEGIONELLA ENVIRONMENTAL ASSESSMENT FORM

Pe	rsons completing the assessment:					
Na	me:	Job Title:		Organization:		
Tel	ephone:	E-mail:		_		
Nai	me:	Job Title:		Organization:		
Tel	ephone:	E-mail:		_		
As	sessment details:					
Fac	ility Name:		Date	of Assessment:		
Fac	ility Address:					
	street		city	state	zip	
Pe	rson(s) interviewed during assessment:					
Nai	me:	Job Title:				
Nai	me:	Job Title:				
	me:					
	Facility Characteristics					
1.	Is this a healthcare facility or senior living fa skilled nursing facility, or clinic)? ☐ YES → If yes, skip to Q.3 & also comple ☐ NO If NO, indicate type of facility (check all that ☐ Senior living facility (e.g., retirement hou ☐ Other residential building (e.g., apartme ☐ Hotel, motel, or resort ☐ Recreational facility (e.g., health club, w ☐ Office building ☐ Manufacturing facility ☐ Restaurant ☐ Other	ete Appendix A. apply): me without skille nt, condominium rater park)	ed nursing care) 1)	, hospital, long term care	/rehab/assisted li	ving/
3.	Total number of buildings on campus:			 being assessed:		
4.	Total number of rooms that can be occupied	overnight (e.g.,	patient rooms, hote	el rooms):		
5.	Does occupancy vary throughout the year?	I YES I I	NO			
	If YES, seasons with lowest occupancy (chee	ck all that apply)				
	Winter Spring Summer					
6.	Are any occupant rooms taken out of service	e during specific	parts of the year, e	e.g., low season?		
	YES NO					
	If YES, which rooms?					

2 | CDC Legionella Environmental Assessment Form | www.cdc.gov/legionella/outbreak-toolkit/

7. Average length of stay for occupants (check one):

 $\Box$  1 night  $\Box$  2-3 nights  $\Box$  4-7 nights  $\Box$  >7 nights

8. Does the facility have emergency water systems (e.g., fire sprinklers, safety showers, eye wash stations)?

□ YES □ NO

If YES, are these systems regularly tested (i.e., sprinkler head flow tests)?  $\Box$  YES  $\Box$  NO

If YES, how often and when was the last test? \_\_\_\_

9. Are there any cooling towers or evaporative condensers on the facility premises?

 $\Box$  YES  $\rightarrow$  If yes, also complete Appendix B.

🗆 NO

10. Are there any whirlpool spas, hot tubs, or hydrotherapy spas on the facility premises?

 $\Box$  YES  $\rightarrow$  If yes, also complete Appendix C.

🗆 NO

11. Are there any decorative fountains, misters, water features, etc. on the facility premises?

 $\Box$  YES  $\rightarrow$  If yes, also complete Section D.

12. Does the facility have centralized humidification (e.g., on air-handling units) or any room humidifiers?

□ YES □ NO

If YES, describe their location and operation:

13. Has there been any recent (last 6 months) or ongoing major construction on or around the facility premises?

 $\Box$  YES  $\rightarrow$  If yes, also complete Appendix E.

🗆 NO

14. Has this facility been associated with a previous legionellosis cluster or outbreak?

□ YES □ NO

If YES, please describe number of cases, dates, source if found, and any interventions (immediate and long-term) to prevent recurrence:

15. Does the facility have a water safety plan or Legionella prevention program?

□ YES □ NO

If YES, does the facility ever test for Legionella in water samples?

 $\Box$  YES  $\rightarrow$  If yes, obtain copies of results  $\Box$  NO

If YES, please describe the plan briefly here (does it include clinical disease surveillance and/or environmental *Legionella* surveillance?) and **obtain a written copy** of the program policy:

16. Describe each building that shares water or air systems, including the main facility

		Original Construction	Later Construction (renovation, expansion)	Stories or Levels	Occupancy rate (%)*	<b>Daily Census</b> (yr. avg.)	<b>Use</b> (List all types of uses)
<b>Building Name</b> (List main facility building first)		Year Completed	From/To or "N/A"	#	Rate (%) or "N/A"	#/day or "N/A"	e.g., occupant rooms, utilities, heating/AC plant For healthcare, specify: Outpatient = 0 Inpatient (acute) = I Chronic = C Intensive care = ICU Transplant = Tx
	1.						
	2.						
	3.						
	4.						
	5.						
	6.						
	7.						

\*[occupancy rate = (# of rooms occupied overnight / total # of rooms) X 100]

V	Vater Supply Source
	What is the source of the water used by the facility? (Check all that apply)
	Municipal water if YES: Name of supplier
	How is the municipal water disinfected? (Check one) Chlorine Monochloramine Other Has treatment of municipal water changed in the past year? YES NO If YES, specify
	Non-municipal well if YES:
	How is the well water disinfected? (Check one)  Chlorine  Other Not disinfected Is the water filtered onsite?  YES  NO
	Other
	Have there been any pressure drops, boil water advisories, or water disruptions (e.g., water main break) to the facility in the past 6 months?  u YES  u NO
-	If YES, describe what happened and which buildings or parts of buildings were affected:
- 19.	Does the facility monitor incoming water parameters (e.g., residual disinfectant, temperature, pH)?
	$\Box$ YES $\rightarrow$ If yes, obtain copies of the logs $\Box$ NO
	If YES, what is the range of disinfectant residual, temperature, and pH entering the facility?
F	Premise Plumbing System Note: It is important to gain an understanding of where and how water flows, starting where it enters the
	facility and including its distribution to and through buildings to the points of use. Understand water processes, including but not limited to: heating, storage, filtration, UV irradiation, and addition of secondary disinfectants. Refer to a facility map and blueprints; <i>obtain copies of these and/or draw a diagram</i> and include with the completed assessment.
	Are cisterns and/or water storage holding tanks used to store potable water before it's heated?
21.	Is there a recirculation system (a system in which water flows continuously through the piping to ensure constant hot water to all endpoints) for the hot water?
	YES INO
	If YES, please describe where it runs and delivery/return temperatures if they are measured:
-	Are thermostatic mixing voluce used?
۲۲. ۱	Are thermostatic mixing valves used?

□ YES □ NO

If YES, describe where they are located (ideally, mixing valves are close to the point of use): \_\_\_\_

### 23. How is the hot water system configured to deliver hot water to each building?

	Building name	<b>Type of system</b> (e.g., instantaneous heater, hot water heater with a storage tank, solar heating)	Name of system (e.g., Boiler #1, Loop #1)	<b>Areas served</b> (e.g., floor, rooms)	Date of installation	<b>Total capacity</b> (gallons)	Usual temperature setting (°F)
1.							
2.							
3.							
4.							
5.							
6.							
7.							

Comments/notes:

24.	What is the maximum hot water temperature at the point of delivery permitted by state / local regulations?
	°F or °C
25.	Are <b>hot</b> water temperatures ever measured by the facility at the points of use?
	$\Box$ YES $\rightarrow$ If yes, obtain copies of the temperature logs
	If YES, what is the lowest documented hot water temperature measured at any point within the facility?
	°F or °C documented on (Month/Date/Year)//
	□ NO
26.	Are <b>cold</b> water temperatures ever measured by the facility at the points of use?
	$\Box$ YES $\rightarrow$ If yes, obtain copies of the temperature logs
	If YES, what is the highest documented cold water temperature measured at any point within the facility?
	°F or °C documented on (Month/Date/Year)//
	□ NO
27.	Are the potable water disinfectant levels (e.g., chlorine) ever measured by the facility at the points of use?
	$\Box$ YES $\rightarrow$ If yes, obtain copies of the logs
	If YES, how often are they measured?
	If YES, list the range of disinfectant residuals

🗆 NO

28. Does the facility have a supplemental disinfection system for long term control of *Legionella* or other microorganisms?

#### 🗆 YES 🛛 NO

If YES, obtain SOPs for routine use and maintenance as well as maintenance logs and records of disinfection levels, and complete the table:

Buildings with supplemental disinfection	<b>Type of system</b> (e.g., chlorine, chlorine dioxide, copper-silver)	Date installed	Describe any maintenance in the past year (include routine and emergency)

#### Comments/Notes: \_\_\_\_\_

29. Please describe any maintenance (either routine or emergency) carried out on the potable water system in the past year. Obtain records/SOPs if available.

# 30. Measured Water System Parameters (see instructions on p. 1)

Copy from table f	or question 23 (p. 6)	Part of system	Sampling site			Maximum	
Building name	Name of system (e.g., incoming water, Boiler #1, Loop #1)	(Central heater/ boiler=C Proximal occupant room=P Distal occupant room=D)	(e.g., heater #1, hot water tap in room #436)	Free chlorine (ppm)	рН	measured temperature (°F)	Time to reach max temp (min)

### **APPENDIX A. HEALTHCARE FACILITIES**

Note: Complete for all healthcare facilities, including but not limited to hospitals, long term care/rehab/assisted living/skilled nursing facilities, or clinics.

- 1. Type of healthcare facility (check all that apply):
  - Acute care hospital

If YES, does the facility have a solid organ or bone marrow transplant program?

□ YES □ NO

- D Long term care facility (i.e., nursing home, long term acute care)
- □ Rehabilitation facility or other skilled nursing care
- Assisted living facility
- Outpatient surgical center
- Other outpatient clinic (describe): \_\_\_\_\_\_
- Other healthcare facility (describe): \_\_\_\_\_\_

#### 2. Number of beds: \_\_\_\_\_

3. Are ice machines used to provide ice for patient consumption or processing medical equipment?

□ YES □ NO

If YES, list manufacturer and model or catalog number:

4. Has this facility experienced previous Legionnaires' disease cases that were "possibly" or "definitely" facility-acquired?

□ YES □ NO

If YES, describe (e.g., number of cases, dates):

### APPENDIX B. COOLING TOWERS AND EVAPORATIVE CONDENSERS

Note: It is important to gain an understanding of where the cooling towers are located, how they work, and how they are maintained. Cooling towers are frequently maintained by an outside contractor, and you may need to contact them directly if facility management does not have an in-depth knowledge of these systems. Request copies of the maintenance logs.

1. List all cooling towers and evaporative condensers on the facility premises:

Name of device (e.g., CT1)	Date Installed	Manufacturer	Location of device	Distance to nearest air intake*/location of the air intake/ passive or forced	Drift eliminators used? (Y/N)	Party responsible for maintenance

\*intakes to air handling units (AHUs)

#### 2. List details of how each cooling tower is chemically disinfected:

Name of device from Table 1 (e.g., CT1)	List type/name of bactericide(s) used	Range in which the bactericide(s) is regularly maintained (e.g., 5–10 ppm)	Schedule and method of adding bactericide (e.g., daily, weekly, as needed, automatic, by hand)	Are cooling towers turned off at any time? (e.g., seasonally) (Y/N) If yes, include schedule

#### List recent (last 6 months) special (non-routine) treatments, maintenance, or repairs to cooling devices: 3.

Name of device from Table 1 (e.g., CT1)	Action taken	Date	Comments			
pes the cooling tower water come from a branch of the potable water system inside the facility?						

□ YES □ NO

If YES, are backflow prevention devices in place to ensure cooling tower water is not introduced into the potable water system?

□ YES □ NO

If NO, what is the source of water for the cooling towers and evaporative condensers?

5. Can any windows in any occupant rooms or common areas be opened? YES NO

If YES, describe which rooms or which buildings have windows that can be opened:

4.

#### APPENDIX C. WHIRLPOOL SPAS, HOT TUBS, AND HYDROTHERAPY SPAS

Note: Do NOT complete Appendix C for Jacuzzis or whirlpool baths that are filled from the tap and drained after each use. In many jurisdictions, whirlpool spas are publicly permitted and inspected by the local health authority. An environmental health specialist with expertise in pool and spa inspection should participate in assessment of spas and will be aware of local regulations and enforcement powers, as well as have access to a pool sampling kit. Request copies of the last inspection report as well as routine maintenance logs.

- 1. Who performs the spa maintenance (e.g., on-site facilities management, name of outside contractor)?
- 2. Describe each whirlpool spa and how it is disinfected:

See Questions	Spa Descriptor/Location (e.g., main pool, private room #)				
Spa Questions					
Indoor or outdoor?					
Max. bather load					
Filter type					
S = sand DE = diatomaceous earth, C = cartridge					
Date filter was last changed					
Date of last filter backwash					
Compensation tank present?					
Type of disinfectant used					
(include chemical name, formulation, and amount used)					
Current measured disinfectant level					
(e.g., free chlorine, bromine) (ppm)					
Current measured pH					
Method used for adding disinfectant					
(e.g., automatic feeder, by hand)					
Method used for monitoring and maintaining disinfectant and pH levels					
(e.g., automatic controllers)					
Date last drained and scrubbed					
Was there a recent disinfectant "shock" treatment?					
Operating as designed and in good repair?					
If no, describe issues.					

C-1 | CDC Legionella Environmental Assessment Form | Appendix C: Whirlpool Spas, Hot Tubs, and Hydrotherapy Spas

# **APPENDIX D. OTHER WATER FEATURES**

Note: Complete for decorative fountains, water walls, recreational misters, etc. This can also be modified for industrial use water. If SOPs and/or maintenance logs exist, request copies.

Water Feature Questions	Water Feature Descriptor/Location (e.g., lobby fountain, cabana misters)				
Indoor or outdoor?					
Source of water					
Operates continuously (C) or intermittently (I)					
Presence of a heat source?					
(e.g., incandescent lighting)					
Type of disinfectant used					
(include chemical name, formulation, and amount used)					
Current measured disinfectant level					
(e.g., free chlorine, bromine) (ppm)					
Current measured pH					
Is there a maintenance protocol?					
Date last cleaned					
Operating as designed and in good repair?					
If no, describe issues.					

## APPENDIX E. RECENT OR ONGOING MAJOR CONSTRUCTION

1.	Describe in general the extent of the construction:						
2.	Was temporary water service provided to the new construction area (i.e., separate meter)?						
	If YES, describe:						
3.	Has jack-hammering or pile-driving been used during the construction process?						
0.	□ YES □ NO						
	If YES, list dates and locations:						
4.	Have there been disruptions or changes to the existing potable water system during the construction?						
	□ YES □ NO						
	If YES, describe:						
5.	Has the potable water changed in terms of taste or color during the construction process?						
-	□ YES □ NO						
	If YES, describe the changes including when they started and ended:						
6.	Is there a standard operating procedure (SOP) for shutting down, isolating, and refilling/flushing for water service areas that have been subjected to repair and/or construction interruptions?						
	□ YES □ NO						
	If YES, briefly describe the steps used in the SOP (attach a copy if possible):						
7.	Was the potable water system flushed before occupying the new building space?						
1.	→ YES → NO						
	If YES, what period of time passed between flushing and when the building was occupied?						

8. Complete table on next page.

8. Complete the table below:

New Building/Wing Name or Remodeled Area	Date construction began	Estimated date of completion	Date water service began or restarted*	Relationship to existing potable water system Independent=I Extension of existing system=E	Stories and Square Feet Involved (# and Ft <sup>2</sup> )	Uses (e.g., rooms, dining, recreation, utilities) For healthcare: Inpatient = I Outpatient = 0 Both = B Intensive Care = ICU Transplant = Tx	Date occupants began occupying new or remodeled building	Floors currently occupied

\*If remodeling of existing structure, include water shut-down date and re-start date.