

Regional Reliability Standard Name: Disturbance Monitoring			
Regional Reliability Standard No: PRC-002-NPCC-01			
NPCC Tracking Number: NPCC			
	QR	BOT	Gov't.Auth.*
SAR – Standard Authorization Request Attachment A			
<i>File Name: RSAR--Revise_or_Retire----PRC-002-NPCC-01--2-19-15</i>			
Regional Reliability Standard(s) (clean as approved) Attachment B			
<i>File Name: PRC-002-NPCC-01</i>			
Regional Reliability Standard(s) (clean as proposed) Attachment B-1			
<i>File Name: NA</i>			
Regional Reliability Standard(s) (redlined) Attachment C			
<i>File Name: NA</i>			
Project Roadmap Attachment D			
<i>File Name: NA</i>			
Implementation Plan Attachment E			
<i>File Name: NA</i>			
Technical Justification Attachment F			
<i>File Name: PRC-002-NPCC-01 Disturbance Monitoring Technical Justification</i>			
VRF & VSL Justification Attachment G			
<i>File Name: NA</i>			
Issue Table and Mapping Document – Optional Attachment G1			
<i>File Name: NA</i>			
Regional Reliability Standard Submittal Request Attachment H			
<i>File Name: NA</i>			
Order 672 Criteria Attachment I			
<i>File Name: NA</i>			
Drafting Team Roster with Biographies Attachment J			
<i>File Name: PRC-002-NPCC-02 Drafting Team Roster</i>			
Ballot Pool Results and Ballot Pool Members Attachment K			
<i>File Name: PRC-002-NPCC-01 Disturbance Monitoring Ballot Announcement and Results</i>			
Guidance Document- Optional Attachment L			
<i>File Name: NA</i>			

Minority Issues Attachment M			
<i>File Name: NA</i>			
NPCC Standards Committee Roster Attachment N			
<i>File Name: RSC Roster</i>			
FERC Issues Table Optional Attachment O			
<i>File Name: NA</i>			
Additional Supporting Documentation Optional Attachment P and Q			
<i>File Name: NA</i>			
Responses to Comments – NPCC Attachment R1			
<i>File Name: NA</i>			
Responses to Comments – NPCC Attachment R2			
<i>File Name: NA</i>			
Responses to Comments – NERC Attachment R3			
<i>File Name: NA</i>			

The following is for NERC completion.

Petition Filing (Federal Energy Regulatory Commission)			
<i>File Name:</i>			
*Applicable governmental authorities in the United States, Canada, and Mexico			
<i>To be provided by NERC.</i>			
<i>The above documents have been provided to NERC in MS Word format.</i>			

Information in a Regional Standard Authorization Request (RSAR)

The tables below identify information to be submitted in a Regional Standard Authorization Request to the NPCC Regional Standards Process Manager, NPCCstandard@npcc.org. The NPCC Regional Standards Process Manager shall be responsible for implementing and maintaining this form as needed to support the information requirements of the standards process.

Regional Standard Authorization Request Form

Title of Proposed Standard:	PRC-002-NPCC-02
Request Date:	02-18-2015

RSAR Requester Information

<i>Name:</i> Paul DiFilippo	RSAR Type (Check box for one of these selections.)
<i>Company:</i> NPCC	<input type="checkbox"/> New Standard
<i>Telephone:</i> 416-345-5042	<input checked="" type="checkbox"/> Revision to Existing Standard
<i>Fax:</i>	<input type="checkbox"/> Withdrawal of Existing Standard
<i>Email:</i> paul.difilippo@HydroOne.com	<input type="checkbox"/> Urgent Action

Purpose (Describe the purpose of the proposed standard – what the standard will achieve in support of reliability.)

The purpose of the proposed RSAR is to review the regional standard for potential revisions made necessary by the industry’s adoption of the new NERC BES definition, the Paragraph 81 directive, and the development of NERC’s PRC-002-2 Disturbance Monitoring and Reporting Requirements standard. Retiring PRC-002-NPCC-01 is to be considered if it is determined that it can be retired without sacrificing the ability to capture post-disturbance data.

Industry Need (Provide a detailed statement justifying the need for the proposed standard, along with any supporting documentation.)

To enhance efficiencies and cost effectiveness, it must be determined if PRC-002-NPCC-01 requirements should be revised or retired to address the new NERC BES definition, to incorporate Paragraph 81, and to eliminate redundancy leading to double jeopardy with PRC-002-2 requirements without sacrificing the ability to capture post-disturbance data.

Brief Description (Describe the proposed standard in sufficient detail to clearly define the scope in a manner that can be easily understood by others.)

The requirements in PRC-002-NPCC-01 will be reviewed individually for revision or deletion with respect to the new NERC BES definition and Paragraph 81. In addition, PRC-002-NPCC-01 will be reviewed against NERC’s PRC-002-2. PRC-002-2 mandates the capturing of adequate data to facilitate the analysis of BES disturbances. This “umbrella” encompasses the relevant requirements in PRC-002-NPCC-01. However, the relevant requirements in each of the standards are to be compared and the requirements of PRC-002-NPCC-01, if so determined, will be revised or deleted to eliminate redundancy and the concomitant double jeopardy. The review will be governed by bullet 1 of the NERC Rules of Procedure, Section 312, Regional Reliability Standards, which reads “Regional Entities may propose Regional Reliability Standards that set more stringent reliability requirements than the NERC Reliability Standard or cover matters not covered by an existing NERC Reliability Standard.”

After this review is completed, it will be determined if PRC-002-NPCC-01 should be revised, or retired.

--

Reliability Functions

The Standard will Apply to the Following Functions (Check all applicable boxes.)		
<input checked="" type="checkbox"/>	Reliability Coordinator	The entity that is the highest level of authority who is responsible for the reliable operation of the Bulk Electric System, has the Wide Area view of the Bulk Electric System, and has the operating tools, processes and procedures, including the authority to prevent or mitigate emergency operating situations in both next-day analysis and real-time operations. The Reliability Coordinator has the purview that is broad enough to enable the calculation of Interconnection Reliability Operating Limits, which may be based on the operating parameters of transmission systems beyond any Transmission Operator's vision.
<input type="checkbox"/>	Balancing Authority	The responsible entity that integrates resource plans ahead of time, maintains load-interchange-generation balance within a Balancing Authority Area, and supports Interconnection frequency in real time.
<input type="checkbox"/>	Interchange Authority	Authorizes valid and balanced Interchange Schedules.
<input type="checkbox"/>	Planning Authority	The responsible entity that coordinates and integrates transmission facility and service plans, resource plans, and protection systems.
<input type="checkbox"/>	Transmission Service Provider	The entity that administers the transmission tariff and provides Transmission Service to Transmission Customers under applicable transmission service agreements.
<input checked="" type="checkbox"/>	Transmission Owner	The entity that owns and maintains transmission facilities.
<input type="checkbox"/>	Transmission Operator	The entity responsible for the reliability of its "local" transmission system, and that operates or directs the operations of the transmission facilities.
<input type="checkbox"/>	Transmission Planner	The entity that develops a long-term (generally one year and beyond) plan for the reliability (adequacy) of the interconnected bulk electric transmission systems within its portion of the Planning Authority Area.
<input type="checkbox"/>	Resource Planner	The entity that develops a long-term (generally one year and beyond) plan for the resource adequacy of specific loads (customer demand and energy requirements) within a Planning Authority Area.

<input type="checkbox"/>	Generator Operator	The entity that operates generating unit(s) and performs the functions of supplying energy and Interconnected Operations Services.
<input checked="" type="checkbox"/>	Generator Owner	Entity that owns and maintains generating units.
<input type="checkbox"/>	Purchasing-Selling Entity	The entity that purchases or sells, and takes title to, energy, capacity, and Interconnected Operations Services. Purchasing-Selling Entities may be affiliated or unaffiliated merchants and may or may not own generating facilities.
<input type="checkbox"/>	Distribution Provider	Provides and operates the “wires” between the transmission system and the customer.
<input type="checkbox"/>	Load-Serving Entity	Secures energy and transmission service (and related Interconnected Operations Services) to serve the electrical demand and energy requirements of its end-use customers.

Reliability and Market Interface Principles

Applicable Reliability Principles <i>(Check all boxes that apply.)</i>	
<input checked="" type="checkbox"/>	1. Interconnected bulk power systems shall be planned and operated in a coordinated manner to perform reliably under normal and abnormal conditions as defined in the NERC Standards.
<input checked="" type="checkbox"/>	2. The frequency and voltage of interconnected bulk power systems shall be controlled within defined limits through the balancing of real and reactive power supply and demand.
<input checked="" type="checkbox"/>	3. Information necessary for the planning and operation of interconnected bulk power systems shall be made available to those entities responsible for planning and operating the systems reliably.
<input checked="" type="checkbox"/>	4. Plans for emergency operation and system restoration of interconnected bulk power systems shall be developed, coordinated, maintained, and implemented.
<input checked="" type="checkbox"/>	5. Facilities for communication, monitoring, and control shall be provided, used, and maintained for the reliability of interconnected bulk power systems.
<input type="checkbox"/>	6. Personnel responsible for planning and operating interconnected bulk power systems shall be trained, qualified, and have the responsibility and authority to implement actions.
<input checked="" type="checkbox"/>	7. The security of the interconnected bulk power systems shall be assessed, monitored, and maintained on a wide-area basis.
Does the proposed Standard comply with all of the following Market Interface Principles? <i>(Select ‘yes’ or ‘no’ from the drop-down box.)</i>	
Recognizing that reliability is a Common Attribute of a robust North American economy:	
1. A reliability standard shall not give any market participant an unfair competitive advantage. Yes	

2. A reliability standard shall neither mandate nor prohibit any specific market structure. Yes
3. A reliability standard shall not preclude market solutions to achieving compliance with that standard. Yes
4. A reliability standard shall not require the public disclosure of commercially sensitive information. All market participants shall have equal opportunity to access commercially non-sensitive information that is required for compliance with reliability standards. Yes

Detailed Description (Provide enough detail so that an independent entity familiar with the industry could draft a standard based on this description.)

Review PRC-002-NPCC-01 against PRC-002-2 to determine if revisions are necessary or retirement of PRC-002-NPCC-01 is possible.

Related Standards

Standard No.	Explanation
PRC-002-2	NERC Disturbance Monitoring and Reporting Requirements standard

Related SARs or RSARs

SAR ID	Explanation
RSAR-- 11/26/12	RSAR for PRC-002-NPCC-01 to be reviewed with respect to the revised BES definition (withdrawn).

A. Introduction

- 1. Title:** **Disturbance Monitoring**
- 2. Number:** PRC-002-NPCC-01
- 3. Purpose:** Ensure that adequate disturbance data is available to facilitate Bulk Electric System event analyses. All references to equipment and facilities herein unless otherwise noted will be to Bulk Electric System (BES) elements.
- 4. Applicability:**
 - 4.1.** Transmission Owner
 - 4.2.** Generator Owner
 - 4.3.** Reliability Coordinator
- 5. (Proposed) Effective Date:** To be established.

B. Requirements

- R1.** Each Transmission Owner and Generator Owner shall provide Sequence of Event (SOE) recording capability by installing Sequence of Event recorders or as part of another device, such as a Supervisory Control And Data Acquisition (SCADA) Remote Terminal Unit (RTU), a generator plant Digital (or Distributed) Control System (DCS) or part of Fault recording equipment. This capability shall: *[Violation Risk Factor: Medium] [Time Horizon: Planning and Operations Planning]*
- 1.1** Be provided at all substations and at locations where circuit breaker operation affects continuity of service to radial Loads greater than 300MW, or the operation of which drops 50MVA Nameplate Rating or greater of Generation, or the operation of which creates a Generation/Load island.
- Be provided at generating units above 50MVA Nameplate Rating or series of generating units utilizing a control scheme such that the loss of 1 unit results in a loss of greater than 50MVA Nameplate Capacity, and at Generating Plants above 300MVA Name Plate Capacity.
- 1.2** Monitor the following at each location listed in 1.1:
- 1.2.1** Transmission and Generator circuit breaker positions
 - 1.2.2** Protective Relay tripping for all Protection Groups that operate to trip circuit breakers identified in 1.2.1.
 - 1.2.3** Teleprotection keying and receive

- R2.** Each Transmission Owner shall provide Fault recording capability for the following Elements at facilities where Fault recording equipment is required to be installed as per R3: *[Violation Risk Factor: Medium]* *[Time Horizon: Planning and Operations Planning]*
- 2.1** All transmission lines.
 - 2.2** Autotransformers or phase-shifters connected to busses.
 - 2.3** Shunt capacitors, shunt reactors.
 - 2.4** Individual generator line interconnections.
 - 2.5** Dynamic VAR Devices.
 - 2.6** HVDC terminals.
- R3.** Each Transmission Owner shall have Fault recording capability that determines the Current Zero Time for loss of Bulk Electric System (BES) transmission Elements. *[Violation Risk Factor: Medium]* *[Time Horizon: Planning and Operations Planning]*
- R4.** Each Generator Owner shall provide Fault recording capability for Generating Plants at and above 200 MVA Capacity and connected through a generator step up (GSU) transformer to a Bulk Electric System Element unless Fault recording capability is already provided by the Transmission Owner. *[Violation Risk Factor: Medium]* *[Time Horizon: Planning and Operations Planning]*
- R5.** Each Transmission Owner and Generator Owner shall record for Faults, sufficient electrical quantities for each monitored Element to determine the following: *[Violation Risk Factor: Medium]* *[Time Horizon: Planning and Operations Planning]*
- 5.1** Three phase-to-neutral voltages. (Common bus-side voltages may be used for lines.)
 - 5.2** Three phase currents and neutral currents.
 - 5.3** Polarizing currents and voltages, if used.
 - 5.4** Frequency.
 - 5.5** Real and reactive power.
- R6.** Each Transmission Owner and Generator Owner shall provide Fault recording with the following capabilities: *[Violation Risk Factor: Medium]* *[Time Horizon: Planning and Operations Planning]*
- 6.1** Each Fault recorder record duration shall be a minimum of one (1) second.
 - 6.2** Each Fault recorder shall have a minimum recording rate of 16 samples per cycle
 - 6.3** Each Fault recorder shall be set to trigger for at least the following:
 - 6.3.1** Monitored phase overcurrents set at 1.5 pu or less of rated CT secondary current or Protective Relay tripping for all Protection Groups.
 - 6.3.2** Neutral (residual) overcurrent set at 0.2 pu or less of rated CT secondary current.
 - 6.3.3** Monitored phase undervoltage set at 0.85 pu or greater.
 - 6.4** Document additional triggers and deviations from the settings in 6.3.2 and 6.3.3 when local conditions dictate.
- R7.** Each Reliability Coordinator shall establish its area's requirements for Dynamic Disturbance Recording (DDR) capability that: *[Violation Risk Factor: Medium]* *[Time Horizon: Planning and Operations Planning]*

Standard PRC-002-NPCC-01— Disturbance Monitoring

- 7.1 Provides a minimum of 1 DDR per 3,000 MW of peak Load.
- 7.2 Records dynamic disturbance information with consideration of the following facilities/locations:
 - 7.2.1 Major Load centers.
 - 7.2.2 Major Generation clusters.
 - 7.2.3 Major voltage sensitive areas.
 - 7.2.4 Major transmission interfaces.
 - 7.2.5 Major transmission junctions.
 - 7.2.6 Elements associated with Interconnection Reliability Operating Limits (IROLs).
 - 7.2.7 Major EHV interconnections between operating areas.
- R8. Each Reliability Coordinator shall specify that DDRs installed, after the approval of this standard, function as continuous recorders. *[Violation Risk Factor: Medium] [Time Horizon: Planning and Operations Planning]*
- R9. Each Reliability Coordinator shall specify that DDRs are installed with the following capabilities: *[Violation Risk Factor: Medium] [Time Horizon: Planning and Operations Planning]*
 - 9.1 A minimum recording time of sixty (60) seconds per trigger event.
 - 9.2 A minimum data sample rate of 960 samples per second, and a minimum data storage rate for RMS quantities of six (6) data points per second.
 - 9.3 Each DDR shall be set to trigger for at least one of the following (based on manufacturers' equipment capabilities):
 - 9.3.1 Rate of change of Frequency.
 - 9.3.2 Rate of change of Power.
 - 9.3.3 Delta Frequency (recommend 20 mHz change).
 - 9.3.4 Oscillation of Frequency.
- R10. Each Reliability Coordinator shall establish requirements such that the following quantities are monitored or derived where DDRs are installed: *[Violation Risk Factor: Medium] [Time Horizon: Planning and Operations Planning]*
 - 10.1 Line currents for most lines such that normal line maintenance activities do not interfere with DDR functionality.
 - 10.2 Bus voltages such that normal bus maintenance activities do not interfere with DDR functionality.
 - 10.3 As a minimum, one phase current per monitored Element and two phase-to-neutral voltages of different Elements. One of the monitored voltages shall be of the same phase as the monitored current.
 - 10.4 Frequency.
 - 10.5 Real and reactive power.
- R11. Each Reliability Coordinator shall document additional settings and deviations from the required trigger settings described in R9 and the required list of monitored quantities as described in R10, and

Standard PRC-002-NPCC-01— Disturbance Monitoring

report this to the Regional Entity (RE) upon request. *[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]*

- R12.** Each Reliability Coordinator shall specify its DDR requirements including the DDR setting triggers established in R9 to the Transmission Owners and Generator Owners. *[Violation Risk Factor: Medium] [Time Horizon: Planning and Operations Planning]*
- R13.** Each Transmission Owner and Generator Owner that receives a request from the Reliability Coordinator to install a DDR shall acquire and install the DDR in accordance with R12. Reliability Coordinators, Transmission Owners, and Generator Owners shall mutually agree on an implementation schedule. *[Violation Risk Factor: Medium] [Time Horizon: Planning and Operations Planning]*
- R14.** Each Transmission Owner and Generator Owner shall establish a maintenance and testing program for stand alone DME (equipment whose only purpose is disturbance monitoring) that includes: *[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*
- 14.1** Maintenance and testing intervals and their basis.
 - 14.2** Summary of maintenance and testing procedures.
 - 14.3** Monthly verification of communication channels used for accessing records remotely (if the entity relies on remote access and the channel is not monitored to a control center staffed around the clock, 24 hours a day, 7 days a week (24/7)).
 - 14.4** Monthly verification of time synchronization (if the loss of time synchronization is not monitored to a 24/7 control center).
 - 14.5** Monthly verification of active analog quantities.
 - 14.6** Verification of DDR and DFR settings in the software every six (6) years.
 - 14.7** A requirement to return failed units to service within 90 days. If a DME device will be out of service for greater than 90 days the owner shall keep a record of efforts aimed at restoring the DME to service.
- R15.** Each Reliability Coordinator, Transmission Owner and Generator Owner shall share data within 30 days upon request. Each Reliability Coordinator, Transmission Owner, and Generator Owner shall provide recorded disturbance data from DMEs within 30 days of receipt of the request in each of the following cases: *[Violation Risk Factor: Lower] [Time Horizon: Operations]*
- 15.1** NERC, Regional Entity, Reliability Coordinator.
 - 15.2** Request from other Transmission Owners, Generator Owners within NPCC.
- R16.** Each Reliability Coordinator, Transmission Owner and Generator Owner shall submit the data files conforming to the following format requirements: *[Violation Risk Factor: Lower] [Time Horizon: Operations]*
- 16.1** The data files shall be capable of being viewed, read, and analyzed with a generic COMTRADE analysis tool as per the latest revision of IEEE Standard C37.111.
 - 16.2** Disturbance Data files shall be named in conformance with the latest revision of IEEE Standard C37.232.
 - 16.3** Fault Recorder and DDR Files shall contain all monitored channels. SOE records shall contain station name, date, time resolved to milliseconds, SOE point name, status.

Standard PRC-002-NPCC-01— Disturbance Monitoring

R17. Each Reliability Coordinator, Transmission Owner and Generator Owner shall maintain, record and provide to the Regional Entity (RE), upon request, the following data on the DMEs installed to meet this standard: [*Violation Risk Factor: Lower*] [*Time Horizon: Operations*]

17.1 Type of DME.

17.2 Make and model of equipment.

17.3 Installation location.

17.4 Operational Status.

17.5 Date last tested.

17.6 Monitored Elements.

17.7 All identified channels.

17.8 Monitored electrical quantities.

C. Measures

M1. Each Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it provided Sequence of Event recording capability in accordance with 1.1 and 1.2. (R1)

M2. Each Transmission Owner shall have, and provide upon request, evidence that it provided Fault recording capability in accordance with 2.1 to 2.6. (R2)

M3. Each Transmission Owner shall have, and provide upon request, evidence that it provided Fault recording capability that determined the Current Zero Time for loss of Bulk Electric System (BES) transmission Elements in accordance with R3.

M4. Each Generator Owner shall have, and provide upon request, evidence that it provided Fault recording capability for its Generating Plants at and above 200 MVA Capacity in accordance with R4.

M5. Each Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it records for Faults, sufficient electrical quantities for each monitored Element to determine the parameters listed in 5.1 to 5.5. (R5)

M6. Each Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it provided Fault recording capability in accordance with 6.1 to 6.4. (R6)

M7. Each Reliability Coordinator shall have, and provide upon request, evidence that it established its area's requirements for Dynamic Disturbance Recording (DDR) capability in accordance with 7.1 and .2. (R7)

M8. Each Reliability Coordinator shall have, and provide upon request, evidence that DDRs installed after the approval of this standard function as continuous recorders. (R8)

M9. Each Reliability Coordinator shall have, and provide upon request, evidence that it developed DDR setting triggers to include the parameters listed in 9.1 to 9.3. (R9)

M10. Each Reliability Coordinator shall have, and provide upon request, evidence that DDRs monitor the Elements listed in 10.1 through 10.5. (R10)

M11. Each Reliability Coordinator shall have, and provide upon request, evidence that it documented additional settings and deviations from the required trigger settings described in R9 and the required list of monitored quantities as described in R10. (R11)

Standard PRC-002-NPCC-01— Disturbance Monitoring

- M12.** Each Reliability Coordinator shall have, and provide upon request, evidence that it specified its DDR requirements which included the DDR setting triggers established in R9 to the Transmission Owners and Generator Owners in the Reliability Coordinator's area. (R12)
- M13.** Each Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it acquired and installed the DDRs in accordance with the specifications contained in the Reliability Coordinator's request, and a mutually agreed upon implementation schedule. (R13)
- M14.** Each Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it has a maintenance and testing program for stand alone DME
(equipment whose only purpose is disturbance monitoring) that meets the requirements in 14.1 through 14.7. (R14)
- M15.** Each Reliability Coordinator, Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it provided recorded disturbance data from DMEs within 30 days of the receipt of the request from the entities listed in 15.1 and 15.2. (R15)
- M16.** Each Reliability Coordinator, Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it submitted the data files in a format that meets the requirements in 16.1 through 16.3. (R16)
- M17.** Each Reliability Coordinator, Transmission Owner and Generator Owner shall have, and provide upon request, evidence that it maintained a record of and provided to NPCC when requested, the data on DMEs installed meeting the requirements 17.1 through 17.8. (R17)

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority

NPCC Compliance Committee

1.2. Compliance Monitoring Period and Reset Time Frame

Not Applicable

1.3. Data Retention

The Transmission Owner and Generator Owner shall keep evidences for three calendar years for Measures 1, 5, 6, 13, 16 and 17.

The Transmission Owner shall keep evidence for three years for Measures 2 and 3.

The Generator Owner shall keep evidence for three years for Measure 4.

The Reliability Coordinator shall keep evidence for three years for Measures 7, 8, 9, 10, 11, 12, 16 and 17.

The Transmission Owner and Generator Owner shall keep evidences for twenty-four calendar months for Measures 14 and 15.

The Reliability Coordinator shall keep evidence for twenty-four calendar months for Measure 15.

Standard PRC-002-NPCC-01— Disturbance Monitoring

If a Transmission Owner, Generator Owner or Reliability Coordinator is found non-compliant, it shall keep information related to the non-compliance until found compliant.

The Compliance Enforcement Authority shall keep the last audit and all subsequent record.

1.4. Compliance Monitoring and Assessment Processes

- Self-Certifications
- Spot Checking
- Compliance Audits
- Self-Reporting
- Compliance Violation Investigations
- Complaints

1.5. Additional Compliance Information

None

2. Violation Severity Levels

R #	Lower VSL	Moderate VSL	High VSL	Severe VSL
R1 The Transmission Owner or Generator Owner provided the Sequence of Event recording capability meeting the bulk of R1 but missed...	Up to and including 10% of the total set, which is the product of the total number of locations in 1.1 times the total number of parameters in 1.2.	More than 10% and up to and including 20% of the total set, which is the product of the total number of locations in 1.1 times the total number of parameters in 1.2.	More than 20% and up to and including 30% of the total set, which is the product of the total number of locations in 1.1 times the total number of parameters in 1.2.	More than 30% of the total set, which is the product of the total number of locations in 1.1 times the total number of parameters in 1.2.
R2 The Transmission Owner provided the Fault recording capability meeting the bulk of R2 but missed...	Up to and including 10% of the total set, which is the total number of Elements at all locations required to be installed as per R3 that meet the criteria listed in 2.1 through 2.6.	More than 10% and up to and including 20% of the total set, which is the total number of Elements at all locations required to be installed as per R3 that meet the criteria listed in 2.1 through 2.6.	More than 20% and up to and including 30% of the total set, which is the total number of Elements at all locations required to be installed as per R3 that meet the criteria listed in 2.1 through 2.6.	More than 30% of the total set, which is the total number of Elements at all locations required to be installed as per R3 that meet the criteria listed in 2.1 through 2.6.
R3 The Transmission	Not applicable.	Not applicable.	Not applicable.	Fault recording capability that determines the

Standard PRC-002-NPCC-01— Disturbance Monitoring

Owner failed to provide...				current zero time for loss of transmission Elements.
R4 The Generator Owner failed to provide Fault recording capability at...	Up to and including 10% of its Generating Plants at and above 200 MVA Capacity and connected to a Bulk Electric System Element if Fault recording capability for that portion of the system is inadequate.	More than 10% and up to and including 20% of its Generating Plants at and above 200 MVA Capacity and connected to a Bulk Electric System Element if Fault recording capability for that portion of the system is inadequate.	More than 20% and up to 30% of its Generating Plants at and above 200 MVA Capacity and connected to a Bulk Electric System Element if Fault recording capability for that portion of the system is inadequate.	More than 30% of its Generating Plants at and above 200 MVA Capacity and connected to a Bulk Electric System Element if Fault recording capability for that portion of the system is inadequate.
R5 The Transmission Owner or Generator Owner failed to record for the Faults...	Up to and including 10% of the total set of parameters, which is the product of the total number of monitored Elements and the number of parameters listed in 5.1 through 5.5.	More than 10% and up to and including 20% of the total set of parameters, which is the product of the total number of monitored Elements and the number of parameters listed in 5.1 through 5.5.	More than 20% and up to and including 30% of the total set of parameters, which is the product of the total number of monitored Elements and the number of parameters listed in 5.1 through 5.5.	More than 30% of the total set of parameters, which is the product of the total number of monitored Elements and the number of parameters listed in 5.1 through 5.5.
R6 The Transmission Owner or Generator Owner failed ...	To provide Fault recording capability for up to and including 10% of the total set of requirements, which is the product of the total number of monitored Elements and the total number of capabilities identified in 6.1	To provide Fault recording capability for more than 10% and up to and including 20% of the total set of requirements, which is the product of the total number of monitored Elements and the total number of capabilities identified in 6.1 through 6.2. OR Failed to document additional triggers or	To provide Fault recording capability for more than 20% and up to and including 30% of the total set of requirements, which is the product of the total number of monitored Elements and the total number of capabilities identified in 6.1 through 6.2. OR Failed to document additional triggers or deviations from the settings stipulated in	To provide Fault recording capability for more than 30% of the total set of requirements, which is the product of the total number of monitored Elements and the total number of capabilities identified in 6.1 through 6.2. OR Failed to document additional triggers or deviations from the settings stipulated in 6.3 through 6.4 for more than ten (10) locations.

Standard PRC-002-NPCC-01— Disturbance Monitoring

	through 6.2. OR Failed to document additional triggers or deviations from the settings stipulated in 6.3 through 6.4 for up to 2 locations.	deviations from the settings stipulated in 6.3 through 6.4 for more than two (2) and up to and including five (5) locations.	6.3 through 6.4 for more than five (5) and up to and including ten (10) locations.	
R7 The Reliability Coordinator failed to establish its area's requirements for...	Up to and including 10% of the required DDR coverage for its area as per 7.1 and 7.2.	More than 10% and up to and including 20% of the required DDR coverage for its area as per 7.1 and 7.2.	More than 20% and up to and including 30% of the required DDR coverage for its area as per 7.1 and 7.2.	More than 30% of the required DDR coverage for its area as per 7.1 and 7.2.
R8 The Reliability Coordinator failed to specify that DDRs installed...	Not applicable.	Not applicable.	Not applicable.	Function as continuous recorders.
R9 The Reliability Coordinator failed to specify that DDRs are installed without...	Not applicable.	Not applicable.	Not applicable.	The capabilities listed in 9.1 through 9.3.
R10 The Reliability Coordinator failed to ensure that the quantities listed in 10.1 through 10.5 are monitored or derived...	Not applicable.	Not applicable.	Not applicable.	Where DDRs are installed.
R11 The Reliability Coordinator failed to document and report to the Regional Entity upon request additional settings and deviations from the required trigger settings described in R9	Up to two (2) facilities within the Reliability Coordinator's area that have a DDR.	More than two (2) and up to five (5) facilities within the Reliability Coordinator's area that have a DDR.	More than five (5) and up to ten (10) facilities within the Reliability Coordinator's area that have a DDR.	More than ten (10) facilities within the Reliability Coordinator's area that have a DDR.

Standard PRC-002-NPCC-01— Disturbance Monitoring

and the required list of monitored quantities as described in R10 for...				
R12 The Reliability Coordinator failed to specify to the Transmission Owners and Generator Owners its DDR requirements including the DDR setting triggers established in R9 but missed...	Not applicable.	Not applicable.	Not applicable.	Established setting triggers.
R13 The Transmission Owner or Generator Owner failed to comply with the Reliability Coordinator's request installing the DDR in accordance with R12 for...	Up to and including 10% of the requirement set of the Reliability Coordinator's request to install DDRs, with the requirement set being the total number of DDRs requested times the number of setting triggers specified for each DDR.	More than 10% and up to 20% of the requirement set requested by the Reliability Coordinator for installing DDRs, with the requirement set being the total number of DDRs requested times the number of setting triggers specified for each DDR.	More than 20% and up to 30% of the requirement set requested by the Reliability Coordinator for installing DDRs, with the requirement set being the total number of DDRs requested times the number of setting triggers specified for each DDR.	More than 30% of the requirement set requested by the Reliability Coordinator and installing DDRs, with the requirement set being the total number of DDRs requested times the number of setting triggers specified for each DDR OR The Reliability Coordinator, Transmission Owners, and Generator Owners failed to mutually agree on an implementation schedule.
R14 The Transmission Owner or Generator Owner...	Established a maintenance and testing program for stand alone DME but provided incomplete data for any one (1) of 14.1 through	Established a maintenance and testing program for stand alone DME but provided incomplete data for more than one (1) and up to and including three (3) of 14.1 through 14.7.	Established a maintenance and testing program for stand alone DME but provided incomplete data for more than three (3) and up to and including six (6) of 14.1 through 14.7.	Did not establish any maintenance and testing program for DME; OR The Transmission Owner or Generator Owner established a maintenance and testing program for DME but did not provide any data that

Standard PRC-002-NPCC-01— Disturbance Monitoring

	14.7.			meets all of 14.1 through 14.7.
R15 The Reliability Coordinator, Transmission Owner or Generator Owner provided recorded disturbance data from DMEs but was late for...	Up to and including fifteen (15) days in meeting the requests of an entity, or entities in 15.1, or 15.2.	More than fifteen (15) days but less than and including thirty (30) days in meeting the requests of an entity, or entities in 15.1 or 15.2.	More than 30 days but less than and including forty-five (45) days in meeting the requests of an entity, or entities in 15.1 or 15.2.	More than forty-five (45) days in meeting the requests of an entity, or entities in 15.1 or 15.2.
R16 The Reliability Coordinator, Transmission Owner or Generator Owner failed to submit...	Up to and including two (2) data files in a format that meets the applicable format requirements in 16.1 through 16.3.	More than two (2) and up to and including five (5) data files in a format that meets the applicable format requirements in 16.1 through 16.3.	More than five (5) and up to and including ten (10) data files in a format that meets the applicable format requirements in 16.1 through 16.3.	More than ten (10) data files in a format that meets the applicable format requirements in 16.1 through 16.3.
R17 The Reliability Coordinator, Transmission Owner or Generator Owner failed to maintain or provide to the Regional Entity , upon request...	Up to and including two (2) of the items in 17.1 through 17.8.	More than two (2) and up to and including four (4) of the items in 17.1 to 17.8.	More than four (4) and up to and including six (6) of the items in 17.1 through 17.8.	More than six (6) of the items in 17.1 through 17.8.

E. Associated Documents

Version History

Version	Date	Action	Change Tracking
1	November 4, 2010	Adopted by NERC Board of Trustees	New
1	October 20, 2011	FERC Order issued approving PRC-002-NPCC-01 (FERC’s Order became effective on October 20, 2011)	



NORTHEAST POWER COORDINATING COUNCIL, INC.
1040 AVE. OF THE AMERICAS, NEW YORK, NY 10018 (212) 840-1070 FAX (212) 302-2782

March 31, 2016

To: NERC Board of Trustees

Subject: Request for Approval, Retirement of NPCC Regional Reliability Standard PRC-002-NPCC-01 *Disturbance Monitoring*.

On March 23, 2016 in accordance with the NPCC Regional Standard Processes Manual the NPCC Board of Directors approved the retirement of NPCC Regional Standard PRC-002-NPCC-01 *Disturbance Monitoring*.

The subject standard was originally adopted by the NERC Board of Trustees on November 4, 2010 and approved by the FERC on October 20, 2011. The standard was subject to enforcement on October 20, 2013. FERC recently approved the NERC continent-wide standard PRC-002-2 *Disturbance Monitoring and Reporting Requirements*, which becomes enforceable on July 1, 2016. NPCC participated in the development of the continent-wide standard and attributes of the Regional standard were incorporated into PRC-002-2.

Upon approval of the continent-wide standard by the FERC, NPCC's Task Force on System Protection, acting as a standard review/drafting team, initiated an analysis to determine if there was a reliability related need to maintain the Regional standard. The results of the review, as attached, indicated that the continent-wide standard's requirements were sufficient and redundant in their objectives with the Regional standard and identified where any differences are addressed by NPCC's existing more stringent reliability criteria.

Further, in accordance with the NERC "Regional Reliability Standards Evaluation Procedure 2.1", the proposal to retire the standard has been posted by NERC and no non-supportive comments were received.

Accordingly, NPCC is requesting that PRC-002-NPCC-01 be retired effective the later of July 1, 2016 or the date the retirement is approved by the applicable regulatory authorities. Contingent upon the approval of the NERC BOT, NPCC will work with NERC Legal Staff in order to prepare the necessary filings and petitions.

Thank you for your consideration.

Ruida Shu
Northeast Power Coordinating Council, Inc.
Senior Engineer, Reliability Standards and Criteria
Main: 212-840-1070
Direct: 917-934-7976
Fax: 212-302-2782
Email: rshu@npcc.org

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

LOCATIONS FOR DATA CAPTURE (SER, FR)	LOCATIONS FOR DATA CAPTURE (SER, FR)	LOCATIONS FOR DATA CAPTURE (SER, FR)		
<p>R1. Each Transmission Owner and Generator Owner shall provide Sequence of Event (SER) recording capability by installing Sequence of Event recorders or as part of another device, such as a Supervisory Control And Data Acquisition (SCADA) Remote Terminal Unit (RTU), a generator plant Digital (or Distributed) Control System (DCS) or part of Fault recording equipment. This capability shall:</p> <p>1.1 Be provided at all substations and at locations where circuit breaker operation affects continuity of service to radial Loads greater than 300MW, or the operation of which drops 50MVA Nameplate Rating or greater of Generation, or the operation of which creates a Generation/Load island.</p> <p>Be provided at generating units above 50MVA Nameplate Rating or series of generating units utilizing a control scheme such that the loss of 1 unit results in a loss of greater than 50MVA Nameplate Capacity, and at Generating Plants above 300MVA Name Plate Capacity.</p> <p>1.2 Monitor the following at each location listed in 1.1:</p> <p>1.2.1 Transmission and Generator circuit breaker positions</p> <p>1.2.2 Protective Relay tripping for all Protection Groups that operate to trip circuit breakers identified in 1.2.1.</p> <p>1.2.3 Teleprotection keying and receive</p> <p>R2. Each Transmission Owner shall provide Fault recording capability for the following Elements at facilities where Fault recording equipment is required to be installed as per R3:</p> <p>2.1 All transmission lines.</p> <p>2.2 Autotransformers or phase-shifters connected to busses.</p> <p>2.3 Shunt capacitors, shunt reactors.</p> <p>2.4 Individual generator line interconnections.</p> <p>2.5 Dynamic VAR Devices.</p> <p>2.6 HVDC terminals.</p> <p>R7. Each Reliability Coordinator shall establish its area's requirements for Dynamic Disturbance</p>	<p>R1. Each Transmission Owner shall:</p> <p>1.1. Identify BES buses for which sequence of events recording (SER) and fault recording (FR) data is required by using the methodology in PRC-002-2, Attachment 1.</p> <p>1.2. Notify other owners of BES Elements connected to those BES buses, if any, within 90-calendar days of completion of Part 1.1, that those BES Elements require SER data and/or FR data.</p> <p>1.3. Re-evaluate all BES buses at least once every five calendar years in accordance with Part 1.1 and notify other owners, if any, in accordance with Part 1.2, and implement the re-evaluated list of BES buses as per the Implementation Plan.</p>	<p>3.2. Sequence of Event recorders shall be provided at all bulk power system substations and at generating units above 50 MW capacity, and at generating plants above 300 MW capacity</p> <p>4.3 Fault recording capability shall be provided by the GO for generating units above 200 MW capacity.</p> <p>4.4 Fault recorders shall monitor the following elements at each location where fault recorders are installed:</p> <ul style="list-style-type: none"> - All BPS Transmission Lines - Autotransformers or phase-shifters connected to BPS busses - Shunt capacitors 345 kV and above - Individual generator interconnections - Dynamic Var Devices - HVDC Terminals - A Transmission Owner may optionally include the monitoring of transformers serving load from a BPS bus. <p>5.2 On an Area basis, there shall be at least ten (10) DDRs per 30,000 MW of peak load, distributed throughout the system, and installed at various types of locations, with consideration given to the following factors:</p> <ul style="list-style-type: none"> - Major load centers - Major generation clusters - Major voltage sensitive areas - Major transmission interfaces - Major transmission junctions - Elements associated with Interconnection Reliability Operating Limits (IROLs) - Major EHV interconnections between control areas. <p>5.3 An evaluation of the need for a DDR should be made upon each new major BPS installation and upon each bulk power system station addition or expansion where a fault recorder replacement project is being made. (A field for this purpose will be included in the next revision of Document C-22.)</p> <p>5.4 DDRs shall monitor the following elements at each location where dynamic recorders are installed:</p> <ul style="list-style-type: none"> - Most lines such that normal maintenance 	<p>Because of its Attachment 1 Methodology for Selecting Buses for Capturing Sequence of Events Recording (SER) and Fault Recording (FR) Data in PRC-002-2, PRC-002-2 does not require SER coverage at as many buses as PRC-002-NPCC-01. There is no FR or SER required by PRC-002-2 from generators.</p> <p>Locations requiring monitoring in PRC-002-NPCC-01 were amended by Compliance Guidance Statements CGS-002 Defining Generator Materiality for Registration dated May 4, 2009 (to be retired 7/1/16), CGS-004 Generating Plant Capacity in PRC-002-NPCC-01 dated March 20, 2013, and CGS-005 Clarification of Monitoring and Enforcement of PRC-002-NPCC-01.</p>	<p>Specifics provided in the sections below on SOE (PRC-002-NPCC-01), SER (PRC-002-2), Fault recording (FR), and DDR.</p>

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

**Differences Between PRC-002-
NPCC-01 and PRC-002-2**

A-15 Revisions Needed

<p>Recording (DDR) capability that:</p> <ul style="list-style-type: none">7.1 Provides a minimum of 1 DDR per 3,000 MW of peak Load.7.2 Records dynamic disturbance information with consideration of the following facilities/locations:<ul style="list-style-type: none">7.2.1 Major Load centers.7.2.2 Major Generation clusters.7.2.3 Major voltage sensitive areas.7.2.4 Major transmission interfaces.7.2.5 Major transmission junctions.7.2.6 Elements associated with Interconnection Reliability Operating Limits (IROLs).7.2.7 Major EHV interconnections between operating areas.		<p>activities do not interfere with DDR requirements. - Bus voltages</p>		
---	--	--	--	--

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

<u>SOE</u>	<u>SER</u>	<u>SOE</u>		
<p>R1. Each Transmission Owner and Generator Owner shall provide Sequence of Event (SER) recording capability by installing Sequence of Event recorders or as part of another device, such as a Supervisory Control And Data Acquisition (SCADA) Remote Terminal Unit (RTU), a generator plant Digital (or Distributed) Control System (DCS) or part of Fault recording equipment. This capability shall:</p> <p>1.1 Be provided at all substations and at locations where circuit breaker operation affects continuity of service to radial Loads greater than 300MW, or the operation of which drops 50MVA Nameplate Rating or greater of Generation, or the operation of which creates a Generation/Load island.</p> <p>Be provided at generating units above 50MVA Nameplate Rating or series of generating units utilizing a control scheme such that the loss of 1 unit results in a loss of greater than 50MVA Nameplate Capacity, and at Generating Plants above 300MVA Name Plate Capacity.</p> <p>1.2 Monitor the following at each location listed in 1.1:</p> <p>1.2.1 Transmission and Generator circuit breaker positions</p> <p>1.2.2 Protective Relay tripping for all Protection Groups that operate to trip circuit breakers identified in 1.2.1.</p> <p>1.2.3 Teleprotection keying and receive</p>	<p>R2. Each Transmission Owner and Generator Owner shall have SER data for circuit breaker position (open/close) for each circuit breaker it owns connected directly to the BES buses identified in Requirement R1 and associated with the BES Elements at those BES buses.</p>	<p>3.2. Sequence of Event recorders shall be provided at all bulk power system substations and at generating units above 50 MW capacity, and at generating plants above 300 MW capacity</p> <p>3.3. Sequence of Events recording shall monitor the following at each location:</p> <ul style="list-style-type: none"> - Transmission and Generator circuit breaker positions - Protective Relay tripping for all protection groups - Teleprotection keying & receive 	<p>PRC-002-NPCC-01 is more specific and inclusive in the locations (substations and generating units) where SOE is to be provided (PRC-002-NPCC-01 Parts 1.1 and 1.2). Also more specific in that it specifies that SER is to be provided for protective relay tripping and teleprotection keying.</p>	<p>3.2--for generating units, 50MW to be changed to 50MVA, 300MW to 300MVA.</p> <p>Add radial loads greater than 300MW, or the operation of which creates a Generation/Load island.</p> <p>Bulk power system to be changed to Bulk Electric System.</p>

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

FAULT RECORDING	FAULT RECORDING	FAULT RECORDING		
<p>R2. Each Transmission Owner shall provide Fault recording capability for the following Elements at facilities where Fault recording equipment is required to be installed as per R3:</p> <p>2.1 All transmission lines. 2.2 Autotransformers or phase-shifters connected to busses. 2.3 Shunt capacitors, shunt reactors. 2.4 Individual generator line interconnections. 2.5 Dynamic VAR Devices. 2.6 HVDC terminals.</p> <p>R3. Each Transmission Owner shall have Fault recording capability that determines the Current Zero Time for loss of Bulk Electric System (BES) transmission Elements.</p> <p>R4. Each Generator Owner shall provide Fault recording capability for Generating Plants at and above 200 MVA Capacity and connected through a generator step up (GSU) transformer to a Bulk Electric System Element unless Fault recording capability is already provided by the Transmission Owner.</p> <p>R5. Each Transmission Owner and Generator Owner shall record for Faults, sufficient electrical quantities for each monitored Element to determine the following:</p> <p>5.1 Three phase-to-neutral voltages. (Common bus-side voltages may be used for lines.) 5.2 Three phase currents and neutral currents. 5.3 Polarizing currents and voltages, if used. 5.4 Frequency. 5.5 Real and reactive power.</p> <p>R6. Each Transmission Owner and Generator Owner shall provide Fault recording with the following capabilities:</p> <p>6.1 Each Fault recorder record duration shall be a minimum of one (1) second. 6.2 Each Fault recorder shall have a minimum recording rate of 16 samples per cycle</p>	<p>R3. Each Transmission Owner and Generator Owner shall have FR data to determine the following electrical quantities for each triggered FR for the BES Elements it owns connected to the BES buses identified in Requirement R1:</p> <p>3.1 Phase-to-neutral voltage for each phase of each specified BES bus. 3.2 Each phase current and the residual or neutral current for the following BES Elements: 3.2.1 Transformers that have a low-side operating voltage of 100kV or above. 3.2.2 Transmission Lines.</p> <p>R4. Each Transmission Owner and Generator Owner shall have FR data as specified in Requirement R3 that meets the following:</p> <p>4.1 A single record or multiple records that include: • A pre-trigger record length of at least two cycles and a total record length of at least 30-cycles for the same trigger point, or • At least two cycles of the pre-trigger data, the first three cycles of the post-trigger data, and the final cycle of the fault as seen by the fault recorder.</p> <p>4.2 A minimum recording rate of 16 samples per cycle. 4.3 Trigger settings for at least the following: 4.3.1 Neutral (residual) overcurrent. 4.3.2 Phase undervoltage or overcurrent.</p>	<p>4.1 Fault recording is the responsibility of transmission owners and generation owners. When adding or replacing a DFR at an existing BPS facility, the TO or GO should complete a notification in accordance with Document C-22.</p> <p>4.2 Fault recording shall be provided by the TO to determine the current zero time for loss of BPS transmission elements. The current zero time shall be reported as the time of the final current zero on the last phase to interrupt.</p> <p>4.3 Fault recording capability shall be provided by the GO for generating units above 200 MW capacity.</p> <p>4.4 Fault recorders shall monitor the following elements at each location where fault recorders are installed: - All BPS Transmission Lines - Autotransformers or phase-shifters connected to BPS busses - Shunt capacitors 345 kV and above - Individual generator interconnections - Dynamic Var Devices - HVDC Terminals - A Transmission Owner may optionally include the monitoring of transformers serving load from a BPS bus.</p> <p>4.5 Electrical quantities to be recorded for each monitored element shall be sufficient to determine the following: - Three phase-to-neutral voltages. (Common bus-side voltages may be used for lines.) - Three phase currents and neutral currents. - Polarizing currents and voltages, if used. - Frequency. - Active and reactive power.</p> <p>4.6 Fault recorder record duration shall be a minimum of one (1) second.</p> <p>4.7 Fault recorder minimum recording rate shall be 16 samples per cycle.</p> <p>4.8 As a minimum, fault recorders shall be set to trigger for all the following functions:</p>	<p>Because of its Attachment 1 <u>Methodology for Selecting Buses for Capturing Sequence of Events Recording (SER) and Fault Recording (FR) Data</u>, PRC-002-2 doesn't require SER coverage at as many buses as PRC-002-NPCC-01.</p> <p>Current Zero Time is not addressed in PRC-002-2.</p> <p>There NO FR required by PRC-002-2 from generators.</p> <p>PRC-002-2 does not require recording polarizing currents or voltages, frequency, and real and reactive power.</p> <p>PRC-002-NPCC-01 specifies a record duration of one (1) second. PRC-002-2 specifies "at least 30-cycles" or "two cycles of the pre-trigger data...and the final cycle of the fault..."</p> <p>PRC-002-NPCC-01 specifies fault recorder triggering for specified per unit values of rated CT secondary current, set per unit values of neutral (residual) overcurrent, specified undervoltage per unit value, and documentation of additional triggers when necessary.</p>	<p>Triggering for monitored phase overcurrent set at 1.5 pu or less.</p> <p>4.4--Change BPS to BES Remove "345kV and above" from shunt capacitors Add shunt reactors</p> <p>4.1--Change BPS to BES</p> <p>4.2-- Change BPS to BES</p> <p>4.3--Change MW to MVA</p> <p>4.5--Change Active to Real</p> <p>4.8--Add monitored phase overcurrent set at 1.5 pu or less of rated CT secondary current Add "or greater" to "Phase undervoltage set at 0.85 pu"</p>

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

<p>6.3 Each Fault recorder shall be set to trigger for at least the following:</p> <p>6.3.1 Monitored phase overcurrents set at 1.5 pu or less of rated CT secondary current or Protective Relay tripping for all Protection Groups.</p> <p>6.3.2 Neutral (residual) overcurrent set at 0.2 pu or less of rated CT secondary current.</p> <p>6.3.3 Monitored phase undervoltage set at 0.85 pu or greater.</p> <p>6.4 Document additional triggers and deviations from the settings in 6.3.2 and 6.3.3 when local conditions dictate.</p>		<p>- Protective Relay tripping for all protection groups</p> <ul style="list-style-type: none">- Neutral (residual) overcurrent set at 0.2 pu rated CT secondary current- Phase undervoltage set at 0.85 pu <p>4.9 When local conditions require different settings or additional functions, such situations shall be documented.</p>		
---	--	--	--	--

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

DYNAMIC DISTURBANCE RECORDING	DYNAMIC DISTURBANCE RECORDING	DYNAMIC DISTURBANCE RECORDING		
<p>R7. Each Reliability Coordinator shall establish its area’s requirements for Dynamic Disturbance Recording (DDR) capability that:</p> <p>7.1 Provides a minimum of 1 DDR per 3,000 MW of peak Load.</p> <p>7.2 Records dynamic disturbance information with consideration of the following facilities/locations:</p> <p>7.2.1 Major Load centers.</p> <p>7.2.2 Major Generation clusters.</p> <p>7.2.3 Major voltage sensitive areas.</p> <p>7.2.4 Major transmission interfaces.</p> <p>7.2.5 Major transmission junctions.</p> <p>7.2.6 Elements associated with Interconnection Reliability Operating Limits (IROLs).</p> <p>7.2.7 Major EHV interconnections between operating areas.</p> <p>R8. Each Reliability Coordinator shall specify that DDRs installed, after the approval of this standard, function as continuous recorders.</p> <p>R9. Each Reliability Coordinator shall specify that DDRs are installed with the following capabilities:</p> <p>9.1 A minimum recording time of sixty (60) seconds per trigger event.</p> <p>9.2 A minimum data sample rate of 960 samples per second, and a minimum data storage rate for RMS quantities of six (6) data points per second.</p> <p>9.3 Each DDR shall be set to trigger for at least one of the following (based on manufacturers’ equipment capabilities):</p> <p>9.3.1 Rate of change of Frequency.</p> <p>9.3.2 Rate of change of Power.</p> <p>9.3.3 Delta Frequency (recommend 20 mHz change).</p> <p>9.3.4 Oscillation of Frequency.</p> <p>R10. Each Reliability Coordinator shall establish requirements such that the following quantities are monitored or derived where DDRs are installed:</p> <p>10.1 Line currents for most lines such that</p>	<p>R5. Each Responsible Entity shall:</p> <p>5.1 Identify BES Elements for which dynamic Disturbance recording (DDR) data is required, including the following:</p> <p>5.1.1 Generating resource(s) with:</p> <p>5.1.1.1 Gross individual nameplate rating greater than or equal to 500 MVA.</p> <p>5.1.1.2 Gross individual nameplate rating greater than or equal to 300 MVA where the gross plant/facility aggregate nameplate rating is greater than or equal to 1,000 MVA.</p> <p>5.1.2 Any one BES Element that is part of a stability (angular or voltage) related System Operating Limit (SOL).</p> <p>5.1.3 Each terminal of a high voltage direct current (HVDC) circuit with a nameplate rating greater than or equal to 300 MVA, on the alternating current (AC) portion of the converter.</p> <p>5.1.4 One or more BES Elements that are part of an Interconnection Reliability Operating Limit (IROL).</p> <p>5.1.5 Any one BES Element within a major voltage sensitive area as defined by an area with an in-service undervoltage load shedding (UVLS) program.</p> <p>5.2 Identify a minimum DDR coverage, inclusive of those BES Elements identified in Part 5.1, of at least:</p> <p>5.2.1 One BES Element; and</p> <p>5.2.2 One BES Element per 3,000 MW of the Responsible Entity’s historical simultaneous peak System Demand.</p> <p>5.3 Notify all owners of identified BES Elements, within 90-calendar days of completion of Part 5.1, that their respective BES Elements require DDR data when requested.</p> <p>5.4 Re-evaluate all BES Elements at least once</p>	<p>5.1 Where the DDR capability is deemed necessary by the Reliability Coordinator, the Reliability Coordinator shall provide guidance in setting triggers and shall monitor the performance of the DDR devices.</p> <p>5.2 On an Area basis, there shall be at least ten (10) DDRs per 30,000 MW of peak load, distributed throughout the system, and installed at various types of locations, with consideration given to the following factors:</p> <ul style="list-style-type: none"> - Major load centers - Major generation clusters - Major voltage sensitive areas - Major transmission interfaces - Major transmission junctions - Elements associated with Interconnection Reliability Operating Limits (IROLs) - Major EHV interconnections between control areas. <p>5.3 An evaluation of the need for a DDR should be made upon each new major BPS installation and upon each bulk power system station addition or expansion where a fault recorder replacement project is being made. (A field for this purpose will be included in the next revision of Document C-22.)</p> <p>5.4 DDRs shall monitor the following elements at each location where dynamic recorders are installed:</p> <ul style="list-style-type: none"> - Most lines such that normal maintenance activities do not interfere with DDR requirements. - Bus voltages <p>5.5 As a minimum, DDRs shall monitor one phase current per monitored element and two phase-to-neutral voltages of different elements. One of the monitored voltages shall be of the same phase as the monitored current.</p> <p>5.6 Electrical quantities to be recorded for each monitored element shall be sufficient to determine the following:</p> <ul style="list-style-type: none"> - Voltage, current, and frequency - Active and reactive power <p>5.7 DDRs installed after January 1, 2009 shall function</p>	<p>For non-continuous recorders, PRC-002-2 specifies triggered record lengths of at least 3 minutes versus 60 seconds for PRC-002-NPCC-01 (R9).</p> <p>PRC-002-2 specifies an output recording rate of at least 30 times per second. PRC-002-NPCC-01 specifies a minimum data storage rate of 6 data points per second.</p> <p>PRC-002-2 specifies an off nominal frequency trigger (if used).</p> <p>PRC-002-2 is specific on the rate of change of frequency trigger values (if used).</p> <p>PRC-002-2 specifies an undervoltage trigger (if used).</p> <p>PRC-002-NPCC-01 specifies a rate of change of Power trigger (if used).</p> <p>PRC-002-NPCC-01 specifies a Delta Frequency trigger (if used), and an oscillation of Frequency trigger (if used).</p> <p>PRC-002-2 stipulates that normal line maintenance does not interfere with DDR functionality for monitoring line currents.</p> <p>PRC-002-2 stipulates that normal bus maintenance does not interfere with DDR functionality for monitoring bus voltages.</p> <p>PRC-002-NPCC-01 addresses DDR installation. PRC-002-2 does not address equipment.</p>	<p>5.1--Add “The Reliability Coordinator shall request DDR capability, and shall, with Transmission Owners, and Generator Owners mutually agree on an implementation schedule.”</p> <p>5.2--Change “control” to “operating”.</p> <p>5.3--Change BPS to BES Change “bulk power System” to Bulk Electric System</p> <p>5.4--Revise first bullet to read “Lines and buses such that ...”</p> <p>5.4--“Bus voltages” should be “bus”.</p> <p>5.6--Change Active to real.</p> <p>Add 5.12: Each Reliability Coordinator shall document additional settings and deviations from the required trigger settings and the required list of monitored quantities and report this to NPCC upon request.</p>

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

<p>normal line maintenance activities do not interfere with DDR functionality.</p> <p>10.2 Bus voltages such that normal bus maintenance activities do not interfere with DDR functionality.</p> <p>10.3 As a minimum, one phase current per monitored Element and two phase-to-neutral voltages of different Elements. One of the monitored voltages shall be of the same phase as the monitored current.</p> <p>10.4 Frequency.</p> <p>10.5 Real and reactive power.</p> <p>R11. Each Reliability Coordinator shall document additional settings and deviations from the required trigger settings described in R9 and the required list of monitored quantities as described in R10, and report this to the Regional Entity (RE) upon request.</p> <p>R12. Each Reliability Coordinator shall specify its DDR requirements including the DDR setting triggers established in R9 to the Transmission Owners and Generator Owners.</p> <p>R13. Each Transmission Owner and Generator Owner that receives a request from the Reliability Coordinator to install a DDR shall acquire and install the DDR in accordance with R12. Reliability Coordinators, Transmission Owners, and Generator Owners shall mutually agree on an implementation schedule.</p>	<p>every five calendar years in accordance with Parts 5.1 and 5.2, and notify owners in accordance with Part 5.3 to implement the re-evaluated list of BES Elements as per the Implementation Plan.</p> <p>R6. Each Transmission Owner shall have DDR data to determine the following electrical quantities for each BES Element it owns for which it received notification as identified in Requirement R5: [Violation Risk Factor: Lower] [Time Horizon: Long-term Planning]</p> <p>6.1 One phase-to-neutral or positive sequence voltage.</p> <p>6.2 The phase current for the same phase at the same voltage corresponding to the voltage in Requirement R6, Part 6.1, or the positive sequence current.</p> <p>6.3 Real Power and Reactive Power flows expressed on a three phase basis corresponding to all circuits where current measurements are required. 6.4 Frequency of any one of the voltage(s) in Requirement R6, Part 6.1.</p> <p>R7. Each Generator Owner shall have DDR data to determine the following electrical quantities for each BES Element it owns for which it received notification as identified in Requirement R5:</p> <p>7.1 One phase-to-neutral, phase-to-phase, or positive sequence voltage at either the generator step-up transformer (GSU) high-side or low-side voltage level.</p> <p>7.2 The phase current for the same phase at the same voltage corresponding to the voltage in Requirement R7, Part 7.1, phase current(s) for any phase-to-phase voltages, or positive sequence current.</p> <p>7.3 Real Power and Reactive Power flows expressed on a three phase basis corresponding to all circuits where current measurements are required.</p> <p>7.4 Frequency of at least one of the voltages in Requirement R7, Part 7.1.</p> <p>R8. Each Transmission Owner and Generator Owner responsible for DDR data for the BES Elements identified in Requirement R5 shall have continuous data recording and storage. If the equipment was installed prior to the effective</p>	<p>as continuous recorders.</p> <p>5.8 Each device shall sample data at a rate of at least 960 samples per second (16 samples per cycle and shall store the RMS value of electrical quantities at a rate of at least 6 data points per second.)</p> <p>5.9 The following DDR triggers shall be considered where available based on manufacturers capability:</p> <ul style="list-style-type: none"> - Rate of change of Frequency - Rate of change of Power - Delta Frequency 20 mHz change - Oscillation of Frequency <p>5.10 When local conditions require different settings or additional functions, such situations shall be documented.</p> <p>5.11 When DDR triggers are used, duration of triggered records shall be a minimum of sixty (60) seconds.</p>		
--	--	---	--	--

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

	<p>date of this standard and is not capable of continuous recording, triggered records must meet the following:</p> <ul style="list-style-type: none">8.1 Triggered record lengths of at least three minutes.8.2 At least one of the following three triggers:<ul style="list-style-type: none">• Off nominal frequency trigger set at:<table border="0" style="margin-left: 20px;"><tr><td></td><td style="text-align: center;">Low</td><td style="text-align: center;">High</td></tr><tr><td>o Eastern Interconnection</td><td><59.75Hz</td><td>>61.0Hz</td></tr><tr><td>o Western Interconnection</td><td><59.55Hz</td><td>>61.0Hz</td></tr><tr><td>o ERCOT Interconnection</td><td><59.35Hz</td><td>>61.0 Hz</td></tr><tr><td>o Hydro-Quebec Interconnection</td><td><58.55Hz</td><td>>61.5Hz</td></tr></table>• Rate of change of frequency trigger set at:<table border="0" style="margin-left: 20px;"><tr><td>o Eastern Interconnection</td><td>< -0.03125 Hz/sec</td><td>>0.125 Hz/sec</td></tr><tr><td>o Western Interconnection</td><td>< -0.05625 Hz/sec</td><td>>0.125 Hz/sec</td></tr><tr><td>o ERCOT Interconnection</td><td>< -0.08125 Hz/sec</td><td>>0.125 Hz/sec</td></tr><tr><td>o Hydro-Quebec Interconnection</td><td>< -0.18125 Hz/sec</td><td>>0.1875 Hz/sec</td></tr></table>• Undervoltage trigger set no lower than 85 percent of normal operating voltage for a duration of 5 seconds. <p>R9. Each Transmission Owner and Generator Owner responsible for DDR data for the BES Elements identified in Requirement R5 shall have DDR data that meet the following:</p> <ul style="list-style-type: none">9.1 Input sampling rate of at least 960 samples per second.9.2 Output recording rate of electrical quantities of at least 30 times per second.		Low	High	o Eastern Interconnection	<59.75Hz	>61.0Hz	o Western Interconnection	<59.55Hz	>61.0Hz	o ERCOT Interconnection	<59.35Hz	>61.0 Hz	o Hydro-Quebec Interconnection	<58.55Hz	>61.5Hz	o Eastern Interconnection	< -0.03125 Hz/sec	>0.125 Hz/sec	o Western Interconnection	< -0.05625 Hz/sec	>0.125 Hz/sec	o ERCOT Interconnection	< -0.08125 Hz/sec	>0.125 Hz/sec	o Hydro-Quebec Interconnection	< -0.18125 Hz/sec	>0.1875 Hz/sec			
	Low	High																													
o Eastern Interconnection	<59.75Hz	>61.0Hz																													
o Western Interconnection	<59.55Hz	>61.0Hz																													
o ERCOT Interconnection	<59.35Hz	>61.0 Hz																													
o Hydro-Quebec Interconnection	<58.55Hz	>61.5Hz																													
o Eastern Interconnection	< -0.03125 Hz/sec	>0.125 Hz/sec																													
o Western Interconnection	< -0.05625 Hz/sec	>0.125 Hz/sec																													
o ERCOT Interconnection	< -0.08125 Hz/sec	>0.125 Hz/sec																													
o Hydro-Quebec Interconnection	< -0.18125 Hz/sec	>0.1875 Hz/sec																													

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

<p><u>TIME SYNCHRONIZATION</u></p> <p>R14. Each Transmission Owner and Generator Owner shall establish a maintenance and testing program for stand alone DME (equipment whose only purpose is disturbance monitoring) that includes:</p> <p>14.1 Maintenance and testing intervals and their basis.</p> <p>14.2 Summary of maintenance and testing procedures.</p> <p>14.3 Monthly verification of communication channels used for accessing records remotely (if the entity relies on remote access and the channel is not monitored to a control center staffed around the clock, 24 hours a day, 7 days a week (24/7)).</p> <p>14.4 Monthly verification of time synchronization (if the loss of time synchronization is not monitored to a 24/7 control center).</p> <p>14.5 Monthly verification of active analog quantities.</p> <p>14.6 Verification of DDR and DFR settings in the software every six (6) years.</p> <p>14.7 A requirement to return failed units to service within 90 days. If a DME device will be out of service for greater than 90 days the owner shall keep a record of efforts aimed at restoring the DME to service.</p>	<p><u>TIME SYNCHRONIZATION</u></p> <p>R10. Each Transmission Owner and Generator Owner shall time synchronize all SER and FR data for the BES buses identified in Requirement R1 and DDR data for the BES Elements identified in Requirement R5 to meet the following:</p> <p>10.1 Synchronization to Coordinated Universal Time (UTC) with or without a local time offset.</p> <p>10.2 Synchronized device clock accuracy within ± 2 milliseconds of UTC.</p>	<p><u>TIME SYNCHRONIZATION</u></p> <p>7.0 Time Synchronization</p> <p>Internal clocks in DME devices shall be time synchronized to within 2 milliseconds or less of Coordinated Universal Time (UTC) scale. The time zone shall be clearly identified as either universal time zone or local time zone.</p> <hr/> <p><u>PRC-018-1 Requirement</u></p> <p>R1. Each Transmission Owner and Generator Owner required to install DMEs by its Regional Reliability Organization (reliability standard PRC-002 Requirements 1-3) shall have DMEs installed that meet the following requirements:</p> <p>R1.1. Internal Clocks in DME devices shall be synchronized to within 2 milliseconds or less of Universal Coordinated Time scale (UTC)</p> <p>R1.2. Recorded data from each Disturbance shall be retrievable for ten calendar days.</p>	<p>PRC-002-2, and PRC-018-1 (to be retired 6 years after the implementation date for PRC-002-2) specify synchronization of ± 2 milliseconds and its coordination to UTC.</p>	<p>Section 6--Add 7.1: Monthly verification of time synchronization (if the loss of time synchronization is not monitored to a 24/7 control center).</p> <p><u>NOTE: This is also in B-26 Guide for Application of Disturbance Recording Equipment</u></p>
---	---	---	--	---

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

DATA SPECIFICATIONS	DATA SPECIFICATIONS	DATA SPECIFICATIONS		
<p>R15. Each Reliability Coordinator, Transmission Owner and Generator Owner shall share data within 30 days upon request. Each Reliability Coordinator, Transmission Owner, and Generator Owner shall provide recorded disturbance data from DMEs within 30 days of receipt of the request in each of the following cases:</p> <p>15.1 NERC, Regional Entity, Reliability Coordinator.</p> <p>15.2 Request from other Transmission Owners, Generator Owners within NPCC.</p> <p>R16. Each Reliability Coordinator, Transmission Owner and Generator Owner shall submit the data files conforming to the following format requirements:</p> <p>16.1 The data files shall be capable of being viewed, read, and analyzed with a generic COMTRADE analysis tool as per the latest revision of IEEE Standard C37.111.</p> <p>16.2 Disturbance Data files shall be named in conformance with the latest revision of IEEE Standard C37.232.</p> <p>16.3 Fault Recorder and DDR Files shall contain all monitored channels. SER records shall contain station name, date, time resolved to milliseconds, SER point name, status.</p>	<p>R11. Each Transmission Owner and Generator Owner shall provide, upon request, all SER and FR data for the BES buses identified in Requirement R1 and DDR data for the BES Elements identified in Requirement R5 to the Responsible Entity, Regional Entity, or NERC in accordance with the following:</p> <p>11.1 Data will be retrievable for the period of 10-calendar days, inclusive of the day the data was recorded.</p> <p>11.2 Data subject to Part 11.1 will be provided within 30-calendar days of a request unless an extension is granted by the requestor.</p> <p>11.3 SER data will be provided in ASCII Comma Separated Value (CSV) format following Attachment 2.</p> <p>11.4 FR and DDR data will be provided in electronic files that are formatted in conformance with C37.111, (IEEE Standard for Common Format for Transient Data Exchange (COMTRADE), revision C37.111-1999 or later.</p> <p>11.5 Data files will be named in conformance with C37.232, IEEE Standard for Common Format for Naming Time Sequence Data Files (COMNAME), revision C37.232-2011 or later.</p>	<p>6.1 Recorded disturbance data from DMEs shall be forwarded within 30 days of receipt of the request in each of the following cases:</p> <ul style="list-style-type: none"> - Request from NERC Disturbance Investigation Team - Request from NPCC Disturbance Investigation Team - Reliability Coordinator Request <p>6.2 Data forwarded shall be archived in its native format for a period of 3 years by the TO or GO.</p> <p>6.3 Disturbance data files shall be provided in a format which is capable of being viewed, read, and analyzed with a generic COMTRADE analysis tool (8).</p> <p>6.4 Disturbance Data files shall be named in conformance with IEEE C37.232 Recommended Practice for Naming Time Sequence Data Files.</p> <p>6.5 Fault Recorder and DDR Files shall contain all monitored channels. SER records shall contain station, date, time resolved to milliseconds, SER point name, status.</p> <p>6.6 Recorded data from each disturbance shall be retrievable for 10 calendar days. This requirement does not apply to relays unless those relays are designated as DME.</p> <hr/> <p>PRC-018-1 Requirement</p> <p>R1. Each Transmission Owner and Generator Owner required to install DMEs by its Regional Reliability Organization (reliability standard PRC-002 Requirements 1-3) shall have DMEs installed that meet the following requirements:</p> <p>R1.1. Internal Clocks in DME devices shall be synchronized to within 2 milliseconds or less of Universal Coordinated Time scale (UTC)</p> <p>R1.2. Recorded data from each Disturbance shall be retrievable for ten calendar</p>	<p>PRC-002-2 stipulates 30 days unless an extension is granted.</p> <p>PRC-002-2 and PRC-018-1 stipulate that data is retrievable for 10 calendar days.</p> <p>PRC-002-2 is more specific on the data parameters.</p> <p>PRC-002-NPCC-01 is more specific as to the time resolution for SER data.</p> <p>PRC-018-1 stipulates archiving of data for at least three years. A-15 specifies archiving for 3 years. <u>Note: PRC-018-1 is going to be retired in six years after the implementation period for PRC-002-2.</u></p>	<p>Section 6--</p> <p>NOTE: This is also in C-25 Procedure to Collect Power System Event Data for Analysis of System Performance</p>

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-
NPCC-01 and PRC-002-2

A-15 Revisions Needed

		<p>days.</p> <p>R4. The Transmission Owner and Generator Owner shall each provide Disturbance data (recorded by DMEs) in accordance with its Regional Reliability Organization's requirements (reliability standard PRC-002 Requirement 4).</p> <p>R5. The Transmission Owner and Generator Owner shall each archive all data recorded by DMEs for Regional Reliability Organization-identified events for at least three years.</p>		
--	--	--	--	--

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

<p><u>STATUS OF RECORDING CAPABILITY</u></p> <p>R14. Each Transmission Owner and Generator Owner shall establish a maintenance and testing program for stand alone DME (equipment whose only purpose is disturbance monitoring) that includes:</p> <p>14.1 Maintenance and testing intervals and their Basis.</p> <p>14.2 Summary of maintenance and testing procedures.</p> <p>14.3 Monthly verification of communication channels used for accessing records remotely (if the entity relies on remote access and the channel is not monitored to a control center staffed around the clock, 24 hours a day, 7 days a week (24/7)).</p> <p>14.4 Monthly verification of time synchronization (if the loss of time synchronization is not monitored to a 24/7 control center).</p> <p>14.5 Monthly verification of active analog quantities.</p> <p>14.6 Verification of DDR and DFR settings in the software every six (6) years.</p> <p>14.7 A requirement to return failed units to service within 90 days. If a DME device will be out of service for greater than 90 days the owner shall keep a record of efforts aimed at restoring the DME to service.</p>	<p><u>STATUS OF RECORDING CAPABILITY</u></p> <p>R12. Each Transmission Owner and Generator Owner shall, within 90-calendar days of the discovery of a failure of the recording capability for the SER, FR or DDR data, either:</p> <ul style="list-style-type: none">• Restore the recording capability, or• Submit a Corrective Action Plan (CAP) Regional Entity and implement it.	<p><u>STATUS OF RECORDING CAPABILITY</u></p> <p>8.0 Maintenance And Testing</p> <p>Each TO, and GO shall establish a maintenance and testing program for DME (guidance for maintenance and testing is provided in Document B-26) that includes:</p> <ul style="list-style-type: none">• Maintenance and testing intervals and their basis.• Summary of maintenance and testing procedures. <hr/> <p><u>PRC-018-1 Requirement</u></p> <p>R6. Each Transmission Owner and Generator Owner that is required by its Regional Reliability Organization to have DMEs shall have a maintenance and testing program for those DMEs that includes:</p> <p>R6.1. Maintenance and testing intervals and their basis.</p> <p>R6.2. Summary of maintenance and testing procedures.</p>		<p>With the exception of PRC-002-NPCC-01 Part 14.4 (time synchronization), Requirement R14 to be added.</p> <p><u>NOTE: This is also in B-26 Guide for Application of Disturbance Recording Equipment</u></p>
---	---	---	--	--

PRC-002-NPCC-01 REQUIREMENTS

PRC-002-2 REQUIREMENTS

A-15

Differences Between PRC-002-NPCC-01 and PRC-002-2

A-15 Revisions Needed

<u>DATA ON THE DISTURBANCE MONITORING EQUIPMENT</u>	<u>DATA ON THE DISTURBANCE MONITORING EQUIPMENT</u>	<u>DATA ON THE DISTURBANCE MONITORING EQUIPMENT</u>		
<p>R17. Each Reliability Coordinator, Transmission Owner and Generator Owner shall maintain, record and provide to the Regional Entity (RE), upon request, the following data on the DMEs installed to meet this standard:</p> <ul style="list-style-type: none"> 17.1 Type of DME. 17.2 Make and model of equipment. 17.3 Installation location. 17.4 Operational Status. 17.5 Date last tested. 17.6 Monitored Elements. 17.7 All identified channels. 17.8 Monitored electrical quantities. 	<p>Not Applicable.</p>	<p>6.7 The TO and GO shall each maintain and be ready to report to NPCC on request the following data on the DMEs installed to meet this standard:</p> <ul style="list-style-type: none"> - Type of DME - Make and model of equipment - Installation location - Operational Status - Date last tested - Monitored Elements - Monitored Devices - Monitored Electrical Quantities 	<p>No gaps with PRC-018-1.</p>	<p>6.7--Revise "Monitored Devices" bullet to read "All identified channels"</p>
		<p><u>PRC-018-1 Requirement</u></p>		
		<p>R3. The Transmission Owner and Generator Owner shall each maintain, and report to its Regional Reliability Organization on request, the following data on the DMEs installed to meet that region's installation requirements (reliability standard PRC-002 Requirements 1.1, 2.1 and 3.1):</p> <ul style="list-style-type: none"> R3.1. Type of DME (sequence of event recorder, fault recorder, or dynamic disturbance recorder). R3.2. Make and model of equipment. R3.3. Installation location. R3.4. Operational status. R3.5. Date last tested. R3.6. Monitored elements, such as transmission circuit, bus section, etc. R3.7. Monitored devices, such as circuit breaker, disconnect status, alarms, etc. R3.8. Monitored electrical quantities, such as voltage, current, etc. 		

PRC-002-NPCC-02 Disturbance Monitoring Draft Team Roster

Name:	Company:	Qualifications:
Don Burkart	Con Edison	Don has 5 years in relay protection engineering and have had countless experiences in system event analyses. Additionally, He is the Lead Disciple Engineer for the company wide DME programs.
Robert Grabovickic	National Grid	Responsibilities include the analysis of events and system disturbances, protection co-ordination studies, calculations of settings for protection relays and disturbance fault recorders (DFRs), configuration of DFRs for NY PMU project, reviewing the relay settings of generators owned by customers, the development of protection standards.
Tim Kucey	PSEG	Member of current NPCC PRC-002-NPCC review SDT (joined SDT in 2013 in response to membership solicitation). Co-lead of the “Tools and Training” team of the NERC investigation of the August 2003 Northeast Blackout. Responsible for the bulk of the team’s findings/discoveries – and the associated write-ups in the NERC and US-Canada Bilateral Commission reports - regarding key entities’ implementation, usage and the performance of system monitoring and analysis “tools” (e.g. EMS, RTCAs, SEs) involved in the incident. For the period 1994 through to 2002, technical positions with process and power industry DCS/EMS, SCADA and RTU OEMs: Fisher-Rosemount (now Emerson); Moore Process Control (now Siemens); GE Harris (previously Westronics, HDAP; now GE Power). NERC Manager of Enforcement and Mitigation from 2006 until 2010, then NERC’s CEA agent (Manager of NOP Development) until late 2011. Duties included review of all compliance actions taken by NERC to the NERC BOT Compliance Committee, frequent engagement with the CCC and the Standards Committee, FERC staff, SDTs. Also involvement in several NERC events analyses/investigations and joint NERC-FERC 1B actions, typically involving transmission organizations, balancing authorities and reliability coordinators.
Brian Evans-Mongeon	Utility Services	As a prior member of the drafting team, he believe that he is qualified to serve again. He has been involved in numerous drafting teams including EOP-004, PRC-006 for both NPCC and NERC, BES, and Dispersed Generating Resources. He also serve on the NPCC RCC and the NERC PC, ERSTF, and RBRTF.
Robert Pellegrini	UI	Involved in designing P&C SCADA systems
Jim Watson	Dynergy	He has been employed in the electric utility industry for 33 years in the areas of generation operations, planning, and environmental compliance and for the last 4 years – NERC compliance.
George Wegh	Eversource	George has over 25 years of Electrical Engineering experience, of which 15 years have been in the utility industry. He is presently the Manager of Transmission Protection and Controls Engineering at Eversource Energy. He has been working in the Transmission Protection and Controls Department at Eversource Energy for over 8 years. He presently serve as the NPCC representative on the NERC System Protection and Controls Subcommittee (SPCS) and am Vice Chairman of the NPCC Task Force on System Protection (TFSP).
Paul Difilippo	Hydro One	28 years of experience in various aspects of protection systems at Hydro One including analysis of the 2003 Northeast blackout utilizing all available DME in Ontario. Member of TFSP since 2008 and current Chair. He is also the requester for the RSAR.
Ruida Shu	NPCC	NPCC Standards Staff. Ruida Shu has 8+ years of experience in

		Distribution, Transmission, SCADA, Construction, Daily Electric Operations, Facility Maintenance, Security, DOE/FEMA/APPA Grant Projects, Safety, Compliance and Reliability Standards.
Lee Pedowicz	NPCC	Manager of Reliability Standards at NPCC. Chair of PRC-002-2 Drafting Team. System operations real-time operating and outage scheduling, protective system testing, and substation design experience.
Daniel Kidney	NPCC	NPCC Compliance Staff. Daniel has been a member of the Compliance Enforcement staff at NPCC since 2014. Prior to joining NPCC, he was employed as a Transmission Planner at Central Maine Power.



NORTHEAST POWER COORDINATING COUNCIL, INC.
1040 AVE OF THE AMERICAS. NEW YORK. NY 10018 (212) 840-1070 FAX (212) 302-2782

November 16, 2015

Subject: Notification of (10) Day Ballot Period for Retirement of Regional Standard PRC-002-NPCC-01 Disturbance Monitoring

Dear Madam/Sir:

On October 8, 2015, in accordance with the NPCC Regional Standards Process Manual (RSPM), the NPCC Regional Standards Committee (RSC) acting on the recommendation of the PRC-002-NPCC-01 Drafting Team, initiated the process to retire NPCC Regional Standard [PRC-002-NPCC-01 Disturbance Monitoring](#).

The PRC-002-NPCC-01 standard drafting team was convened to address an RSC approved Regional Standard Authorization Request (RSAR) which proposed retiring PRC-002-NPCC-01 subsequent to FERC approval of PRC-002-2 *Disturbance Monitoring and Reporting Requirements*. PRC-002-2 was approved by the FERC on September 25, 2015 without any directives issued.

In accordance with the RSPM the retirement of PRC-002-NPCC-01 must be initially approved by the NPCC Full and General Members, with subsequent approvals by the NPCC Board of Directors, NERC Board of Trustees and finally filing with the applicable governmental authorities.

The PRC-002-NPCC-01 standard and all supporting documentation have been posted on the NPCC Website for a ten (10) day ballot period beginning November 16th, 2016.

<https://www.npcc.org/Standards/SitePages/DevStandardDetail.aspx?DevDocumentId=120>

Please contact me with any questions.

Thank you.

Ruida Shu
Northeast Power Coordinating Council, Inc.
Senior Engineer, Reliability Standards and Criteria
Main: 212-840-1070
Direct: 917-934-7976
Fax: 212-302-2782
Email: rshu@npcc.org



NORTHEAST POWER COORDINATING COUNCIL, INC.
1040 AVE. OF THE AMERICAS, NEW YORK, NY 10018 (212) 840-1070 FAX (212) 302-2782

December 2nd, 2015

NPCC Full and General Members:

In accordance with the NPCC Regional Standard Processes Manual the ballot period for the retirement of NPCC Regional Standard PRC-002-NPCC-01 Disturbance Monitoring closed at 23:59PM on November 26th, 2015.

The results of the ballot were as follows:

Quorum: 69% of the Total Registered

Approval: 97.10%

No negative ballots were received with comments therefore, in accordance with our Standards Processes Manual a recommendation for final Regional approval will be sent to the NPCC Board of Directors for consideration at their meeting on February 2, 2016.

Contingent upon the approval of the NPCC BOD, the proposal to retire PRC-002-NPCC-01 will be submitted to the NERC Board of Trustees with subsequent filings with the FERC and applicable provincial authorities.

Voting was conducted electronically and the full retirement record for the standard may be viewed at:

<https://www.npcc.org/Standards/SitePages/DevStandardDetail.aspx?DevDocumentId=120>

Thank you for your participation.

Ruida Shu
Northeast Power Coordinating Council, Inc.
Senior Engineer, Reliability Standards and Criteria
Main: 212-840-1070
Direct: 917-934-7976
Fax: 212-302-2782
Email: rshu@npcc.org

NPCC Registered Members	1. Determine Quorum			2. Vote/Ballot Recording		
	In Attendance (denote w/ 1)	By Proxy (denote w/ 1)		Affirmative (denote w/ 1)	Negative (denote w/ 1)	Abstain (denote w/ 1)
Sector 1, Transmission Owners	19	15	0	14	0	1
Central Hudson Gas and Electric Corporation	1	1		1		
Central Maine Power Company	1	1		1		
Consolidated Edison Company of New York, Inc.	1	1		1		
Emera Maine	1	1				1
Eversource	1	1		1		
Hydro One Inc	1	1		1		
Hydro-Quebec TransEnergie	1	1		1		
Long Island Power Authority	1	1		1		
National Grid	1	1		1		
New Brunswick Power Transmission Corporation	1	1		1		
New Hampshire Transmission, LLC	1					
New York Power Authority	1	1		1		
New York State Electric & Gas	1					
Nova Scotia Power Inc.	1	1		1		
NStar Electric Company	1					
Orange and Rockland Utilities Inc	1	1		1		
Rochester Gas & Electric	1	1		1		
The United Illuminating Company	1	1		1		
Vermont Transco	1					

NPCC Registered Members	1. Determine Quorum		2. Vote/Ballot Recording		
	In Attendance (denote w/ 1)	By Proxy (denote w/ 1)	Affirmative (denote w/ 1)	Negative (denote w/ 1)	Abstain (denote w/ 1)
Sector 2, Reliability Coordinators	5	5	0	5	0
Hydro-Quebec TransEnergie	1	1		1	
Independent Electricity System Operator	1	1		1	
ISO-New England, Inc.	1	1		1	
New Brunswick System Operator	1	1		1	
New York Independent System Operator	1	1		1	

NPCC Registered Members	1. Determine Quorum			2. Vote/Ballot Recording		
	In Attendance (denote w/ 1)	By Proxy (denote w/ 1)		Affirmative (denote w/ 1)	Negative (denote w/ 1)	Abstain (denote w/ 1)
Sector 3, TDUs, Dist. And LSE	20	13	0	12	0	1
Braintree Electric Light Department	1	1		1		
Consolidated Edison Company of New York, Inc.	1	1		1		
Eversource	1					
Groton Electric Light	1	1		1		
Hingham Municipal Lighting Plant	1	1		1		
Hydro One Inc	1	1		1		
Hydro Quebec Distribution	1	1		1		
Ipswich Municipal Light Department	1					
Long Island Power Authority	1	1		1		
Marblehead Municipal Light Department	1					
National Grid	1	1		1		
New York Power Authority	1					
Orange and Rockland Utilities Inc	1	1		1		
Princeton Municipal Light Department	1	1		1		
Shrewsbury Electric & Cable Operations	1	1		1		
Sterling Municipal Light Department	1					
Toronto Hydro Electric System Ltd.	1					
Vermont Electric Cooperative, Inc.	1					
Wakefield Municipal Gas and Light Department	1	1				1
Westfield Gas & Electric Light Department	1	1		1		

NPCC Registered Members	1. Determine Quorum			2. Vote/Ballot Recording		
	In Attendance (denote w/ 1)	By Proxy (denote w/ 1)		Affirmative (denote w/ 1)	Negative (denote w/ 1)	Abstain (denote w/ 1)
Sector 4, Generator Owners	22	17	0	17	0	0
Consolidated Edison Company of New York, Inc.	1	1		1		
Covanta Energy	1	1		1		
Dominion Resources Inc.	1	1		1		
Dynegy, Inc.	1	1		1		
Entergy Nuclear Northeast	1	1		1		
Eversouce	1	1		1		
Exelon Generation	1	1		1		
First Wind Operations & Maintenance	1	1		1		
International Power America	1					
Long Island Power Authority	1					
Massachusetts Municipal Wholesale Electric Company	1	1		1		
New York Power Authority	1	1		1		
NextEra Energy Resources	1	1		1		
NRG Energy Inc.	1	1		1		
Nova Scotia Power Inc.	1	1		1		
Ontario Power Generation Inc.	1					
PSEG Power Connecticut, LLC	1	1		1		
PSEG Power New York, LLC	1	1		1		
Talen Energy Marketing, LLC	1	1		1		
TransCanada	1					
US Power Generating Company, LLC	1					
Wheelabrator Westchester LP	1	1		1		

NPCC Registered Members	1. Determine Quorum			2. Vote/Ballot Recording		
	In Attendance (denote w/ 1)	By Proxy (denote w/ 1)		Affirmative (denote w/ 1)	Negative (denote w/ 1)	Abstain (denote w/ 1)
Sector 5, Marketers, Brokers, Aggregators	14	8	0	8	0	0
Brookfield Power Corporation	1	1		1		
Consolidated Edison Company of New York, Inc.	1	1		1		
Consolidated Edison Energy/Development	1					
Constellation New Energy, Inc.	1					
HQ Energy Marketing Inc.	1	1		1		
H.Q. Energy Services (U.S.) Inc.	1	1		1		
Long Island Power Authority	1					
Massachusetts Municipal Wholesale Electric Company	1	1		1		
Nalcor Energy	1					
New York Power Authority	1	1		1		
PSEG Energy Resources & Trade, LLC	1	1		1		
Shell Energy North America	1					
Utility Services Inc.	1	1		1		
Windy Bay Power, LLC	1					

NPCC Registered Members	1. Determine Quorum			2. Vote/Ballot Recording		
	In Attendance (denote w/ 1)	By Proxy (denote w/ 1)		Affirmative (denote w/ 1)	Negative (denote w/ 1)	Abstain (denote w/ 1)
Sector 6, State and Provincial Reg. and Govt.	7	4	0	4	0	0
Long Island Power Authority	1	1		1		
Maine Public Utilities Commission	1	1		1		
Massachusetts Attorney General	1	1		1		
New Hampshire Public Utilities Commission	1					
New York Power Authority	1	1		1		
New York State Department of Public Service	1					
Vermont Department of Public Service	1					

NPCC Registered Members	1. Determine Quorum			2. Vote/Ballot Recording		
	In Attendance (denote w/ 1)	By Proxy (denote w/ 1)		Affirmative (denote w/ 1)	Negative (denote w/ 1)	Abstain (denote w/ 1)
Sector 7, Sub Regional Rel. Councils, REs and	13	7	0	7	0	0
4g Technologies, LP	1					
Ascendant Energy Solutions, Inc.	1					
Energy Sector Security Consortium, Inc.	1					
ERLPhase Power Technologies	1	1		1		
International Business Machines Corporation	1					
McCoy Power Consultants, Inc.	1	1		1		
New York State Reliability Council, LLC	1	1		1		
Oxbow-Sherman Energy, LLC	1	1		1		
PLM, Inc.	1	1		1		
Preti, Flaherty, Beliveau, and Pachios, LLP.	1					
Proven Compliance Solutions, Inc.	1	1		1		
SGC Engineering, LLC	1	1		1		
VIASYN, Inc.	1					

Determine Electronic Quorum						
Sector	Sector Name	Total Registered	In Attendance	By Proxy	Total Represented	Sector % Attending
1	Transmission Owners	19	15	0	15	0.79
2	Reliability Coordinators	5	5	0	5	1.00
3	TDUs, Dist. And LSE	20	13	0	13	0.65
4	Generator Owners	22	17	0	17	0.77
5	Marketers, Brokers, Aggragators	14	8	0	8	0.57
6	Customers- large and small	7	4	0	4	0.57
7	State and Provincial Reg. and Govt. Authorities	13	7	0	7	0.54
		100	69	0	69	
Electronic Vote Quorum= at least 2/3 of the Total Registered						
Quorum Present?			YES			

Determine if Motion or Item Passes										
Sector	Sector Name	Total Registered	Sector % Attending	Affirmative		Negative		Abstain	Votes Cast	Sector has Voted(1- Y, 0-N)
				# of Votes	Fraction	# of Votes	Fraction	# of Votes	Total (-Abstentions)	
1	Transmission Owners	19	0.79	14	1.000	0	0.000	1	14	1
2	Reliability Coordinators	5	1.00	5	1.000	0	0.000	0	5	1
3	TDUs, Dist. And LSE	20	0.65	12	1.000	0	0.000	1	12	1
4	Generator Owners	22	0.77	17	1.000	0	0.000	0	17	1
5	Marketers, Brokers, Aggregators	14	0.57	8	1.000	0	0.000	0	8	1
6	Customers- large and small	7	0.57	4	1.000	0	0.000	0	4	1
7	State and Provincial Reg. and Govt. Authorities	13	0.54	7	1.000	0	0.000	0	7	1
Totals		100		67	7.000	0	0.000	2	67	7
Sum of Affirmative/Number of Sectors that Voted				1.000						
MUST BE AT LEAST 2/3 to pass										
Did MOTION PASS?				PASS						

REGIONAL STANDARDS COMMITTEE

Chairman:

Guy V. Zito
Assistant Vice President - Standards
Northeast Power Coordinating Council, Inc.
Tel. (212) 840-1070
Email: gzito@npcc.org

Co-Vice Chairman:

Si Truc Phan
Engineer – Reliability Standards & Operating Procedures
Reliability Coordinator
2 Complexe Desjardins, 19th floor, East Tower
Montreal, Québec, Canada H5B 1H7
Tel. (514) 879-4100 Ext. 3610
Email: phan.si_truc@hydro.qc.ca

Co-Vice Chairman:

Bruce Metruck
Director, Reliability Standards & Compliance
New York Power Authority
F.R. Clark Energy Center
6520 Glass Factory Road
Marcy, NY 13403
Tel. (315) 792-8213
Email: bruce.metruck@nypa.gov

Sector 1 - Transmission Owners

Hydro One Networks, Inc.

Primary

Paul Malozewski, P. Eng., MBA, PMP
Manager – Reliability Standards and Strategies
Tel. 416-345-5005
Email: paul.malozewski@hydroone.com

Alternate

Payam Farahbakhsh, M. Eng, P. Eng.
Network Management Engineer – Reliability
Standards and Strategies
Tel. (416) 345-5484
Email: Payam.Farahbakhsh@HydroOne.com

Consolidated Edison Company of New York, Inc.

Primary

Michael Forte
Chief Transmission Planning Engineer
Tel. (212) 460-3416
Fax (212) 529-1130
Email: fortem@coned.com

Alternate

Martin Paszek
Manager, Bulk Power System Performance and
Analysis
Tel. (212) 460-6415
Fax (212) 529-1130
Email: paszekm@coned.com

National Grid

Primary

Brian Shanahan
Lead Engineer
Transmission Control Center – NY
National Grid, US
Tel. (315) 460-4346
Email: brian.shanahan@nationalgrid.com

Alternate

Michael Schiavone
Director, Transmission Control Center – NY
National Grid, US
Tel. (315) 460-4472
Email: Michael.schiavone@nationalgrid.com

New Brunswick Power Corporation

Primary

Rob Vance, P.Eng.
Power System Engineer
Tel. (506) 458-3922
Email: rob.vance@nbpower.com

Alternate

The United Illuminating Company

Primary

Alternate

Sylvain Clermont
Manager Transmission Services
Tel. (514) 879-4648
Email: clermont.sylvain@hydro.qc.ca

Michele Tondalo
Compliance Analyst
180 Marsh Hill Road
Orange, Connecticut 06477
Tel. (203) 499-2542
Email: Michele.Tondalo@uinet.com

Hydro-Quebec TransÉnergie

Primary

Alternate

Sylvain Clermont
Manager Transmission Services
Tel. (514) 879-4648
Email: clermont.sylvain@hydro.qc.ca

Orange & Rockland Utilities, Inc.

Primary

Edward Bedder
Compliance Program Manager
Tel. (845) 577-3827
Fax (845) 577-3256
Email: beddere@ORU.com

Alternate

Boris Shulim
Section Manager – Substation & Transmission
Engineering
Orange and Rockland Utilities Inc.
390 West Route 59
Spring Valley NY 10977
845-577-3716
Email: shulimb@oru.com

Eversource Energy

Primary

Mark J. Kenny
Program Manager - Reliability Compliance
Eversource Energy
Westwood, MA 02090
Tel. (781) 441-8179
Cell. (617) 429-1837
Email: Mark.Kenny@eversource.com

Alternate

Quintin Lee
Program Manager - Reliability Compliance
Eversource Energy
780 North Commercial Street
Manchester, NH 03101
Office: (603) 634-3579
Cell: (603) 634-3562
Email: quintin.lee@eversource.com

Sector (2) - Reliability Coordinators

New York Independent System Operator

Primary

Gregory A. Campoli
Manager, Reliability Compliance & Industry
Affairs
Tel. (518) 356-6159
Email: gcampoli@nyiso.com

Alternate

James (Jim) Grant
Reliability Senior Engineer
Tel. (518) 356-6128
Email: jgrant@nyiso.com

ISO New England, Inc.

Primary

Kathleen M. Goodman
Senior Operations Compliance Coordinator
Tel. (413) 535-4111
Email: kgoodman@iso-ne.com

Alternate

Matthew Goldberg
Director of Reliability & Operations Compliance
Tel. (413) 535-4029
Email: mgoldberg@iso-ne.com

Independent Electricity System Operator

Primary

Helen Lainis
Senior Engineer/Technical Officer
Tel. (905) 855-4106
Email: helen.lainis@ieso.ca

Alternate

Scott Berry
Senior Engineer/Technical Officer
Tel. (905) 403-6912
Email: scott.berry@ieso.ca

Hydro-Quebec TransÉnergie

Primary

Si Truc Phan
Engineer – Reliability Standards & Operating
Procedures
Reliability Coordinator
2 Complexe Desjardins, 19th floor, East Tower
Montreal, Québec, Canada H5B 1H7
Tel. (514) 879-4100 Ext. 3610
Email: phan.si_truc@hydro.qc.ca

Alternate

Chantal Mazza
Direction Contrôle des Mouvements d'énergie
C.P. 10000, succ. pl Desjardins
Complexe Desjardins 19th floor
Montréal, QC H5B 1H7
Tel. (514) 879-4100 Ext. 5499
Email: mazza.chantal@hydro.qc.ca

New Brunswick Power Corporation

Primary

Randy MacDonald
Director, Corporate Compliance
Tel. (506) 458-4653
Cell. (506) 470-3536
Email: RaMacDonald@NBPower.com

Alternate

Sector (3) - Transmission Dependent Utilities (“TDUs”); Distribution Companies and Load-Serving Entities (“LSEs”)

Consolidated Edison Company of New York, Inc.

Primary

Kelly Silver
Engineer – Standards and Compliance
Room 1300 NW 4 Irving Place NY, NY 10003
Tel. (212) 460-4155
Fax (845) 577-3256
Email: silverk@coned.com

Alternate

Dermot Smyth
Senior Enigneer
Tel. (212) 460-4093
Fax (212) 529-1130
Email: smythd@coned.com

National Grid

Primary

Michael Jones
Lead Analyst – FERC Compliance
40 Sylvan Road
Waltham, Massachusetts 02451
Tel. (781) 907-2404
Email: michael.jones@nationalgrid.com

Alternate

Orange & Rockland Utilities, Inc.

Primary

David Burke
Senior Specialist - Compliance
Tel. (845) 577-2841
Fax (845) 577-2840
Email: burkeda@oru.com

Alternate

Ben Wu
Principal Engineer
Transmission & Substation Engineering
Tel. (845) 577-3713
Email: WUB@oru.com

Sector (4) - Generator Owners

Consolidated Edison Company of New York, Inc.

Primary

Peter Yost
Manager, Standards & Compliance
Tel. (212) 460-2889
Fax (212) 529-1130
Email: yostp@coned.com

Alternate

Robert Winston
Sr. Engineer
Tel. (212) 460-2790
Fax (212) 529-1130
Email: winstonr@coned.com

New York Power Authority

Primary

Wayne Sipperly
NERC Compliance Program Manager II
Tel. (914) 287-3753
Email: wayne.sipperly@nypa.gov

Alternate

Salvatore Spagnolo
Senior Reliability Standards & Compliance
Engineer I
Tel. (914) 390-8224
Mob. (347) 992-7015
Email: Salvatore.Spagnolo@nypa.gov

Dominion Resources Services, Inc.

Primary

Connie Lowe
NERC Compliance Policy Manager
Dominion Resources Services, Inc.
Tel. (804) 819-2917
Email: connie.lowe@dom.com

Alternate

Lou Oberski
Managing Director NERC Compliance Policy
Dominion Resources Services, Inc.
Tel. (804) 819-2837
Email: lou.oberski@dom.com

Ontario Power Generation, Inc.

Primary

David Ramkalawan, P.Eng.
Senior Manager - Reliability Compliance
Tel. (416) 592-6089
Email: david.ramkalawan@opg.com

Alternate

NextEra Energy, LLC

Primary

Silvia Parada Mitchell
Director, Reliability Standards & Compliance
Tel. (561) 904-3767
Email: silvia.parada.mitchell@fpl.com

Alternate

Summer Esquerre
Manager, Reliability Standards & Compliance
Tel. (561) 904-3765
Email: summer.esquerre@fpl.com

Alternate

Rogelio Moraitis
Compliance Analyst
Reliability Standards and Compliance
Tel. (561) 904-3402
Email: Rogelio.Moraitis@nee.com

Entergy Services, Inc

Primary

Glen Smith
NERC Compliance
Entergy Services, Inc
440 Hamilton Avenue
White Plains, NY 10601
914-272-3513
Email: gsmith@entergy.com

Alternate

Sector (5) - Marketers, Brokers and Aggregators

Consolidated Edison Company of New York, Inc.

Primary

Brian O'Boyle
Engineer
Tel. (212) 460-5596
Fax (212) 529-1130
Email: oboyleb@coned.com

Alternate

Alyson Slanover
Engineer
Tel. (212) 460-8351
Fax (212) 529-1130
Email: slanovera@coned.com

Utility Services, Inc.

Primary

Brian Robinson
Compliance Analyst
Tel. (802) 241-1400
Email: brian.robinson@utilitysvcs.com

Alternate

Brian Evans-Mongeon
President/CEO
Tel. (802) 241-1400
Email: brian.evans-mongeon@utilitysvcs.com

Sector (6) – State and Provincial Regulatory and/or Governmental Authorities

New York Power Authority

Primary

Bruce Metruck
NERC Compliance Program Manager II
F.R. Clark Energy Center
6520 Glass Factory Road
Marcy, NY 13403
Tel. (315) 792-8213
Email: bruce.metruck@nypa.gov

Alternate

Shivaz Chopra
RSC Engineer II, Technical Compliance
Tel. (914) 681-6828
Email: shivaz.chopra@nypa.gov

New York State Department of Public Service

Primary

Vijay Puran
Utility Engineer 3
Tel. (518) 486-5948
Email: vijay.puran@dps.ny.gov

Alternate

Jerry Ancona
Senior Engineer
Tel. (315) 428-5160
Email: Jerry.Ancona@dps.ny.gov

Sector 7 – Sub-Regional Reliability Councils, Customers and Other Regional Entities and Interested Entities

New York State Reliability Council, LLC

Primary

Alan Adamson
Independent Consultant
2104 Braxton Street
Clermont, FL 34711
Tel. (352) 989-4653
Email: aadamson@nycap.rr.com

Alternate