

§ 25.26-50 Servicing of EPIRBs.

(a) The master of each vessel required to have an EPIRB under this subpart shall ensure that each EPIRB on board is tested and serviced as required by this section.

(b) The EPIRB must be tested immediately after installation and at least once each month thereafter, unless it is an EPIRB installed in a Coast Guard approved inflatable liferaft that is tested annually during the servicing of the liferaft by an approved servicing facility. The test shall be conducted in accordance with the manufacturer's instructions, using the visual or audio indicator on the EPIRB. If the EPIRB is not operating, it must be repaired or replaced with an operating EPIRB.

(c) The battery of the EPIRB must be replaced—

(1) Immediately after the EPIRB is used for any purpose other than being tested; and

(2) Before the expiration date that is marked on the battery.

[CGD 87-016a, 58 FR 13367, Mar. 10, 1993; 58 FR 27658, May 11, 1993]

§ 25.26-60 Exemptions.

(a) A skiff or work boat is not required to carry an EPIRB if—

(1) Its "mother ship" is required to carry an EPIRB under this subpart; and

(2) When not in use, the skiff or work boat is carried on board the mother ship.

(b) Each Coast Guard District Commander may, on a case-by-case basis, grant exemptions from the carriage requirements of EPIRBs in this subpart for certain geographic areas within the boundaries of his or her own district if the District Commander determines that an EPIRB will not significantly enhance the overall safety of the vessel and crew. Exemptions may be limited to specific time periods. Exemptions granted under this paragraph must be:

(1) Issued in writing by the cognizant Coast Guard District Commander for each individual application; and

(2) For geographic locations and may be limited to specific time periods.

Subpart 25.30—Fire Extinguishing Equipment**§ 25.30-1 Application.**

(a) The provisions of this subpart, with the exception of § 25.30-90, shall apply to all vessels contracted for on or after November 19, 1952. Vessels contracted for prior to that date shall meet the requirements of § 25.30-90.

§ 25.30-5 General provisions.

(a) Where equipment in this subpart is required to be of an approved type, such equipment requires the specific approval of the Commandant. Such approvals are published in the FEDERAL REGISTER, and in addition, are contained in Coast Guard publication COMDTINST M16714.3 (Series), Equipment Lists.

(b) All hand portable fire extinguishers, semiportable fire extinguishing systems, and fixed fire extinguishing systems shall be of an approved type.

[CGFR 65-50, 30 FR 16653, Dec. 30, 1965, as amended by CGD 96-041, 61 FR 50726, Sept. 27, 1996]

§ 25.30-10 Hand portable fire extinguishers and semiportable fire extinguishing systems.

(a) Hand portable fire extinguishers and semiportable fire extinguishing systems are classified by a combination letter and number symbol. The letter indicating the type of fire which the unit could be expected to extinguish, and the number indicating the relative size of the unit.

(b) For the purpose of this subchapter, all required hand portable fire extinguishers and semiportable fire extinguishing systems are of the "B" type; i.e., suitable for extinguishing fires involving flammable liquids, greases, etc.

(c) The number designations for size will start with "I" for the smallest to "V" for the largest. For the purpose of this subchapter, only sizes I through III will be considered. Sizes I and II are considered hand portable fire extinguishers and sizes III, IV, and V are considered semiportable fire extinguishing systems which shall be fitted with suitable hose and nozzle or other practicable means so that all portions

§ 25.30-15

46 CFR Ch. I (10-1-02 Edition)

of the space concerned may be covered. Examples of size graduations for some of the typical hand portable fire extinguishers and semiportable fire extinguishing systems are set forth in Table 25.30-10(c).

TABLE 25.30-10(c)

Classification		Foam, gal- lons	Carbon Di- oxide, pounds	Dry chem- ical, pounds
Type	Size			
B	I	1¾	4	2
B	II	2½	15	10
B	III	12	35	20

(d) All hand portable fire extinguishers and semiportable fire extinguishing systems shall have permanently attached thereto a metallic name plate giving the name of the item, the rated capacity in gallons, quarts, or pounds, the name and address of the person or firm for whom approved, and the identifying mark of the actual manufacturer.

(e) Vaporizing-liquid type fire extinguishers containing carbon tetrachloride or chlorobromomethane or other toxic vaporizing liquids are not acceptable as equipment required by this subchapter.

(f) Hand portable or semiportable extinguishers which are required on their name plates to be protected from freezing shall not be located where freezing temperatures may be expected.

(g) The use of dry chemical, stored pressure, fire extinguishers not fitted with pressure gauges or indicating devices, manufactured prior to January 1, 1965, may be permitted on motorboats and other vessels so long as such extinguishers are maintained in good and serviceable condition. The following maintenance and inspections are required for such extinguishers:

(1) When the date on the inspection record tag on the extinguishers shows that 6 months have elapsed since last weight check ashore, then such extinguisher is no longer accepted as meeting required maintenance conditions until reweighed ashore and found to be in a serviceable condition and within required weight conditions.

(2) If the weight of the container is ¼ ounce less than that stamped on container, it shall be serviced.

(3) If the outer seal or seals (which indicate tampering or use when broken) are not intact, the boarding officer or marine inspector will inspect such extinguisher to see that the frangible disc in neck of the container is intact; and if such disc is not intact, the container shall be serviced.

(4) If there is evidence of damage, use, or leakage, such as dry chemical powder observed in the nozzle or elsewhere on the extinguisher, the container shall be replaced with a new one and the extinguisher properly serviced or the extinguisher replaced with another approved extinguisher.

(h) The dry chemical, stored pressure, fire extinguishers without pressure gauges or indicating devices manufactured after January 1, 1965, shall not be labeled with the marine type label bed in §162.028-4 of this title nor shall such extinguishers manufactured after January 1, 1965, be carried on board motorboats or other vessels as required equipment.

[CGFR 65-50, 30 FR 16653, Dec. 30, 1965, as amended by CGFR 68-32, 33 FR 5711, Apr. 12, 1968; CGFR 69-18, 34 FR 5723, Mar. 27, 1969]

§ 25.30-15 Fixed fire extinguishing systems.

(a) When a fixed fire extinguishing system is installed, it shall be of an approved carbon dioxide type, designed and installed in agreement with the applicable provisions of subpart 76.15 of subchapter H (Passenger Vessels) of this chapter.

§ 25.30-20 Fire extinguishing equipment required.

(a) *Motorboats.* (1) All motorboats shall carry at least the minimum number of hand portable fire extinguishers set forth in Table 25.30-20(a)(1), except that motorboats less than 26 feet in length, propelled by outboard motors and not carrying passengers for hire, need not carry such portable fire extinguishers if the construction of such motorboats will not permit the entrapment of explosive or flammable gases or vapors.