

Generic Environmental Impact Statement for Licensing of New Nuclear Reactors

Draft Report for Comment

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at the NRC's Library at www.nrc.gov/reading-rm.html. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources:

1. The Superintendent of Documents

U.S. Government Publishing Office
Washington, DC 20402-0001
Internet: <https://bookstore.gpo.gov/>
Telephone: (202) 512-1800
Fax: (202) 512-2104

2. The National Technical Information Service

5301 Shawnee Road
Alexandria, VA 22312-0002
Internet: <https://www.ntis.gov/>
1-800-553-6847 or, locally, (703) 605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: **U.S. Nuclear Regulatory Commission**
Office of Administration
Digital Communications and Administrative
Services Branch
Washington, DC 20555-0001
E-mail: Reproduction.Resource@nrc.gov
Facsimile: (301) 415-2289

Some publications in the NUREG series that are posted at the NRC's Web site address www.nrc.gov/reading-rm/doc-collections/nuregs are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library

Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute

11 West 42nd Street
New York, NY 10036-8002
Internet: www.ansi.org
(212) 642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licensee, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and the Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of the NRC's regulations (NUREG-0750), (6) Knowledge Management prepared by NRC staff or agency contractors (NUREG/KM-XXXX).

DISCLAIMER: This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

Generic Environmental Impact Statement for Licensing of New Nuclear Reactors

Draft Report for Comment

Manuscript Completed: September 2024
Date Published: September 2024

COMMENTS ON DRAFT REPORT

Any interested party may submit comments on this report for consideration by the NRC staff. Comments may be accompanied by additional relevant information or supporting data. Please specify the report number **NUREG-2249** in your comments and send them by the end of the comment period specified in the *Federal Register* notice announcing the availability of this report.

Addresses: You may submit comments by any one of the following methods. Please include Docket ID **NRC-2020-0101** in the subject line of your comments. Comments submitted in writing or in electronic form will be posted on the NRC website and on the Federal rulemaking website <http://www.regulations.gov>.

Federal Rulemaking Website: Go to <http://www.regulations.gov> and search for documents filed under Docket ID **NRC-2020-0101**.

Mail comments to: Office of Administration, Mail Stop: TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Division of Resource Management and Administration.

For any questions about the material in this report, please contact: Stacey Imboden, Senior Environmental Project Manager, at 301-415-2462 or by email at Stacey.Imboden@nrc.gov, or Laura Willingham, Senior Environmental Project Manager, at 301-415-0857 or by email at Laura.Willingham@nrc.gov.

Please be aware that any comments that you submit to the NRC will be considered a public record and entered in the Agencywide Documents Access and Management System (ADAMS). Do not provide information you would not want to be publicly available.

ABSTRACT

1

2 The U.S. Nuclear Regulatory Commission (NRC) staff prepared this generic environmental
3 impact statement (GEIS) in accordance with the National Environmental Policy Act of 1969
4 (NEPA), as amended, to address the NRC licensing of the building and operation of new
5 nuclear reactors in the United States. In this GEIS, the NRC staff uses the values and
6 assumptions in a technology-neutral plant parameter envelope (PPE) for a new nuclear reactor
7 to evaluate the environmental impacts of constructing and operating a nuclear reactor. In
8 addition, this GEIS assumes that a new reactor might be built anywhere in the United States
9 and territories that meets the requirements of the NRC's siting regulations. To accommodate
10 this broad range of siting possibilities, the staff developed a site parameter envelope (SPE) that
11 provides limiting values and assumptions related to the site.

12 The purpose and need for this GEIS is to present impact analyses for the environmental issues
13 that are common to many new nuclear reactors that can be addressed generically, thereby
14 eliminating the need to repeatedly reproduce the same analyses each time a licensing
15 application is submitted and allowing applicants and NRC staff to focus future environmental
16 review efforts on issues that can only be resolved once a site is identified. The results from this
17 GEIS will be codified in Title 10 of the *Code of Federal Regulations* Part 51. Applicants
18 submitting licensing applications for new nuclear reactors may cite the regulation for those
19 issues bounded by the PPE and SPE and related values and assumptions rather than
20 presenting application-specific analyses. The NRC staff performing environmental reviews may
21 cite the analyses in this GEIS for those same issues instead of addressing the issues
22 individually in application-specific documentation. By developing this GEIS, the NRC staff
23 expects to streamline the time and effort needed to complete environmental reviews under
24 NEPA for most new nuclear reactors.

25 This GEIS evaluates the potential environmental impacts of 122 issues relevant to building and
26 operation of a nuclear reactor. It identifies 100 issues as Category 1 issues. This number
27 includes issues for which potential environmental impacts have been generically determined to
28 be SMALL and adverse provided that the project is bounded by relevant PPE and SPE values
29 and assumptions, and issues for which the impacts are beneficial. The GEIS identifies 20 issues
30 as Category 2 issues and concludes that an application-specific analysis considering
31 site-specific conditions is necessary for those issues. Finally, as discussed in Section 1.3.3.3,
32 there are two issues that are designated as N/A (i.e., impacts are Uncertain), which are neither
33 Category 1 nor 2. Upon receipt of an application for a new nuclear reactor, the NRC staff would
34 prepare a supplemental environmental impact statement or other supplemental NEPA
35 documentation for the proposed project.

36 In general, an application for a new nuclear reactor can refer to the generic analysis in this GEIS
37 for any Category 1 issue without further analysis, if it demonstrates that the relevant values and
38 assumptions in the PPE and SPE are met and there is no new and significant information to
39 change the conclusions in this GEIS. If the relevant parameters and assumptions for a
40 Category 1 issue are not met, the applicant would have to supply the requisite information
41 necessary for the staff to perform a site-specific analysis. Applicants addressing Category 2
42 issues would have to provide all of the information typically needed to perform a site-specific
43 analysis.

1 The NRC staff also addresses a No-Action Alternative where the staff would not issue this GEIS
2 and would instead prepare individualized NEPA documentation when reviewing each incoming
3 new nuclear reactor licensing application. The NRC staff concluded that this alternative was not
4 environmentally preferable to the proposed action (development of this GEIS).

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35

TABLE OF CONTENTS

| | |
|--|-------------|
| ABSTRACT | iii |
| LIST OF FIGURES..... | xi |
| LIST OF TABLES | xiii |
| EXECUTIVE SUMMARY | xv |
| ABBREVIATIONS AND ACRONYMS | xxi |
| 1 INTRODUCTION | 1-1 |
| 1.1 Purpose and Need for this GEIS..... | 1-2 |
| 1.2 NEPA Process..... | 1-2 |
| 1.3 Analytical Approach Used in this GEIS | 1-3 |
| 1.3.1 Methodology | 1-3 |
| 1.3.2 Primary Documents Used to Develop this GEIS..... | 1-8 |
| 1.3.3 Issue Categories | 1-9 |
| 1.3.3.1 Category 1 Issues – Generic Analysis | 1-9 |
| 1.3.3.2 Category 2 Issues – Project-Specific Analysis..... | 1-9 |
| 1.3.3.3 Uncertain Issues..... | 1-13 |
| 1.4 Implementation of the Rule (10 CFR Part 51) | 1-18 |
| 1.4.1 General Requirements | 1-19 |
| 1.4.2 Applicant’s Environmental Report | 1-19 |
| 1.4.3 The NRC’s SEIS | 1-19 |
| 1.4.4 Public Scoping and Public Comments..... | 1-19 |
| 1.4.5 The NRC’s Draft SEIS..... | 1-20 |
| 1.4.6 The NRC’s Final SEIS..... | 1-20 |
| 2 DESCRIPTION OF PROPOSED ACTION AND ALTERNATIVES | 2-1 |
| 2.1 Proposed Action and Alternatives to the GEIS..... | 2-1 |
| 2.1.1 Proposed Action: Issue Technology-Neutral GEIS Based on Performance-Based Assumptions | 2-1 |
| 2.1.2 No-Action Alternative: No GEIS – Project-Specific National Environmental Policy Act Review Only | 2-2 |
| 2.1.3 Other Alternatives Considered but Not Analyzed in Detail..... | 2-2 |
| 2.1.3.1 Limiting the GEIS to Reactors Less than 30 MWt | 2-2 |
| 2.1.3.2 GEIS for Advanced Nuclear Reactors Only | 2-2 |
| 2.1.3.3 GEIS Analyzing All Potential Environmental Impacts..... | 2-3 |
| 3 AFFECTED ENVIRONMENT AND ENVIRONMENTAL CONSEQUENCES | 3-1 |
| 3.1 Land Use | 3-2 |

| | | | |
|----|---------|---|-------|
| 1 | 3.1.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-2 |
| 2 | 3.1.2 | Land Use Impacts | 3-4 |
| 3 | 3.1.2.1 | Environmental Consequences of Construction | 3-5 |
| 4 | 3.1.2.2 | Environmental Consequences of Operation..... | 3-9 |
| 5 | 3.2 | Visual Resources..... | 3-11 |
| 6 | 3.2.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-11 |
| 7 | 3.2.2 | Visual Resources Impacts..... | 3-11 |
| 8 | 3.2.2.1 | Environmental Consequences of Construction | 3-12 |
| 9 | 3.2.2.2 | Environmental Consequences of Operation..... | 3-14 |
| 10 | 3.3 | Meteorology and Air Quality..... | 3-15 |
| 11 | 3.3.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-15 |
| 12 | 3.3.2 | Air Quality Impacts | 3-18 |
| 13 | 3.3.2.1 | Environmental Consequences of Construction | 3-20 |
| 14 | 3.3.2.2 | Environmental Consequences of Operation..... | 3-22 |
| 15 | 3.4 | Water Resources..... | 3-26 |
| 16 | 3.4.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-26 |
| 17 | 3.4.1.1 | Surface Water Resources..... | 3-28 |
| 18 | 3.4.1.2 | Groundwater Resources..... | 3-30 |
| 19 | 3.4.2 | Water Resources Impacts | 3-33 |
| 20 | 3.4.2.1 | Environmental Consequences of Construction | 3-33 |
| 21 | 3.4.2.2 | Environmental Consequences of Operation..... | 3-42 |
| 22 | 3.5 | Terrestrial Ecology..... | 3-58 |
| 23 | 3.5.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-58 |
| 24 | 3.5.2 | Terrestrial Ecology Impacts..... | 3-60 |
| 25 | 3.5.2.1 | Environmental Consequences of Construction | 3-61 |
| 26 | 3.5.2.2 | Environmental Consequences of Operation..... | 3-71 |
| 27 | 3.6 | Aquatic Ecology..... | 3-82 |
| 28 | 3.6.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-82 |
| 29 | 3.6.2 | Aquatic Ecology Impacts | 3-84 |
| 30 | 3.6.2.1 | Environmental Consequences of Construction | 3-84 |
| 31 | 3.6.2.2 | Environmental Consequences of Operation..... | 3-90 |
| 32 | 3.7 | Historic and Cultural Resources..... | 3-99 |
| 33 | 3.7.1 | Baseline Conditions | 3-99 |
| 34 | 3.7.1.1 | National Historic Preservation Act and NEPA | 3-100 |
| 35 | 3.7.2 | Historic and Cultural Resources Impacts..... | 3-101 |
| 36 | 3.7.2.1 | Environmental Consequences of Construction | 3-101 |
| 37 | 3.7.2.2 | Environmental Consequences of Operation..... | 3-102 |
| 38 | 3.8 | Environmental Hazards..... | 3-103 |
| 39 | 3.8.1 | Radiological Environment..... | 3-103 |
| 40 | 3.8.1.1 | Baseline Conditions and PPE/SPE Values and | |
| 41 | | Assumptions..... | 3-103 |

| | | | | |
|----|-------|----------|---|-------|
| 1 | | 3.8.1.2 | Radiological Environment Impacts..... | 3-108 |
| 2 | 3.8.2 | | Nonradiological Environment..... | 3-117 |
| 3 | | 3.8.2.1 | Baseline Conditions and PPE/SPE Values and | |
| 4 | | | Assumptions..... | 3-117 |
| 5 | | 3.8.2.2 | Nonradiological Environment Impacts..... | 3-119 |
| 6 | 3.9 | | Noise | 3-124 |
| 7 | | 3.9.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-124 |
| 8 | | 3.9.2 | Noise Impacts | 3-125 |
| 9 | | 3.9.2.1 | Environmental Consequences of Construction | 3-125 |
| 10 | | 3.9.2.2 | Environmental Consequences of Operation..... | 3-125 |
| 11 | 3.10 | | Waste Management..... | 3-126 |
| 12 | | 3.10.1 | Radiological Waste Management..... | 3-126 |
| 13 | | 3.10.1.1 | Baseline Conditions and PPE/SPE Values and | |
| 14 | | | Assumptions..... | 3-126 |
| 15 | | 3.10.1.2 | Radiological Waste Impacts | 3-129 |
| 16 | | 3.10.2 | Nonradiological Waste Management..... | 3-131 |
| 17 | | 3.10.2.1 | Baseline Conditions and PPE/SPE Values | 3-131 |
| 18 | | 3.10.2.2 | Nonradiological Waste Impacts | 3-132 |
| 19 | 3.11 | | Postulated Accidents | 3-135 |
| 20 | | 3.11.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-135 |
| 21 | | 3.11.1.1 | Design Basis Accidents Involving Radiological | |
| 22 | | | Releases | 3-135 |
| 23 | | 3.11.1.2 | Accidents Involving Releases of Hazardous | |
| 24 | | | Chemicals | 3-135 |
| 25 | | 3.11.1.3 | Severe Accidents | 3-137 |
| 26 | | 3.11.1.4 | Severe Accident Mitigation Design Alternatives..... | 3-138 |
| 27 | | 3.11.1.5 | Acts of Terrorism | 3-139 |
| 28 | | 3.11.2 | Postulated Accidents Impacts | 3-140 |
| 29 | | 3.11.2.1 | Design Basis Accidents Involving Radiological | |
| 30 | | | Releases | 3-141 |
| 31 | | 3.11.2.2 | Accidents Involving Releases of Hazardous | |
| 32 | | | Chemicals | 3-141 |
| 33 | | 3.11.2.3 | Severe Accidents | 3-142 |
| 34 | | 3.11.2.4 | Severe Accident Mitigation Design Alternatives..... | 3-142 |
| 35 | | 3.11.2.5 | Acts of Terrorism | 3-142 |
| 36 | 3.12 | | Socioeconomics | 3-143 |
| 37 | | 3.12.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-143 |
| 38 | | 3.12.2 | Socioeconomic Impacts | 3-144 |
| 39 | | 3.12.2.1 | Socioeconomic Consequences of Construction..... | 3-144 |
| 40 | | 3.12.2.2 | Socioeconomic Consequences of Operations | 3-148 |
| 41 | 3.13 | | Environmental Justice..... | 3-150 |
| 42 | | 3.13.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-150 |

| | | | |
|----|----------|---|-------|
| 1 | 3.13.2 | Environmental Justice Impacts..... | 3-151 |
| 2 | 3.13.2.1 | Environmental Consequences of Construction and | |
| 3 | | Operation | 3-151 |
| 4 | 3.14 | Fuel Cycle..... | 3-151 |
| 5 | 3.14.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-151 |
| 6 | 3.14.1.1 | Uranium Fuel Cycle Environmental Data | 3-151 |
| 7 | 3.14.1.2 | Other Fissile Fuel Cycles..... | 3-153 |
| 8 | 3.14.1.3 | DOE High-Assay Low-Enriched Uranium Availability | |
| 9 | | Program | 3-154 |
| 10 | 3.14.1.4 | Nuclear Fuel Cycle Regulatory Requirements for New | |
| 11 | | Reactors..... | 3-154 |
| 12 | 3.14.1.5 | Changes in the Nuclear Fuel Cycle since WASH-1248... | 3-155 |
| 13 | 3.14.1.6 | PPE Assumptions..... | 3-156 |
| 14 | 3.14.2 | Fuel Cycle Impacts..... | 3-157 |
| 15 | 3.14.2.1 | Uranium Recovery..... | 3-157 |
| 16 | 3.14.2.2 | Uranium Conversion..... | 3-159 |
| 17 | 3.14.2.3 | Enrichment | 3-160 |
| 18 | 3.14.2.4 | Fuel Fabrication..... | 3-161 |
| 19 | 3.14.2.5 | Reprocessing | 3-168 |
| 20 | 3.14.2.6 | Storage and Disposal of Radiological Wastes | 3-170 |
| 21 | 3.14.3 | Staff Conclusions about the Environmental Impacts of a New | |
| 22 | | Reactor Fuel Cycle..... | 3-175 |
| 23 | 3.15 | Transportation of Fuel and Waste..... | 3-176 |
| 24 | 3.15.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-176 |
| 25 | 3.15.1.1 | Table S-4 on the Transportation of Fuel and Waste..... | 3-176 |
| 26 | 3.15.1.2 | Additional NRC Studies of the Risk from the | |
| 27 | | Transportation of SNF | 3-177 |
| 28 | 3.15.1.3 | Additional NRC Information Sources | 3-179 |
| 29 | 3.15.1.4 | U.S. Department of Energy Transportation Risk | |
| 30 | | Assessments | 3-179 |
| 31 | 3.15.1.5 | Issues for the Transportation of Non-LWR Fuel and | |
| 32 | | Wastes | 3-179 |
| 33 | 3.15.1.6 | Development of the Transportation Plant Parameter | |
| 34 | | Envelope | 3-180 |
| 35 | 3.15.1.7 | Transportation of Unirradiated New Reactor Fuel..... | 3-182 |
| 36 | 3.15.1.8 | Transportation of Radioactive Waste from New | |
| 37 | | Reactors..... | 3-187 |
| 38 | 3.15.1.9 | Transportation of SNF from New Reactors | 3-193 |
| 39 | 3.15.2 | Transportation Impacts..... | 3-199 |
| 40 | 3.15.2.1 | Transportation of Unirradiated New Reactor Fuel..... | 3-200 |
| 41 | 3.15.2.2 | Transportation of Radioactive Waste from New | |
| 42 | | Reactors..... | 3-201 |
| 43 | 3.15.2.3 | Transportation of Irradiated Fuel from New Reactors | 3-202 |

| | | | |
|----|-------------------|--|------------|
| 1 | 3.16 | Decommissioning | 3-203 |
| 2 | 3.16.1 | Baseline Conditions and PPE/SPE Values and Assumptions..... | 3-203 |
| 3 | 3.16.2 | Decommissioning Impacts | 3-205 |
| 4 | 4 | SUMMARY OF FINDINGS | 4-1 |
| 5 | 4.1 | Unavoidable Adverse Environmental Impacts and Irreversible and | |
| 6 | | Irretrievable Commitments of Resources | 4-28 |
| 7 | 4.2 | Relationship between Short-Term Use of the Environment and Long-Term | |
| 8 | | Productivity | 4-28 |
| 9 | 4.3 | No-Action Alternative Conclusion..... | 4-29 |
| 10 | 4.4 | Cost Benefit | 4-29 |
| 11 | 5 | REFERENCES | 5-1 |
| 12 | APPENDIX A | CONTRIBUTORS TO THE ENVIRONMENTAL IMPACT | |
| 13 | | STATEMENT | A-1 |
| 14 | APPENDIX B | OUTREACH | B-1 |
| 15 | APPENDIX C | CHRONOLOGY OF NRC STAFF ENVIRONMENTAL REVIEW | |
| 16 | | CORRESPONDENCE RELATED TO THE ADVANCED | |
| 17 | | REACTOR GENERIC ENVIRONMENTAL IMPACT STATEMENT .. | C-1 |
| 18 | APPENDIX D | DISTRIBUTION LIST | D-1 |
| 19 | APPENDIX E | COMMENTS ON THE GEIS..... | E-1 |
| 20 | APPENDIX F | LAWS, REGULATIONS, AND OTHER AUTHORIZATIONS | F-1 |
| 21 | APPENDIX G | PLANT PARAMETER ENVELOPE AND SITE PARAMETER | |
| 22 | | ENVELOPE | G-1 |
| 23 | APPENDIX H | GREENHOUSE GAS EMISSIONS ESTIMATES FOR A | |
| 24 | | REFERENCE 1,000 MWE REACTOR | H-1 |
| 25 | | | |

1
2
3
4
5
6
7
8
9

LIST OF FIGURES

| | | |
|------------|---|-------|
| Figure 3-1 | SMALL Surface Water Use Impacts for Plant Withdrawals of 6,000 gpm or Less Compared to the 95 Percent Exceedance Discharge in the Flowing Surface Water Body..... | 3-45 |
| Figure 3-2 | Representative Radiological Exposure Pathways to Human. | 3-106 |
| Figure 3-3 | Representative Radiological Exposure Pathways to Nonhuman Biota. | 3-107 |
| Figure 3-4 | Options of the Current Fuel Cycle which Includes the Table S-3 Uranium Fuel Cycle..... | 3-153 |

LIST OF TABLES

| | | | |
|----|------------|---|-------|
| 2 | Table 1-1 | Issues Discussed in the Generic Environmental Impact Statement | 1-13 |
| 3 | Table 3-1 | Plant Parameter Envelope Values for Greenhouse Gas Emissions..... | 3-19 |
| 4 | Table 3-2 | Construction Worker Individual and Collective Doses | 3-109 |
| 5 | Table 3-3 | Maximally Exposed Individual Doses | 3-112 |
| 6 | Table 3-4 | Total Population and Collective Natural Background Doses in | |
| 7 | | 50 mi Radius | 3-114 |
| 8 | Table 3-5 | Aquatic Nonhuman Biota Doses | 3-116 |
| 9 | Table 3-6 | Terrestrial Nonhuman Biota Doses | 3-116 |
| 10 | Table 3-7 | Level of Service Value Descriptions | 3-146 |
| 11 | Table 3-8 | Light-Water Reactor Fuel Fabrication Capacity | 3-162 |
| 12 | Table 3-9 | WASH-1248 Fuel Fabrication Environmental Impacts..... | 3-163 |
| 13 | Table 3-10 | Number of Truck Shipments and One-Way Shipping Distances for | |
| 14 | | Unirradiated Fuel | 3-184 |
| 15 | Table 3-11 | Radiological Impacts Under Normal Conditions of Transporting | |
| 16 | | Unirradiated Fuel from WASH-1238 and New Reactor Sites..... | 3-185 |
| 17 | Table 3-12 | Nonradiological Impacts of Transporting Unirradiated Fuel | 3-187 |
| 18 | Table 3-13 | Summary of Radioactive Waste Shipments and One-Way Shipping | |
| 19 | | Distances | 3-189 |
| 20 | Table 3-14 | Low-Level Radioactive Waste by Volume | 3-190 |
| 21 | Table 3-15 | Low-Level Radioactive Waste by Activity | 3-191 |
| 22 | Table 3-16 | Annual Nonradiological Impacts of Transporting Waste from the Site | 3-193 |
| 23 | Table 3-17 | Incident-Free Radiological Impacts for Shipping Spent Nuclear Fuel to the | |
| 24 | | Yucca Mountain Site | 3-195 |
| 25 | Table 3-18 | Radiological Accident Impacts for Shipping Spent Nuclear Fuel to the | |
| 26 | | Yucca Mountain Site | 3-196 |
| 27 | Table 3-19 | Nonradiological Accident Impacts for Shipping Spent Nuclear Fuel to the | |
| 28 | | Yucca Mountain Site | 3-197 |
| 29 | Table 3-20 | Summary of the Environmental Impacts from Decommissioning Nuclear | |
| 30 | | Power Facilities..... | 3-206 |
| 31 | Table 4-1 | Summary of Findings and Mitigation | 4-2 |
| 32 | | | |
| 33 | | | |

1

EXECUTIVE SUMMARY

2 In recent years, interest in developing and licensing new nuclear reactors, including advanced
3 nuclear reactors (ANRs)¹, in the United States using new technologies has increased. The
4 increased interest is demonstrated by the Nuclear Energy Innovation Capabilities Act of 2017
5 (Public Law 115-248) and Nuclear Energy Innovation and Modernization Act of 2019 (Public
6 Law 115-439). On November 15, 2019, the U.S. Nuclear Regulatory Commission (NRC) staff
7 issued a *Federal Register* notice (84 FR 62559) announcing an exploratory process and
8 soliciting comments to determine the possible utility of developing a generic environmental
9 impact statement (GEIS) for licensing ANRs.

10 In a GEIS, the NRC staff evaluates environmental impacts common to a group of related future
11 licensing actions, thereby allowing the staff to focus on impacts requiring consideration of
12 project-specific and site-specific factors once applications are received. As part of the
13 exploratory process, the staff considered its experience with previous GEIS documents
14 developed by NRC staff for power reactor license renewals, in situ uranium recovery facilities,
15 and decommissioning. The NRC issued a notice of intent to prepare the GEIS on April 30, 2020
16 (85 FR 24040), carried out a scoping process, and held a scoping meeting to receive public
17 comments on the GEIS on May 28, 2020. After considering the comments received from
18 interested stakeholders and the public during the scoping process, the NRC staff developed this
19 GEIS as a document that would be applicable to ANRs only.

20 The GEIS was developed initially using a technology-neutral, performance-based approach to
21 allow its use by a wide range of future ANR applicants. In Staff Requirements Memorandum
22 (SRM) SECY-20-0020, dated September 21, 2020, (NRC 2020-TN6492), the Commission
23 approved the development of a GEIS for the construction and operation of ANRs using a
24 technology-neutral, performance-based approach, and directed staff to codify results in the
25 *Code of Federal Regulations* (CFR).

26 In SRM SECY-21-0098, dated April 17, 2024, the Commission directed the NRC staff to change
27 the limited applicability of this GEIS from solely “advanced nuclear reactors” to any new nuclear
28 reactor licensing application, provided the application meets the values and the assumptions of
29 the plant parameter envelopes and the site parameter envelopes used to develop the GEIS.
30 The term “nuclear reactor,” as it is used in this GEIS, is defined in 10 CFR 50.2 as “an
31 apparatus, other than an atomic weapon, designed or used to sustain nuclear fission in a
32 self-supporting chain reaction.”

33 In SRM SECY-23-0001, dated April 13, 2023, the Commission directed the staff to regulate
34 near-term fusion systems under the 10 CFR Part 30 byproduct material framework. Therefore,
35 this GEIS does not address the environmental impacts of fusion systems.

36 **ES.1 Purpose and Need for this GEIS**

37 The purpose and need for this GEIS is to present impact analyses for the environmental issues
38 common to many new nuclear reactors that can be addressed generically, thereby eliminating
39 the need to repeatedly reproduce the same analyses each time a licensing application is

¹ A definition for an ANR is provided in the Nuclear Energy Innovation and Modernization Act of 2019 (Public Law 115-439). ANRs are a subset of the broader range of new nuclear reactors addressed by this GEIS.

1 submitted and allowing applicants and NRC staff to focus future environmental review efforts on
2 issues that can only be resolved once a site is identified. This GEIS is intended to improve the
3 efficiency of licensing new nuclear reactors by (1) identifying the possible types of
4 environmental impacts of constructing and operating a nuclear reactor, (2) assessing impacts
5 that are expected to be generic (the same or similar) for many nuclear reactors, and (3) defining
6 the environmental issues that will need to be addressed in project-specific supplemental
7 environmental impact statements (SEISs) addressing specific projects.

8 **ES.2 Proposed Action**

9 The proposed action is for the NRC staff to use a technology-neutral approach to issue a GEIS
10 that identifies and analyzes environmental issues, common to building and operation of a
11 nuclear reactor, for which a generic determination that impacts would not be environmentally
12 significant is possible as long as specific reasonable and practicable values and assumptions
13 are met. Values and assumptions regarding the design of the plant are termed the plant
14 parameter envelope (PPE) and values and assumptions regarding site conditions are termed
15 the site parameter envelope (SPE). The results of this GEIS will be codified in 10 CFR Part 51.

16 To develop this GEIS, the NRC established an interdisciplinary team of environmental subject
17 matter experts (SMEs) from the NRC and from contractor Pacific Northwest National
18 Laboratory—all of whom have extensive experience in evaluating the environmental impacts of
19 new reactors. In the GEIS, the interdisciplinary team is collectively referred to as the NRC staff.
20 The SMEs included individuals who have expertise in nuclear technology, radiation protection,
21 land use, aquatic and terrestrial ecology, hydrology and water use, socioeconomics,
22 environmental justice, meteorology and air quality, and human health.

23 Because new nuclear reactors are likely to include a range of reactor designs and could be sited
24 anywhere in the United States and territories that meets NRC siting requirements, the NRC
25 pursued a technology-neutral approach using assumptions contained in the PPE and SPE
26 (Appendix G). The PPE consists of bounding values or parameters for reactor design features
27 regardless of the site. In addition, the staff developed an SPE table of site conditions and
28 assumptions. The table includes the site size, size of water bodies supplying water to the
29 reactor, and demographics of the region surrounding the site, as well as specific assumptions
30 related to the condition of the affected environment, such as the extent and occurrence of
31 wetlands and floodplains, site position relative to aquatic features, and its proximity to sensitive
32 noise receptors. This GEIS presents generic analyses that evaluate the possible impacts of a
33 reactor that fits within the bounds of the PPE on a site that fits within the bounds of the SPE for
34 those issues for which a generic conclusion was possible (referred to as Category 1 issues).

35 The environmental issues are organized into 16 environmental resources. Each issue
36 corresponds to a specific type of environmental impact determined by the interdisciplinary team
37 of SMEs to potentially result from building or operation of a nuclear reactor. This GEIS will allow
38 licensing applications for new nuclear reactors to reference the generic analysis for each
39 Category 1 environmental issue for which it can demonstrate that the project is bounded by the
40 applicable assumptions in the PPE and SPE and for which there is no new and significant
41 information affecting the evaluation. The NRC staff would have to prepare a SEIS or other
42 supplemental National Environmental Policy Act of 1969, as amended (NEPA) documentation
43 for the licensing of a new nuclear reactor, if using this GEIS. The SEIS would briefly describe
44 how the project meets the PPE and SPE values and assumptions for the appropriate
45 Category 1 issues. The SEIS would also evaluate the environmental impacts of any issues for

1 which an application cannot demonstrate that the relevant assumptions in the PPE and SPE are
2 met, as well as issues that the staff could not address generically in this GEIS.

3 **ES.3 Impact Significance Levels and Categorization of Issues**

4 For each issue, the SMEs identified each value or assumption in the PPE and SPE that could
5 effectively bound a meaningful generic analysis. The SMEs performed and described generic
6 analyses for each issue for a hypothetical reactor that falls within the bounding values of the
7 PPE on a site that falls within the bounding values of the SPE. The SMEs drew conclusions
8 about each analysis using one of the three significance levels that the NRC staff typically uses
9 in environmental impact statements (EISs) for new reactors:

- 10 • **SMALL** – Environmental effects that are not detectable or are so minor that they will neither
11 destabilize nor noticeably alter any important attribute of the resource. For the purposes of
12 assessing radiological impacts, the Commission has concluded that those impacts that do
13 not exceed permissible levels in the Commission’s regulations are considered **SMALL**.
- 14 • **MODERATE** – Environmental effects are sufficient to alter noticeably, but not to destabilize,
15 important attributes of the resource.
- 16 • **LARGE** – Environmental effects are clearly noticeable and are sufficient to destabilize
17 important attributes of the resource.

18 These significance levels follow the definitions presented in the footnotes to Table B-1 in
19 Appendix B to Subpart A of 10 CFR Part 51.

20 The SMEs assigned each issue to one of two categories depending on the potential utility of the
21 generic analysis to applicants preparing specific new nuclear reactor licensing applications and
22 to the NRC staff when completing environmental reviews of those applications. The categories
23 are as follows:

- 24 • **Category 1 issues** – environmental issues for which a generic analysis concluding **SMALL**
25 adverse environmental impacts is possible, provided that relevant values and assumptions
26 in the PPE and SPE are met, or beneficial impacts;
- 27 • **Category 2 issues** – environmental issues for which a meaningful generic analysis of
28 environmental impacts is not possible because the issue requires consideration of project-
29 specific information.

30 In addition, as discussed in Section 1.3.3.3, there are two issues that are designated as N/A
31 (i.e., impacts are Uncertain), which are neither Category 1 nor 2.

32 An applicant addressing a Category 1 issue in its environmental report (ER) that accompanies
33 an application may refer to the generic analysis in this GEIS for that issue without further
34 analysis, provided that it demonstrates that the relevant assumptions in the PPE and SPE are
35 met and there is no new and significant information to change the conclusions in this GEIS. If
36 the relevant parameters and assumptions for a Category 1 issue are not met, the applicant
37 would have to supply the requisite information necessary for the staff to perform a site-specific
38 analysis. All applicants would have to individually address each Category 2 issue without
39 reference to this GEIS.

1 This GEIS also identifies other elements of environmental documentation that must be
2 addressed individually, including sections addressing the purpose and need, need for power (or
3 project), and alternatives to the proposed action.

4 **ES.4 Alternatives**

5 In addition to the proposed action of preparing a GEIS for new nuclear reactors, the NRC staff
6 analyzed a No-Action Alternative in which the NRC does not issue this GEIS. Without the
7 availability of this GEIS, applicants for licensing new nuclear reactors would have to address all
8 relevant environmental issues individually in their ERs, and staff would have to prepare
9 individual EISs for each application received that address all relevant environmental issues
10 (including all Category 1 and Category 2 issues). The processes for an applicant to prepare an
11 ER and for the NRC staff to prepare an EIS would remain those used in the past for new reactor
12 licensing applications. Conclusions in this GEIS regarding potential environmental impacts could
13 not be referenced. However, the No-Action Alternative would accomplish none of the benefits
14 intended by the preparation of this GEIS, which would include (1) reducing the time and
15 resources for the applicant's preparation of the environmental report, (2) reducing the time and
16 resources for the NRC staff's preparation of the EIS and (3) focusing the resources of the
17 applicant, NRC staff, and decision-makers on issues where there is truly a potential for
18 significant environmental impacts. The NRC staff therefore concludes that the No-Action
19 Alternative is not preferable to the proposed action.

20 Prior to scoping, the NRC staff contemplated preparing a GEIS that would analyze the potential
21 environmental impacts of a hypothetical reactor that would have a power level of approximately
22 30 megawatts thermal or less on a hypothetical site. The analytical approach to developing this
23 GEIS would have been similar to that used under the proposed action, but the PPE/SPE would
24 have been developed based on a typical reactor of 30 megawatts thermal, limiting the range of
25 reactors for which this GEIS would have been useful. Use of the power-level-based GEIS by
26 applicants for small reactors and NRC staff would have been the same as for the environmental
27 performance-based GEIS called for in the proposed action. During scoping, multiple
28 commenters suggested that the parameters used in the generic analyses should be tied to the
29 potential for environmental impacts rather than to an arbitrary power level. After reviewing the
30 comments, the staff agreed that a GEIS developed using technology-neutral performance-
31 based values and assumptions tied to environmental impacts might help streamline
32 environmental reviews even for some larger ANRs that have a low potential for significant
33 environmental impacts with respect to some environmental issues. Because of the limited utility
34 of a GEIS based on a limited power level, the staff decided not to evaluate this alternative
35 approach in detail.

36 The NRC staff initially developed this GEIS as a document that would be applicable to only
37 ANRs. See SECY-21-0098, *Proposed Rule: Advanced Nuclear Reactor Generic Environmental*
38 *Impact Statement*, dated November 29, 2021. However, in SRM SECY-21-0098, dated April 17,
39 2024, the Commission directed the NRC staff to change the limited applicability of this GEIS
40 from solely "advanced nuclear reactors" to any new nuclear reactor licensing application,
41 provided the application meets the values and the assumptions of the plant parameter
42 envelopes and the site parameter envelopes used to develop the GEIS. Based on the direction
43 from the Commission, the alternative of developing a GEIS that would be applicable to only
44 advanced nuclear reactors will not be considered further.

1 The staff also considered whether it would be possible to develop a GEIS that could serve as
2 the sole technical documentation of potential environmental impacts for any new nuclear
3 reactor. However, the staff concluded that it is not technically possible to develop generic
4 analyses addressing all potentially significant environmental impacts from any new nuclear
5 reactor without consideration of project-specific and site-specific conditions. It is also unrealistic
6 to assume that a GEIS would be able to fully comply with other environmental laws such as the
7 Endangered Species Act (16 U.S.C. §§ 1531 et seq.) or the National Historic Preservation Act
8 (54 U.S.C. §§ 300101 et seq.). Therefore, the staff decided not to evaluate this alternative
9 approach in detail.

10 **ES.5 Affected Environment and Environmental Consequences**

11 The baseline condition described as the “affected environment” in this GEIS is the environment
12 that exists at a site proposed for building and operation of a nuclear reactor. The site could be
13 anywhere in the United States or its territories that meets the NRC reactor siting criteria in
14 10 CFR Part 100. The affected environment reflects the existing condition of environmental
15 resources, as influenced by natural physical conditions and by past human activities such as
16 agriculture, forestry, mining, urbanization, and industrial and non-industrial development. The
17 range of existing environmental conditions that might possibly occur at a proposed site located
18 anywhere in the United States is too broad to characterize. To address this, the NRC staff
19 developed the PPE, SPE, and related assumptions presented in Appendix G. The PPE and
20 SPE contain assumptions regarding the absence of, or limited presence of, sensitive
21 environmental resources such as sensitive habitats, wetlands, floodplains, and residences on or
22 near the site. The PPE and SPE also contain assumptions regarding the size and condition of
23 resources near the site, including water sources and air.

24 The NRC staff evaluated the potential environmental impacts from 122 issues in 16
25 environmental resources in this GEIS. Of these, the staff identified 100 issues as Category 1
26 issues and 20 issues as Category 2 issues (Table 4-1). In addition, as discussed in
27 Section 1.3.3.3, there are two issues that are designated as N/A (i.e., impacts are Uncertain),
28 which are neither Category 1 nor 2. The NRC staff determined that the potential environmental
29 impacts for each Category 1 issue would be of SMALL significance, as long as the applicable
30 assumptions in the PPE and SPE are met. The basis for identifying an issue as a Category 1
31 issue is whether a generic analysis of the issue is sufficient for decision-makers and the public
32 when licensing a new nuclear reactor that meets the assumptions in the PPE and SPE.

33 The NRC staff determined that it is not possible to evaluate the significance of environmental
34 impacts from the Category 2 issues without application-specific evaluation after receiving a
35 licensing application that identifies specific design parameters and site conditions. The staff
36 identified certain issues as Category 2 issues because they require project-specific consultation
37 with outside agencies to comply with statutes other than NEPA. Examples include issues
38 related to threatened or endangered species regulated under the Endangered Species Act,
39 essential fish habitat regulated under the Magnuson-Stevens Fishery Conservation and
40 Management Act, and historic properties regulated under the National Historic Preservation Act.
41 The staff is unable to evaluate the significance of impacts on those resources without receiving
42 technical input from the consultations. The staff identified certain other issues as Category 2
43 issues because it was not possible to set realistic assumptions that could underlie a conclusion
44 that the impacts would necessarily be SMALL at any hypothetical site in the United States.
45 However, the fact that an individualized analysis is necessary does not mean that the
46 supplemental NEPA documentation will lead the NRC staff to conclude that impacts pertaining
47 to the issue will be greater than SMALL; it only means that more than a generic analysis is

1 necessary to reach a conclusion. Although it would theoretically be possible to constrain the
2 assumptions to the extent that impacts on almost any environmental impact would be SMALL,
3 the NRC staff intends for this new reactor GEIS to be a practicable, usable document for
4 different types of new reactor projects.

1

ABBREVIATIONS AND ACRONYMS

| | | |
|----|---------------------|---|
| 2 | °C | degree(s) Celsius |
| 3 | °F | degree(s) Fahrenheit |
| 4 | ²³⁵ U | uranium-235 |
| 5 | | |
| 6 | ac | acre(s) |
| 7 | ACHP | Advisory Council on Historic Preservation |
| 8 | ADAMS | Agencywide Documents Access and Management System |
| 9 | ADU | ammonium diuranate |
| 10 | ALARA | as low as is reasonably achievable |
| 11 | AEC | Atomic Energy Commission |
| 12 | AEGL | Acute Exposure Guideline Level |
| 13 | APE | area of potential effect |
| 14 | APLIC | Avian Power Line Interaction Committee |
| 15 | ARE | Aircraft Reactor Experiment |
| 16 | ATF | accident tolerant fuel |
| 17 | | |
| 18 | BMP | best management practice |
| 19 | Bq | becquerel(s) |
| 20 | BWXT | BWX Technologies, Inc. |
| 21 | | |
| 22 | CAA | Clean Air Act |
| 23 | CDF | core damage frequency |
| 24 | CEQ | Council on Environmental Quality |
| 25 | CERCLA | Comprehensive Environmental Response, Compensation, and Liability Act (Superfund) |
| 26 | | |
| 27 | CFR | <i>Code of Federal Regulations</i> |
| 28 | CH ₄ | methane |
| 29 | Ci | curie(s) |
| 30 | CISF | Consolidated Interim Storage Facility |
| 31 | CO | carbon monoxide |
| 32 | CO ₂ | carbon dioxide |
| 33 | CO ₂ (e) | CO ₂ equivalent |
| 34 | COL | combined construction permit and operating license or combined license |
| 35 | CP | construction permit |
| 36 | CWA | Clean Water Act (aka Federal Water Pollution Control Act) |
| 37 | CZMA | Coastal Zone Management Act |
| 38 | | |
| 39 | d | day(s) |
| 40 | dBA | decibel(s) on the A-weighted scale |

| | | |
|----|-----------------|---|
| 1 | DBA | design basis accident |
| 2 | DCP | dry conversion process |
| 3 | DOE | U.S. Department of Energy |
| 4 | DOT | U.S. Department of Transportation |
| 5 | DTS | dry transfer system |
| 6 | | |
| 7 | EA | environmental assessment |
| 8 | EBR-II | Experimental Breeder Reactor-II |
| 9 | EIS | environmental impact statement |
| 10 | EJ | environmental justice |
| 11 | EMF | electromagnetic field |
| 12 | EPA | U.S. Environmental Protection Agency |
| 13 | ER | environmental report |
| 14 | ESA | Endangered Species Act of 1973, as amended |
| 15 | ESP | early site permit |
| 16 | | |
| 17 | FAST | Fixing America's Surface Transportation Act |
| 18 | FEIS | final environmental impact statement |
| 19 | FPPA | Farmland Protection Policy Act |
| 20 | FSAR | Final Safety Analysis Report |
| 21 | ft | foot or feet |
| 22 | ft ² | square foot or feet |
| 23 | ft ³ | cubic foot or feet |
| 24 | FWS | U.S. Fish and Wildlife Service |
| 25 | | |
| 26 | g | gram(s) |
| 27 | gal | gallon(s) |
| 28 | GEIS | generic environmental impact statement |
| 29 | GHG | greenhouse gas |
| 30 | gpd | gallon(s) per day |
| 31 | gpm | gallon(s) per minute |
| 32 | GTCC | greater than Class C |
| 33 | GWd | gigawatt day(s) |
| 34 | Gy | gray(s) |
| 35 | | |
| 36 | ha | hectare(s) |
| 37 | HALEU | high-assay low- enriched uranium |
| 38 | HAP | hazardous air pollutant |
| 39 | HEU | highly enriched uranium |
| 40 | HLW | high-level waste |
| 41 | hr | hour(s) |

| | | |
|----|-----------------|---|
| 1 | Hz | hertz |
| 2 | | |
| 3 | IAEA | International Atomic Energy Agency |
| 4 | ICRP | International Commission on Radiological Protection |
| 5 | in. | inch(es) |
| 6 | INL | Idaho National Laboratory |
| 7 | IPCC | Intergovernmental Panel on Climate Change |
| 8 | ISFSI | independent spent fuel storage installation |
| 9 | ISG | Interim Staff Guidance |
| 10 | | |
| 11 | kg | kilogram(s) |
| 12 | km | kilometer(s) |
| 13 | km ² | square kilometer(s) |
| 14 | kV | kilovolt(s) |
| 15 | kWh | kilowatt-hour(s) |
| 16 | | |
| 17 | L | liter(s) |
| 18 | lb | pound(s) |
| 19 | LEU | low-enriched uranium |
| 20 | LLC | Limited Liability Company |
| 21 | LLRW | low-level radioactive waste |
| 22 | LOS | level of service |
| 23 | LWR | light-water reactor |
| 24 | | |
| 25 | m | meter(s) |
| 26 | m ³ | cubic meter(s) |
| 27 | MEI | maximally exposed individual |
| 28 | mGy | milligray(s) |
| 29 | mi | mile(s) |
| 30 | mi ² | square mile(s) |
| 31 | MIMS | Manifest Information Management System |
| 32 | M | million |
| 33 | MMT | million metric tons |
| 34 | mo | month(s) |
| 35 | mrad | millirad(s) |
| 36 | mrem | millirem(s) |
| 37 | MSR | molten-salt reactor |
| 38 | MSRE | Molten-Salt Reactor Experiment |
| 39 | MT | metric ton(nes) |
| 40 | MTU | metric ton(nes) uranium |
| 41 | MW | megawatt(s) |

| | | |
|----|-------------------|--|
| 1 | MWe | megawatt(s) electrical |
| 2 | MWt | megawatt(s) thermal |
| 3 | MWd | megawatt-day(s) |
| 4 | MWd/MTU | megawatt-day(s) per metric ton of uranium |
| 5 | MWh | megawatt-hour(s) |
| 6 | | |
| 7 | N/A | not applicable |
| 8 | N ₂ O | nitrous oxide |
| 9 | NAAQS | National Ambient Air Quality Standard |
| 10 | NCRP | National Council on Radiation Protection and Measurements |
| 11 | NEI | Nuclear Electric Institute |
| 12 | NEIMA | Nuclear Energy Innovation and Modernization Act of 2019 |
| 13 | NEPA | National Environmental Policy Act of 1969, as amended |
| 14 | NHPA | National Historic Preservation Act |
| 15 | NMFS | National Marine Fisheries Service |
| 16 | NO _x | oxides of nitrogen |
| 17 | NPDES | National Pollutant Discharge Elimination System |
| 18 | NR | nuclear reactor |
| 19 | NR GEIS | <i>Generic Environmental Impact Statement for Licensing New Nuclear Reactors</i> |
| 20 | | |
| 21 | NRC | U.S. Nuclear Regulatory Commission |
| 22 | NRHP | National Register of Historic Places |
| 23 | NRIC | National Reactor Innovation Center |
| 24 | NUREG | U.S. Nuclear Regulatory Commission technical document |
| 25 | NWP | Nation Wide Permit |
| 26 | | |
| 27 | OSHA | Occupational Safety and Health Administration |
| 28 | | |
| 29 | PA | Programmatic Agreement |
| 30 | PER | pyrochemical/electrochemical reprocessing |
| 31 | PFSF | Private Fuel Storage Facility |
| 32 | PM | particulate matter |
| 33 | PM ₁₀ | particulate matter with a mean aerodynamic diameter of 10 µm or less |
| 34 | PM _{2.5} | particulate matter with a mean aerodynamic diameter of 2.5 µm or less |
| 35 | PNNL | Pacific Northwest National Laboratory |
| 36 | PPE | plant parameter envelope |
| 37 | ppt | part(s) per thousand |
| 38 | PRA | probabilistic risk assessment |
| 39 | PSAR | Preliminary Safety Analysis Report |
| 40 | PSDAR | post-shutdown decommissioning activity report |
| 41 | PSEG | Public Service Enterprise Group |

| | | |
|----|-----------------|--|
| 1 | PUREX | plutonium uranium extraction |
| 2 | PWR | pressurized water reactor |
| 3 | | |
| 4 | RCRA | Resource Conservation and Recovery Act of 1976, as amended |
| 5 | REMP | Radiological Environmental Monitoring Program |
| 6 | RG | Regulatory Guide |
| 7 | RMP | Risk Management Plan |
| 8 | ROW | right-of-way |
| 9 | RRY | reference reactor-year |
| 10 | Ryr | reactor-year(s) |
| 11 | | |
| 12 | s or sec | second(s) |
| 13 | SAFSTOR | SAFe STORage |
| 14 | SAMA | severe accident mitigation alternative |
| 15 | SAMDA | severe accident mitigation design alternative |
| 16 | SDWA | Safe Drinking Water Act |
| 17 | SEIS | supplemental environmental impact statement |
| 18 | SHPO | State Historic Preservation Office |
| 19 | SME | subject matter expert |
| 20 | SMR | small modular reactor |
| 21 | SNF | spent nuclear fuel |
| 22 | SNM | special nuclear material |
| 23 | SO _x | oxides of sulfur |
| 24 | SPE | site parameter envelope |
| 25 | SRM | Staff Requirements Memorandum |
| 26 | SRP | standard review plan |
| 27 | SSA | Sole Source Aquifer |
| 28 | SWU | separative work unit |
| 29 | | |
| 30 | T | ton(nes) |
| 31 | TCP | traditional cultural properties |
| 32 | TDS | total dissolved solids |
| 33 | TEDE | total effective dose equivalent |
| 34 | Th-232 | thorium-232 |
| 35 | THPO | Tribal Historic Preservation Office |
| 36 | TPQ | Threshold Planning Quantity |
| 37 | TQ | threshold quantity |
| 38 | TRISO | TRi-structural ISOtropic |
| 39 | TRU | transuranic |
| 40 | | |
| 41 | U-235 | uranium-235 |

| | | |
|----|-----------------|--------------------------------|
| 1 | U-238 | uranium-238 |
| 2 | UF ₆ | uranium hexafluoride |
| 3 | U.S. | United States of America |
| 4 | UO ₂ | uranium dioxide |
| 5 | USACE | U.S. Army Corps of Engineers |
| 6 | USBR | U.S. Bureau of Reclamation |
| 7 | U.S.C. | United States Code |
| 8 | USDA | U.S. Department of Agriculture |
| 9 | USNC | Ultra Safe Nuclear Corporation |
| 10 | | |
| 11 | VOC | volatile organic compound |
| 12 | | |
| 13 | WCS | Waste Control Specialists, LLC |
| 14 | WNA | World Nuclear Association |
| 15 | | |
| 16 | yd ³ | cubic yard(s) |
| 17 | yr | year(s) |

1 INTRODUCTION

1

2 In recent years, interest in developing and licensing new nuclear reactors, including advanced
3 nuclear reactors (ANRs), in the United States using new technologies has increased. The
4 increased interest is demonstrated by the Nuclear Energy Innovation Capabilities Act of 2017
5 (Public Law 115-248; TN6468) and Nuclear Energy Innovation and Modernization Act of 2019
6 (NEIMA, Public Law 115-439; TN6469). One purpose of NEIMA is to provide a program for
7 developing “the expertise and regulatory processes necessary to allow innovation and
8 commercialization of advanced nuclear reactors.” A strategic nonprofit organization dedicated to
9 advancing nuclear development in the United States, ClearPath, sent a letter, dated February
10 19, 2019, to the U.S. Nuclear Regulatory Commission (NRC) recommending that it develop a
11 generic environmental impact statement (GEIS) for construction and operation of ANRs
12 (ClearPath 2019-TN6466). Multiple representatives of Congress also expressed interest in
13 having the NRC develop such a GEIS. On June 25, 2019, Senators Barrasso and Braun sent a
14 letter to the Chairman of the NRC requesting that the NRC initiate a process to develop a GEIS
15 for ANRs (Barrasso and Braun 2019-TN6465). The Chairman responded on July 29, 2019
16 (NRC 2019-TN6467) that the NRC would explore whether development of a GEIS would
17 beneficially streamline environmental reviews for ANRs while still fulfilling NRC’s responsibilities
18 to protect the environment and comply with the National Environmental Policy Act of 1969
19 (NEPA; 42 U.S.C. §§ 4321 et seq.; TN661).

20 On November 15, 2019, the NRC staff issued a *Federal Register* notice (84 FR 62559-TN6470)
21 announcing an exploratory process and soliciting comments to determine the possible utility of
22 developing a GEIS for licensing ANRs. The exploratory process included two public meetings, a
23 comprehensive public workshop attended by multiple stakeholders, and a site visit to the Idaho
24 National Laboratory, one location that is being contemplated for some ANRs. As part of the
25 exploratory process, the staff considered its experience with previous NRC GEIS documents
26 that support power reactor license renewals, in situ uranium recovery facilities, and
27 decommissioning. The staff gathered information to determine whether a GEIS for construction
28 and operation of ANRs might be viable. The exploratory process concluded with an information
29 paper to the NRC Commission concluding that the staff decided to pursue a GEIS using a
30 technology-neutral approach, and that a GEIS would generically resolve many environmental
31 issues, saving resources and providing predictability for potential applicants.

32 In Staff Requirements Memorandum (SRM) SECY-20-0020, dated September 21, 2020,
33 (NRC 2020-TN6492), the Commission approved the development of a GEIS for the construction
34 and operation of ANRs using a technology-neutral, performance-based approach, and directed
35 staff to codify results in the *Code of Federal Regulations*. Details of this approach are discussed
36 in Section 1.3. The NRC issued a notice of intent to prepare the GEIS on April 30, 2020 (85 FR
37 24040), carried out a scoping process, and held a scoping meeting to receive public comments
38 on the GEIS on May 28, 2020. After considering the comments received from various sources
39 during the scoping process, the NRC staff initially developed this GEIS as a document that
40 would be applicable to only ANRs.

41 Because this GEIS was initially developed using a technology-neutral, performance-based
42 approach, its analyses can be used by any reactor. In SRM SECY-21-0098, dated April 17,
43 2024, the Commission directed the NRC staff to change the limited applicability of the GEIS
44 from solely “advanced nuclear reactors” to any new nuclear reactor licensing application,
45 provided the application meets the values and the assumptions of the plant parameter
46 envelopes and the site parameter envelopes used to develop the GEIS.

1 **1.1 Purpose and Need for this GEIS**

2 The purpose and need for this GEIS is to present impact analyses for the environmental issues
3 common to many new nuclear reactors that can be addressed generically, thereby eliminating
4 the need to repeatedly reproduce the same analyses each time a licensing application is
5 submitted and allowing applicants and NRC staff to focus future environmental review efforts on
6 issues that can only be resolved once a site is identified. This GEIS is intended to improve the
7 efficiency of licensing new nuclear reactors by (1) identifying the types of potential
8 environmental impacts¹ of constructing and operating a nuclear reactor, (2) assessing impacts
9 that are expected to be generic (the same or similar) for many new nuclear reactors, and
10 (3) defining the environmental issues that will need to be addressed in project-specific
11 supplemental EISs (SEISs) addressing specific projects.

12 **1.2 NEPA Process**

13 After completing the exploratory process, the NRC established an interdisciplinary team of
14 environmental subject matter experts (SMEs) to develop this GEIS. The team comprised
15 experts from the NRC staff and from contractors, including Pacific Northwest National
16 Laboratory, possessing extensive experience in evaluating the environmental impacts of new
17 reactors. The SMEs included individuals who have expertise in nuclear technology, radiation
18 protection, land use, aquatic and terrestrial ecology, hydrology and water use, socioeconomics,
19 environmental justice, meteorology and air quality, and human health. A complete list of SMEs,
20 their credentials, and their roles in preparing this GEIS is provided in Appendix A of this GEIS.

21 On April 30, 2020, the NRC issued a *Federal Register* notice informing the public of its intent to
22 develop an ANR GEIS and to conduct a scoping process to gather the information necessary to
23 prepare an ANR GEIS for small-scale ANRs (85 FR 24040-TN6458). The NRC held a webinar
24 on May 28, 2020, to receive comments from the public on the scope of this GEIS (NRC 2020-
25 TN6459).

26 The *Federal Register* notice stated that the NRC intended to develop a GEIS for ANRs that
27 have a small generating output and correspondingly small environmental footprint in order to
28 streamline the environmental review process for future small-scale ANR environmental reviews
29 (85 FR 24040-TN6458). At the time of scoping, the NRC staff considered a “small-scale” ANR to
30 be one that has the potential to generate up to approximately 30 megawatts thermal (MWt) per
31 unit and has a correspondingly small environmental footprint. The staff indicated that the actual
32 bounding thermal power level and environmental footprint used in this GEIS were topics to be
33 determined during the scoping process.

34 The NRC received a number of comments about the scope of this GEIS during the May 28,
35 2020, webinar and throughout the scoping comment period. A summary of the scoping
36 comments was issued on September 25, 2020 (NRC 2020-TN6593). A number of commenters
37 questioned the utility of a GEIS for ANRs, given that the NRC did not know the type of reactor or
38 the site where the reactor would be located. Others agreed with the technology-neutral
39 approach but recommended a performance-based approach without limiting this GEIS to small-
40 scale reactors. Based on the comments received during scoping, the NRC determined to use a
41 technology-neutral, performance-based approach with specified values and assumptions.
42 “Performance” reflects the ability of an applicant to design a nuclear reactor that minimizes

¹ This GEIS documents the potential impacts of construction, operation and decommissioning of new nuclear reactors and henceforth when discussing impacts, they are potential impacts.

1 environmental impacts while still meeting the reactor’s objectives. The approach outlined above
2 constitutes a technology-neutral, performance-based approach whereby the efficiencies gained
3 through use of this GEIS increase as the potential for environmental impacts decreases.

4 The Commission, in SRM SECY-21-0098, dated April 17, 2024, directed the NRC staff to
5 change the limited applicability of the GEIS initially developed from solely “advanced nuclear
6 reactors” to any new nuclear reactor licensing application, provided the application meets the
7 values and the assumptions of the plant parameter envelopes and the site parameter envelopes
8 used to develop the GEIS. Therefore, this document is referred to as the new reactor (NR) GEIS
9 throughout the content.

10 **1.3 Analytical Approach Used in this GEIS**

11 **1.3.1 Methodology**

12 This section discusses the methodology the NRC staff used to develop this GEIS. This GEIS
13 evaluates the impacts of building, operating, and decommissioning a nuclear reactor sited within
14 the United States and its territories that is bounded by the values and assumptions in
15 Appendix G and the analyses in this GEIS. In addition, this GEIS considered fuel cycle impacts
16 and the impacts from continued storage of spent fuel after operations. The term building, as
17 used in this GEIS, includes the full range of preconstruction (building activities not within the
18 NRC’s regulatory authority), and construction and installation activities (building activities within
19 the NRC’s regulatory authority). The term construction worker includes any worker engaged in
20 building activities and the term construction equipment includes any equipment used for building
21 activities. For the purposes of this GEIS, the staff assumed that the U.S. Army Corps of
22 Engineers (USACE) would be a cooperating agency, in accordance with the Memorandum of
23 Understanding between the two agencies (USACE and NRC 2008-TN637). Based on this
24 assumption, preconstruction activities are addressed in Chapter 3 along with the impacts of
25 NRC-authorized construction.

26 Because new nuclear reactors are not specific to only one reactor design and could be sited
27 anywhere in the United States and its territories that meets NRC siting requirements as set forth
28 in Title 10 of the *Code of Federal Regulations* Part 100 (10 CFR Part 100; TN282), the NRC
29 decided to pursue a technology-neutral, performance-based approach using a plant parameter
30 envelope (PPE). The PPE consists of parameters for specific reactor design features regardless
31 of the site. Examples of parameters include the site footprint size, building height, water use, air
32 emissions, employment levels, and noise generation levels. For each PPE parameter, the staff
33 developed a set of bounding values and assumptions.

34 In addition, the staff developed a set of site-related parameters termed the site parameter
35 envelope (SPE). Examples of parameters include site size, size of water bodies supplying water
36 to the reactor, and demographics of the region surrounding the site. For each SPE parameter,
37 the staff developed a set of bounding values and assumptions related to the condition of the
38 affected environment, such as the extent and occurrence of wetlands and floodplains, position
39 near aquatic features, and proximity to sensitive noise receptors. The GEIS presents generic
40 analyses that evaluate the possible impacts of a reactor that fits within the bounds of the PPE
41 on a site that fits within the bounds of the SPE.

42 The PPE and SPE are presented in Appendix G. The PPE and SPE values and assumptions
43 were developed by the interdisciplinary team of SMEs assigned to prepare this GEIS. The
44 SMEs developed the values and assumptions based on one or more of the following:

- 1 • regulatory limits and permitting requirements relevant to the resource as established by
2 Federal, State, or local agencies;
- 3 • relevant information obtained from other NRC GEISs, including the License Renewal GEIS
4 (NRC 2024-TN10161) and the Continued Storage GEIS (NRC 2014-TN4117);
- 5 • empirical knowledge gained from conducting evaluations and analyses for past new reactor
6 environmental impact statements (EISs);
- 7 • values and assumptions derived from other documents applying a PPE/SPE approach (such
8 as the National Reactor Innovation Center [NRIC] PPE Report; NRIC 2021-TN6940); and
- 9 • subject matter expertise and/or development of calculations and formulas based upon
10 education and experience with the resource.

11 The SMEs strove to ensure that the PPE and SPE were set broadly enough to make this GEIS
12 a useful licensing tool, while still ensuring that enough project-specific analysis would be
13 completed upon receipt of an application to document significant environmental impacts for the
14 public and decision-makers.

15 The NRC staff presented preliminary tables outlining the PPE and SPE at the March 28, 2020,
16 scoping meeting. The PPE and SPE presented in Appendix G reflect the staff's consideration of
17 comments received during the scoping process and subsequent research conducted by the
18 SMEs to prepare the draft GEIS.

19 The SMEs started their analysis by identifying specific types of impacts relevant to each of 16
20 environmental resource areas. Each type of impact is termed an issue. Each issue corresponds
21 to a specific type of environmental impact determined by the interdisciplinary team of SMEs that
22 could potentially result from construction or operation of a nuclear reactor. The SMEs identified
23 122 specific issues. For each issue, the SMEs then determined whether it would be possible to
24 identify values and assumptions in the PPE and SPE that could effectively bound a meaningful
25 generic analysis and provided the basis for each value and assumption. The SMEs then
26 performed and described their generic analyses for each issue, for a hypothetical reactor/site
27 that meets the PPE and SPE values and assumptions. For this GEIS, the values and
28 assumptions were set such that the SMEs could reach a generic conclusion of SMALL adverse
29 impacts, which are designated as Category 1 issues (i.e., issues for which a generic analysis
30 was possible). Issues for which the impacts are beneficial are also designated as Category 1.

31 After considering potential values and assumptions for the PPE and SPE for some
32 environmental impact issues, the staff could not reach a generic conclusion. In some cases, this
33 was due to requirements of other statutes, such as the National Historic Preservation Act
34 (54 U.S.C. §§ 300101 et seq.; TN4157) and the Endangered Species Act (ESA; 16 U.S.C.
35 §§ 1531 et seq.; TN1010). In other cases, the wide range of potential reactor designs and
36 potential site locations made it impossible for the staff to reach a generic conclusion. These
37 issues are designated as Category 2 issues, which require site- or project-specific analysis in an
38 NRC EIS.

39 The SMEs drew conclusions about each analysis using one of the three significance levels that
40 the NRC staff typically uses in EISs for new reactors, including the following:

- 41 • SMALL – Environmental effects that are not detectable or are so minor that they will neither
42 destabilize nor noticeably alter any important attribute of the resource. For the purposes of

- 1 assessing radiological impacts, the Commission has concluded that those impacts that do
2 not exceed permissible levels in the Commission’s regulations are considered SMALL.
- 3 • MODERATE – Environmental effects are sufficient to alter noticeably, but not to destabilize,
4 important attributes of the resource.
 - 5 • LARGE – Environmental effects are clearly noticeable and are sufficient to destabilize
6 important attributes of the resource.

7 These significance levels follow the definitions presented in the footnotes in Table B-1 in
8 Appendix B of Subpart A of 10 CFR Part 51 (TN250). These are the same environmental
9 significance levels and definitions used in the License Renewal GEIS (NRC 2024-TN10161) and
10 in recent EISs prepared by the NRC staff for combined licenses and early site permits for new
11 light-water reactors (LWRs). The discussion of each Category 1 environmental impact issue in
12 this GEIS includes an explanation of how the significance category of SMALL was determined.
13 For issues for which the probability of occurrence is a key consideration (i.e., postulated
14 accidents), the probability of occurrence has been factored into the determination of
15 significance. Possible mitigation measures that could be used to avoid, minimize, rectify,
16 reduce, eliminate, or compensate for adverse impacts are discussed where appropriate.

- 17 • The SMEs assigned each issue to one of the two categories depending on the potential
18 utility of the generic analysis to applicants preparing specific new nuclear reactor licensing
19 applications and to the NRC staff when completing environmental reviews of those
20 applications. In summary, the categories are as follows:
- 21 • Category 1 issues – environmental issues for which a generic analysis concluding SMALL
22 adverse environmental impacts is possible, provided that relevant values and assumptions
23 in the PPE and SPE are met, or beneficial impacts;
- 24 • Category 2 issues – environmental issues for which a meaningful generic analysis of
25 environmental impacts is not possible because the issue requires consideration of
26 project-specific information.

27 In addition, as discussed in Section 1.3.3.3, there are two issues that are designated as N/A
28 (i.e., impacts are Uncertain), which are neither Category 1 nor 2.

29 Category 1 issues include one or more PPE/SPE parameters with associated values and
30 assumptions; these values and assumptions are set to define a SMALL impact. This GEIS
31 provides generic analyses for these Category 1 environmental issues, organized under the
32 16 environmental resources described in Chapter 3 of this GEIS.

33 An applicant addressing a Category 1 issue in its environmental report (ER) may refer to the
34 generic analysis in this GEIS for that issue without further analysis, provided that it
35 demonstrates that the relevant values and assumptions of the PPE and SPE used in the
36 resource analysis are met and there is no new and significant information that would require
37 project-specific analysis. The applicant will have to document how the values and assumptions
38 are met, unless this is made clear in other information provided in the application package. The
39 extent of the information necessary to demonstrate that a value or assumption is met will vary.
40 In some cases, the demonstration may only require showing that the project falls within a
41 parameter value or assumption (e.g., building height). But in other cases, analysis may be
42 required to demonstrate that a value or assumption has been met (e.g., building- or operations-
43 related noise levels).

1 If the relevant values and assumptions for a Category 1 issue are not met, the applicant would
2 have to supply the requisite information necessary for the staff to perform a project-specific
3 analysis. One place for guidance for applicants providing information to the staff in an ER is
4 available in the latest version of Regulatory Guide (RG) 4.2² (NRC 2024-TN7081). The applicant
5 may, however, be able to incorporate by reference all or part of the generic analysis provided in
6 this GEIS and focus on providing the additional project-specific information needed. Applicants
7 addressing Category 2 issues in an ER would have to provide all the information typically
8 needed by the staff to perform a project-specific analysis and may rely on guidance available in
9 RG 4.2 (NRC 2024-TN7081). The staff expects that applicants may be able to rely on the
10 generic conclusions for certain Category 1 issues, but not all Category 1 issues.

11 When addressing Category 1 issues in SEISs, the NRC staff may likewise refer to the generic
12 analysis in this GEIS for that issue without further analysis, provided that the relevant values
13 and assumptions in the PPE and SPE are met and there is no new and significant information
14 that changes the conclusions in this GEIS. Staff may also have to briefly document how the
15 values and assumptions are met. If the relevant values and assumptions are not met, staff
16 would have to complete a project-specific analysis in accordance with the latest version of the
17 Environmental Standard Review Plan or related guidance (such as any relevant Interim Staff
18 Guidance). Staff may however be able to streamline the effort by incorporating all or a portion of
19 the generic analysis in this GEIS and expanding it to account for project-specific information.

20 It is possible that applicants for certain new nuclear reactors carefully designed to minimize
21 environmental impacts may be able to demonstrate that their projects fall within all or most of
22 the values and assumptions and may be able to reference generic analyses in this GEIS for all
23 or most of the Category 1 environmental issues. In such a case, the NRC staff's SEIS would
24 likely be shorter than an EIS has been in the past for a typical new reactor application. Also, as
25 has always been the case, if the design of a project is such that an environmental issue (or
26 group of environmental issues) is not applicable, then the applicant need not analyze the
27 issue(s). For example, if the nuclear reactor design does not use cooling water then the impact
28 issues associated with the use of cooling water do not need to be analyzed. However, the
29 applicant must briefly describe its basis for concluding that the issue(s) is/are not applicable.

30 The NRC cannot rely on this GEIS alone to analyze the environmental impacts of construction
31 or operation of any nuclear reactors. For example, the staff would still have to conduct the
32 consultations required by Section 106 of the National Historic Preservation Act (54 U.S.C.
33 §§ 300101 et seq.; TN4157) and Section 7 of the ESA (16 U.S.C. §§ 1531 et seq.; TN1010) and
34 include the documentation in the SEIS for each application using this GEIS. Therefore, these
35 consultations will not be part of this GEIS. The NRC staff will still have to complete other project-
36 specific analyses upon receiving a new nuclear reactor application.

37 The NRC staff has evaluated fuel cycle impacts for LWRs, as documented in 10 CFR 51.51
38 (10 CFR Part 51-TN250), Table S-3, Table of Uranium Fuel Cycle Environmental Data.
39 However, in accordance with 10 CFR 51.51, only an ER for LWRs can include Table S-3. For
40 reactors other than LWRs, the application must contain the basis for evaluating the contribution
41 of the environmental effects of fuel cycle activities for the reactor (10 CFR 51.50(b)(3) and
42 10 CFR 51.50(c)). Section 3.14 of this NR GEIS evaluated the fuel cycle impacts for nuclear
43 reactor fuel and determined that data from Table S-3 could bound the impacts of the fuel cycle
44 for certain advanced non-LWRs. An applicant for an advanced non-LWR license could meet the

² Unless stated otherwise, references to RG 4.2 in this document refer to DG-4032 (NRC 2022-TN7081), the draft revision to RG 4.2, which is being published at the same time as this draft GEIS.

1 requirements of 10 CFR 51.50(b)(3) and 10 CFR 51.50(c) by demonstrating that their fuel falls
2 within the fuel cycle analysis in this GEIS. If the fuel cycle or parts of the fuel cycle do not fall
3 within the analysis in this GEIS, then the applicant would need to provide the analysis of the
4 parts of the fuel cycle that are not bounded.

5 This GEIS incorporates by reference NUREG-2157, *Generic Environmental Impact Statement*
6 *for Continued Storage of Spent Nuclear Fuel* (NRC 2014-TN4117), in which the NRC evaluated
7 the environmental impacts of the continued storage of spent nuclear fuel beyond the licensed
8 life for the operation of LWRs. In 10 CFR 51.23 (TN250), “Environmental impacts of continued
9 storage of spent nuclear fuel beyond the licensed life for operation of a reactor,” the NRC
10 specifies that NUREG-2157 is deemed to be incorporated into the EIS for a new reactor.
11 However, NUREG-2157 did not evaluate the storage of spent nuclear fuel from non-LWRs. The
12 staff expects that many new nuclear reactors will not be LWRs. Section 3.14.2.6 of this
13 NR GEIS therefore evaluates the applicability of NUREG-2157 and determines that the findings
14 were applicable to non-LWR fuel, provided that the non-LWR fuel is stored in a manner that
15 meets the regulatory requirements for spent fuel storage cask approval and fabrication in
16 accordance with 10 CFR Part 72 (TN4884), Subpart L – “Approval of Spent Fuel Storage
17 Casks,” as was the LWR spent fuel evaluated in NUREG-2157 (NRC 2014-TN4117).

18 The NRC has generically evaluated the environmental impacts of the transportation of fuel and
19 waste in 10 CFR 51.52 (TN250), “Environmental effects of transportation of fuel and waste –
20 Table S4,” Table S-4, Environmental Impact of Transportation of Fuel and Waste to and from
21 One Light Water Cooled Nuclear Power Reactor, for LWR fuel that meets certain entry
22 conditions specified in 10 CFR 51.52(a). The staff evaluated the impacts of transportation of
23 non-LWR fuel and waste in Section 3.15 of this GEIS and determined that the shipment of
24 unirradiated and irradiated non-LWR fuel and radioactive waste would be a Category 1 issue.
25 The applicant can rely on the generic analysis as long as the PPE values and assumptions are
26 met.

27 This GEIS incorporates by reference NUREG-0586, Supplement 1 (NRC 2002-TN665), in which
28 the NRC evaluated the environmental impacts of the decommissioning of nuclear power
29 reactors as residual radioactivity at the site is reduced to levels that allow for termination of the
30 NRC license. The NRC staff’s evaluation of the environmental impacts of decommissioning
31 presented in NUREG-0586, Supplement 1, considered environmental issues for LWRs and
32 three permanently shutdown facilities that included a fast breeder reactor and two
33 high-temperature gas-cooled reactors (NRC 2002-TN665). NUREG-0586, Supplement 1,
34 identified whether the environmental issues were considered generic to all decommissioning
35 sites or project-specific. While most issues were considered generic to all decommissioning
36 sites, two issues were determined to require a project-specific review and four issues were
37 considered to be conditionally project-specific. Therefore, in Section 3.16.2 of this GEIS, the
38 NRC staff evaluated the applicability of NUREG-0586, Supplement 1, and determined that the
39 findings for the issues considered generic to all decommissioning sites are expected to be
40 applicable to any new nuclear reactor, provided that the impacts from decommissioning can be
41 shown to be within the bounds described in the Decommissioning GEIS, and that regulatory
42 requirements for decommissioning in 10 CFR 50.82 (TN249) or 10 CFR 52.110 (TN251) are
43 met. Additional analysis would be required for the identified project-specific issues.

44 In summary, the general analytical approach used by the NRC staff in this GEIS to evaluate
45 environmental impacts was to (1) describe each environmental issue relevant to each of the 16
46 environmental resources considered; (2) categorize each issue as Category 1 or Category 2;

1 (3) identify for each Category 1 issue the relevant values and assumptions in the PPE and SPE;
2 and (4) assess the significance of the environmental impact on the Category 1 issue.

3 **1.3.2 Primary Documents Used to Develop this GEIS**

4 The NRC staff drew information from a broad range of sources while developing this GEIS,
5 including the following more prominent written sources:

- 6 • Results of Exploratory Process for Developing a Generic Environmental Impact Statement
7 for the Construction and Operation of Advanced Nuclear Reactors (SECY-20-0020,
8 NRC 2020-TN6493)
- 9 • Staff Requirements – SECY-20-0020 – Results of Exploratory Process for Developing a
10 Generic Environmental Impact Statement for the Construction and Operation of Advanced
11 Nuclear Reactors (SRM-SECY-20-0020, NRC 2020-TN6492)
- 12 • Staff Requirements – SECY-21-0098 – Proposed Rule: Advanced Nuclear Reactor Generic
13 Environmental Impact Statement (SRM SECY-21-0098, NRC 2021-TN10127)
- 14 • Staff Requirements – SECY-23-0001 – Options for Licensing and Regulating Fusion Energy
15 Systems (SRM SECY-23-0001, NRC 2023-TN10128)
- 16 • *Standard Review Plans for Environmental Reviews for Nuclear Power Plants*
17 (NUREG-1555, NRC 2000-TN614)
- 18 • *Preparation of Environmental Reports for Nuclear Power Stations* (RG 4.2, NRC 2018-
19 TN6006)
- 20 • *Generic Environmental Impact Statement for License Renewal of Nuclear Plants*
21 (NUREG-1437, NRC 2024-TN10161)
- 22 • *Generic Environmental Impact Statement for In-Situ Leach Uranium Milling Facilities*
23 (NUREG-1910, NRC 2009-TN2559)
- 24 • *Generic Environmental Impact Statement for Continued Storage of Spent Nuclear Fuel:*
25 *Final Report, Volumes 1 and 2* (NUREG-2157, NRC 2014-TN4117)
- 26 • *Generic Environmental Impact Statement on Decommissioning of Nuclear Facilities:*
27 *Supplement 1, Regarding the Decommissioning of Nuclear Power Reactors* (NUREG-0586,
28 Supplement 1, NRC 2002-TN665)
- 29 • *Environmental Considerations Associated with Micro-Reactors* (COL-ISG-029, NRC 2019-
30 TN6523)
- 31 • *Final Environmental Assessment for the Use of Department of Energy-Owned High-Assay*
32 *Low-Enriched Uranium Stored at Idaho National Laboratory* (DOE/EA-2087; DOE 2019-
33 TN6757)
- 34 • *Advanced Nuclear Reactor Plant Parameter Envelope and Guidance* (NRIC-21-ENG-0001;
35 PNNL-30992, NRIC 2021-TN6940)
- 36 • *Advances in Small Modular Reactor Technology Developments; A Supplement to IAEA*
37 *Advanced Reactors Information System (ARIS), 2020 Edition* (IAEA 2020-TN6953)
- 38 • *Manifest Information Management System* (DOE 2024-TN10120).

1 **1.3.3 Issue Categories**

2 *1.3.3.1 Category 1 Issues – Generic Analysis*

3 This GEIS identifies 100 environmental issues as Category 1 issues. Chapter 3 of this GEIS
4 provides generic analyses for each Category 1 issue and indicates the relevant values and
5 assumptions in the PPE and SPE underlying the analyses. Applicants and NRC staff may rely
6 on the generic analysis for each Category 1 issue provided that the relevant values and
7 assumptions are met and there is no new and significant information that changes the
8 conclusions in this GEIS.

9 These issues and a list of the sections where they are discussed in this GEIS are listed in
10 Table 1-1 (in Section 1.3.3.3).

11 *1.3.3.2 Category 2 Issues – Project-Specific Analysis*

12 This GEIS identifies 20 environmental issues as Category 2 issues. These issues cannot be
13 evaluated generically and must be evaluated in the ER and SEIS using project-specific
14 information. For example, the ESA requires every Federal agency to document its consideration
15 of the impacts of its actions on threatened and endangered species and critical habitats. This
16 ESA Section 7 consultation requirement is required in addition to NEPA; however, the impacts
17 on threatened and endangered species and critical habitat are considered in the NEPA
18 documents.

19 These issues and a list of the sections where they are discussed in this GEIS are listed in
20 Table 1-1.

21 *1.3.3.2.1 Resource-Specific Category 2 Issues*

22 Category 2 issues specific to a given environmental resource are described in the applicable
23 section of Chapter 3.

24 *1.3.3.2.2 Category 2 Issues Applying Across Resources*

25 Certain Category 2 issues apply across all resources and are summarized below.

26 Climate Change

27 Climate change is a subject of national and international interest that causes changes to the
28 affected environment. Commission Order CLI-09-21 (NRC 2009-TN6406) provides the current
29 direction to the NRC staff to include the consideration of the impacts of the emissions of carbon
30 dioxide and other greenhouse gases in its environmental reviews for major licensing actions.
31 Climate change is an environmental trend that could result in changes to the affected
32 environment independent of the new nuclear reactor project. Climate-related changes include
33 rising temperatures and sea levels; increased frequency and intensity of extreme weather (e.g.,
34 heavy downpours, floods, and droughts); earlier snowmelts and associated frequent wildfires;
35 and reduced snow cover, glaciers, permafrost, and sea ice. Greenhouse gases are transparent
36 to incoming short-wave radiation from the sun but opaque to outgoing long-wave (infrared)
37 radiation from the Earth's surface. The net effect over time is a trapping of absorbed radiation
38 and a tendency to warm the Earth's atmosphere, which together constitute the "greenhouse
39 effect" (GCRP 2014-TN3472, USGCRP 2023-TN9762).

1 The NRC staff has considered the impacts of climate change in its recent new reactor EISs.
2 Climate change can lead to changes in the affected environment around a new reactor project,
3 potentially influencing the level of impacts on resources affected by the project. However, the
4 effects of climate change are location-specific and cannot, therefore, be evaluated generically.
5 For example, while climate change may cause many areas to receive less average annual
6 precipitation, other areas may see an increase in average annual precipitation. Therefore,
7 applicants and staff will address the effects of climate change in the environmental documents
8 for new nuclear reactor licensing. For additional information, see RG 4.2 (NRC 2024-TN7081)
9 and Interim Staff Guidance (ISG), COL/ESP-ISG-026 (NRC 2014-TN3767).

10 Cumulative Effects

11 Cumulative effects are the effects on the environment that result from the incremental effects of
12 the proposed action when added to the effects of other past, present, and reasonably
13 foreseeable actions, regardless of which agency (Federal or non-Federal) or person undertakes
14 such other actions. Evaluating cumulative effects without knowing specific site locations or the
15 time frame for evaluating reasonably foreseeable actions is not possible generically. The
16 cumulative effects of building and operating a nuclear reactor must be considered on a
17 project-specific basis. Effects would depend on regional resource characteristics, the
18 resource-specific impacts of the proposed project, and the cumulative significance of other
19 factors affecting the resource. This is a Category 2 issue.

20 *1.3.3.2.3 Non-Resource Related Category 2 Issues*

21 This GEIS addresses the environmental impact issues associated with building and operating a
22 nuclear reactor. However, the ER and the staff's SEIS must also include other information, as
23 required by the regulations and discussed in regulatory guidance. These are not resource-
24 specific issues. Rather, they are project-specific issues, not tied to any specific environmental
25 resource, that are necessary to support the NRC staff's completion of its environmental review
26 in accordance with NEPA. These issues cannot be evaluated generically and must be
27 addressed in the ER and SEIS using project-specific information. Because of their unique
28 nature, some of these issues are discussed further below, and are summarized in Table 4-1 (in
29 Chapter 4). This list is not all-inclusive. NRC regulations at 10 CFR Part 51 (TN250) and
30 guidance such as RG 4.2 (NRC 2024-TN7081) describe information not included in this list that
31 must be included as part of an application.

32 Purpose and Need

33 The applicant must describe in its ER the purpose and need for its proposed action, i.e., the
34 reasons for developing the project (10 CFR 51.45(b); TN250). The NRC staff will use this
35 information to inform its development of the NRC's purpose and need in the SEIS. Properly
36 defining the purpose and need is a critical step in the development of an environmental
37 document for the purposes of meeting NEPA requirements because it establishes the need for
38 the action and the range of reasonable alternatives that must be considered. For additional
39 information, see RG 4.2 (NRC 2024-TN7081, ISG COL/ESP-ISG-026 (NRC 2014-TN3767), and
40 COL-ISG-029 (NRC 2019-TN6523).

41 Need for Power

42 The Atomic Energy Act requires the social and environmental consequences of the civilian use
43 of nuclear materials be weighed against the benefits that their use would provide. Historically,

1 the primary benefit of nuclear power generation projects has been to provide electrical power to
2 the grid. Therefore, the NRC staff has evaluated the need for power in its new reactor EISs. Any
3 new nuclear reactor that uses this GEIS may also provide power to the grid, and if so, may
4 require the same type of need for power evaluation in both the ER and SEIS. However, some
5 nuclear reactors may be built for other purposes (e.g., to generate process heat, to desalinate
6 water, or as a research and demonstration project). In such cases, the applicant will need to
7 present, and the NRC staff will have to evaluate, the need for the project (10 CFR 51.45(b);
8 TN250).

9 Alternatives

10 The applicant's ER must address alternatives to the proposed action (10 CFR 51.45(b)(3) and
11 (c); TN250). Identification and evaluation of alternatives for any proposed action are inherently
12 project-specific. The NRC staff is unable to generically evaluate alternatives universally
13 applicable to licensing of new nuclear reactors. This GEIS therefore does not consider any
14 alternatives to the action of constructing and operating a nuclear reactor. Identification of a
15 range of reasonable alternatives³ requires consideration of information about a specific project
16 and site. The staff will have to individually consider the range of reasonable alternatives that
17 meet the purpose and need behind each incoming new nuclear reactor licensing application.

18 Most new reactor EISs prepared by the NRC staff have evaluated alternatives with respect to
19 the proposed reactor site (site alternatives), with respect to fuel used to generate the requisite
20 power (energy alternatives), and with respect to cooling system use (system design
21 alternatives). Each of these broad types of alternatives is briefly discussed in the sections
22 below. The staff expects that the range of reasonable alternatives will differ for each incoming
23 new nuclear reactor licensing application and may include alternatives from one or more of
24 these groupings of possible alternatives. Other types of alternatives might also be possible.

25 Site Alternatives

26 New reactor EISs prepared by NRC staff have evaluated in detail siting the proposed reactor
27 at three or four alternative sites as well as the proposed site (unless siting has been previously
28 addressed, as in the case of a combined license referencing an early site permit). For any site
29 to be a reasonable alternative, it must meet all of the NRC siting criteria established in 10 CFR
30 Part 100 (TN282). Applicants typically consider many other factors as well when determining
31 whether sites are reasonable alternatives—factors such as proximity to customers, proximity to
32 existing transmission lines, availability of water sources, land ownership, avoidance of sensitive
33 features such as wetlands and historic sites, accessibility to workers, and considerations of local
34 residents and government officials. Applicants often favor sites on or adjacent to existing
35 nuclear plant sites or sites containing other energy generation facilities. The advantages of such
36 sites include the availability of existing transmission lines, pipelines, highways, and other
37 facilities that do not have to be newly built, thereby reducing construction costs and disturbance
38 to non-industrial landscapes and environmentally sensitive lands.

³ Changes to the NEPA statute (42 U.S.C. § 4321 et seq.) from the Fiscal Responsibility Act of 2023 (Public Law No. 118-5, 137 Stat. 10) included adding a new Section 102(2)(F) directing agencies to "...study, develop, and describe technically and economically feasible alternatives." The Council on Environmental Quality defines "reasonable alternatives" as meaning a "reasonable range of alternatives that are technically and economically feasible, and meet the purpose and need for the proposed action" (40 CFR 1508.1(hh)).

1 Applicants commonly follow systematic approaches to narrowing a field of potential sites such
2 as that developed by the Electric Power Research Institute (EPRI 2015-TN5285). However, use
3 of any specific siting guidance is not mandatory. The NRC offers additional guidance in RG 4.7
4 (NRC 2014-TN3550).

5 The geographical area that must be considered for site alternatives will be determined based on
6 the purpose and need for the proposed action. ISG COL/ESP-027 (NRC 2014-TN3774)
7 contains some insights regarding this aspect in its discussion of Chapter 9.

8 According to ISG-027, an applicant may request construction at a specific location to meet its
9 purpose and need for a light-water small modular reactor (SMR) facility (NRC 2014-TN3774).
10 For example, an applicant may propose to use excess heat for industrial processes or station
11 heating. A proposed SMR may be used to provide a secure energy source for military,
12 government, or critical industrial facilities. In these cases, the applicant must still submit and the
13 staff must review alternative sites. However, the region of interest used for the site selection
14 process may be much smaller than is typical for large LWRs (e.g., within the confines of a
15 military installation).

16 Although the ISG was written specifically for SMRs, the fundamental concept is informative for
17 most other new nuclear reactors as well. The range of alternatives that must be considered is a
18 direct product of the purpose and need for the proposed action. The proposed and alternative
19 sites can be adjacent to each other.

20 This GEIS can be used for both the proposed and alternative sites for the evaluation of resource
21 impacts. However, the application must compare the differences between the proposed and
22 alternative sites, so that a determination can be made about whether an alternative site is
23 environmentally preferable or obviously superior to the proposed site.

24 Energy Alternatives

25 A reasonable alternative must meet the purpose and need for the project. For example, new
26 reactor EISs recently have evaluated alternatives that could meet the purpose and need for the
27 project to supply baseload power. The EISs have evaluated alternatives such as coal, natural
28 gas, and mixtures of natural gas and renewable energy sources that could supply baseload
29 power. Energy sources such as wind and solar by themselves were not considered reasonable
30 alternatives because they could not supply baseload power.

31 The range of alternative energy sources constituting reasonable alternatives for each proposed
32 new nuclear reactor project may differ. For example, if the purpose and need statement was “to
33 demonstrate a specific type of advanced reactor technology to supply power,” then coal, natural
34 gas, wind, or solar would not be reasonable alternatives because they do not demonstrate the
35 specific type of nuclear reactor technology and therefore the EIS would not evaluate them.
36 Other potential purposes of new reactors include desalinating water, providing process heat, or
37 aiding States in meeting carbon emission goals. Because the purpose and need for each project
38 is likely to be different, applicants and the NRC staff would have to individually identify
39 reasonable alternatives suited to each specific application.

40 System Design Alternatives

41 Because operation of water-based cooling systems to discharge waste heat from large nuclear
42 reactors has the potential to significantly affect the water bodies from which water is taken, and

1 into which it is discharged, new reactor EISs recently prepared by NRC staff have evaluated
 2 alternative system designs that use different cooling processes. Possible cooling systems
 3 considered have included (1) once-through cooling, in which water is withdrawn from a source
 4 such as a river or lake and run through the system once to absorb waste heat before being
 5 returned to the source; (2) recirculating cooling-water systems, in which water is withdrawn and
 6 recirculated through cooling towers multiple times (cycles of concentration) before being
 7 discharged; (3) air cooling that does not involve water; and (4) use of multiple cooling
 8 approaches. Different types of cooling towers are also possible, such as natural draft cooling
 9 towers comprising tall hyperbolic structures that direct air upward on a pressure gradient to cool
 10 water, or lower mechanical draft cooling towers that use electrically driven fans to cool water.
 11 Consideration of system design alternatives involving cooling systems may not be appropriate
 12 for nuclear reactors designed for air cooling or for which smaller volumes of cooling water may
 13 be used. If the design of the project does not use cooling water, then an evaluation of alternative
 14 cooling systems is not required. Because of the wide range of possible new nuclear reactor
 15 technologies, the NRC staff is not able to anticipate all possible alternative design approaches
 16 that might be reasonable.

17 **1.3.3.3 Uncertain Issues**

18 The GEIS identifies the impacts of two issues as Uncertain, and therefore the determination of
 19 Category 1 or Category 2 is not applicable (N/A). These issues relate to exposure to
 20 electromagnetic fields (EMFs). Studies of 60 hertz (Hz) EMFs have not uncovered consistent
 21 evidence linking harmful effects with field exposures. Because the state of the science is
 22 currently inadequate, no generic conclusion on human health impacts is possible. If, in the
 23 future, the Commission finds that a general agreement has been reached by appropriate
 24 Federal health agencies that there are adverse health effects from EMFs, the Commission will
 25 require applicants to submit plant-specific reviews of these health effects as part of their
 26 application. Until such time, applicants are not required to submit information on this issue.

27 **Table 1-1 Issues Discussed in the Generic Environmental Impact Statement**

| Issue | Section | Category |
|--|-----------|----------|
| Land Use | | |
| <i>Construction</i> | | |
| Onsite Land Use | 3.1.2.1.1 | 1 |
| Offsite Land Use | 3.1.2.1.2 | 1 |
| Impacts to Prime and Unique Farmland | 3.1.2.1.3 | 1 |
| Coastal Zone and Compliance with the Coastal Zone Management Act | 3.1.2.1.4 | 1 |
| <i>Operation</i> | | |
| Onsite Land Use | 3.1.2.2.1 | 1 |
| Offsite Land Use | 3.1.2.2.2 | 1 |
| Visual | | |
| <i>Construction</i> | | |
| Visual Impacts in Site and Vicinity | 3.2.2.1.1 | 1 |
| Visual Impacts from Transmission Lines | 3.2.2.1.2 | 1 |
| <i>Operation</i> | | |
| Visual Impacts During Operations | 3.2.2.2.1 | 1 |

Table 1-1 Issues Discussed in the Generic Environmental Impact Statement (Continued)

| Issue | Section | Category |
|---|----------------|-----------------|
| Air Quality | | |
| <i>Construction</i> | | |
| Emissions of Criteria Pollutants and Dust During Construction | 3.3.2.1.1 | 1 |
| Greenhouse Gas Emissions During Construction | 3.3.2.1.2 | 1 |
| <i>Operation</i> | | |
| Emissions of Criteria and Hazardous Air Pollutants during Operation | 3.3.2.2.1 | 1 |
| Greenhouse Gas Emissions During Operation | 3.3.2.2.2 | 1 |
| Cooling-System Emissions | 3.3.2.2.3 | 1 |
| Emissions of Ozone and oxides of nitrogen (NOx) during Transmission Line Operation | 3.3.2.2.4 | 1 |
| Water Resource | | |
| <i>Construction</i> | | |
| Surface Water Use Conflicts during Construction | 3.4.2.1.1 | 1 |
| Groundwater Use Conflicts due to Excavation Dewatering | 3.4.2.1.2 | 1 |
| Groundwater Use Conflicts due to Construction-Related Groundwater Withdrawals | 3.4.2.1.3 | 1 |
| Water Quality Degradation due to Construction-Related Discharges | 3.4.2.1.4 | 1 |
| Water Quality Degradation due to Inadvertent Spills during Construction | 3.4.2.1.5 | 1 |
| Water Quality Degradation due to Groundwater Withdrawal | 3.4.2.1.6 | 1 |
| Water Quality Degradation due to Offshore or In-Water Construction Activities | 3.4.2.1.7 | 1 |
| Water Use Conflict Due to Plant Municipal Water Demand | 3.4.2.1.8 | 1 |
| Degradation of Water Quality from Plant Effluent Discharges to Municipal Systems | 3.4.2.1.9 | 1 |
| <i>Operation</i> | | |
| Surface Water Use Conflicts during Operation due to Water Withdrawal from Flowing Water Bodies | 3.4.2.2.1 | 1 |
| Surface Water Use Conflicts during Operation due to Water Withdrawal from Non-flowing Water Bodies | 0 | 1 |
| Groundwater Use Conflicts Due to Building Foundation Dewatering | 3.4.2.2.3 | 1 |
| Groundwater Use Conflicts Due to Groundwater Withdrawals for Plant Uses | 3.4.2.2.4 | 1 |
| Surface Water Quality Degradation Due to Physical Effects from Operation of Intake and Discharge Structures | 3.4.2.2.5 | 1 |
| Surface Water Quality Degradation Due to Changes in Salinity Gradients Resulting from Withdrawals | 3.4.2.2.6 | 1 |
| Surface Water Quality Degradation Due to Chemical and Thermal Discharges | 3.4.2.2.7 | 2 |
| Groundwater Quality Degradation Due to Plant Discharges | 3.4.2.2.8 | 1 |
| Water Quality Degradation due to Inadvertent Spills and Leaks during Operation | 3.4.2.2.9 | 1 |
| Water Quality Degradation due to Groundwater Withdrawals | 3.4.2.2.10 | 1 |
| Water Use Conflict from Plant Municipal Water Demand | 3.4.2.2.11 | 1 |

Table 1-1 Issues Discussed in the Generic Environmental Impact Statement (Continued)

| Issue | Section | Category |
|---|----------------|-----------------|
| Degradation of Water Quality from Plant Effluent Discharges to Municipal Systems | 3.4.2.2.12 | 1 |
| Terrestrial Ecology | | |
| <i>Construction</i> | | |
| Permanent and Temporary Loss, Conversion, Fragmentation, and Degradation of Habitats | 3.5.2.1.1 | 1 |
| Permanent and Temporary Loss and Degradation of Wetlands | 3.5.2.1.2 | 1 |
| Effects of Building Noise on Wildlife | 3.5.2.1.3 | 1 |
| Effects of Vehicular Collisions on Wildlife | 3.5.2.1.4 | 1 |
| Bird Collisions and Injury from Structures and Transmission Lines | 3.5.2.1.5 | 1 |
| Important Species and Habitats – Resources Regulated under the Endangered Species Act of 1973 | 3.5.2.1.6 | 2 |
| Important Species and Habitats – Other Important Species and Habitats | 3.5.2.1.6 | 1 |
| <i>Operation</i> | | |
| Permanent and Temporary Loss or Disturbance of Habitats | 3.5.2.2.1 | 1 |
| Effects of Operational Noise on Wildlife | 3.5.2.2.2 | 1 |
| Effects of Vehicular Collisions on Wildlife | 3.5.2.2.2 | 1 |
| Exposure of Terrestrial Organisms to Radionuclides | 3.5.2.2.3 | 1 |
| Cooling-Tower Operational Impacts on Vegetation | 3.5.2.2.4 | 1 |
| Bird Collisions and Injury from Structures and Transmission Lines | 3.5.2.2.5 | 1 |
| Bird Electrocutions from Transmission Lines | 3.5.2.2.6 | 1 |
| Water Use Conflicts with Terrestrial Resources | 3.5.2.2.7 | 1 |
| Effects of Transmission Line ROW Management on Terrestrial Resources | 3.5.2.2.8 | 1 |
| Effects of Electromagnetic Fields on Flora and Fauna | 3.5.2.2.9 | 1 |
| Important Species and Habitats – Resources Regulated under the ESA of 1973 | 3.5.2.2.10 | 2 |
| Important Species and Habitats – Other Important Species and Habitats | 3.5.2.2.10 | 1 |
| Aquatic Ecology | | |
| <i>Construction</i> | | |
| Runoff and Sedimentation from Construction Areas | 3.6.2.1.1 | 1 |
| Dredging and Filling Aquatic Habitats to Build Intake and Discharge Structures | 3.6.2.1.2 | 1 |
| Building Transmission Lines, Pipelines, and Access Roads Across Surface Waterbodies | 3.6.2.1.3 | 1 |
| Important Species and Habitats – Resources Regulated under the ESA and Magnuson-Stevens Fishery Conservation and Management Act | 3.6.2.1.4 | 2 |
| Important species and habitats – Other Important Species and Habitats | 3.6.2.1.4 | 1 |
| <i>Operation</i> | | |
| Stormwater Runoff | 3.6.2.2.1 | 1 |
| Exposure of Aquatic Organisms to Radionuclides | 3.6.2.2.2 | 1 |
| Effects of Refurbishment on Aquatic Biota | 3.6.2.2.3 | 1 |

Table 1-1 Issues Discussed in the Generic Environmental Impact Statement (Continued)

| Issue | Section | Category |
|---|----------------|-----------------|
| Effects of Maintenance Dredging on Aquatic Biota | 3.6.2.2.4 | 1 |
| Impacts of Transmission Line ROW Management on Aquatic Resources | 3.6.2.2.5 | 1 |
| Impingement and Entrainment of Aquatic Organisms | 3.6.2.2.6 | 1 |
| Thermal Impacts on Aquatic Biota | 3.6.2.2.7 | 2 |
| Other Effects of Cooling-Water Discharges on Aquatic Biota | 3.6.2.2.8 | 2 |
| Water Use Conflicts with Aquatic Resources | 3.6.2.2.9 | 1 |
| Important Species and Habitats – Resources Regulated under the ESA and Magnuson-Stevens Act | 3.6.2.2.10 | 2 |
| Important species and habitats – Other Important Species and Habitats | 3.6.2.2.10 | 1 |
| Historic and Cultural Resources | | |
| <i>Construction</i> | | |
| Construction Impacts on Historic and Cultural Resources | 3.7.2 | 2 |
| <i>Operation</i> | | |
| Operation Impacts on Historic and Cultural Resources | 3.7.2 | 2 |
| Radiological Environment | | |
| <i>Construction</i> | | |
| Radiological Dose to Construction Workers | 3.8.1.2.1 | 1 |
| <i>Operation</i> | | |
| Occupational Doses to Workers | 3.8.1.2.2 | 1 |
| Maximally Exposed Individual Annual Doses | 3.8.1.2.2 | 1 |
| Total Population Annual Doses | 3.8.1.2.2 | 1 |
| Nonhuman Biota Doses | 3.8.1.2.2 | 1 |
| Nonradiological Environment | | |
| <i>Construction</i> | | |
| Building Impacts of Chemical, Biological, and Physical Nonradiological Hazards | 3.8.2.2.1 | 1 |
| Building Impacts of EMFs | 3.8.2.2.1 | N/A |
| <i>Operation</i> | | |
| Operation Impacts of Chemical, Biological, and Physical Nonradiological Hazards | 3.8.2.2.2 | 1 |
| Operation impacts of EMFs | 3.8.2.2.2 | N/A |
| Noise | | |
| <i>Construction</i> | | |
| Construction-Related Noise | 3.9.2.1 | 1 |
| <i>Operation</i> | | |
| Operation-Related Noise | 3.9.2.2 | 1 |
| Radiological Waste Management | | |
| <i>Operation</i> | | |
| Low-Level Radioactive Waste | 3.10.1.2.1 | 1 |
| Onsite Spent Nuclear Fuel and High-Level Waste Management | 3.10.1.2.2 | 1 |
| Mixed Waste | 3.10.1.2.3 | 1 |

Table 1-1 Issues Discussed in the Generic Environmental Impact Statement (Continued)

| Issue | Section | Category |
|--|----------------|-----------------|
| Nonradiological Waste Management | | |
| <i>Construction</i> | | |
| Construction Nonradiological Waste | 3.10.2.2.1 | 1 |
| <i>Operation</i> | | |
| Operation Nonradiological Waste | 3.10.2.2.2 | 1 |
| Postulated Accidents | | |
| <i>Operation</i> | | |
| Design Basis Accidents Involving Radiological Releases | 3.11.2.1 | 1 |
| Accidents Involving Releases of Hazardous Chemicals | 3.11.2.2 | 1 |
| Severe Accidents | 3.11.2.3 | 2 |
| Severe Accident Mitigation Design Alternatives | 3.11.2.4 | 1 |
| Acts of Terrorism | 3.11.2.5 | 1 |
| Socioeconomics | | |
| <i>Construction</i> | | |
| Community Services and Infrastructure | 3.12.2.1.1 | 1 |
| Transportation Systems and Traffic | 3.12.2.1.2 | 1 |
| Economic Impacts | 3.12.2.1.3 | 1 |
| Tax Revenue Impacts | 3.12.2.1.4 | 1 |
| <i>Operation</i> | | |
| Community Services and Infrastructure | 3.12.2.2.1 | 1 |
| Transportation Systems and Traffic | 3.12.2.2.2 | 1 |
| Economic Impacts | 3.12.2.2.3 | 1 |
| Tax Revenue Impacts | 3.12.2.2.4 | 1 |
| Environmental Justice | | |
| <i>Construction</i> | | |
| Construction Environmental Justice Impacts | 3.13.2.1 | 2 |
| <i>Operation</i> | | |
| Operation Environmental Justice Impacts | 3.13.2.1 | 2 |
| Fuel Cycle | | |
| <i>Operation</i> | | |
| Uranium Recovery | 3.14.2.1 | 1 |
| Uranium Conversion | 3.14.2.2 | 1 |
| Enrichment | 3.14.2.3 | 1 |
| Fuel Fabrication ^(a) | 3.14.2.4 | 1 |
| Reprocessing | 3.14.2.5 | 1 |
| Storage and Disposal of Radiological Wastes | 3.14.2.6 | 1 |
| Transportation of Fuel and Waste | | |
| <i>Operation</i> | | |
| Transportation of Unirradiated New Reactor Fuel | 3.15.2.1 | 1 |
| Transportation of Radioactive Waste from New Reactors | 3.15.2.2 | 1 |
| Transportation of Irradiated Fuel from New Reactors | 3.15.2.3 | 1 |

Table 1-1 Issues Discussed in the Generic Environmental Impact Statement (Continued)

| Issue | Section | Category |
|---|-----------|----------|
| Decommissioning | | |
| Decommissioning Impacts (generically addressed issues in NUREG-0586) | 3.16.2 | 1 |
| Decommissioning Impacts (site-specific and/or conditionally site-specific issues in NUREG-0586) | 3.16.2 | 2 |
| Issues Applying Across All Resources | | |
| Climate Change | 1.3.3.2.2 | 2 |
| Cumulative Impacts | 1.3.3.2.2 | 2 |
| Non-Resource Related Issues | | |
| Purpose and Need | 1.3.3.2.3 | 2 |
| Need for Power | 1.3.3.2.3 | 2 |
| Site Alternatives | 1.3.3.2.3 | 2 |
| Energy Alternatives | 1.3.3.2.3 | 2 |
| System Design Alternatives | 1.3.3.2.3 | 2 |
| (a) Fuel fabrication impacts for metal fuel and liquid fueled molten salt are not included in the NRC staff's generic analysis. | | |

1 1.4 Implementation of the Rule (10 CFR Part 51)

2 Applicants and the NRC staff will use this GEIS as a tool to increase the efficiency and
3 effectiveness of environmental reviews for constructing and operating new nuclear reactors,
4 while at the same time ensuring that NRC's NEPA requirements are met. This GEIS presents
5 generic analyses of environmental impacts that the staff expects will be common to most new
6 nuclear reactors meeting a set of design conditions (termed the PPE) built on a hypothetical site
7 meeting a set of site conditions (termed the SPE) (Appendix G). Applicants will be able to
8 streamline ERs by referring to the generic analyses in this GEIS codified in 10 CFR Part 51
9 (TN250) whenever possible and focus on providing the project-specific information needed for
10 the staff to complete environmental reviews of issues that cannot be addressed generically.

11 The staff will be able to streamline environmental reviews by referring to the generic analyses in
12 this GEIS whenever possible and focus their review efforts on environmental issues where a
13 consideration of project-specific information is needed to ascertain the potential for significant
14 environmental impacts. Upon receipt of specific new nuclear reactor licensing applications, the
15 staff will prepare SEISs tiered⁴ from this GEIS, in accordance with the associated rule, that
16 briefly identify the environmental issues that can be addressed through this GEIS and then
17 cover the remaining issues in more detail using project-specific information. The staff expects
18 that use of this GEIS along with the SEIS will reduce the time and resources needed to
19 complete environmental reviews, while still providing decision-makers and the public with a
20 complete and robust analysis of potential environmental impacts and meeting all NEPA
21 requirements.

22 Applicants for a construction permit and operating license or a combined license for a nuclear
23 reactor are required as part of their application to submit a safety analysis report and an ER.
24 The NRC then performs a safety review which results in a safety evaluation report and an

⁴ The process of tiering is described in 10 CFR Part 51, Subpart A, Appendix A.

1 environmental review that results in an EIS. This GEIS does not evaluate the safety of a reactor
2 design; that is a separate review done when an application is submitted.

3 Every 10 years, the Commission intends to review the material in this NR GEIS and the
4 associated rule and update it if necessary. A scoping notice will be published in the *Federal*
5 *Register* inviting public comments and proposals for other areas that should be updated and
6 indicating the results of the NRC's review.

7 The implementation of the rule is described in more detail below.

8 **1.4.1 General Requirements**

9 The regulatory requirements for conducting a NEPA review for a new nuclear reactor are the
10 same as the requirements for other plant licensing actions. Consistent with the current NEPA
11 practice for plant licensing actions, an applicant will be required to submit an ER that assesses
12 the environmental impacts associated with the proposed action, consider alternatives to the
13 proposed action, and evaluate any alternatives for reducing adverse environmental effects. For
14 a new nuclear reactor license using this NR GEIS, the NRC will prepare a draft SEIS to this
15 GEIS for public comment and issue a final SEIS after considering public comments on the draft.

16 **1.4.2 Applicant's Environmental Report**

17 The applicant's ER must contain an assessment of the environmental impacts of constructing
18 and operating a nuclear reactor and alternatives that meet the purpose and need. In preparing
19 the analysis of environmental impacts contained in the ER, the applicant should refer to the
20 information provided in Table C-1 of 10 CFR Part 51 (TN250). The applicant is not required to
21 assess the environmental impacts of Category 1 issues listed in Table C-1 if (1) the applicant
22 has demonstrated that its project is bounded by the applicable PPE and SPE values and
23 assumptions in Table C-1, and (2) the applicant has not identified any new and significant
24 information that would change the conclusions in this GEIS. If a value or assumption is not met,
25 then the applicant may be able to limit its analysis to just the impact of not meeting the value or
26 assumption. Similarly, if the applicant identifies new and significant information that would
27 change the conclusions in this GEIS, then the applicant may be able to limit its analysis to just
28 the impact of the new and significant information. For Category 2 issues listed in Table C-1, the
29 applicant must provide a project-specific assessment of the impacts.

30 **1.4.3 The NRC's SEIS**

31 As required by 10 CFR 51.20(b)(2) (TN250), the NRC will be required to prepare a SEIS to this
32 GEIS for each new nuclear reactor application using this NR GEIS. The SEIS will serve as the
33 NRC's analysis of the environmental impacts of issuing a new nuclear reactor license and will
34 compare those impacts to the environmental impacts of the alternatives. This document will also
35 present the NRC's recommendation to approve or deny the proposed action.

36 **1.4.4 Public Scoping and Public Comments**

37 For a SEIS, the NRC will conduct scoping to inform the public about the licensing process, and
38 typically will hold public scoping meetings to receive comments about the scope of the NRC's
39 plant-specific environmental review. At the conclusion of the scoping period, the NRC will review
40 and address public comments in a scoping summary report. In addition, the draft SEIS will be
41 issued for public comment (see 10 CFR 51.73; TN250). In both the scoping and the SEIS public

1 comment process, the NRC will consider comments and will determine whether the comments
2 provide any information that is new and significant compared to information previously
3 considered in this GEIS (for Category 1 issues). If the comments are determined to provide new
4 and significant information that could change the conclusions in this GEIS, these comments will
5 be considered and addressed in the SEIS.

6 **1.4.5 The NRC’s Draft SEIS**

7 The NRC’s draft SEIS will include its analysis of the environmental impacts of the proposed
8 action and the environmental impacts of the alternatives to the proposed action. The NRC will
9 use and integrate (1) the environmental impacts of the proposed action as provided in Table C-1
10 of 10 CFR Part 51 (TN250) for Category 1 issues, (2) the appropriate plant-specific analyses of
11 Category 2 issues, (3) other project-specific information necessary to support the analyses (see
12 Section 1.3.3), and (4) any new and significant information identified in the applicant’s ER or
13 during the scoping and public comment process, to arrive at a conclusion regarding the
14 environmental impacts of issuing a new nuclear reactor license. These impacts will be
15 compared to the environmental impacts of the alternatives presented in the SEIS.

16 **1.4.6 The NRC’s Final SEIS**

17 The NRC will issue a final SEIS in accordance with 10 CFR 51.91 and 51.93 (10 CFR Part 51-
18 TN250) after considering (1) the public comments, (2) the analysis of Category 2 issues, and
19 (3) any new and significant information involving Category 1 issues. The NRC will provide a
20 record of its decision regarding the environmental impacts of the proposed action (see 10 CFR
21 51.102 and 51.103). All comments on the draft SEIS will be addressed by the NRC in the final
22 SEIS in accordance with 10 CFR 51.91(a)(1).

23
24

2 DESCRIPTION OF PROPOSED ACTION AND ALTERNATIVES

The term “alternatives” is used two ways in this GEIS. The first use refers to alternatives to the proposed action of issuing the GEIS. Only those alternatives, outlined below in Section 2.1, are compared in the GEIS and considered in the record of decision for the GEIS. The other use refers to alternatives to building and operation of a specific nuclear reactor. It is possible to identify those alternatives only after identification of a specific project on a specific site. The NRC staff will evaluate and compare such alternatives in a supplemental EIS (SEIS) issued following receipt of each individual new nuclear reactor licensing application.

2.1 Proposed Action and Alternatives to the GEIS

The staff developed the following proposed action and alternatives in response to the purpose and need outlined in Section 1.1. These alternatives were developed and informed by an exploratory process completed in January 2020, involving interested stakeholders and through the public scoping process that concluded in May 2020.

2.1.1 Proposed Action: Issue Technology-Neutral GEIS Based on Performance-Based Assumptions

The proposed action is for the NRC to issue a GEIS containing generic analyses of the environmental impacts of building and operation of a hypothetical nuclear reactor on a hypothetical site. The generic analyses for each Category 1 issue would be bounded by the plant design values and assumptions in the PPE and by the site condition values and assumptions in the SPE presented in Appendix G. The values and assumptions in Appendix G are performance-based, where performance reflects minimization of potential environmental impacts by the applicant when choosing a plant design and site prior to submitting an application. The values and assumptions are based on environmental conditions and impact levels below which the staff believes that they may rely on a generic analysis to confidently conclude that environmental impacts would be SMALL for any location within the United States.

This GEIS presents generic analyses for Category 1 issues, for which a meaningful impact assessment is possible based on reasonable values and assumptions in the PPE and SPE. Category 2 issues include those environmental issues for which a meaningful generic analysis of environmental impacts is not possible without consideration of project-specific information. As such, analysis of Category 2 issues is not included in this GEIS.

Once this GEIS is issued, applicants will be able to rely on and reference the generic analyses for each Category 1 issue for which the proposed project is bounded by the PPE and SPE values and assumptions, thereby streamlining the environmental reviews associated with a new nuclear reactor application. The NRC staff will likewise be able to reference the generic analyses when it prepares a SEIS in response to an application, thereby simplifying and streamlining the environmental reviews. Instead of developing individual analyses specific to all environmental issues in any proposed new nuclear reactor ER or SEIS, applicants and NRC staff may focus their efforts on the environmental issues that require individualized consideration of project-specific information (Category 1 issues where the proposed project is not bounded by the PPE and SPE values and assumptions, and Category 2 issues) to address the potential for significant environmental impacts. The shorter, more focused ERs and SEISs will help NRC staff and decision-makers concentrate on issues for which there is potential for significant environmental impacts.

1 **2.1.2 No-Action Alternative: No GEIS – Project-Specific National Environmental Policy**
2 **Act Review Only**

3 Under the No-Action Alternative, the NRC staff would not develop a GEIS for new nuclear
4 reactors. Without the availability of a GEIS, applicants for licensing new nuclear reactors would
5 have to address all relevant environmental issues individually in their ERs, and staff would have
6 to prepare individual EISs for each application received that address all relevant environmental
7 issues (including all Category 1 and Category 2 issues). The processes for an applicant to
8 prepare an ER and for the NRC staff to prepare an EIS would remain similar to those used in
9 the past for new reactor licensing applications. Regardless of whether the licensing review
10 process uses a GEIS or not, the actual environmental impacts of the project are the same.
11 However, the No-Action Alternative would accomplish none of the benefits intended by the
12 preparation of this GEIS, which would include (1) reducing the time and resources for the
13 applicant's preparation of the ER, (2) reducing the time and resources for the NRC staff's
14 preparation of the EIS, and (3) focusing the effort of applicant, NRC staff, and decision-makers
15 on issues that involve a potential for significant environmental impacts. Because the No-Action
16 Alternative would result in the same level of project-specific impacts without the benefit of
17 streamlining provided by the GEIS, the NRC staff concludes that the No-Action Alternative is not
18 environmentally preferable to the proposed action.

19 **2.1.3 Other Alternatives Considered but Not Analyzed in Detail**

20 *2.1.3.1 Limiting the GEIS to Reactors Less than 30 MWt*

21 Prior to scoping, the NRC staff contemplated preparing a GEIS that would analyze the potential
22 environmental impacts of a hypothetical reactor that has a power level of approximately 30 MWt
23 or less on a hypothetical site. The analytical approach to developing the GEIS would have been
24 similar to that used under the proposed action, but the PPE/SPE would have been developed
25 based on a typical reactor of 30 MWt, thereby limiting the range of reactors for which the GEIS
26 would have been useful. Use of the power-level-based GEIS by applicants for small reactors
27 and NRC staff would have been the same as for the environmental performance-based GEIS
28 called for in the proposed action. During the scoping process, multiple commenters suggested
29 that the parameters used in the generic analyses should be tied to the potential for
30 environmental impacts rather than to an arbitrary power level. After reviewing the comments,
31 the staff agreed that a GEIS developed using performance-based values and assumptions tied
32 to environmental impacts might help streamline environmental reviews even for some larger
33 advanced nuclear reactors that would still have a low potential for significant environmental
34 impacts with respect to some environmental issues.

35 *2.1.3.2 GEIS for Advanced Nuclear Reactors Only*

36 The NRC staff initially developed this GEIS as a document that would be applicable to only
37 advanced nuclear reactors. See SECY-21-0098, *Proposed Rule: Advanced Nuclear Reactor*
38 *Generic Environmental Impact Statement*, dated November 29, 2021. However, in
39 SRM SECY-21-0098, dated April 17, 2024, the Commission directed the NRC staff to change
40 the limited applicability of this GEIS from solely "advanced nuclear reactors" to any new nuclear
41 reactor licensing application, provided the application meets the values and the assumptions of
42 the plant parameter envelopes and the site parameter envelopes used to develop the GEIS.
43 Based on the direction from the Commission, the alternative of developing a GEIS that would be
44 applicable to only advanced nuclear reactors will not be considered further.

1 2.1.3.3 *GEIS Analyzing All Potential Environmental Impacts*

2 The staff also considered whether it would be possible to develop a GEIS that could serve as
3 the sole technical documentation of potential environmental impacts for any new nuclear
4 reactor. However, the staff concluded that it is not technically possible to develop generic
5 analyses addressing all potentially significant environmental impacts from any new nuclear
6 reactor without consideration of site-specific and project-specific conditions. Reliance on such a
7 GEIS would not meet the NRC's regulations in Title 10 of the *Code of Federal Regulations*
8 Part 51 (TN250) for compliance with the National Environmental Policy Act of 1969 (42 U.S.C.
9 §§ 4321 et seq.; TN661). The GEIS would also not meet the requirements of other
10 environmental laws, such as the Endangered Species Act (16 U.S.C. §§ 1531 et seq.; TN1010)
11 or the National Historic Preservation Act (54 U.S.C. §§ 300101 et seq.; TN4157).

3 AFFECTED ENVIRONMENT AND ENVIRONMENTAL CONSEQUENCES

This chapter of the GEIS describes the affected environment and environmental consequences resulting from building and operation of a nuclear reactor. This introduction describes the concept and background behind the development and analysis of the baseline, the values and assumptions bounding the PPE and SPE and impacts from building and operation on the environmental resources. This chapter is organized into subsections that address each of 16 relevant environmental resources that the NRC staff identified following the scoping process outlined in Chapter 1.

- **Overview of Affected Environment.** The baseline condition described as the “affected environment” in this GEIS is the environment that exists at and around a site proposed for building and operation of a nuclear reactor. A site could be anywhere in the United States or its territories that meets NRC reactor siting criteria in Title 10 of the *Code of Federal Regulations* Part 100 (10 CFR Part 100; TN282). The affected environment reflects the existing condition of environmental resources, as influenced by natural physical conditions and by past human activities such as agriculture, forestry, mining, urbanization, and industrial and non-industrial development. The site might be situated at an existing nuclear power plant property, and, if so, the generalized description of the affected environment at an existing nuclear power generation site presented in the License Renewal GEIS (NRC 2024-TN10161) might be informative. However, new nuclear reactors might also be proposed for sites not previously used for nuclear power generation. New nuclear reactors might be proposed for sites that have a history of industrial use or other development, or they might be proposed for greenfield sites that have not been previously developed other than for agricultural, forestry, or conservation purposes. New nuclear reactors might be proposed for sites on government-owned or managed installations such as military bases or national laboratories, or they might be proposed for privately owned sites.

The range of existing environmental conditions that might possibly occur at any possible proposed site is too broad to characterize. The NRC staff instead developed the PPE and SPE values and assumptions presented in Appendix G. An application for a license that references this GEIS and for which the reactor and site meet the PPE and SPE values and assumptions for a Category 1 issue will be able to rely on the generic environmental impact analyses and conclusions for that issue in this GEIS. If the PPE or SPE values and assumptions relevant to an environmental impact are not met, the applicant will have to perform an analysis of that impact in the ER using project-specific environmental information. Relevant project-specific information would be presented in an application for a license that references the GEIS and in the NRC’s supplemental environmental review documentation.

Each resource-specific section that follows discusses the affected environment in terms of baseline conditions and the PPE and SPE values and assumptions as they relate to that resource.

- **Overview of Environmental Consequences.** This chapter also evaluates the potential environmental consequences of building, operation, fuel cycle, and decommissioning of a nuclear reactor that meet the values and assumptions for the parameters in the PPE and SPE. Each subsection identifies specific environmental issues involving the possible impacts of a new nuclear reactor on the subject resource. Each subsection then presents generic analyses of potential environmental impacts for each issue for which a generic

1 analysis is possible (i.e., Category 1 issues), assuming that all of the PPE and SPE values
2 and assumptions for that issue are met. Each environmental issue is defined as either a
3 Category 1 or a Category 2 issue.

4 The basis for identifying an issue as being a Category 1 issue is whether a generic analysis of
5 the issue is sufficient for decision-makers and the public when licensing a new nuclear reactor
6 that meets the values and assumptions in the PPE and SPE. The generic analyses for all issues
7 identified by the NRC staff as Category 1 issues support determinations of SMALL impacts. In
8 general, however, individualized analyses that consider project-specific information are
9 necessary for impacts of greater than SMALL significance. In addition, the fact that an
10 individualized analysis is necessary does not mean that the supplemental environmental
11 documentation will conclude that impacts pertaining to the issue will be greater than SMALL; it
12 only means that more than a generic analysis is necessary to reach that conclusion.

13 The generic analyses presented in this chapter assume possible mitigation measures on a
14 resource-specific basis developed on a generic basis to reduce adverse environmental impacts.
15 If a proposed new nuclear reactor application meets the PPE and SPE values and assumptions,
16 including mitigation, pertaining to an environmental issue, then the generic assessment can be
17 relied upon in the SEIS. The staff will always individually consider the possible mitigation
18 measures for Category 2 issues.

19 **3.1 Land Use**

20 **3.1.1 Baseline Conditions and PPE/SPE Values and Assumptions**

21 Baseline conditions influencing potential land use impacts associated with construction and
22 operation of a new nuclear reactor include past and present land uses and land cover on and
23 surrounding the site, applicable zoning regulations, and relevant planning documents such as
24 comprehensive land use plans or installation land use plans. Land use conditions relevant to the
25 environmental analysis include the plant site and surroundings but also offsite land (and
26 surroundings) for affiliated uses such as construction laydown and intake and discharge
27 structures, and any offsite rights-of-way (ROWs) for transmission lines, pipelines, or heavy-haul
28 roads.

29 In developing the values and assumptions in the PPE and SPE pertaining to land use, the staff
30 relied upon the information and analyses contained in multiple new reactor EISs prepared since
31 2005, the License Renewal GEIS (NRC 2024-TN10161), other past NRC EISs, and common
32 elements of State and local land use regulation. Some assumptions made in this section of the
33 GEIS involve parameters and values that are developed based on previous staff environmental
34 reviews or are the subject of Federal and State regulations; some have been appropriately
35 scaled down to account for the size and technology differences between large LWRs and
36 potential smaller new nuclear reactors. In every case, the NRC staff has selected a value or
37 parameter that will ensure a minimal impact on land use from construction and operation of a
38 nuclear reactor after considering all available information and leveraging professional judgment
39 and expertise. The NRC staff's assumptions that support the PPE and SPE are described
40 below.

41 In addition to assuming that any proposed facilities would comply with NRC siting regulations in
42 10 CFR Part 100 (TN282), the staff assumes that the proposed plant site would be no larger
43 than 100 ac, within which site disturbance would affect no more than 30 ac of land permanently
44 and no more than 20 ac of additional land temporarily. The staff also assumes that the site

1 would be at least 0.5 mi from the nearest existing residence. The staff established these values
2 to ensure that dedication and disturbance of land in most settings could not substantially
3 interfere with nearby land uses or alter regional land use characteristics and trends. The staff
4 also assumes that construction and operation of a power plant would be consistent with
5 applicable zoning and with the objectives of any local land use plans (typically prepared for
6 counties or multi-county planning areas). Reliance on zoning compliance and compatibility with
7 land use plans underlie conclusions regarding minimal land use impacts in all recent new
8 reactor EISs, as well as most EISs prepared for other major land development projects. The
9 staff assumes that any cooling towers built on the site would be mechanical draft towers under
10 100 ft in height rather than the taller natural draft cooling towers. Taller cooling towers can
11 generate drift capable of affecting sensitive land uses, such as residential uses, at greater
12 distances from the towers. Taller towers could also pose a collision risk to birds and other flying
13 wildlife (see Section 3.5.2.1.5). The staff also assumes that a project would not include salt
14 evaporation ponds, whose use could potentially result in significant salt deposition in
15 surrounding residential lands (NRC 2011-TN6437).

16 The staff assumes that new offsite ROWs for transmission lines, pipelines, access roads, or
17 other new linear facilities would be no longer than 1 mi and have a maximum ROW width of
18 100 ft. However, the assumptions allow for unlimited additional mileage for building new linear
19 facilities within existing ROWs or adjacent to existing ROWs or public highways, unless in
20 residential areas. As for the assumed site area values, the staff established the ROW values to
21 ensure that the offsite ROWs could not substantially interfere with other land uses or alter
22 regional land use characteristics or trends. For similar reasons, the staff assumes that the site
23 and ROWs would not be situated closer than 0.5 mi to residential areas or 1 mi to sensitive land
24 uses such as Federal, State, or local parks, wildlife refuges, conservation lands, Wild and
25 Scenic Rivers, or Natural Heritage Rivers. The staff also assumes that the land disturbed by
26 building activities (footprint of disturbance) could be accommodated within the site but still avoid
27 impacts on more than 0.5 ac of wetlands and other waters of the United States (project wide),
28 and avoid any encroachment into floodplains, shoreline, or riparian lands that may be within the
29 site boundaries (although the SPE allows for offsite ROWs to traverse such features). The
30 0.5 ac limit is based on the fact that many Nationwide Permits under Section 404 of the Clean
31 Water Act (CWA) (33 U.S.C. § 1344-TN1019) include a project-wide limitation of 0.5 acres (ac)
32 of wetland loss. The staff also assumes that the site and ROWs do not have a history of past
33 industrial use capable of leaving a legacy of contamination requiring cleanup to protect human
34 health or the environment.

35 The staff further assumes that projects would comply with NRC siting regulations in 10 CFR
36 Part 100 (TN282) (including 10 CFR 100.20 – Factors to be considered when evaluating sites;
37 10 CFR 100.21 – Non-seismic siting criteria; and 10 CFR 100.23 – Geologic and seismic siting
38 criteria), the Coastal Zone Management Act of 1972 (CZMA; 16 U.S.C. §§ 1451 et seq.;
39 TN1243) and the Farmland Protection Policy Act (FPPA; 7 U.S.C. §§ 4201 et seq.; TN708),
40 including implementation of any mitigation measures necessary for compliance with these
41 statutes and regulations. The staff will include the findings made and the data gathered as a
42 result of this compliance in its evaluation of land use impacts, as applicable (NRC 2000-TN614).
43 Under the CZMA, each State bordering the tidal waters of the oceans or the Great Lakes has
44 the opportunity to identify its coastal zone and issue a plan for managing land use in that zone
45 that balances the objectives of conservation and economic development. The CZMA is a
46 voluntary program for States (16 U.S.C. § 1451(i) and 1452(2) and (4)). If a State has decided
47 to participate in the CZMA program, then compliance with the CZMA is necessary for all reactor
48 licensing projects sited in that State's coastal zone, in accordance with the State's coastal
49 management program (16 U.S.C. § 1456(c)). Additionally, if an applicant proposes to construct

1 and operate a reactor outside of the State's coastal zone, compliance with the CZMA may still
2 be required to the extent that the proposed project may have a reasonably foreseeable effect
3 upon offsite coastal zone land uses or resources (15 CFR 930.33(a)(1); TN4475). The State's
4 coastal management program is approved by the National Oceanic and Atmospheric
5 Administration, of the U.S. Department of Commerce.

6 The staff assumes there is no prime or unique farmland, or other farmland of statewide or local
7 importance within the footprint of disturbance, unless the site does not abut other agricultural
8 areas and is situated in a predominantly agricultural setting. The purpose of the FPPA is to
9 minimize the extent that Federal programs contribute to the unnecessary and irreversible
10 conversion of farmland to nonagricultural uses. The FPPA defines three categories of regulated
11 farmland namely, prime farmland, unique farmland, and farmland of State or local importance.
12 Prime farmland means "land that has the best combination of physical and chemical
13 characteristics for producing food, feed, fiber, forage, oilseed, and other agricultural crops with
14 minimum inputs of fuel, fertilizer, pesticides, and labor, and without intolerable soil erosion," as
15 determined by the Secretary of the U.S. Department of Agriculture (7 U.S.C. 4201(c)(1)(A)).
16 Prime farmland includes land that possesses the above characteristics but is being used
17 currently to produce livestock and timber. Prime farmland does not include land already in or
18 committed to urban development or water storage. Unique farmland means "land other than
19 prime farmland that is used for production of specific high-value food and fiber crops, as
20 determined by the Secretary. It has the special combination of soil quality, location, growing
21 season, and moisture supply needed to economically produce sustained high quality or high
22 yields of specific crops when treated and managed according to acceptable farming methods"
23 (7 U.S.C. § 4201(c)(1)(B); TN708). Examples of crops grown on unique farmland include citrus
24 fruits, olives, and cranberries. The third category is farmland, other than prime or unique
25 farmland, which is determined to be of State or local significance as determined by the
26 appropriate State or local agency with the concurrence of the U.S. Department of Agriculture
27 Secretary (7 U.S.C. § 4201(c)(1)(C)).

28 The FPPA does not apply to Federal permitting and licensing (7 U.S.C. § 4208(a); TN708),
29 including the issuance of an NRC license for a reactor, unless the reactor is to be constructed or
30 installed on federally owned or leased land that falls under one of the above-described FPPA
31 categories. If the reactor is to be located on such federally owned or leased land, then the NRC
32 must consider the impacts of its proposed action in accordance with the FPPA. Even if the
33 FPPA does not apply to an action, impacts on farmland still constitute an environmental
34 consideration in the context of NEPA. The FPPA definitions include land mapped by the Natural
35 Resources Conservation Service that feature soils possessing optimal physical and climatic
36 properties for food and fiber production, even if the soils are not actually in agricultural use.
37 Soils with a past history of disturbance for urban development are excluded from the farmland
38 designations used in the FPPA.

39 **3.1.2 Land Use Impacts**

40 Most land use impacts from new nuclear reactors would take place during the preconstruction
41 and construction phases of the project. Evaluation requires consideration of the proposed
42 safety-related facilities such as the nuclear island as well as non-safety-related facilities such as
43 cooling towers, administration buildings, parking lots, switchyards, and any onsite and offsite
44 pipelines, access roads, and transmission lines. Many smaller nuclear reactors may be housed
45 in one or a few small buildings on a site of less than a few acres and may lack cooling towers,
46 switchyards, or offsite pipelines or transmission lines. Larger nuclear reactors may require some
47 or all of these support facilities and hence larger sites exceeding the site and disturbance area

1 assumptions. Land uses are unlikely to substantially change during operation of a nuclear
2 reactor, although minor land use changes could be necessary to refurbish or upgrade a nuclear
3 reactor during its operational life (NRC 2024-TN10161).

4 3.1.2.1 *Environmental Consequences of Construction*

5 The staff's evaluation of land use impacts for building a nuclear reactor focused on land use
6 changes being consistent with potentially applicable zoning and land use plans. The NRC staff
7 identified four land use issues for analysis of the building of a nuclear reactor:

- 8 • onsite land use, especially the compliance of onsite land uses with zoning and land use
9 plans and compatibility with adjacent and nearby land uses;
- 10 • offsite land use, especially the compatibility of offsite linear facilities such as pipelines and
11 transmission lines with adjacent land uses;
- 12 • potential impacts on prime farmland, unique farmland, and farmland of State or local
13 significance; and
- 14 • CZMA compliance for a nuclear reactor to be constructed or installed at a site within a
15 designated coastal zone or at a site outside of a coastal zone but the construction or the
16 installation of the reactor may have a reasonably foreseeable effect upon a coastal zone use
17 or resource.

18 3.1.2.1.1 *Onsite Land Use*

19 The PPE and SPE assume that the new nuclear reactor would require the dedication of a site
20 no larger than 100 ac in area, within which site disturbance would affect no more than 30 ac of
21 land permanently and no more than 20 ac of land temporarily. A site of that size would likely be
22 large enough to accommodate any exclusion areas required under 10 CFR Part 100 (TN282).
23 Use of a site of that size is unlikely to noticeably affect the availability of land for other purposes
24 in most settings that are rural enough to meet the NRC siting criteria for a nuclear reactor in
25 10 CFR Part 100. Existing land use within the 30 ac of permanently disturbed land would be
26 converted to industrial land use. The remainder of the site would be available for management
27 as buffer land surrounding the new facilities and could be left in existing natural vegetation,
28 agricultural land uses, or other uses that do not encroach on the exclusion area defined in
29 10 CFR Part 100 or interfere with reactor operations. As required by 10 CFR Part 100, no land
30 uses unrelated to operation of the reactor would be allowed within the exclusion area, although
31 conservation and management of natural vegetation would be allowed. The staff assumes that
32 the 20 ac of temporarily disturbed land would be restored to regionally indigenous vegetation
33 and then be available for other allowable land uses (if it is outside of the exclusion area defined
34 in 10 CFR Part 100). The analysis recognizes that the entire 100 ac site would be unavailable
35 for other industrial, commercial, residential, or recreational land uses until after the reactor is
36 fully decommissioned.

37 The assumptions in Section 3.1.1 include compliance with applicable zoning ordinances and
38 compatibility with any comprehensive land use plans adopted by local governments or planning
39 agencies for the affected area. Zoning ordinances and land use plans are prepared to ensure
40 that future development projects are compatible with other existing and reasonably foreseeable
41 land uses in the area. The ordinances and plans also strive to ensure that adequate land is
42 available for reasonably foreseeable competing land use demands. Land use plans are also
43 often prepared by government agencies or contractors for national laboratory properties or
44 military bases. These plans help ensure that new land uses are compatible with the facility's

1 mission and conservation objectives. The assumption in Section 3.1.1 that the site is at least
2 0.5 mi from existing residential areas further reduces the risk that the proposed new facilities
3 might interfere with nearby residential properties. Constructing or installing a reactor of a size
4 encompassed by the PPE and fitting onto a site featuring the size and disturbance limitations
5 noted above would attract only a limited construction workforce for a temporary period of time,
6 which should not noticeably alter land use patterns in the surrounding landscape.

7 The NRC staff has determined that onsite land use during the building of a nuclear reactor is a
8 Category 1 issue. The staff concludes that as long as the assumptions outlined in Section 3.1.1
9 for the site are met, then impacts from building a nuclear reactor can be generically determined
10 to be SMALL. The staff relied on the following PPE and SPE values and assumptions to reach
11 this conclusion:

- 12 • The proposed project, including any associated land uses, complies with NRC siting
13 regulations in 10 CFR Part 100 (TN282).
- 14 • The site size is 100 ac or less.
- 15 • The permanent footprint of disturbance includes 30 ac or less of vegetated lands, and the
16 temporary footprint of disturbance includes no more than an additional 20 ac or less of
17 vegetated lands.
- 18 • The proposed project complies with the site's zoning and is consistent with any relevant land
19 use plans or comprehensive plans.
- 20 • The site would not be situated closer than 0.5 mi to existing residential areas or 1.0 mi to
21 sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation
22 lands; Wild and Scenic Rivers; or Natural Heritage Rivers.
- 23 • The site does not have a history of past industrial use capable of leaving a legacy of
24 contamination requiring cleanup to protect human health and the environment.
- 25 • The total wetland loss from use of the site, including use of any offsite ROWs, would be no
26 more than 0.5 ac.
- 27 • Best management practice (BMPs) for erosion, sediment control, and stormwater
28 management would be used.
- 29 • Compliance with any mitigation measures established through zoning ordinances, local
30 building permits, site use permits, or other land use authorizations.

31 *3.1.2.1.2 Offsite Land Use*

32 A project meeting the assumptions outlined in Section 3.1.1 would establish no more than 1 mi
33 of new offsite ROW that is no more than 100 ft in width, although unlimited offsite linear
34 development within or adjacent to existing ROWs or roadway is assumed. Any required
35 acquisition of land or easements is also assumed to be obtained from willing landowners without
36 resorting to use of eminent domain.¹ Development of 1 mi of ROW that is no more than 100 ft in
37 width would result in conversion of approximately 12.1 ac of existing land cover to land
38 managed for a utility ROW. Forest cover, whether natural or managed, would be removed and
39 converted to managed grassland, scrubland, or other land cover compatible with management
40 of the ROW. It might be possible to continue the current use of some land in the ROW during
41 and after the utility line construction or installation for cropland, pasture, orchards, or range, or

¹ The NRC would not engage in eminent domain on behalf of an applicant or licensee.

1 for outdoor recreation or conservation, although some land uses would be permanently
2 converted to build access roads, transmission towers, or other facilities.

3 Establishment of new ROWs across existing land uses could fragment properties and interfere
4 with existing or potential uses, but those effects would be minimized in most settings by the 1 mi
5 limitation on new ROW length not co-located with or adjoining existing ROWs or roadways. The
6 presence of ROWs and especially overhead transmission conductors could interfere with some
7 agricultural operations such as aerial pesticide spraying and pivot irrigation. The presence of the
8 ROW would not likely interfere with abutting or nearby land uses, although it could be perceived
9 as undesirable when abutting or close to residential, recreational, or educational land uses.

10 Other than in residential areas, use of existing ROWs has little potential for the types of land use
11 impacts described above for establishing new ROWs. Building utilities such as transmission
12 lines within existing ROWs, including existing roadway ROWs, would not expose additional
13 existing land uses to the presence of a ROW. Widening existing ROWs to accommodate new
14 offsite utilities would also not fragment other land uses and is much less likely to interfere with
15 other land uses or be perceived as incompatible. Additional land might be affected by widening
16 existing ROWs, but the widened ROWs would not fragment additional land uses or expose new
17 land uses to the presence of adjacent transmission lines or other linear utilities. However, the
18 staff recognizes that widening an existing ROW, or even new work within an existing ROW,
19 could have impacts in residential areas, where a consideration of site-specific conditions could
20 be necessary to determine potential effects on residential properties.

21 The NRC staff has determined that offsite land use during construction of a nuclear reactor is a
22 Category 1 issue. The staff concludes that as long as the PPE and SPE values and
23 assumptions outlined in Section 3.1.1 for the offsite ROWs are met, the impacts of building
24 offsite linear features associated with a nuclear reactor can be generically determined to be
25 SMALL. The staff relied on the following PPE and SPE values and assumptions to reach this
26 conclusion:

- 27 • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than
28 100 ft in width and total no more than 1 mi in length.
- 29 • No new offsite ROW would be situated closer than 0.5 mi to existing residential areas or
30 sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation
31 lands; Wild and Scenic Rivers; or Natural Heritage Rivers.
- 32 • No existing ROWs in residential areas would be used or widened to accommodate project
33 features.
- 34 • No ROW has a history of past industrial use capable of leaving a legacy of contamination
35 requiring cleanup to protect human health and the environment.
- 36 • The total wetland loss from use of the entire project, including use of the site and any offsite
37 ROWs, would be no more than 0.5 ac.
- 38 • BMPs for erosion, sediment control, and stormwater management would be used.
- 39 • Compliance with any mitigation measures established through zoning ordinances, local
40 building permits, site use permits, or other land use authorizations.

1 3.1.2.1.3 *Impacts on Prime and Unique Farmland*

2 The PPE and SPE assume that the site is no larger than 100 ac and does not contain any prime
3 or unique farmland, or other farmland of statewide or local importance, as defined in the FPPA
4 (7 U.S.C. §§ 4201 et seq.; TN708). The assumptions do, however, allow for the presence of
5 prime or unique farmland on the site as long as the site does not abut other land actively
6 managed for agricultural purposes and does not occur in a predominantly agricultural
7 landscape.

8 Loss of less than 100 ac of land optimal for agricultural use is unlikely to substantially affect
9 regional agricultural production if the affected land is not positioned close to other agricultural
10 land. Building transmission lines and other structures bounded by the PPE and SPE in offsite
11 ROWs is also unlikely to adversely affect the use of farmland, including farmland regulated
12 under the FPPA. Establishing up to 1 mi of new offsite ROW would affect no more than
13 approximately 12.1 ac of farmland. Additional farmland could be affected by widening ROWs but
14 would not experience the effects of fragmentation by the presence of new utility structures. Not
15 all of the affected land would necessarily be excluded from agricultural use, because farming
16 could continue under transmission conductors and over the top of backfilled pipeline and buried
17 utility trenches. Some of the soils in the ROW could be disturbed to excavate trenches or build
18 towers or access roads, thereby permanently altering the physical properties of the soils that
19 make them optimal for agricultural use. However, the small area of disturbance allowed within
20 the PPE and SPE ensures that the agricultural effects would be low.

21 The NRC staff has determined that prime and unique farmland during construction of a nuclear
22 reactor is a Category 1 issue. The staff relied on the following PPE and SPE values and
23 assumptions to reach this conclusion:

- 24
 - The site size is 100 ac or less.

25 The site does not contain any prime or unique farmland or other farmland of statewide or local
26 importance; or the site does not abut any agricultural land and is not situated in a predominantly
27 agricultural landscape. The generic analysis can be relied on without conducting any mitigation
28 measures. If the site includes any federally owned land (or if the applicant is itself a Federal
29 agency), however, the agency charged with managing the land must demonstrate compliance
30 with the FPPA by consulting with the Natural Resources Conservation Service, which may
31 specify mitigation measures. However, the FPPA exempts actions not affecting federally owned
32 land, even if the actions require permits or involve the acceptance of funding from Federal
33 agencies.

34 3.1.2.1.4 *Coastal Zone and Compliance with the Coastal Zone Management Act*

35 The NRC staff has determined that impacts on the coastal zone during the construction or
36 installation of a nuclear reactor is a Category 1 issue. The NRC cannot license an activity
37 affecting the designated coastal zone without the applicant documenting that it has received a
38 consistency determination from the applicable State agency. The State agency will not issue a
39 consistency determination under the Act unless the potential impacts from the activity on the
40 coastal zone are shown to be minimal or otherwise appropriately mitigated. The staff expects
41 that only minimal impacts on the coastal zone will result from the construction/installation and
42 operation of a reactor meeting the PPE criteria on a site meeting the SPE criteria. The staff
43 concludes that any potential impacts on the coastal zone would be SMALL provided the
44 applicant receives a CZMA consistency determination from the applicable State agency. The
45 staff relied on the following PPE and SPE assumption to reach this conclusion:

- 1 • The site is not situated in any designated coastal zone, or the applicant can demonstrate
2 that the affected state(s) have or will issue a consistency determination or other indication
3 that the project complies with the Coastal Zone Management Act.

4 *3.1.2.2 Environmental Consequences of Operation*

5 The NRC staff recognizes that the greatest potential for adverse land use impacts is during
6 construction, when existing land cover at the site is altered to build the reactor and supporting
7 facilities. Nevertheless, the staff identified two environmental issues for analysis of land use
8 impacts from operation of a nuclear reactor:

- 9 • onsite land use, especially possible land use changes on the site during operation of a
10 reactor; and
11 • offsite land use, especially land use changes within ROWs during operation of offsite linear
12 facilities such as pipelines and transmission lines.

13 Once the project has been built, further impacts on prime and unique farmland or the coastal
14 zone are not a potential concern.

15 *3.1.2.2.1 Onsite Land Use*

16 Once a site has been developed with a nuclear reactor, onsite land use would not substantially
17 change over the course of operations. It is possible that small areas of land cover within the site
18 could be temporarily or permanently disturbed as facilities are maintained or refurbished or to
19 accommodate additional support facilities such as expanded parking lots. However, the entire
20 site would still be dedicated to the reactor throughout its operational life and the overall
21 character of the site would remain unchanged. Land use restrictions in the exclusion areas
22 would remain restricted in accordance with 10 CFR Part 100 (TN282) throughout operations.
23 The licensee may initiate new uses of other land within the site, such as management of
24 undeveloped land for agriculture or conservation or for other land uses not regulated by the
25 NRC, but those actions would not constitute substantial land use changes within a site not
26 exceeding the PPE of 100 ac. If the licensee has obtained permission from the NRC to build
27 and operate an onsite storage facility on the site, the NRC staff has already determined on
28 page 4-3 and 4-5 of the continued storage GEIS that land use impacts from building and
29 operating additional onsite short-term and long-term nuclear fuel storage facilities during the
30 operational life of the reactor would be SMALL (NRC 2014-TN4117). The continued storage
31 GEIS recognized that only small areas of land would be needed to build and operate the
32 facilities and could be accommodated within previously disturbed lands on operating reactor
33 sites. The analysis presented above is also corroborated by page 4-7 of the License Renewal
34 GEIS where the staff concluded that onsite land use impacts from operation of the existing large
35 LWRs would be SMALL (NRC 2024-TN10161).

36 The NRC staff has determined that onsite land use during operation of a nuclear reactor is a
37 Category 1 issue. The staff concludes that, as long as the PPE and SPE values and
38 assumptions outlined in Section 3.1.1 for the site are met, the land use impacts from operating a
39 nuclear reactor can be generically determined to be SMALL. The staff relied on the following
40 PPE and SPE values and assumptions to reach this conclusion:

- 41 • The proposed project, including any associated land uses, complies with NRC siting
42 regulations in 10 CFR Part 100.
43 • The site size is 100 ac or less.

- 1 • If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in
2 height; and equipped with drift eliminators.
- 3 • Any makeup water for the cooling towers would be fresh water (less than 1 part(s) per
4 thousand [ppt] salinity).
- 5 • BMPs for erosion, sediment control, and stormwater management would be used.

6 *3.1.2.2.2 Offsite Land Use*

7 Once a nuclear reactor is built and begins operation, substantial new offsite land use changes
8 are unlikely. The staff has determined that the potential for offsite land use impacts from
9 continued operation of already-built reactors is minimal (NRC 2024-TN10161). It would be
10 possible to continue use of some land in offsite ROWs for cropland, pasture, orchards, or range,
11 or for outdoor recreation or conservation. The License Renewal GEIS described studies in
12 which the presence of overhead electrical transmission conductors somewhat depressed the
13 yield of cotton, but not rice or soybeans, planted underneath, and attributed the effects either to
14 the presence of EMFs or physical interference by the conductors with aerial pesticide spraying
15 (NRC 2024-TN10161). Landowners are, however, compensated for utility easements crossing
16 their land (unless the utility buys the land underlying the ROW outright), and the indicated yield
17 suppressions would not limit economically viable agriculture.

18 Operation of cooling towers can result in fogging, icing, and salt drift that interfere with offsite
19 land uses, including agricultural and residential uses. As reported in the original License
20 Renewal GEIS, a review for possible visible vegetation damage from operation of natural draft
21 cooling towers at eight nuclear plants across the United States revealed no damage, and a
22 review for possible visible vegetation damage from 10 nuclear plants that have mechanical draft
23 cooling towers revealed no damage more than 500 ft from the towers (NRC 1996-TN288). The
24 PPE and SPE assume that natural draft cooling towers, which are taller and hence capable of
25 depositing drift farther away from the towers, would not be used; however, the fact that even
26 they have been shown to result in minimal drift effects supports an assertion that drift impacts
27 have only minimal potential to affect land outside of a power plant site. Furthermore, the PPE
28 and SPE assume that there are no existing (at the time of licensing) residential properties within
29 0.5 mi of the site, including any cooling towers, thereby ensuring conservatism with respect to
30 the potential for drift-related impacts. The analysis presented above is also corroborated by the
31 current License Renewal GEIS in which the staff concluded that onsite land use impacts from
32 operation of the existing large LWRs would be SMALL (NRC 2024-TN10161).

33 Operation of any new nuclear reactor would result in increased employment in the surrounding
34 region, possibly requiring the use of land to provide additional housing and services. However,
35 accommodating any increase in regional population growth for operation of a nuclear reactor, as
36 outlined in the PPE and SPE for the socioeconomic analysis in Section 3.12, is unlikely to result
37 in enough increased regional development by housing and support services to lead to
38 noticeable adverse competition for offsite land resources in most economic regions.

39 The staff has determined that offsite land use during operations of a nuclear reactor is a
40 Category 1 issue. The staff concludes that as long as the PPE and SPE values and
41 assumptions outlined in Section 3.1.1 for the offsite ROWs are met, the impacts can be
42 generically determined to be SMALL. The staff relied on the following PPE and SPE values and
43 assumptions to reach this conclusion:

- 1 • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than
2 100 ft in width and total no more than 1 mi in length.
- 3 • BMPs for erosion, sediment control, and stormwater management would be used (wherever
4 land is disturbed during the course of ROW management).

5 **3.2 Visual Resources**

6 **3.2.1 Baseline Conditions and PPE/SPE Values and Assumptions**

7 Baseline conditions influencing visual impacts include land cover and topography on the
8 proposed site and surrounding landscape, weather patterns and conditions, the height of any
9 existing structures and vegetation on the property, the proximity to other uses of the site, the
10 extent of viewsheds (the area visible from a location sensitive to visual impacts, such as a
11 residence or a park), and other landscape characteristics. Visual effects depend greatly on the
12 setting. A nuclear power plant that might be visually obtrusive in residential or tourist settings
13 might not raise any visual objections in areas where industrial or power generation facilities are
14 common. Among the various visual impact assessment methodologies developed by Federal
15 agencies, one of the best known is the Visual Contrast Rating process, which emphasizes the
16 visual contrast between development actions and their surroundings (BLM 1986-TN6403).

17 In developing the values and assumptions in the PPE and SPE pertaining to visual resources,
18 the staff relied upon the information and analyses contained in multiple new reactor EISs
19 prepared since 2005, the License Renewal GEIS (NUREG-1437; NRC 2024-TN10161), other
20 past NRC EISs, and common elements of State and local land use regulation. In each case,
21 staff has selected a value or parameter that will ensure a minimal visual impact from
22 construction and operation of a nuclear reactor after considering all available information and
23 leveraging professional judgment and expertise. The staff's assumptions that support the PPE
24 and SPE are described below.

25 Most of the assumptions relevant to visual impacts are also ones outlined in Section 3.1.1 for
26 land use. In addition, the staff assumes a maximum building and structure height of 50 ft (except
27 200 ft for meteorological towers and 100 ft for transmission poles/towers and mechanical draft
28 cooling towers). The staff assumes that projects would not include natural draft cooling towers,
29 which are typically several hundred feet in height and therefore visible from considerable
30 distances away from the site in most settings, depending on factors such as vegetation and
31 topography. The staff also assumes that project structures would not be visible from Federal or
32 State parks or wilderness areas designated as Class 1 under Section 162 of the Clean Air Act
33 (42 U.S.C. § 7472; TN6954) or a Wild and Scenic River, a Natural Heritage River, or a river of
34 similar State designation. The staff acknowledges that many proposed facilities may not be
35 completely invisible at all times from all sensitive locations such as residences or parks, even if
36 meeting all of the values and assumptions noted above. The visibility of structures from places
37 on or eligible for listing on the National Register of Historic Places (NRHP) is addressed in
38 Section 3.9.

39 **3.2.2 Visual Resources Impacts**

40 Context plays a key role in the evaluation of visual impacts; the appearance of industrial
41 structures in established industrial settings is generally better tolerated than the same structures
42 in pastoral or residential settings. Taller or larger structures, especially structures of a type not
43 previously occurring on the landscape, tend to affect the visual properties of landscapes more

1 than other structures. For example, for the proposed Greene County Nuclear Power Plant,
2 cancelled in the 1980s because of opposition due to aesthetic concerns, greater opposition was
3 recorded among members of the public to a natural draft cooling tower than to a cement plant,
4 an industrial feature already existing in the generally rural landscape (Petrich 1982-TN6810).
5 Evaluators of visual impacts often speak of effects in terms of viewsheds, defined as the
6 landscape that can be directly seen under favorable atmospheric conditions, from a viewpoint or
7 along a transportation corridor (BLM 1984-TN5536). Many smaller nuclear reactors meeting the
8 assumptions in the PPE and SPE may consist only of, or be housed in, smaller, lower structures
9 compared to the larger, commercial reactors that have been previously licensed by the NRC.
10 Such smaller, lower structures meeting the values and assumptions would have little potential
11 for visual impacts on viewsheds, whether or not those viewsheds contain existing nuclear
12 facilities or other power generation or industrial facilities.

13 3.2.2.1 *Environmental Consequences of Construction*

14 The NRC staff identified two environmental issues related to visual resources for building a
15 nuclear reactor:

- 16 • visual impacts from structures on and in the vicinity of the site, and
- 17 • visual impacts from transmission lines.

18 3.2.2.1.1 *Visual Impacts in Site and Vicinity*

19 Projects meeting the values and assumptions outlined in Section 3.2.1 would not likely be
20 visually obtrusive, even from sensitive features such as residences, parks, and areas
21 designated for conservation. Not being visually obtrusive does not necessarily imply incapable
22 of being seen, especially from a distance. Power generation facilities are however industrial in
23 appearance and would therefore contrast strongly with most natural settings found on greenfield
24 (previously undeveloped) sites, although they would not likely contrast markedly if built in close
25 proximity to existing nuclear or other power plants or other industrial facilities. In landscapes that
26 feature substantial forest cover, structures would likely only be visible close to the site. The
27 structures might be visible from distant high points or ridges but not be a prominent visual
28 feature. The structures would be visible for greater distances in open landscapes characterized
29 predominantly as agricultural, grassland, or scrub cover, but their visual prevalence would
30 decrease with distance. In a completely open landscape such as the ocean or a grassland with
31 no trees, the horizon visible to a standing person 6 ft in height would be approximately 3 mi
32 away; even at distances of only 1 mi, structures would be visible although not prominent. Most
33 landscapes, however, contain hills, trees, and other features that soften the appearance of
34 structures relative to a completely open, flat landscape. Little or no change in the overall visual
35 character of most landscapes would occur if structures meeting the assumed building height
36 values noted in Section 3.2.1 were built close to existing industrial facilities such as existing
37 nuclear generation facilities or other power plants, or in industrial parks or industrially developed
38 areas of military bases. The structures could be aesthetically detrimental to residences or parks
39 situated close to the site, but the structures would not likely alter the aesthetic quality of
40 residences or parks more than 1 mi from the site.

41 The staff has determined that visual impacts on the site and vicinity are a Category 1 issue. The
42 staff relied on the following PPE and SPE values and assumptions to reach this conclusion:

- 43 • The site size is 100 ac or less.

- 1 • The site would not be situated closer than 0.5 mi to existing residential areas or 1 mi to
2 sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation
3 lands; Wild and Scenic Rivers; or Natural Heritage Rivers.
- 4 • The maximum proposed building and structure height is no more than 50 ft, except that the
5 maximum height is 200 ft for proposed meteorological towers and 100 ft for transmission line
6 poles/towers and mechanical draft cooling towers.
- 7 • The proposed project structures would not be visible from Federal or State parks or
8 wilderness areas designated as Class 1 under Section 162 of the Clean Air Act (42 U.S.C.
9 § 7472; TN6954); or as a Wild and Scenic River, a Natural Heritage River, or a river of
10 similar State designation.

11 Note that the generic analysis assumes both that the site and ROWs are not within 1 mi of
12 exceptionally sensitive areas such as wilderness areas and special-status rivers and that the
13 proposed new structures would not be visible from these sensitive areas. No visual simulation or
14 other projection of visual effects is needed to corroborate this conclusion as long as the relevant
15 PPE and SPE values and assumptions are met. If the PPE and SPE values and assumptions
16 are met, the applicant does not need to submit visual simulations (such as an artistic rendering)
17 or other projections of visual effects. Optional mitigation measures that might be considered
18 include planting trees, earthen berms, walls, or other landscaping activities around any part of
19 the perimeter of the site.

20 *3.2.2.1.2 Visual Impacts from Transmission Lines*

21 The assumptions in the PPE and SPE regarding transmission line ROWs and structures (poles
22 or towers) ensure that the visual effects of any new transmission lines serving a nuclear reactor
23 project would be minimal and that the visual integrity of sensitive features such as parks,
24 wilderness areas, conservation lands, Wild and Scenic Rivers, and American Heritage Rivers
25 would not be compromised. Transmission towers, poles, and conductors are visually prominent
26 features that can contrast with and detract from the aesthetic beauty of most non-industrial
27 landscapes. Using Bureau of Land Management terminology (BLM 1986-TN6403), these
28 features can have “moderate” contrast with most natural landscapes. In certain cases, larger
29 steel-lattice transmission towers or tall steel poles may have “strong” contrast relative to some
30 natural landscapes.

31 However, overhead electric lines, including overhead transmission lines carried on various types
32 of towers and poles, are a common feature in all but the most pristine of landscapes. In many
33 landscapes, new transmission lines may be routed to follow existing transmission line ROWs
34 and thereby avoid introducing such structures to pristine areas. Overhead electric lines on the
35 sides of roadways are a common visual occurrence expected by most drivers. The clearing of
36 new ROWs across forested landscapes can create a visually noticeable notch or strip that
37 breaks the lines of the forest canopy and can be visible from substantial distances, but the
38 limited length of new ROWs assumed under the PPE limits the extent of any such visual effects.

39 The NRC staff has determined that visual impacts from building transmission lines are a
40 Category 1 issue. The staff relied on the following PPE and SPE values and assumptions to
41 reach this conclusion:

- 42 • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than
43 100 ft in width and total no more than 1 mi in length.
- 44 • No transmission line structures (poles or towers) would be over 100 ft in height.

- 1 • The new offsite ROWs would not be situated closer than 1 mi to existing residential areas or
2 sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation
3 lands; Wild and Scenic Rivers; or Natural Heritage Rivers.
- 4 • Any proposed new structures on offsite ROWs would not be visible from Federal or State
5 parks or wilderness areas designated as Class 1 under Section 162 of the Clean Air Act
6 (42 U.S.C. § 7472; TN6954); or as a Wild and Scenic River, a Natural Heritage River, or a
7 river of similar State designation.

8 If the PPE and SPE values and assumptions are met, the applicant does not need to submit
9 visual simulations (such as an artistic rendering) or other projections of visual effects. The
10 generic analysis can be relied on without conducting any mitigation measures, but possible
11 mitigation measures to consider might include preserving or establishing tree screens at road
12 crossings or along the edges of ROWs, or painting steel towers or poles brown or dark green.

13 3.2.2.2 *Environmental Consequences of Operation*

14 The NRC staff identified one environmental issue related to visual resources for operation of a
15 nuclear reactor:

- 16 • visual impacts during operations.

17 3.2.2.2.1 *Visual Impacts During Operations*

18 Once structures are built, whether onsite or offsite, they are established features of the
19 landscape. Operation of the structures for their intended purpose once built does not
20 substantially alter their appearance. If there is a need during the operational life to refurbish
21 structures or build new support structures on the site, those changes would most likely not
22 substantially contrast with the already-developed industrial appearance of the site. Operating
23 cooling towers release visible fog-like plumes, but any such plumes from mechanical draft
24 cooling towers meeting the values and assumptions in Section 3.2.1 would likely only be visible
25 from areas close to the site. A nuclear reactor that meets the values and assumptions would not
26 include the tall hyperbolic natural draft cooling towers whose plumes can be visible from
27 substantial distances. Section 3.5.2.2.4 analyzes the potential for drift from cooling towers from
28 nuclear reactors to injure vegetation and concludes that possible effects are localized to the
29 immediate location of the cooling towers and would be minimal. The staff has determined that
30 visual impacts from building transmission lines are a Category 1 issue. The staff relied on the
31 following PPE and SPE values and assumptions to reach this conclusion:

- 32 • The site would not be situated closer than 1 mi to existing residential areas or sensitive land
33 uses such as Federal, State, or local parks; wildlife refuges; conservation lands; Wild and
34 Scenic Rivers; or Natural Heritage Rivers.
- 35 • The maximum proposed building and structure height would be no more than 50 ft, except
36 that the maximum height would be 200 ft for proposed METs and 100 ft for proposed
37 transmission line poles/towers and proposed mechanical draft cooling towers.
- 38 • The proposed project structures would not be visible from Federal or State parks or
39 wilderness areas designated as Class 1 under Section 162 of the Clean Air Act (42 U.S.C.
40 § 7472; TN6954); or as a Wild and Scenic River, a Natural Heritage River, or a river of
41 similar State designation.
- 42 • If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in
43 height; and equipped with drift eliminators.

- 1 • Any makeup water for the cooling towers would be fresh water (less than 1 ppt salinity).

2 **3.3 Meteorology and Air Quality**

3 **3.3.1 Baseline Conditions and PPE/SPE Values and Assumptions**

4 Baseline conditions influencing potential air quality impacts associated with construction and
5 operation of a new nuclear reactor include climatology, regional meteorology, atmospheric
6 stability, the potential for severe weather events, and regional air quality. The atmospheric
7 processes that occur as a result of these baseline conditions determine the transport of routine
8 air emissions during construction and routine air emissions or accidental releases during
9 operation, and their effects on regional air quality. Impacts on regional air quality may result not
10 only from construction and operation at the plant site but also from construction and operations
11 at offsite land, which could include construction of intake and discharge structures and
12 transmission lines, pipelines, or heavy-haul roads. Activities that could potentially cause air
13 emissions include the following:

- 14 • land clearing and material processing, handling, and removal
- 15 • excavation for structures, utilities, access roads and other infrastructure, including
16 transmission lines
- 17 • material replacement (e.g., subsurface preparation and concrete pouring and paving)
- 18 • driving piles and erecting structures
- 19 • construction machinery operation and maintenance
- 20 • truck deliveries of reactor modules, supplies, and materials
- 21 • soil transport and temporary stockpiling
- 22 • workforce vehicle use during daily commuting to and around the site and during refueling
23 outages
- 24 • periodic testing of standby power generators and other support equipment
- 25 • operation of cooling towers and auxiliary systems
- 26 • operation of transmission lines
- 27 • refurbishments activities.

28 In developing the values and assumptions in the PPE and SPE pertaining to air quality, the staff
29 relied upon the information and analyses contained in multiple new reactor EISs prepared since
30 2005, the License Renewal GEIS (NRC 2024-TN10161), and common elements of State and
31 local regulations. Some values and assumptions made in this section of the GEIS involve
32 parameters and values that are developed based on previous staff environmental reviews or are
33 the subject of Federal and State regulations and some have been appropriately scaled down to
34 account for the size and technology differences between large LWRs potentially smaller new
35 nuclear reactors. In every case, the staff has selected a value or parameter that will ensure a
36 minimal impact on local meteorology and air quality from construction and operation of a nuclear
37 reactor after considering all available information and leveraging professional judgment and
38 expertise.

1 The PPE and SPE values relevant to air quality assume that the proposed plant site would be
2 no larger than 100 ac, within which site disturbance would affect no more than 30 ac of land
3 permanently and no more than 20 ac of additional land temporarily, and offsite ROWs
4 for transmission lines, pipelines, or access roads would be no longer than 1 mi; however, these
5 values and assumptions allow for unlimited additional mileage for linear features built within
6 existing ROWs or directly adjacent to existing ROWs or public highways. The staff has
7 concluded that the values stated above used for the land use analysis (as discussed in
8 Section 3.1) will also apply for the analysis of air quality for determining impacts during building
9 activities. The PPE and SPE values assume the construction and operation workforce traffic
10 would not change the level of service (LOS) determination for local road systems, which is
11 discussed in Section 3.12. The staff has concluded that this PPE/SPE value used for
12 socioeconomics would also apply for the analysis of air quality for determining impacts from
13 traffic during building and operation. The PPE and SPE values assume plant cooling would be
14 accomplished by mechanical draft cooling towers, if needed, which are equipped with drift
15 eliminators, and are 100 ft in height or less, and the makeup water would be fresh (with a
16 salinity less than 1 ppt). These values are based on previous license renewal and new reactor
17 environmental reviews, as discussed in Section 3.5, and will be used to determine the air quality
18 impacts from the operation of cooling towers. Lastly, for plants using cooling towers, the air
19 quality section also relies on an assumption that there are no existing residential areas within
20 0.5 mi of site. This assumption is based on previous new reactor reviews analyses.

21 New reactor siting also includes consideration of mandatory Class I Federal areas where
22 visibility is an important value (40 CFR Part 81-TN7226). Although there is little likelihood that
23 activities at a nuclear reactor site could adversely affect air quality and air quality-related values
24 (e.g., visibility or acid deposition) in Class I areas, the PPE and SPE assumes that completed
25 structures would not be located within 1 mi of areas designated as Class I under Section 162 of
26 the Clean Air Act (42 U.S.C. § 7472-TN6954).

27 Air quality is generally measured by the amount of pollution present in the atmosphere. The
28 U.S. Environmental Protection Agency (EPA) has set National Ambient Air Quality Standards
29 (NAAQSs) for six criteria pollutants, including sulfur dioxide, nitrogen dioxide, carbon monoxide
30 (CO), ozone, particulate matter with a mean aerodynamic diameter of 10 μm or less (PM_{10}),
31 particulate matter with a mean aerodynamic diameter of 2.5 μm or less ($\text{PM}_{2.5}$), and lead.
32 Primary NAAQSs specify maximum ambient (outdoor air) concentration levels of the criteria
33 pollutants with the aim of protecting public health with an adequate margin of safety. Secondary
34 NAAQSs specify maximum concentration levels with the aim of protecting public welfare. States
35 can have their own State Ambient Air Quality Standards. State Ambient Air Quality Standards
36 must be at least as stringent as the NAAQSs and can include standards for additional
37 pollutants. If a State has no standard corresponding to one of the NAAQSs, the NAAQSs apply
38 (40 CFR Part 50-TN1089).

39 An area where criteria air pollutants are within NAAQS levels is referred to as an attainment
40 area, and an area where criteria air pollutants exceed NAAQS levels is called a nonattainment
41 area (40 CFR Part 81-TN7226). In some cases, the EPA is not able to determine an area's
42 status after evaluating the available information and those areas are designated as
43 "unclassifiable" (EPA 2020-TN6772). Previous nonattainment areas where air quality has been
44 improved to meet the NAAQSs are redesignated maintenance areas and are subject to an air
45 quality maintenance plan. Locations of EPA-Designated Nonattainment and Maintenance Areas
46 for each criteria pollutant, as of April 30, 2024, are available at
47 <https://www3.epa.gov/airquality/greenbook/ancl.html> (EPA 2024-TN10122).

1 If a proposed project is in a nonattainment or maintenance area, the General Conformity Rule
2 (40 CFR Part 93-TN2495) ensures that Federal actions comply with the NAAQs (EPA 2020-
3 TN6773). In accordance with Section 176(c) of the Clean Air Act (42 U.S.C. § 7506-TN4856)
4 and the General Conformity Rule, the NRC must analyze the proposed permit action for
5 conformity applicability; therefore, the NRC must demonstrate that the air emissions associated
6 with activities within its authority would conform to the appropriate state implementation plans,
7 which are developed to improve or maintain air quality in designated nonattainment and
8 maintenance areas. The EPA has established de minimis levels for each criteria pollutant
9 (EPA 2020-TN6774). If a project is located in a nonattainment or maintenance area and the
10 project's emissions are estimated to exceed the de minimis levels for any criteria pollutant as
11 demonstrated in an applicability analysis, a conformity determination must be performed. When
12 the total direct and indirect emissions from the proposed plant are below the de minimis levels,
13 the project/action would not be subject to a conformity determination (EPA 2020-TN6773). The
14 first step in determining whether an action conforms is to perform an applicability analysis to
15 determine whether the action is exempt or has total net direct and indirect emissions below the
16 de minimis levels. The applicability analysis must be documented. If the applicability analysis
17 demonstrates that the total net direct and indirect emissions exceed the de minimis levels, the
18 agency must prepare a written conformity determination for each pollutant for which the
19 emissions caused by a proposed Federal action would exceed the de minimis levels. A
20 conformity determination, if needed, must be completed before the action is taken. The PPE
21 and SPE assume the proposed plant could be located in either attainment, nonattainment, or
22 maintenance areas, but if located in a nonattainment or maintenance area the criteria
23 pollutant(s) emitted would be less than the de minimis levels set by the EPA or State.

24 Some plant equipment such as diesel generators and cooling towers may emit some hazardous
25 air pollutants (HAPs) during operation. The EPA coordinates with State, local, and Tribal
26 governments to reduce the air emissions of almost 200 toxic air pollutants to the environment.
27 The PPE assumes that these emissions are within limits established by the EPA or State.

28 CEQ has recognized that climate change is a fundamental environmental issue within NEPA's
29 purview (88 FR 1196). In accordance with Executive Order 13990, CEQ rescinded draft
30 guidance entitled, "Draft National Environmental Policy Act Guidance on Consideration of
31 Greenhouse Gas Emissions," and on January 9, 2023 issued interim guidance entitled,
32 "National Environmental Policy Act Guidance on Consideration of Greenhouse Gas Emissions
33 and Climate Change," (88 FR 1196) to assist agencies in conducting greenhouse gas (GHG)
34 and climate change effects analyses on their proposed actions. At the time of publication of this
35 GEIS, CEQ had not finalized the interim guidance.

36 Gases found in the Earth's atmosphere that trap heat and play a role in the Earth's climate are
37 collectively termed GHGs. GHGs include carbon dioxide (CO₂); methane (CH₄); nitrous oxide
38 (N₂O); water vapor; and fluorinated gases, such as hydrofluorocarbons, perfluorocarbons, and
39 sulfur hexafluoride. Climate change research indicates that the cause of the Earth's warming
40 over the last 50 years is the buildup of GHGs in the atmosphere, resulting from human activities
41 (IPCC 2023-TN10123). The EPA has determined that GHGs "may reasonably be anticipated
42 both to endanger public health and to endanger public welfare" (74 FR 66496-TN245). Climate
43 change is a subject of national and international interest because of how it changes the affected
44 environment. Commission Order CLI-09-21 (NRC 2009-TN6406) provides the current direction
45 to the NRC staff to include the consideration of the impacts of the emissions of CO₂ and other

1 GHGs that drive climate change in its environmental reviews for major licensing actions.²
2 Estimates of GHG emissions from a reference 1,000 megawatts electrical (MWe) reactor were
3 developed using the approach in Interim Staff Guidance COL/ESP-ISG-026 (NRC 2014-
4 TN3767), Interim Staff Guidance on Environmental Issues Associated with New Reactors, and
5 also considered the Council on Environmental Quality's (CEQ's) 2016 final guidance on
6 considering GHGs emissions and effects of climate changes in NEPA reviews (NRC 2014-
7 TN3768; CEQ 2016-TN4732) and are presented in Appendix H of this GEIS.

8 GHGs are emitted from equipment and vehicles used during building, operation, the uranium
9 fuel cycle, transportation of fuel and waste, and decommissioning including extended SAFE
10 STORage (SAFSTOR). Appendix H estimates GHG emissions for life-cycle phases for a
11 reference 1,000 MWe reactor with an 80 percent capacity factor. The calculation of GHG
12 emissions for a new nuclear reactor assumes two 1,000 MW(e) nuclear reactors could be
13 installed on the same site, based on previous applications for sites with two or more new LWRs
14 (NRC 2015-TN6438, NRC 2016-TN6434, NRC 2019-TN6136). GHG emission estimates for
15 building, operation, decommissioning, including extended SAFSTOR, for a two-unit nuclear
16 plant would be based on the plant's physical size, and the estimates for these stages are
17 assumed to be twice the value of the reference 1,000 MWe reactor emission estimates in
18 Appendix H. However, GHG emission estimates for the uranium fuel cycle and transportation of
19 fuel and waste would be based on the anticipated efficiency of the proposed plant. For example,
20 the Final EIS for Turkey Point Units 6 and 7 scaled GHG emissions from the fuel cycle upward
21 by a factor of 2.6, and the Final EIS for the Public Service Enterprise Group (PSEG) scaled
22 GHG emissions from the fuel cycle upward by a factor of 3, based on plant efficiencies greater
23 than the 80 percent assumption in Appendix H (NRC 2016-TN6434, NRC 2015-TN6438). To
24 provide bounding values, the estimates for GHG emissions for uranium fuel cycle activities and
25 fuel and waste transport associated with a new nuclear reactor in this GEIS were calculated
26 using three times the values for the reference 1,000 MWe reactor in Appendix H.

27 Based on the Interim Staff Guidance COL/ESP-ISG-026 approach used in several new reactor
28 EISs, the reference 1,000 MWe reactor emissions described in Appendix H, and the scaling
29 factors discussed above, the PPE/SPE value for GHGs emitted by equipment and vehicles
30 during the 97-year GHG life-cycle period for a nuclear reactor would be equal to or less than
31 2,534,000 metric tonnes (MT) of CO₂(e),³ as shown in Table 3-1.

32 **3.3.2 Air Quality Impacts**

33 Most air quality impacts from new nuclear reactors would take place during the building of the
34 project. Impacts would occur primarily during site preparation and the building of facility
35 components such as the nuclear island and facilities such as cooling towers, administration
36 buildings, parking lots, switchyards, and any onsite and offsite pipelines, access roads, and
37 transmission lines. Air emissions from vehicles and stationary support equipment, such as
38 auxiliary equipment, would occur during operation and would increase periodically during
39 equipment testing and during refueling outages, depending on the plant design. Air emissions
40 also result from operation of the cooling towers. Small amounts of ozone and NO_x are produced
41 by transmission lines during operation.

² The Commission stated that "the Staff's analysis for reactor applications should encompass emissions from the uranium fuel cycle as well as from construction and operation of the facility to be licensed." (CLI-09-21, at 6)

³ A measure to compare the emissions from various GHGs on the basis of their global warming potential (GWP), defined as the ratio of heat trapped by one unit mass of the GHG to that of one unit mass of CO₂ over a specific time period.

1 **Table 3-1 Plant Parameter Envelope Values for Greenhouse Gas Emissions**

| Source | Total Emissions (reference 1,000 MW Reactor) (MT CO ₂ (e)) | Activity Duration (yr) | Scaling Factor | PPE Emission Values (Two 1,000 MW Reactors) (MT CO ₂ (e)) |
|--|---|------------------------|----------------|--|
| Construction Equipment ^(a) | 39,000 | 7 | 2 | 78,000 |
| Construction Workforce ^(a) | 43,000 | 7 | 2 | 86,000 |
| Plant Operations ^(b) | 181,000 | 40 | 2 | 362,000 |
| Operations Workforce ^(b) | 136,000 | 40 | 2 | 272,000 |
| Uranium Fuel Cycle ^(b) | 540,000 | 40 | 3 | 1,620,000 |
| Fuel and Waste Transportation ^(b) | 14,000 | 40 | 3 | 42,000 |
| Decommissioning Equipment ^(c) | 19,000 | 10 | 2 | 38,000 |
| Decommissioning Workforce ^(c) | 8,000 | 10 | 2 | 16,000 |
| SAFSTOR Workforce | 10,000 | 40 | 2 | 20,000 |
| TOTAL ^(d) | 990,000 | 97 | - | 2,534,000 |

(a) Activities are assumed to occur over the same time frame.

(b) Activities are assumed to occur over the same time frame.

(c) Activities are assumed to occur over the same time frame.

(d) Results are rounded to the nearest 1,000 MT CO₂(e).

2 The NRC staff evaluated the total GHG emissions for a nuclear reactor. Equipment and vehicles
3 used during building, operation, uranium fuel cycle, transportation of fuel and waste, and
4 decommissioning activities would emit a total of 2,534,000 MT of CO₂(e) over the assumed
5 97-year GHG life-cycle of the plant (see Table 3-1). For comparison, in 2022, total gross annual
6 U.S. GHG emissions were 6,343.2 million metric tons (MMT) of CO₂(e), of which 5,199.8 MMT
7 CO₂(e) were from the energy sector (EPA 2024-TN10121). Assuming this annual rate for energy
8 sector emissions is constant over the same 97-year time span as the operation of the plant, the
9 total emissions from the U.S. energy sector would be 525 billion metric tons (BMT) CO₂(e).
10 Based on these values and assumptions, estimated annual GHGs emissions from the plant life-
11 cycle would be about 0.0005 percent of GHG emissions from the U.S. energy sector over the
12 same period.

13 The staff has determined that the contribution of GHG emissions from total plant life-cycle
14 activities to national emissions is a Category 1 issue. The staff concludes that, as long as the
15 PPE assumption associated with GHG emissions is met, the GHG impacts from building,
16 operating, conducting the fuel cycle, transporting fuel and waste, and decommissioning of a
17 nuclear reactor can be generically determined to be SMALL. The staff relied on the following
18 PPE assumption to reach this conclusion:

- 19 • GHGs emitted by equipment and vehicles during the 97-year reactor GHG life-cycle period
20 would be equal to or less than 2,534,000 MT of CO₂(e). Appendix H of this GEIS contains
21 the staff's methodology for developing this value, which includes emissions from
22 construction, operation, and decommissioning. As long as this total value is met, the impacts
23 for the life-cycle of the project and the individual phases of the project are determined to be
24 SMALL.

25 The generic analysis can be relied on without applying any mitigation measures. GHG impacts
26 associated with building and operation (including the fuel cycle and transportation of fuel and

1 waste) are discussed below. Air quality impacts including GHG emissions for decommissioning
2 are evaluated in Section 3.16 of this GEIS.

3 3.3.2.1 *Environmental Consequences of Construction*

4 The staff's evaluation of impacts on air quality during building activities focused on emissions
5 from construction equipment and vehicles, and fugitive dust generation. Major activities include
6 earthmoving, open burning, placement of land fill, concrete batch plant operation, facility
7 construction, operation of temporary boilers, and emission of vehicular exhaust. Emissions from
8 these activities would include PM, CO, NO_x, sulfur dioxide, and volatile organic compounds
9 (VOCs). Building activities at the site of a new nuclear reactor would result in temporary impacts
10 on local air quality.

11 The NRC staff identified two air quality issues for analysis of construction of a nuclear reactor:

- 12 • emissions of criteria pollutants and fugitive dust to the atmosphere in relation to regional air
13 quality conditions and NAAQSs for criteria pollutants; and
- 14 • emissions of GHGs.

15 3.3.2.1.1 *Emissions of Criteria Pollutants and Dust during Construction*

16 Equipment and vehicle emissions from building activities including passenger cars and light duty
17 trucks of the construction workforce, delivery trucks, and heavy equipment (e.g., excavators,
18 bulldozers, heavy-haul trucks, cranes) would contain CO, NO_x, VOCs, and oxides of sulfur
19 (SO_x) to a lesser extent. Fugitive dust (such as PM₁₀ and PM_{2.5}) would be generated during
20 windy periods, earthmoving, concrete batch plant operation, and movement of vehicular traffic
21 over recently disturbed or cleared areas or unpaved roads. Painting, coating, and similar
22 operations would generate emissions of VOCs. Typically, the construction workforce would be
23 divided into two or three shifts and the increased traffic would be distributed over the day, with
24 periodic and short-term increases at shift changes. Construction activities are typically subject to
25 air permits under State and Federal laws that address the impact of air emissions on any local
26 sensitive receptors. Air emission mitigation measures that may be used to reduce potential
27 impacts include the following:

- 28 • phasing activities and equipment use
- 29 • minimizing the idling time of vehicles
- 30 • using properly maintained equipment in compliance with applicable regulations
- 31 • minimizing speeds on unpaved roads
- 32 • watering unpaved roads and exposed areas
- 33 • minimizing soil storage piles
- 34 • locating stationary equipment (e.g., generators, temporary boilers, and compressors) away
35 from sensitive receptors
- 36 • minimizing dust-generating activities during high winds.

37 Emissions of fugitive dust and construction equipment engine exhaust are generally limited in
38 duration, infrequent, mostly localized to the project area, and would vary based on the level and
39 duration of a specific activity throughout the building phase of the facility. The PPE/SPE
40 assumes the total site size is 100 ac or less, the permanent disturbed vegetated areas is 30 ac
41 or less, and the additional vegetated area disturbed by temporary activities is 20 ac or less, and

1 that new offsite ROWs for transmission lines, pipelines, or access roads would be no longer
2 than 1 mi and have a maximum ROW width of 100 ft. The air quality impacts are therefore
3 expected to be temporary and limited to the area within 6 mi of the plant construction site. The
4 PPE/SPE assumes the plant is located in an attainment area or that criteria pollutants emitted
5 from vehicles and standby power equipment during construction are less than Clean Air Act de
6 minimis levels set by the EPA and that the project/action is located in a nonattainment or
7 maintenance area and, therefore, would not be subject to a conformity determination. The
8 PPE/SPE assumes the site is not located within 1 mi of a mandatory Class I Federal area where
9 visibility is an important value.

10 Some communities located near the construction site may experience increases in traffic and
11 associated increases in the amount of particulate and gaseous emissions. The impact of
12 emissions from additional workforce and other construction traffic would be localized and
13 temporary and have little impact on the regional air quality (NRC 2021-TN7037). Under the PPE
14 and SPE assumption that the LOS determination associated with anticipated peak construction
15 would not change, traffic bottlenecks that could significantly increase localized emissions from
16 idling vehicles are not expected to occur.

17 The staff has determined that emissions of criteria pollutants during construction of a nuclear
18 reactor are a Category 1 issue. The staff concludes that as long as the applicable PPE and SPE
19 values and assumptions are met, the air quality impacts from building a nuclear reactor can be
20 generically determined to be SMALL. The staff relied on the following PPE values and
21 assumptions to reach this conclusion:

- 22 • The site size is 100 ac or less.
- 23 • The permanent footprint of disturbance is 30 ac or less of vegetated lands and the
24 temporary footprint of disturbance is an additional 20 ac or less of vegetated land.
- 25 • New offsite ROWs for transmission lines, pipelines, or access roads would be no longer than
26 1 mi and have a maximum ROW width of 100 ft.
- 27 • Criteria pollutants emitted from vehicles and standby power equipment during construction
28 are less than Clean Air Act de minimis levels set by the EPA if the site is located in a
29 nonattainment or maintenance area, or the site is located in an attainment area.
- 30 • The site is not located within 1 mi of a mandatory Class I Federal area where visibility is an
31 important value.
- 32 • The LOS determination for affected roadways does not change.
- 33 • Mitigation necessary to rely on the generic analysis includes implementation of BMPs for
34 dust control.
- 35 • Compliance with air permits under State and Federal laws that address the impact of air
36 emissions during construction.

37 3.3.2.1.2 GHG Emissions during Construction

38 Equipment and vehicles used during building activities, including construction worker vehicles
39 and delivery trucks, would emit GHGs, principally CO₂. Combining the PPE values for GHG
40 emissions for these two stages listed in Table 3-1 above, 164,000 MT CO₂(e) would be emitted
41 during a 7-year construction period of two 1,000 MW reactors, or less than 24,000 MT/yr CO₂(e)
42 on average. For comparison, in 2022, total gross annual GHG emissions in the United States
43 were 6,343.2 MMT of CO₂(e), of which 5,199.8 MMT CO₂(e) was from the energy sector (EPA

1 2024-TN10121). Estimated annual GHG emissions from equipment used during building
2 activities are about 0.00045 percent of the 2022 GHG emissions from the U.S. energy sector.

3 As noted in Section 3.3.2.1.2 above, the NRC staff has determined that the contribution of plant
4 life-cycle GHG emissions to national emissions is a Category 1 issue. The NRC staff concludes
5 that, as long as the PPE and SPE assumptions associated with the life-cycle GHG emissions
6 are met, the GHG impacts from building a nuclear reactor can also be generically determined to
7 be SMALL. The staff relied on the following PPE values and assumptions to reach this
8 conclusion:

- 9 • GHGs emitted by equipment and vehicles during the 97 year reactor GHG life-cycle period
10 would be equal to or less than 2,534,000 MT of CO₂(e). Appendix H of this GEIS contains
11 the staff's methodology for developing this value, which includes emissions from
12 construction, operation, and decommissioning. As long as this total value is met, the impacts
13 for the life-cycle of the project and the individual phases of the project are determined to be
14 SMALL.

15 The generic analysis can be relied on without applying any mitigation measures.

16 3.3.2.2 *Environmental Consequences of Operation*

17 The NRC staff identified four air quality issues for analysis of the operation of a nuclear reactor:

- 18 • emissions of criteria and HAPs to the atmosphere during operation activities in relation to
19 regional air quality conditions and thresholds for NAAQSs for criteria pollutants and HAPs;
- 20 • cooling-system impacts such as ground-level fogging/icing, plume shadowing, drift
21 deposition from dissolved salts and chemicals found in the cooling water, and ground-level
22 temperature and humidity increases;
- 23 • emissions to the atmosphere of ozone and NO_x from transmission line operation; and
- 24 • GHG emissions during operations.

25 These air quality impacts would be expected to continue during the operational life of the
26 reactor.

27 3.3.2.2.1 *Emissions of Criteria and Hazardous Air Pollutants during Operation*

28 The principal air emission sources for criteria pollutants would be auxiliary equipment, such as
29 boilers for heating and startup, engine-driven emergency equipment, emergency power supply
30 system diesel generators and/or gas turbines, depending on the plant design, and refurbishment
31 activities. Emissions would include NO_x, CO, SO_x, CO₂, CH₄, N₂O, hydrocarbons in the form of
32 VOCs, and PM_{2.5} and PM₁₀.

33 Impacts on air quality during normal plant operations can result from operations of fossil-fuel-
34 fired equipment needed for various plant functions, although these types of operations may be
35 reduced, limited, or not present for smaller reactor designs. Each licensed plant typically
36 employs emergency diesel generators for use as a backup power source. Emergency
37 generators would be used on an infrequent basis and therefore pollutants discharged
38 (e.g., particulates, SO_x, CO, hydrocarbons, and NO_x) would be released infrequently.
39 Emergency diesel generators and fire pumps typically require State or local operating permits
40 for routine (typically monthly) testing. These monthly tests have several test burns of various

1 durations (e.g., 1 to several hours). In addition to these maintenance tests, longer-running
2 endurance tests are typically conducted at each plant. Each generator is typically tested for
3 24 hours on a staggered test schedule (e.g., once every refueling outage) (NRC 2024-
4 TN10161). Plants with nonelectric fire pumps, typically also diesel-fired, usually employ test
5 protocols identical or similar to those used for emergency generators. Many State air pollution
6 regulations provide exemptions for air pollution sources that are not routinely operated, which
7 can be defined as sources that have insignificant activity, meeting specified operating criteria
8 (e.g., so many hours of continuous operation over specified periods or so many hours of
9 operation per year) (NRC 2024-TN10161). In addition to the emergency diesel generators,
10 fossil-fueled (i.e., diesel-, oil-, or natural-gas-fired) boilers can be used primarily for evaporator
11 heating, plant space heating, and/or feed water purification. Again, depending on the simplicity
12 of the reactor design, this equipment may be reduced or eliminated.

13 Air emission sources associated with nuclear power plant operation would be managed in
14 accordance with Federal, State, and local air quality control laws and regulations. A new plant at
15 any U.S. site would comply with all regulatory requirements of the Clean Air Act, as well as any
16 relevant State requirements to minimize impacts on State and regional air quality. When an
17 applicant selects a project design, modeling, as required, will be conducted to demonstrate the
18 project emissions will not result in exceedances of the NAAQS. The evaluation will include a
19 determination of whether the project is in an attainment area for all NAAQS criteria pollutants
20 (Clean Air Act, Part D-TN6972), and whether the proposed project is subject to a Nonattainment
21 New Source Review (EPA 2016-TN6970). A PPE for this GEIS assumes that all operational
22 emissions of criteria pollutants are below de minimis levels for NAAQSs if the project/action is
23 located in a nonattainment or maintenance area.

24 Operations-related traffic would also result in vehicular air emissions. Some communities
25 located near the construction site may experience increases in traffic and associated increases
26 in the amount of particulate and gaseous emissions. The impact of emissions from additional
27 workforce traffic would be localized and have little impact on the regional air quality (NRC 2021-
28 TN7037). Nominal localized increases in emissions would occur as a result of the increased
29 numbers of cars, trucks, and delivery vehicles that would travel to and from the plant site.
30 Emission impacts for operation assume that LOS values can be maintained with the increased
31 traffic volumes.

32 In addition to criteria pollutants, fuel oil for the diesel generators is a source of HAPs. To be
33 considered a major source of HAPs by EPA, a facility must have the potential to emit 10 T/yr of
34 an individual HAP or 25 T/yr or more total for all HAPs (Clean Air Act; 42 U.S.C.
35 §§ 7401 et seq.; TN1141). Because diesel generators operate on a limited basis (typically
36 monthly), the staff does not expect that HAPs associated with a nuclear reactor would meet the
37 10 tons/yr threshold. The PPE assumes that HAPs emissions will be within regulatory limits.

38 The staff has determined that air quality during operation of a nuclear reactor is a Category 1
39 issue. The potential impact from emergency generators and boilers on air quality, given the
40 infrequency and short duration of maintenance testing, would not be an air quality concern. The
41 staff concludes that air quality impacts from operating a nuclear reactor can be generically
42 determined to be SMALL. The staff relied on the following PPE values and assumptions to
43 reach this conclusion:

- 44 • Criteria pollutants emitted from vehicles and standby power equipment during operations
45 are less than Clean Air Act de minimis levels set by the EPA if located in a nonattainment or
46 maintenance area.

- 1 • The site is not located within 1 mi of a mandatory Class I Federal area where visibility is an
2 important value.
- 3 • The LOS determination for affected roadways does not change.
- 4 • The generic analysis can be relied on without applying any mitigation measures.
- 5 • Compliance with air permits under State and Federal laws that address the impact of air
6 emissions.
- 7 • HAP emissions will be within regulatory limits.

8 *3.3.2.2 GHG Emissions during Operation*

9 Equipment and vehicles used during plant operations, the uranium fuel cycle, and fuel and
10 waste transport would emit GHGs, principally CO₂. Combining the PPE values for GHG
11 emissions for these stages listed in Section 3.3.1 above, 2,296,000 MT would be emitted during
12 a 40-year operation period for two 1,000 MW reactors, or about 57,400 MT/yr on average. As
13 with construction activities, these emissions can be compared with 2022 total gross annual U.S.
14 energy sector emissions of 5,199.8 MMT CO₂(e) (EPA 2024-TN10121). Estimated annual
15 GHGs emissions from equipment used during operation, the uranium fuel cycle, and
16 transportation of fuel and waste activities are about 0.001 percent of the 2019 GHG emissions
17 from the U.S. energy sector.

18 As noted in Section 3.3.2.2 above, the staff has determined that the contribution of plant life-
19 cycle GHG emissions to national emissions is a Category 1 issue. The staff concludes that, as
20 long as the PPE assumption associated with GHG emissions is met, the GHG impacts from
21 operating a nuclear reactor can also be generically determined to be SMALL. The staff relied on
22 the following PPE values and assumptions to reach this conclusion:

- 23 • GHGs emitted by equipment and vehicles during the 97-year reactor GHG life-cycle period
24 would be equal to or less than 2,534,000 MT of CO₂(e). Appendix H of this GEIS contains
25 the staff's methodology for developing this value, which includes emissions from
26 construction, operation, and decommissioning. As long as this total value is met, the impacts
27 for the life-cycle of the project and the individual phases of the project are determined to be
28 SMALL.

29 The generic analysis can be relied on without applying any mitigation measures.

30 *3.3.2.3 Cooling-System Emissions*

31 The primary impacts of operating a new nuclear power plant on local meteorology would be
32 from releases to the environment of heat and moisture from the primary cooling system. Cooling
33 towers, if used, would remove excess heat by evaporating water. Upon exiting the tower, water
34 vapor would mix with the surrounding air, and this process would generally lead to condensation
35 and formation of a visible plume, which would have aesthetic impacts. Cooling towers would
36 also produce drift. Drift is composed of small water droplets that are carried out of the cooling
37 tower. These droplets evaporate, leaving particles that contain residual salts and chemicals
38 from the cooling water. Drift from mechanical draft cooling towers is deposited near the cooling
39 tower, and drift from natural draft towers is deposited farther downwind (NRC 2024-TN10161).
40 Wet cooling towers at existing nuclear power plants generally have drift eliminators to reduce
41 drift (NRC 2024-TN10161). Other meteorological and atmospheric impacts from cooling towers
42 include ground-level fogging/icing, plume shadowing, and ground-level temperature and

1 humidity increases. In addition, plumes from the cooling towers could interact cumulatively with
2 emissions from other sources on the site.

3 The PPE includes an assumption of a maximum height of 100 ft for mechanical draft cooling
4 towers that have drift eliminators. The PPE also assumes that the site is not located within 1 mi
5 of a mandatory Class I Federal area where visibility is an important value. The SPE assumes
6 there will be no existing residential areas within 0.5 mi of the site.

7 The License Renewal GEIS (NRC 2024-TN10161) and SEISs for individual plant relicensing
8 evaluated the impact of the continued operation of cooling towers, including natural draft cooling
9 towers, at existing power plants for an additional 20 years and found the impacts to be SMALL.
10 For these license renewal reactor EISs, most of the impacts occurred within 1 mi of the cooling
11 towers. The staff evaluated the impact of continued operation of cooling towers, including
12 natural draft cooling towers, at existing power plants for an additional 20 years and found the
13 impacts to be SMALL. In the License Renewal GEIS (NRC 2024-TN10161) the staff reviewed
14 the distances and impacts from deposition of salt drift from nuclear power plants, which states
15 the "...measurements indicate that, beyond about 1.5 km (1 mi) from nuclear plant cooling
16 towers, salt deposition is not significantly above natural background levels." In addition, the
17 NRC staff reviewed the recent new reactor EIS reviews for cooling-tower impacts and the
18 impacts were found to be SMALL for ground-level fogging/icing, plume shadowing, drift
19 deposition from dissolved salts and chemicals found in the cooling water, and ground-level
20 temperature and humidity increases (NRC 2021-TN7037). For these new reactor EISs, most of
21 the impacts occurred within 1 mi of the cooling towers except for the longest plumes which
22 occurred typically within 5 mi of the cooling towers, but these plume lengths were infrequent,
23 occurring a small percentage of the time during certain times of the year. Icing impacts were
24 infrequent and in more southern areas of the U.S. were not likely to occur (i.e., Florida, Texas,
25 South Carolina) as compared to more northern areas of the United States.

26 In addition to emissions of criteria pollutants, releases of HAP could be expected from chemical
27 additives used in the cooling-tower water. Some examples of these chemical additives are
28 sodium hypochlorite (NaOCl), sodium hydroxide (NaOH), hydroxyethylidene diphosphonic acid
29 (HEDP), and petroleum distillate. Chemical additives added to cooling-tower water are within
30 State regulatory limits or would be within the releases of HAPs listed in Section 112 of the Clean
31 Air Act (42 U.S.C. § 7412-TN7014). The PPE assumes that the emissions of HAPs from the
32 cooling tower will meet the regulatory limits set by EPA or the State.

33 The staff has determined that air quality during operation of cooling towers associated with a
34 nuclear reactor is a Category 1 issue. The staff concludes that air quality impacts from operating
35 cooling towers associated with a nuclear reactor can be generically determined to be SMALL.
36 The staff relied on the following PPE values and assumptions to reach this conclusion:

- 37 • If needed, cooling towers would be mechanical draft, not natural draft.
- 38 • Cooling towers would be equipped with drift eliminators.
- 39 • The site is not located within 1 mi of a mandatory Class I Federal area where visibility is an
40 important value.
- 41 • Mechanical draft cooling towers would be less than 100 ft tall.
- 42 • Makeup water would be fresh (with a salinity less than 1 ppt).
- 43 • Operation of cooling towers is assumed to be subject to State permitting requirements.

- 1 • HAP emissions would be within regulatory limits.
- 2 • No existing residential areas within 0.5 mi of the site.

3 3.3.2.2.4 Emissions of Ozone and NOx during Transmission Line Operation

4 Small amounts of ozone and even smaller amounts of NOx are produced by transmission lines
5 and associated equipment. The impacts of existing transmission lines on air quality are
6 addressed in the License Renewal GEIS (NRC 2024-TN10161). The staff found the production
7 of ozone and NOx to be insignificant for 765 kilovolts (kV) transmission lines (the largest lines in
8 operation) and for a prototype 1,200 kV transmission line (NRC 2024-TN10161). In addition, it
9 was determined that potential mitigation measures, such as burying transmission lines, would
10 be very costly and would not be warranted.

11 The staff has determined that air quality during operation of transmission lines is a Category 1
12 issue. The staff concludes that based on the License Renewal GEIS (NRC 2024-TN10161) and
13 more recent new reactor EIS findings, impacts from emissions of ozone and NOx can be
14 generically determined to be SMALL without relying on mitigation. The staff relied on the
15 following PPE value to reach this conclusion:

- 16 • The transmission line voltage would be no higher than 1,200 kV.

17 3.4 Water Resources

18 3.4.1 Baseline Conditions and PPE/SPE Values and Assumptions

19 Water resources comprise surface water bodies (e.g., rivers, streams, lakes, ponds, estuaries,
20 oceans, and manufactured reservoirs) and groundwater aquifers (including unconfined, water
21 table aquifers, deeper confined aquifers, and perched saturated zones). Exchange between
22 surface water bodies and groundwater systems is common (e.g., groundwater discharge to, or
23 recharge from, abovementioned surface water bodies). Water may be used for many purposes
24 including public and domestic supplies, industrial (including cooling) processes, building-related
25 activities, agriculture, hydropower production, recreation, and general ecosystems support. An
26 assessment of baseline conditions for water resources includes a description of the surface
27 water bodies and groundwater aquifers potentially affected by the building and operation of a
28 proposed plant, the existing and planned uses of the affected water bodies, trends in water
29 quality, and any regulatory restrictions on water use or on discharges affecting water quality.

30 Nuclear power plants use water during both construction and operation. However, impacts on
31 water resources are typically greatest during plant operations, which require water over an
32 operating period that could last for 40 or more years. In the current fleet of power plants with
33 large LWRs, the predominant use for water during operations is for removing excess heat
34 generated in the reactor by condenser cooling. Some new nuclear reactor designs may not use
35 water for cooling purposes. If cooling water is not used, then the impacts from the use of cooling
36 water does not need to be analyzed. In addition to removing heat from the reactor, cooling water
37 is also provided to the service water system and to the auxiliary cooling-water system. However,
38 the amount of water used by these systems is small compared to the amount of water typically
39 required for the condenser cooling system. Nuclear power plants may also require water for
40 other plant systems (e.g., fire suppression) and for sanitary or potable uses. During operations,
41 nuclear power plants typically discharge warm water to a receiving water body. This discharge
42 can contain blowdown from cooling systems, process water from other plant systems, and
43 sanitary system discharges. Reduction or elimination of water use and discharge will increase

1 the number of potential sites at which a new nuclear reactor may be located and decrease the
2 potential for impacts on water resources in the vicinity of the corresponding location.

3 Construction activities and nuclear power plant operations may contribute to changes in water
4 quality conditions. Removal of vegetation and construction of buildings, parking lots, and other
5 impervious surfaces can increase runoff from a site and result in the entrainment of sediments
6 and pollutants in the runoff that ultimately discharges to nearby water bodies. Building of intake
7 and discharge structures may temporarily disturb natural water flows similar to dredging or fill
8 placement in waterways. Water withdrawal for plant use may affect the quality of the
9 groundwater or surface water source. Discharge of cooling water and other plant wastewaters
10 introduces chemical constituents of plant operations (e.g., cooling-water treatment chemicals)
11 and thermal pollution to the receiving water body. In addition, inadvertent chemical spills or
12 releases that are transported with runoff may contaminate surface water and groundwater
13 resources.

14 During both construction and operation of a nuclear power plant, water from municipal sources
15 may be needed to support the potable and sanitary needs of plant personnel. The potential
16 municipal water demand is expected to be relatively small compared to a plant's cooling-water
17 needs. However, this water demand may affect the ability of nearby municipal water systems to
18 meet their planned obligations. Nuclear power plants may also discharge plant effluents (e.g.,
19 sanitary and sewage discharges) to municipal wastewater systems that may affect the municipal
20 systems' ability to meet their planned obligations.

21 Applicants seeking to construct and operate a nuclear reactor must obtain and comply with all
22 applicable permits and authorizations that regulate alterations and limit impacts on the
23 hydrologic environment. Federal regulations for water quality, use, and withdrawal stem from
24 the CWA (codified as the Federal Water Pollution Control Act of 1972; 33 U.S.C. §§ 1251
25 et seq.; TN662).⁴ Dredging and construction-related activities are regulated by provisions of the
26 CWA Section 404 (33 U.S.C. § 1344-TN1019) and Section 10 of the Rivers and Harbors
27 Appropriation Act of 1899 (33 U.S.C. §§ 401 et seq.; TN660). Federal regulations may be
28 administered through a State permitting program, which may institute more restrictive criteria
29 based on the unique regional or local environment or environmental issues. In addition, local or
30 regional water boards or river authorities may require registration, notification, and permitting of
31 the use of water from rivers, reservoirs, and aquifers. Descriptions of applicable laws,
32 regulations, and other authorizations are provided in Appendix F.

33 For each potential resource impact described in the following sections, the level of information
34 provided should be related to the amount of use and the degree of anticipated impacts.
35 Applicants should provide a description of communications with relevant Federal, State,
36 regional, and local authorities and agencies related to obtaining applicable permits and
37 authorizations governing water use and quality. Compliance with environmental quality
38 standards and permit requirements does not satisfy the need for NRC staff to evaluate
39 environmental impacts. However, any assessment that supports the permit may be considered
40 as part of the evaluation of environmental impacts. See footnote 3 to 10 CFR 51.71(d) (TN250).

⁴ The CWA includes Sections 401 (Water Quality Certification; 33 U.S.C. § 1341-TN4764), 402 (National Pollutant Discharge Elimination System, or NPDES, permit; 33 U.S.C. § 1342-TN4765), and Sections 316(a) and 316(b) (for cooling-water discharges and withdrawals, respectively; 33 U.S.C. § 1326-TN4823). Applicable regulations also include U.S. Environmental Protection Agency measures for spill prevention and response (40 CFR Part 112 [TN1041]).

1 Monitoring programs should be developed to identify potential adverse impacts and to formulate
2 associated water resource mitigation strategies related to operation. Monitoring programs,
3 which are required as part of Federal and State permits, should include identification of
4 alternatives or engineering measures that could be implemented to mitigate impacts, if needed.

5 *3.4.1.1 Surface Water Resources*

6 *3.4.1.1.1 Surface Water Use*

7 Operating large LWR nuclear power plants typically withdraw large volumes of surface water to
8 meet a variety of plant needs related primarily to use in cooling systems. Nuclear reactors could
9 be either “dry” cooled, “wet” cooled, or use a combination of both (“hybrid”). Dry-cooled systems
10 use no water and can significantly decrease the total water consumption of a power plant. Wet-
11 cooled systems rely on water for cooling and use systems that interface significantly with water
12 resources. With one exception, the current fleet of operating large LWR nuclear plants rely on
13 surface water sources for cooling. These sources include flowing water bodies (e.g., stream,
14 canal, or river) and non-flowing water bodies (e.g., oceans, gulfs, intertidal zones, estuaries,
15 lakes, ponds, and reservoirs)⁵ and use a variety of cooling systems. Currently, the Palo Verde
16 Nuclear Generating Station is the only operating plant that uses treated wastewater for cooling
17 purposes. Proposed new large LWRs may also plan to withdraw water from a variety of surface
18 water sources to supply the cooling-water system with makeup water. Once-through systems
19 are used for most operating units. The remaining units employ closed-cycle systems, which rely
20 on cooling ponds, lakes, canals, and mechanical and natural draft cooling towers to transfer
21 waste heat to the atmosphere. Compared to the large LWRs mentioned above, it is anticipated
22 that smaller nuclear reactors may use cooling technologies that reduce or eliminate reliance on
23 water for cooling purposes or for reactor shutdown.

24 In environmental reviews for large LWRs, the NRC staff evaluates the effects that plant water
25 use may have on the availability of surface water resources and the impacts of uses and users
26 of these resources. For this GEIS, the staff developed plant and site parameters for water
27 demand and available supply to provide guidance for evaluating issues arising from water use
28 conflicts between the proposed plant and other uses and users. These parameters are
29 presented and explained in the PPE/SPE table in Appendix G. The total plant water demand
30 PPE was developed by the NRC staff after considering the bounding value for water
31 requirements presented in the NRIC PPE report for advanced nuclear reactor designs
32 (NRIC 2021-TN6940). This NRIC bounding value includes water use by all advanced nuclear
33 reactor plant systems. The NRC staff increased this value to the nearest 1,000 gpm to derive
34 the PPE for this GEIS, which specifies that the total plant water demand does not exceed a daily
35 average of 6,000 gpm. The NRC staff assumed that the total plant water demand accounts for
36 the maximum amount of water supply required for all plant needs and may include water from
37 multiple sources.

38 Based on this PPE value, the total surface water use by plant systems would be less than or
39 equal to 6,000 gpm. Because the NRIC PPE report covers a wide range of reactor types and
40 power outputs, the staff expects that the 6,000 gpm limit would not be overly restrictive of new

⁵ Flowing and non-flowing water bodies are distinguished primarily based on the mechanism that provides water availability. Water availability in flowing water bodies (e.g., stream, canal, or river) is primarily provided by the water body’s discharge rate and storage effects are minor. In non-flowing water bodies (e.g., oceans, gulfs, intertidal zones, estuaries, lakes, ponds, and reservoirs), water availability is primarily provided by the volume of stored water.

1 reactor designs addressed by this GEIS. This limit also provides staff with confidence that
2 conclusions reached in this GEIS will be valid given the wide range of site characteristics and
3 settings to which this GEIS might be applicable.

4 The staff separated potential surface water sources into two broad categories in the generic
5 analysis: (1) flowing surface water bodies (e.g., stream, canal, or river) and (2) non-flowing
6 surface water bodies. The staff differentiated non-flowing surface water bodies into two
7 categories that are based on water body size and correspond to the potential for hydrologic and
8 aquatic impacts from plant water usage at the PPE withdrawal rate discussed above. The
9 categories are large water bodies (specifically the Great Lakes, the Gulf of Mexico, estuaries,
10 intertidal zones, and oceans) and smaller water bodies (e.g., inland lakes, ponds, and
11 reservoirs).

12 To minimize the impact on flowing surface water bodies, the SPE specifies that plant
13 withdrawals from water bodies be limited to no more than 3 percent of the 95 percent
14 exceedance daily low flow of the source. The staff developed this SPE criterion for water
15 withdrawal by evaluating the impacts related to plant use of flowing surface water bodies in EISs
16 for new reactors and the License Renewal GEIS for operating reactors (NRC 1996-TN288, NRC
17 2024-TN10161). Based on the evaluations provided in these recent EISs and the License
18 Renewal GEIS, the staff determined that the impacts would be SMALL for withdrawal rates at or
19 below 3 percent of the water available during low flow conditions. In addition, this SPE value is
20 bounded by the EPA 316(b) Proportional Flow Limitation (40 CFR 125.84(b)(3)(i) [TN254]),
21 which specifies that plants not withdraw more than 5 percent of the source water body annual
22 mean flow. The staff assumed that the 95 percent exceedance daily flow is estimated
23 accounting for all existing withdrawals and instream flow requirements.

24 For large non-flowing surface water bodies, the staff recognize that project-specific conditions
25 could result in noticeable impacts on water resources at sufficiently large withdrawal rates.
26 However, water bodies the staff expects that the total plant water demand PPE value of
27 6,000 gpm would not result in water use conflicts in the Great Lakes, the Gulf of Mexico,
28 estuaries, intertidal zones, and oceans, because the plant demand would be negligible
29 compared to water availability. For smaller non-flowing water bodies (e.g., inland lakes, ponds,
30 and reservoirs), the impacts from competing water uses could manifest in different ways (e.g.,
31 reduction in downstream discharge from the water body, reduction in water surface elevation of
32 the water body, and reduction in nearshore habitat suitability) that depend on site-specific
33 hydrologic conditions. Therefore, these smaller water bodies fall outside the SPE value for
34 Surface Water Availability – Non-flowing in Appendix G.

35 For both flowing and non-flowing sources, corresponding assumptions stated in Appendix G
36 should be met. If water is supplied by municipal systems, the staff assumes that the amounts
37 will be within the available capacity of the system. This is reflected in the PPE value for
38 municipal water availability.

39 *3.4.1.1.2 Surface Water Quality*

40 In environmental reviews for large LWRs, the NRC staff typically evaluates the effects on
41 surface water quality from both construction and operation activities in terms of the degradation
42 of the ambient conditions of the water source and the resulting impacts on uses and users of
43 that source. During operations, surface water quality can be affected by the numerous
44 nonradioactive liquid effluents discharged from nuclear power plants. Discharges from the
45 cooling system usually account for the largest volumes of water and the greatest potential

1 impacts on water quality and aquatic systems, although other systems may contribute heat and
2 contaminants to the effluent. Operation of these cooling systems may alter current patterns at
3 intake and discharge structures, salinity gradients, and thermal attributes of the receiving water
4 bodies. Water quality could be affected by temperature effects, sediment discharge, scouring,
5 eutrophication, and the discharge of water containing biocides, sanitary wastes, heavy metals,
6 and higher total dissolved solids (TDS) concentrations than those in the receiving water bodies.
7 During construction, surface water quality in nearby water bodies can be affected by runoff
8 containing sediments and other contaminants from industrial sites including any inadvertent
9 spills that ultimately reach these water bodies.

10 Plant discharges must meet limits set forth in the CWA and specified in the applicable Federal,
11 State, and local permits received for the site. Discharge criteria are determined and
12 implemented by Federal and State agencies responsible for protection of resources based on
13 various project-specific conditions. As a result, criteria may vary among States and among
14 water body uses and types. To mitigate the effects of thermal discharges a mixing zone may be
15 established in the receiving water body such that changes from ambient temperatures outside of
16 the mixing zone are considered minor. The establishment of a mixing zone is highly
17 project-specific, as discussed in Section 3.4.2.2.7.

18 The PPE/SPE specifies that if discharge water is sent to a municipal wastewater treatment
19 facility, the available capacity of the municipal system to treat effluents will exceed the expected
20 amount of plant effluent.

21 3.4.1.2 *Groundwater Resources*

22 3.4.1.2.1 *Groundwater Use*

23 Groundwater has typically been used for non-cooling-water supplies at proposed and operating
24 nuclear power plants. Groundwater has been used for common construction activities such as
25 dust abatement, soil compaction, and as a supply for concrete batch plants. Excavations of
26 plant foundations may also require dewatering or groundwater removal during
27 construction-related activities. Plants may continue dewatering during operations to maintain
28 low water levels near buildings and foundations. During construction and operation,
29 groundwater has also been used for systems that require a higher degree of water quality such
30 as potable and sanitary systems, service water, fire protection water, and plant systems that
31 require demineralized water. Applications for new large LWR nuclear power plants or early site
32 permits (ESPs) in the past have proposed to use groundwater for construction and/or operation.

33 Nuclear plants that withdraw groundwater may affect the availability of groundwater for other
34 nearby users. Impacts could occur as a direct effect of withdrawing groundwater by lowering the
35 water table or indirectly by inducing the movement of lower quality water (e.g., saline water)
36 toward existing well users. Nearby groundwater users could also be affected indirectly if
37 construction or operation of the power plant were to disrupt the normal recharge of the
38 groundwater aquifer. The impacts of large groundwater withdrawal rates are likely to be more
39 significant for users located close to the plant boundary, and in areas where available water
40 resources are stressed. The magnitude of impacts from groundwater withdrawals is also
41 dependent on the site conditions and the hydrogeologic characteristics of the affected aquifer.
42 For example, groundwater pumping from confined aquifers tends to affect larger areas than
43 does pumping from unconfined aquifers for a given pumping rate, and for aquifers that are less
44 transmissive.

1 A permit from the State or other local/regional governing body is typically required to withdraw
2 groundwater. Permitting criteria may include the effects on water rights, availability of water,
3 interference with other beneficial uses, lowering groundwater levels (drawdown), and water
4 quality. The effects on connected surface water bodies (e.g., reductions in streamflow resulting
5 from groundwater withdrawals) may be a consideration. A permit exemption may be available in
6 areas when the withdrawal is less than a threshold value (e.g., 100,000 gpd or about equivalent
7 to a constant pumping rate of about 70 gpm), consistent with the expectation that lower
8 withdrawal rates would typically result in fewer impacts.

9 For operating plants, the NRC staff has found that groundwater withdrawals of 100 gpm or less
10 created negligible or small impacts at operating nuclear power plants because this use rate
11 would not generally lower groundwater levels beyond the site boundary (NUREG-1437; NRC
12 2024-TN10161). Operating plant site areas are significantly larger than the site area SPE value
13 of 100 ac considered in this GEIS. Because some new nuclear reactor sites would be smaller
14 than large LWR sites, groundwater wells could be closer to the site boundary. As a result, the
15 NRC staff determined that the GEIS PPE/SPE should include a maximum groundwater
16 withdrawal rate less than 100 gpm, the rate used in the License Renewal GEIS (NRC 2024-
17 TN10161). In addition, the staff determined that the GEIS SPE should include limits on the
18 effects of withdrawals and dewatering on groundwater levels at the site boundary.

19 The PPE and SPE parameter table in Appendix G specifies that groundwater withdrawals for all
20 plant uses (excluding dewatering withdrawals) be less than or equal to 50 gpm for a new
21 nuclear reactor. Based on simplified modeling, the NRC staff determined that effects on
22 groundwater levels at the site boundary from pumping 50 gpm on a 100 ac site would
23 approximate the effects from pumping 100 gpm on a larger site the size of a typical large LWR.
24 In addition, the staff assumed that the hydrogeologic properties of the aquifer are such that
25 groundwater withdrawals for plant uses would reasonably result in less than a 1 ft reduction in
26 groundwater levels at the site boundary. The threshold of 1 ft was selected as a de minimis
27 value likely to be less than the natural annual fluctuations in groundwater levels at most sites.
28 The groundwater withdrawal parameter also includes the assumption that plant groundwater
29 withdrawals would not occur in an aquifer designated by the EPA as a Sole Source Aquifer
30 (SSA), or in any aquifer designated by a State, tribe, or regional authority to have special
31 protections to limit drawdown. Groundwater withdrawals are also assumed to meet the
32 permitting requirements of applicable State and local agencies.

33 The PPE/SPE specifies that groundwater withdrawals for dewatering also be no more than
34 50 gpm. The staff assumed the value of 50 gpm represents the long-term, steady dewatering
35 rate; the initial rate of dewatering may be larger. Based on simplified modeling, the NRC staff
36 determined that, relative to the plant site area, the effects on groundwater levels caused by
37 dewatering withdrawals of 50 gpm at a 100 ac site would be similar to the effects caused by
38 dewatering withdrawals of 100 gpm on a larger site the size of a typical large LWR. Consistent
39 with the site area used in this NR GEIS, the staff assumed in this simplified modeling that the
40 area to be dewatered and the depth of groundwater drawdown at the excavation/foundation
41 would be smaller for new nuclear reactors than for a typical large LWR. The PPE/SPE
42 dewatering parameter also includes assumptions that the hydrogeologic characteristics of the
43 site are such that dewatering has a negligible effect on groundwater levels at the site boundary
44 and that dewatering discharge does not affect the quality of the receiving water body.

45 Because groundwater withdrawals could affect wetlands on or near the site, the SPE includes
46 assumptions that any changes in wetland water levels and hydroperiod caused by groundwater
47 use or dewatering are within historical annual or seasonal fluctuations to avoid adverse impacts

1 on wetlands. Potential groundwater use impacts on wetlands are discussed in
2 Sections 3.5.2.1.2 and 3.5.2.2.7 of this GEIS.

3 *3.4.1.2.2 Groundwater Quality*

4 When conducting environmental reviews for large LWRs, the staff evaluates the potential effects
5 of plant construction and operation on current groundwater quality conditions. Groundwater
6 withdrawals could impair groundwater quality if they result in the movement of lower quality
7 groundwater. For example, long-term pumping of groundwater from coastal plain aquifers by
8 industrial and municipal facilities has contributed to saltwater intrusion in areas of nearly every
9 Atlantic and Gulf Coast State (Trapp and Horn 1997-TN1865; USGS 1990-TN6648).
10 Groundwater quality could also be impaired at inland sites where groundwater may be replaced
11 by poorer quality surface water through induced infiltration, or where groundwater has been
12 previously contaminated. Groundwater quality impacts are considered to be of small
13 significance when the plant does not contribute to changes in groundwater quality that would
14 preclude current and future uses of the groundwater. As with water use impacts, these types of
15 groundwater quality impacts are likely to be most significant when a plant withdrawal rate is
16 large.

17 Groundwater quality may be affected by releases of potential contaminants to the subsurface.
18 Any intentional discharge of wastewaters to the subsurface would be regulated by the EPA as
19 required by 40 CFR Part 144 (Underground Injection Control Program) and/or State
20 underground injection control requirements. Spills or leaks from nuclear power plant facilities
21 can also impair groundwater quality. Nonradioactive materials such as fuels, solvents, and other
22 chemicals are typically stored and used at the nuclear power plants as part of general industrial
23 activities. Spills of these materials can occur during their use, and leaks from storage containers
24 and associated transfer lines can occur above and below the ground surface. Storage and
25 handling of fuels and chemicals are regulated by EPA and State requirements, and typically
26 require that spill prevention and response procedures be considered.

27 NRC licensees are required to document and report the hazard of known releases of
28 radionuclides. However, inadvertent releases of radionuclides to groundwater may not be easily
29 detected and have resulted in groundwater contamination at operating nuclear power plants.
30 Operating plants have implemented a voluntary groundwater protection program to detect and
31 respond to inadvertent releases of radionuclides to groundwater (NEI 2019-TN6775). This
32 program includes characterization of site geology and hydrology, risk assessment for releases,
33 groundwater monitoring, establishment of a remediation protocol to prevent offsite migration
34 of radionuclides, and reporting of leaks/spills and groundwater monitoring results. Appendix I
35 to 10 CFR Part 50 provides the framework for the radiological environmental monitoring
36 program (REMP) by directing licensees to establish surveillance and monitoring
37 programs, including groundwater monitoring, for release of radionuclides. Guidance
38 related to the REMP is provided in RG 4.1 (NRC 2009-TN3802). In addition, 10 CFR 50.36a
39 (TN249) requires that licensees establish Technical Specifications to keep releases of
40 radioactive materials as low as reasonably achievable or ALARA.

41 To minimize the potential groundwater quality impacts, the PPE and SPE parameter table in
42 Appendix G specifies that the plant will not be located in the recharge area for an
43 EPA-designated SSA, or in the recharge area for any aquifer designated by a State, tribe, or
44 regional authority to have special protections. Under the provisions of the Safe Drinking Water
45 Act (SDWA), States must establish demonstration programs for protection of critical aquifers. In
46 addition, the groundwater quality parameter in Appendix G specifies that the plant will not be

1 located in a wellhead protection area or designated groundwater recharge area for a public
2 water supply well. It is also assumed that there are no planned plant discharges to the
3 subsurface, that applicable requirements and guidance on spill prevention and control are
4 followed, and that a groundwater protection program to detect and monitor inadvertent releases
5 is established and followed. If a new nuclear reactor is proposed for a site that does not conform
6 to these groundwater quality parameters and assumptions, a project-specific evaluation would
7 be required, and the NRC would consult with the jurisdictional authority and responsible
8 agencies when evaluating impacts.

9 **3.4.2 Water Resources Impacts**

10 The NRC staff took four steps to develop a basis for determining values and assumptions for an
11 PPE and SPE for new nuclear reactors in order to determine which issues related to water
12 resources might be dispositioned generically (Category 1) and which would require a
13 project-specific evaluation (Category 2). First, the staff reviewed all EISs published since 2006
14 for new reactor projects that have received NRC permits and licenses to evaluate the
15 corresponding water use and summarize the resultant impact determinations.⁶ Second, the staff
16 reviewed the License Renewal GEIS (NRC 2024-TN10161) to understand the key factors and
17 assumptions used to determine the impact level and category designation for water resource
18 issues. Third, the staff evaluated criteria for water withdrawal and discharge from three states
19 (Tennessee, Idaho, and Alaska), which are representative of variable regions and climates
20 where a new nuclear reactor might be sited, to develop a bounding set of PPE and SPE
21 parameters that are independent of a potential design or power rating. Lastly, the NRC staff
22 reviewed the applicable Federal and State regulations and permit requirements related to water
23 resources.

24 Applicants for a new nuclear reactor license would be expected to obtain and comply with all
25 applicable permits and authorizations that regulate and limit impacts on the hydrologic
26 environment. Federal regulations administered by a State may be more restrictive than the
27 corresponding Federal regulations in order to account for unique regional or local environment
28 or environmental issues. As a result, the water-related authorizations may include, but not be
29 limited to, those listed in Appendix F of this GEIS. The applicant would also comply with other
30 applicable regional, State, tribal, and local regulations, which may include the following:

- 31 • Water withdrawal registration and notification. Some States may require notification and
32 water withdrawal registration for amounts that exceed State-specified limits to aid in water
33 resource management during drought conditions.
- 34 • Water and sewer connection permits. Typically issued by a city, county, or municipal district.

35 *3.4.2.1 Environmental Consequences of Construction*

36 Construction activities that may result in impacts on water quality, availability, and designated
37 use include the following:

⁶ Combined license EISs reviewed were those for Fermi Unit 3 (NRC 2013-TN6436), Levy Units 1 and 2 (NRC 2012-TN1976), North Anna Unit 3 (NRC 2010-TN6), South Texas Project Units 3 and 4 (NRC 2011-TN1722), V.C. Summer Units 2 and 3 (NRC 2011-TN1723), Vogtle Units 3 and 4 (NRC 2011-TN6439), W.S. Lee Units 1 and 2 (NRC 2013-TN6435), and Turkey Points Units 6 and 7 (NRC 2016-TN6434). ESP EISs reviewed were those for Clinton (NRC 2006-TN672), Grand Gulf (NRC 2006-TN674), North Anna (NRC 2006-TN7), Vogtle (NRC 2008-TN673), PSEG (NRC 2015-TN6438) and Clinch River (NRC 2019-TN6136).

- 1 • land clearing, grading, and placement of fill and spoils associated with site preparation
- 2 • construction of drainage and detention/retention features
- 3 • construction of features at, in, or near-surface water bodies, which may include intake and
- 4 outfall structures, cofferdams, bulkheads, piers, jetties, and basins
- 5 • water channel modifications, including filling or dredging
- 6 • alteration of floodplains, natural drainage features or waterways near site
- 7 • development of infrastructure such as roads, parking lots, laydown areas, and surface and
- 8 subsurface transmission lines (above and below ground)
- 9 • inadvertent spills of liquids (e.g., oil, fuel, diesel, solvents, wastewater)
- 10 • excavations and dewatering of building foundations
- 11 • surface water, groundwater, or municipal water use for construction-related purposes (e.g.,
- 12 dust suppression, concrete batch plant, potable and sanitary water)
- 13 • discharges from stormwater runoff and sanitary systems.

14 These construction activities may affect the quality and availability of surface water and
 15 groundwater resources in the vicinity of the proposed site. The NRC staff identified and
 16 evaluated the following environmental issues related to water use and quality, which may arise
 17 from the construction activities listed above:

- 18 • surface water use conflicts during construction
- 19 • groundwater use conflicts due to excavation dewatering
- 20 • groundwater use conflicts due to construction-related groundwater withdrawals
- 21 • water quality degradation due to construction-related discharges
- 22 • water quality degradation due to inadvertent spills during construction
- 23 • water quality degradation due to groundwater withdrawal
- 24 • water quality degradation due to offshore or in-water construction activities
- 25 • water use conflicts due to plant municipal water demand
- 26 • degradation of water quality due to plant effluent discharges to municipal systems.

27 Each of the above environmental issues is discussed in more detail in the subsequent sections.

28 *3.4.2.1.1 Surface Water Use Conflicts during Construction*

29 During construction, surface water may be used for activities such as dust abatement, concrete
 30 mixing, and potable water needs. Construction-related water use is usually a small portion of the
 31 amount of water needed for operation of a plant that has a water-cooled heat dissipation system
 32 and because timeframes for construction are shorter. As a result, construction-related surface
 33 water use impacts on water resources are typically less than operational impacts and, as such,
 34 construction uses would be bounded by the total plant water demand limitation of 6,000 gpm (a
 35 daily average) included in the PPE and SPE table (see Appendix G).

1 No EIS for a plant licensed since 2006 has concluded that the impacts of surface water use
2 during construction would be greater than SMALL, even when surface water was the only
3 source of construction-related water. An example is the EIS for VC Summer Units 2 and 3, in
4 which the staff determined that construction-related surface water use would be about 1 percent
5 of the average makeup water withdrawn during operations (NRC 2011-TN1723); if a plant used
6 a mix of surface and groundwater resources for construction, then this percentage of surface
7 water use would be expected to be less.

8 Acquiring water withdrawal permits and/or water rights for construction-related use has not
9 resulted in water use conflicts at large LWR sites. In addition, some new nuclear reactor
10 technologies are anticipated to require a smaller site footprint with a correspondingly reduced
11 reliance on water resources for construction than large LWR sites. Based on the preceding
12 discussion, the staff assumes that any applicable water withdrawal permits can be obtained,
13 and water rights can be acquired to support construction-related use at new nuclear reactor
14 sites. Therefore, the staff determined that the impacts on surface water use from construction of
15 a new nuclear reactor is a Category 1 issue. The staff concludes that, as long as the relevant
16 PPE and SPE criteria and assumptions are met for the applicable water body type, the impacts
17 on surface water use from building a new nuclear reactor can be generically determined to be
18 SMALL. This conclusion relies on the following PPE/SPE parameter and the associated value
19 and assumptions:

- 20 • Total Plant Water Demand
 - 21 – Less than or equal to a daily average of 6,000 gpm.

22 If water is obtained from a flowing water body, then the following PPE/SPE parameter and
23 associated assumptions also apply:

- 24 • Surface Water Availability – Flowing
 - 25 – Average plant water withdrawals do not reduce discharge from the flowing water body by
26 more than 3 percent of the 95 percent exceedance daily flow and do not prevent the
27 maintenance of applicable instream flow requirements.
 - 28 – The 95 percent exceedance flow accounts for existing and planned future withdrawals.
 - 29 – Water availability is demonstrated by the ability to obtain a withdrawal permit issued by
30 State, regional, or tribal governing authorities.
 - 31 – Water rights for the withdrawal amount are obtainable, if needed.

32 If water is obtained from a non-flowing water body, then the following PPE/SPE parameter and
33 associated value and assumptions also apply:

- 34 • Surface Water Availability – Non-flowing
 - 35 – Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and
36 intertidal zones exceeds the amount of water required by the plant.
 - 37 – Water availability is demonstrated by the ability to obtain a withdrawal permit issued by
38 state, regional, or tribal governing authorities.
 - 39 – Water rights for the withdrawal amount are obtainable, if needed.
 - 40 – CZMA consistency determination is obtainable, if applicable, for the non-flowing water
41 body.

1 *3.4.2.1.2 Groundwater Use Conflicts Due to Excavation Dewatering*

2 Excavation dewatering during construction of building foundations may be required for any new
3 nuclear reactor project. Dewatering lowers groundwater levels adjacent to and beneath an
4 excavation to facilitate construction and increase the stability of excavation slopes (DOD 2004-
5 TN6814). Groundwater levels in the region surrounding the excavation will also be affected, and
6 the magnitude of the affected area will depend on the hydrogeologic conditions of the site, the
7 duration of dewatering, and the methods used to mitigate the effects of dewatering. Changes in
8 groundwater levels may locally affect the direction of groundwater flow, and may alter
9 groundwater recharge or discharge rates, including discharge to wetlands.

10 The impacts of dewatering have been evaluated in the EIS for each of the licensed new reactor
11 sites. At these sites, dewatering rates were expected to be minimized by using engineering
12 practices to limit groundwater inflow to the excavations. In instances where dewatering impacts
13 were modeled, drawdown at the site boundary was typically less than the amount of seasonal
14 fluctuation in the surficial aquifer and water elevations were expected to rebound quickly when
15 dewatering ceased. With a single exception (i.e., the Grand Gulf ESP), impacts were expected
16 to be SMALL. In the Grand Gulf ESP EIS, the staff concluded that the impacts of water use,
17 including dewatering, on the underlying EPA SSA could not be determined because of
18 uncertainty in the plant design, planned pumping rates, and site characterization (NRC 2006-
19 TN674). Groundwater use conflicts, including the impacts of dewatering, were evaluated in the
20 License Renewal GEIS (NRC 2024-TN10161) and determined to be a Category 2 issue
21 (SMALL, MODERATE, or LARGE impacts depending on project-specific characteristics) for
22 plants that withdraw more than 100 gpm. Groundwater withdrawals of less than 100 gpm were
23 determined to have SMALL impacts because the effects on groundwater levels typically do not
24 extend beyond the site boundary (NRC 2024-TN10161).

25 A dewatering rate of 50 gpm is specified in the PPE/SPE table (Appendix G) of this GEIS, as
26 discussed in Section 3.4.1.2.1. While this dewatering rate is less than the rate determined to
27 have SMALL impacts in the License Renewal GEIS, the staff determined that the 50 gpm value
28 is appropriate for the site size (100 ac) specified in the PPE/SPE table. The actual impacts of
29 dewatering at any particular site will depend on the size of the site, the area and depth of the
30 excavation, and the hydrogeologic characteristics of the site. In evaluating the impacts of
31 dewatering for this generic analysis, staff considered that excavations for some new nuclear
32 reactor sites are expected to be smaller, and the depth of groundwater drawdown at the
33 excavation are expected to be less, than those for the licensed fleet of large LWRs. With these
34 expectations, the staff used simplified modeling to determine that, relative to the plant site area,
35 the effects on groundwater levels caused by dewatering withdrawals of 50 gpm at a 100 ac site
36 would be similar to the effects caused by dewatering withdrawals of 100 gpm on a larger site the
37 size of a typical large LWR. Accepted methods for the design of dewatering systems (DOD
38 2004-TN6814) were used by staff in this impact evaluation. As specified in the PPE/SPE table,
39 dewatering is assumed to result in negligible drawdown at the site boundary. This indicates that
40 the radius of influence of the dewatering activities, (the distance beyond which pumping of a
41 dewatering system has no significant effect on ambient groundwater levels), does not extend
42 beyond the site boundary. With these specifications and assumptions, the staff determined that
43 the impacts of dewatering are likely to be localized at sites where the effective saturated
44 hydraulic conductivity of the surficial aquifer is no more transmissive than that represented by a
45 silty or very fine sand, or fractured/permeable rock. At smaller sites and sites that have more
46 transmissive aquifers, the staff assumed that additional engineering controls would be used to
47 avoid dewatering impacts beyond the site boundary.

1 The staff has determined that groundwater use conflicts due to excavation dewatering during
2 construction of a new nuclear reactor is a Category 1 issue. The staff concludes that the effects
3 of dewatering activities related to the construction of new nuclear reactors would be localized
4 and temporary, and groundwater use conflicts from dewatering can be generically determined to
5 have a SMALL impact for this GEIS. This conclusion relies on the following PPE/SPE parameter
6 and the associated value and assumptions:

- 7 • Groundwater Withdrawal for Excavation or Foundation Dewatering
 - 8 – The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate
9 may be larger).
 - 10 – Dewatering results in negligible groundwater level drawdown at the site boundary.

11 Because wetlands located on or adjacent to the site may be affected by groundwater
12 withdrawals for excavation dewatering, the PPE/SPE includes the assumption that changes in
13 wetland water levels and hydroperiod resulting from groundwater use are within historical
14 annual or seasonal fluctuations, to avoid adverse impacts on nearby wetlands. Potential
15 groundwater use impacts on wetlands are discussed in Sections 3.5.2.1.2 and 3.5.2.2.7 of this
16 GEIS.

17 Engineering controls may be required to achieve the limit on drawdown. As described in
18 Chapter 1, the staff anticipates that an application for a new nuclear reactor license will include
19 the appropriate data and analysis to establish with reasonable assurance that the proposed
20 project meets the conditions of the PPE/SPE with respect to dewatering, including the limitation
21 on drawdown at the site boundary. If the PPE/SPE conditions cannot be met, a project-specific
22 evaluation of the impacts of excavation dewatering is required.

23 *3.4.2.1.3 Groundwater Use Conflicts Due to Construction-Related Groundwater Withdrawals*

24 During construction, groundwater may be used for activities such as dust abatement, concrete
25 mixing, and potable water needs. Groundwater withdrawals from one or more wells located on
26 the plant site will lower groundwater hydraulic head levels in the aquifer around the well(s). The
27 magnitude of the drawdown in hydraulic head and the extent of the affected area depend on the
28 withdrawal rate, the hydrogeologic conditions of the site, and the duration of withdrawal.
29 Changes in groundwater levels may locally affect the direction of groundwater flow, and may
30 alter groundwater recharge or discharge rates, including discharge to wetlands and streams.

31 Construction-related groundwater withdrawal rates proposed for the licensed new reactor plant
32 and ESP sites planning to use only groundwater for construction (i.e., South Texas Project,
33 PSEG ESP, Vogtle, and Levy) ranged from 119 gpm to 420 gpm. In the final EIS (FEIS) for
34 each of these proposed plants, the staff determined these pumping rates would have a SMALL
35 impact on groundwater resources, in part due to the limited duration of construction and typical
36 associated withdrawal rates that are less than those proposed for plant operations.

37 The withdrawal associated with construction use of groundwater would be subject to the
38 limitation of 50 gpm included in the PPE/SPE table (Appendix G), as discussed in
39 Section 3.4.1.2.1. This withdrawal limitation is more restrictive than the construction-related
40 groundwater withdrawal rates proposed for the four licensed sites referenced above. In addition,
41 the PPE/SPE assumes that withdrawals for plant use reduce groundwater heads at the site
42 boundary by no more than 1 ft, as discussed in Section 3.4.1.2.1. The 1 ft limit includes the
43 potential cumulative effect of simultaneous excavation or foundation dewatering and
44 groundwater withdrawal for plant use because dewatering is assumed to contribute negligible

1 drawdown at the site boundary, as specified in Appendix G. The impacts of groundwater
2 withdrawals during operation are evaluated in Section 3.4.2.2.4 and found to be SMALL when
3 the specifications and assumptions of the PPE/SPE are met. Because the duration of
4 groundwater withdrawal would be shorter during construction than during operation, the staff
5 determined that the operational impacts bound those during construction for this issue. The staff
6 therefore concludes that this is a Category 1 issue. If actions required by appropriate permits
7 are implemented and applicable assumptions in the PPE and SPE are met (as described in
8 Section 3.4.2.2.4), water use conflicts related to groundwater withdrawals during construction of
9 a nuclear reactor will be minor, and impacts can be generically determined to be SMALL for this
10 GEIS.

11 *3.4.2.1.4 Water Quality Degradation Due to Construction-Related Discharges*

12 During construction-related activities, runoff from disturbed and laydown areas can potentially
13 carry sediments to nearby surface water bodies. Because engineering controls (BMPs, silt
14 fences, detention basins, etc.) regulated by a combination of National Pollutant Discharge
15 Elimination System (NPDES) and USACE permitting are required during these activities,
16 construction-related impacts on surface water quality would be controlled, localized, and
17 temporary. Shallow groundwater withdrawn during dewatering of foundations during
18 construction could be discharged to surface water bodies on or near the site. The discharge rate
19 is limited to 50 gpm by the PPE/SPE value for groundwater excavation dewatering, as
20 discussed in Section 3.4.1.2.1. These discharges would be subject to the limits of an NPDES
21 permit designed to avoid adverse impacts on the receiving water body.

22 The impacts on surface water quality from construction-related discharges were determined to
23 be SMALL in each of the EIS evaluations for new reactors because of adherence to the
24 conditions of the NPDES permit and because of the temporary nature of the discharge. The
25 staff expects that these impacts would be bounding for new nuclear reactors because
26 adherence to NPDES requirements would similarly be required and because of the PPE
27 assumption that the area disturbed would be relatively small (PPE values of 30 ac permanently
28 disturbed and 20 ac temporarily disturbed). Accordingly, the staff has determined that water
29 quality degradation due to construction-related discharges of a nuclear reactor is a Category 1
30 issue. The staff concludes that the effects of discharges related to the construction of new
31 nuclear reactors would be localized and temporary and impacts can be generically determined
32 to be SMALL. This conclusion relies on the following PPE/SPE parameters and the associated
33 values and assumptions:

- 34 • Permanent Footprint of Disturbance – and Temporary Footprint of Disturbance
 - 35 – The permanent footprint of disturbance includes 30 ac or less of vegetated lands, and
 - 36 the temporary footprint of disturbance includes no more than an additional 20 ac or less
 - 37 of vegetated lands.
- 38 • Impacts on Aquatic Biota
 - 39 – Adherence to requirements in NPDES permits issued by the EPA or State permitting
 - 40 program, and any other applicable permits.
- 41 • Groundwater Withdrawal for Excavation or Foundation Dewatering
 - 42 – The long-term groundwater dewatering withdrawal rate is less than or equal to 50 gpm.
 - 43 – Dewatering discharge has minimal effects on the quality of the receiving water body
 - 44 (e.g., as demonstrated by conformance with NPDES permit requirements).

1 The staff also concludes that water quality impacts on groundwater can be generically
2 determined to be SMALL. This conclusion relies on the following PPE/SPE parameter and the
3 associated value and assumptions:

- 4 • Groundwater Quality
 - 5 – There are no planned discharges to the subsurface (by infiltration or injection), including
 - 6 stormwater discharge.

7 *3.4.2.1.5 Water Quality Degradation Due to Inadvertent Spills during Construction*

8 During construction, inadvertent spills of gasoline, diesel fuel, hydraulic fluid, lubricants,
9 solvents, and wastewater used for construction equipment could affect both surface water and
10 groundwater resources. Pursuant to 40 CFR Part 112 (TN1041), applicants would be required
11 to use BMPs and implement a Spill Prevention, Control, and Countermeasure (SPCC) to
12 minimize the occurrence of spills and limit their effects. Impacts on water quality from
13 inadvertent spills during construction were determined to be SMALL in the EIS evaluations for
14 new reactors because of adherence to these spill prevention and pollution control measures.

15 Building any nuclear reactor is expected to involve activities and methods similar to those for
16 building a large LWR. The associated BMPs and SPCC implementation are also expected to be
17 similar. Therefore, the staff has determined that water quality degradation due to inadvertent
18 spills during construction of a nuclear reactor is a Category 1 issue. The staff concludes that the
19 impacts of inadvertent spills on water quality during construction of a nuclear reactor can
20 generically be determined to be SMALL. This conclusion relies on the following PPE/SPE
21 parameters and the associated values and assumptions. This conclusion relies on the following
22 assumptions:

- 23 • Site Size and Location
 - 24 – The site size is 100 ac or less
- 25 • Permanent Footprint of Disturbance and Temporary Footprint of Disturbance
 - 26 – The permanent footprint of disturbance includes 30 ac or less of vegetated lands, and
 - 27 the temporary footprint of disturbance includes no more than an additional 20 ac or less
 - 28 of vegetated lands.
- 29 • Groundwater Quality
 - 30 – Applicable requirements and guidance on spill prevention and control are followed,
 - 31 including relevant BMPs and SPCCs.

32 *3.4.2.1.6 Water Quality Degradation Due to Groundwater Withdrawal*

33 Degradation of groundwater resources may occur when dewatering or withdrawal of
34 groundwater for plant uses induces the flow of lower quality water from the surrounding aquifers
35 or connected surface water bodies. This could result from pumping of deep confined aquifers
36 and dewatering of shallow, unconfined surficial aquifers.

37 Groundwater withdrawals may induce infiltration from surface water (e.g., rivers, ponds, or
38 lakes), or contribute to saltwater intrusion from oceans and estuaries in aquifers near the coast.
39 In the License Renewal GEIS (NRC 2024-TN10161) the staff determined that pumping of
40 confined groundwater at operating plants in estuary or coastal sites had a small impact on

1 groundwater quality. The pumping rates considered in the License Renewal GEIS greatly
2 exceed the PPE/SPE limits for groundwater withdrawals.

3 In EISs for new reactors, the staff has generally determined that the impacts of dewatering of
4 the surficial aquifer would not extend far beyond the site boundary. At sites located near water
5 bodies of lower quality, such as PSEG, the surficial aquifer can be impacted. In that case, the
6 impacts were due to hydraulic connections with brackish Delaware River water limiting the
7 private use of groundwater in the area and the potential for further degradation (NRC 2015-
8 TN6438).

9 The PPE/SPE table limits groundwater withdrawals for excavation dewatering and plant uses to
10 50 gpm each and assumes that groundwater withdrawals will result in no more than a 1 ft
11 lowering of groundwater levels at the site boundary, as discussed in Section 3.4.1.2.1. The 1 ft
12 limit includes the potential cumulative effect of simultaneous excavation dewatering and
13 groundwater withdrawal for plant uses because dewatering is assumed to contribute negligible
14 drawdown at the site boundary, as specified in the PPE/SPE table (Appendix G). In areas that
15 have exploitable groundwater resources, the PPE/SPE withdrawal rate is expected to be a small
16 fraction of the total withdrawal rate by other users (typically agricultural or municipal uses in
17 rural and urban areas, respectively). With no more than a 1 ft change in groundwater levels at
18 the site boundary, the potential for PPE/SPE withdrawals to induce flow from adjacent water
19 bodies is unlikely to be noticeable. In addition, the effects of groundwater withdrawals would be
20 limited to the period of construction.

21 The staff has determined that water quality degradation due to groundwater withdrawals is a
22 Category 1 issue. The staff concludes that water quality impacts resulting from groundwater
23 withdrawals during construction of any new nuclear reactors would be localized and temporary
24 and can be generically determined to be SMALL for this GEIS. This conclusion relies on the
25 following PPE/SPE parameters and the associated values and assumptions:

- 26 • Groundwater Withdrawal for Excavation or Foundation Dewatering
 - 27 – The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate
 - 28 may be larger).
 - 29 – Dewatering results in negligible groundwater level drawdown at the site boundary.
- 30 • Groundwater Withdrawal for Plant Uses
 - 31 – Groundwater withdrawal for all plant uses (excluding dewatering) is less than or equal to
 - 32 50 gpm.
 - 33 – Withdrawal results in no more than 1 ft of groundwater level drawdown at the site
 - 34 boundary.
 - 35 – Withdrawals are not derived from an EPA-designated SSA, or from any aquifer
 - 36 designated by a State, tribe, or regional authority to have special protections to limit
 - 37 drawdown.
 - 38 – Withdrawals meet any applicable State or local permit requirements.

39 *3.4.2.1.7 Water Quality Degradation Due to Offshore or In-Water Construction Activities*

40 Activities that may be associated with water quality degradation in lakes, rivers, and marine
41 environments include offshore or in-water construction of cofferdams; dredging operations;
42 placement of fill material into the water; creation of shoreside facilities involving bulkheads,

1 piers, jetties, basins, or other structures or activities with potential to alter existing shoreline
2 processes; construction of intake and outfall structures; water channel modifications; and bridge
3 or culvert construction. Activities related to in-water building are localized and temporary, lasting
4 for the duration of the construction. These in-water building activities are regulated by provisions
5 of the CWA Section 404 (33 U.S.C. § 1344-TN1019) and Section 10 of the Rivers and Harbors
6 Appropriation Act of 1899 (33 U.S.C. §§ 401 et seq.; TN660). Adverse effects of these building
7 activities are traditionally controlled using BMPs like installation of turbidity curtains or
8 installation of cofferdams.

9 As such, the staff has determined that water quality degradation due to offshore or in-water
10 construction activities is a Category 1 issue and that the impacts could be generically
11 determined to be SMALL. This conclusion relies on the following PPE/SPE parameter and the
12 associated values and assumptions:

- 13 • In-Water Structures (including intake and discharge structures)
 - 14 – Constructed in compliance with provisions of the CWA Section 404 (33 U.S.C. § 1344-
15 TN1019) and Section 10 of the Rivers and Harbors Appropriation Act of 1899 (33 U.S.C.
16 §§ 401 et seq.; TN660).
 - 17 – Adverse effects of building activities controlled and localized using BMPs such as
18 installation of turbidity curtains or installation of cofferdams.
 - 19 – Construction duration would be less than 7 years.

20 *3.4.2.1.8 Water Use Conflicts Due to Plant Municipal Water Demand*

21 Municipal water supply used to support construction-related water use (e.g., potable and
22 sanitary needs) may affect the municipal systems' ability to meet their planned obligation to
23 other users. This plant need would only exist during the period of plant construction. To
24 generically assess the potential impact on municipal systems from the plant's
25 construction-related water use, the staff assumed that the needed amount of municipal water
26 would be available and within the existing capacity of the municipal systems, thereby accounting
27 for all existing and planned future uses. If these assumptions are satisfied, the staff determined
28 that the plant's construction-related municipal water use would not unduly stress the municipal
29 systems' ability to meet their existing and planned obligations.

30 The staff has determined that the effect of water supply from municipal systems is a Category 1
31 issue. The staff concludes that, as long as the relevant PPE and SPE are met the impacts on
32 municipal systems from building a nuclear reactor can be generically determined to be SMALL.
33 This conclusion relies on the following PPE/SPE parameter and the associated value and
34 assumptions:

- 35 • Municipal Water Availability
 - 36 – The amount available from municipal water systems exceeds the amount of municipal
37 water required by the plant.
 - 38 – Municipal Water Availability accounts for all existing and planned future uses.
 - 39 – An agreement or permit for the usage amount can be obtained from the municipality.

1 *3.4.2.1.9 Degradation of Water Quality Due to Plant Effluent Discharges to Municipal Systems*

2 During construction, certain plant effluents (e.g., sanitary and sewer discharges) could be
3 discharged to a municipal wastewater treatment system. This plant effluent discharge would
4 only exist during the period of plant construction. To generically assess the potential impact on
5 the municipal wastewater system, the staff assumed that the municipal system has an existing
6 or planned capacity to treat all plant effluents while accounting for all existing and planned future
7 discharges. The staff further assumed that the plant effluent constituents can be treated by the
8 receiving system and therefore a permit can be obtained for construction-related plant effluent
9 discharge to the municipal systems.

10 The staff has determined that the degradation of water quality from plant effluent discharges to
11 municipal systems is a Category 1 issue. The staff concludes that, as long as the relevant PPE
12 and SPE criteria are met the impacts on water quality from plant effluent discharges to
13 municipal systems related to building a nuclear reactor can be generically determined to be
14 SMALL. This conclusion relies on the following PPE/SPE parameter and the associated values
15 and assumptions:

- 16 • Municipal Systems' Available Capacity to Receive and Treat Plant Effluent
 - 17 – Municipal Systems' Available Capacity to Receive and Treat Plant Effluent accounts for
 - 18 all existing and reasonably foreseeable future discharges.
 - 19 – Agreement to discharge to a municipal treatment system is obtainable.

20 *3.4.2.2 Environmental Consequences of Operation*

21 If the plant is water-cooled, the primary water-related impact would be associated with
22 withdrawals and discharges related to the cooling-water system. Potential impacts on water
23 quality, availability, and designated use may occur as a result of operations-related activities
24 that may include the following:

- 25 • maintenance dredging and disposal of dredged spoils
- 26 • groundwater dewatering of site structures to support plant operations
- 27 • surface water withdrawal at intake structures
- 28 • surface water discharge of plant blowdown and effluents to discharge structures
- 29 • groundwater withdrawal for plant use
- 30 • inadvertent spills of chemicals, fuels, solvents, and oils
- 31 • water supply from and discharges to municipal systems.

32 As described in the following sections, the NRC staff identified the following environmental
33 issues related to water use, which may arise during operation:

- 34 • surface water use conflicts during operations due to water withdrawal from flowing water
35 bodies
- 36 • surface water use conflicts during operation due to water withdrawal from non-flowing water
37 bodies
- 38 • groundwater use conflicts due to building foundation dewatering
- 39 • groundwater use conflicts due to groundwater withdrawals for plant uses

- 1 • surface water quality degradation due to operation of intake and discharge structures
- 2 • surface water quality degradation due to changes in salinity gradients resulting from
- 3 withdrawals
- 4 • surface water quality degradation due to chemical and thermal discharges
- 5 • groundwater quality degradation due to plant discharges
- 6 • water quality degradation due to inadvertent spills and leaks during operation
- 7 • water quality degradation due to groundwater withdrawals
- 8 • water use conflict due to plant municipal water demand
- 9 • degradation of water quality due to plant effluent discharges to municipal systems.

10 The potential impacts related to water use conflicts and water quality degradation are discussed
11 in the following sections.

12 *3.4.2.2.1 Surface Water Use Conflicts during Operation Due to Water Withdrawal from Flowing*
13 *Water Bodies*

14 The staff used a performance-based approach to identify a conservative and defensible SPE
15 criterion based on water availability at the new nuclear reactor site. The SPE criteria and
16 assumptions were developed for flowing (e.g., stream, canal, or river) and non-flowing (e.g.,
17 oceans, gulfs, intertidal zones, estuaries, lakes, ponds, and reservoirs) water bodies because
18 withdrawals affect each of these types of water bodies differently (see Appendix G). The SPE
19 criteria and assumptions for flowing water bodies are discussed in this section. SPE criteria and
20 assumptions for non-flowing water bodies are discussed in Section 3.4.2.2.2. Using these
21 performance-based criteria and assumptions potentially allows a larger number of sites in a
22 variety of hydrologic settings to fall within Category 1 under this GEIS.

23 As discussed in Section 3.4.1.1, the staff determined that the total amount of surface water
24 withdrawn from surface water bodies for use by the nuclear reactor would be less than or equal
25 to 6,000 gpm, which is the PPE related to total plant water demand. This PPE value was
26 derived by considering the water needs of currently known ANR technologies. During
27 operations, some of this water would be consumed through evaporative loss or by other plant
28 systems. It is expected that operation-related water needs of some new nuclear reactors will be
29 much lower if the plant does not use water for cooling. The PPE limit includes water withdrawn
30 from surface water sources for use by all plant systems (cooling water, service water, fire
31 protection, potable, and sanitary) but does not include water from a municipal provider even if
32 the municipal provider obtained the water from a surface water source, because the impacts of
33 withdrawal by a municipal provider would have been considered in the provider's withdrawal
34 permit. The staff estimated that the total plant water demand PPE is 5 to 10 times less than the
35 average surface water withdrawal rate proposed by the recently licensed large LWRs that
36 planned to rely predominately on flowing surface water bodies during operations (e.g., VC
37 Summer, WS Lee, and Clinch River). In each recently licensed large LWR, the impacts of water
38 withdrawal on surface water resources were determined to be SMALL, in part due to the
39 comparatively large amount of water available for use at each site. As a result of these factors,
40 the NRC staff determined that the PPE for total plant water demand conservatively supports a
41 generic impact determination when neither the design nor the site are currently known.

1 The SPE criteria for surface water availability of a flowing water body was determined by
2 identifying the following:

- 3 • An appropriate low flow characteristic to be used in the water impact assessment for flowing
4 surface water bodies. The staff chose to use the 95 percent exceedance flow of the flowing
5 surface water body as the flow characteristic for the impact assessment because this
6 characteristic is statistically representative of low flow conditions for that water body.
- 7 • A conservative impact measure of the low flow characteristic, which could be used to relate
8 withdrawal to the impact and category designation. Based on the evaluation described
9 below, the staff determined that plant withdrawals of 3 percent or less of the 95 percent
10 exceedance flow of the flowing surface water body would result in a SMALL impact and
11 Category 1 designation.
- 12 • Constraints on the applicability of the Category 1 determination. These constraints were
13 developed by evaluating the previous EISs for circumstances that led to impacts that were
14 greater than SMALL and are included as assumptions for the SPE criteria.

15 The staff developed the SPE criteria for water withdrawal (i.e., 3 percent of the 95 percent
16 exceedance flow) by evaluating the impacts related to plant use of flowing surface water bodies
17 in EISs for new reactors and the License Renewal GEIS for operating reactors (NRC 1996-
18 TN288 and NRC 2024-TN10161). In each recent EIS for new large LWRs withdrawing from
19 flowing surface water bodies, the staff determined that the impacts would be SMALL even
20 though maximum withdrawal rates were above 3 percent of the water available during low flow
21 conditions. The only exceptions to this were the proposed Grand Gulf and PSEG sites, where
22 the ratio of maximum plant withdrawal to availability during low flow conditions was much
23 smaller because of the size of the adjacent river resulting in SMALL impact determinations
24 (NRC 2006-TN674). The License Renewal GEIS discusses two plants where plant withdrawals
25 from flowing surface water bodies that exceeded 10 percent of minimum flows could result in
26 future water use conflicts (Limerick and Duane Arnold; NRC 1996-TN288). In both cases,
27 reducing the withdrawal to a much smaller percentage of the minimum flow, such as the SPE
28 value of 3 percent or less, would reduce the chances of future water use conflicts and minimize
29 impacts on other users. The SPE value of 3 percent would also comply with the EPA 316(b)
30 Proportional Flow Limitation (40 CFR 125.84(b)(3)(i) [TN254]), which specifies that plants not
31 withdraw more than 5 percent of the source water body annual mean flow.

32 The staff's generic analysis for water use impacts on flowing surface water bodies is described
33 here. The impact of water withdrawals on the resource is expected to be SMALL when the plant
34 withdrawal from a flowing surface water body is less than 3 percent of the 95 percent
35 exceedance flow and when assumptions stated in Appendix G are met. The criterion may be
36 described using the following equation:


37
38
$$Q_w \leq 0.03 \times Q_{95\%}$$

39 where Q_w is the plant water withdrawal rate and $Q_{95\%}$ is the 95 percent exceedance flow (rate)
40 of the flowing surface water body.

41 Using this relationship, a plant withdrawing water at the 6,000 gpm (the PPE limit) would need
42 to be sited on a flowing surface water body with a 95 percent exceedance flow of at least
43 200,000 gpm (approximately 450 cubic feet per second). Plants with lower withdrawal rates
44 could be sited on smaller flowing surface water bodies and be included in this generic analysis,
45 as illustrated by the shaded region in Figure 3-1. If this relationship is met, the staff has

1 determined that surface water use conflicts during operations due to water withdrawal from
2 flowing surface water bodies is a Category 1 issue. This conclusion relies on the following
3 PPE/SPE parameters and the associated values and assumptions for the following parameters:

- 4 • Total Plant Water Demand
 - 5 – Less than or equal to a daily average 6,000 gpm.
- 6 • Surface Water Availability – Flowing
 - 7 – Average plant water withdrawals do not reduce discharge from the flowing water body by
 - 8 more than 3 percent of the 95 percent exceedance daily flow and do not prevent the
 - 9 maintenance of applicable instream flow requirements.
 - 10 – The 95 percent exceedance flow accounts for existing and planned future withdrawals.
 - 11 – Water availability is demonstrated by the ability to obtain a withdrawal permit issued by
 - 12 State, regional, or tribal governing authorities.
 - 13 – Water rights for the withdrawal amount are obtainable, if needed.



14
15 **Figure 3-1 SMALL Surface Water Use Impacts for Plant Withdrawals of 6,000 gpm or**
16 **Less Compared to the 95 Percent Exceedance Discharge in the Flowing**
17 **Surface Water Body**

18 If the assumptions are not met or the plant water demand exceeds the PPE, assessing surface
19 water use impacts would require a project-specific evaluation in the SEIS.

20 Radial (Ranney[®]) collector wells have been proposed for some new reactor sites and may be
21 proposed to supply water for future nuclear reactors. Radial collector wells are installed within
22 an aquifer and have a direct, productive connection to a surface water body so that they can
23 withdraw water from the surface water body that is of better quality, due to bank filtration, while
24 minimizing impacts such as sedimentation and scouring in the surface water body. Because
25 these wells either directly pump surface water or are removing groundwater that is discharging
26 to a surface water body, the PPE/SPE values and assumptions for surface water availability and
27 the evaluation of surface water use conflicts above also apply to withdrawals from radial
28 collector wells.

1 3.4.2.2.2 *Surface Water Use Conflicts during Operation Due to Water Withdrawal from*
2 *Non-flowing Water Bodies*

3 The staff considers the water availability of some non-flowing surface water bodies, i.e., the
4 Great Lakes, the Gulf of Mexico, estuaries, intertidal zones, bays, and oceans, to be large water
5 bodies compared to the total plant water demand PPE value of 6,000 gpm. For example, in the
6 EIS for Fermi (NRC 2013-TN6436), the staff determined that the annual water withdrawal
7 amounted to an inconsequential amount (0.0014 percent) of the volume of Lake Erie.

8 The staff considers that smaller non-flowing surface water bodies (e.g., inland lakes,
9 manufactured ponds, and reservoirs) have limited water availability. These water bodies are not
10 included in the staff's generic analysis. The water availability in these smaller non-flowing
11 surface water bodies may be allocated or planned for multiple uses. Therefore, withdrawing
12 water for use from these smaller non-flowing surface water bodies is more likely to result in
13 surface water use conflicts. The impacts from the competing water use could manifest in
14 different ways (e.g., reduction in downstream discharge from the water body, reduction in water
15 surface elevation of the water body, and reduction in nearshore habitat suitability) that depend
16 on site-specific hydrologic conditions. The staff has determined that impacts of plant water
17 withdrawal from these smaller non-flowing surface water bodies on surface water resources will
18 be assessed in a project-specific analysis in the SEIS.

19 As a result, the staff determined that the impact of surface water use from these large non-
20 flowing surface water bodies is a Category 1 issue. The staff concludes that if the conditions
21 and assumptions of the PPE and SPE are met the impact on surface water resources from plant
22 water withdrawal from these large non-flowing surface water bodies would be negligible and can
23 be generically determined to be SMALL. This conclusion relies on the following PPE/SPE
24 parameters and the associated values and assumptions for the following parameters:

- 25 • Total Plant Water Demand
 - 26 – Less than or equal to a daily average of 6,000 gpm.
- 27 • Surface Water Availability – Non-flowing
 - 28 – Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and
 - 29 intertidal zones exceeds the amount of water required by the plant.
 - 30 – Water availability is demonstrated by the ability to obtain a withdrawal permit issued by
 - 31 State, regional, or tribal governing authorities.
 - 32 – Water rights for the withdrawal amount are obtainable, if needed.
 - 33 – Coastal Zone Management Act of 1972 (16 U.S.C. §§ 1451 et seq.; TN1243)
 - 34 consistency determination is obtainable, if applicable.

35 The discussion related to radial collector wells that withdraw water from flowing surface water
36 bodies in Section 3.4.2.2.1 is also relevant if water were withdrawn using radial collector wells
37 from a non-flowing surface water body.

38 3.4.2.2.3 *Groundwater Use Conflicts Due to Building Foundation Dewatering*

39 The potential impacts of excavation dewatering are described in Section 3.4.2.1.2, in which the
40 staff concluded that dewatering during construction is expected to result in a SMALL impact on
41 groundwater resources. This conclusion relied on the PPE/SPE specification that the
42 dewatering rate is less than 50 gpm and the assumption that dewatering results in negligible

1 alterations in groundwater levels at the site boundary. The basis for the PPE/SPE values and
2 assumptions are discussed in Section 3.4.1.2.1. The effects of dewatering building foundations
3 during plant operation would be similar to those occurring during construction, but the
4 magnitude of the effects may increase because of the longer period of operation.

5 The combined impact of operational dewatering and plant groundwater use for large LWRs was
6 evaluated in the License Renewal GEIS (NRC 2024-TN10161). Based on a review of operating
7 plants, the staff concluded in the License Renewal GEIS that plants withdrawing less than
8 100 gpm (for operational dewatering or for plant uses) would have SMALL impacts. However,
9 the staff also determined that plants withdrawing more than 100 gpm have the potential to
10 create conflicts with other local groundwater users if groundwater levels are lowered beyond the
11 site boundary. For these plants, the staff concluded that the impacts of groundwater withdrawals
12 cannot be determined generically.

13 When evaluating the impacts of dewatering in Section 3.4.2.1.2, the staff noted that although
14 the PPE/SPE dewatering rate of 50 gpm is less than the rate determined to have SMALL
15 impacts in the License Renewal GEIS, the actual impacts of dewatering at any particular site will
16 depend on the size of the site, the area dewatered, the depth of groundwater drawdown at the
17 dewatering location (i.e., the building foundations), and the hydrogeologic conditions of the site.
18 As a result, the actual effects of dewatering on groundwater levels are uncertain and this
19 uncertainty increases with the duration of the projected need for dewatering. The staff relied on
20 the temporary nature of dewatering during construction in concluding that the impacts of
21 dewatering during construction would be SMALL. Because dewatering of building foundations
22 could occur for the duration of operations, the potential impacts of operational dewatering could
23 be larger than those of the relatively shorter period of construction.

24 The effects of dewatering on groundwater levels would be monitored, and appropriated
25 mitigation would be used with the PPE/SPE conditions met, the effects of dewatering will be
26 localized to the plant site and therefore unlikely to result in groundwater use conflicts. On this
27 basis, the staff has determined that groundwater use conflicts due to building foundation
28 dewatering during operation of a nuclear reactor are a Category 1 issue. The staff concludes
29 that the effects of dewatering activities related to the operation of nuclear reactors would be
30 localized to the plant site, and groundwater use conflicts from dewatering can be generically
31 determined to have a SMALL impact for this GEIS. This conclusion relies on the following
32 PPE/SPE parameter and the associated values and assumptions.

- 33 • Groundwater Withdrawal for Excavation or Foundation Dewatering
 - 34 – The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate
 - 35 may be larger).
 - 36 – Dewatering results in negligible groundwater level drawdown at the site boundary.

37 Because wetlands located on or adjacent to the site may be affected by building foundation
38 dewatering during operations, the PPE/SPE includes the assumption that changes in wetland
39 water levels and hydroperiod resulting from groundwater use are within historical annual or
40 seasonal fluctuations, to avoid adverse impacts on nearby wetlands. Potential groundwater use
41 impacts on wetlands are discussed in Sections 3.5.2.1.2 and 3.5.2.2.7 of this GEIS.

42 As discussed in Chapter 1, the staff anticipates that an application for a new nuclear reactor
43 license will include the appropriate data and analysis to establish with reasonable assurance
44 that the proposed project meets the conditions of the PPE/SPE with respect to dewatering,
45 including the limitations on groundwater withdrawal rate and on drawdown at the site boundary.

1 If the PPE/SPE conditions cannot be met, a project-specific evaluation of the impacts of
2 excavation dewatering is required.

3 *3.4.2.2.4 Groundwater Use Conflicts Due to Groundwater Withdrawals for Plant Uses*

4 Construction use of groundwater is discussed in Section 3.4.2.1.3. Groundwater may be used
5 during operations for various plant purposes, including potable, sanitary, process, and cooling
6 uses. The operational effects of groundwater use would be similar to those described for
7 construction, with the principal difference being that the duration of pumping for operations
8 would be significantly longer. When evaluating impacts, the staff considered an operational
9 period of 40 years. Groundwater withdrawals from one or more wells located on the plant site
10 will lower groundwater hydraulic head levels in the aquifer around the well(s), and the
11 magnitude of the drawdown in hydraulic head and the extent of the affected area tend to
12 increase with the duration of the withdrawal. As noted previously, changes in groundwater levels
13 may locally affect the direction of groundwater flow, and may alter groundwater recharge or
14 discharge rates, including discharge to wetlands and streams.

15 The staff reviewed recent new reactor EISs and found that the proposed groundwater pumping
16 rates exceeding 100 gpm were determined to have a SMALL impact on groundwater resources.
17 In each case, this conclusion was made, in part, because the site locations and specific
18 pumping rates were known and could be fully evaluated. In one instance (Grand Gulf), where
19 the plant design and groundwater withdrawal rate were uncertain, and where withdrawals would
20 be from an EPA-designated SSA, the staff concluded that a MODERATE impact was possible
21 (NRC 2006-TN674).

22 Based on a review of groundwater withdrawals for operational purposes at existing plants, the
23 staff reported in the License Renewal GEIS (NRC 2024-TN10161) that impacts on water
24 resources could vary based on geographic location, especially if pumping rates exceeded
25 100 gpm. As a result, the staff determined that groundwater use conflicts are a Category 2 issue
26 (SMALL, MODERATE, or LARGE impacts depending on project-specific characteristics) for
27 plants that withdraw more than 100 gpm. For plants that withdraw less than 100 gpm, the staff
28 determined that groundwater use conflicts were a Category 1 issue and concluded that these
29 plants would have SMALL impacts because the effects on groundwater levels do not usually
30 extend beyond the site boundary (NRC 2024-TN10161).

31 A groundwater withdrawal rate of 50 gpm is specified in the PPE/SPE table (Appendix G), as
32 discussed in Section 3.4.1.2.1. While this withdrawal rate is less than the rate determined to
33 have SMALL impacts in the License Renewal GEIS, the actual impacts of groundwater
34 withdrawals at any particular site will depend on the size of the site. The site size (100 ac)
35 specified in the PPE/SPE table is much smaller than the areas of operating plants and licensed
36 new reactors (e.g., the Clinch River site proposed for a small modular reactor is more than
37 900 ac). In evaluating the impacts of groundwater use for this generic analysis, the staff
38 considered the 100-ac size specified in the PPE for reactor sites and used a distance between
39 the pumped well and the site boundary of about 1,000 ft (the distance of a well located at the
40 center of a square 100 ac site). As noted below, mitigation to prevent significant impacts may be
41 required if the well is closer to the site boundary. The staff's analysis used a single well,
42 screened over the entire depth of an infinite (in area), homogeneous aquifer, and withdrawing
43 50 gpm for 40 years. As specified in the PPE/SPE table, and discussed in Section 3.4.1.2.1,
44 groundwater withdrawals are assumed to result in no more than 1 ft of drawdown at the site
45 boundary.

1 Given the specifications and assumptions described above, groundwater drawdown at any
2 distance from the pumped well can be estimated with an analytical approach for radial flow to a
3 well (e.g., Freeze and Cherry 1979-TN3275). Because drawdown depends on the
4 hydrogeological properties of the aquifer (which is unknown for a generic site), the staff
5 evaluated the effects of groundwater use for a representative range of aquifer properties. The
6 staff determined that the impacts of groundwater withdrawals are likely to be localized (i.e.,
7 groundwater drawdown beyond the site boundary is less than 1 ft) at sites where the effective
8 transmissivity is greater than about 5,000 ft²/d for withdrawals from an unconfined aquifer and
9 greater than 10,000 ft²/d for withdrawals from a confined aquifer. These transmissivity values
10 imply aquifers that are productive sources of groundwater, with well-specific capacities in the
11 range of 25 to 40 gpm/ft of drawdown (Driscoll 1986-TN6823). At smaller sites or sites where
12 the pumped well is located closer to the site boundary, and at sites with less transmissive
13 aquifers, additional mitigation may be needed to avoid groundwater use conflicts (e.g., reducing
14 the withdrawal rate or altering the location of the well with respect to other groundwater users).

15 The staff determined that groundwater use conflicts due to groundwater withdrawals during
16 operation of a nuclear reactor is a Category 1 issue. The staff concludes that the effects of
17 groundwater use related to the operation of nuclear reactors would be localized to the site area
18 and groundwater use conflicts from withdrawals for plants uses can be generically determined
19 to have a SMALL impact for this GEIS. This conclusion relies on the following PPE/SPE
20 parameter and the associated value and assumptions:

21 • Groundwater Withdrawal for Plant Uses

- 22 – Groundwater withdrawal for all plant uses (excluding dewatering) is less than or equal to
23 50 gpm.
- 24 – Withdrawal results in no more than 1 ft of groundwater level drawdown at the site
25 boundary.
- 26 – Withdrawals are not derived from an EPA-designated SSA, or from any aquifer
27 designated by a State, tribe, or regional authority to have special protections to limit
28 drawdown.
- 29 – Withdrawals meet any applicable State or local permit requirements.

30 Because wetlands located on or adjacent to the site may be affected by building foundation
31 dewatering during operations, the PPE/SPE includes the assumption that changes in wetland
32 water levels and hydroperiod resulting from groundwater use are within historical annual or
33 seasonal fluctuations, to avoid adverse impacts on nearby wetlands. Potential groundwater use
34 impacts on wetlands are discussed in Sections 3.5.2.1.2 and 3.5.2.2.7 of this GEIS.

35 As described in Chapter 1, the staff anticipates that an application for a new nuclear reactor
36 license will include the appropriate data and analysis to establish with reasonable assurance
37 that the proposed project meets the conditions of the PPE/SPE with respect to groundwater
38 withdrawals for plant use. If the PPE/SPE conditions cannot be met, a project-specific
39 evaluation of the impacts of groundwater withdrawal is required.

40 *3.4.2.2.5 Surface Water Quality Degradation Due to Physical Effects from Operation of Intake
41 and Discharge Structures*

42 Cooling-water intake and discharge structures have the potential to create localized impacts on
43 surface water quality through physical effects such as alterations of current patterns, scouring,
44 sediment transport, and increased turbidity. The License Renewal GEIS reports that (NRC

1 2024-TN10161) these impacts have typically been small for operating reactors, in part due to
2 adherence to Section 316 of the CWA (33 U.S.C. § 1326; TN4823) and because effects are
3 limited to the area of the intake and discharge structure. Section 316(b) of the CWA requires
4 that the “best technology available for minimizing adverse environmental impact” be used for
5 cooling-water intake structure. This has made the use of once-through cooling-water systems
6 unlikely for new power plants. Any applicant for a new nuclear reactor license that uses intake
7 or discharge structures as part of the cooling or water supply system would also need to comply
8 with the same requirements of Section 316(b) of the CWA and the conditions of the NPDES
9 permit that would be required for the site.

10 Because the effects of intake and discharge structures are dependent on water withdrawal and
11 discharge rates, the staff expects that the plant discharge rate would be less than the
12 withdrawal rate. The withdrawal rate is based on the PPE limit for total plant water demand and
13 any applicable SPE values and assumptions for the selected water source (Surface Water
14 Availability for Flowing or Non-flowing water bodies). For flowing water bodies, withdrawals
15 would be limited to the total plant water demand PPE/SPE value of 6,000 gpm and be 3 percent
16 or less of the 95 percent low flow value for the water body as explained in Section 3.4.2.2.1. For
17 non-flowing water bodies, withdrawals would also be limited to the total plant water demand
18 PPE/SPE value of 6,000 gpm and be subject to SPE values and assumptions.

19 The staff has determined that degradation of surface water quality due to operation of intake
20 and discharge structures is a Category 1 issue. The staff concludes that the impacts on the
21 aquatic environment from the alteration of current patterns, scouring, sediment transport, and
22 increased turbidity would be localized to the vicinity of these structures, and therefore the impact
23 on surface water quality can be generically determined to be SMALL. This conclusion relies on
24 the following PPE/SPE parameters and the associated values and assumptions for the following
25 parameters:

- 26 • Total Plant Water Demand
 - 27 – Less than or equal to a daily average of 6,000 gpm.
- 28 • Intake and Discharge Structures
 - 29 – Adhere to best available technology requirements of CWA 316(b) (33 U.S.C. § 1326-
30 TN4823).
 - 31 – Operated in compliance with CWA Section 316 (b) and 40 CFR 125.83, including
32 compliance with monitoring and recordkeeping requirements in 40 CFR 125.87 and
33 40 CFR 125.88, respectively (40 CFR Part 125-TN254).
 - 34 – Best available technologies are employed in the design and operation of intake and
35 discharge structures to minimize alterations due to scouring, sediment transport,
36 increased turbidity and erosion.
 - 37 – Adherence to requirements in NPDES permits issued by the EPA or a given state.
- 38 • If water is obtained from a flowing water body, then the following PPE/SPE parameter and
39 associated value also applies.
- 40 • Surface Water Availability – Flowing
 - 41 – The average rate of plant withdrawal does not exceed 3 percent of the 95 percent
42 exceedance daily flow for the water body.

1 If water is obtained from a non-flowing water body, then the following PPE/SPE parameters and
2 associated values and assumptions also apply:

- 3 • Surface Water Availability – Non-flowing
- 4 – Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and
5 intertidal zones exceeds the amount of water required by the plant.

6 *3.4.2.2.6 Surface Water Quality Degradation Due to Changes in Salinity Gradients Resulting*
7 *from Withdrawals*

8 Power plant withdrawals may cause alterations to salinity concentrations and salinity gradients if
9 the source water body is an estuary or intertidal zone. As a result, States with estuaries or
10 intertidal zones typically require consideration of the effect of power plant withdrawals on the
11 alteration of salinity regimes as part of the development of permits.

12 The impacts of water withdrawal and discharge on salinity gradients near operating nuclear
13 power plants, including those located on estuaries or intertidal zones, were evaluated by the
14 staff for the 2013 License Renewal GEIS (NRC 2024-TN10161). The 2013 License Renewal
15 GEIS drew upon project-specific examples provided in the 1996 License Renewal GEIS
16 (NRC 1996-TN288) to conclude that altered salinity gradients were expected to be noticeable
17 only in the immediate vicinity of the intake and discharge structures. The 1996 License Renewal
18 GEIS considered the impacts to be SMALL and designated this a Category 1 issue. To develop
19 this GEIS, the staff considered the conclusions and examples provided in both the 1996 License
20 Renewal GEIS and the 2013 revision. In one example shared in the 1996 GEIS, the staff noted
21 that a fossil-fuel plant located on the same large estuary as a nuclear plant, was found to have
22 altered natural salinity patterns because it was sited in a shallower area. This illustrates that,
23 even in large estuaries, the degree of impact is somewhat dependent on the location of the
24 plant. Siting may be an even more important factor when a smaller water body is involved. In
25 addition, the 1996 GEIS noted that impacts were also dependent on whether alterations to
26 salinity gradient were, "...within the normal tidal or seasonal movements of salinity gradients
27 that characterize estuaries" (NRC 1996-TN288).

28 For this GEIS, the staff recognizes that for water bodies other than estuaries and intertidal
29 zones, maintaining the natural salinity regime is not a critical issue and is not typically included
30 in water quality criteria for that water body. As noted above, in sensitive water bodies such as
31 estuaries or intertidal zones, factors that affect the magnitude of potential impacts include the
32 size of the water body, the placement of the plant intake structures in relation to the water body,
33 and any changes in the normal range and movement of the salinity gradients that characterize
34 that water body. These factors are project-specific and are considered important in the
35 development of the impact level for nuclear reactors that may be sited in a variety of locations
36 and water body types.

37 For this GEIS, the staff has determined that degradation of surface water quality due to changes
38 in salinity gradients resulting from withdrawal is a Category 1 issue that can be generically
39 determined to be SMALL. This conclusion relies on the following PPE/SPE parameter and the
40 associated values:

- 41 • Total Plant Water Demand
- 42 – Less than or equal to a daily average 6,000 gpm.

1 If water is obtained from a flowing water body, then the following PPE/SPE parameter and
2 associated assumptions also apply:

3 • Surface Water Availability – Flowing

4 – Average plant water withdrawals do not reduce discharge from the flowing water body by
5 more than 3 percent of the 95 percent exceedance daily flow and do not prevent the
6 maintenance of applicable instream flow requirements.

7 – The 95 percent exceedance flow accounts for existing and planned future withdrawals.

8 – Water availability is demonstrated by the ability to obtain a withdrawal permit issued by
9 State, regional, or tribal governing authorities.

10 – Water rights for the withdrawal amount are obtainable, if needed.

11 – If withdrawals are from an estuary or intertidal zone, then changes to salinity gradients
12 are within the normal tidal or seasonal movements that characterize the water body.

13 If water is obtained from a non-flowing water body, then the following PPE/SPE parameter and
14 associated values and assumptions also apply:

15 • Surface Water Availability – Non-flowing

16 – Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and
17 intertidal zones exceeds the amount of water required by the plant.

18 – Water availability is demonstrated by the ability to obtain a withdrawal permit issued by
19 State, regional, or tribal governing authorities.

20 – Water rights for the withdrawal amount are obtainable, if needed.

21 – If withdrawals are from an estuary or intertidal zone, then changes to salinity gradients
22 are within the normal tidal or seasonal movements that characterize the water body.

23 The Coastal Zone Management Act of 1972 (16 U.S.C. §§ 1451 et seq.; TN1243) consistency
24 determination is obtainable, if applicable. The finding applies to all water bodies. However,
25 based on the discussion above, for estuaries and intertidal zones, the staff's impact conclusion
26 relies on the SPE assumption, adopted from the License Renewal GEIS, that changes to salinity
27 gradients be localized near the intake of the power plant and remain within the normal tidal or
28 seasonal movements of salinity gradients that characterize the water body. If PPE and SPE
29 values and assumptions are not met, then a project-specific evaluation will be required.

30 *3.4.2.2.7 Surface Water Quality Degradation Due to Chemical and Thermal Discharges*

31 During operations, nuclear plants may discharge water from the cooling, service, and sanitary
32 water system to surface water bodies near the plant. If the plant is water-cooled, the largest
33 volume of discharge and the greatest potential impacts on water quality are associated with the
34 heat and chemical constituents in the effluent discharged from the cooling-water system.
35 Discharges typically contain increased TDS, salinity, biocides, heavy metals, and other
36 contaminants that may have been included in the withdrawn cooling water but become
37 concentrated due to evaporative loss during the cooling process. Some chemicals may also be
38 added to the withdrawn water before it is discharged (e.g., biocides). Impacts on surface water
39 from plant discharge may vary based on the quality and rate of the plant discharge and the
40 characteristics of the receiving water body, some of which are related to location. These
41 location-dependent characteristics may include natural variations in temperature, salinity levels,
42 or normal tidal or seasonal movements of salinity gradients.

1 To operate, power plants must obtain an NPDES permit under Section 402 of the CWA
2 (33 U.S.C. § 1342-TN4765). The permit specifies discharge standards and monitoring
3 requirements, and licensees are required to be in compliance with the limits set by the permit.
4 NPDES permits are issued by the EPA or, more commonly, a designated State water quality
5 regulatory agency.

6 The staff performed a review of the historical impacts of discharges from known plant discharge
7 designs on well-understood sites and determined that the impacts were determined to be of
8 small significance (NRC 2024-TN10161). The staff also reviewed EISs for licensed new reactors
9 and determined that the impacts of discharges during operations on surface water quality would
10 be SMALL, with one exception. This exception occurred in the Grand Gulf ESP EIS, where the
11 staff concluded that the impacts of plant discharges on the Mississippi River water quality were
12 not able to be determined because "...the bounds of concentrations of chemical effluents" for all
13 waste streams had not been provided in the PPE or ER (NRC 2006-TN674). For both operating
14 and proposed sites, the conclusion that impacts on water quality would be SMALL was reached
15 after a project-specific review. These project-specific reviews included an estimation of the
16 extents of the mixing zones in the receiving water bodies and how the mixing zone may affect
17 aquatic resources under site-specific conditions (e.g., geometry, ambient discharge
18 characteristics, ambient water quality characteristics, aquatic habitat, and designated uses of
19 the water body).

20 During the evaluation conducted for this GEIS, the staff sought to develop a comprehensive
21 bounding set of water quality criteria, including both thermal and chemical criteria, for use in the
22 PPE and SPE. The staff found this to be impractical and determined that it would not ultimately
23 be beneficial to the GEIS. Development of a bounding list for the PPE was complicated by
24 uncertainties in how a new, advanced plant design might affect cooling systems, and the
25 thermal and chemical characteristics of the discharges.

26 Development of a bounding set of characteristics for the SPE was challenging for the reasons
27 presented below.

28 First, a State with delegated permitting authority may impose limitations on temperature and
29 effluent that are tailored to the conditions of the State and they may be more stringent than
30 those required by the EPA. These State-specific conditions include characteristics of the
31 receiving water body such as type (e.g., ocean, lake, river), designated use (e.g., water supply,
32 agricultural use, recreational), ambient temperature, ambient water quality and assimilative
33 capacity, and the significance of the aquatic habitat (e.g., spawning zones). For example,
34 contaminant concentration standards for domestic water supplies prescribed by the States of
35 Tennessee (TN 0400-40-03-TN7038) and Alaska (18 AAC 70-TN7039) are more restrictive than
36 the legally enforceable standards required by the National Primary Drinking Water Regulations
37 of the SDWA.

38 Second, the more stringent criteria developed by States may vary. The staff reviewed the
39 acceptable temperature ranges in discharges and the resulting thermal impacts on receiving
40 water bodies for Tennessee, Alaska, and Idaho and found them to vary (TN 0400-40-03-
41 TN7038; 18 AAC 70-TN7039; IDAPA 58.01.02-TN7040). This variance between States results
42 primarily from the difference in the ambient temperature of the water bodies caused by the
43 regional climate as well as the tolerance for temperature variations of the aquatic species
44 present in the water bodies. In addition, States with estuaries or intertidal zones (e.g., Maryland)
45 typically require consideration of the effect of power plant discharges on the alteration of salinity
46 regimes at the discharge site as part of the NPDES permits. State with these zones may set

1 more restrictive limits on salinity and require greater evaluation of potential impacts of the
2 discharge on salinity gradients than states without these zones.

3 Third, if permits establish effluent limits that exceed water quality criteria a regulatory mixing
4 zone may be determined, for which individual requirements can be established on a case-by-
5 case basis. In theory, impacts could be negligible if the potential for significant dilution of effluent
6 discharge and minimization of thermal and salinity impacts in the receiving water body exists.
7 However, computation of an acceptable dilution factor for permits often factors in limits on
8 mixing zone sizes set by States for specific water bodies, making the dilution factor project-
9 specific.

10 Lastly, development of a bounding set of plant parameters for the PPE or site parameters for
11 the SPE was not considered beneficial for this GEIS, because compliance with water quality
12 standards set forth in the NPDES permit does not necessarily equate to a SMALL impact (i.e.,
13 indicating no noticeable impact on surface water quality of the resource; see 10 CFR 51.71(d),
14 footnote 3 [TN250]). Therefore, a project-specific evaluation would be necessary to develop the
15 impact determination as part of a SEIS.

16 As a result, the staff determined that degradation of surface water quality from chemical and
17 thermal discharges requires consideration of project-specific information on a case-by-case
18 basis. Therefore, the staff determined that the degradation of surface water quality due to
19 chemical and thermal discharges is a Category 2 issue (SMALL, MODERATE, or LARGE
20 impacts depending on project-specific characteristics). The staff concludes that the impact on
21 surface water quality due to chemical and thermal discharges should be determined on a case-
22 by-case basis using project-specific information in a SEIS.

23 *3.4.2.2.8 Groundwater Quality Degradation Due to Plant Discharges*

24 Based on reviews of proposed large LWRs and existing plants, the staff has determined that the
25 discharge to surface water bodies during operation would not noticeably impact groundwater
26 resources. However, some existing and proposed plants discharge, or plan to discharge, plant
27 effluents directly to groundwater via deep well injection or indirectly to groundwater via
28 infiltration from ponds or canals. Water discharged to a cooling pond has elevated
29 concentrations of TDS and other constituents and could infiltrate into the underlying
30 groundwater system. The significance of the groundwater quality impacts would depend on
31 cooling pond water quality, site hydrogeologic conditions, and the location, depth, and pumping
32 rate of offsite wells. The potential for impacts is decreased in areas that have poorer
33 groundwater quality, such as coastal areas and salt marshes (NRC 2024-TN10161), but all
34 plant discharges to the subsurface have the potential to degrade groundwater quality. At the
35 Turkey Point site, in-depth, project-specific analysis of the potential effects of discharge from an
36 operating plant located above an EPA-designated SSA has also been conducted. The staff
37 evaluated the impacts of infiltration of hypersaline water from the operation of Units 3 and 4
38 discharged into the cooling-canal system (NRC 2019-TN6824). The staff found that infiltration of
39 plant effluents into the shallow aquifer underlying the canal has had a significant impact on
40 groundwater quality on and off the plant site. In the Turkey Point Units 6 and 7 EIS (NRC 2016-
41 TN6434), the staff also evaluated the potential impact of injection of plant discharge into a deep
42 aquifer. The staff ultimately determined that deep well injection would lead to a SMALL impact.
43 However, this determination relied upon a detailed project-specific evaluation.

44 Because the potential impacts on groundwater can be significant, the PPE/SPE groundwater
45 quality parameter specifies that a new nuclear plant be located outside the recharge area for

1 any aquifer designated to have special protections. In addition, the PPE/SPE specifies that the
2 plant be outside the designated contributing area for any public water supply well. Because any
3 discharge of plant effluents to the subsurface would have significant potential impacts on
4 groundwater quality, the PPE/SPE also assumes that there would be no planned discharges to
5 the subsurface via either direct injection or via infiltration from ponds or canals. Based on these
6 PPE/SPE values and assumptions, the staff has determined that groundwater quality
7 degradation due to plant discharges during operation of a nuclear reactor is a Category 1 issue.
8 The staff concludes that the discharges can be generically determined to have a SMALL impact
9 on groundwater quality. This conclusion relies on the following PPE/SPE parameter and the
10 associated values and assumptions:

- 11 • Groundwater Quality
 - 12 – The plant is outside the recharge area for any EPA-designated SSA or any aquifer
 - 13 designated to have special protections by a State, tribal, or regional authority.
 - 14 – The plant is outside the wellhead protection area or designated contributing area for any
 - 15 public water supply well.
 - 16 – There are no planned discharges to the subsurface (by infiltration or injection).

17 If these PPE/SPE values and assumptions are not met, a project-specific evaluation of the
18 impacts of groundwater withdrawal is required.

19 *3.4.2.2.9 Water Quality Degradation Due to Inadvertent Spills and Leaks during Operation*

20 During operation, inadvertent spills of gasoline, diesel fuel, hydraulic fluid, lubricants, solvents
21 and wastewater used for construction equipment could impact both surface water and
22 groundwater resources. Pursuant to 40 CFR Part 112 (TN1041), applicants would be required
23 to use BMPs and implement a SPCC to minimize the occurrence of spills and limit their effects.
24 While not necessarily uncommon at operating nuclear power plants, minor chemical spills have
25 not constituted widespread, consistent water quality impacts because they are readily amenable
26 to correction (NRC 1996-TN288).

27 During operation, features of the stormwater discharge system, such as retention basins, may
28 increase infiltration over the area of the basin and increase local recharge to groundwater,
29 thereby potentially affecting groundwater quality. Stormwater discharge would be regulated
30 under the NPDES permit and it would conform to the terms of the NPDES permit, including
31 monitoring of discharge water quality for potential inadvertent releases. In recent EISs for
32 proposed large LWRs the NRC staff has assumed that the system would be designed to
33 preclude discharge to groundwater during operations and, as a result, plant runoff during
34 operations would not affect groundwater quality.

35 Radionuclide leaks from plant components and pipes have occurred at numerous plants (NRC
36 2023-TN10129). Groundwater protection programs have been established at all operating
37 nuclear power plants to minimize potential impacts from inadvertent releases (NEI 2019-
38 TN6775). The License Renewal GEIS evaluated the impacts from leaks occurring at operating
39 reactor sites and determined that that if leaks were to occur, the magnitude of impacts would be
40 dependent on project-specific characteristics (NRC 2024-TN10161). The staff concluded in the
41 License Renewal GEIS that, because the impacts of radionuclide leaks to groundwater could be
42 greater than SMALL and must be based on a project-specific analysis, this is a Category 2
43 issue.

1 While contamination from inadvertent leaks have occurred at operating plants, the staff
2 determined that this operating experience is not sufficient to preclude a generic determination
3 on this issue for the operation of new nuclear reactors. As a result, the staff has determined that
4 water quality degradation due to inadvertent spills during operation of a nuclear reactor is a
5 Category 1 issue. The staff concludes that the impacts of inadvertent spills on water quality
6 during operation of a nuclear reactor site would be SMALL. This conclusion relies on the
7 following PPE/SPE parameters and the associated values and assumptions:

8 • Groundwater Quality

- 9 – Applicable requirements and guidance on spill prevention and control are followed,
10 including relevant BMPs and SPCCs.
- 11 – There are no planned discharges to the subsurface (by infiltration or injection), including
12 stormwater discharge.
- 13 – A groundwater protection program conforming to NEI 07-07 (NEI 2019-TN6775) is
14 established and followed.

15 • Site Size and Location

- 16 – The site size is 100 ac or less.

17 • Permanent Footprint of Disturbance

- 18 – Use of BMPs for soil erosion, sediment control, and stormwater management.

19 • Impacts on Aquatic Biota

- 20 – Adherence to requirements in NPDES permits issued by the EPA or a given State, and
21 any other applicable permits.

22 If the PPE/SPE conditions are not met, a project-specific evaluation of the impacts of
23 inadvertent spills and leaks is required.

24 *3.4.2.2.10 Water Quality Degradation Due to Groundwater Withdrawals*

25 Water quality degradation due to groundwater withdrawals during construction is discussed in
26 Section 3.4.2.1.6. Degradation of groundwater resources may occur when dewatering or
27 withdrawal of groundwater for plant uses induces the flow of lower quality water from the
28 surrounding aquifers or connected surface water bodies. Groundwater withdrawals may induce
29 infiltration from surface water (e.g., rivers) or contribute to increased saltwater intrusion from
30 nearby oceans and estuaries in aquifers already impacted by saltwater intrusion. The effects of
31 groundwater withdrawals during operation of a nuclear reactor would be similar to those during
32 construction, but they would occur over a longer duration.

33 In the License Renewal GEIS (NRC 1996-TN288 and NRC 2024-TN10161) the staff reported
34 that operating plants in estuary or coastal sites that pumped groundwater from confined aquifers
35 at rates between 400 gpm and 1,000 gpm had a small effect on groundwater quality, especially
36 when the plant's withdrawal rate was a small fraction of the regional total groundwater use. In
37 the EISs for new large LWRs, groundwater pumping during operation was determined to have a
38 SMALL impact on groundwater resources at all sites except for Grand Gulf. In the Grand Gulf
39 ESP EIS (NRC 2006-TN674) the staff evaluated a range of potential pumping rates because the
40 estimates of the pumping rate were not provided. The staff determined that high groundwater
41 withdrawal rates (from radial collector wells) could induce flow of lower quality groundwater from
42 deeper aquifers upward into the Catahoula (an EPA-designated SSA) and significantly degrade
43 water quality.

1 The PPE/SPE table limits groundwater withdrawals for building foundation dewatering and plant
2 uses to 50 gpm and assumes that groundwater withdrawals will result in no more than a 1 ft
3 lowering of groundwater levels at the site boundary. The basis for the PPE/SPE values and
4 assumptions is discussed in Section 3.4.1.2.1. The 1 ft limit includes the potential cumulative
5 effect of simultaneous dewatering and groundwater withdrawal for plant uses because
6 dewatering is assumed to contribute negligible drawdown at the site boundary, as specified in
7 the PPE/SPE table (Appendix G). In areas that have exploitable groundwater resources, the
8 PPE/SPE withdrawal rate is expected to be a small fraction of the total withdrawal rate by other
9 users (typically agricultural or municipal uses in rural and urban areas, respectively). With
10 minimal changes in groundwater levels at the site boundary, the potential for PPE/SPE
11 withdrawals to induce flow from adjacent water bodies is unlikely to be noticeable.

12 The staff has determined that water quality degradation due to groundwater withdrawals is a
13 Category 1 issue. The staff concludes that water quality impacts resulting from groundwater
14 withdrawals during operation of the any nuclear reactors would be localized and can be
15 generically determined to be SMALL for this GEIS. This conclusion relies on the following
16 PPE/SPE parameters and the associated values and assumptions:

- 17 • Groundwater Withdrawal for Excavation or Foundation Dewatering
 - 18 – The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate
19 may be larger).
 - 20 – Dewatering results in negligible groundwater level drawdown at the site boundary.
- 21 • Groundwater Withdrawal for Plant Uses
 - 22 – Groundwater withdrawal for all plant uses (excluding dewatering) is less than or equal to
23 50 gpm.
 - 24 – Withdrawal results in no more than 1 ft of groundwater level drawdown at the site
25 boundary.
 - 26 – Withdrawals are not derived from an EPA-designated SSA, or from any aquifer
27 designated by a State, tribe, or regional authority to have special protections to limit
28 drawdown.
 - 29 – Withdrawals meet any applicable State or local permit requirements.

30 If any of the PPE/SPE conditions are not met, a project-specific evaluation of the water quality
31 impacts of groundwater withdrawals is required. For example, use of a radial collector well
32 during operation is likely to involve withdrawals that exceed the 50 gpm PPE/SPE value, which
33 will require a project-specific evaluation of potential water quality degradation.

34 *3.4.2.2.11 Water Use Conflict Due to Plant Municipal Water Demand*

35 Municipal water supply used to support water use (e.g., potable and sanitary needs) during
36 plant operations may affect the municipal systems' ability to meet their planned obligation to
37 other users. To generically assess the potential impact on municipal systems from the plant's
38 operation-related water use, the staff assumed that the needed amount of municipal water is
39 available and within the existing or planned capacity of the municipal systems while accounting
40 for all existing and planned future uses. If these assumptions are satisfied, the staff determined
41 that the plant's operation-related municipal water use will not unduly stress the municipal
42 systems' ability to meet their existing and planned obligations.

1 The staff has determined that the effect of water supply from municipal systems is a Category 1
2 issue. The staff concludes that, as long as the relevant PPE and SPE are met, the impacts on
3 municipal systems from operating a nuclear reactor can be generically determined to be
4 SMALL. This conclusion relies on the following PPE/SPE parameter and the associated values
5 and assumptions:

- 6 • Municipal Water Availability
 - 7 – Usage amount is within the existing capacity of the system(s), accounting for all existing
8 and planned future uses.
 - 9 – An agreement or permit for the usage amount can be obtained from the municipality.

10 *3.4.2.2.12 Degradation of Water Quality Due to Plant Effluent Discharges to Municipal Systems*

11 During operation of a plant, certain plant effluents (e.g., sanitary and sewer discharges) could
12 be discharged to a municipal wastewater treatment system. To generically assess the potential
13 impact on the municipal wastewater system, the staff assumed that the municipal system has
14 an existing or planned capacity to treat all plant effluent while accounting for all existing and
15 planned future discharges. The staff further assumed that the plant effluent constituents can be
16 treated by the receiving system and therefore a permit can be obtained for operation-related
17 plant effluent discharge to the municipal systems.

18 The staff has determined that the degradation of water quality from plant effluent discharges to
19 municipal systems is a Category 1 issue. The staff concludes that, as long as the relevant PPE
20 and SPE are met (e.g., the plant effluent discharge is bounded by municipal wastewater
21 systems' capacity) and appropriate permits can be obtained, the impacts on water quality from
22 plant effluent discharges to municipal systems from operating a nuclear reactor can be
23 generically determined to be SMALL. This conclusion relies on the following PPE/SPE
24 parameter and the associated values and assumptions:

- 25 • Municipal Systems' Available Capacity to Receive and Treat Plant Effluent
 - 26 – Municipal Systems' Available Capacity to Receive and Treat Plant Effluent accounts for
27 all existing and reasonably foreseeable future discharges.
 - 28 – Agreement to discharge to a municipal treatment system is obtainable.

29 **3.5 Terrestrial Ecology**

30 **3.5.1 Baseline Conditions and PPE/SPE Values and Assumptions**

31 Any site proposed for a new reactor would contain terrestrial habitat of some type. Even land
32 areas with past industrial or urban development provide habitat for terrestrial species. The NRC
33 staff expects that most proposed new reactor sites would contain some naturally vegetated land
34 such as forest, scrub, grassland, or wetlands; landscaped land such as lawns or mowed areas;
35 or agricultural land such as cropland, pasture, and orchard. Sites may also contain active or
36 abandoned structures, pavement, rubble, borrow pits, or strip-mined lands. In natural habitats,
37 the vegetation present may be the climax vegetation featuring species composition typical for
38 the landscape position after long periods without human or natural disturbance, or it may be
39 successional vegetation influenced by more recent disturbance. Sites may be greenfield,
40 without a history of nonagricultural development, or all or part of a proposed site may contain
41 operating or abandoned power generation facilities or other industrial facilities. More information
42 about how the NRC staff defines and characterizes terrestrial habitats is available in RG 4.11
43 (NRC 2012-TN1967).

1 Vegetation varies greatly across the United States. Vegetation is typically forest in humid
2 settings receiving high rainfall but may be grassland (prairie), shrubland, or desert vegetation in
3 drier or rockier settings or areas subject to past disturbance, or taiga (boreal forest) or tundra in
4 permafrost settings. Wetlands are intermediate between terrestrial and aquatic habitat types.
5 Wetlands are delineated using the *Corps of Engineers Wetlands Delineation Manual* (USACE
6 1987-TN2066) and regional supplemental guidance recognized by the USACE and may or may
7 not be under the jurisdiction of the CWA protecting wetlands and threatened and endangered
8 species, and relevant scientific literature. Some assumptions made in this section of this GEIS
9 involve parameters and values adapted from previous staff environmental reviews or are the
10 subject of Federal regulations; some have been appropriately scaled down to account for the
11 size and technology differences between large LWRs and smaller reactors. In every case, the
12 staff has selected a value or parameter that will ensure a SMALL impact on terrestrial resources
13 from building and operation of a reactor after considering all available information and
14 leveraging professional judgment and expertise.

15 Based on information contained in past new reactor EISs and the staff's ability to scale that
16 information to smaller reactors, the staff includes an assumption in the PPE and SPE that calls
17 for the permanent disturbance of no more than 30 ac of vegetated (unpaved) terrestrial habitat,
18 and temporary disturbance of an additional 20 ac of vegetated terrestrial habitat. However, the
19 PPE and SPE assume that any temporarily disturbed habitat would be restored using regionally
20 indigenous vegetation once the new facilities are built. The staff reasons that disturbance to
21 larger areas could potentially result in substantial effects on regional ecosystems. The
22 assumptions also recognize limitations on the type and quality of terrestrial habitat disturbed.
23 There can be no ecologically sensitive features within the disturbed areas (footprint of
24 disturbance), such as floodplains, shorelines, riparian vegetation, late-successional vegetation,
25 land specifically designated for conservation, or habitat known to be potentially suitable for one
26 or more Federal or State threatened or endangered species. In addition, the PPE assumes that
27 there can be no more than 0.5 ac of wetlands or other surface waters impacted by the entire
28 project. This value is based on the fact that many Nation Wide Permits (NWP) established
29 under the CWA (33 CFR Part 330-TN4318) allow up to 0.5 ac of project-wide disturbance to
30 wetlands and other waters of the United States. Additionally, drawing from analyses in past new
31 reactor EISs, the staff included an assumption in the PPE and SPE of a maximum building
32 height of 50 ft, except for 200 ft for meteorological towers and 100 ft for transmission line
33 poles/towers and mechanical draft cooling towers. The PPE assumes new meteorological
34 towers will have non-red, flashing lights. The Federal Aviation Administration recommends
35 voluntary marking of meteorological towers <200 ft AGL and does not permit red non-flashing
36 lights on any new tower above 150 ft AGL to reduce the number of migratory bird collisions
37 (FAA 2020-TN10130; FCC 2017-TN10131). The PPE and SPE likewise assume no noise
38 generation greater than 85 decibel(s) on the A-weighted scale (dBA) at a point 50 ft from the
39 source. The assumptions in the PPE and SPE regarding site employment (Section 3.12.2) also
40 apply to the staff's evaluation of potential impacts on wildlife from vehicular traffic.

41 As presented in Section 3.1, the staff assumes that offsite ROWs for transmission lines,
42 pipelines, and access roads are not more than 1 mi in length or 100 ft in width, but may be
43 unlimited in mileage for linear features built within existing ROWs or in widened ROWs directly
44 adjacent to existing ROWs or public highways. The staff recognizes that these values would
45 effectively minimize disturbance to terrestrial habitats and wildlife in most surrounding
46 landscapes. Additionally, the NRC staff assumes that the total disturbance to any wetlands (as
47 delineated using the *Corps of Engineers Wetlands Delineation Manual* [USACE 1987-TN2066]
48 and regional supplements) and other surface waters from the entire project (including onsite and
49 offsite activities) would not exceed 0.5 ac (based on criteria underlying many NWP).

1 Otherwise, the staff does not assume other qualitative limitations on other habitats that may be
2 present in proposed offsite ROWs, because only a small fraction of the area would be disturbed
3 by support foundations and most of the ROW area would be spanned by overhead power lines.
4 In addition, the staff assumes there would be no physical disturbance to streams greater than
5 10 ft in width below the ordinary high-water mark. While the potential impacts on most such
6 narrow streams would be localized, physical disturbance to larger streams could potentially
7 affect more distant connected wetland and shoreline habitats.

8 The staff assumes that licensees would comply with State and local regulatory requirements for
9 implementing BMPs for soil erosion, sediment control, and stormwater management whenever
10 ground-disturbing activities take place either onsite or offsite. Even if a project is proposed for
11 somewhere lacking such regulatory requirements, the staff assumes for purposes of its generic
12 analyses that licensees would voluntarily implement BMPs similar to those commonly required
13 by most States and local jurisdictions. The staff also assumes that any impacts on wetlands or
14 other waters of the United States can be permitted through general permits rather than
15 individual permits, and that licensees would implement any mitigation called for in the permits.

16 The NRC staff typically evaluates effects on terrestrial resources in terms of habitats and broad
17 groupings of wildlife, as well as on the individual species and habitats that meet the definition of
18 “important” species and habitats outlined in RG 4.2 (NRC 2024-TN7081). Determining which
19 species and habitats potentially affected by a project meet the criteria for “important” is not
20 possible until a specific site and ROWs are identified. While the analysis in Section 3.5.2 is able
21 to consider the potential effects on many types of important species generically, it reserves
22 consideration of potential effects on federally listed threatened or endangered species until after
23 receipt of an application. Several available mapping tools and databases contain relevant
24 information about potential important species for sites anywhere in the United States. The U.S.
25 Fish and Wildlife Service (FWS) maintains online mapping tools and databases regarding the
26 potential occurrence of threatened, endangered, proposed, or candidate species and critical
27 habitats designated under the Federal ESA (16 U.S.C. §§ 1531 et seq.; TN1010). As of 2024,
28 the FWS mapping tool is termed Information for Planning and Consulting (IPaC). Users can
29 enter an action area (potentially affected area) polygon into IPaC which then generates a list of
30 potentially occurring listed species and habitats as well as other ecologically useful information.
31 Users can also use IPaC to automatically generate an official species letter that serves the
32 same function as the official species letters that agencies formerly used to request from the
33 FWS in writing. The FWS also continues to add automated features that help in assessing
34 potential impacts to certain listed species. Most States have Natural Heritage Programs with
35 databases containing known locations of species and habitats with Federal or State special
36 designations.

37 **3.5.2 Terrestrial Ecology Impacts**

38 For most new reactors, terrestrial ecology impacts related to loss, conversion, and
39 fragmentation of upland and wetland habitats and habitats for threatened or endangered
40 species would primarily take place during preconstruction, especially during site preparation
41 work such as clearing, grubbing, and grading. Potential impacts related to exposure of wildlife to
42 noise or the potential for collision of birds and bats with structures and transmission lines could
43 continue throughout the building period and extend into operations. Issues related to the
44 exposure of flora and fauna to cooling-tower drift, radiological releases, EMFs, or the risk of
45 avian electrocution on powerlines are more of a concern during operations.

1 3.5.2.1 *Environmental Consequences of Construction*

2 The NRC staff identified the following environmental issues for analysis for the building of a new
3 reactor:

- 4 • permanent and temporary loss, conversion, fragmentation, and degradation of habitats;
- 5 • permanent and temporary loss, conversion, and degradation of wetlands;
- 6 • effects of building noise on wildlife;
- 7 • effects of vehicular collisions on wildlife; and
- 8 • bird collisions with structures.

9 In addition to evaluating the issues noted above, the NRC staff addressed as a separate issue
10 any impacts on important species and habitats as defined for NRC environmental reviews in
11 RG 4.2 (NRC 2024-TN7081).

12 3.5.2.1.1 *Permanent and Temporary Loss, Conversion, Fragmentation, and Degradation of*
13 *Habitats*

14 Because of the assumptions in the PPE and SPE outlined in Section 3.5.1, building a new
15 reactor would not require permanent disturbance of more than 30 ac of land or temporary
16 disturbance of more than 20 ac of additional land, within a site no larger than 100 ac. The
17 assumptions also limit impacts on wetlands (addressed further in Section 3.5.2.1.2) and exclude
18 impacts on floodplains, riparian land, late-successional vegetation, land specifically designated
19 for conservation, or habitat potentially suitable for one or more Federal or State threatened or
20 endangered species. These assumptions are conservative regarding parameters related to
21 terrestrial ecology and recognize the high degree of variability in the sensitivity of various
22 habitats and species in various landscape settings. Habitat that is permanently lost to build a
23 reactor would no longer provide food or cover for terrestrial flora or fauna. However, loss of
24 50 ac of habitat not situated in sensitive settings is unlikely to noticeably reduce the overall
25 availability of such habitat for most species in the surrounding landscape. Many of the EISs for
26 new LWRs over the last 10 years have identified noticeable impacts on terrestrial habitats (e.g.,
27 those for Levy and Turkey Point; NRC 2012-TN1976 and NRC 2016-TN6434, respectively), but
28 these proposed reactors have each encompassed hundreds of acres of habitat loss,
29 substantially exceeding the PPE used in this GEIS. Much of the terrestrial habitat outside of
30 sensitive settings consists of current or former agricultural land, pasture or degraded range land,
31 forest monocultures, or ruderal habitat compromising the presence of invasive plant species
32 such as cheatgrass (*Bromus tectorum*), red brome (*Bromus rubens*), garlic mustard
33 (*Alliaria petiolata*), stiltgrass (*Microstegium vimineum*), or ailanthus (*Ailanthus altissima*). Losses
34 of such degraded habitat on new reactor sites are unlikely to noticeably limit resources for most
35 species in the surrounding landscape. Even for higher-quality habitats such as late-successional
36 forest, scrub, or prairie vegetation, the loss of only 50 ac is unlikely to result in a noticeable
37 decline in the ecological quality of the surrounding landscape.

38 However, the staff recognizes the typically long time horizon following past disturbance that is
39 necessary for late-successional vegetation to develop, particularly in arid regions where
40 vegetation recovery and succession are poorly understood (Abella 2010-TN6722; Engel and
41 Abella 2011-TN6721; McAuliffe 1988-TN6723). Thus, project-specific review of the plans would
42 be necessary to evaluate the value of late-successional habitats and the consequences of
43 losing the ecological services they provide. In many settings, the individualized review may

1 reveal that impacts from losses of those habitats might be minimal, but the staff considers
2 individualized review to be necessary. The assumptions in the PPE and SPE therefore exclude
3 late-successional vegetation from the onsite footprint of disturbance. Applicants would likely
4 select sites located in areas of relatively low habitat value.

5 Habitat conversion involves changing habitat to a different habitat type. Habitat conversion
6 typically involves a change from a more mature to a less mature vegetational stage (Abella
7 2010-TN6722) that may be then maintained indefinitely (e.g., from forest to shrub or grassland
8 within a ROW). Habitat conversion may also include the cutting of forest near new reactors to
9 open sightlines for security purposes. Unlike habitat loss, converted habitat continues to provide
10 food or cover for terrestrial flora or fauna, but food or cover that is different from and perhaps
11 inferior to that provided by the original habitat. When habitat changes, basic elements of an
12 ecosystem upon which a species relies for shelter, food, and reproduction may be altered or
13 may no longer be available. Habitat generalists may be able to adapt more readily to such
14 changes than habitat specialists. Habitat conversion may result in a shift in species dominance
15 and composition (Abella 2010-TN6722). Disturbance to convert habitats may also provide an
16 opportunity for increased establishment of invasive species. Habitat conversion over small
17 parcels is unlikely to noticeably limit resources for most species in the surrounding landscape.

18 Fragmentation of mature forests or rangeland habitats, and other high-quality terrestrial habitats
19 can be as harmful to wildlife as habitat losses, because it can limit wildlife movement and
20 migration and limit access to food, water, and other resources, as well as increase the amount
21 of edge habitat and invasive species resulting in habitat degradation and increased predation.
22 Fragmentation can result from new clearings or the establishment of new features such as
23 roads or fences that can interfere with the movement of wildlife. Fragmentation of natural
24 habitats by human activity is recognized as being a key contributor to biodiversity losses over
25 five continents (Haddad et al. 2015-TN6563). In North America, forest fragmentation has been
26 shown to have adverse effects on neotropical migratory birds (birds that nest in the tropics and
27 migrate north to breed in summer) through small forest-patch size, reduced proximity of
28 patches, more edge, and negative interactions with non-forest species, in addition to those from
29 habitat loss (Boulinier et al. 2001-TN6724, Critical Area Commission 2000-TN6564). Lynch
30 (1987-TN6726) described the negative insular effects of forest fragmentation on neotropical
31 migrants in terms of reduced patch size and isolation in the eastern United States. Yahner
32 (2000-TN6565) demonstrated that the probability of four neotropical migratory bird species
33 favoring forest interiors in the eastern United States declined sharply in forest tracts of less than
34 100 ha (247 ac). Initially, forest fragmentation triggers effects on a local scale, resulting in a
35 range retraction of populations to less fragmented parts of a region (Rolstad 2008-TN6725).
36 Similar effects have been shown to result from fragmentation of rangeland vegetation in the
37 Midwest and Western North America. Schoerbel (2003-TN6727) and Knick and Rotenberry
38 (1995-TN6728, 2002-TN6729) demonstrated the effects of shrub-steppe fragmentation on
39 songbirds requiring sagebrush (*Artemisia* spp.) habitat. Smith (2016-TN6730) demonstrated that
40 the fragmentation of 1 mi² of shrub-steppe habitat for agricultural development can reduce
41 sage-grouse (*Centrocercus urophasianus*) population persistence within an area 12 times that
42 size. The FWS highlighted similar implications of fragmentation by energy development to
43 sage-grouse, other sagebrush-dependent species, and the greater sagebrush ecosystem (FWS
44 2014-TN6731).

45 The assumptions in the PPE and SPE would effectively ensure minimization of losses and
46 fragmentation of late-successional vegetation. Technical guidance on minimization of loss and
47 fragmentation of habitats is available for most habitat types. Most call for locating new
48 infrastructure on the periphery of already-developed areas and clustering or sharing ROWs for

1 new infrastructure to avoid affecting late-successional habitats where possible (Critical Area
2 Commission 2000-TN6564; Paige and Ritter 1999-TN6802).

3 Clearing new offsite ROWs, even those under 100 ft in width, can fragment large blocks of
4 forest and rangeland, reduce the availability of habitat to forest-interior and area-sensitive
5 wildlife to an extent greater than suggested by the acreage of clearing. Rich et al. (1994-
6 TN6732) demonstrated that narrow forest-dividing corridors as small as 8 m (26 ft) can
7 substantially reduce the abundance of forest-interior neotropical migrant birds. Creating new
8 offsite ROWs with upright structures such as poles and towers increases perching habitat for
9 predators and can increase predation for populations of at-risk species in sagebrush
10 ecosystems (e.g., sage-grouse) (Manier et al. 2014-TN6746). However, the PPE limits the
11 length of new offsite ROWs not co-located with or adjacent to existing utilities or roads to less
12 than 1 mi, ensuring that the potential fragmentation of habitat and associated indirect risks to
13 wildlife (e.g., predation) would be minimal. The NRC staff anticipates (but does not assume, for
14 purposes of this analysis) that applicants would strive to locate new offsite ROWs whenever
15 possible in areas of low extant habitat value and sufficiently distant from any seasonal
16 habitats (e.g., nesting areas) to minimize predation risk.

17 The staff has determined that permanent or temporary loss, conversion, fragmentation, or
18 degradation of nonsensitive habitats is a Category 1 issue. The staff concludes that, as long as
19 the applicable assumptions in the PPE and SPE are met, impacts from building a new reactor
20 can be generically determined to be SMALL. The staff relied on the following PPE and SPE
21 values and assumptions to reach this conclusion:

- 22 • The permanent footprint of disturbance would include 30 ac or less of vegetated lands, and
23 the temporary footprint of disturbance would include no more than an additional 20 ac or
24 less of vegetated lands.
- 25 • Temporarily disturbed lands would be revegetated using regionally indigenous vegetation
26 once the lands are no longer needed to support building activities.
- 27 • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than
28 100 ft in width and total no more than 1 mi in length.
- 29 • The footprint of disturbance (permanent and temporary) would contain no ecologically
30 sensitive features such as floodplains, shorelines, riparian vegetation, late-successional
31 vegetation, land specifically designated for conservation, or habitat known to be potentially
32 suitable for one or more Federal or State threatened or endangered species.
- 33 • Total wetland impacts from use of the site and any offsite ROWs would be no more than
34 0.5 ac (see Section 3.5.2.1.2 below).
- 35 • Applicants would demonstrate an effort to minimize fragmentation of terrestrial habitats by
36 using existing ROWs, or widening existing ROWs, to the extent practicable.
- 37 • BMPs would be used for erosion, sediment control, and stormwater management.

38 *3.5.2.1.2 Permanent and Temporary Loss and Degradation of Wetlands*

39 The assumptions would ensure that there would be no more than 0.5 ac of wetlands within the
40 footprint of disturbance, and hence subject to filling, on the site and in the offsite ROWs (except
41 for building intake and discharge structures if needed). A project meeting the assumptions
42 would most likely not require an Individual Permit under Section 404 of the CWA; 33 U.S.C. §
43 1344-TN1019).

1 Wetlands for purposes of the analyses contained in this NR GEIS include the lands that meet
2 the criteria for delineation as wetlands as established in the USACE Wetlands Delineation
3 Manual (USACE 1987-TN2066) and applicable regional supplementary wetland delineation
4 guidance, regardless of whether they meet other criteria required for jurisdiction under the CWA
5 (33 CFR Part 328-TN1683). Many wetlands not meeting the criteria for jurisdiction under the
6 CWA, sometimes termed “isolated wetlands” or “non-jurisdictional wetlands,” can still provide
7 beneficial ecological services such as contributing to groundwater recharge, attenuating
8 overland surface runoff thereby reducing flooding potential, and providing specialized habitat for
9 many wetland-dependent wildlife species. Many depressional features such as vernal pools,
10 prairie potholes, Carolina bays, and playa lakes play key roles in flood control and groundwater
11 recharge, and provide specialized habitat required by many wildlife species that are declining
12 rapidly in many regions, yet are isolated from navigable waterways and surface tributary
13 systems and hence not under the jurisdiction of the CWA. Because the functions and values of
14 wetlands are not dependent on whether the wetland is under CWA jurisdiction, the staff
15 established the 0.5 ac assumed limit on wetland disturbance to be inclusive of impacts on any
16 wetlands regardless of jurisdictional status under the CWA.

17 The 0.5 ac of wetlands might be physically lost or disturbed by site preparation work, commonly
18 referred to as “discharge of dredged or fill material,” or by other types of disturbances. The
19 hydrology of wetlands, and hence biota that rely on the hydrological properties of wetlands, can
20 also be altered by changes in landscape drainage patterns and overland runoff. Wetlands are
21 also subject to sedimentation from upgradient soil disturbances. Wetland losses and
22 disturbances cause the loss or reduction of multiple hydrological functions such as groundwater
23 recharge and discharge, flood flow abatement, and shoreline stabilization; ecological functions
24 such as fish and wildlife habitat, production export, and providing specialized habitat for many
25 threatened or endangered species; and societal values such as recreation and aesthetics
26 (USACE 1999-TN1793).

27 Excavations to build a reactor can cause temporary drawdowns of the water table, thereby
28 influencing the hydrology and hence the water levels, hydroperiod (number and timing of days
29 per year that soils remain saturated or covered with water), spatial extent and function of nearby
30 wetlands. Even for large reactors, however, analyses in recent EISs have indicated that some
31 hydrological effects on wetlands might be brief and localized. A conservative analysis of the
32 drawdown effects of excavating 56 ft deep to build a large pond component for the proposed
33 Bell Bend nuclear power plant in Pennsylvania, and pumping groundwater at a rate of 235 to
34 310 gpm, estimated that the effects of water table drawdown on nearby wetlands would last only
35 as much as 24 months and not extend more than about 1,200 ft from the excavation (NRC and
36 USACE 2016-TN6562). Analysis of water table drawdowns during excavations for the proposed
37 Levy Units 1 and 2 in a landscape in north-central Florida containing extensive wetlands
38 concluded that the drawdown effects on adjoining wetlands would be temporary and within the
39 range of expected seasonal water table fluctuations to which the wetlands are adapted
40 (NRC 2012-TN1976). Both analyses assumed, however, that nearby wetlands would be
41 monitored over the period of excavation and action would be taken to restore water levels as
42 necessary. Based on these analyses, for a new reactor bounded by the assumptions for
43 groundwater withdrawals and dewatering in the SPE (50 gpm with negligible effect on
44 groundwater levels at the site boundary), onsite wetlands with a groundwater connection could
45 be affected, but similar wetlands offsite would not be affected. Temporary adverse impacts on
46 onsite wetlands can result if groundwater dewatering causes changes in water levels or
47 hydroperiod that exceed historical annual or seasonal fluctuations. This applies to all onsite
48 wetlands with a groundwater connection, and the effects may be accentuated in wetlands that
49 only have a surface water connection. The staff expects that applicants relying on the generic

1 analysis would demonstrate that the assumption regarding the influence of groundwater
2 withdrawal for dewatering on connected wetlands (changes in wetland water levels and
3 hydroperiod are within historical annual or seasonal fluctuations) in the SPE are met. If this
4 assumption is not met, then project-specific analysis would be necessary to demonstrate that
5 impacts are minimal.

6 Wetlands may also be affected by habitat conversion. One of the most notable types of habitat
7 changes in wetland water levels and hydroperiod within historical annual or seasonal fluctuation
8 conversions that may occur in association with new reactors is forest clearing for the purpose of
9 spanning wetlands with transmission lines (EPA 2018-TN6747). The removal of vertical habitat
10 structure reduces the diversity of species and creates corridors that fragment forests (addressed
11 in previous section) (EPA 1994-TN6748). Canopy and subcanopy trees are typically removed,
12 eliminating nesting habitat for forest-interior bird species. Extant shade-tolerant forest
13 understory vegetation may change to herbaceous and/or shrub species adapted to full-sun
14 conditions. Amphibian breeding pools may become unsuitable because of increased solar
15 exposure and change to an unsuitable temperature regime. The amount of edge habitat would
16 increase, thereby increasing the risk of invasive species establishment and habitat degradation.
17 Ultimately, early successional plants and wildlife could become established in the converted
18 area, which subsequently could be maintained over the long term as an emergent or
19 scrub-shrub wetland in order to avoid vegetation interference with overhead transmission lines.
20 There would be a net reduction in wetland functions and values due to conversion of forested
21 wetland to emergent or scrub-shrub wetland (DOE 2019-TN6749; NextEra Energy 2020-
22 TN6750). However, the 0.5 ac limit on wetland disturbance renders minimal the potential effects
23 of wetland habitat conversion, degradation, or fragmentation.

24 The staff recognizes that up to 0.5 ac of wetlands can be disturbed by building utility lines in
25 NWP 12 under the CWA, which the USACE recognizes as not having a significant impact on
26 waters of the United States (33 CFR 330.1(b); TN4318). The staff assumes that the applicant
27 would implement any mitigation required by the USACE under the CWA or required by State
28 agencies that have similar wetland regulatory authority. Even if a project may not require a
29 permit under the CWA or State wetland protection regulations, the staff expects that applicants
30 relying on the generic analysis would provide a wetland delineation demonstrating that
31 assumptions regarding wetlands in the PPE are met. The PPE includes assumptions, based on
32 information contained in most recent new reactor EISs, that applicants would be required by
33 State or local governments to implement BMPs as mitigation to minimize sedimentation and
34 erosion of nearby wetlands. Additionally, because hydrology is one of the most important factors
35 in the establishment and maintenance of wetlands and wetland processes (SFWMD 1995-
36 TN6799), the PPE includes an assumption that licensees relying on the generic analysis would
37 demonstrate that the assumption regarding the influence of groundwater withdrawal for
38 dewatering on connected wetlands in the SPE (changes in wetland water levels and
39 hydroperiod are within historical annual or seasonal fluctuations) is met. If this assumption is not
40 met, then project-specific analysis would be necessary to demonstrate that impacts would be
41 minimal. The staff developed this assumption in the PPE based on experience from past
42 reviews supporting EISs for proposed new reactors in Levy County, Florida (NUREG-1941;
43 NRC 2012-TN1976) and Berwick, Pennsylvania (NUREG 2179; NRC and USACE 2016-
44 TN6562).

45 The staff has determined that permanent or temporary loss or degradation of wetlands during
46 building of a new reactor is a Category 1 issue. The staff concludes that as long as the relevant
47 assumptions in the PPE and SPE are met, the impacts from building a new reactor can be

1 generically determined to be SMALL. The staff relied on the following PPE and SPE values and
2 assumptions to reach this conclusion:

- 3 • Applicant would provide a delineation of potentially impacted wetlands, including wetlands
4 not under CWA jurisdiction.
- 5 • Total wetland impacts from use of the site and any offsite ROWs would be no more than
6 0.5 ac.
- 7 • If activities regulated under the CWA are performed, those activities would receive approval
8 under one or more NWP (33 CFR Part 330) or other general permits recognized by the
9 USACE.
- 10 • Temporary groundwater withdrawals for excavation or foundation dewatering would not
11 exceed a long-term rate of 50 gpm.
- 12 • Applicants would be able to demonstrate that the temporary groundwater withdrawals would
13 not substantially alter the hydrology of wetlands connected to the same groundwater
14 resource.
- 15 • Any required State or local permits for wetland impacts would be obtained.
- 16 • Any mitigation measures indicated in the NWPs or other permits would be implemented.
- 17 • BMPs would be used for erosion, sediment control, and stormwater management.

18 3.5.2.1.3 Effects of Building Noise on Wildlife

19 Activities to build reactor facilities are usually performed in a series of steps or phases, and
20 noise associated with different phases can vary greatly depending on the type of equipment
21 used. Average maximum noise levels of typical building equipment 50 ft from the source may
22 range from about 73 to 101 dBA for non-impact heavy equipment (earthmoving equipment such
23 as bulldozers), 79 to 110 dBA for impact equipment (jackhammers, pile drivers, etc.), and 68 to
24 88 dBA for stationary equipment (pumps, etc.) (WSDOT 2017-TN5313), but an overall noise
25 level of approximately 85 dBA at 50 ft from the source is typical (DOT 2017-TN5383). Noise
26 from operating construction equipment can startle and interfere with the behavior and
27 movement of wildlife. The effects can be exacerbated by the fact that some building noise
28 occurs episodically rather than continuously over extended periods, and hence wildlife may be
29 less capable of habituating to it (Shannon et al. 2016-TN6566). A comprehensive literature
30 review of wildlife responses to anthropogenic noise indicated that some species adversely
31 respond to noise levels as low as 40 dBA, but 20 percent of the literature documented
32 responses only above 50 dBA (Shannon et al. 2016-TN6566). Restrictions have been placed on
33 noise at similar levels within the habitat of sensitive wildlife species. For example, the
34 U.S. Department of Energy (DOE) considers an increase in noise levels greater than 6 dBA
35 above ambient to constitute a disturbance to the Mexican spotted owl (*Strix occidentalis lucida*)
36 on the Los Alamos Site in New Mexico (Hathcock et al. 2017-TN6789).

37 The assumptions in the PPE and SPE include no noise generation greater than 85 dBA at a
38 point 50 ft from the source. However, noise levels decrease by approximately 6 dBA per
39 doubling of distance over hard site conditions (i.e., substrate such as concrete or open water) in
40 accordance with the inverse square law (DOT 2017-TN6567), and by an additional 1.5 dBA
41 decrease if soft site conditions (e.g., unpacked earth) are present (WSDOT 2017-TN5313).
42 Therefore, typical building noise of 85 dBA at a distance of only 50 ft from the source may
43 diminish to only around 50 dBA at about 1,200 ft from the source (assuming soft ground
44 conditions). This noise level would not generally disturb most wildlife. Furthermore, this value is

1 conservative because it likely overestimates the actual noise level because the calculation does
2 not take into account additional noise attenuation by vegetation and topography (WSDOT 2017-
3 TN5313), which are difficult to consider without project-specific analysis.

4 The staff therefore expects that potential noise impacts would extend over a sufficiently small
5 part of the landscape and that any effects on wildlife would be minor and thus be a Category 1
6 issue. The staff concludes that as long as the assumption in the PPE regarding a maximum
7 noise generation of 85 dBA 50 ft from the source is met, the impacts can be generically
8 determined to be SMALL. Effects on wildlife from building noise over 85 dBA would extend over
9 a greater distance and area and thus require project-specific evaluation. The staff relied on the
10 following PPE and SPE values and assumptions to reach this conclusion:

- 11 • Noise generation would not exceed 85 dBA 50 ft from the source.

12 *3.5.2.1.4 Effects of Vehicular Collisions on Wildlife*

13 Wildlife can also be killed or injured through collisions with vehicles, although the low number of
14 construction workers needed to build a reactor of a size fitting the assumptions in the PPE and
15 SPE suggests that vehicular usage, and hence the potential for collisions, would be minimal.
16 While roadkill may increase somewhat during the building period, except for special situations
17 (e.g., ponds and wetlands crossed by roads where large numbers of migrating amphibians
18 would be susceptible), traffic mortality rates rarely limit population size (Forman and Alexander
19 1998-TN2250). The potential for significant vehicular collisions with wildlife is limited by the
20 assumptions in the PPE and SPE regarding site size, size of the footprint of disturbance, and by
21 limitations on traffic growth, as evidenced by traffic LOSs on roads near the site.

22 Federal and State wildlife conservation agencies commonly suggest practices to reduce the
23 potential for vehicular collisions with wildlife species regarded as regionally sensitive or
24 desirable. For example, an EIS prepared by the NRC (NRC 2013-TN6436 | NUREG-2105,
25 Fermi Unit 3 COL EIS, p. 4-37 |) acknowledged the potential for injury and mortality of eastern
26 fox snakes, a rare (and State-listed) species known to occur near the site, related to
27 construction equipment while building a proposed reactor, but it also concluded that readily
28 implemented mitigation measures suggested by the State could prevent noticeable impacts on
29 the regional population of that species. Some specific mitigation measures proposed included
30 signage along roads, worker education, and reduced speed limits. Another NRC EIS (NRC
31 2016-TN6434) recognized the potential for mortality of American crocodiles (a federally listed
32 threatened species known to inhabit the site and surrounding landscape) by construction vehicle
33 collisions, but concluded that easily implemented mitigation measures recommended by the
34 FWS, such as signage and speed limits, could prevent substantial population effects.

35 The staff has therefore determined that traffic effects on wildlife are a Category 1 issue. The
36 staff concludes that as long as the project fits within the PPE regarding site size (no more than
37 100 ac, with a permanent building footprint of no more than 30 ac and a temporary footprint of
38 no more than 20 ac) and site employment, the impacts can be generically determined to be
39 SMALL. The staff relied on the following PPE and SPE values and assumptions to reach this
40 conclusion:

- 41 • The site size would be 100 ac or less.
- 42 • The permanent footprint of disturbance would include 30 ac or less of vegetated lands, and
43 the temporary footprint of disturbance would include no more than an additional 20 ac or
44 less of vegetated lands.

- 1 • There would be no decreases in the LOS designation for affected roadways.
- 2 • The licensee would communicate with Federal and State wildlife agencies and implement
- 3 mitigation actions recommended by those agencies to reduce potential for vehicular injury to
- 4 wildlife.

5 Mitigation measures that Federal and State wildlife agencies might recommend include the use
6 of signage, worker education, reduced speed limits where construction equipment crosses
7 habitat potentially containing regionally rare or declining wildlife, and discussion of these and
8 other possible mitigation measures with relevant Federal, State, and local conservation offices.

9 *3.5.2.1.5 Bird Collisions and Injury from Structures and Transmission Lines*

10 Birds and other flying wildlife such as bats can be injured and killed when colliding with tall
11 structures such as buildings, towers, and transmission lines. The assumptions in the PPE and
12 SPE are that the tallest building or structure height would be no more than 50 ft, although the
13 PPE and SPE allow for taller meteorological or communications towers or mechanical draft
14 cooling towers. Additionally, during construction, cranes that are taller than the structures they
15 are being used to build may be in place temporarily. It is possible that some birds or bats could
16 be injured or killed by flying into and colliding with buildings, towers, transmission lines, or
17 cranes. In the License Renewal GEIS, the NRC reviewed the scientific literature about bird
18 collisions with buildings and indicated that collisions with buildings and windows account for the
19 vast majority of annual avian collision mortality in the United States (NRC 2024-TN10161).
20 Researchers have estimated that the annual mortality rate for each building 1 to 3 stories tall
21 (approximately 42 ft in height) is about 2 birds and about 16 birds for each building 4 to 11
22 stories tall (approximately 56 to 154 ft in height) (Loss et al. 2014-TN6568). The PPE assumes,
23 based on the staff's experience from recent new reactor EISs and on the scientific literature
24 cited above, that most buildings and structures developed on smaller new reactor sites would be
25 less than 50 ft in height, and only a few would be over 50 ft in height (mechanical draft cooling
26 towers). The low per-building mortality rate for buildings 1 to 3 stories tall plus the 100 ac bound
27 on the size of the site, which limits and localizes the number of 50 ft or less tall structures,
28 render negligible the potential for building collision injury and mortality. Although the mortality
29 rate for each mechanical draft cooling tower is expected to be somewhat higher because of its
30 greater height (typically 50–100 ft), in the License Renewal GEIS the NRC considered avian
31 collision mortality from mechanical draft cooling towers to be negligible and therefore did not
32 address the subject (NRC 2024-TN10161). The staff has determined this conclusion to also be
33 appropriate for mechanical draft cooling towers on new reactor sites.

34 The License Renewal GEIS reviewed the scientific literature about bird collisions with
35 structures, including nuclear power plant structures, transmission lines, and communication
36 towers, and evaluated the potential for bird collisions with several operating large LWRs
37 containing natural draft cooling towers over 400 ft in height and concluded that the effects on
38 bird populations were minimal (NRC 2024-TN10161). The GEIS found the overall effect from
39 operating these plants constitutes a small fraction of annual avian collision mortality from all
40 sources nationwide. The onsite plant structures and communication towers would all be
41 clustered within the 100 ac site fitting the PPE. For new reactors that meet the assumptions
42 listed below, the only new transmission lines would likely be those needed to connect the plant
43 to the regional power distribution system. The assumptions in the PPE and SPE limit the length
44 of new transmission lines and other offsite linear facilities to less than 1 mi of new ROW not
45 adjoining existing utilities or roads, and they limit the height of transmission structures (poles or
46 towers) to no more than 100 ft. The PPE allows for additional co-located transmission line

1 ROWs, but co-location would not introduce the potential for collisions to new areas of the
2 landscape. The transmission lines at such new reactor sites would constitute both a very low
3 fraction of transmission lines nationwide as well as related collision mortality. Loss et al.
4 (TN9396) estimated median annual collision rate of about 29.6 birds/km (47.7 birds/mi) of
5 powerline using strict study inclusion criteria and 23.2 birds/km (37.4 birds/mi) relaxed study
6 inclusion criteria.

7 A new reactor facility within the bounds of the assumptions would have only one or a few towers
8 or other tall structures clustered on a site of less than 100 ac. METs could be about 197 ft
9 (60 m) aboveground level (the prescribed height at which wind speed and direction should be
10 measured), and could be guyed (NRC 2007-TN278). The PPE allows for a single MET of any
11 height on a site, with non-red, flashing lights if lit. METs (Kerlinger et al. 2012-TN4401), as well
12 as other types of towers such as communication towers (Longcore et al. 2008-TN4398,
13 Longcore et al. 2013-TN4399), have been implicated in avian collision mortality of
14 predominantly neotropical night-migrating songbirds being affected (Longcore et al. 2013-
15 TN4399). Estimated rates of avian fatality from collision with ten 50 m (164 ft) and eight 60 m
16 (197 ft) temporary METs supported by guy wires near wind turbines in central California were
17 about seven total birds per tower per year, including night-migrating songbirds (Kerlinger et al.
18 2012-TN4401). Collision mortality increases with increasing tower height; the highest rate of
19 collision mortality is associated with towers taller than 1,000 ft that use guy wires, and the use of
20 continuously (as opposed to intermittently) illuminated lights (Longcore et al. 2008-TN4398;
21 Gehring et al. 2011-TN6581). METs at new reactor sites, regardless of whether they are guyed
22 or whether or how they may be lit, would cause only negligible avian collision mortality due to
23 their relatively low height. It is also possible that communication towers could be present on new
24 reactor sites. Any communication towers would make up only a very minute fraction of all such
25 towers nationwide and of the collision mortality posed by such towers noted above. The 100 ac
26 maximum size of the site assumed in the PPE limits the possible number of communication
27 towers.

28 Any effects from buildings, towers, and transmission lines would be localized and not likely to
29 noticeably contribute to bird mortality in the surrounding landscape. The staff has therefore
30 determined that bird collisions with structures and transmission lines during building are a
31 Category 1 issue. The staff concludes that as long as the applicable assumptions in the PPE
32 and SPE regarding site size and building and structure height are met, the impacts can be
33 generically determined to be SMALL. The staff relied on the following PPE and SPE values and
34 assumptions to reach this conclusion:

- 35 • The site size would be 100 ac or less.
- 36 • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than
37 100 ft in width and total no more than 1 mi in length.
- 38 • No transmission line structures (poles or towers) would be more than 100 ft in height.
- 39 • Licensees would implement common mitigation measures such as those provided by the
40 American Bird Conservancy (ABC 2015-TN6763) for buildings, by FWS (2013-TN6764) for
41 towers, and by the Avian Power Line Interaction Committee (APLIC) for transmission lines
42 (APLIC 2012-TN6779).

43 Examples of possible mitigation measures include using building designs that use less glass,
44 screens and shutters that partly obscure glass, and two-dimensional patterns that birds perceive
45 as barriers (ABC 2015-TN6763); using unguyed lattice or monopole structures where possible,
46 keeping towers unlit if the Federal Aviation Administration regulations permit but otherwise using

1 flashing (as opposed to steady) lights (FWS 2013-TN6764); marking devices to enhance the
2 visibility of existing power lines; and considering migratory patterns and high-use areas when
3 planning new power lines (APLIC 2012-TN6779).

4 *3.5.2.1.6 Important Species and Habitats*

5 Species and habitats meeting the NRC criteria (NRC 2024-TN7081) for a given site can only be
6 determined once an application is received that identifies the site boundaries. Because of
7 differing regulations and sensitivities to impacts, two separate issues are analyzed below
8 regarding important species and habitats: (1) resources regulated under the ESA (16 U.S.C.
9 §§ 1531 et seq.; TN1010), and (2) other important species and habitats.

10 Resources Regulated under the Endangered Species Act of 1973

11 The FWS has developed online databases and mapping tools that identify threatened,
12 endangered, proposed, and candidate species under the ESA, as well as critical habitats
13 designated and proposed under the Act. Because these federally regulated resources occur in
14 the same setting and are subject to the same types of impacts as those considered in
15 Sections 3.5.2.1.1 through 3.5.2.1.5, the limitations placed upon the extent and intensity of
16 ecological impacts by meeting the assumptions in the PPE and SPE would likewise limit the
17 potential for impacts on these resources. However, the staff would need to consult individually
18 with the FWS under ESA Section 7 regarding the potential effects of each specific licensing
19 action. Furthermore, the criteria for listing species under the ESA are based on the potential for
20 the most severe of potential ecological impacts: extinction of species, subspecies, or distinct
21 population segments. Species that have experienced previous impacts so severe that they are
22 now, or could imminently become, in danger of extinction may also be substantially more
23 sensitive to impacts that might only pose minimal threat to other species. The staff has therefore
24 determined that building impacts on resources regulated under the ESA is a Category 2 issue.
25 Because of their potential for future regulation over the course of a licensing action, the
26 Category 2 designation extends also to proposed and candidate species and critical habitat
27 proposed under the Act. Even if the assumptions in the PPE and SPE that are referenced in
28 Section 3.5.1 are met, the NRC staff is unable to determine the significance of potential impacts
29 without consideration of project-specific factors, including the specific species and habitats
30 affected and the types of ecological changes potentially resulting from each specific licensing
31 action. Furthermore, completing the required consultation requires individualized action by the
32 staff for each application.

33 Other Important Species and Habitats

34 Most States maintain natural heritage databases that identify known occurrences of species and
35 habitats receiving various categories of State regulation or recognition. Many species and
36 habitats that do not display the potential for extinction necessary for regulation under the ESA
37 are still recognized by States because of declining numbers within State boundaries. However,
38 extirpation from a State is not as severe an impact as range-wide extinction. Regarding other
39 types of important species and habitats, most sites containing undeveloped land may support
40 commercially or recreationally valuable species such as whitetail deer (*Odocoileus virginianus*),
41 wild turkey (*Meleagris gallopavo*), and ring-necked pheasant (*Phasianus colchicus*), and
42 nuisance or invasive species such as Canada thistle (*Cirsium arvense*), johnsongrass
43 (*Sorghum halepense*), cheatgrass (*Bromus tectorum*), European starlings (*Sturnus vulgaris*),
44 Burmese pythons (*Python bivittatus*), and nutria (*Myocastor coypus*). Research of and
45 communication with State and local agencies, private conservation organizations, and other

1 stakeholders would be necessary to determine other important species and habitats potentially
2 present on a site, such as species with monitoring requirements, State threatened or
3 endangered species, other State status species, protected habitats, habitats with high priority
4 for protection, or other habitats of interest such as nesting or nursery grounds.

5 The analyses presented above regarding impacts on terrestrial habitats and wildlife from
6 specific terrestrial ecological issues suggest that the potential impacts on many important
7 species and habitats (NRC 2024-TN7081) from building of a new reactor meeting the PPE
8 and SPE assumptions discussed in Section 3.5.1 would likely be minimal regardless of site
9 location and the important species specifically present on a given site. The assumptions in
10 the PPE and SPE limit the potential for adverse impacts, especially limitations on the size of
11 the footprint of disturbance and the assumed absence of sensitive habitat types
12 potentially containing rare species within the footprint.

13 The staff has therefore determined that building impacts on important species and habitats other
14 than those regulated under the ESA is a Category 1 issue. The staff concludes that as long as
15 the assumptions regarding the size and habitat quality within the building footprint, wetlands,
16 building height, noise generation, and employment in the PPE and SPE are met, the impacts
17 can be generically determined to be SMALL. The staff relied on the following PPE and SPE
18 values and assumptions to reach this conclusion:

- 19 • Applicants would communicate with State natural resource or conservation agencies
20 regarding wildlife and plants and implement mitigation recommendation of those agencies.

21 3.5.2.2 *Environmental Consequences of Operation*

22 The NRC staff identified the following environmental issues for analysis for operation of a new
23 reactor:

- 24 • permanent and temporary loss or disturbance of habitats;
- 25 • effects of operational noise and traffic on wildlife;
- 26 • exposure of terrestrial organisms to radionuclides;
- 27 • cooling-tower operational impacts on vegetation;
- 28 • bird injury and mortality related to collisions with structures and transmission lines;
- 29 • bird electrocutions by transmission lines;
- 30 • water use conflicts with terrestrial resources;
- 31 • effects of transmission line ROW management on terrestrial resources; and
- 32 • effects of EMFs on flora and fauna.

33 In addition to evaluating the issues noted above, the NRC staff addressed as a separate issue
34 any impacts on important species and habitats as defined for NRC environmental reviews (NRC
35 2024-TN7081).

36 3.5.2.2.1 *Permanent and Temporary Loss or Disturbance of Habitats*

37 Substantial losses or changes in habitats on new reactor sites are unlikely during operations,
38 although small areas of vegetated land might have to be disturbed to maintain, upgrade, or
39 expand structures or add support structures. In reviewing the environmental effects of operating
40 large LWRs, the NRC staff explained that most unpaved lands in the developed areas on
41 nuclear sites are maintained as modified habitats with lawns and other landscaped areas or
42 may contain early successional habitats (NRC 2024-TN10161). Even if other habitats are
43 present in developed areas, they can be expected to be small, fragmented, and heavily

1 influenced by noise and human activity associated with reactor operations. Based on the
2 License Renewal GEIS (NRC 2024-TN10161), the NRC staff expects that there would be no
3 wetlands in such areas, or that any wetland disturbances (except for intake and discharge
4 structures [Section 3.6.2.1]) would not cause total wetland impacts for the project to exceed the
5 PPE value of 0.5 ac (Section 3.5.2.1.2). Wetland impacts for projects within the PPE value of
6 0.5 ac would most likely not require an Individual Permit under CWA Section 404 (33 U.S.C. §
7 1344-TN1019) and may result from “discharge of dredged or fill material” or other types of
8 disturbances. The License Renewal GEIS explains that habitats in such settings are generally
9 tolerant of disturbance (NRC 2024-TN10161), as are associated populations of birds, mammals,
10 and lizards (Samia et al. 2015-TN6790). Small areas of such habitats could be lost or disturbed
11 as facilities on the site are refurbished, upgraded, or expanded, although the ecological effects
12 of any losses on the surrounding landscape are likely to be minimal. Not only would the effects
13 be minimized because of the limited spatial extent of facilities meeting the PPE, but also
14 because of the previously altered character of the affected areas.

15 The staff has determined that this is a Category 1 issue. The staff concludes that the impacts
16 can be generically determined to be SMALL. The staff relied on the following PPE and SPE
17 values and assumptions to reach this conclusion:

- 18 • Temporarily disturbed lands would be revegetated using regionally indigenous vegetation
19 once the lands are no longer needed to support building activities.
- 20 • The total wetland loss from site disturbance over the operational life of the plant would be no
21 more than 0.5 ac.
- 22 • Any State or local permits for wetland impacts would be obtained.
- 23 • Any mitigation measures indicated in the NWP or other wetland permits would be
24 implemented.
- 25 • BMPs would be used for erosion, sediment control, and stormwater management.

26 *3.5.2.2.2 Effects of Operational Noise and Vehicular Collisions on Wildlife*

27 The effects of operational noise and traffic on wildlife would be as described above for building
28 in Sections 3.5.2.1.3 and 3.5.2.1.4, respectively, but the effects would occur over an extended
29 period of time covering the operational lifespan of the reactor. Operational noise would tend to
30 be lower in intensity and steadier than building noise, and wildlife may therefore be better able
31 to habituate to and tolerate the noise. As for during construction, the potential for injury or
32 mortality of wildlife caused by vehicular collisions would be limited by the low employment at the
33 reactor established in the PPE. Furthermore, it is unlikely that new roads would be constructed
34 through substantial blocks of natural habitat thereby exposing additional wildlife to noise or
35 collision threats during operations. The staff has therefore determined that operational noise
36 and traffic are Category 1 issues. The staff concludes that as long as the applicable
37 assumptions in the PPE and SPE regarding noise generation and employment are met, the
38 impacts can be generically determined to be SMALL. The staff relied on the following PPE and
39 SPE values and assumptions to reach this conclusion:

- 40 • Noise generation would not exceed 85 dBA 50 ft from the source.
- 41 • There would be no decreases in the LOS designation for affected roadways.
- 42 • The licensee would communicate with Federal and State wildlife agencies and implement
43 mitigation actions recommended by those agencies to reduce potential for vehicular injury to
44 wildlife.

1 3.5.2.2.3 *Exposure of Terrestrial Organisms to Radionuclides*

2 The NRC staff recognizes that small amounts of radioactive particulates can be vented to the
3 exterior environment during operation of LWRs and evaluated the potential effects of those
4 releases on terrestrial ecological receptors in the License Renewal GEIS (NRC 2024-TN10161).
5 Section 3.8.1.2.2 of this GEIS concludes that the impact of routine radiological releases from
6 past and current operations on terrestrial biota would be SMALL. To support that conclusion,
7 Table 3-6 (in Section 3.8.1 in this GEIS) presents radiological exposure estimates for two
8 mammal and two bird species modeled using NRC Dose code, as presented in 15 EISs for
9 proposed new LWRs published between 2006 and 2019. All estimates were substantially lower
10 than exposure levels considered protective of terrestrial animal populations by the International
11 Atomic Energy Agency (IAEA).

12 In the License Renewal GEIS (NRC 2024-TN10161), the staff also used the RESRAD-BIOTA
13 dose evaluation model developed by DOE (DOE 2004-TN6460) to calculate estimated dose
14 rates to terrestrial biota receptors using REMP reports submitted by licensees for 15 operating
15 LWRs in the United States. RESRAD-BIOTA accounts for bioaccumulation of radionuclides in
16 the tissues of biological organisms and biomagnification, whereby radionuclides become
17 concentrated at higher levels in organisms occupying higher positions in the food chain. The
18 staff calculated estimated doses for three terrestrial ecological receptors: riparian animals
19 (animals estimated to spend approximately half their time in aquatic environments and half in
20 terrestrial environments), terrestrial animals, and terrestrial plants. None of the estimated doses
21 exceeded levels recognized by DOE as being protective of riparian or terrestrial animals
22 (0.1 rad/d [0.001 Gy/d]) or terrestrial plants (1.0 rad/d [0.01 Gy/d]) (DOE 2002-TN4551).

- 23 • While many new reactors may use fuels containing different compositions of radionuclides
24 than the LWRs considered in the analyses presented above, a reactor meeting the PPE for
25 Radiological Environmental Hazards in Appendix G would not be likely to result in greater
26 releases of radioactivity. The staff has determined that this is a Category 1 issue. The staff
27 concludes that as long as the assumptions in the PPE underlying the analysis in Section 3.8
28 are met, the impacts can be generically determined to be SMALL without mitigation. The
29 staff relied on the following PPE and SPE values and assumptions to reach this conclusion:
- 30 • Applicants would demonstrate in their application that any radiological nonhuman biota
31 doses would be below IAEA (1992-TN712) and National Council on Radiation Protection
32 and Measurements (NCRP) (1991-TN729) guidelines.

33 3.5.2.2.4 *Cooling-Tower Operational Impacts on Vegetation*

34 The PPE assumes that a new reactor would use only fresh makeup water that has a salinity of
35 under 1 ppt for operation of any cooling towers. The staff has found in past new reactor EISs
36 that salt drift modeling sometimes indicates potentially significant impacts on vegetation when
37 brackish water is used as makeup water (NRC 2012-TN1976, NRC 2016-TN6434, NRC 2016-
38 TN6840). The PPE also assumes that any cooling towers would be the mechanical draft type
39 rather than natural draft cooling towers and under 100 ft in height. While mechanical draft
40 cooling towers are typically under 100 ft in height, natural draft cooling towers can be more than
41 400 ft in height. Natural draft towers release drift higher into the atmosphere and therefore can
42 spread drift farther across the landscape than can mechanical draft towers. Drift from
43 mechanical draft towers tends to affect only vegetation in close proximity to the towers, which is
44 mostly limited to disturbed lawns and other successional vegetation typical of existing
45 industrially developed areas. The PPE also assumes that any cooling towers would be equipped
46 with drift eliminators to minimize the amount of drift.

1 The NRC staff recognizes that salt deposition rates between 1 and 2 kg/ha/mo are generally not
2 damaging to plants, while rates approaching or exceeding 10 kg/ha/mo in any month during the
3 growing season could cause leaf damage in many species (NRC 2000-TN614). Even
4 10 kg/ha/mo is a conservative estimate representing documented acute injury only of the most
5 sensitive of crop and native vegetation plant species (NRC 1996-TN288). It is reasonable to
6 expect that substantially higher deposition rates would be needed to cause noticeable injury to
7 vegetation consisting of a mixture of plant species of differing sensitivities.

8 Estimates for TDS (total dissolved solids, referred to hereafter as “salt”) deposition rates were
9 less than 10 kg/ha/mo for several recently completed new reactor EISs where mechanical draft
10 cooling towers were to be operated using fresh makeup water. Estimates for maximum salt drift
11 deposition from operation of four mechanical draft cooling towers serving the proposed
12 Comanche Peak Units 3 and 4 in inland Texas were approximately 3.49 kg/ha/mo, at a point
13 100 m (328 ft) north of the towers (NRC 2011-TN6437). Estimates for maximum salt drift
14 deposition from operation of four mechanical draft cooling towers serving the proposed William
15 States Lee Units 1 and 2 in western South Carolina were 0.0103 kg/ha/mo, at a point 200 m
16 (656 ft) north of the towers (NRC 2013-TN6435). The estimates for building SMRs of
17 unspecified technology at the Clinch River site in Oak Ridge, Tennessee, were as high as
18 112.7 kg/ha/mo at a point approximately 100 m (328 ft) from the towers but were less than
19 10 kg/ha/mo at 300 m (984 ft) from the towers. Even though the Clinch River data suggest
20 possible vegetation damage in close proximity to operating mechanical draft cooling towers,
21 such close-in areas to a nuclear power plant are usually industrial in character and any
22 vegetation present would likely be ruderal or highly disturbed vegetation of low ecological value.
23 The low estimated drift rate for areas 1,000 ft from the towers suggests that the potential effects
24 of vegetation damage on the surrounding landscape would be low.

25 There is less of a record to draw from for cooling towers operated using brackish water or
26 seawater makeup sources. The maximum deposition for the proposed Turkey Point Units 6 and
27 7, which were modeled using mechanical draft cooling towers with makeup water as salty as
28 seawater, was estimated to be as high a 105 kg/ha/mo close to the towers (NRC 2016-TN6434)
29 but to diminish rapidly with distance to under 10 kg/ha/mo within 1 mi from the towers
30 (NRC 2016-TN6434). Although the Turkey Point EIS concluded that the effects would be
31 minimal, the proposed site was situated on an island with an existing nuclear plant where the
32 nearest high-quality natural habitat was nearly 1 mi distant (NRC 2016-TN6434). Had
33 high-quality natural habitats been present close to those reactors, habitat function could have
34 been noticeably compromised due to leaf injury. The maximum deposition for the proposed
35 Levy Units 1 and 2 in north-central Florida, which was to use natural draft cooling towers with
36 brackish makeup water of about 24 ppt, was estimated to be 10.75 kg/ha/mo (NRC 2012-
37 TN1976). Such deposition suggests the possibility of noticeable leaf damage in terrestrial
38 habitats close to the site. The Levy plant, however, was designed with natural draft cooling
39 towers, which tend to disburse drift farther from the towers than mechanical draft towers.

40 The NRC staff recognizes that damage to forested habitats can result from icing of
41 cooling-tower drift but recognizes such damage as being “rare, minor, and localized” (NRC
42 2024-TN10161). The recently completed new reactor EISs discussed above dismiss the effects
43 of icing on terrestrial habitats from cooling-tower operation as being minimal. Even in arctic or
44 very cold habitats, the existing vegetation would have to already be adapted to heavy snow and
45 ice accumulation.

46 The staff has determined that cooling-tower effects on vegetation are a Category 1 issue. The
47 staff concludes that as long as the applicable assumptions regarding cooling towers in the PPE

1 and SPE are met, including that the source of makeup water is fresh (salinity of less than 1 ppt),
2 the impacts can be generically determined to be SMALL. The staff relied on the following PPE
3 and SPE values and assumptions to reach this conclusion:

- 4 • If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in
5 height; and equipped with drift eliminators.
- 6 • Any makeup water for the cooling towers would be fresh water (less than 1 ppt salinity).

7 The staff recognizes that vegetation damage from the operation of cooling towers using
8 brackish water or seawater as makeup water may also have a low probability of noticeable
9 adverse effects on terrestrial habitats, but less evidence is available to support high confidence
10 in that conclusion without completion of project-specific analysis.

11 *3.5.2.2.5 Bird Collisions and Injury from Structures and Transmission Lines*

12 The structures and transmission lines discussed in Section 3.5.2.1 for building would continue to
13 be present during operations, and no new structures or transmission lines would be introduced
14 during operations that were not previously considered. Thus, the analyses in Section 3.5.2.1
15 also apply during operations. As for construction, the staff has determined that bird collisions
16 with structures and transmission lines during operations are a Category 1 issue. The staff
17 concludes that as long as the assumptions regarding structure heights and transmission lines
18 are met, the impacts can be generically determined to be SMALL. The staff relied on the
19 following PPE and SPE values and assumptions to reach this conclusion:

- 20 • The site size would be 100 ac or less.
- 21 • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than
22 100 ft in width and total no more than 1 mi in length.
- 23 • No transmission line structures (poles or towers) would be more than 100 ft in height.
- 24 • Licensees would implement common mitigation measures such as those provided by the
25 American Bird Conservancy (ABC 2015-TN6763) for buildings, by FWS (2013-TN6764) for
26 towers, and by the APLIC for transmission lines (APLIC 2012-TN6779).

27 See Section 3.5.2.1.5 for a brief discussion of the types of possible mitigation measures.

28 *3.5.2.2.6 Bird Electrocutions from Transmission Lines*

29 The potential for avian electrocutions from energized transmission conductors depends on a
30 combination of biological, environmental, and electrical design factors (APLIC 2006-TN794).
31 Biological and environmental factors include proximate habitat, bird species (body size,
32 behavior, distribution, and abundance), and prey availability. The key electrical design factor is
33 the physical separation between energized conductors (wires). If the distance between
34 energized conductors is less than that of the head-to-foot or wrist-to-wrist distance of a bird,
35 electrocution may occur. APLIC (2006-TN794) recommends that conductors be spaced a
36 minimum of 60 in. apart horizontally and 40 in. apart vertically, with 60 in. vertical separation
37 recommended near sensitive avian habitats. Contact between a single conductor and a bird
38 does not generally result in electrocution, but simultaneous contact by a bird with more than one
39 conductor (or air space very close to a conductor) can cause electrocution because of the
40 phase differences in voltage. Most electrocutions are of birds that have large wingspans, such
41 as eagles, hawks, vultures, ravens, and large waterbirds. Of particular concern are bald eagles
42 (*Haliaeetus leucocephalus*) and golden eagles (*Aquila chrysaetos*), which are protected under

1 the Bald and Golden Eagle Protection Act (16 U.S.C. §§ 668 et seq.; TN1447) (APLIC and EEI
2 2018-TN6809). Although collisions occur at both distribution lines and transmission lines,
3 electrocutions mostly occur at distribution lines, with voltages between 2.4 and 60 kV (Loss
4 et al. 2014-TN9396). Electrocutation mortality is not known to have been a concern at existing
5 nuclear power plants in the United States; thus, the NRC did not address the subject in its
6 License Renewal GEIS (NRC 2024-TN10161).

7 The staff expects the likelihood of avian electrocution mortality, up to and including population
8 level effects, would be low for new reactor transmission lines in any environmental setting and
9 has concluded this is a Category 1 issue. As long as the assumptions regarding transmission
10 lines in the PPE and SPE are met, the impacts can be generically determined to be SMALL.
11 The staff relied on the following PPE and SPE values and assumptions to reach this conclusion:

- 12 • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than
13 100 ft in width and total no more than 1 mi in length.
- 14 • Common mitigation measures, such as those recommended by APLIC (2006-TN794), would
15 be implemented.

16 The potential for electrocutions is limited by the PPE that assumes a maximum of 1 mi of ROW
17 not co-located with existing ROWs or roads. APLIC (2006-TN794) recognizes that co-location of
18 new power lines with existing power lines reduces the potential for electrocutions. The greatest
19 potential for electrocutions is where power lines cross open treeless areas (APLIC and EEI
20 2018-TN6809), but even in these areas the limitations assumed under the PPE are expected to
21 keep impacts at low significance. Examples of mitigation measures recommended by APLIC
22 include separation of phase conductors and grounded hardware, and installation of covers on
23 phases or grounds where adequate separation is not feasible (APLIC 2006-TN794). Moreover,
24 most electrocutions are on distribution lines, not transmission lines (Loss et al. 2014).

25 *3.5.2.2.7 Water Use Conflicts with Terrestrial Resources*

26 Water levels and hydroperiod are important factors in determining the composition of wetland
27 plant and animal species present (EPA 1996-TN6800; SFWMD 1995-TN6799). Through
28 physiological stress and habitat alteration, water-level fluctuations create temporal and spatial
29 heterogeneity that shapes littoral zone (shoreline and nearshore) habitats. Freshwater littoral
30 zones typically harbor diverse ecological communities that serve numerous ecosystem functions
31 that are influenced, in part, by water-level fluctuations (Carmignani and Roy 2017-TN6795). For
32 example, some native plants and animals have adapted to the range of hydrologic conditions
33 that occur in natural wetlands (SFWMD 1995-TN6799).

34 Large anthropogenic water withdrawals can influence the water levels and hydroperiod in
35 wetlands, floodplains, riparian, and other terrestrial habitats connected to flowing water bodies;
36 non-flowing freshwater, brackish, and marine water bodies; and groundwater sources supplying
37 water to meet the demands. Adverse effects on these habitats can occur when the water levels
38 or hydroperiod are changed beyond historical annual or seasonal fluctuations. In the License
39 Renewal GEIS, which addresses large LWRs operating as of 2013 that typically use
40 water-based cooling systems requiring large quantities of water, the NRC staff concluded that
41 project-specific analyses were necessary to characterize the potential impacts from water use
42 conflicts on terrestrial habitats (NRC 2024-TN10161).

1 Flowing Water Bodies

2 The staff's assumption regarding surface water availability for flowing systems (i.e., withdrawals
3 from rivers under low flow conditions of less than or equal to 3 percent of the 95 percent
4 exceedance flow, or extreme low flow conditions) would result in the loss of an even much
5 smaller percentage of the full or out-of-bank flows typically required to maintain riparian habitats
6 and connected wetlands, floodplains, and riparian areas (Hill et al. 1991-TN6791; Navratil 2006-
7 TN6792; Poff et al. 1997-TN6794; Kendy et al. 2012-TN6793). The 95 percent exceedance flow
8 accounts for cumulative hydrologic impacts because it includes existing withdrawals and
9 planned future withdrawals. Although there are no standard metrics for determining the flow
10 quantity or duration needed to maintain wetland, floodplain, and riparian habitats (Hill et al.
11 1991-TN6791), a minor water withdrawal such as 3 percent of the 95 percent exceedance flow
12 is unlikely to reduce water levels or alter hydroperiods in such habitats enough to cause
13 noticeable adverse effects, even when added to existing or planned water withdrawals. If the
14 low flow withdrawal assumption is not met, project-specific analysis would be required to
15 determine potential impacts on connected wetland, floodplain, and riparian habitats.

16 Non-flowing Water Bodies

17 Human activities that reduce lake water levels and hydroperiods below historical annual or
18 seasonal fluctuations may threaten littoral zone ecological integrity (Carmignani and Roy 2017-
19 TN6795; SFWMD 1995-TN6799) as described above for withdrawals from flowing water bodies.
20 Freezing or drying out of root systems and compaction of sediment may stress emergent and
21 aquatic plants. Reduced plant productivity, cover, and food supplies may result in a decrease in
22 dependent microorganisms, invertebrates, fish, and wildlife. Forage species that supply food for
23 birds and other wildlife might be replaced by species more tolerant of desiccation and/or
24 freezing, thereby having detrimental ecological effects on existing communities. For example, a
25 U.S. Bureau of Reclamation EIS (USBR 2004-TN6796) evaluated a proposed 5 ft drawdown of
26 Banks Lake in eastern Washington State lasting up to 2 months and concluded that there would
27 be adverse impacts on the distribution of vegetation, fish, and wildlife; prompting the U.S.
28 Bureau of Reclamation to propose vegetation mitigation and further investigate potential effects
29 on wildlife. Flat, shallow habitats are anticipated to incur greater areal exposure than steeper
30 habitats during a given drawdown.

31 The staff assumes a maximum surface water use rate of 6,000 gpm (Section 3.4.1) for total
32 plant water demand, applying to non-flowing water bodies such as the Great Lakes, the Gulf of
33 Mexico, oceans, estuaries, and intertidal zones. The staff assumes for the generic analysis that
34 the quantity of surface water withdrawn from these water bodies would not result in a reduction
35 in water levels or hydroperiod that could adversely affect connected wetlands, floodplains, or
36 riparian or other habitats. However, for other non-flowing bodies of freshwater (e.g., inland
37 lakes, ponds, and reservoirs) the staff assumes that applicants relying on the generic analysis
38 would demonstrate that the assumption regarding connected wetlands, floodplains, or riparian
39 habitats (changes in water levels and hydroperiod are within historical annual or seasonal
40 fluctuations) is met. If the applicant cannot so demonstrate, project-specific analysis would be
41 necessary to determine potential impacts on connected wetland, floodplain, and riparian
42 habitats. Such a demonstration would only be necessary if the site contains more than just low
43 value wetlands or other terrestrial habitats, such as drainage ditches or manufactured
44 depressions within uplands, or dominated by invasive vegetation.

1 Estuaries and Intertidal Zones

2 Water withdrawals from brackish non-flowing water bodies such as estuaries (partially enclosed,
3 coastal water body where freshwater mixes with marine water) could affect connected terrestrial
4 habitats and wildlife due to potential changes in water quality. Many different terrestrial habitat
5 types are found in estuaries, including freshwater and saltwater tidal marshes, tidal swamps,
6 sandy beaches, mud and sand flats, rocky shores, mangrove forests, and river deltas. The most
7 influential gradient in estuaries is salinity because it structures the spatial patterns of physical
8 properties, biogeochemical processes, and plants and wildlife with species-specific adaptations
9 to different salinity ranges (Cloern et al. 2017-TN6967). The salinity gradient in such settings
10 depends on the relative exchanges of both fresh and marine water, which may be altered
11 beyond historical annual or seasonal fluctuations by withdrawal of either fresh or marine water
12 (40 CFR 230.25; TN427). Water withdrawals in estuaries may alter both the physical extent of
13 saltwater influence and salinity levels and thereby affect populations of salinity-dependent food
14 sources that could in turn affect the survival of dependent wildlife. The staff therefore assumes
15 that applicants relying on the generic analysis would demonstrate that the assumption for
16 estuaries regarding connected terrestrial habitats (changes in the physical extent of saltwater
17 influence and salinity gradients are within historical annual or seasonal fluctuations) is met. If
18 the assumption is not met, further project-specific analysis would be necessary to determine
19 potential impacts on the physical extent of saltwater influence and salinity gradients as well as
20 associated food chain effects.

21 Water withdrawals from marine or brackish non-flowing water bodies such as intertidal zones (area
22 of shoreline between low and high tides) could affect habitat and wildlife due to potential
23 changes in water quality. Intertidal zones can encompass terrestrial habitats such as sandy
24 beaches, mud and sand flats, and rocky shores. Intertidal zones are characterized by unique
25 environmental conditions, including variable temperatures (depending on the status of the tide),
26 microclimates, and ecological factors that provide habitat for a wide variety of plant and animal
27 species. The vulnerability of intertidal zones to water withdrawals depends to a large extent on
28 the degree of enclosure from the open ocean. Partially enclosed intertidal zones with little
29 connectivity or current exchange with the open ocean would be more susceptible to water
30 withdrawals affecting salinity gradients than intertidal zones that are more open and connected
31 to the ocean. The irregularity in the geomorphology of coastal environments in terms of the
32 vertical and horizontal degree of enclosure from the open ocean varies widely, as does the
33 degree of vulnerability of intertidal zones to the effects of water withdrawal on changes in
34 salinity levels. The staff therefore assumes that applicants relying on the generic analysis would
35 demonstrate that the assumption for intertidal zones (changes in salinity levels are within
36 historical annual or seasonal fluctuations) is met. If the assumption is not met, further project-
37 specific analysis would be required to determine potential impacts on salinity gradients as well
38 as associated habitat and food chain effects.

39 Groundwater

40 The water use assumptions established in the PPE and SPE for surficial groundwater depletion
41 that could influence terrestrial habitats include withdrawal of less than or equal to 50 gpm
42 resulting in drawdown of no more than 1 ft at the site boundary. Withdrawals of surficial
43 groundwater during plant operations would be continual and thus have the potential for
44 permanent impacts on connected terrestrial habitats. Localized shoreline habitats throughout
45 the United States and internationally have undergone changes consistent with a loss or
46 reduction of groundwater discharge (EPA 1996-TN6800). High-risk hydrologic settings include
47 groundwater-fed wetlands without a surface water connection (EPA 1996-TN6800; MBWSR

1 2016-TN6801), such as many prairie potholes, pocosins, peat bogs, fens, and Carolina bays.
2 Long-term lowering of groundwater levels may impact groundwater-fed isolated wetlands in
3 much the same way as surface water withdrawals (described above for flowing and non-flowing
4 water bodies), but very few studies provide quantitative analysis. Some data suggest that
5 chronic reductions of groundwater levels result in a reduction in hydroperiod and can have
6 significant effects on plant community structure in wetlands (SFWMD 1995-TN6799). A less
7 than 1 ft modeled drawdown of groundwater has been shown to be associated with actual
8 drawdowns of several feet in isolated wetlands, and an extended modeled drawdown of
9 groundwater from 0.6 to 1.0 ft, within seasonally to semi-permanently flooded isolated wetlands,
10 has been shown to correspond with significant changes in plant community composition and
11 structure (SFWMD 1995-TN6799). Thus, there was ample evidence that a drawdown criterion of
12 less than 1 ft may be appropriate in some areas of Florida (SFWMD 1995-TN6799). However,
13 most of the studies reviewed by the South Florida Water Management District (SFWMD 1995-
14 TN6799) did not establish a threshold of harm corresponding to specific groundwater drawdown
15 level (modeled or actual).

16 Desert springs, often the sole sources of water for some wildlife in the arid west, often support
17 wetland and wetland/upland transition ecosystems including rare and endemic species.
18 Groundwater withdrawal may lower the local water table, reducing the areal cover of wetland
19 and wetland/upland transition vegetation and reduce the amount of upland phreatophytic
20 vegetation (deep-rooted plants that obtain water from the water table or the layer of soil just above
21 it) by causing water levels to drop below plant rooting depths. Percolation of salts to surface
22 soils may be reduced, eventually altering desert shrub cover from halophytes (plants adapted to
23 growing in saline conditions) to nonhalophytes. The extent of these effects will vary among
24 springs, based on their distance from groundwater extraction sites and location relative to
25 regional groundwater flow paths (Patten et al. 2007-TN6968). For example, outflow distance at
26 springs that have low discharge rates generally may not be more than 200 m, while outflow
27 distance at springs that have large discharges can be many kilometers (Patten et al. 2007-
28 TN6968).

29 Based on the above information related to the extraction of surficial groundwater, the staff has
30 no assurance that relying on assumed PPE/SPE values of groundwater drawdown of no more
31 than 50 gpm and no more than 1 ft at the site boundary, would adequately protect wetlands with
32 a groundwater connection, either within or outside of the site boundary. Based on these
33 analyses, even for a new reactor bounded by the assumptions for groundwater withdrawals for
34 dewatering in the PPE and SPE (50 gpm with no more than a 1 ft drawdown of groundwater
35 levels at the site boundary), some onsite and offsite wetlands in certain settings with a
36 groundwater connection could be affected. Adverse impacts on onsite and offsite wetlands
37 could result if groundwater dewatering causes changes in water levels or hydroperiod that
38 exceed historical annual or seasonal fluctuations. This applies to wetlands with a groundwater
39 connection but may be accentuated in such wetlands without a surface water connection. The
40 staff expects that applicants relying on the generic analysis would demonstrate that the
41 terrestrial resources assumption regarding wetlands (changes in water levels and hydroperiod
42 are within historical annual or seasonal fluctuations) in the SPE is met. It might be possible to
43 demonstrate that there are no wetlands, or only wetlands of minimal value, present on or in the
44 immediate vicinity of the site. Or it might be possible to demonstrate that the only wetlands on or
45 near the site belong to hydrogeomorphic classes not typically influenced by groundwater, such
46 as the hydrogeomorphic classes of riverine wetlands or tidal or lacustrine fringe wetlands
47 (Brinson et al. 1995-TN6969). Other tools might be available from various regulatory agencies
48 or other institutions and could be used. Such a demonstration would also have to provide

1 evidence that the maximum depth to groundwater lay substantially below the surface. If this
2 assumption is not met, further project-specific analysis would be required.

3 Conclusion

4 The staff has determined that water use conflicts with terrestrial resources are a Category 1
5 issue under the assumptions discussed above for flowing water bodies, non-flowing water
6 bodies (including freshwater, brackish, and marine), and surficial groundwater. If the applicable
7 assumptions for terrestrial resources in the relevant water body type are not met,
8 project-specific analyses would be necessary to characterize potential impacts on habitats
9 connected to such water bodies as well as on dependent wildlife. The staff relied on the
10 following PPE and SPE values and assumptions to reach this conclusion:

- 11 • Total plant water demand would be less than or equal to a daily average of 6,000 gpm.
- 12 • If water is withdrawn from flowing water bodies, average plant water withdrawals would not
13 reduce flow by more than 3 percent of the 95 percent exceedance daily flow, and would not
14 prevent maintenance of applicable instream flow requirements.
- 15 • Any water withdrawals would be in compliance with any EPA or State permitting
16 requirements.
- 17 • Applicants would be able to demonstrate that hydroperiod changes are within historical or
18 seasonal fluctuations.

19 *3.5.2.2.8 Effects of Transmission Line ROW Management on Terrestrial Resources*

20 Once a transmission line is built, ROWs in potential forest habitat will require routine
21 maintenance to keep them free of trees tall enough to cause electrical current to arc through
22 vegetation to the ground, which may ignite fires and cause power outages. It may also be
23 necessary to trim or remove trees growing near the edge of the ROW that are capable of falling
24 too close to the conductors (commonly termed “danger trees”). Trimming or removing individual
25 danger trees is unlikely to substantially alter the ecological properties of terrestrial habitats
26 adjoining the ROW. Some utilities also maintain “screens” of low trees under transmission line
27 conductors where they cross aesthetically sensitive suburban roadways; those tree screens
28 require frequent maintenance. The ecological properties of the screens are unlikely to be
29 substantially altered by trimming the entire screen or by removal of individual trees. Sometimes
30 relatively level upland areas on transmission line ROWs, especially in aesthetically sensitive
31 residential areas, are periodically mowed. But the most common techniques used in managing
32 transmission line ROWs involve the use of herbicides. Herbicides can be applied directly to
33 vegetation in the ROW, or herbicides can be applied to cut stump surfaces once trees are felled.

34 The NRC staff performed a comprehensive literature review of the potential effects of
35 transmission line ROW management on terrestrial resources as part of the License Renewal
36 GEIS (NRC 2024-TN10161). The analysis considered various common ROW management
37 practices including tree trimming and clearing, mowing, and herbicide application and concluded
38 that the overall ecological effects were neither substantially adverse nor beneficial. Limitations
39 on the length and routing of transmission lines in the PPE further reduce the potential for
40 adverse impacts.

41 The staff has determined that this is a Category 1 issue. The staff concludes that as long as the
42 assumptions regarding transmission lines in the PPE and SPE are met, the impacts can be
43 generically determined to be SMALL. The PPE includes an assumption that licensees would

1 implement integrated vegetation management practices to maintain ROWs in areas where
2 vegetation growth may interfere with power lines. Mitigation measures necessary to rely on the
3 generic analysis include ensuring that all work is performed in compliance with all applicable
4 laws and regulations and that herbicides are applied only by licensed applicators in compliance
5 with the applicable manufacturer label instructions. The staff relied on the following PPE and
6 SPE values and assumptions to reach this conclusion:

- 7 • Vegetation in transmission line ROWs would be managed following a plan consisting of
8 integrated vegetation management practices.
- 9 • All ROW maintenance work would be performed in compliance with all applicable laws and
10 regulations.
- 11 • Herbicides would be applied by licensed applicators, and only if in compliance with
12 applicable manufacturer label instructions.

13 *3.5.2.2.9 Effects of Electromagnetic Fields on Flora and Fauna*

14 Electric current moving through transmission lines generates an EMF in the surrounding
15 airspace. The NRC staff performed a comprehensive literature review of the potential effects of
16 EMFs on terrestrial resources, including flora, honeybees, and wildlife and livestock and
17 identified no significant impacts (NRC 2024-TN10161). Based on the literature review in the
18 License Renewal GEIS, the staff determined that this is a Category 1 issue and impacts would
19 be SMALL regardless of the length, location, or size of the transmission lines. The staff did not
20 recommend any mitigation in the License Renewal GEIS (NRC 2024-TN10161); hence, none is
21 needed here. The staff did not rely on any PPE and SPE values or assumptions in reaching this
22 conclusion.

23 *3.5.2.2.10 Important Species and Habitats*

24 As noted for building, important species and habitats meeting the NRC criteria (NRC 2024-
25 TN7081) for a given site can only be determined once the site is identified. Because of different
26 regulations and sensitivities to impacts, two separate issues are analyzed below regarding
27 important species and habitats: (1) resources regulated under the ESA (16 U.S.C.
28 §§ 1531 et seq.; TN1010), and (2) other important species and habitats.

29 Resources Regulated under the Endangered Species Act of 1973

30 For the same reasons noted for building in Section 3.5.2.1.6, the staff has determined that
31 operational impacts on resources regulated under the ESA are a Category 2 issue. Because of
32 their potential for future regulation over the course of a licensing action, the Category 2
33 designation extends also to candidate species and species and critical habitat proposed for
34 designation under the Act. Even if the applicable assumptions in the PPE and SPE outlined in
35 Section 3.5.1 are met, the NRC staff is unable to determine the significance of potential impacts
36 without consideration of project-specific factors, including the specific species and habitats
37 affected and the types of ecological changes potentially resulting from each specific licensing
38 action. Furthermore, completing the required consultation requires individualized action by the
39 staff for each application.

40 Other Important Species and Habitats

41 The analyses presented in Section 3.5.2.1.6 also apply to operations and suggest that the
42 potential impacts on other important species and habitats as defined in RG 4.2 (NRC 2024-

1 TN7081) from operating a new reactor that meets the PPE and SPE would likely be minimal
2 regardless of site location and the important species specifically present on a given site. The
3 assumptions in the PPE and SPE limit the potential for adverse impacts, especially limiting the
4 size of the disturbance footprint and the assumed absence of sensitive habitat types potentially
5 containing rare species within the footprint. The staff has therefore determined that operational
6 impacts on important species and habitats other than those regulated under the ESA are a
7 Category 1 issue. The staff concludes that as long as the applicable assumptions regarding the
8 size and habitat quality of the building footprint, wetlands, building height, noise generation, and
9 employment in the PPE and SPE are met, the impacts can be generically determined to be
10 SMALL. The staff relied on the following PPE and SPE values and assumptions to reach this
11 conclusion:

- 12 • Applicants would communicate with State natural resource or conservation agencies
13 regarding wildlife and plants and implement mitigation recommendation of those agencies.

14 **3.6 Aquatic Ecology**

15 **3.6.1 Baseline Conditions and PPE/SPE Values and Assumptions**

16 Some sites proposed for a new reactor may include (or be adjacent to) aquatic habitats in
17 streams, rivers, ponds, lakes, or other surface water features. Other sites may lack aquatic
18 habitats within their perimeters, but activities there could still affect aquatic habitats because the
19 sites lie in the watershed, thereby contributing overland runoff to down-gradient surface water
20 features containing aquatic habitats. Some watersheds may drain directly to large bodies of
21 waters such as oceans, estuaries, or large lakes; while others may instead drain into tributary
22 systems that flow into the larger bodies of water. In some landscapes, sites may drain into
23 depressions where the accumulated water forms permanent or temporary lakes or ponds, or
24 ephemeral features such as playas and vernal pools, from which it evaporates to the
25 atmosphere or leaches into the groundwater. In landscapes overlying limestone (karst
26 landscapes), sites may drain into streams whose flow disappears into the underlying
27 groundwater and may emerge at springs elsewhere in the landscape.

28 The separation between aquatic and terrestrial habitats is not always sharp; the edges of some
29 aquatic habitats are clearly bounded by an ordinary high-water mark, while elsewhere the
30 transition is gradual and may include interim zones of wetlands. The NRC staff typically
31 considers wetlands that contain persistent emergent vegetation, including most swamps and
32 marshes, to be terrestrial habitats (addressed in Section 3.5), while considering wetlands
33 dominated only by submerged aquatic vegetation to be aquatic habitats (NRC 2024-TN7081).
34 More information about how the NRC staff defines and characterizes aquatic habitats is
35 available in RG 4.24 (NRC 2017-TN6720).

36 Aquatic habitats may be marine, estuarine, or freshwater. Marine habitats in oceans or bays
37 broadly open to the ocean generally are saltwater, with a typical seawater salinity of
38 approximately 35–37 ppt. Seawater that accumulates in depressions may attain higher salinities
39 due to partial evaporation. Estuaries are surface water areas where freshwater entering through
40 tributaries or runoff mixes with seawater carried by the tides, resulting in brackish water
41 between 0.5 ppt and less than 35 ppt. Estuarine habitats are typically in continuous flux in
42 response to changing tides, freshwater inflow, and freshwater runoff. Freshwater habitats, with
43 salinities generally 0.5 ppt or less, are sometimes characterized as either lotic, situated in
44 portions of streams or rivers containing running water; or lentic, situated in ponds, lakes, or
45 portions of streams or rivers containing standing water. Biota at the base of aquatic food chains

1 are photosynthetic (capable of using sunlight to produce biomass); including photosynthetic
2 bacteria, phytoplankton (free-floating microscopic algae), larger floating algae or algae fixed to
3 solid substrates by holdfasts or rooted submerged vascular plants. Other components of the
4 aquatic food chain can include zooplankton (free-floating microscopic animal-like biota), benthic
5 organisms (generally larval insects or other fauna that attach to rocks and other solid
6 underwater substrates), fish, crustaceans, and shellfish. Many fish and shellfish include
7 microscopic life stages that behave more like plankton than the independently mobile adults.
8 The aquatic food chain is intimately connected to the terrestrial food chain and can be
9 influenced by terrestrial organisms such as birds, mammals, reptiles, amphibians, and insects.

10 The NRC staff developed the values and assumptions in the PPE and SPE pertaining to aquatic
11 ecology based on the information and analyses contained in multiple new reactor EISs prepared
12 since 2005, the License Renewal GEIS (NRC 2024-TN10161), other past NRC EISs, and
13 Federal and State regulations protecting waters of the United States and threatened and
14 endangered species.

15 Based on experience gained from preparing past new reactor EISs, the NRC staff included an
16 assumption in the PPE and SPE that permanent disturbance would encompass no more than
17 30 ac of vegetated land, with temporary disturbance of as much as an additional 20 ac of
18 vegetated land. The NRC staff also assumes the temporarily disturbed land will be restored
19 once it is no longer needed using regionally indigenous vegetation. Disturbances to land in the
20 watershed of surface water bodies can result in sedimentation and stormwater runoff reaching
21 habitats of aquatic flora and fauna. The NRC staff would have to consider project-specific
22 factors if greater disturbances were necessary. Also, based on the staff's experience with past
23 new reactor EISs, the PPE and SPE additionally assume that the footprint of disturbance (other
24 than for building intake or discharge structures) would not encompass aquatic habitats.
25 However, as explained in Section 3.5.1, the assumptions in the PPE and SPE allow for impacts
26 on as much as 0.5 ac of wetlands or other waters of the United States, based on disturbance
27 area limits built into several NWPs established by the USACE under Section 404 of the CWA
28 (33 U.S.C. § 1344-TN1019). The PPE and SPE also recognize that transmission lines,
29 pipelines, and access roads might extend across or under streams or small surface water
30 features (as long as the project's total impact on wetlands and other surface water bodies is less
31 than 0.5 ac).

32 Recognizing that the evaluation of aquatic impacts in the License Renewal GEIS (NRC 2024-
33 TN10161) and past new reactor EISs identified substantial impacts from certain types of plant
34 cooling systems, the staff included an assumption in the PPE and SPE that allows for use of
35 recirculated-water cooling towers, but not once-through cooling systems, cooling ponds, or new
36 cooling-water reservoirs. However, the assumptions still recognize that any cooling towers
37 would have to be mechanical draft type rather than natural draft type, and that any makeup
38 water for cooling would have to be fresh (salinity less than 1 ppt). EISs for proposed new
39 reactors in Levy County, Florida (NRC 2012-TN1976) and Homestead, Florida (NRC 2016-
40 TN6434) identified potentially damaging salt drift at certain locations close to cooling towers
41 using brackish makeup water. The PPE and SPE also assume that any intake would meet the
42 requirements established by the EPA in 40 CFR 125.83 (TN254) for protection of aquatic biota
43 from entrainment or impingement. Because of the potential for contamination by dissolved
44 metals in cooling-system blowdown water that are toxic to aquatic biota, the PPE also assumes
45 no use of copper alloy tubes in cooling systems. Based on information in past new reactor EISs,
46 the staff established assumptions in the PPE and SPE regarding features such as transmission
47 lines and other linear utilities. The PPE and SPE assume that any new poles or towers would be
48 built outside of wetlands and floodplains and that any pipelines would be directionally drilled

1 under surface water features such as streams without disturbance to shorelines or bottom
2 substrates. Finally, the PPE and SPE assumptions relevant to aquatic ecology include all of the
3 assumptions developed for Hydrology (Section 3.4.1) with respect to withdrawal of surface
4 water and groundwater.

5 The NRC staff typically evaluates impacts on aquatic habitats, as well as on the individual
6 species and habitats that meet the definition of “important,” as outlined in RG 4.2 (NRC 2024-
7 TN7081). Determining which species and habitats potentially affected by a project meet the
8 criteria for “important” is not possible until a specific site is identified. While the analysis in
9 Section 3.6.2 is able to consider the potential impacts on many types of important species
10 generically, it reserves a consideration of potential impacts on federally listed threatened or
11 endangered species and species regulated under the Magnuson-Stevens Fishery Conservation
12 and Management Act (Magnuson-Stevens Act; 16 U.S.C. §§ 1801 et seq.; TN1061) until after
13 receipt of an application. The generic analyses of environmental consequences presented
14 below therefore address potential impacts on aquatic habitats, food chains, and groupings of
15 biota, while reserving consideration of potential impacts on federally listed threatened or
16 endangered species and species regulated under the Magnuson-Stevens Act for project-
17 specific documentation for the review of a specific license application.

18 A number of available databases contain relevant information about aquatic biota for sites
19 anywhere in the United States. The FWS and National Marine Fisheries Service (NMFS)
20 maintain online databases regarding the potential occurrence of threatened, endangered,
21 proposed, or candidate species and critical habitats designated under the Federal ESA
22 (16 U.S.C. §§ 1531 et seq.; TN1010); and the NMFS maintains maps depicting the geographic
23 extent of essential fish habitat regulated under the Magnuson-Stevens Act (16 U.S.C. §§ 1801
24 et seq.; TN1061). Most States have Natural Heritage Programs with databases that contain
25 information about the locations of species and habitats that have Federal or State special
26 designations.

27 **3.6.2 Aquatic Ecology Impacts**

28 For a nuclear plant meeting the assumptions in the PPE and SPE, the potential for significant
29 impacts on aquatic ecological resources would generally be minor. There would be a potential
30 for runoff and sedimentation to affect aquatic habitats during preconstruction and construction,
31 but the PPE and SPE assume BMPs would be used to minimize adverse effects. There would
32 also be a potential for limited impacts on wetlands and other shallow surface waters, although
33 the potential impacts would be limited by the assumptions in the PPE and SPE. It may be
34 necessary to build transmission lines, pipelines, or access roads spanning rivers, streams, or
35 other surface waters; and the assumptions in the PPE and SPE allow for limited occurrence of
36 such encroachments. For plants operated using water-based cooling, operational impacts on
37 aquatic resources could also result from entrainment and impingement or thermal discharges.
38 The evaluation below also considers the potential for impacts on aquatic resources from
39 releases of radionuclides or nonradiological contamination during operations. The evaluation
40 also considers the possible impacts on aquatic habitats from operation and maintenance of
41 transmission lines and other facilities on offsite ROWs.

42 *3.6.2.1 Environmental Consequences of Construction*

43 The NRC staff considered the following environmental issues related to aquatic resources for
44 the building of a new reactor meeting the PPE and SPE:

- 45 • runoff and sedimentation from building areas;

- 1 • dredging and filling aquatic habitats to build intake and discharge structures;
- 2 • building transmission lines, pipelines, and access roads across surface water bodies; and
- 3 • impacts on important species and habitats.

4 The NRC staff addressed as a separate issue any impacts on important species as defined for
5 NRC environmental reviews (NRC 2024-TN7081).

6 3.6.2.1.1 *Runoff and Sedimentation from Construction Areas*

7 Even though the PPE and SPE assume no more than 0.5 ac of disturbance of aquatic habitats
8 (including wetlands delineated using the *Corps of Engineers Wetlands Delineation Manual*
9 [USACE 1987-TN2066] and regional supplements), physical disturbance of surface soils could
10 cause runoff and sediment to enter nearby streams, rivers, lakes, and other surface water
11 features. Precipitation can dislodge soil particles from surface soils exposed by clearing,
12 grubbing, and grading; and those dislodged particles can become suspended in surface runoff
13 and be carried overland into nearby surface water features. Upon entering surface waters,
14 sediment can settle onto the bottom substrate and smother benthic (substrate-borne) flora and
15 fauna. Runoff and sediment can also block sunlight needed by photosynthetic organisms that
16 form the base of the aquatic food chain, and runoff can carry soil-borne nutrients such as
17 phosphorus and nitrogen to surface waters where they can cause rapid growth of algae, plants,
18 or microorganisms in a process termed eutrophication. These “blooms” of aquatic organisms
19 can rapidly deplete oxygen carried in the water (dissolved oxygen) needed by fish and other
20 aquatic organisms, causing suffocation. Runoff and sediment can also carry pesticides and
21 other chemical contaminants from terrestrial to aquatic settings. The entry of large volumes of
22 runoff can increase currents and scour bottom sediments, dislodging benthic biota and
23 increasing sedimentation of downstream habitats. As soil is compacted by building equipment
24 and structures are built, soil permeability is reduced, and precipitation is prevented from slowly
25 entering the soil column and is instead directed overland toward aquatic habitats. Rapid flushes
26 of stormwater following intense precipitation can generate flood flows capable of carrying large
27 volumes of nutrients or contaminants into aquatic habitats and scouring benthic biota (biota
28 attached to underwater surfaces).

29 Significant erosion and sedimentation of aquatic habitats caused by construction could be
30 effectively prevented by implementing BMPs. Common BMPs for sedimentation and erosion
31 control include, but are not limited to, placing silt fences at the perimeter of areas prior to soil
32 disturbance, installing sediment traps to catch sediment, and temporarily and permanently
33 stabilizing exposed soil using straw or fast-growing vegetation. Stormwater runoff from
34 impervious surfaces could be managed by building basins to detain runoff so that more
35 ultimately moves into the soil column rather than overland to surface waters. Many States or
36 localities require developers to implement detailed plans for soil erosion and sediment control
37 and stormwater management.

38 Because of the widespread availability of effective BMPs, the staff has determined that runoff
39 and sedimentation from building areas is a Category 1 issue. The staff concludes that as long
40 as the applicable PPE and SPE assumptions regarding the permanent and temporary areas of
41 disturbance are met, the impacts from building a new reactor can be generically determined to
42 be SMALL. The staff relied on the following PPE and SPE values and assumptions to reach this
43 conclusion:

- 44 • BMPs would be used for erosion and sediment control.

- 1 • Temporarily disturbed lands would be revegetated using regionally indigenous vegetation
2 once the lands are no longer needed to support building activities.

3 Applicants relying on the generic determination would prepare and implement a soil erosion and
4 sediment control plan and a stormwater management plan that have been approved by all
5 applicable State and local authorities. If a project involves building in an area where there are no
6 requirements for regulatory approval of those plans, the PPE and SPE still assume that for
7 purposes of relying on the generic conclusions in this GEIS, applicants would develop and
8 implement BMPs commonly recognized as being effective.

9 *3.6.2.1.2 Dredging and Filling Aquatic Habitats to Build Intake and Discharge Structures*

10 Based on recent license applications for new reactors, building intake and discharge structures
11 for cooling typically require disturbing no more than 200 linear feet of shoreline and affect less
12 than 1–2 ac of aquatic habitat per structure. The Tennessee Valley Authority recently estimated
13 that it would have to build an intake structure measuring approximately 50 ft by 50 ft and a
14 discharge structure containing two 3 ft pipes to support mechanical draft cooling towers for a
15 future SMR project in Tennessee (NRC 2019-TN6136). Building those structures would likely
16 disturb less than 200 ft of shoreline on the reservoir and less than 1 ac of bottom sediment in
17 the reservoir. An application for a new reactor in Pennsylvania proposed disturbing
18 approximately 0.61 ac within a river to build an intake structure and approximately 0.46 ac in the
19 river to build a discharge structure (NRC and USACE 2016-TN6562). Positioning excavation
20 and building equipment may also require temporarily disturbing a small area of adjoining
21 riparian habitat, likely under 0.5 ac per structure. The structures are typically built in the same
22 river, lake, or other source water body but usually have to be established at separate locations
23 so discharges do not interfere with intakes. The staff has typically concluded that the impacts of
24 building the intakes and discharges would be minimal as long as the structures qualify for a
25 NWP 7 under the CWA Section 404 (33 CFR Part 330-TN4318), BMPs are followed, and any
26 mitigation measures required by the USACE under CWA permits are implemented.

27 The PPE does not assume any limitations on the extent of land, shoreline, and riparian
28 disturbance because of the ability to perform mitigation. Excavation to build the intake and
29 discharge structures would disturb a small area of aquatic habitat as well as a small area of
30 adjoining riparian vegetation, thereby influencing the quality of aquatic habitat. The resulting
31 habitat losses or disturbance would not substantially alter the overall aquatic ecosystem in most
32 surface water features large enough to function as sources of makeup water. Excavation would
33 briefly generate plumes of sediment capable of being carried by currents to distant aquatic
34 habitats; however, it is usually possible to construct small temporary cofferdams around
35 excavation locations to limit the escape of sediment. Cofferdams temporarily surround the
36 excavation area with a physical structure that blocks movement of suspended sediment into
37 adjoining waters. Most surface water bodies large enough to serve as makeup water sources
38 are navigable or situated on tributary systems and would therefore be regulated as waters of the
39 United States under the CWA (33 U.S.C. §§ 1251 et seq.; codified as the Federal Water
40 Pollution Control Act of 1972-TN662). Work to build intake and discharge structures would
41 therefore require a permit from the USACE under CWA Section 404 but would be covered in
42 most instances by one or more NWPs (33 CFR Part 330-TN4318).

43 The staff has determined that this is a Category 1 issue. The staff concludes that as long as the
44 assumptions in the PPE and SPE regarding the intake structure are met, the impacts from this
45 issue can be generically determined to be SMALL. The staff relied on the following PPE and
46 SPE values and assumptions to reach this conclusion:

- 1 • Applicant would obtain approval, if required, under NWP 7 in 33 CFR Part 330.
- 2 • Applicant would implement any mitigation required under NWP 7 in 33 CFR Part 330.
- 3 • Applicant would minimize any temporarily disturbed shoreline and riparian lands needed to
- 4 build the intake and discharge structures and restore those areas with regionally indigenous
- 5 vegetation suited to those landscape settings once the disturbances are no longer needed.
- 6 • BMPs would be used for erosion and sediment control.

7 *3.6.2.1.3 Building Transmission Lines, Pipelines, and Access Roads across Surface Water*
8 *Bodies*

9 Transmission conductors of any voltage can be built to span rivers, streams, and narrow lakes
10 without physically disturbing shorelines, sediments, or other components of the channel or
11 basin. The conductors would not cast a substantial shadow capable of reducing sunlight
12 reaching the water surface or otherwise altering the condition of the aquatic habitat. The PPE
13 and SPE assume that conductors would be mounted on towers situated only in uplands and that
14 no new towers would be built within surface water bodies or adjacent wetlands or floodplains.
15 Pipelines can typically be built under waterways using directional horizontal drilling, thereby
16 avoiding physical disturbance of overlying surface water bodies. The PPE and SPE assume that
17 pipelines would be extended under (or over) surface water bodies through directional drilling (or
18 aboveground placement) without physically disturbing shorelines or bottom substrate.

19 Access roads can be built across smaller streams using a bridge or ford. It is usually possible to
20 place matting over shallow water areas to facilitate fording with minimal physical disturbance of
21 shorelines and bottom substrate. Building the bridge abutments or a ford would temporarily
22 disturb small areas of shoreline and bottom substrate and use of a ford could disturb substrate
23 each time a vehicle passes. Fish and other mobile aquatic biota may briefly disperse from areas
24 near a crossing each time the crossing is used due to noise and vibrations caused by the
25 vehicles. A bridge could also limit the occurrence of aquatic plants and other photosynthetic
26 organisms because of shading. The assumptions in the PPE and SPE regarding the length of
27 offsite ROW and the 0.5 ac limit on impacts on wetlands and surface waters function to limit the
28 number of possible crossings by access roads. Another assumption is that no access roads
29 would be extended across stream channels over 10 ft in width (at ordinary high water). Crossing
30 wider streams would likely require building fords or bridges that involve a potential for aquatic
31 resource impacts and would require project-specific analysis to assess their significance. The
32 PPE and SPE also assume that no more than 0.5 ac of surface waters or wetlands would be
33 disturbed. Limiting crossings to streams of that width would limit the potential for habitat
34 disturbance, disturbance of mobile biota, or generation of sediment.

35 No impacts on aquatic resources would likely result from spanning or horizontal drilling under a
36 surface water body. Extending roadways across waters of the United States typically qualifies
37 under one or more NWPs (33 CFR Part 330-TN4318), the availability of which supports the
38 staff's conclusions. The USACE issues NWPs only for classes of activity determined to
39 generally not result in significant adverse impacts on aquatic resources and are subject to public
40 review every 5 years. NWP 12 (temporarily vacated at the present time) applies to utility lines
41 such as pipelines or transmission lines and NWP 14 applies to linear transportation projects
42 associated with any project. Both NWPs limit the total disturbance to waters of the United States
43 and adjacent wetlands to 0.5 ac; additional limitations apply to tidal areas. Applicants relying on
44 the generic determination would be expected to demonstrate that the USACE has approved
45 any impacts on waters of the United States under one or more NWPs or that the

1 crossings meet the criteria for approval. Applicants would also be expected to implement
2 BMPs as mitigation to minimize runoff and sedimentation to surface water features from
3 building transmission lines, access roads, or pipelines.

4 Like other CWA permitting requirements, the need for approval under a NWP applies only to
5 wetlands under CWA jurisdiction. Building transmission lines, pipelines, and access roads could
6 impact both jurisdictional and non-jurisdictional wetlands or surface water features. The PPE
7 and SPE therefore includes an assumption that access roads crossing non-jurisdictional surface
8 water features meet the substantive requirements of NWPs 12 or 14 regarding limits on
9 disturbance and requirements for mitigation. Both permits limit the cumulative disturbance from
10 a “single and complete project” to no more than 0.5 ac of jurisdictional surface water features
11 that can serve as an equivalent benchmark for non-jurisdictional surface water features as well.
12 While greater impacts on non-jurisdictional surface waters might not be significant, the staff can
13 only make that determination after review of project-specific information.

14 The staff has determined that this is a Category 1 issue. The staff concludes that as long as the
15 PPE and SPE assumptions established for offsite ROWs are met, the impacts from this issue
16 can be generically determined to be SMALL. The staff relied on the following PPE and SPE
17 values and assumptions to reach this conclusion:

- 18 • If activities regulated under the Clean Water Act are performed, they would receive approval
19 under one or more NWPs (33 CFR Part 330-TN4318) or other general permits recognized
20 by the USACE.
- 21 • Pipelines would be extended under (or over) surface through directional drilling without
22 physically disturbing shorelines or bottom substrate.
- 23 • Access roads would span streams and other surface waterbodies with a bridge or ford, and
24 any fords would include placement and maintenance of matting to minimize physical
25 disturbance of shorelines and bottom substrates.
- 26 • No access roads would be extended across stream channels over 10 ft in width (at ordinary
27 high water).
- 28 • Any bridges or fords would be removed once no longer needed, and any exposed soils or
29 substrate would be revegetated using regionally indigenous vegetation appropriate to the
30 landscape setting.
- 31 • Any mitigation measures indicated in the NWPs or other permits would be implemented.
- 32 • BMPs would be used for erosion and sediment control.

33 *3.6.2.1.4 Important Species and Habitats*

34 Important species and habitats meeting the NRC criteria (NRC 2024-TN7081) for a given site
35 can only be determined once the site is identified. Because of differing regulations and
36 sensitivities to impacts, two separate issues are analyzed below regarding important species
37 and habitats: (1) resources regulated under the ESA (16 U.S.C. §§ 1531 et seq.; TN1010) and
38 the Magnuson-Stevens Fishery Conservation and Management Act (Magnuson-Stevens Act;
39 16 U.S.C. §§ 1801 et seq.; TN1061), and (2) other important species and habitats.

1 Resources Regulated under the Endangered Species Act and Magnuson-Stevens Act

2 The FWS has developed online databases and mapping tools that identify threatened,
3 endangered, proposed, and candidate species under the ESA (16 U.S.C. §§ 1531 et seq.;
4 TN1010), as well as critical habitats designated under the Act. The NMFS maintains similar
5 information for marine or anadromous species protected under the Act. NMFS also maintains
6 maps and other information about essential fish habitats regulated under the Magnuson-
7 Stevens Act.

8 Because these federally regulated resources occur in the same setting and are subject to the
9 same types of impacts as those considered in Sections 3.5.2.1.1 through 3.5.2.1.5, the
10 limitations placed upon the extent and intensity of ecological impacts by meeting the
11 assumptions in the PPE and SPE would likewise limit the potential for impacts on these
12 resources. However, the staff would need to consult individually with the FWS and/or NMFS
13 (depending on the specific setting) under the ESA and Magnuson-Stevens Act regarding the
14 potential impacts from each specific licensing action. Furthermore, with respect to the ESA, the
15 criteria for listing species are based upon the potential for the most severe of potential
16 ecological impacts: extinction of species, subspecies, or distinct population segments. Species
17 that have experienced previous impacts so severe that they are now, or could imminently
18 become, in danger of extinction may also be substantially more sensitive to impacts that might
19 only pose minimal threat to other species.

20 The staff has therefore determined that building impacts on resources regulated under the ESA
21 and Magnuson-Stevens Act are a Category 2 issue. Because of their potential for future
22 regulation over the course of a licensing action, the Category 2 designation extends also to
23 proposed and candidate species designated under the ESA. Even if the assumptions in the PPE
24 and SPE discussed in Sections 3.6.2.1.1 through 3.6.2.1.3 are met, the NRC staff is unable to
25 determine the significance of potential impacts without consideration of project-specific factors,
26 including the specific species and habitats affected and the types of ecological changes
27 potentially resulting from each specific licensing action. Furthermore, the ESA and
28 Magnuson-Stevens Act require consultations for each licensing action that may affect regulated
29 resources.

30 Other Important Species and Habitats

31 Most States maintain natural heritage databases that identify known occurrences of species and
32 habitats receiving various categories of State regulation or recognition. Many species and
33 habitats that do not display the potential for extinction necessary for regulation under the ESA
34 are still recognized by States because of declining numbers within state boundaries. However,
35 extirpation from a State is not as severe an impact as complete extinction. Regarding other
36 types of important species and habitats, most sites containing aquatic habitats may support
37 commercially or recreationally valuable fisheries, as well as nuisance or invasive species such
38 as zebra mussels (*Dreissena polymorpha*), Asiatic clams (*Corbicula fluminea*), northern
39 snakehead fish (*Channa argus*), and invasive aquatic vegetation such as common water
40 hyacinth (*Pontederia crassipes*) and Eurasian watermilfoil (*Myriophyllum spicatum*). Invasive
41 aquatic species not only adversely affect native aquatic species but can also interfere with
42 navigation and recreational use of waterways. The NRC staff expects that applicants will
43 communicate with State and local agencies, private conservation organizations, and other
44 stakeholders as necessary to determine what other important species and habitats are
45 potentially present on a site, such as species that have a Federal or State monitoring
46 requirement or other species of known interest, protected habitats, habitats identified by Federal

1 or State agencies as being of high priority for protection, or other habitats of interest such as
2 nesting or nursery grounds.

3 The analyses presented above regarding impacts on aquatic resources from specific ecological
4 issues suggest that the potential impacts on many important species and habitats (NRC 2024-
5 TN7081) from building of a new reactor that meets the PPE and SPE would likely be minimal
6 regardless of site location. The NRC staff is confident in this conclusion for any site meeting the
7 assumptions in the PPE and SPE discussed in Sections 3.6.2.1.1 through 3.6.2.1.3, even
8 without identifying the important species specifically present on a given site. The assumptions in
9 the PPE and SPE limit the potential for adverse impacts, especially limitations on the size of the
10 footprint of disturbance and the assumed absence of sensitive habitat types potentially
11 containing rare species. The staff has therefore determined that building impacts on important
12 species and habitats other than those regulated under the ESA and Magnuson-Stevens Act are
13 a Category 1 issue. The staff concludes that as long as the assumptions in the PPE and SPE
14 discussed in Sections 3.6.2.1.1 through 3.6.2.1.3 are met, the impacts can be generically
15 determined to be SMALL. The staff relied on the following PPE and SPE values and
16 assumptions to reach this conclusion:

- 17 • Applicants would communicate with State natural resource or conservation agencies
18 regarding aquatic fish, wildlife, and plants and implement mitigation recommendation of
19 those agencies.

20 3.6.2.2 *Environmental Consequences of Operation*

21 The NRC staff considered the following environmental issues related to aquatic resources for
22 building of a new reactor meeting the PPE and SPE assumptions:

- 23 • stormwater runoff,
- 24 • exposure of aquatic organisms to radionuclides,
- 25 • impacts of refurbishment on aquatic biota,
- 26 • impacts of maintenance dredging on aquatic biota,
- 27 • impacts of transmission line ROW management on aquatic resources,
- 28 • impingement and entrainment of aquatic organisms,
- 29 • thermal impacts on aquatic biota,
- 30 • other impacts of cooling-water discharges on aquatic biota,
- 31 • water use conflicts with aquatic resources, and
- 32 • impacts on important species and habitats.

33 The list of issues considered is similar to that presented for operations in the License Renewal
34 GEIS (NRC 2024-TN10161). However, the PPE assumes there will be no use of once-through
35 cooling systems, cooling ponds, or building of new reservoirs. The PPE also assumes limits on
36 the quantities of water taken in and discharged for new reactors with dry or water-cooled cooling
37 towers. The License Renewal GEIS addresses losses from predation, parasitism, and disease
38 among organisms exposed to sublethal stresses (NRC 2024-TN10161), but those impacts are
39 encompassed herein as part of the interrelated issues noted above. Any possible impacts from
40 cooling-tower drift falling on aquatic habitats are addressed as part of the same issue in
41 Section 3.5.2.

1 3.6.2.2.1 *Stormwater Runoff*

2 Stormwater runoff generated by impervious surfaces during building is addressed above in
3 Section 3.6.2.1.1. The potential for stormwater runoff continues as long as impervious surfaces
4 remain on the site. Typical impervious surfaces at a reactor site include the tops of buildings
5 and other structures, roads and parking lots, exterior paved areas, walkways and other exterior
6 “hardscaping” areas. Unpaved but heavily compacted soils can also function as mostly
7 impervious surfaces and generate substantial quantities of runoff. Chemicals such as
8 pesticides, paints, and petroleum products are sometimes stored or handled on impervious
9 surfaces and contribute chemical contamination to runoff. Runoff from roads and parking lots
10 can contain oil and grease leaked from vehicles. Exterior areas, including landscaped areas,
11 can also contribute pesticides to runoff potentially reaching aquatic habitats. The potential for
12 stormwater runoff reaching aquatic habitats is typically minimized through implementation of
13 stormwater management plans as explained in Section 3.6.2.1.1. As noted in Section 3.10.2.1,
14 the PPE assumes that licensees would comply with any additional requirements established
15 through permits for the storage and use of hazardous materials issued by Federal and State
16 agencies under the Resource Conservation and Recovery Act (RCRA; 42 U.S.C. §§ 6901
17 et seq.; TN1281). The staff has determined that stormwater runoff during operations is a
18 Category 1 issue. The staff relied on the following PPE and SPE values and assumptions to
19 reach this conclusion:

- 20 • Preparation, approval by applicable regulatory agencies, and implementation of a
21 stormwater management plan.
- 22 • Obtaining and complying with any required permits for the storage and use of hazardous
23 materials issued by Federal and State agencies under RCRA.
- 24 • BMPs would be used for stormwater management.

25 3.6.2.2.2 *Exposure of Aquatic Organisms to Radionuclides*

26 The NRC staff recognizes that small amounts of radioactive particulates can be released to the
27 exterior environment during operation of LWRs and evaluated the potential impacts of those
28 releases on aquatic ecological receptors in the License Renewal GEIS (NRC 2024-TN10161).
29 Section 3.8.1.2.2 of this GEIS concludes that the impact of routine radiological releases from
30 past and current operations on aquatic biota would be SMALL. To support that conclusion,
31 Table 3-5 (in Section 3.8.1 of this GEIS) presents radiological exposure estimates for fish,
32 invertebrates, and algae modeled using the NRC Dose code, as presented in 15 EISs for
33 proposed new LWRs published between 2006 and 2019. All estimates were substantially lower
34 than exposure levels considered protective of terrestrial animal populations by the IAEA.

35 Additionally, in the License Renewal GEIS (NRC 2024-TN10161), the NRC staff used the
36 RESRAD-BIOTA dose evaluation model developed by DOE (2004-TN6460) to calculate
37 estimated dose rates to aquatic biota receptors using REMP reports submitted by licensees for
38 15 operating LWRs in the United States. RESRAD-BIOTA accounts for possible
39 bioaccumulation of radionuclides in biological organisms and biomagnification, whereby
40 radionuclides become concentrated at higher levels in organisms occupying higher positions in
41 the food chain. The total estimated doses for aquatic biota were all less than 0.2 rad/d
42 (0.002 Gy/d), considerably less than the guideline value of 1 rad/d (0.01 Gy/d) recognized by
43 DOE as being protective (DOE 2002-TN4551).

1 While many new reactors may use fuels containing differing distributions of radionuclides than
2 the LWRs considered in the analyses presented above, a reactor meeting the PPE and SPE
3 would not be likely to result in greater releases of radioactivity. The staff has determined that
4 exposure of aquatic organisms to radionuclides is a Category 1 issue. The staff concludes that
5 as long as the project meets the assumptions in the PPE and SPE underlying the analysis in
6 Section 3.8, the impacts can be generically determined to be SMALL, and mitigation would not
7 be warranted. The staff relied on the following PPE and SPE values and assumptions to reach
8 this conclusion:

- 9 • Applicants would demonstrate in their application that any radiological nonhuman biota
10 doses would be below IAEA (1992-TN712) and NCRP (1991-TN729) guidelines.

11 *3.6.2.2.3 Effects of Refurbishment on Aquatic Biota*

12 Refurbishment constitutes the replacement, improvement, or addition of new facilities within the
13 site of a new reactor throughout its operating life. Examples of possible new facilities might
14 include additional or expanded storage buildings, parking lots, administration buildings, or
15 independent spent fuel storage installation. Existing facilities might be demolished or rebuilt in
16 part. The SPE assumes that there are no surface water features on a site prior to the building of
17 a new reactor, although it is possible that developers of a new facility might build artificial ponds
18 or ditches as part of the stormwater management system for the site. These would be the only
19 possible locations for aquatic habitats on a site that meets the SPE. Any aquatic habitats that
20 form in these artificial features over time would be simpler and of lower ecological value than
21 most natural aquatic habitats and because they were generated after development of the site,
22 they would be easily replaceable. Loss or degradation of these artificial habitats to
23 accommodate refurbishment would not constitute a noticeable loss of aquatic habitat function in
24 the landscape. It is possible that over the operational lifetime of a new reactor that work in or
25 near natural aquatic habitats may be necessary to maintain or replace intake or discharge
26 structures or pipelines. The impacts would be bounded by the analyses presented above for the
27 building of those facilities.

28 The staff has determined that the impacts of refurbishment on aquatic organisms at an
29 operating reactor are a Category 1 issue. Impacts can be generically determined to be SMALL
30 as long as assumptions in the PPE regarding the area of disturbance and the SPE regarding
31 features within the area of disturbance are met. The staff relied on the following PPE and SPE
32 values and assumptions to reach this conclusion:

- 33 • BMPs would be used for erosion, sediment control, and stormwater management.
- 34 • Exposed soils would be restored as soon as possible with regionally indigenous vegetation.

35 *3.6.2.2.4 Effects of Maintenance Dredging on Aquatic Biota*

36 The NRC staff recognizes that maintenance dredging of sediment is sometimes necessary
37 during the operational life of a nuclear power plant, for purposes such as keeping intake screens
38 free of sediment or removing sediment from areas where boats are used (NRC 2024-TN10161).
39 As explained in the License Renewal GEIS, accumulation of sediment in standing or slow-
40 moving waters over time is a natural and unavoidable process that requires attention in order to
41 maintain facilities or navigational capabilities. The License Renewal GEIS describes the
42 potential impacts on aquatic biota from maintenance dredging at a LWR and concludes that the
43 impacts would be minimal because of its infrequency and the small areas affected. The extent
44 of the effects is not likely to be increased by the fuels or technologies of future new reactors.
45 Dredging of any type is considered under the CWA to constitute “discharge of dredged or fill
46 material” requiring a permit from the USACE under Section 404 (33 U.S.C. § 1344-TN1019);

1 however, dredging for the purpose of maintaining existing navigation capabilities such as marina
2 basins or boat slips is covered under NWP 35. There are no area or volume limitations
3 established for NWP 35, although certain conditions regarding the presence of sensitive
4 resources such as threatened or endangered species or wild and scenic rivers must be met,
5 and specific mitigation must be implemented. By issuing this NWP, the USACE acknowledges
6 that such maintenance dredging has minimal potential for having significant environmental
7 impacts on aquatic resources.

8 The staff has determined that the impacts on aquatic organisms of maintenance dredging of any
9 type at an operating reactor are a Category 1 issue. Impacts can be generically determined to
10 be SMALL as long as relevant assumptions in the PPE and the SPE are met. The staff relied on
11 the following PPE and SPE values and assumptions to reach this conclusion:

- 12 • If activities regulated under the Clean Water Act are performed, those activities would
13 receive approval under one or more NWPs (33 CFR Part 330-TN4318) or other general
14 permits recognized by the USACE.
- 15 • Any mitigation measures indicated in the NWPs or other permits would be implemented.
- 16 • BMPs would be used for erosion and sediment control.

17 *3.6.2.2.5 Impacts of Transmission Line ROW Management on Aquatic Resources*

18 Once a transmission line is built, the ROW requires routine maintenance to keep it free of trees
19 tall enough to cause electrical current to arc through vegetation to the ground. It may also be
20 necessary to remove or trim trees growing near the edge of the ROW capable of falling too
21 close to the conductors (commonly termed “danger trees”). Some utilities also maintain
22 “screens” of low trees under transmission line conductors where they cross aesthetically
23 sensitive suburban roadways; such tree screens require frequent maintenance. Sometimes
24 relatively level upland areas on transmission line ROWs, especially in aesthetically sensitive
25 residential areas, are periodically mowed. But the most common techniques in managing
26 transmission line ROWs involve use of herbicides. Herbicides can be applied directly to
27 vegetation in the ROW, or to cut stump surfaces once trees are felled. Even when applied in
28 uplands, herbicides can be carried in overland runoff to streams or other surface water features.
29 Herbicides can also leach into groundwater under application sites and be carried to surface
30 waters. Herbicides entering aquatic habitats vary in their lethality to aquatic organisms
31 depending on their active ingredient but also on how they are formulated. For example,
32 formulations of the nonselective herbicide glyphosate labeled for use in upland settings are
33 more lethal to aquatic biota than are glyphosate formulations labeled for use in wetlands or near
34 aquatic features (Langeland and Gettys 2015-TN6461).

35 Operation of spray equipment or mowers on ROWs can physically disturb soils, thereby
36 generating small amounts of sedimentation that can enter aquatic habitats (see
37 Section 3.6.2.1.1 for an explanation of the impacts of sedimentation on aquatic biota).
38 Maintenance of service roads on the ROW can also cause small amounts of sedimentation.
39 Heavy equipment traversing streams or wetlands can physically damage aquatic biota and the
40 soils and sediment supporting aquatic biota. The potential for noticeable adverse impacts on
41 aquatic habitats from sedimentation can be readily prevented using BMPs. Physical disturbance
42 of soils and sediments in aquatic habitats by fording equipment can be prevented by use of
43 temporary matting that can be removed once it is longer needed. The NRC staff considered
44 possible impacts of transmission line ROW maintenance on aquatic habitats associated with
45 relicensing of existing LWRs and concluded that impacts would be minimal because they would
46 be infrequent, localized, and temporary (NRC 2024-TN10161).

1 The staff has determined that the impacts of transmission line maintenance on aquatic biota are
2 a Category 1 issue. The staff concludes that as long as the assumptions in the PPE and SPE
3 regarding work in offsite ROWs are met, the impacts can be generically determined to be
4 SMALL. The staff relied on the following PPE and SPE values and assumptions to reach this
5 conclusion:

- 6 • Vegetation in transmission line ROWs would be managed following a plan consisting of
7 integrated vegetation management practices.
- 8 • All ROW maintenance work would be performed in compliance with all applicable laws and
9 regulations.
- 10 • Herbicides would be applied by licensed applicators, and only if in compliance with
11 applicable manufacturer label instructions.
- 12 • BMPs would be used for erosion and sediment control.

13 *3.6.2.2.6 Impingement and Entrainment of Aquatic Organisms*

14 Impingement and entrainment of aquatic organisms is a consideration only for facilities whose
15 operation involves use of intake structures for cooling water. The PPE assumes recirculating
16 cooling-water systems using cooling towers but not using once-through cooling systems that
17 require intake of substantially larger volumes of water. The potential for impingement or
18 entrainment generally increases with the volume of water withdrawn and the velocity of
19 movement through the intake screen. For purposes of regulation under CWA Section 316(b),
20 the EPA defines impingement as the entrapment of all life stages of fish and shellfish on the
21 outer part of an intake structure or against a screening device during periods of water
22 withdrawal (40 CFR 125.83; TN254). The EPA defines entrainment as incorporation of all life
23 stages of fish and shellfish with intake water flow entering and passing through a cooling-water
24 intake structure and into a cooling-water system (40 CFR 125.83). Impingement can immobilize
25 organisms rendering them subject to starvation or predation. Organisms that are entrained may
26 pass through the cooling system and emerge in the discharge but are usually killed or
27 substantially injured in the process. Although the EPA regulatory definitions address only fish
28 and shellfish, plankton, comprising both faunal (zooplankton) and floral (phytoplankton)
29 organisms carried by water currents, may also be entrained. Impacts on plankton can harm fish
30 and shellfish by altering supportive food chains.

31 The PPE includes limits on flow rates at intake structures based on regulatory limits established
32 by EPA in 40 CFR 125.84 (TN254) to protect fish and shellfish. The regulations establish a
33 maximum through-screen velocity of 0.5 ft/s. The total design intake flow must generally be no
34 more than 5 percent of the mean annual flow of rivers or streams and low enough to not disturb
35 natural thermal stratification or turnover in lakes or reservoirs. Thermal stratification is the
36 formation of layers of water of differing temperatures in standing water bodies due to
37 temperature-related differences in water density. Turnover is the shifting of layers in the water
38 column in response to seasonal changes in temperature. Both the stratification and seasonal
39 turnover can be highly influential on the development and survival of aquatic biota. For
40 intakes in tidal water bodies, the regulations limit intake to less than 1 percent of the volume
41 of the water column centered around the opening to the intake structure. The regulations
42 establish additional requirements, including monitoring requirements, to ensure that
43 these rates of intake are protective of fish and shellfish.

44 The NRC staff included a description of the potential impacts of impingement and entrainment
45 of aquatic biota from operation of large LWRs in Section 4.6.1.2 of the License Renewal GEIS

1 (NRC 2024-TN10161). Even though the staff identified potentially significant impacts from
2 impingement and entrainment for operating plants with once-through cooling systems (NRC
3 2024-TN10161), they also noted that substantial reductions of aquatic biota populations did not
4 occur during operation of plants that have cooling towers because of the smaller volume of
5 water intake (NRC 2024-TN10161). Cooling towers require less water intake because they
6 recirculate the same water for multiple cycles of cooling before discharge and replacement.
7 Cooling systems for nuclear as well as non-nuclear power plants operate independently of the
8 fuel or power generation technology; hence, the minimal impacts observed with large LWRs
9 suggest that similarly minimal impacts would result from operation of new reactors using any
10 fuel or technology.

11 The staff has determined that impingement and entrainment of aquatic biota is a Category 1
12 issue. The staff concludes that as long relevant PPE and SPE are met, the impacts can be
13 generically determined to be SMALL. The staff relied on the following PPE and SPE values and
14 assumptions to reach this conclusion:

- 15 • Intakes would comply with regulatory requirements established by EPA in 40 CFR 125.84
16 (TN254) to be protective of fish and shellfish.
- 17 • Best available control technology would be employed in the design of intakes to minimize
18 entrainment and impingement, such as use of screens and intake rates recognized to
19 minimize effects.

20 3.6.2.2.7 Thermal Impacts on Aquatic Biota

21 Operation of power plants requires the disposition of excess heat generated by the fuel but not
22 converted into electricity. Although some new reactors may be air-cooled, whereby the waste
23 heat is transferred to air, others, like most large LWRs, may be water-cooled, whereby the
24 waste heat is transferred to water. The PPE assumes no use of once-through cooling systems,
25 whereby makeup water is withdrawn and passed over heat exchangers only once before being
26 discharged. New reactors within the PPE may however use recirculated-water cooling systems
27 where makeup water is passed over the heat exchangers and run through a cooling tower to
28 dissipate most of its heat content to the air before being recirculated to dissipate more heat in
29 the same way. After recirculation for a specified number of passes (cycles of concentration), the
30 cooling water is discharged as blowdown to a river, lake, or other surface water body (usually
31 the same body that provided the makeup water). The thermal quality of discharges is regulated
32 under CWA Section 316(a), under which the EPA and States can issue thermal variances as
33 part of NPDES permits.

34 If water is discharged at a temperature higher than that of the receiving water, the discharges
35 can affect aquatic biota. Aquatic biota are adapted to seasonal patterns of water temperatures,
36 including seasonal turnover of stratified water column layers. A particularly serious problem is
37 heat shock: fish and other aquatic biota favoring warmer water temperatures congregate in the
38 vicinity of heated water discharges that persist only as long as a power plant is in operation, but
39 are faced with suddenly colder water whenever operations cease for maintenance or refueling.
40 Increased water temperatures can also encourage growth of invasive aquatic species such as
41 hydrilla (*Hydrilla verticillata*) and Eurasian watermilfoil (*Myriophyllum spicatum*).

42 The NRC staff included a description of the potential thermal impacts on aquatic biota from
43 operation of large LWRs in Section 4.6.1.2 of the License Renewal GEIS (NRC 2024-TN10161).
44 Even though staff identified potentially significant impacts from thermal impacts for operating
45 nuclear plants with once-through cooling systems (NRC 2024-TN10161), the staff also
46 concluded that the impacts were minimal from nuclear plants using cooling towers because of

1 the smaller discharge plumes resulting from the reduced volume of water being discharged
2 (NRC 2024-TN10161). Cooling systems operate independently of the fuel or power generation
3 technology; hence, the minimal impacts observed with large LWRs provide evidence that
4 similarly minimal impacts would result from operation of new reactors using any fuel or
5 technology. However, the conclusion in the License Renewal GEIS that impacts would be
6 minimal was reached after a review of a series of existing reactors under known conditions. As
7 discussed in Section 3.4.2.2.7, project-specific reviews included an estimation of the extents of
8 the mixing zones in the receiving water bodies and how the mixing zone may affect aquatic
9 resources under project-specific conditions.

10 The staff concludes that the impact of thermal impacts on aquatic biota is a Category 2 issue.
11 The staff concludes that it is not possible to generically evaluate the potential impacts of the
12 thermal impacts on aquatic ecosystems without first considering project-specific factors. The
13 staff would have to first review the discharge plume analysis (as described in Section 3.4.2.2.7)
14 and the aquatic biota potentially present before being able to reach a conclusion regarding the
15 possible significance of impacts on that biota.

16 However, this issue is relevant only to nuclear power plants that will have discharges (other than
17 stormwater discharges) to surface water during operations. In general, nuclear power plants that
18 do not use water for cooling do not have discharges capable of adversely affecting aquatic
19 biota. For such plants, detailed analysis of thermal impacts on aquatic biota are not necessary.

20 *3.6.2.2.8 Other Effects of Cooling-Water Discharges on Aquatic Biota*

21 The NRC staff recognizes that discharges of cooling-tower blowdown water from operating
22 nuclear power plants can release nonradiological contaminants to aquatic habitats (NRC 2024-
23 TN10161). The License Renewal GEIS discusses copper introduced into cooling water when it
24 passes over copper alloy tubes used in a few existing LWRs but notes that those tubes have
25 been replaced by tubes made of other metals such as titanium as mitigation. The PPE therefore
26 assumes that copper alloy tubes would not be used in new reactors. Operators of nuclear power
27 plants that use cooling towers typically add biocides to the cooling water to prevent the buildup
28 of microorganisms, algae, and invasive species such as zebra mussels and Asiatic clams that
29 can interfere with water conveyance. As explained in the License Renewal GEIS (NRC 2024-
30 TN10161), NPDES permits include restrictions on biocide use to protect non-target organisms in
31 receiving waters such as indigenous mussels and fish. Various methods are available to
32 minimize biocide use in order to comply with NPDES permits. Cooling water can also affect
33 dissolved oxygen levels and cause eutrophication in receiving waters, and discharges can
34 cause localized areas of gas supersaturation (gas bubbles) that are detrimental to aquatic biota,
35 but the staff has concluded in the License Renewal GEIS that the impacts would be minor (NRC
36 2024-TN10161). However, development of a bounding set of plant parameters for the PPE or
37 site parameters for the SPE that are adequately protective of aquatic biota is not possible,
38 because compliance with standards set forth in an NPDES permit would not necessarily result
39 in only minimal impacts on aquatic biota in all settings. This is especially true for discharges to
40 waters not under the CWA jurisdiction and hence not requiring an NPDES permit.

41 The staff therefore concludes that the impact of cooling-water discharges on aquatic biota is a
42 Category 2 issue. The staff concludes that it is not possible to generically evaluate the potential
43 impacts of the discharges on aquatic ecosystems without first considering project-specific
44 factors. The staff would have to first review the discharge plume analysis (as described in
45 Section 3.4.2.2.7) and the aquatic biota potentially present before being able to reach a
46 conclusion regarding the possible significance of impacts on that biota.

1 However, this issue is relevant only to nuclear power plants that will have discharges (other than
2 stormwater discharges) to surface water during operations. In general, nuclear power plants that
3 do not use water for cooling do not have discharges capable of adversely affecting aquatic
4 biota. For such nuclear power plants, detailed analysis of cooling water discharges on aquatic
5 biota is not necessary.

6 *3.6.2.2.9 Water Use Conflicts with Aquatic Resources*

7 The water demands for operating a nuclear reactor are typically low unless water is used for
8 cooling purposes. The more substantive demands for cooling water could however reduce water
9 levels in some aquatic habitats. Recirculating cooling-water systems withdraw water and
10 repeatedly cycle it through multiple passes over the heat exchangers, evaporating a portion of
11 the water in each cycle. Substantially less water is therefore discharged back to the source
12 water body than is withdrawn. The reduced water availability can reduce flow in streams and
13 rivers, reduce water elevations in lakes and reservoirs, contract shorelines, and periodically dry
14 out shallow areas and wetlands. As discussed in Section 3.5.2.2.7, the assumption in the SPE
15 regarding water use and surface water availability applies to flowing systems. Water
16 withdrawals from streams or rivers would constitute less than 3 percent of the 95 percent
17 exceedance daily flow (essentially, extreme low flow conditions), which would ensure that
18 aquatic fauna and flora in riverine habitats would not experience adverse effects caused by
19 hydrological changes during droughts.

20 The staff recognizes that it is not as easy to estimate the potential impacts of water withdrawals
21 on non-flowing surface water bodies. The PPE value of 6,000 gpm (Section 3.4.1) for total plant
22 water demand applies to non-flowing water bodies such as the Great Lakes, the Gulf of Mexico,
23 oceans, estuaries, and intertidal zones. The staff recognizes that the quantity of water
24 withdrawals for new reactors from very large water bodies such as oceans, the Great Lakes,
25 and the Gulf of Mexico would not result in a reduction in water levels or hydroperiod that could
26 adversely affect the ecological integrity of aquatic habitats or biota. However, water withdrawals
27 from smaller or more sensitive non-flowing fresh water bodies such as inland lakes and
28 reservoirs, estuaries, and intertidal zones could require project-specific review of the potential
29 impacts of changes in water level and hydroperiod (Section 3.5.2.2.7). The staff assumes that
30 applicants relying on the generic analysis can demonstrate that hydroperiod changes are within
31 historical annual or seasonal fluctuations. If the applicant cannot so demonstrate, project-
32 specific analysis would be needed to determine potential impacts on aquatic habitats.

33 The water losses resulting from operation of cooling-water systems for power plants are unlikely
34 to result in substantial changes to most aquatic ecosystems under normal conditions but could
35 be noticeable during times of extended drought. In the License Renewal GEIS, the NRC staff
36 determined that evaluating the potential impacts of water use conflicts with aquatic biota
37 requires a project-specific analysis for the individual reactor undergoing relicensing (NRC 2024-
38 TN10161). However, for this GEIS (unlike in the License Renewal GEIS), the staff relies on
39 assumptions in the PPE and SPE regarding water use that the staff developed to limit potential
40 adverse effects on aquatic habitats. The staff has therefore determined that water use conflicts
41 with aquatic biota are a Category 1 issue. The staff concludes that as long as relevant values
42 and assumptions in the PPE and SPE regarding cooling systems (Section 3.6.1) and
43 assumptions regarding surface water withdrawal (Section 3.4.1) are met, including that it is
44 possible to demonstrate that hydroperiod changes are within historical or seasonal fluctuations,
45 the impacts can be generically determined to be SMALL. The staff relied on the following PPE
46 and SPE values and assumptions to reach this conclusion:

- 1 • If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in
2 height; and equipped with drift eliminators.
- 3 • Any makeup water for the cooling towers would be fresh water (less than 1 ppt salinity).
- 4 • Total plant water demand would be less than or equal to a daily average of 6,000 gpm.
- 5 • If water is withdrawn from flowing waterbodies, average plant water withdrawals would not
6 reduce flow by more than 3 percent of the 95 percent exceedance daily flow and would not
7 prevent maintenance of applicable instream flow requirements.
- 8 • Any water withdrawals would be in compliance with any EPA or State permitting
9 requirements.
- 10 • Applicants would be able to demonstrate that hydroperiod changes are within historical or
11 seasonal fluctuations.

12 *3.6.2.2.10 Important Species and Habitats*

13 As noted for building, important species and habitats that meet the NRC criteria (NRC 2024-
14 TN7081) on a given site can only be determined once the site is identified. Because of differing
15 regulations and sensitivities to impacts, two separate issues are analyzed below regarding
16 important species and habitats: (1) resources regulated under the ESA (16 U.S.C.
17 §§ 1531 et seq.; TN1010) and the Magnuson-Stevens Act (16 U.S.C. §§ 1801 et seq.; TN1061),
18 and (2) other important species and habitats.

19 Resources Regulated under the Endangered Species Act and Magnuson-Stevens Act

20 For the same reasons noted for building in Section 3.6.2.1.4, the staff has determined that
21 operational impacts on resources regulated under the ESA and Magnuson-Stevens Act are a
22 Category 2 issue. Because of their potential for future regulation over the course of a licensing
23 action, the Category 2 designation extends also to proposed and candidate species designated
24 under the ESA. Even if the applicable assumptions in the PPE and SPE are met, the NRC staff
25 is unable to determine the significance of potential impacts without consideration of project-
26 specific factors, including the specific species and habitats affected and the types of ecological
27 changes potentially resulting from each specific licensing action. Furthermore, the ESA and
28 Magnuson-Stevens Act require consultations for each licensing action that may affect regulated
29 resources.

30 Other Important Species and Habitats

31 The analyses presented in Section 3.6.2.1.4 also apply to operations and suggest that the
32 potential impacts on other important species and habitats from operation of a new reactor that
33 meets the PPE and SPE would likely be minimal regardless of site location. The NRC staff is
34 confident in this conclusion for any site that meets the assumptions in the PPE and SPE
35 associated with cooling systems and meets the regulatory limits in 40 CFR 125.84 (TN254) and
36 requirements associated with applicable NPDES permits, even without identifying the important
37 species specifically present on a given site. The assumptions in the PPE and SPE limit the
38 potential for adverse impacts, especially limitations on the amount of water used and the
39 assumed absence of sensitive habitat types potentially containing rare species. Licensees
40 would also likely communicate with multiple State and local authorities, who may recommend
41 following routine BMPs to prevent the introduction of invasive species to affected water bodies.

1 The staff has therefore determined that operational impacts on important species and habitats
2 other than those regulated under the ESA and Magnuson-Stevens Act are a Category 1 issue.
3 The staff concludes that as long as the applicable assumptions in the PPE and SPE are met,
4 the impacts can be generically determined to be SMALL. The staff relied on the following PPE
5 and SPE values and assumptions to reach this conclusion:

- 6 • Applicants would communicate with State natural resource or conservation agencies
7 regarding aquatic fish, wildlife, and plants and implement mitigation recommendation of
8 those agencies.

9 **3.7 Historic and Cultural Resources**

10 **3.7.1 Baseline Conditions**

11 Historic and cultural resources are the remains of past human activities and include precontact
12 (i.e., prehistoric) and historic era archaeological sites, districts, buildings, structures, and
13 objects. Precontact era archaeological sites pre-date the arrival of Europeans in North America
14 and may include small temporary camps, larger seasonal camps, large village sites, or
15 specialized-use areas associated with fishing or hunting or with tool and pottery manufacture.
16 Historic era archaeological sites post-date European contact with American Indian Tribes and
17 may include farmsteads, mills, forts, residences, industrial sites, and shipwrecks. Architectural
18 resources include buildings and structures. Historic and cultural resources also include
19 elements of the cultural environment such as landscapes, sacred sites, and other resources that
20 are of religious and cultural importance to American Indian Tribes, such as traditional cultural
21 properties (TCPs) important to a living community of people for maintaining its culture.⁷

22 Within the scope of the National Historic Preservation Act of 1966 (NHPA; 54 U.S.C.
23 §§ 300101 et seq.; TN4157), a historic or a cultural resource is considered a historic property if
24 it has met at least one of the four criteria for listing or is listed on the NRHP.⁸ The NRHP is the
25 Nation’s official list recognizing buildings, structures, objects, sites, and districts of national,
26 State, or local places that are historically significant and worthy of preservation. The list is
27 maintained by the U.S. National Park Service in accordance with its regulations in 36 CFR
28 Part 60 (TN1682). The NRHP criteria to evaluate the eligibility of a property are set forth in
29 36 CFR 60.4.⁹ In this regard, a historic property is at least 50 years old, although exceptions can
30 be made for properties determined to be of “exceptional significance.”¹⁰

⁷ According to U.S. National Park Service (NPS) guidance, a “traditional cultural property” is associated “with the cultural practices or beliefs of a living community that (a) are rooted in that community’s history, and (b) are important in maintaining the continuing cultural identity of the community” (Parker and King 1998-TN5840).

⁸ Historic property is defined in 36 CFR 800.16(l)(1) (TN513) as “... any prehistoric or historic district, site, building, structure, or object included in, or eligible for inclusion in, the [NRHP] maintained by the Secretary of Interior. This term includes artifacts, records, and remains that are related to and located within such properties.” As defined in 36 CFR 800.16(l)(2), “The term eligible for inclusion in the National Register includes both properties formally determined as such in accordance with regulations of the Secretary of the Interior and all other properties that meet National Register listing criteria.”

⁹ The eligibility of a resource for listing on the NRHP is evaluated based on four criteria and is articulated in 36 CFR 60.4 (TN1682), as follows: Criterion a: Associated with events that have made a significant contribution to broad patterns of our history; Criterion b: Associated with the lives of persons significant in our past; or Criterion c: Embodies the distinctive characteristics of a type, period, or method of construction, or represents the work of a master, or that possesses high artistic values, or that represents a significant and distinguishable entity whose components may lack individual distinction; and Criterion d: Has yielded, or is likely to yield, information important to prehistory and history.

¹⁰ 36 CFR 60.4(g).

1 3.7.1.1 National Historic Preservation Act and NEPA

2 NEPA (42 U.S.C. §§ 4321 et seq.; TN661) requires Federal agencies to consider the potential
3 effects of their actions on the “affected human environment,” which includes “aesthetic, historic,
4 and cultural resources as these terms are commonly understood, including such resources as
5 sacred sites” (CEQ and ACHP 2013-TN4603). For NEPA compliance, impacts on cultural
6 resources that are not eligible for or listed on the National Register would also need to be
7 considered (CEQ and ACHP 2013-TN4603).

8 Section 106 of the NHPA (54 U.S.C. §§ 300101 et seq.; TN4157) requires Federal agencies to
9 take into account the effects of their undertakings¹¹ on historic properties and consult with the
10 appropriate consulting parties as defined in 36 CFR 800.2 (TN513). Consulting parties consist
11 of the State Historic Preservation Officer (SHPO), Advisory Council on Historic Preservation
12 (ACHP), Tribal Historic Preservation Officer (THPO), Indian Tribes that attach cultural and
13 religious significance to historic properties on a government-to-government basis, and other
14 parties that have a demonstrated interest in the effects of the undertaking, including local
15 governments and the public, as applicable. The ACHP is an independent Federal agency that
16 oversees the NHPA Section 106 review process in accordance with its implementing regulations
17 in 36 CFR Part 800, *Protection of Historic Properties* (TN513). Issuing a license for a new
18 reactor is an undertaking that requires compliance with NHPA Section 106.

19 Historic and cultural resources vary widely from site to site; there is no generic way of
20 determining their existence or significance. Historic and cultural resource impacts must be
21 analyzed on a project-specific basis, and the NRC is required to complete a NEPA and NHPA
22 Section 106 review (NRC 2024-TN7081) prior to issuing a license.¹²

23 For a specific application, in accordance with 36 CFR Part 800 (TN513), the NRC would
24 establish the undertaking, identify consulting parties, and determine the scope of potential
25 effects from the undertaking by defining the area of potential effect (APE). The APE for a new
26 reactor is the area that may be directly (e.g., physical) or indirectly (e.g., visual and auditory)
27 affected by activities during construction or plant operations. The APE typically encompasses
28 the nuclear power plant site where onsite ground-disturbing activities may occur, its immediate
29 environs including viewshed, and in-scope transmission lines. The APE may extend beyond the
30 nuclear plant site and transmission lines when building and operation activities may affect
31 historic properties at offsite locations. The NRC will rely on cultural resource investigations of
32 the APE and NRHP-eligibility evaluations completed by qualified professionals, who meet the
33 Secretary of Interior’s standards at 36 CFR Part 61 (TN4848), in consultation with the SHPO
34 and other consulting parties to determine whether historic properties are present in the APE.

35 When preparing project-specific supplements to this GEIS (see 36 CFR 800.8(c); TN513), the
36 NRC’s practice is to fulfill the requirements of NHPA Section 106 through the NEPA review
37 process. Additional historic and cultural resource laws could apply if a proposed project is
38 located on Federal lands (see Appendix F).

¹¹ An undertaking is defined as “a project, activity, or program funded in whole or in part under the direct or indirect jurisdiction of a Federal agency, including those carried out by or on behalf of a Federal agency; those carried out with Federal financial assistance; and those requiring a Federal permit, license, or approval” (see CFR 800.16(y); TN513).

¹² The NRC is required to comply with the NHPA including the anticipatory demolition clause, Section 110(k) of the NHPA (54 U.S.C. 306113). See Section 4.6 of RG 4.2 (NRC 2022-TN7081)

1 **3.7.2 Historic and Cultural Resources Impacts**

2 The NRC considers impacts on historic and cultural resources in this GEIS through its NEPA
3 requirements in 10 CFR Part 51 (TN250). Impacts may be direct, indirect, visual, or auditory.
4 Any new construction activity, including the building and operation of a new reactor, parking
5 areas, access roads, or transmission lines, is particularly important to an analysis of impacts on
6 historic and cultural resources. Building- and operation-related ground-disturbing activities or
7 alterations to buildings or structures that are NRHP-eligible can result in direct effects on
8 archaeological sites, aboveground resources, and TCPs. Introduction of noise or visual
9 intrusions (i.e., use of reflective materials, tall structures, building design that is inconsistent with
10 surrounding environment) that are either temporary or permanent in nature can result in both
11 direct and indirect effects on aboveground resources and TCPs.

12 The NRC staff will rely on preliminary recommendations made by qualified professionals, who
13 meet the Secretary of Interior's standards at 36 CFR Part 61 (TN4848), in its determination of
14 whether historic properties will be or will not be adversely affected. For a historic or cultural
15 resource that does not meet the criteria to be considered a historic property under the NHPA,
16 the NRC will assess whether there are any potential significant impacts on this resource through
17 the NEPA process.

18 If historic and cultural resource investigations do not identify historic properties within the APE,
19 the NRC will conclude a finding of *no historic properties affected* in accordance with 36 CFR
20 800.4(d)(1) (TN513). The NRC will provide documentation of these findings for review and
21 concurrence to SHPO/THPO, American Indian Tribes, and interested members of the public in
22 accordance with documentation standards set forth in 36 CFR 800.11(d).

23 If historic properties have been identified but would not be impacted by the proposed
24 construction and operation activities, or if the impacts can be either minimized or avoided, the
25 NRC staff will apply the criteria of *no adverse effect* on historic properties outlined in 36 CFR
26 800.5(b). The NRC will provide documentation of these findings for review and concurrence to
27 SHPO/THPO, American Indian Tribes, and interested members of the public in accordance with
28 documentation standards set forth in 36 CFR 800.11(e).

29 If historic properties have been identified and cannot be avoided by the proposed construction
30 and operation activities, the NRC staff will apply the criteria of *adverse effect* to historic
31 properties outlined in 36 CFR 800.5(a) (TN513). Adverse effects result when an undertaking
32 may alter, directly or indirectly, any of the characteristics of a historic property that qualify the
33 property for inclusion on the NRHP in a manner that would diminish the integrity of the
34 property's location, design, setting, materials, workmanship, feeling, or association. These
35 include physical destruction or alteration of a property's characteristics that contribute to its
36 historic significance. Examples of adverse effects are described in 36 CFR 800.5(a)(2).

37 The NRC staff will provide documentation of this finding to the ACHP, SHPO/THPO, Indian
38 Tribes, and interested members of the public for review and concurrence in accordance with
39 documentation standards set forth in 36 CFR 800.11(e) (TN513). The NRC will consult with the
40 same parties regarding the resolution of adverse effects and develop measures to avoid,
41 minimize, or mitigate the adverse effects. Such measures to address adverse effects are
42 typically documented in a Memorandum of Agreement or a Programmatic Agreement.

43 **3.7.2.1 Environmental Consequences of Construction**

44 The NRC staff identified one environmental issue:

- 45 • construction impacts on historic and cultural resources

1 Most impacts on historic and cultural resources would occur during the construction phase.
2 Impacts would occur primarily from both onsite and offsite preparation-related ground-disturbing
3 activities (e.g., land clearing, grading and excavation, and road work) and the construction of
4 safety-related facilities such as the nuclear island and non-safety-related facilities such as
5 cooling towers, administration buildings, parking lots, switchyards, pipelines, access roads, and
6 transmission lines. Archaeological sites are sensitive to disturbance and even a small amount of
7 ground disturbance (e.g., ground clearing and grading) could affect a significant resource. Much
8 of the information contained in an archaeological site is derived from the spatial relationships
9 between soil layers and associated artifacts. Once these spatial relationships are altered, they
10 can never be reclaimed (NRC 2024-TN10161). Alterations to the visual setting, whether
11 temporary or permanent, could also affect other types of historic and cultural resources such as
12 cultural landscapes, architectural resources, or TCPs.

13 Direct and indirect impacts from construction on historic and cultural resources and historic
14 properties can be avoided or minimized if the undertaking is modified or if the applicant takes
15 the appropriate mitigation measures. Impacts on archaeological resources can typically be
16 avoided by re-siting ground-disturbing activities. Minimization efforts can include but are not
17 limited to use of geomembranes or geotextile fabric to protect and/or stabilize archaeological
18 deposits, construction monitoring, and development of inadvertent discovery plans. Direct
19 impacts on aboveground resources can be avoided by not altering any of the exterior or interior
20 physical components of the building that contribute to its NRHP eligibility. Indirect impacts can
21 be avoided by existing natural topography or vegetation screening. Minimization efforts for
22 aboveground resources can include but are not limited to vegetation restoration, creative
23 landscaping, integration of structures with the surrounding environment, minimization of the use
24 of bright flashy surfaces, and other considerations related to overall design. Adaptive reuse of
25 an aboveground resource is often viewed as a beneficial effect depending on the scope of
26 modifications necessary.

27 If impacts on a historic property cannot be avoided or minimized, they can be mitigated through
28 the development of mitigation measures that are formalized in an Memorandum of Agreement
29 or a Programmatic Agreement. Historic and cultural resources are nonrenewable, hence certain
30 activities depending upon the resource and its significance can result in an irretrievable loss of
31 the resource. Mitigation efforts for archaeological sites typically entail data recovery and
32 controlled excavation if in situ stabilization is not possible. Despite being a form of mitigation,
33 archaeological data recovery results in an irretrievable loss of the historic and archaeological
34 information. Mitigation efforts for aboveground resources can include but are not limited to
35 formal documentation in a Historic American Buildings Survey/Historic American Engineering
36 Record (HABS/HAER) study and public education activities. Development of avoidance,
37 minimization, and mitigation measures for adverse effects on TCPs must be done in
38 consultation with the tribe or community that has an interest in that TCP.

39 This GEIS does not identify any specific sites for NRC licensing actions that would trigger NHPA
40 Section 106 consultation requirements that are normally conducted during project-specific
41 licensing reviews. Development of this GEIS is not a licensing action; it does not authorize the
42 building or operation of any new reactor. Because the analysis requires project-specific
43 information, the impact of building a new reactor on historic and cultural resources is a
44 Category 2 issue.

45 3.7.2.2 *Environmental Consequences of Operation*

46 The NRC staff identified one environmental issue:

- 47 • operation impacts on historic and cultural resources

1 Continued operations can affect historic and cultural resources through ground-disturbing
2 activities associated with plant operations and ongoing maintenance of existing onsite and
3 offsite facilities, roads, and transmission lines; and changes to the appearance of the nuclear
4 power plant and transmission lines. Impacts from operation and maintenance activities on
5 historic and cultural resources and historic properties can be avoided or minimized through the
6 development of historic and cultural resource protection procedures. These procedures outline
7 stop work and notification protocols in the event that archaeological materials or human remains
8 are inadvertently discovered during building, operation, or maintenance activities. The
9 procedures should follow State burial laws if the new reactor is sited on non-Federal land or the
10 Native American Graves Protection and Repatriation Act (25 U.S.C. §§ 3001 et seq.; TN1686) if
11 it is sited on Federal land. Development of avoidance, minimization, and mitigation measures
12 (i.e., stop work and notification procedures) for addressing adverse effects on historic properties
13 must be done in consultation with SHPO/THPO and Indian Tribes.

14 NHPA Section 106 consultation requirements are normally conducted during project-specific
15 licensing reviews. This GEIS is not a licensing action; it does not authorize the construction or
16 operation of any new reactor. Because the analysis requires project-specific information, the
17 impact of operating a new reactor on historic and cultural resources is a Category 2 issue.

18 **3.8 Environmental Hazards**

19 **3.8.1 Radiological Environment**

20 *3.8.1.1 Baseline Conditions and PPE/SPE Values and Assumptions*

21 Radiological exposures from nuclear power plants include offsite doses to members of the
22 public and onsite doses to the workforce. Each of these impacts is common to all commercial
23 U.S. reactors. The Atomic Energy Act of 1954 (42 U.S.C. §§ 2011 et seq.; TN663) requires the
24 NRC to promulgate, inspect, and enforce standards that provide an adequate level of
25 protection for public health and safety and the environment. The NRC continuously evaluates
26 the latest radiation protection recommendations from international and national scientific
27 bodies to establish the requirements for nuclear power plant licensees. The NRC has
28 established multiple layers of radiation protection limits to protect the public from potential
29 health risks related to exposure to radioactive materials effluent discharges from nuclear
30 power plant operations. If the licensees exceed a certain fraction of these dose levels in a
31 calendar quarter, they are required to notify the NRC, investigate the cause, and
32 initiate corrective actions within the specified time frame.

33 An assessment of the radiological environment for a proposed site on which to build and
34 operate a nuclear power plant would depend on the characteristics of the site relative to prior
35 and adjacent activities. If the site has not been used for any prior industrial activities, i.e., it is a
36 greenfield site, then the environment is only affected by natural radioactive background.
37 However, if the footprint of the proposed nuclear power plant is within an existing licensed
38 nuclear facility's property, there is an adjacent or nearby nuclear facility (e.g., nuclear power
39 plant, nuclear fuel cycle facility, or another NRC-licensed, Agreement State-licensed, or Federal
40 nuclear facility), or the site was a former nuclear facility, then radiological effects from such
41 nuclear facilities, such as direct radiation or residual radionuclides in the soil on the proposed
42 site, should already have been assessed for their impacts with respect to regulatory
43 requirements (10 CFR 20.1101, CFR 20.1201, 10 CFR 20.1301, 10 CFR Part 20 Appendix B
44 [10 CFR Part 20-TN283]).

1 Existing licensed nuclear facilities have a REMP. The limits for all radiological releases are
2 specified in a nuclear power plant’s Offsite Dose Calculation Manual, and these limits are
3 designed to meet Federal standards and requirements. The REMP includes monitoring of the
4 aquatic environment (fish, invertebrates, and shoreline sediment), atmospheric environment
5 (airborne radioiodine, gross beta, and gamma), terrestrial environment (vegetation), and direct
6 radiation. These reports have shown that doses to individuals around the nuclear site were a
7 small fraction of the limits specified in Federal environmental radiation standards (10 CFR
8 Part 20 [TN283], 10 CFR Part 50 [TN249], Appendix I, and 40 CFR Part 190 [TN739]).

9 In an Atomic Safety Licensing Board initial decision for the North Anna ESPs (ASLB 2007-
10 TN6826) it was ruled that the limits in 40 CFR 190.10 (TN739)—and hence 10 CFR 20.1301(e)
11 (TN283)—do not apply to non-LWRs. EPA’s radiation protection standard applies to operations
12 within the “uranium fuel cycle,” which it defines as the processes involved in the production of
13 uranium fuel, “generation of electricity by a light-water cooled nuclear power plant using uranium
14 fuel,” and reprocessing spent uranium fuel. This definition excludes gas-cooled, molten salt-
15 cooled, liquid metal-cooled, and heat pipe-cooled nuclear power reactors, regardless of fuel
16 composition. Therefore, under the current regulatory scheme, non-LWR nuclear power reactors
17 would not be subject to the dose limits of 10 CFR 20.1301(e) for the applicable environmental
18 radiation standards in 40 CFR 190.10. In addition, 10 CFR Part 50 (TN249), Appendix I,
19 provides “numerical guidance on design objectives for [LWRs] to meet the requirements that
20 radioactive material in effluents released to unrestricted areas be kept [ALARA].” No similar
21 specific numerical guidance on design objectives currently exist for non-LWRs. However, the
22 staff assumes that the ALARA design objective requirements in 10 CFR 50.34a (see below) and
23 radiation protection programs under 10 CFR 20.1101 (TN283), which are applicable to
24 non-LWR licensees, will ensure that radioactive effluent releases from non-LWRs should remain
25 below applicable regulatory limits. The use of 40 CFR Part 190 (TN739) limits and the results in
26 Table 3-2 to Table 3-6 are provided as examples for demonstrating small impacts.

27 *3.8.1.1.1 Regulatory Requirements and Guidance*

28 Nuclear power reactors in the United States must be licensed by the NRC and must comply with
29 NRC regulations and conditions specified in the license in order to operate. The application
30 must provide assurance that the limits on the release of radioactive liquid and gaseous effluents
31 during normal operation (including expected operational occurrences) will meet the
32 requirements in 10 CFR Part 20 (TN283), Subpart B, “Radiation Protection Programs,”
33 Subpart C, “Occupational Dose Limits for Adults,” and Subpart D, “Radiation Dose Limits for
34 Individual Members of the Public.” In addition, a new reactor applicant would need to meet the
35 following 10 CFR Part 20 and 10 CFR Part 50 (TN249) regulations concerning radioactive
36 effluent releases:

- 37 • applicable 10 CFR Part 20, Appendix B (TN283) regulatory standards for discharge
38 radioactive effluents;
- 39 • the requirements in 10 CFR 50.34a, “Design objectives for equipment to control releases of
40 radioactive material in effluents—nuclear power reactors” (TN249); and
- 41 • the special license conditions a reactor design shall meet to minimize the radiological
42 impacts associated with plant operations, as provided in 10 CFR 50.36a, “Technical
43 specifications on effluents from nuclear power reactors” (TN249).

44 Additional details and discussion of the radiation protection regulatory requirements to be
45 addressed in a new reactor application, excluding Appendix I to 10 CFR Part 50 (TN249), which
46 only applies to LWRs, can be found in Section 3.9.1.1, Regulatory Requirements, of Revision 2

1 to NUREG-1437, *Generic Environmental Impact Statement for License Renewal of Nuclear*
2 *Plants* (NRC 2024-TN10161), which is incorporated by reference.

3 The PPE assumes that the application contains sufficient technical information, both in scope
4 and depth, for the NRC staff to complete the detailed technical review and render an
5 independent assessment with regard to applicable regulatory requirements and the protection of
6 public health, safety, and security. The level of detail provided in each section of the Final
7 Safety Analysis Report/Preliminary Safety Analysis Report is expected to be commensurate
8 with the safety significance of the topic. The PPE also assumes that the staff will find the
9 application to be in compliance with the above regulations that will ensure that effluent release
10 limits will be met during normal operations for the life of the plant.

11 3.8.1.1.2 Radiological Exposure Pathways

12 There are various environmental pathways by which radiation and radioactive effluents can be
13 transmitted from a reactor to living organisms, assuming there are radiological effluent releases.
14 The scope of this radiological health evaluation for the dose to the maximally exposed individual
15 (MEI) and to the population includes consideration of (1) the pathways by which gaseous and
16 liquid radioactive effluents can be transported to individual receptors (MEI, construction workers,
17 and occupational workers) along with the surrounding population, and (2) the location of these
18 receptors.

19 For the radiological gaseous effluent releases, the following exposure pathways may exist:


- 20 • immersion in airborne activity in the plume;
- 21 • inhalation of airborne activity in the plume;
- 22 • direct radiation exposure from deposited activity on the ground; and
- 23 • ingestion of locally grown meats, fruits, vegetables, and milk from the absorption of the
24 released radionuclides into the production of major types of foods within 80 km (50 mi) of
25 the plant.

26 The radiological liquid effluent exposure pathways may include the following:

- 27 • ingestion of water from downstream sources;
- 28 • ingestion of aquatic organisms as food (i.e., fish and invertebrates);
- 29 • ingestion of locally grown meats, fruits, vegetables, and milk within 80 km (50 mi) of the
30 plant that is irrigated by water drawn from a body of water into which the liquid effluent is
31 discharged; and
- 32 • radiation exposure from swimming and boating activities in the same body of water.


33 Similar pathways exist to expose nonhuman biota to the radiological effluent releases from a
34 reactor. Radiological exposure for construction and occupational workers is expected to be from
35 inhalation of the airborne plume, direct radiation from deposited plume activity on the ground or
36 from radiation sources due to byproduct material devices used during construction, and from the
37 plant or other co-located nuclear facility operations. In addition, there is the potential for these
38 receptors to be exposed to radionuclides via the ingestion of water from downstream sources if
39 they are the plant's potable water source.

1 Representative diagrams of the radiological exposure pathways to be considered are provided
2 in Figure 3-2 for human exposure and Figure 3-3 for nonhuman exposure.



3
4
5

Figure 3-2 Representative Radiological Exposure Pathways to Human.
Source: Modified from Soldat et al. 1974-TN710.



1
2
3

Figure 3-3 Representative Radiological Exposure Pathways to Nonhuman Biota.
 Source: Modified from Soldat et al. 1974-TN710.

1 3.8.1.2 *Radiological Environment Impacts*

2 This section characterizes the environmental impacts of the liquid and gaseous effluent
3 releases, the onsite radiological waste management systems, solid low-level radioactive waste
4 management (LLRW), and onsite storage of spent fuel. This analysis includes assessing
5 potential radiological impacts on construction workers as well as radiological impacts on
6 humans (occupational workers and members of the public) and nonhuman biota from operation
7 of a new reactor. Building a nuclear power station is a project that may affect construction
8 workers as a result of direct radiation and radiological releases from co-located operating
9 nuclear facilities. Radiological health impacts on occupational workers can occur from operation
10 of the radioactive waste systems, onsite storage of waste, and from operation of the nuclear
11 power station. The impacts on members of the public and nonhuman biota can come from the
12 ingestion of food and water, external exposure from water immersion, inhalation of airborne
13 radionuclides, and external exposure to immersion in gaseous effluent plume.

14 3.8.1.2.1 *Environmental Consequences of Construction*

15 The NRC staff identified one environmental issue associated with construction:

- 16 • radiological dose to construction workers.

17 If the site for the new reactor is a greenfield site (i.e., no adjacent or nearby nuclear facilities),
18 then there are no potential radiation exposure pathways and no analysis of construction worker
19 dose is necessary. For sites that have adjacent nuclear facilities (LWRs, other reactors,
20 independent spent fuel storage installation [ISFSIs], nuclear research facilities, nuclear fuel
21 cycle facilities, etc.) that are already operational, potential sources of radiation exist that will
22 expose construction workers to radiation during the site preparation and construction phases of
23 building. Similarly, if the site for the new reactor is a brownfield site (i.e., a site characterized by
24 the potential presence of hazardous substances, pollutants, or contaminants; EPA 2021-
25 TN6848) potential sources of radiation exist that could expose construction workers to radiation
26 during the site preparation and construction phases of building. If a reactor building could hold
27 multiple cores, it is also assumed that once the first reactor core became critical, construction on
28 any other modules would be performed by properly trained and qualified radiation workers
29 whose radiation exposure would be controlled under the regulatory limits of 10 CFR 20.1201
30 (TN283).

31 New reactors could be manufactured at an offsite location and either major components or, if
32 small enough, the complete reactor system with a fueled subcritical core, could be delivered to
33 the site. Thus, the onsite time required for construction and installation of a packaged reactor
34 system is expected to be noticeably less than that for a large LWR employing traditional
35 construction methods. This offsite manufacturing process reduces radiation exposures to
36 construction workers by reducing the amount of time they would be working near operating
37 units.

38 Construction worker radiation doses must remain below the radiation dose limit for individual
39 members of the public (100 millirems/year [mrem/yr] [10 CFR 20.1301; TN283]) pursuant to
40 10 CFR Part 20, Subpart D (TN283), "Radiation Dose Limits for Individual Members of the
41 Public." Because of the variability in new reactor designs, power levels, and timeframes for the
42 construction stage, the potential radiation exposure levels could range from not measurable to
43 close to the 100 mrem/yr regulatory limit. It is also expected that the applicant, if issued a
44 license, would mitigate the construction worker radiation exposures by following radiation

1 protection best practices to maintain radiation dose ALARA standards in accordance with
 2 10 CFR 20.1101 (TN283), "Radiation Protection Programs."

3 New reactor licensing actions for LWRs have shown that the anticipated radiological doses to
 4 construction workers would be within regulatory limits for members of the public, as shown in
 5 Table 3-2. These results show that even for sites with co-located nuclear power plants, dose
 6 levels are generally significantly below 100 mrem/yr. The only exception is for the Fermi 3
 7 licensing action, which involved an anticipated dose slightly less than 100 mrem/yr, and this was
 8 in part due to the type of reactor in operation at Fermi 2 and having an ISFSI adjacent to the
 9 Fermi 3 construction site that would have a number of storage casks in place during the
 10 construction time frame (see Section 4.9 of NRC 2013-TN6436). Therefore, it is important that
 11 exposure pathways from any adjacent or nearby nuclear facility, whether licensed by the NRC,
 12 an Agreement State, or if next to another Federal nuclear facility, be properly accounted for
 13 when assessing annual doses to construction workers.

14 **Table 3-2 Construction Worker Individual and Collective Doses**

| Site Name | Worker Population | Individual Construction Worker Dose (mrem/yr) | Cumulative Construction Worker Dose (person-rem/yr) |
|--|-------------------|---|---|
| Clinton Exelon ESP (NRC 2006-TN672) | 3,150 | 25 | 80 |
| Grand Gulf ESP (NRC 2006-TN674) | 3,150 | 36 | 112 |
| North Anna Power Station Unit 3 ESP (NRC 2010-TN6) | 3,500 | 29 | 102 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 3,950 | 38.81 | 4.6 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 5,950 | 19 | - |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 3,600 | 1.2 | 4.7 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 3,300 | 2.7 | - |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 4,953 | 2.5 | - |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 3,500 | 26.3 | 92 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 2,900 | 96.6 | - |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 2,100 | 0.4 | 0.83 |
| PSEG ESP (NRC 2015-TN6438) | 4,100 | 18.7 | 77 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 2,800 | 6 | 17 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 3,950 | 16.4 | 10.3 |
| Clinch River ESP (NRC 2019-TN6136) | 3,300 | 53 | 170 |

15 Based on these considerations, the NRC concludes that radiological impacts during
 16 construction would be SMALL for all new reactors independent of power level or design and the
 17 doses would be less than the regulatory limits, which will be demonstrated in the application.
 18 This is a Category 1 issue. The staff relied on the following PPE assumptions to reach this
 19 conclusion:

- 20 • For protection against radiation, the applicant must meet the regulatory requirements of:
 - 21 – 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a
 - 22 license
 - 23 – 10 CFR 20.1201 Occupational dose limits for adults

- 1 – 10 CFR 20.1301 Dose limits for individual members of the public
- 2 – Appendix B of 10 CFR Part 20 Annual Limits on Intake (ALIs) and Derived Air
- 3 Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent
- 4 Concentrations; Concentrations for Release to Sewerage
- 5 – 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control
- 6 releases of radioactive material in effluents—nuclear power reactors
- 7 – 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors.
- 8 • Application contains sufficient technical information for the staff to complete the detailed
- 9 technical safety review.
- 10 • Application will be found to be in compliance by the staff with the above regulations through
- 11 a radiation protection program and an effluent release monitoring program.

12 3.8.1.2.2 *Environmental Consequences of Operation*

13 If the new reactor design does not have radiological gaseous and liquid effluent releases and no
14 significant quantities of solid radioactive waste are being stored onsite, then there are no
15 potential offsite radiation exposure pathways and no environmental analysis of offsite
16 radiological dose is necessary. To receive an NRC license, the applicant must provide
17 assurances that the new reactor’s operations would not exceed regulatory limits for
18 occupational doses and doses to individual members of the public, as set forth in 10 CFR
19 Part 20 (TN283). Under the safety review, the staff would review and confirm in the Final Safety
20 Evaluation Report that the application demonstrates adequate protection of the public’s health
21 and safety by meeting the appropriate regulatory limits through all operational phases. The
22 application’s safety analysis does not assess the collective dose to the surrounding population
23 or doses to nonhuman biota.

24 The NRC staff identified four environmental issues related to radiological environment impacts
25 for operation of a new reactor:

- 26 • occupational doses to workers
- 27 • MEI annual doses
- 28 • total population annual doses
- 29 • nonhuman biota doses.

30 Variability in radiological waste management systems between new reactor designs is
31 expected. Some new reactors may be designed to have no radiological effluent releases and
32 very small quantities of onsite solid radioactive waste. Other new reactors, such as liquid-fueled
33 molten-salt reactors, may have industrial processes for removing fission products from the
34 nuclear fuel as part of their normal operating procedures with accompanying releases of noble
35 and volatile radioactive gases, and liquid waste from processing stream(s). This would
36 necessitate an appropriately designed and approved 10 CFR Part 50 (TN249) or Part 52
37 (TN251) radioactive waste management system and an associated processing and storage
38 facility to support plant operations. It is also expected that the various new reactor designs with
39 lower power levels and inherent design features, while satisfying the regulatory limits for effluent
40 releases of 10 CFR Part 20 (TN283), would not necessarily have the same level of effluent
41 releases as the LWRs previously assessed in the new reactor ESP and COL EISs. Thus, based
42 on the assumption that new reactors will meet regulatory effluent release limits, the previous

1 new reactor environmental impacts for LWRs would provide bounding impacts for new
2 reactors with radioactive waste streams leading to offsite doses.

3 Occupational Doses to Workers

4 The licensee of a new plant would need to maintain individual doses to workers to within 5 rem
5 annually as specified in 10 CFR 20.1201 (TN283) and incorporate provisions to maintain doses
6 ALARA. Section 3.9.1.2, "Occupational Radiological Exposures," of Revision 2 to NUREG-1437
7 (NRC 2024-TN10161) provides a detailed analysis of occupational doses to workers at LWR
8 nuclear power plants. This analysis shows improvements have been implemented over the
9 years of operational experience to reduce occupational doses to workers and that the average
10 annual doses are well within regulatory limits, and Revision 2 to NUREG-1437 (NRC 2024-
11 TN10161) is incorporated by reference.

12 New reactor applicants' radiation protection programs should be able to build upon and apply
13 the lessons learned through LWR operational experience to maintain their workers' occupational
14 doses well below regulatory limits and would ensure that occupational exposures are
15 maintained ALARA. In addition, new reactor applicants could establish plans for worker training,
16 monitoring, and radiation safety programs.

17 The staff concludes that the health impacts from occupational radiation exposure would be
18 SMALL based on individual worker doses being maintained within 10 CFR 20.1201 (TN283)
19 limits and collective occupational doses for new reactors should be in line with the radiation
20 protection practices at current operating LWRs. Additional mitigation would not be warranted
21 because the operating plant would be required to maintain doses ALARA. This is a Category 1
22 issue. The staff relied on the following PPE assumptions to reach this conclusion:

- 23 • For protection against radiation, the applicant must meet the regulatory requirements of:
 - 24 – 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a
25 license
 - 26 – 10 CFR 20.1201 Occupational dose limits for adults
 - 27 – Appendix B of 10 CFR Part 20 Annual Limits on Intake (ALIs) and Derived Air
28 Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent
29 Concentrations; Concentrations for Release to Sewerage
 - 30 – 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control
31 releases of radioactive material in effluents—nuclear power reactors
 - 32 – 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors.
- 33 • Application contains sufficient technical information for the staff to complete the detailed
34 technical safety review.
- 35 • Application will be found to be in compliance by the staff with the above regulations through
36 a radiation protection program and an effluent release monitoring program.

37 Maximally Exposed Individual Annual Doses

38 Prior new reactor EISs have assessed the total dose to the MEI as part of meeting the
39 requirements of the 10 CFR Part 20 (TN283) based on the methodology provided in RG 1.109,
40 *Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose*
41 *of Evaluating Compliance with 10 CFR Part 50, Appendix I* (NRC 1977-TN90). The MEI total

1 dose is usually assessed from the nuclear power plant to the nearest resident assuming all
 2 appropriate exposure pathways are at that location. This assumption provides for a conservative
 3 or bounding analysis for demonstrating compliance with regulatory dose limits. Prior LWR new
 4 reactor ESP and COL MEI annual doses are provided in Table 3-3 along with two non-LWRs,
 5 namely the Kairos Hermes test reactor and the Abilene Christian University Molten Salt
 6 Research Reactor. The table demonstrates that the MEI annual dose assessed not only met the
 7 regulatory limit of 100 mrem/yr in 10 CFR 20.1301(a) (TN283) but also met the lower regulatory
 8 limits in 40 CFR Part 190 (TN739), which is incorporated into NRC regulations under 10 CFR
 9 20.1301(e) (TN283), even for sites with co-located nuclear power plants.

10 **Table 3-3 Maximally Exposed Individual Doses^(a)**

| Site Name | Total Body (mrem/yr) ^(b) | Thyroid (mrem/yr) | Organ (mrem/yr) |
|---|-------------------------------------|-------------------|-----------------|
| Clinton Exelon ESP (NRC 2006-TN672) | 3.21 | 9.47 | 5.04 |
| Grand Gulf ESP (NRC 2006-TN674) | 8.9 | 17.0 | 21.0 |
| North Anna Power Station Unit 3 ESP (NRC 2010-TN6) | 6.9 | 18.0 | 14.0 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 0.458 | 0.88 | 1.3 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 5.71 | 4.55 | 1.94 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 2.2 | 14.0 | 3.5 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 5.5 | 12.9 | 19.5 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 3.7 | 3.1 | 7.8 |
| Vogtle Units 3 and 4 ESP (NRC 2011-TN6439) | 2.36 | 12.39 | 8.88 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 5.66 | 13.99 | 2.32 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 3.74 | 20.0 | 9.05 |
| PSEG ESP (NRC 2015-TN6438) | 2.94 | 6.86 | 3.97 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 7.8 | 15.0 | 8.4 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 4.52 | 6.80 | 7.32 |
| Clinch River ESP (NRC 2019-TN6136) | 11 | 25.0 | 24.0 |
| Kairos Hermes construction permit (CP) (NRC 2023-TN9771) | 2.4 | 1.7 | 1.5 |
| Abilene Christian University Molten Salt Research Reactor CP (NRC 2024-TN10337) | <0.5 | - | - |

(a) 40 CFR 190.10 (a) (TN739) states “the annual dose equivalent does not exceed 25 millirems to the whole body, 75 millirems to the thyroid, and 25 millirems to any other organ of any member of the public as the result of exposures to planned discharges of radioactive materials, radon and its daughters excepted, to the general environment from uranium fuel cycle operations and to radiation from these operations.”

(b) These values meet the restrictions stated in 40 CFR 190 (a) (TN739) as well as the restrictions in 10 CFR 20.1301(a)(1) (TN283) Dose Limits.

11 A new reactor applicant must provide the necessary information on the docket for the staff to
 12 reach a regulatory finding that the regulatory requirements have been met, such as annual dose
 13 limits to members of the public provided in 10 CFR 20.1301 (TN283). Additionally, 10 CFR Parts
 14 20 (TN283) and 50 (TN249) require that a REMP be established to provide data about
 15 measurable levels of radiation and radioactive materials in the site environs. Licensees would
 16 rely on the REMP or a similar program to satisfy the requirements of Criterion 64, “Monitoring
 17 Radioactivity Releases,” of Appendix A, “General Design Criteria for Nuclear Power Plants,” to
 18 10 CFR Part 50, *Domestic Licensing of Production and Utilization Facilities* (NRC 2016-
 19 TN6463) or applicant-developed plant-specific Principal Design Criteria for non-LWRs (NRC
 20 2018-TN7066). Therefore, the environmental impacts on the MEI are expected to be SMALL
 21 where new reactor applicants demonstrate in their application that any radiological effluent

1 releases and annual doses would be within regulatory limits, or where the staff during their
2 safety review finds the applicant would be in compliance with the applicable 10 CFR Part 20
3 regulations. This is a Category 1 issue. The staff relied on the following PPE assumptions to
4 reach this conclusion:

- 5 • For protection against radiation, the applicant must meet the regulatory requirements of:
 - 6 – 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a
7 license
 - 8 – 10 CFR 20.1301 Dose limits for individual members of the public
 - 9 – Appendix B of 10 CFR Part 20 Annual Limits on Intake (ALIs) and Derived Air
10 Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent
11 Concentrations; Concentrations for Release to Sewerage
 - 12 – 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control
13 releases of radioactive material in effluents—nuclear power reactors
 - 14 – 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors.
- 15 • Application contains sufficient technical information for the staff to complete the detailed
16 technical safety review.
- 17 • Application will be found to be in compliance by the staff with the above regulations through
18 a radiation protection program and an effluent release monitoring program.

19 Total Population Annual Doses

20 If there are radiological effluent releases, they will move beyond the site into the surrounding
21 area exposing the surrounding population, and the impacts from such releases need to be
22 assessed under NRC's NEPA obligations. For the past new reactor ESP and COL application
23 reviews, this analysis of total population doses was provided using the NRC Dose code, which
24 was also applied as part of the safety analysis and was evaluated out to a distance of 80 km
25 (50 mi.). These total population dose results from the various ESPs and COLs approved by the
26 NRC are provided in Table 3-4. As part of these reviews, the staff compared the total population
27 dose associated with the licensing action to the collective dose from natural background
28 radiation based on an average annual individual natural background dose of 310 mrem/yr. The
29 results from the various ESP and COL radiological assessments show that the surrounding
30 population would receive a very small fraction of what would be expected from natural
31 background.

32 Both the NCRP and the International Council on Radiation Protection and Measurements
33 (ICRP) suggest that when the collective effective dose is smaller than the reciprocal of the
34 relevant risk detriment (i.e., less than 1/0.00057, which is less than 1,754 person-rem), the
35 assessment should find that the most likely number of excess health effects is zero (NCRP
36 1995-TN728; ICRP 2007-TN422). As noted above, all of the ESP and COL total population
37 doses are significantly less than the 1,754 person-rem value that both ICRP and NCRP suggest
38 would most likely result in zero excess health effects (NCRP 1995-TN728; ICRP 2007-TN422).

1 **Table 3-4 Total Population and Collective Natural Background Doses in 50 mi Radius^(a)**

| Site Name | 50 mi Population | 50 mi Population Collective Dose (person-rem/yr) | Collective Dose from Natural Background Radiation (person-rem/yr) |
|--|------------------|--|---|
| Clinton Exelon ESP (NRC 2006-TN672) | 800,000 | 1.83 | 230,000 |
| Grand Gulf ESP (NRC 2006-TN674) | 332,369 | 3.20 | 102,000 |
| North Anna Power Station Unit 3 ESP (NRC 2010-TN6) | 2,800,000 | 8.70 | 840,000 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 6,418,570 | 3.9 | 2,000,000 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 514,000 | 0.58 | 160,000 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 2,131,394 | 34.50 | 663,000 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 1,440,000 | 13.8 ^(a) | 520,000 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 3,490,000 | 8.00 | 985,000 |
| Vogtle Units 3 and 4 ESP (NRC 2011-TN6439) | 674,101 | 1.84 | 243,000 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 7,710,000 | 21.60 | 2,400,000 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 4,195,000 | 10.6 | 1,305,000 |
| PSEG ESP (NRC 2015-TN6438) | 8,138,635 | 65.90 | 2,531,000 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 7,500,000 | 8.00 | 2,500,000 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 2,640,368 | 8.54 | 821,154 |
| Clinch River ESP (NRC 2019-TN6136) | 2,658,157 | 68.00 | 830,000 |

(a) The 50 mi population collective dose for one unit was multiplied by 2 to account for a two-unit site.

2 The combination of these radiological impacts demonstrates a low MEI dose correlates to a
3 small total population dose, even out to 80 km (50 mi.), where zero excess health effect in the
4 general population would be expected. Therefore, the environmental impacts on the
5 surrounding population are expected to be SMALL where new reactor applicants demonstrate in
6 their application that any radiological effluent releases and annual doses to the population would
7 be within regulatory limits of 10 CFR Part 20 (TN283). This is a Category 1 issue. The staff
8 relied on the following PPE assumptions to reach this conclusion:

- 9 • For protection against radiation, the applicant must meet the regulatory requirements of:
 - 10 – 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a
 - 11 license
 - 12 – 10 CFR 20.1301 Dose limits for individual members of the public
 - 13 – Appendix B of 10 CFR Part 20 Annual Limits on Intake (ALIs) and Derived Air
 - 14 Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent
 - 15 Concentrations; Concentrations for Release to Sewerage
 - 16 – 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control
 - 17 releases of radioactive material in effluents—nuclear power reactors
 - 18 – 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors.
- 19 • Application contains sufficient technical information for the staff to complete the detailed
- 20 technical safety review.

1 Application will be found to be in compliance by the staff with the above regulations through a
2 radiation protection program and an effluent release monitoring program.

3 Nonhuman Biota Doses

4 The Commission position on nonhuman biota doses is that the current set of radiation protection
5 controls is protective of the environment. Therefore, the NRC radiation protection regulations, by
6 protecting members of the public, also protect nonhuman biota and there is no need to have
7 separate radiation protection regulations for plant and animal species (SECY-04-0223 [NRC
8 2004-TN6431], SECY-06-0168 [NRC 2006-TN6430], SECY-08-0197 [NRC 2008-TN6432],
9 SECY-04-0055 [NRC 2004-TN7100], and related Staff Requirements Memorandums SRM-
10 SECY-04-0223 [NRC 2005-TN6649], SRM-SECY-06-0168 [NRC 2005-TN6650], SRM-SECY-
11 08-0197 [NRC 2009-TN6651]), SRM-SECY-04-0055 [NRC 2004-TN7101]. The IAEA (1992-
12 TN712) and the NCRP (1991-TN729) report that a chronic dose rate of no greater than
13 10 milligrays/day (mGy/d) (1,000 millirads/day [mrad/d]) to the MEI in a population of aquatic
14 organisms would ensure protection of the population. The IAEA (IAEA 1992-TN712) also
15 concluded that chronic dose rates of 1 mGy/d (100 mrad/d) or less do not appear to cause
16 observable changes in terrestrial animal populations. These two guidelines (1,000 mrad/d for
17 aquatic biota, 100 mrad/d for terrestrial biota) have been applied in various NRC environmental
18 reviews. For example, the impact of radionuclides on aquatic organisms has been raised as an
19 issue by the public for several of the nuclear plants that have undergone license renewal. The
20 License Renewal GEIS Revision 1 (NRC 2024-TN10161) concludes that the impact of routine
21 radionuclide releases from past and current operations on aquatic and terrestrial biota would be
22 SMALL for all nuclear plants and would not be expected to appreciably change during the
23 renewal period.

24 Nonhuman biota doses have also been assessed in the new reactor ESP and COL FEISs. The
25 results from the new reactor reviews for the seven surrogate species (three aquatic species and
26 four terrestrial species analyzed within the NRCDose code) are shown in Table 3-5 and
27 Table 3-6. These tables clearly show the absorbed dose rates for all surrogate species were
28 much lower than the IAEA and NCRP guidelines (IAEA 1992-TN712; NCRP 1991-TN729).
29 Thus, the conclusion in all of the new reactor environmental reviews was the radiological impact
30 on nonhuman biota from a new nuclear power plant at the selected site would be SMALL.
31 Therefore, the environmental impacts on nonhuman biota are expected to be SMALL where
32 new reactor applicants demonstrate in their application that any radiological effluent releases
33 and annual doses would be within regulatory limits. This is a Category 1 issue. The staff relied
34 on the following PPE assumption to reach this conclusion:

- 35 • Applicants would demonstrate in their application that any radiological nonhuman biota
36 doses would be below IAEA (1992-TN712) and NCRP (1991-TN729) guidelines.

1

Table 3-5 Aquatic Nonhuman Biota Doses^(a)

| Site Name | Fish (mrad/d) | Invertebrate (mrad/d) | Algae (mrad/d) |
|--|------------------------|--------------------------|-----------------------|
| Clinton Exelon ESP (NRC 2006-TN672) | 0.0171 | 0.0376 | 0.0762 |
| Grand Gulf ESP (NRC 2006-TN674) | 0.068 ^(b) | 0.452 ^(b) | 0.405 ^(b) |
| North Anna Power Station Unit 3 ESP (NRC 2010-TN6) | 0.009 ^(b) | 0.033 ^(b) | 0.047 ^(b) |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 0.00077 | 0.0064 | 0.015 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 0.0068 | 0.015 | 0.0015 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 0.0022 | 0.0063 | 0.018 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 0.01 | 0.02 | 0.03 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 0.052 | 0.088 | 0.11 |
| Vogtle Units 3 and 4 ESP (NRC 2011-TN6439) | 0.00044 ^(c) | 0.0012 ^(c) | 0.0036 ^(c) |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 0.0063 | 0.021 | 0.033 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 0.0016 | 0.0044 | 0.013 |
| PSEG ESP (NRC 2015-TN6438) | 0.0045 | 0.0161 | 0.0225 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 0.00 | 0.00 | 0.00 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 0.00052 | 0.0018 | 0.0058 |
| Clinch River ESP (NRC 2019-TN6136) | 0.0045 | 0.021 | 0.0067 |

(a) The IAEA and NCRP reported a chronic absorbed dose rate of no greater than 1,000 mrad/d would ensure protection of aquatic organism populations (IAEA 1992-TN712; NCRP 1991-TN729).

(b) Dose converted from mGy/yr to mrad/d.

(c) Dose converted from mGy/d to mrad/d.

2

Table 3-6 Terrestrial Nonhuman Biota Doses^(a)

| Site Name | Muskrat (mrad/d) | Raccoon (mrad/d) | Heron (mrad/d) | Duck (mrad/d) |
|--|-----------------------|-----------------------|----------------------|-----------------------|
| Clinton Exelon ESP (NRC 2006-TN672) | 0.0471 | 0.0222 | 0.191 | 0.0470 |
| Grand Gulf ESP (NRC 2006-TN674) | 0.227 ^(b) | 0.058 ^(b) | 0.534 ^(b) | 0.227 ^(b) |
| North Anna Power Station Unit 3 ESP (NRC 2010-TN6) | 0.112 ^(b) | 0.056 ^(b) | 0.082 ^(b) | 0.112 ^(b) |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 0.0038 | 0.00075 | 0.0011 | 0.0038 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 0.03 | 0.031 | 0.03 | 0.036 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 0.020 | 0.023 | 0.044 | 0.027 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 0.02 | 0.01 | 0.01 | 0.02 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 0.19 | 0.060 | 0.55 | 0.19 |
| Vogtle Units 3 and 4 ESP (NRC 2011-TN6439) | 0.0055 ^(c) | 0.0066 ^(c) | 0.01 ^(c) | 0.0071 ^(c) |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 0.071 | 0.032 | 0.049 | 0.071 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 0.016 | 0.011 | 0.030 | 0.015 |
| PSEG ESP (NRC 2015-TN6438) | 0.0199 | 0.0170 | 0.0203 | 0.0206 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 0.14 | 0.14 | 0.14 | 0.14 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 0.010 | 0.0090 | 0.013 | 0.010 |
| Clinch River ESP (NRC 2019-TN6136) | 0.24 | 0.23 | 0.25 | 24 |

(a) The IAEA concluded that a chronic absorbed dose rate of 100 mrad/d or less does not appear to cause observable changes in terrestrial animal populations (IAEA 1992-TN712).

(b) Dose converted from mGy/yr to mrad/d.

(c) Dose converted from mGy/d to mrad/d.

1 **3.8.2 Nonradiological Environment**

2 *3.8.2.1 Baseline Conditions and PPE/SPE Values and Assumptions*

3 Baseline conditions influencing potential public and occupational health impacts associated with
4 the building and operation of a new reactor include consideration of nonradiological chemical
5 hazards, biological hazards, EMFs, the distance to receptors (occupational workers or a
6 member of the public), the number of people potentially exposed, and other industrial physical
7 concerns, such as falls, burns from high temperature, shock, or asphyxiation. Relevant public
8 and occupational health conditions involve not only industrial processes at the plant itself, but
9 also consider other sources of public and occupational exposure, such a neighboring chemical
10 facilities and current road conditions. Section 3.3 includes information about air quality.
11 Section 3.4 includes information about water resources. Section 3.9 includes information about
12 noise. Section 3.11 includes information about postulated accidents. Section 3.12 includes
13 information about traffic impacts. Section 3.15 includes information about transportation of fuel
14 and waste, while Section 3.10 includes information about waste impacts. The overall well-being
15 of these resource areas is important to maintaining the quality of public and occupational health.

16 The assumption of the PPE/SPE developed for this GEIS is that the applicant must adhere to
17 applicable Federal, State, local and tribal public and occupational health regulatory limits and
18 BMPs regarding chemical hazards, biological hazards, EMFs, and physical hazards.

19 *3.8.2.1.1 Chemical Hazards*

20 A chemical hazard occurs when workers or members of the public are exposed to a
21 nonradiological hazardous substance by inhalation, skin absorption, or ingestion. Chemical
22 hazards can have immediate effects (nausea, vomiting, acid burns, asphyxiation—also known
23 as acute hazards) or the effects might take time to develop (dermatitis, asthma, liver damage,
24 cancer—also known as chronic hazards). Figure 3-2 shows the exposure pathways for
25 radiological hazards to humans. Those same exposure pathways also apply to nonradiological
26 chemical hazards to humans.

27 For large LWRs, there are multiple pathways by which humans can be exposed to pollutants
28 from a plant. For example, a direct pathway would be a human breathing in a gaseous effluent
29 or swimming in water that was contaminated by a liquid effluent. An indirect pathway would be a
30 human eating a fish that had absorbed a pollutant into its body or eating crops that had been
31 irrigated with water contaminated by a liquid effluent. One advantage of a new reactor is that
32 pathways for exposure could be limited based on the design.

33 The Occupational Safety and Health Administration is responsible for developing and enforcing
34 workplace safety regulations. Congress created the Occupational Safety and Health
35 Administration by enacting the Occupational Safety and Health Act of 1970, as amended (29
36 U.S.C. 651 et seq.) to safeguard the health of workers. Nuclear power plant conditions that
37 result in an occupational risk, but do not affect the safety of licensed radioactive materials, are
38 under the statutory authority of the Occupational Safety and Health Administration rather than
39 the NRC as set forth in a memorandum of understanding (NRC 2013-TN10165) between the
40 two agencies. The Occupational Safety and Health Administration rather than the NRC as set
41 forth in a memorandum of understanding (NRC 2013-TN10165) between the two agencies. The
42 Occupational Safety and Health Administration sets enforceable permissible exposure limits for
43 about 500 hazardous chemicals to protect workers against the health effects of exposure to
44 hazardous substances, including limits on the airborne concentrations of hazardous chemicals

1 in the air and skin contact. Most permissible exposure limits are 8-hour time-weighted averages,
2 although there are also ceiling and peak limits. Regulatory limits for chemical hazards are found
3 in 29 CFR Part 1910 (TN654).

4 The EPA is responsible for the regulation of most chemicals that can enter the environment
5 through the following Federal Acts: the Federal Insecticide, Fungicide, and Rodenticide Act
6 (7 U.S.C. §§ 136 et seq.; TN4535); Toxic Substances Control Act (15 U.S.C. §§ 2601 et seq.;
7 TN4454); RCRA (42 U.S.C. §§ 6901 et seq.; TN1281); Clean Water Act (codified as the Federal
8 Water Pollution Control Act of 1972; 33 U.S.C. §§ 1251 et seq.; TN662); SDWA (42 U.S.C.
9 §§ 300f et seq.; TN1337); Clean Air Act (42 U.S.C. §§ 7401 et seq.; TN1141); and the
10 Comprehensive Environmental Response Compensation and Liability Act (42 U.S.C. §§ 9601
11 et seq.; TN6592). Discharged biocides, liquid wastes, chemicals, and heavy metals are
12 regulated by the NPDES permitting system.

13 *3.8.2.1.2 Biological Hazards*

14 Biological hazards are organic substances that pose a threat to the health of humans and other
15 organisms. Biological hazards include pathogenic microorganisms, insects, animals, viruses,
16 toxins, spores, and fungi. Biological hazards, such as mosquitos, bees, and ticks could be
17 present at any industrial site, either while building the facility itself or while the facility is in
18 operation. Microbiological hazards occur when workers or members of the public come into
19 contact with disease-causing microorganisms, also referred to as etiological agents. Examples
20 of etiological agents are Salmonella spp., Shigella spp., Legionella spp., Pseudomonas
21 aeruginosa, or thermophilic fungi. NUREG-1437, Volume 1, Revision 1 (NRC 2024-TN10161),
22 provides further background information about microorganisms of concern at large LWRs and a
23 description of studies of microorganisms in cooling towers.

24 *3.8.2.1.3 Electromagnetic Fields*

25 An EMF is caused by a combination of electric and magnetic fields of force or moving electric
26 charges. The strength of the EMF will increase with an increase in voltage. EMFs are generated
27 by natural phenomena (for example the Earth's magnetic field) or any electrical equipment
28 (WHO 2020-TN6561). There are no U.S. Federal standards limiting residential or occupational
29 exposure to EMFs from power lines, but some states, such as Florida, Minnesota, Montana,
30 New Jersey, New York, and Oregon, have set electric field and magnetic field standards for
31 transmission lines (NIEHS 2002-TN6560). EMFs resulting from a 60 Hz power transmission line
32 falls under the category of non-ionizing radiation. A voluntary occupational standard has been
33 set for EMFs by the International Commission on Non-Ionizing Radiation Protection. For
34 occupational workers who are exposed to 60 Hz (power lines), the electric field standard is
35 8.3 kV/m and the magnetic field standard is 4,200 milligauss, while for the general public who
36 are exposed to 60 Hz, the electrical field standard is 4.2 kV/m and the magnetic field standard is
37 833 milligauss (ICNIRP 1998-TN6591). The National Institute of Occupational Safety and Health
38 does not consider EMFs to be a proven health hazard (NIOSH 1996-TN6766). NUREG-1437,
39 Volume 1 (NRC 2024-TN10161), provides further background information about EMFs at large
40 LWRs.

41 In 1996, the World Health Organization began a multidisciplinary research study regarding the
42 possible health effects from exposure to EMF sources (WHO 2020-TN6561) and concluded
43 current evidence does not support the existence of any health consequences from exposure to
44 low-level EMFs. Two additional reports, one from the U.S. National Academy of Science

1 (National Research Council 1997-TN6595), and another from the National Institute of
2 Environmental Health Sciences, concluded similar findings (NIEHS 2002-TN6560).

3 *3.8.2.1.4 Physical Hazards*

4 A physical hazard is an action, agent, or condition that can cause harm upon contact. Physical
5 hazards include actions such as slips, trips, and falls. Physical hazards from agents include
6 noise (see Section 3.9), shock, vibration, ionizing radiation, and ergonomic factors from heavy
7 lifting and repetitive motion. Physical conditions could include high heat, cold, pressure, or
8 confined space. A new reactor is an industrial facility and will have many of the typical
9 occupational hazards found at other electric power generation utilities. Physical hazards such as
10 ladder safety, fall protection, noise exposure, non-ionizing radiation, and personal protective
11 equipment are regulated by 29 CFR Part 1910 (TN654).

12 If a new reactor were to be a power-producing facility, transmission lines to support the power
13 grid would be necessary. Occupational workers and members of the public could be exposed to
14 acute electric shock from transmission lines or electrical equipment needed to support the
15 facility. Secondary shock currents are also produced when humans make contact with
16 (1) capacitively charged bodies, such as a vehicle parked near a transmission line, or
17 (2) magnetically linked metallic structures, such as fences near transmission lines. The National
18 Electrical Safety Code contains the basic provisions that are considered necessary for the
19 safety of employees and the public under specific conditions. 29 CFR 1926 Subpart V (TN4455)
20 contains safety regulations related to electrical power transmission and distribution.
21 NUREG-1437, Volume 1 (NRC 2024-TN10161), provides further information about electric
22 shock.

23 *3.8.2.2 Nonradiological Environment Impacts*

24 The NRC has assessed the impacts on nonradiological public and occupational health from the
25 existing operating reactor fleet during license renewal assessments and from proposed new
26 reactors as part of the COL and ESP process under 10 CFR Part 52 (TN251). Impacts on
27 nonradiological public and occupational health from the continued operation and refurbishment
28 of typical large LWRs in the existing U.S. fleet are evaluated in the License Renewal GEIS
29 (NRC 2024-TN10161). Impacts from the building and operation of new reactors have been
30 evaluated in several EISs. The NRC staff assumes that the impacts on nonradiological public
31 and occupational health from the construction and operation of new reactors would generally be
32 bounded by the large LWRs.

33 *3.8.2.2.1 Environmental Consequences of Construction*

34 The NRC staff identified two environmental issues:

- 35 • building impacts of chemical, biological, and physical nonradiological hazards, and
- 36 • building impacts of EMFs.

37 The primary impacts of constructing a new reactor on nonradiological public and occupational
38 health would be from building activities. Potential occupational worker impacts would come from
39 chemical hazards, biological hazards, EMFs, and physical hazards typical of large-scale
40 building construction. This would include exposure to the following:

- 41 • equipment engine exhaust

- 1 • heavy metals in solder or welding fumes
- 2 • solvent vapors
- 3 • fugitive dust
- 4 • plant toxins, insects, and other biological hazards
- 5 • vibration
- 6 • slips, trips, falls from scaffolding
- 7 • heat or cold stress, burns, frost-bite
- 8 • noise (see Section 3.9 regarding information about this subject)
- 9 • heat stress
- 10 • non-ionizing radiation from welding
- 11 • shock from electrical equipment
- 12 • repetitive motion (ergonomic concerns), strains, and sprains
- 13 • traffic-related impacts from construction worker and supply transportation (see Section 3.12
- 14 regarding information about this subject).

15 Building Impacts of Chemical, Biological, and Physical Nonradiological Hazards

16 Chemical exposure would exist in the form of dust, fumes, fibers (solids), liquids, mists, gases,
 17 or vapors. Examples of chemical hazards found in construction work could include lead, silica,
 18 cadmium, carbon monoxide, oxides of nitrogen, VOCs, welding fumes, spray paints, cutting oil
 19 mists, solvents, and hexavalent chromium. Fugitive emissions of dust in particular would be
 20 generated during windy periods, earthmoving, and movement of vehicular traffic over recently
 21 disturbed areas. Exposure to plant and insect toxins could occur during earthmoving activities.
 22 Physical impacts common to any large-scale industrial project would also occur.

23 Potential impacts on members of the public during building would be from chemical hazards and
 24 physical hazards typical of large-scale building construction. This would include exposure to
 25 some of the hazards that occupational workers would face, such as equipment engine exhaust,
 26 fugitive dust, vibration, noise, and traffic-related impacts from construction worker and supply
 27 transportation. Members of the public could be exposed to building impacts due to the proximity
 28 of their house, work, school, recreational site, or via a water source. Applicable liquid and air
 29 permits and regulations would also regulate impacts on members of the public, similar to the
 30 regulation for occupational workers.

31 Occupational and public health mitigation measures that may be used to reduce potential
 32 impacts during building, include phasing activities and equipment use; BMPs such as proper
 33 equipment maintenance and use; and watering and stabilizing roads and spoils.

34 Building activities are typically subject to air permits under State and Federal laws to address
 35 impacts of air emissions on any local sensitive receptors. Mitigation could also consist of
 36 providing administrative and engineering design features, such as dikes around large liquid
 37 chemical tanks.

38 The staff has determined that nonradiological public and occupational health impacts associated
 39 with chemical, biological, and physical hazards during construction of a new reactor are a

1 Category 1 issue. The staff concluded that as long as the applicable PPE and SPE values and
2 assumptions are met, the nonradiological public and occupational health impact from building a
3 new reactor can be generically determined to be SMALL. Any planned exposure or release over
4 the regulatory limit would require project-specific analysis. The staff relied on the following PPE
5 values and assumptions to reach this conclusion:

- 6 • The applicant must adhere to all applicable Federal, State, local or Tribal regulatory limits
7 and permit conditions for chemical hazards, biological hazards, and physical hazards.
- 8 • The applicant will follow nonradiological public and occupational health BMPs and mitigation
9 measures, as appropriate.

10 Building Impacts of EMFs

11 Occupational workers would be exposed to EMFs during the use of any electronic tool or
12 equipment. However, the staff has determined that nonradiological public and occupational
13 health impacts from EMFs during construction are uncertain.

14 Studies of 60 Hz EMFs have not uncovered consistent evidence linking harmful effects with field
15 exposures. Because the state of the science is currently inadequate, no generic conclusion on
16 human health impacts is possible. If, in the future, the Commission finds that a general
17 agreement has been reached by appropriate Federal health agencies that there are adverse
18 health effects from EMFs, the Commission will require applicants to submit plant-specific
19 reviews of these health effects as part of their application. Until such time, applicants are not
20 required to submit information about this issue.

21 *3.8.2.2.2 Environmental Consequences of Operation*

22 The NRC staff identified two environmental issues:

- 23 • operation impacts of chemical, biological, and physical nonradiological hazards, and
- 24 • operation impacts of EMFs.

25 The primary impacts of operating a new reactor on nonradiological public and occupational
26 health would be from chemical hazards, biological hazards, EMFs, and physical hazards.
27 Hazards present during operation for occupational workers would be the same as those listed
28 for construction.

29 Operation Impacts of Chemical, Biological, and Physical Nonradiological Hazards

30 For new reactors, operations-related chemical hazards could result from the releases of liquid
31 effluents or gaseous emissions from industrial operations, sanitary discharges, leaching of
32 heavy metals from tanks or pipes, and improper storage or handling of chemicals. Various
33 reactor operational systems may require treatment using chemicals or biocides to avoid scaling.
34 The rate of flow into water systems would be managed, while facility discharges that may
35 contain low-level concentrations of chemicals or biocides, would be managed through
36 engineering and administrative controls necessary to maintain requirements of an NPDES
37 permit or other standards. Industrial processes at a new reactor could also use backup diesel
38 generators, boilers, cooling condensers, or cooling towers. Impacts on occupational workers
39 can result from operations of engine-driven equipment, although these types of operations may
40 be reduced, limited, or not present for some new reactor designs. The regulations in 10 CFR
41 Part 50 (TN249) dictate that safety-related diesel generators and other emission-releasing

1 equipment be tested throughout the year for various durations. Diesel generators that function
2 as standby equipment would also typically be tested throughout the year for various durations.
3 Primary cooling systems, operation of process equipment, mobile emissions, and emergency
4 power supply systems would all release either a liquid effluent or gaseous emission. Emissions
5 could include nitrogen oxide, carbon monoxide, sulfur dioxide, VOCs, and particulate matter,
6 depending upon the plant design. Additionally, new reactors would either have a stand-alone
7 sanitary system or connect to a municipal sanitary system.

8 Chemical effects could also be caused by the improper storage or handling of chemicals or
9 waste. For example, improper storage of acids and bases, chemicals commonly used in onsite
10 laboratories for testing of effluents, could cause an explosion. In addition, there could be
11 impacts from accidental chemical spills either in the laboratory or when chemistries of the
12 primary and secondary coolant systems are being adjusted, if multiple coolant systems are part
13 of the reactor design.

14 Occupational workers would be exposed to biological hazards at a new reactor, as workers at
15 any industrial facility would be. The staff assumes the applicant to employ industry BMPs to
16 minimize biological hazards to occupational workers.

17 Conditions at cooling towers, spent fuel pools, and other thermal discharges could provide ideal
18 living conditions for etiological agents unless those conditions are managed properly.
19 Occupational workers could come into contact with microbiological hazards when cleaning
20 condenser tubes or cooling towers. Management of microbiological hazards could include the
21 use of engineering and administrative controls, such as PPE. NUREG-1437, Volume 1, provides
22 an impact description of microorganisms of concern at large LWRs (NRC 2024-TN10161). The
23 impacts of microbiological hazards would be expected to be similar at a new reactor if the
24 reactor design operates with similar conditions (cooling ponds, lakes, canals or discharge to a
25 river). However, the NRC staff assumes that some new reactor designs will minimize the use of
26 cooling ponds, lakes, canals or discharges to rivers and will adhere to a NPDES permit.

27 Physical hazards from actions such as slips, trips, falls from ladders, forklift operation, burns
28 from high temperatures, and electrical shock would be present for occupational workers.
29 Physical agents, such as noise (see Section 3.9), vibration, and ionizing radiation, and
30 ergonomic factors from heavy lifting and repetitive motion would also be expected. Occupational
31 workers could face potentially hazardous physical conditions, such as high heat, cold, pressure,
32 or performing work in confined spaces or using electrical equipment. Regulations in 29 CFR
33 Part 1910 (TN654) have been set in place to minimize physical hazards. The staff assumes
34 BMPs will be put in place by the applicant, and that the applicant will adhere to the regulations
35 in 29 CFR Part 1910 for nonradiological occupational health.

36 Potential impacts on members of the public during operation from chemical hazards, biological
37 hazards, and physical hazards at a new reactor would be those typical of large LWRs and
38 electric power generating facilities. Hazards present during operation for members of the public
39 are the same as those listed for building, with the addition of planned or accidental chemical
40 releases from industrial processes.

41 Members of the public could be exposed to operation impacts due to the proximity of their
42 house, work, school, recreational site, or via a water source. Applicable liquid and air permits
43 and regulations would also regulate impacts on members of the public, similar to the regulation
44 for occupational workers. The staff assumes that proper emergency management procedures
45 will be put in place.

1 Members of the public could come into contact with microbiological hazards if in contact with a
2 water body that receives runoff or discharge from a new reactor or air deposition from gaseous
3 releases. Changes in microbial populations and in the public use of water bodies might be
4 caused by the operation of a new reactor that uses water as a coolant or a moderator. The staff
5 assumes an applicant would use advanced system designs, distance, dilution, and security
6 measures to minimize microbiological hazards to the public and adhere to NPDES permit
7 limitations.

8 The scope of the transmission line review is from the plant to the first interconnecting point or
9 points on the existing high-voltage transmission system (NRC 2000-TN3549). The greatest
10 hazard from a transmission line is direct contact with the conductors. There is a potential for
11 members of the public to be exposed to acute electrical shock from these lines. The issue of
12 electrical shock is generic to all electrical power plants. Tower designs preclude direct public
13 access to the conductors. However, electrical contact can be made without physical contact
14 between a grounded object and the conductor. A person who contacts a metallic structure or a
15 charged object could receive a secondary shock and experience a painful sensation at the point
16 of contact. The staff assumes the applicant would construct and operate transmission lines in
17 adherence with the National Electrical Safety Code criteria (IEEE 2023-TN10132).

18 Occupational and public health mitigation measures that may be used to reduce potential
19 impacts during operation, include adherence to industrial hygiene and safety practices and
20 locating noisy equipment away from sensitive receptors.

21 The staff has determined that the impacts of nonradiological public and occupational health
22 impacts associated with chemical, biological, and physical hazards during operation is a
23 Category 1 issue. The staff concluded that as long as the applicable PPE and SPE values and
24 assumptions are met, the nonradiological public and occupational health impact from operating
25 a new reactor can be generically determined to be SMALL. Any planned exposure or release
26 over the regulatory limit would require project-specific analysis. The staff relied on the following
27 PPE values and assumptions to reach this conclusion:

- 28 • The applicant must adhere to all applicable Federal, State, local or Tribal regulatory limits
29 and permit conditions for chemical hazards, biological hazards, and physical hazards.
- 30 • The applicant will follow nonradiological public and occupational health BMPs and mitigation
31 measures, as appropriate.

32 Operation Impacts of EMFs

33 Occupational workers would be expected to be exposed to low-frequency EMFs at a new
34 reactor if the primary purpose of the facility is to produce electrical power and electrical
35 equipment would be present. The median magnetic field measurement during a workday for a
36 distribution substation worker at an electric utility is 7.2 milligauss (NIEHS 2002-TN6560). The
37 staff assumes that occupational workers at a new reactor would experience similar fields.
38 Distance and shielding have been shown to be effective mitigation tools for EMFs. Members of
39 the public could also be exposed to EMFs from powerlines associated with the reactor.
40 However, the staff has determined that nonradiological public and occupational health impacts
41 from EMFs during operation are uncertain.

42 Studies of 60 Hz EMFs have not uncovered consistent evidence linking harmful effects with field
43 exposures. Because the state of the science is currently inadequate, no generic conclusion on
44 human health impacts is possible. If, in the future, the Commission finds that a general

1 agreement has been reached by appropriate Federal health agencies that there are adverse
2 health effects from EMFs, the Commission will require applicants to submit plant-specific
3 reviews of these health effects as part of their application. Until such time, applicants are not
4 required to submit information on this issue.

5 **3.9 Noise**

6 This section describes the baseline conditions, PPE/SPE values, and environmental
7 consequences associated with noise, as heard by humans. Wildlife-related noise impacts are
8 described in Section 3.5.

9 **3.9.1 Baseline Conditions and PPE/SPE Values and Assumptions**

10 Noise levels associated with the building and operation of a new reactor (and associated
11 transmission line ROWs) that may influence human health include the volume and duration of
12 the noise, the distance to receptors (where dwelling units or other sites of frequent human use
13 exist), and landscape characteristics such as topography and foliage. Noise from nuclear plant
14 building and operations can often be detected offsite relatively close to the plant site boundary.
15 Major sources of noise during building include earthmoving activities and building of safety- and
16 non-safety-related facilities. Major sources of noise at operating nuclear power plants are
17 cooling towers, turbines, transformers, large pumps, and cooling-water system motors.

18 Sound pressure levels are typically measured by using the logarithmic decibel scale. To assess
19 potential noise impacts on humans, a special weighting scale was developed to account for
20 human sensitivities to certain frequencies and duration of sounds. The dBA is widely used in
21 environmental noise assessments because it correlates well with a human's subjective reaction
22 to sound (Cowan 1994-TN3905).

23 U.S. Department of Housing and Urban Development regulations for exterior noise standards
24 (24 CFR 51.101(a)(8); TN1016), Section 5.3.4 of NUREG-1555 (NRC 2000-TN614) states noise
25 levels are acceptable (i.e., SMALL) if the day-night average sound level outside a residence is
26 less than 65 dBA. Threshold noise levels from industrial sites are subject to threshold values
27 from the National Institute for Occupational Safety and Health under the Occupational Safety
28 and Health Act of 1970 (Public Law 91-596; 29 U.S.C. §§ 651 et seq.; TN4453). Noise
29 abatement issues are also handled by State and local governments because there is no
30 overarching Federal noise abatement program.¹³ The assumption underlying the PPE is that the
31 new reactor will not exceed a 65 dBA threshold at the site boundary, unless a relevant State or
32 local noise abatement law or ordinance sets a different threshold, which would then be the
33 presumptive threshold for PPE purposes. If an applicant cannot meet the 65 dBA threshold
34 through mitigation, then the applicant must obtain a variance or exception from the relevant
35 State or local regulator. Based upon the NRC's past experience reviewing new reactor and
36 license renewal applications for large LWRs, noise impacts during both building and operation
37 have generally not exceeded 65 dBA (except for very short periods of time such as alarm and
38 equipment testing) or these impacts have been successfully mitigated (e.g., through the
39 implementation of BMPs, including modeling, foliage planting, building of noise buffers, and the
40 timing of construction activities). Therefore, the PPE assumes that applicable BMPs and

¹³ In the 1970s, the EPA coordinated all Federal noise control activities pursuant to the Noise Control Act of 1972 (42 U.S.C. §§ 4901 et seq.; TN4294), as amended by the Quiet Communities Act of 1978 (TN7029). The EPA's implementing regulations are at 40 CFR Parts 201 to 211 (TN7030). The EPA phased out the program's funding in 1982 and transferred the primary responsibility of regulating noise to State and local governments.

1 potential mitigation measures would be applied to reduce noise impacts to below a 65 dBA
2 threshold on applicable receptors, particularly during building.

3 **3.9.2 Noise Impacts**

4 Noise impacts associated with new reactors and associated transmission line ROWs would take
5 place during the building and operation phases of the project. The mitigation measures that
6 could be conducted to be able to rely on the generic analysis may include implementation of
7 BMPs, such as modeling, foliage planting, building noise buffers, and the timing of building
8 and/or operation activities.

9 *3.9.2.1 Environmental Consequences of Construction*

10 Impacts would occur during site preparation and the building of both safety-related and non-
11 safety-related facilities. Some smaller new reactor designs can be placed in one or a few small
12 buildings on a small site and may lack structures such as cooling towers, switchyards, or offsite
13 pipelines. As a result, the noise associated with building new reactors could produce lower
14 overall noise impacts relative to what has been typical for a large LWR. Larger new reactors
15 may require the building of facilities similar to those associated with a large LWR and most likely
16 have noise levels similar to those of a large LWR.

17 In certain cases, sound modeling in accordance with industry standards may be necessary to
18 estimate noise levels associated with the building of the reactor. While post-mitigated noise
19 associated with construction may exceed the noise thresholds during certain activities, these
20 impacts are expected to be temporary and short in duration. As part of the ER, the applicant
21 should conduct a noise survey in the relevant area, identify the peak day and night noise levels
22 in dBA at each survey point, and establish the likely source of that noise level (e.g., road traffic,
23 industrial and construction noises, etc.). Therefore, the NRC staff concludes that building-
24 related human noise impacts from a new reactor would be SMALL and a Category 1 issue. The
25 staff relied upon the following PPE assumptions to reach this determination:

- 26 • The noise level would be no more than 65 dBA at site boundary, unless a relevant State or
27 local noise abatement law or ordinance sets a different threshold, which would then be the
28 presumptive threshold for PPE purposes.
- 29 • If an applicant cannot meet the 65 dBA threshold through mitigation, then the applicant must
30 obtain a variance or exception with the relevant State or local regulator.
- 31 • The project would implement BMPs, including such as modeling, foliage planting,
32 construction of noise buffers, and the timing of construction and/or operation activities.

33 *3.9.2.2 Environmental Consequences of Operation*

34 Impacts associated with the operation of the new reactor would also occur. However, the noise
35 associated with the operation of the reactor, while longer in duration, is expected to be
36 generated at a lower level than during building. Therefore, building-generated noise impacts
37 establish the upper bound for operations-related noise.

38 The NRC staff assumes that the noise associated with the operation of a new reactor would be
39 mitigated and would not routinely exceed 65 dBA at the site boundary. Therefore, the NRC staff
40 concludes that operation-related human noise impacts from a new reactor would be SMALL and
41 a Category 1 issue. The NRC staff assumes that any mitigation necessary to achieve the noise
42 thresholds from construction would remain in place and that no additional mitigation would be

1 needed to maintain those thresholds for the duration of operations. The staff relied upon the
2 following PPE assumptions to reach this determination:

- 3 • The noise level would be no more than 65 dBA at site boundary, unless a relevant State or
4 local noise abatement law or ordinance sets a different threshold, which would then be the
5 presumptive threshold for PPE purposes.
- 6 • If an applicant cannot meet the 65 dBA threshold through mitigation, then the applicant must
7 obtain a various or exception with the relevant State or local regulator.
- 8 • The project would implement BMPs, including such as modeling, foliage planting,
9 construction of noise buffers, and the timing of construction and/or operation activities.

10 **3.10 Waste Management**

11 **3.10.1 Radiological Waste Management**

12 *3.10.1.1 Baseline Conditions and PPE/SPE Values and Assumptions*

13 There are three types of radiological wastes that could be associated with a new reactor: LLRW
14 (low-level radioactive waste), high-level radioactive waste, and mixed wastes. Regulations
15 regarding the how a licensee shall dispose of licensed materials is regulated in accordance with
16 10 CFR Part 20 (TN283) Subpart K. These wastes are described in the sections below.

17 The NRC staff assumes that a new reactor could be installed at an existing licensed facility. The
18 new reactor could be a physically separate nuclear facility or, if there is adequate land, it could
19 be integrated within the boundaries of an existing nuclear power plant or other nuclear facility. If
20 the new reactor is a stand-alone facility, the space needed to store onsite radiological wastes
21 would be within the planned footprint of the facility. If the new reactor is sited at an existing
22 nuclear facility, the existing radiological waste infrastructure and management program could
23 likely support the additional radiological wastes generated by the new reactor. For an existing
24 site, information should be available about the radiological waste management facilities onsite,
25 such as the information developed for that facility's NRC licensing activities and documented,
26 for example, in annual environmental monitoring reports. This and other applicable
27 documentation can be incorporated by reference into the SEIS.

28 *3.10.1.1.1 Low-Level Radioactive Wastes*

29 The Commission's licensing requirements for the land disposal of LLRW are set forth in 10 CFR
30 Part 61 (TN252), *Licensing Requirements for Land Disposal of Radioactive Waste*. Part 61
31 defines LLRW as "radioactive waste not classified as high-level radioactive waste [HLRW],
32 transuranic [TRU] waste, spent nuclear fuel, or byproduct material as defined in paragraphs (2),
33 (3), and (4) of the definition of byproduct material set forth in § 20.1003 of this chapter."¹⁴ The
34 NRC's regulation 10 CFR 61.55 (TN252) established a classification system that categorizes
35 LLRW as Class A, B, C, or Greater Than Class C (GTCC). Class A wastes contain
36 radionuclides at relatively low concentrations, whereas the half-lives and concentrations of
37 radionuclides in the Class B and C wastes are progressively higher. In addition, Class B wastes
38 must meet more rigorous requirements with regard to their form to ensure their stability after
39 disposal (e.g., by adding chemical stabilizing agents such as cement to the waste or placing the
40 waste in a disposal container or structure that provides stability after disposal). Class C wastes
41 must not only meet the more rigorous requirements above but also require the implementation

¹⁴ 10 CFR 61.2 (TN252) (definition of "waste").

1 of additional measures at the disposal facility to protect against inadvertent intrusion (e.g., by
2 increasing the thickness and hardness of the cover over the waste disposal cell). GTCC is
3 LLRW with concentrations of radionuclides that exceed the limits established by the
4 Commission for Class C LLRW (NRC 2019-TN6440). Under the NRC's current regulations,
5 GTCC waste is considered to be generally unacceptable for near-surface disposal and must be
6 disposed of in a geologic repository unless the Commission approves, on a case-by-case basis,
7 disposal of such waste in a disposal site licensed pursuant to 10 CFR 61.55(a)(2)(iv) (TN252).
8 These regulations form the basis for the PPE guidance in Appendix G of this GEIS.

9 For this GEIS, the NRC staff assumes that the quantities of LLRW generated at a new reactor
10 would be less than the quantities of LLRW generated at existing nuclear power plants, which
11 generate an average of 21,200 ft³ (600 m³) and 2,000 curies (Ci) (7.4×10^{13} Bq) per year for
12 boiling water reactors and half that amount for pressurized water reactors (NRC 2024-
13 TN10161). The LLRW generated at a new reactor would likely be similar to LLRW wastes from
14 existing facilities: these wastes typically consist of contaminated protective shoe covers and
15 clothing, wiping rags, mops, filters, equipment and tools, and other contaminated objects
16 depending on the nuclear application (NRC 2017-TN6545). The radioactivity can range from just
17 above the background levels found in nature to very highly radioactive. LLRW that contains
18 radionuclides that have shorter decay times can be stored onsite by licensees until it can be
19 released in accordance with 10 CFR Part 20, Subpart K (TN283). LLRW that contains
20 radionuclides that have longer decay times can be stored onsite until material inventory
21 amounts are large enough for shipment to a low-level waste disposal site. Applicable
22 regulations from the NRC (10 CFR Part 71-TN301, "Packaging and Transportation of
23 Radioactive Material") and/or the U.S. Department of Transportation (49 CFR-TN7054) must be
24 used when offering licensed material for transport.

25 The NRC requires that all licensees implement measures to minimize, to the extent practicable,
26 the generation of radioactive waste (10 CFR 20.1406 [TN283]). Additionally, the new reactor
27 licensee could do the following:

- 28 • Build additional temporary radiological storage facilities on the site.
- 29 • Enter into an agreement with a third-party contractor to process, store, own, and ultimately
30 dispose of LLRW from the new reactor site.

31 The Low-Level Radioactive Waste Policy Amendments Act of 1985 (Public Law 99-240;
32 TN6517)¹⁵ gave States the responsibility for disposal of the LLRW generated at commercial
33 facilities within their states. States are encouraged to enter into compacts that allow them to
34 dispose of the waste at a common disposal facility shared by multiple states. Depending on the
35 location of the new reactor site, the reactor licensee could contract with one or more licensed
36 LLRW disposal sites. There are currently four operating disposal facilities in the United States
37 that are licensed to accept LLRW from commercial facilities (including nuclear power plants)
38 (NRC 2020-TN6516). They are located at Clive, Utah; Andrews County, Texas; Barnwell, South
39 Carolina; and near Richland, Washington. The Energy *Solutions* disposal facility at Clive, Utah,
40 is licensed by the State of Utah to accept Class A LLRW from all regions of the United States.
41 The Waste Control Specialists, LLC (WCS) site in Andrews County, Texas, is licensed to accept
42 Class A, B, and C LLRW from the Texas Compact generators (Texas and Vermont) and from
43 outside generators with permission from the Texas Compact. Energy *Solutions* Barnwell
44 Operations located near Barnwell, South Carolina, accepts waste from the Atlantic Compact

¹⁵ The Low-Level Radioactive Waste Policy Amendments Act superseded, in its entirety, an earlier law, the Low-Level Radioactive Waste Policy Act of 1980 (Public Law 96-573; TN6606).

1 states (Connecticut, New Jersey, and South Carolina) and is licensed by the State of South
2 Carolina to dispose of Class A, B, and C LLRW. U.S. Ecology, located near Richland,
3 Washington, accepts LLRW from the Northwest and Rocky Mountain Compact states
4 (Washington, Alaska, Hawaii, Idaho, Montana, Oregon, Utah, Wyoming, Colorado, Nevada, and
5 New Mexico) and is licensed by the State of Washington to dispose of Class A, B, and C waste.
6 A new reactor licensee would likely have to choose one or a combination of these options.
7 Section 3.10.1.2 addresses the potential environmental impacts of using LLRW disposal
8 facilities. The NRC staff anticipates that a new reactor licensee would enter into an agreement
9 with one of the four above facilities or make alternative arrangements in accordance with
10 10 CFR Part 20 Subpart K (TN283).

11 3.10.1.1.2 High-Level Waste

12 The only two types of high-level waste (HLW) generated at new reactors would be spent nuclear
13 fuel and, potentially, waste from fuel reprocessing (e.g., removal of fission products during
14 operation from liquid-fueled molten-salt reactors) (NRC 2020-TN6955). The regulations for the
15 storage of HLW are found in 10 CFR Part 72 (TN4884) and apply to the proper storage and
16 handling of spent nuclear fuel in an ISFSI. Section 3.14.2.6 provides more information about the
17 storage and disposal of spent nuclear fuel.

18 New reactor designs may not require onsite spent nuclear fuel storage, for example, in cases
19 where the depleted core would be shipped offsite after a short period after shutdown (see
20 Section 3.14 for away-from-reactor impacts during continued storage).

21 If spent nuclear fuel or any treated, reprocessed waste needs to be stored temporarily at a new
22 reactor facility, it would be stored either in a spent fuel pool or in non-water-based spent nuclear
23 fuel storage. After an appropriate holding period, it would be transferred to dry cask storage in
24 an at-reactor ISFSI under a general license or a stand-alone ISFSI under specific license.

25 3.10.1.1.3 Mixed Wastes

26 Mixed waste, regulated under the RCRA (TN1281) and the Atomic Energy Act of 1954
27 (42 U.S.C. §§ 2011 et seq.; TN663), is waste that is both radioactive and hazardous (EPA 2019-
28 TN6956). These wastes are subject to dual regulation by the EPA or an authorized State for
29 their hazardous component, and by the NRC or an Agreement State for the radioactive
30 component. Nuclear power plants generate small quantities of mixed waste, typically accounting
31 for less than 3 percent by volume of the annual LLRW (NRC 1996-TN288). The NRC staff
32 assumes that new reactors would be similar small-quantity generators and generate mixed
33 wastes similar to those wastes generated at currently operating nuclear power plants. If any
34 new reactor would generate more mixed wastes than is assumed in this GEIS, the associated
35 impacts would need to be assessed in the site-specific environmental report developed for the
36 licensing of that facility.

37 The types of mixed wastes generated at nuclear power plants include organics (e.g., liquid
38 scintillation fluids, waste oils, halogenated organics), metals (e.g., lead, mercury, chromium, and
39 cadmium), solvents, paints, cutting fluids, cleaning and refrigeration effluents, and corrosives
40 from acids. The quantity of mixed waste generated varies considerably from plant to plant (NRC
41 1996-TN288). The EIS for the Fermi Unit 3 COL (NUREG-2105; NRC 2013-TN6436) states that
42 0.416 m³/yr (0.544 yd³/yr) of mixed waste would be generated during operation. Overall, the
43 quantities generated during operations are generally relatively small, but because of the added
44 complexity of dual regulation, it is more problematic for plant owners to manage and dispose of

1 mixed wastes than the other types of wastes. Similar to hazardous waste, mixed waste is
2 generally accumulated onsite in designated areas as authorized under RCRA, then shipped
3 offsite for treatment as appropriate and for disposal. The only disposal facilities that are
4 authorized to receive mixed LLRW for disposal at present are the Energy *Solutions* and the
5 WCS facilities (NRC 2024-TN10161).

6 The NRC staff assumes that a new reactor licensee would manage mixed waste in accordance
7 with appropriate regulations and BMPs. In addition, the NRC staff assumes that a licensee for a
8 new reactor would produce waste in quantities that would allow classification as a small-quantity
9 generator of hazardous waste, based on the design features of new reactors and the fact that
10 other large LWRs can meet the classification.

11 3.10.1.2 *Radiological Waste Impacts*

12 The NRC staff identified three environmental issues for analysis of waste management
13 associated with a new reactor:

- 14 • LLRW
- 15 • onsite spent nuclear fuel management
- 16 • mixed waste.

17 3.10.1.2.1 *Low-Level Radioactive Waste*

18 The NRC staff assumes the new reactor site would have sufficient storage for LLRW. The NRC
19 dose limitations (10 CFR Part 20-TN283) would apply for both public and occupational radiation
20 exposure for any onsite facilities (see Section 3.8.1 of this GEIS). The radiological
21 environmental monitoring programs around nuclear power plants that operate such LLRW
22 storage facilities show that the increase in radiation dose at the site boundary is not significant
23 (NRC 2024-TN10161). The NRC staff has concluded that doses to members of the public from
24 the operation of onsite LLRW storage facilities would have a minimal impact.

25 In addition, the NRC staff assessed in the License Renewal GEIS the impacts of onsite LLRW
26 storage at currently operating nuclear power plants and concluded that the radiation doses to
27 offsite individuals from onsite LLRW storage are not significant (NRC 2024-TN10161). The
28 expected types of LLRW generated by new reactors would be very similar to those generated
29 by currently operating nuclear power plants (i.e., LLRW in the form of contaminated protective
30 shoe covers and clothing, wiping rags, mops, filters, equipment and tools, etc.), although the
31 amount is expected to be less because some new reactor designs involve sealed reactor
32 systems (e.g., microreactors) and other designs could have fewer operational maintenance
33 activities, which include only typical sources of LLRW (listed above). The building and operation
34 activities for these onsite LLRW storage facilities for a new reactor would be similar to those of
35 LLRW storage facilities for existing nuclear power plants. However, the magnitude of the impact
36 is expected to be less for many designs, based on factors such as lower power levels, less
37 complex reactor systems, remote maintenance operations, and reduced maintenance activities
38 generating reduced volumes of LLRW.

1 For the shipment of LLRW offsite to a licensed disposal site (as discussed in
2 Section 3.10.1.1.1), the NRC staff assumes that the quantities shipped and associated impacts
3 would be bounded by the impact assessment provided in Section 4.11.1.1 and by the data in
4 Tables 3.11-1 and 3.11-2 of the License Renewal GEIS (NRC 2024-TN10161) related to the
5 volume and activity of LLRW shipped offsite in 2021 for 11 power plant sites. This information is
6 incorporated here by reference.

7 The NRC staff concluded that there should be no significant issues or environmental impacts
8 associated with onsite storage of LLRW generated by nuclear power plants, including new
9 reactors. Onsite storage facilities would be used until the wastes could be safely shipped to
10 licensed LLRW disposal facilities as previously discussed. The NRC staff considers impacts of
11 LLRW management to be SMALL and a Category 1 issue, because of expected compliance
12 with regulations and policies governing radiological waste management. The staff relied on the
13 following PPE assumptions to reach this conclusion:

- 14 • Applicants must meet the regulatory requirements of 10 CFR Part 20 (TN283) (e.g., 20.1406
15 and Subpart K), 10 CFR Part 61 (TN252), 10 CFR Part 71 (TN301), and 10 CFR Part 72
16 (TN4884).
- 17 • Quantities of LLRW generated at many new reactors would be less than the quantities of
18 LLRW generated at existing nuclear power plants, which generate an average of 21,200 ft³
19 (600 m³) and 2,000 Ci (7.4×10^{13} Bq) per year for boiling water reactors and half that
20 amount for pressurized water reactors (NRC 2024-TN10161).

21 As discussed above, in previous assessments the NRC staff concluded that there would be no
22 significant environmental impacts associated with onsite storage of LLRW generated by nuclear
23 power plants, and this conclusion can be applied to new reactors addressed in this GEIS.
24 Onsite storage facilities would likely be used at new reactors until these wastes could be safely
25 shipped to licensed LLRW disposal facilities as previously discussed. Currently operating LLRW
26 disposal facilities have adequate capacity to accommodate the increased demand from new
27 reactors. The NRC staff considers impacts of LLRW management to be SMALL and a
28 Category 1 issue based on the information already available about LLRW management for
29 currently operating nuclear facilities and because of expected compliance with regulations and
30 policies governing radiological waste management.

31 *3.10.1.2.2 Onsite Spent Nuclear Fuel and High-Level Waste Management*

32 Because a new reactor is assumed to generate less spent nuclear fuel than currently operating
33 reactors in the United States (i.e., due to smaller cores and longer core lifetimes), the NRC staff
34 assumes that the impacts of onsite spent nuclear fuel management at new reactor facilities
35 would be bounded by the impacts of spent nuclear fuel storage at current nuclear power plants.
36 The environmental impacts of storage are assessed for current nuclear power plants in the
37 context of operating license renewal in Section 4.11.1.2 of the License Renewal GEIS (NRC
38 2024-TN10161). Current and potential environmental impacts from spent nuclear fuel storage
39 onsite at the reactor sites are well understood and the environmental impacts during the license
40 renewal term were found to be small (NRC 2024-TN10161). Offsite spent nuclear fuel storage
41 and disposal impacts are addressed in Section 3.14.2.6 of this GEIS. During the operational
42 lifetime of the new reactor, appropriate handling and storage of spent nuclear fuel must be
43 performed in accordance with NRC regulations (e.g., 10 CFR Part 72-TN4884). While liquid-fuel
44 molten-salt reactors (MSRs) could process the molten salt to remove fission products and other
45 radionuclides, the resulting high-level and TRU waste must be handled and stored in
46 accordance with NRC regulations (see Section 3.14.2.5 for discussion of reprocessing).

1 Assuming an appropriate decay time, new reactor management of spent nuclear fuel would be
2 similar to current reactor sites and use similar ISFSIs, with a currently approved cask design or
3 a specially designed spent nuclear fuel storage facility or dry cask storage system. The NRC
4 staff assumes that radiological impacts would be within regulatory limits; thus, the environmental
5 impacts of onsite storage during operations would be SMALL. The NRC staff's overall
6 conclusion about onsite management of spent nuclear fuel, high-level waste, and TRU waste
7 during the licensed lifetime of operations for new reactors is that the environmental impacts
8 would be minor. This is a Category 1 issue. The staff relied on the following PPE assumptions to
9 reach this conclusion:

- 10 • Compliance with 10 CFR Part 72 (TN4884).

11 3.10.1.2.3 Mixed Waste

12 New reactors could also be expected to generate small quantities of mixed waste. The waste at
13 the new reactor site would either be treated onsite or sent offsite for treatment followed by
14 disposal at a permitted landfill licensed to accept mixed waste. The comprehensive regulatory
15 controls and the facilities and procedures that are in place at nuclear power plants ensure that
16 the mixed waste is properly handled and stored. The NRC staff assumes that the radioactive
17 dose and exposure to toxic materials from mixed waste should have a small contribution to
18 LLRW impacts based on existing impacts at current LWRs, as was assessed in the License
19 Renewal GEIS (NRC 2024-TN10161 [see Section 4.11.1.4, Mixed Waste Storage and
20 Disposal]). Therefore, the radiological and nonradiological environmental impacts from the long-
21 term disposal of mixed waste for any individual new reactor is considered SMALL. This is a
22 Category 1 issue. The staff relied on the following PPE assumptions to reach this conclusion:

- 23 • RCRA Small Quantity Generator (EPA 2020-TN6590) for Mixed Waste.

24 3.10.2 Nonradiological Waste Management

25 3.10.2.1 Baseline Conditions and PPE/SPE Values

26 Baseline conditions influencing nonradiological waste impacts associated with building and
27 operation of a new reactor include consideration of waste forms, classifications, and exposure
28 pathways. Nonradiological waste can exist in a gaseous, liquid, or solid form. Nonradiological
29 waste can further be classified as hazardous or nonhazardous. When hazardous waste is
30 combined with radiological waste it is referred to as mixed waste. Mixed waste is addressed in
31 Section 3.10.1.2.3. Exposure pathways to nonradiological waste can be either through
32 inhalation, ingestion, or absorption. See Section 3.3.1 for information regarding air quality,
33 Section 3.4.1 for water resources, Section 3.8.1 for public and occupational health information,
34 Section 3.11.1 for postulated accidents, and Section 3.15.1 for transportation of fuel and waste.

35 The assumption of the PPE/SPE developed for this GEIS is that the licensee must meet all
36 applicable permit conditions and regulations, and perform all appropriate BMPs related to solid,
37 liquid, and gaseous waste. The NRC staff also assumes that licensees would implement
38 mitigation measures, such as recycling, along with using the least hazardous substance in its
39 operations, as appropriate.

40 Hazardous waste is defined by the EPA in 40 CFR Part 261 (TN5092). Hazardous wastes may
41 be wastes that are specifically listed as known hazardous wastes or wastes that have one or
42 more characteristics of ignitability, corrosivity, reactivity, or toxicity. Types of hazardous wastes
43 common to new reactors or electric power generation facilities include waste paints, lab packs,

1 and solvents. Per the License Renewal GEIS (NRC 2024-TN10161), most LWRs accumulate
2 their hazardous waste onsite as authorized under RCRA (42 U.S.C. §§ 6901 et seq.; TN1281)
3 and transport it to treatment facilities for processing (NRC 2024-TN10161). The remaining
4 residues are sent to permanent disposal facilities. A class of hazardous waste called universal
5 waste is handled differently than hazardous waste, and includes batteries, pesticides,
6 mercury-containing equipment, light bulbs, and aerosol cans. Federal universal waste
7 regulations can be found in 40 CFR Part 273 (TN6587). All aspects of hazardous waste, such
8 as generation, treatment, transportation, and disposal, are regulated by the EPA or by States
9 under agreements with the EPA per the regulations set forth under RCRA.

10 RCRA also defines categories of hazardous waste generators (EPA 2020-TN6590). These
11 types include large-quantity generators, small-quantity generators, and very small-quantity
12 generators. Very small-quantity hazardous waste generators create 100 kg or less per month of
13 hazardous waste or 1 kg or less per month of acutely hazardous waste. Small-quantity
14 hazardous waste generators create more than 100 kg but less than 1,000 kg of hazardous
15 waste per month. Large-quantity hazardous waste generators create 1,000 kg per month or
16 more of hazardous waste or more than 1 kg per month of acutely hazardous waste. The ESP
17 application for the Clinch River small modular reactor expected the facility to qualify as a small-
18 quantity generator (TVA 2019-TN6589). The ESPs application for the Public Service Enterprise
19 Group stated that it maintains the program required of a small-quantity generator (PSEG 2014-
20 TN3452). The assumption of the PPE/SPE developed for this GEIS is that the proposed plant
21 would conform to RCRA regulations.

22 Nonhazardous waste is waste that is not contaminated with either radionuclides or hazardous
23 chemicals. These wastes include office trash, paper, wood, oils not mixed with hazardous waste
24 or radiological waste, and sewage. Solid wastes, defined as nonhazardous by 40 CFR Part 261
25 (TN5092) are collected and disposed of in a landfill. Sanitary wastes defined as nonhazardous
26 by 40 CFR Part 261 are treated either at an onsite sewage treatment plant (as in the case of
27 many large-scale industrial facilities), discharged directly to a municipal sewage system for
28 treatment, or discharged to onsite septic tanks. The assumptions of the PPE/SPE developed for
29 this GEIS is that the quantity of water discharged to a municipal system would be within the
30 receiving system's capacity, as noted in Appendix G.

31 Large LWRs have nonradioactive waste management systems in place that manage both
32 hazardous and nonhazardous wastes. For example, boiler blowdown, water treatment wastes,
33 boiler metal cleaning wastes, laboratory and sampling wastes, floor and yard drains, and
34 stormwater runoff are all managed by these systems and are regulated by an NPDES permit,
35 with the exception of wastes in solid form (NRC 2024-TN10161). See Section 3.4 for further
36 discussion of water resources. The NRC staff assumes that new reactors would have some of
37 the same systems as a large LWR, although new reactor designs may vary.

38 3.10.2.2 *Nonradiological Waste Impacts*

39 The NRC has assessed nonradiological waste impacts arising from the existing operating fleet
40 during license renewal assessments and from proposed new reactors as part of the COL and
41 ESP process under 10 CFR Part 52 (TN251). Nonradiological waste impacts resulting from the
42 refurbishment and operation of typical large LWRs in the existing U.S. fleet are evaluated in the
43 License Renewal GEIS (NRC 2024-TN10161). Nonradiological waste impacts from building and
44 operating LWRs have been evaluated in several EISs and the impacts were found to be
45 SMALL. Impacts of nonradiological waste from building and operating a new reactor would
46 generally be bounded by the impacts associated with large LWRs. See Section 3.3.2 for

1 impacts on air quality, Section 3.4.2 for impacts on water resources, Section 3.8.2 for impacts
2 on public and occupational health impacts, Section 3.11.2 for impacts of postulated accidents,
3 and Section 3.15.2 for impacts of the transportation of fuel and waste.

4 *3.10.2.2.1 Environmental Consequences of Construction*

5 The primary nonradiological waste impacts of building a new reactor would be those associated
6 with building activities. Impacts would include the generation, handling, and disposal of waste
7 and would be bounded by those of any large-scale construction project. Building waste impacts
8 would depend on whether the new reactor was built at a greenfield (undeveloped land),
9 brownfield (previously developed land available for redevelopment), or currently industrialized
10 site. Potential types of nonradioactive wastes expected from building a new reactor would
11 include construction debris, spoils, stormwater runoffs, municipal and sanitary waste, dust,
12 hazardous waste from construction equipment maintenance (e.g., oils and solvents), and air
13 emissions. Impacts are categorized into one of three waste types: solid, liquid, and gaseous.

14 Building a new reactor could result in solid waste materials such as construction debris from
15 excavation, land clearing, and municipal waste. Debris could either be shipped to a local
16 construction debris landfill or the licensee could construct and operate its own onsite landfill. For
17 example, the Tennessee Valley Authority proposed to construct and operate an onsite landfill in
18 its application for an ESP (TVA 2019-TN5854). The NRC staff assumes municipal and
19 hazardous solid waste would be handled and shipped to the appropriate licensed disposal
20 facility in accordance with applicable regulations. If a licensee were to construct an onsite
21 landfill, those impacts would be considered in a project-specific EIS.

22 Building activities related to building a new reactor could result in liquid waste, such as
23 stormwater runoffs. Surface water and groundwater have the potential to be affected by building
24 activities. The NRC staff assumes the applicant for a new reactor would obtain an NPDES
25 permit for stormwater discharges and maintain a Stormwater Pollution Prevention Plan to
26 minimize potential impacts. The NRC staff also assumes that an erosion and sediment control
27 plan would be implemented as part of the NPDES permit. In addition, the NRC staff assumes
28 sanitary wastes would be handled and shipped to the appropriate licensed disposal facility, such
29 as a local municipal sanitary waste facility. Mitigation for stormwater runoff could include
30 creation of berms around temporary spoils areas, trenching, drainpipes, culverts, and swales to
31 direct runoff to retention ponds. Dewatering at the construction site could be expected for the
32 nuclear island area if the design of the new reactor calls for subsurface installation of major
33 components. Mitigation could include use of horizontal drains to direct water to sumps, grouting
34 to prevent inflow of groundwater, and pumping water from sumps to construction-stormwater
35 management systems. Impacts of dewatering are discussed in Section 3.4.

36 In addition, building activities could result in gaseous waste. Examples of gaseous waste
37 include construction equipment and vehicle emissions and fugitive dust from earthmoving
38 activities. Air permits are required for construction activities. In addition, the NRC staff assumes
39 licensees would use BMPs, such as stabilizing construction roads and spoil piles, covering haul
40 trucks, watering unpaved construction roads, and maintaining equipment in proper working
41 order, as discussed in Section 3.3.

1 The staff has determined that nonradiological waste impacts during construction of a new
2 reactor are a Category 1 issue. The staff concluded that as long as the applicable PPE and SPE
3 values and assumptions are met, the nonradiological waste impacts from building a new reactor
4 can be generically determined to be SMALL. The staff relied on the following PPE values and
5 assumptions to reach this conclusion:

- 6 • The applicant must meet all the applicable permit conditions, regulations, and BMPs related
7 to solid, liquid, and gaseous waste management.
- 8 • For hazardous waste generation, applicants must meet conformity with hazardous waste
9 quantity generation levels in accordance with RCRA.
- 10 • For sanitary waste, applicants must dispose of sanitary waste in a permitted process.
- 11 • For mitigation measures, the applicant would perform mitigation measures to the extent
12 practicable, such as recycling, process improvements, or the use of a less hazardous
13 substance.

14 *3.10.2.2.2 Environmental Consequences of Operation*

15 The NRC staff assumes the nonradiological waste impacts of operating a new reactor would be
16 smaller than those experienced during building and would depend on the design of the new
17 reactor. Impacts would result from the generation, handling, and disposal of nonradiological
18 waste. Such waste can be classified as either hazardous or nonhazardous and found in solid,
19 liquid, or gaseous forms. Depending on the new reactor design, some waste streams may be
20 reduced or eliminated relative to a large LWR. For instance, reactors moderated by substances
21 other than water may not have a significant water footprint.

22 New reactor operational activities could result in solid waste materials such as office waste,
23 cardboard, wood, metal, sewage treatment sludge, and resins. The NRC staff assumes
24 municipal (office trash) and hazardous solid waste would be handled and shipped to the
25 appropriate licensed disposal facility in accordance with the applicable regulations, while
26 cardboard, paper, wood pallets, and metal would be recycled, as appropriate. BMPs regarding
27 solid waste for a new reactor would be similar to those already in use for large LWRs.

28 The operation of a new reactor could result in liquid waste materials such as chemicals,
29 biocides (for control of algae), and stormwater runoff. These discharges would be from cooling
30 or other operations of the reactor and would be managed in accordance with Federal, State,
31 local or tribal regulations. Sanitary waste would either be discharged to a permitted municipal
32 sanitary system or treated in an onsite sanitary system. The NRC staff assumes the licensee
33 would comply with all applicable permits and use BMPs to control liquid waste materials.

34 Gaseous waste materials would come from operation of diesel generators, fossil-fuel boilers,
35 and from the coolant system (i.e., if the new reactor was a gas-cooled reactor). Section 3.3
36 contains further information about air quality impacts. Gaseous wastes include CO, NO_x, carbon
37 dioxide (CO₂), methane (CH₄), N₂O, PM, and VOCs for diesel-, natural-gas-, and oil-fired units.
38 Gaseous waste materials associated with a new reactor would be managed in accordance with
39 Federal, State, local, or tribal regulations. In addition, the NRC staff assumes the licensee would
40 comply with all applicable permits and use BMPs for these wastes.

41 Mitigation for waste management could include recycling, improving an operational process, or
42 using a less hazardous chemical, such as using aqueous ammonium versus anhydrous
43 ammonia.

1 The staff has determined that nonradiological waste impacts during operation of a new reactor
2 are a Category 1 issue. The staff concluded that as long as the applicable PPE and SPE values
3 and assumptions are met, the nonradiological public and occupational health impact from
4 operating a new reactor can be generically determined to be SMALL. The staff relied on the
5 following PPE values and assumptions to reach this conclusion:

- 6 • The applicant must meet all the applicable permit conditions, regulations, and BMPs related
7 to solid, liquid, and gaseous waste management.
- 8 • For hazardous waste generation, applicants must meet conformity with hazardous waste
9 quantity generation levels in accordance with RCRA.
- 10 • For sanitary waste, applicants must dispose of sanitary waste in a permitted process.
- 11 • For mitigation measures, the applicant would perform mitigation measures to the extent
12 practicable, such as recycling, process improvements, or the use of a less hazardous
13 substance.

14 **3.11 Postulated Accidents**

15 **3.11.1 Baseline Conditions and PPE/SPE Values and Assumptions**

16 *3.11.1.1 Design Basis Accidents Involving Radiological Releases¹⁶*

17 Radiological effects from a postulated accident from such nuclear facilities are considered for
18 their impacts with respect to the following regulatory requirements:

- 19 • 10 CFR 50.34(a)(1) (TN249), “Contents of applications; technical information.”
- 20 • 10 CFR 52.79(a)(1)(A) (TN251), “Contents of applications; technical information in final
21 safety analysis report.”

22 Based on the regulations, whether it is a non-LWR or LWR design, the new reactor design basis
23 accident (DBA) analysis must satisfy the following:

- 24 • For the exclusion area boundary, the maximum total effective dose equivalent (TEDE)-for
25 any 2-hour period during the radioactivity release should be calculated.
- 26 • For the low-population zone, the TEDE should be calculated for the duration of the accident
27 release (i.e., 30 days, or other duration as justified).
- 28 • Comparison of the DBA doses with the dose criteria given in regulations related to the
29 application (e.g., 10 CFR 50.34(a)(1) [TN249], 10 CFR 52.17(a)(1) and 10 CFR 52.79(a)(1)
30 [10 CFR Part 52-TN251]), standard review plans (SRPs) (e.g., SRP criteria, Table 1 in SRP
31 Section 15.0.3 of NUREG-0800 [NRC 2007/2019-TN6221]), and RGs, (e.g., RG 1.183
32 [NRC 2000-TN517]), as applicable.

33 *3.11.1.2 Accidents Involving Releases of Hazardous Chemicals*

34 The effects of hazardous chemical releases from nearby facilities have traditionally been
35 reviewed as part of safety reviews for their effects on control room habitability (see

¹⁶ For the purposes of this GEIS, “Design Basis Accidents” are related to a spectrum of accidents that will be evaluated for satisfying siting requirements (e.g., 10 CFR Part 100) and the safety analysis requirements (e.g., 10 CFR Part 50, Part 52) or the applicable NRC safety and siting regulations in place at the time the application is docketed).

1 NUREG-0800, Section 2.2.1–2.2.2, Identification of Potential Hazards in Site Vicinity, and
2 Section 6.4, Control Room Habitability System; NRC 2007-TN613).

3 EPA also regulates hazardous chemicals. For example, the Risk Management Plan Rule
4 (40 CFR Part 68-TN5494) requires facilities that produce, process, or store extremely
5 hazardous substances must identify hazards associated with an accidental release, design and
6 maintain a safe facility, prepare a Risk Management Plan (RMP) and minimize consequences of
7 accidental releases that occur. Facilities holding more than a threshold quantity (TQ) of a
8 regulated substance in a process are required to comply with 40 CFR Part 68 (TN5494). As
9 provided in 40 CFR 68.130, Tables 1, 2, 3, and 4 list the regulated substances and their TQs.

10 The Emergency Planning and Community Right-to-Know Act (EPCRA) requires that if an
11 extremely hazardous substance (EHS) in quantities at or above the Threshold Planning
12 Quantity (TPQ) is present at a facility, then certain emergency planning activities must be
13 conducted. For example, Local Emergency Planning Committees (LEPCs) must develop
14 emergency response plans and facility owner or operator must notify the State Emergency
15 Response Commission or Tribal Emergency Response Commission and their LEPC if any of
16 the EHS is present at the facility or above its TPQ. The EHSs and their TPQs are listed in
17 40 CFR Part 355, Appendices A and B (40 CFR Part 355-TN5493).

18 Because of the potential for the use of hazardous chemicals in the operation of a new reactor,
19 there is also the potential for releases of hazardous chemicals as a result of postulated
20 accidents. In developing the PPE values and assumptions pertaining to accidents involving
21 releases of hazardous chemicals, the staff assumed that if a regulated substance or EHS is
22 present at a new reactor facility in quantities less than the requirement for establishing an RMP
23 and offsite emergency planning, then the consequences of releases of these hazardous
24 chemicals would be small. To establish the PPE, the staff is applying the list of regulated
25 substances and TQs contained in 40 CFR 68.130, and the list of EHSs and TPQs contained in
26 40 CFR Part 355, Appendices A and B (TN5493). The PPE assumptions are as follows:

- 27 • new reactor inventory of a regulated substance is less than its TQ. TQs are found in 40 CFR
28 68.130, Tables 1, 2, 3, and 4 (TN5494); and
- 29 • new reactor inventory of an EHS is less than its TPQ. TPQs are found in 40 CFR Part 355,
30 Appendices A and B (TN5493).

31 If the PPE above is exceeded and a new reactor facility has the potential to release hazardous
32 chemicals from licensed operations, the applicant should provide an analysis in the ER that
33 estimates the consequences to members of the public in the event of such a release. Generally
34 available information or protective emergency guidelines can be useful when characterizing the
35 consequences (e.g., Acute Exposure Guideline Levels (AEGs),¹⁷ Emergency Response
36 Planning Guidelines,¹⁸ Temporary Emergency Exposure Limits,¹⁹ or Protective Action Criteria

¹⁷ AEGs are guidelines designed to help responders deal with emergencies involving chemical spills or other catastrophic events during which members of the general public are exposed to a hazardous airborne chemical (NOAA ORR 2019-TN7023).

¹⁸ Emergency Response Planning Guidelines are guidelines designed to anticipate the health effects from exposure to certain airborne chemical concentrations (NOAA ORR 2019-TN7024).

¹⁹ Temporary Emergency Exposure Limits are guidelines designed to predict the response of members of the general public to different concentrations of a chemical during an emergency response incident (NOAA ORR 2020-TN7025).

1 for Chemicals.²⁰ Relevant analysis prepared for compliance with other State or Federal
2 regulations (e.g., an RMP submitted under 40 CFR Part 68 [TN5494]) should be provided as
3 applicable.

4 *3.11.1.3 Severe Accidents*

5 The Commission provided direction to the staff for the environmental assessment of severe
6 accidents in their policy statement entitled “Nuclear Power Plant Accident Considerations Under
7 the National Environmental Policy Act of 1969,” which includes the following statements
8 (45 FR 40101-TN4270):

9 It is the position of the Commission that its Environmental Impact Statements,
10 pursuant to Section 102(c)(i) of the National Environmental Policy Act of 1969
11 [42 U.S.C. §§ 4321 et seq.; TN661], shall include a reasoned consideration of the
12 environmental risks (impacts) attributable to accidents at the particular facility or
13 facilities within the scope of each such statement. In the analysis and discussion
14 of such risks, approximately equal attention shall be given to the probability of
15 occurrence of releases and to the probability of occurrence of the environmental
16 consequences of those releases. Releases refer to radiation and/or radioactive
17 materials entering environmental exposure pathways, including air, water, and
18 groundwater.

19 and

20 The environmental consequences of releases whose probability of occurrence
21 has been estimated shall also be discussed in probabilistic terms. Such
22 consequences shall be characterized in terms of potential radiological exposures
23 to individuals, to population groups, and, where applicable, to biota. Health and
24 safety risks that may be associated with exposures to people shall be discussed
25 in a manner that fairly reflects the current state of knowledge regarding such
26 risks. Socioeconomic impacts that might be associated with emergency
27 measures during or following an accident should also be discussed. The
28 environmental risk of accidents should also be compared to and contrasted with
29 radiological risks associated with normal and anticipated operational releases.

30 The technical rationale for evaluation of the applicant’s severe accident analysis is discussed in
31 Section 7.2 of the Environmental Standard Review Plan (NRC 2007-TN5141) as follows:

32 The Commission has determined that the evaluation of events or accident
33 sequences that lead to releases shall include, but not be limited to, those events
34 or sequences that can reasonably be expected to occur. It has also stated that
35 the environmental consequences of releases whose probability of occurrence
36 has been estimated shall be discussed in probability terms. The consequences of
37 the accidents that can reasonably be expected to occur are expressed in terms
38 of potential exposure to individuals; the consequences of severe accidents
39 referred to as probabilistic accidents in the policy statements [50 FR 32138-
40 TN4519, 51 FR 30028-TN594] are characterized in terms of exposure to
41 population groups.

²⁰ The Protective Action Criteria for Chemicals data set is a hierarchy-based system of the three common public exposure guideline systems (AEGs, ERPGs, and Temporary Emergency Exposure Limits) (NOAA ORR 2020-TN7026).

1 Releases refer to radiation or radioactive materials or both entering
2 environmental exposure pathways, including air, water, and groundwater. In-
3 plant accident sequences that can lead to a spectrum of releases shall be
4 discussed and shall include sequences that can result in inadequate cooling of
5 reactor fuel and melting of the reactor core. The events arising from causes
6 external to the plant that are considered possible contributors to the risk
7 associated with the plant should be discussed. Socioeconomic impacts
8 associated with emergency measures during or following an accident should also
9 be discussed, and the environmental risks compared to and contrasted with
10 radiological risks should be associated with normal and anticipated operational
11 releases.

12 The Commission also takes the position that detailed quantitative considerations
13 that form the basis of probabilistic estimates of releases do not need to be
14 incorporated into the EIS, but may be referenced, including references to safety
15 evaluation reports.

16 3.11.1.4 Severe Accident Mitigation Design Alternatives

17 The purpose of the evaluation of severe accident mitigation alternatives (SAMAs) is to
18 determine whether there are severe accident mitigation design alternatives (SAMDA),
19 procedural modifications, or training activities that can be justified to further reduce the risks of
20 severe accidents (NRC 2000-TN614). Because new reactors are not anticipated to have
21 established appropriate training and procedures to address severe accidents, this review will
22 only focus on SAMDAs.

23 The current guidance for SAMAs is based on several documents, including NUREG/BR-0058,
24 *Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission* (NRC 2004-
25 TN670), and NUREG/BR-0184, *Regulatory Analysis Technical Evaluation Handbook*
26 (NRC 1997-TN676), with industry guidance for license renewals provided in Nuclear Energy
27 Institute (NEI) 05-01, *Severe Accident Mitigation Alternatives (SAMA) Analysis, Guidance*
28 *Document* (NEI 2005-TN1978). However, the expected probabilities for a new reactor severe
29 accident could be very low. In such a case, a simple SAMA screening could determine whether
30 a detailed SAMA evaluation is necessary, or that a potentially cost-beneficial SAMA does not
31 exist.

32 The screening process should be based on the available risk information from the Final Safety
33 Analysis Report (FSAR)/Preliminary Safety Analysis Report (PSAR) and apply selected cost
34 formulas from NUREG/BR-0184 (NRC 1997-TN676) as a first step rather than a last step, as
35 prescribed under current SAMA practices. The cost formulas for occupational exposure risk
36 cost, cleanup and decontamination risk cost, and replacement power risk cost are all
37 independent of offsite consequences and have input parameters that should be readily
38 available. If the resulting partial maximum benefit cost is clearly low enough that even the
39 largest hypothetical offsite population dose and offsite economic risks for the new reactor design
40 could not raise the maximum benefit to match or exceed the lowest possible implementation
41 cost for any design alternative, then there cannot be a potentially cost-beneficial SAMA.
42 However, if the screening cannot reach such a conclusion, then a detailed SAMA evaluation is
43 necessary using the abovementioned guidance documents.

44 The current guidance referenced above uses core damage frequency (CDF) to express the
45 probability of severe accidents that have a potential effect on the environment, including in cost

1 formulas. CDF is a value that is determined in LWR probabilistic risk assessments (PRAs).
2 However, such a parameter may not be available or applicable to non-LWR PRAs. For non-
3 LWR SAMA screening and assessments, event or release category frequency could be used in
4 place of CDFs.

5 3.11.1.5 Acts of Terrorism

6 Previous U.S. Courts of Appeals decisions addressed the circumstances under which the NRC
7 must assess the environmental impacts of potential acts of terrorism and sabotage. The U.S.
8 Court of Appeals for the Ninth Circuit held that the NRC could not categorically refuse to
9 consider the consequences of a terrorist attack in an analysis under NEPA.²¹ The Commission
10 thereafter stated it would adhere to the Ninth Circuit's decision by considering the potential
11 impacts of a terrorist attack in making licensing decisions for facilities located within the Ninth
12 Circuit's jurisdiction but it would not consider terrorist attacks in licensing decisions outside of
13 that court's jurisdiction.²²

14 The U.S. Court of Appeals for the Third Circuit disagreed with the Ninth Circuit's analysis of
15 NEPA case law.²³ Instead, as the Commission had originally held, the Third Circuit concluded
16 that the issuance of a facility license would not be the "proximate cause" of a terrorist attack on
17 the facility.²⁴ Moreover, the Third Circuit noted that the License Renewal GEIS (NRC 1996-
18 TN288) had reviewed the possible impacts of a sabotage event, which is a form of terrorism.
19 The License Renewal GEIS found that the consequences of a sabotage event would be no
20 worse than those expected from an internally initiated severe accident. As a result, the Third
21 Circuit found that, even if the Commission were required to analyze the impacts of a terrorist
22 attack, the NRC could not have evaluated the risks more meaningfully than it had already done
23 for internally initiated severe accidents.²⁵

24 These court decisions related to NEPA evaluations of terrorist attacks and the NRC staff's
25 subsequent evaluations to address them are discussed in Section E.3, Accident Risk and
26 Impact Assessment, of Appendix E, Environmental Impact of Postulated Accidents, to the
27 License Renewal GEIS (NRC 2024-TN10161), and in Section 4.19, Potential Acts of Sabotage
28 or Terrorism, of NUREG-2157 (NRC 2014-TN4117), which are incorporated herein by
29 reference.

30 As a result of these court decisions, the NEPA evaluation of an application for a new reactor to
31 be located at a site within the Ninth Circuit's jurisdiction would need to address acts of terrorism.
32 For sites not within the jurisdiction of the Ninth Circuit, the NEPA evaluation would not address
33 acts of terrorism.

34 As described in Appendix E of the License Renewal GEIS (NRC 2024-TN10161) and in
35 Section 4.19 of NUREG-2157 (NRC 2014-TN4117), the NRC will continue to address facility
36 physical security measures, including the prevention of and response to terrorist attacks,
37 through its ongoing regulatory and inspection processes. The NRC routinely assesses threats

²¹ *San Luis Obispo Mothers for Peace v. NRC*, 449 F.3d 1016 (9th Cir. 2006) (San Luis Obispo Peace v. Nuclear Regulatory 2006-TN6959).

²² *AmerGen Energy Co., LLC* (Oyster Creek Nuclear Generating Station), CLI-07-8, 65 NRC 124, 126, 128 (NRC 2007-TN6957).

²³ *New Jersey Dept of Environmental Protection v. NRC*, 561 F.3d 132 (3rd Cir. 2009) (NJ Dept. of Environmental Protection v. NRC-TN6958).

²⁴ *Id.*, 561 F.3d at 140.

²⁵ *Id.*, 561 F.3d at 134, 136, 143-44.

1 and other information provided by a variety of Federal agencies and sources. The NRC also
2 ensures that licensees meet appropriate security-level requirements. In this regard, the NRC
3 views facility physical security measures as a current, ongoing, and generic regulatory issue
4 that affects all nuclear facilities.

5 **3.11.2 Postulated Accidents Impacts**

6 New reactor designs could be water-cooled large nuclear power plants (e.g., LWRs like the
7 AP1000), water-cooled small modular reactors (e.g., the NuScale SMR), or non-LWRs (e.g.,
8 high temperature gas, molten salt, and liquid sodium cooled nuclear power plants). The risks
9 from new reactor accidents may be limited. A major emphasis for the development of new
10 reactors is the minimization (i.e., a very low probability of an accident with an offsite radiological
11 or hazardous chemical release) or the elimination of radioactive or hazardous chemical releases
12 from accidents. Thus, the risks from new reactor accidents may be limited as presented in the
13 FSAR/PSAR of the new reactor application. However, the NRC staff cannot prejudge the level
14 of safety of a new reactor design a priori and, therefore, cannot rule out the need for a
15 postulated accident analysis in future license applications. To this end, this section also
16 incorporates the related guidance on postulated accidents and SAMAs from ISG-029,
17 “Environmental Considerations Associated with Micro-reactors” (NRC 2020-TN6710).

18 To support the licensing of non-LWR designs, the staff developed and published RG 1.233,
19 *Guidance for a Technology-Inclusive, Risk-Informed, and Performance-Based Methodology to*
20 *Inform the Licensing Basis and Content of Applications for Licenses, Certifications, and*
21 *Approvals for Non-Light-Water Reactors* (NRC 2020-TN6441). The selection of licensing-basis
22 events; classification and special treatments of structures, systems, and components; and
23 assessment of defense-in-depth are fundamental to the safe design of non-LWRs. The
24 guidance provided in RG 1.233 may assist in the development of the new reactor applicant’s
25 accident analysis in the FSAR/PSAR. Regardless of whether or not a new reactor applicant
26 chooses to conform to RG 1.233, the applicant is required to provide an evaluation of events
27 including accident analyses, and for Part 52 applicants, a description and the results of the
28 project-specific probabilistic risk assessment in the FSAR/PSAR, which may be incorporated by
29 reference in the new reactor application’s ER in order to meet the PPE assumptions.

30 This section addresses all design types of new reactors because the accident analysis is tied to
31 possible radioactive releases from postulated accidents and not for a specific type of new
32 reactor design.

33 Based on the analyses in Section 3.11.1, the following five environmental issues related to
34 impacts from postulated accidents associated with a new reactor are discussed:

- 35 • design basis accidents involving radiological releases
- 36 • design basis accidents involving releases of hazardous chemicals
- 37 • severe accidents
- 38 • severe accident mitigation design alternatives
- 39 • acts of terrorism.

1 3.11.2.1 *Design Basis Accidents Involving Radiological Releases*

2 The environmental guidance for LWR DBA evaluations is provided in the current versions of
3 RG 4.2 (NRC 2024-TN7081) and Section 7.1 of NUREG-1555 (NRC 2013-TN3547). Prior LWR
4 DBA environmental evaluations were slightly different than the DBA analysis considered in the
5 safety reviews. Specifically, the environmental review of DBAs was based on applying
6 dispersion coefficients based on 50th percentile weather data (i.e., “realistic” weather
7 conditions) versus the 95th percentile weather data applied in the applicant’s DBA analysis in
8 Chapter 15 of the FSAR/PSAR. All other factors, such as accident categories and timeframes,
9 were the same for the two assessments. At the conclusion of the staff’s safety review, the
10 applicant’s DBA analysis would have to demonstrate to the staff that no regulatory limits were
11 exceeded, in part, for the NRC to issue the license. This also meant that 50th percentile weather
12 conditions used in the environmental DBA evaluation would also meet the same regulatory
13 limits, resulting in an environmental finding of SMALL. However, given that the safety evaluation
14 must reach a safety determination for DBAs for a license to be issued, it is reasonable to
15 conclude that the staff can also reach an environmental finding of SMALL (i.e., by meeting
16 regulatory requirements for safety) by relying on the DBA analysis in the applicant’s
17 FSAR/PSAR. Therefore, in future new reactor applications, the staff should be able to
18 incorporate by reference into the environmental evaluation the DBA analysis from the
19 FSAR/PSAR and the staff’s safety evaluation of DBAs.

20 DBAs involving radiological releases are a Category 1 issue. The FSAR/PSAR must
21 demonstrate that the reactor falls within the regulatory limits discussed in Section 3.11.1; with
22 incorporation by reference to the ER, the PPE values would be met, and the impacts would be
23 SMALL. The staff relied on the following PPE assumptions to reach this conclusion:

- 24 • For the exclusion area boundary, the maximum TEDE-for any 2-hour period during the
25 radioactivity release should be calculated.
- 26 • For the low-population zone, the TEDE should be calculated for the duration of the accident
27 release (i.e., 30 days, or other duration as justified).

28 The above calculations would compare the DBA doses with the dose criteria given in
29 regulations related to the application (e.g., 10 CFR 50.34(a)(1) [TN249], 10 CFR 52.17(a)(1)
30 and 10 CFR 52.79(a)(1) [10 CFR Part 52-TN251]), SRPs (e.g., SRP criteria, Table 1 in SRP
31 Section 15.0.3 of NUREG-0800 [NRC 2007/2019-TN6221]), and RGs, (e.g., RG 1.183
32 [NRC 2000-TN517]), as applicable.

33 3.11.2.2 *Accidents Involving Releases of Hazardous Chemicals*

34 Accidents involving releases of hazardous chemicals are a Category 1 issue. The applicant can
35 rely on the on the generic analysis in this GEIS if the new reactor inventories of regulated
36 substances and EHSs are less than their TQs and TPQs, respectively, and the impacts would
37 be SMALL. The staff relied on the following PPE assumptions to reach this conclusion:

- 38 • new reactor inventory of a regulated substance is less than its TQ. TQs are found in 40 CFR
39 68.130, Tables 1, 2, 3, and 4 (TN5494)
- 40 • new reactor inventory of an EHS is less than its TPQ. TPQs are found in 40 CFR Part 355,
41 Appendices A and B (TN5493)

1 3.11.2.3 *Severe Accidents*

2 Severe accidents are a Category 2 issue. Based on the analysis in the FSAR/PSAR regarding
3 severe accidents and PRAs, if a new reactor design has severe accident progressions that
4 involve radiological or hazardous chemical releases, then an environmental risk evaluation must
5 be performed.

6 3.11.2.4 *Severe Accident Mitigation Design Alternatives*

7 It is expected that for severe accidents, although a Category 2 issue, the probabilistic risk
8 assessment provided in the safety analysis would have CDFs that would likely be substantially
9 less than the CDFs associated with the current reactor fleet. For non-LWR SAMA screening and
10 assessments, event or release category frequency could be used in place of CDFs. A cost
11 screening could determine that the maximum benefit of avoiding an accident is so small that a
12 SAMDA is not justified based on the minimum cost to design an appropriate SAMDA. This is a
13 Category 1 issue. The staff relied on the following PPE assumption to reach this conclusion:

- 14 • If a cost-screening analysis determines that the maximum benefit for avoiding an accident is
15 so small that a SAMDA analysis is not justified based on a minimum cost to design an
16 appropriate SAMDA.

17 This cost-screening process would be based on the available risk information derived from the
18 FSAR/PSAR and would apply the cost formulas from NUREG/BR-0058 (NRC 2004-TN670). If
19 SAMDAs are not screened out, the bounding assumption is not met and a project-specific
20 analysis is required. For example, the NuScale SMR 50 MWe single module has eight accident
21 release categories and seven out of eight accident release categories have release frequencies
22 of 2.4×10^{-9} per reactor-year or smaller (NuScale 2020-TN6811). The total estimated maximum
23 benefit of these seven low-probability release categories would be less than \$100. It is unlikely
24 that a design mitigation alternative could be developed costing less than \$100, so there is no
25 need to develop potential mitigation strategies.

26 3.11.2.5 *Acts of Terrorism*

27 The NRC staff has determined that the environmental impacts of acts of terrorism and sabotage
28 only need to be addressed if a new reactor facility is subject to the jurisdiction of the U.S. Court
29 of Appeals for the Ninth Circuit. Because the environmental impacts of a facility subject to the
30 jurisdiction of this court cannot be determined without the consideration of project-specific
31 factors, the potential impacts of terrorism and sabotage for these facilities would require a
32 project-specific analysis. The necessary environmental evaluation would be performed based
33 on the design features that provide for physical protection of the new reactor from acts of
34 terrorism and sabotage. The impacts of acts of terrorism can be mitigated by complying with the
35 physical protection requirements under 10 CFR Part 73 (TN423), *Physical Protection of Plants*
36 *and Materials*, that provide reasonable assurance that the risk from sabotage is small. If a
37 facility is not subject to the jurisdiction of the U.S. Court of Appeals for the Ninth Circuit, then
38 this would be a Category 1 issue, since no other jurisdiction currently requires consideration of
39 the consequences of a terrorist attack in an analysis under NEPA.

1 **3.12 Socioeconomics**

2 **3.12.1 Baseline Conditions and PPE/SPE Values and Assumptions**

3 Baseline conditions influencing potential socioeconomic resources associated with the building
4 and operation of a new nuclear reactor include the economic and social service conditions
5 found currently in the vicinity of the site. The analysis will depend on information supplied by the
6 applicant. The applicable NRC guidance is Section 4.4 of RG 4.2, Revision 3, *Preparation of*
7 *Environmental Reports for Nuclear Power Stations* (NRC 2024-TN7081).

8 The NRC's Environmental Standard Review Plan (NRC 2000, 2007-TN614) suggests beginning
9 an analysis of the economic and demographic impacts of building and operating a nuclear
10 power reactor on an area within a 50-mile radius from the proposed plant. Depending on the
11 size and inherent safety features of new reactor designs, the radius of the analytical areas may
12 be reduced from that starting point. The demographic region is the geographic area within a
13 defined radius from the site for which demographic data are analyzed. Facility sites are located
14 within economic regions defined by the local labor market. The economic region for any facility
15 is based on the geographic area from which the facility will draw its workforce—typically a
16 grouping of counties surrounding the site. The economic region and the demographic region
17 may not be the same size or shape.

18 The socioeconomic characteristics of potential sites for new reactors can vary widely, from
19 sparsely populated remote outposts to industrial facilities located in major metropolitan centers.
20 Thus, the staff adopted PPE/SPE values that are proportional metrics based on percentage
21 changes from baseline conditions, rather than absolute values.

22 The PPE and SPE assume that most socioeconomic impacts are driven by changes in the local
23 workforce employed as a result of the proposed action. The in-migration of workers and their
24 families into an economic region for project building and operations, including outage activities,
25 imposes new demands on local infrastructure and community services. Previous new reactor
26 reviews also have shown that traffic impacts on local access routes may be greater than minor,
27 but not typically destabilizing. Beneficial impacts from increased tax revenues associated with
28 the increased assessed value of new reactor projects also tend to be noticeable within the
29 affected economic region or local taxing jurisdiction.

30 Based on staff experience with new license applications for large LWRs, the NRC staff has
31 developed PPE/SPE values for each socioeconomic resource, which, if met, allow the staff to
32 reach a generic conclusion of beneficial or SMALL adverse impacts for that resource. The
33 principal assumption is that the project-related workforce together with associated families
34 would not result in a net increase in the population of the economic region that would be greater
35 than the planned growth for that region by local agencies over the same time period. Based on
36 workforce migration into the economic region, staff determined demand increases for
37 infrastructure (e.g., housing availability) and services (e.g., public schools) would not result in
38 specific thresholds being crossed. Similarly, the staff assumes that the LOS values for the
39 affected roadways would not change as a result of the added traffic pressure from the project
40 workforce traffic.

41 In summary, the NRC staff provides the following PPE/SPE values (also summarized in
42 Appendix G):

- 1 • The peak project-related in-migrating workforce including families does not exceed
2 established local planning and growth projections for infrastructure and service demands.
- 3 • The housing vacancy rate in the affected economic region does not change by more than
4 5 percent, or at least 5 percent of the housing stock remains available.
- 5 • The student:teacher ratios in the affected economic region’s classrooms do not exceed
6 locally mandated levels after including the school age children of the in-migrating worker
7 families.
- 8 • The LOS determination for affected roadways does not change with the addition of the
9 commuting patterns of the building or operations workforce.

10 **3.12.2 Socioeconomic Impacts**

11 Socioeconomic impacts from new reactors would occur during the building and operations
12 phases of the project. Impacts are linked to the size of the local workforce during site
13 preparation and the construction of safety-related facilities such as the nuclear island and non-
14 safety-related facilities such as cooling towers, administration buildings, parking lots,
15 switchyards, and any onsite and offsite pipelines, access roads, and transmission lines. Many
16 smaller new reactors may lack cooling towers, switchyards, or offsite pipelines or transmission
17 lines and may require a site of only a few acres. Larger new reactors may require some or all of
18 these support facilities and hence require larger sites. During operations, the principal
19 socioeconomic impacts would be from employment of the operations workforce and tax revenue
20 generated based on the assessed value of the project.

21 *3.12.2.1 Socioeconomic Consequences of Construction*

22 Historically, the staff’s evaluation of socioeconomic impacts for building a new reactor primarily
23 focused on the in-migration of construction workers and their resulting impacts on local
24 community resources and infrastructure, and related economic impacts. These impacts can vary
25 considerably from site to site and between building and operations. The NRC staff identified four
26 socioeconomic issues for analysis of building a new reactor:

- 27 • community services and infrastructure demands (specifically, housing and schools) altered
28 by construction workers and families migrating to the local economic region; traffic impacts
29 on local site access roadways and associated road networks; economic impacts such as
30 employment, economic output, and local labor income; and
- 31 • tax revenue impacts, such as sales and property taxes.

32 *3.12.2.1.1 Community Services and Infrastructure*

33 To the degree that the size of the construction project requires the acquisition of workers from
34 outside the economic region, impacts related to worker migration would be expected. These
35 impacts occur as workers, including families, relocate temporarily or permanently to be closer to
36 the site. Impacts from local workers already residing within the economic region are assumed to
37 result in no net changes in service demands across the economic region, except as a part of
38 traffic impacts.

39 The impacts of migration from outside the economic region are found by obtaining the
40 applicant’s estimate of the peak construction workforce anticipated to come from outside the
41 economic region. In recent new reactor reviews, the NRC staff evaluated the impacts from in-

1 migrating workers and their families in the context of the local planning authority's estimate of
2 population growth in the economic region. If the percentage of in-migrating construction workers
3 and their families relative to the total population of the economic region is less than the planned
4 rate of population growth in the economic region during the construction period, the reviewer
5 can determine the construction-related impact on housing, community services, and
6 infrastructure are within the planning authority's management capabilities and, therefore, would
7 be minor.

8 Recent new reactor reviews have shown that the principal community service affected by
9 building a new reactor is public school systems. As families migrate into the economic region,
10 local schools may observe increased class sizes at all levels. The PPE value of student:teacher
11 ratio is the principal metric used to assess classroom crowding impacts. The NRC staff
12 assumes that the impact of the new students would be minor as long as the addition of new
13 students from in-migrating worker's families does not increase the student:teacher ratio beyond
14 the locally mandated level.

15 Based on recent reviews of new reactors, the key infrastructure impact metric is housing
16 availability. This metric is assessed in terms of the proportion of the housing stock that is
17 available for residency. The staff assumes that the combination of available unoccupied
18 single-family dwellings and rental housing should remain greater than 5 percent in a healthy
19 housing market with relatively stable prices. The impact on housing would be minor, if the
20 addition of the in-migrating workers does not change the housing supply by 5 or more percent,
21 or if the available number of rental units in the economic region is 5 percent or more after
22 accounting for the rental units needed for the in-migrating construction workers.

23 Experience reviewing new reactors has shown that other community service and infrastructure
24 impacts are generally minor. These include impacts on first-responder resources, public utilities
25 including potable water resources, health care resources, and other public services (e.g.,
26 community aid providers).

27 The staff has determined that the public school system and housing availability are the most
28 likely places where impacts on community services and infrastructure can be observed during
29 building of a new reactor. The staff concludes that, as long as the applicable PPE and SPE
30 assumptions are met, the community services and infrastructure impacts from building a new
31 reactor can be generically determined to be SMALL and mitigation would not be warranted.
32 Therefore, the socioeconomic impacts from building a new reactor are a Category 1 issue. The
33 staff relied upon the following PPE assumptions to reach this determination:

- 34 • The housing vacancy rate in the affected economic region does not change by more than
35 5 percent, or at least 5 percent of the housing stock remains available after accounting for
36 in-migrating construction workers.
- 37 • Student:teacher ratios in the affected economic region do not exceed locally mandated
38 levels after including the school age children of the in-migrating worker families.

39 *3.12.2.1.2 Transportation Systems and Traffic*

40 Facility building activities result in physical impacts on two aspects of local transportation
41 systems in the vicinity of the site: improvements and repairs to roads in anticipation of the
42 project, and traffic-related impacts (the decline in road service quality from construction worker
43 commutes). Transporting materials and equipment to the proposed site may require the
44 applicant to build or refurbish access roads, heavy-haul roads, rail spurs, and barge landing

1 facilities. Local road access routes also may see increased wear from building-related traffic
 2 associated with the workforce commuting and deliveries. Experience from previous NEPA
 3 reviews of large nuclear power plant construction shows the adverse impacts of making road
 4 improvements are typically minor and temporary.

5 Construction-related traffic impacts occur as construction-related truck traffic and the workforce
 6 travel to and from the site in competition with the baseline local traffic. At the peak of building
 7 employment, these impacts can be substantial, depending on the characteristics of the access
 8 route(s). To give context to any expected traffic impacts affecting the site and local vicinity, the
 9 NRC staff uses baseline traffic statistics for the principal roadway access routes to and from the
 10 site. State and County transportation departments typically publish annual average daily traffic
 11 counts (FHWA 2018-TN6584) at key points of principal roads and highways. In addition, the
 12 NRC staff analyzes LOS information (FHWA 2017-TN6585) used by transportation planners for
 13 principal road access routes. Table 3-7 provides a summary of LOS values.

14 **Table 3-7 Level of Service Value Descriptions**

| Level of Service | General Operating Conditions |
|------------------|---|
| A | Free flow, with low volumes and high speeds. |
| B | Reasonably free flow, but speeds beginning to be restricted by traffic conditions. |
| C | Stable flow, but most drivers are restricted in the freedom to select their own speeds. |
| D | Approaching unstable flow; drivers have little freedom to select their own speeds. |
| E | Unstable flow; may be short stoppages. |
| F | Forced or breakdown flow; unacceptable congestion; stop-and-go. |

15 One indicator of a noticeable impact would be a change in a LOS value for a specific roadway.
 16 The PPE and SPE values and assumptions analyzed in this GEIS assume no change in a LOS
 17 value as a result of increased traffic during peak building activities. The staff assumes such
 18 impacts would be of temporary duration (months) and limited to typical day-shift commuting
 19 patterns for the affected roadways. Section 4.4 of RG 4.2, *Preparation of Environmental Reports*
 20 *for Nuclear Power Stations* (NRC 2024-TN7081) regarding traffic studies and the timing of peak
 21 building activities recommends that the applicant use LOS studies to demonstrate that its
 22 project falls within the PPE value.

23 The NRC staff has determined that as long as the applicable PPE and SPE values and
 24 assumptions are met, the traffic impacts and impacts on the local transportation systems from
 25 building a new reactor can be generically determined to be SMALL and a Category 1 issue. The
 26 staff relied upon the following PPE assumptions to reach this determination:

- The LOS determination for affected roadways does not change. Mitigation measures may include implementation of traffic flow management, management of shift-change timing, and encouragement of ride-sharing and use of public transportation options, such that LOS values can be maintained with the increased volumes.

31 **3.12.2.1.3 Economic Impacts**

32 Building new reactor projects has financial and economic impacts on the economic region.
 33 These impacts include construction-related expenditures expected to be made by the applicant
 34 in the local economy, wages and salaries to be paid to construction workers, and the associated
 35 economic activity enabled by these expenditures. Depending on the size of the local economy,

1 these beneficial impacts may range from substantial in small rural economies to minimal in large
2 metropolitan economies, when viewed in the context of the overall economic activity in the
3 region.

4 The NRC staff has assessed the economic impacts of building new nuclear reactors since 2005.
5 To estimate the economic impacts of anticipated construction-related expenditures made in the
6 local economy, the NRC relies upon simple economic input-output modeling of those
7 expenditures to reveal the economic multiplier effect, which estimates the gross output,
8 employment, and income effects of the direct local expenditures. Economic multiplier effects
9 depend on several factors including the size of the initial annual expenditures and the diversity
10 of the local economy. Economic diversity refers to how fast local expenditures leak from the
11 economy as various rounds of economic activity occur. The more diverse the structure of the
12 local economy, the longer direct expenditures will circulate in the economy, generating a higher
13 multiplier effect and greater total impact on output, employment, and income. Because sites can
14 be located in widely varying local economies, economic multiplier values range widely—typically
15 between 1.5 and 4. For example, in the case of an employment multiplier of 3, this indicates that
16 for each direct job created by the construction expenditures, an additional two jobs are also
17 added as a result of the economic activity generated by the one direct construction job. The
18 economic impacts of construction and operation of a new reactor are expected to be beneficial;
19 therefore, this is a Category 1 issue. If, during the project-specific environmental review, the
20 NRC staff determines that detailed analysis of economic costs and benefits is needed for
21 analysis of the range of alternatives considered or relevant to mitigation, the staff may require
22 further information from the applicant.

23 *3.12.2.1.4 Tax Revenue Impacts*

24 While the greatest tax revenue impacts are generally associated with plant operations, some
25 revenue impacts would be expected during the building of a plant. These include any local sales
26 and use taxes paid on local or in-State purchases, service fees from local regulatory bodies
27 (local licenses and permits, etc.), any local taxes paid by in-migrating workers and their families,
28 or payments in lieu of taxes arranged by agreement between the applicant and the jurisdiction.
29 Each site will have differing conditions and agreements with applicants and their contractors and
30 thus revenue impacts during building must be considered site by site. For example, some States
31 and local governments may offer incentives for new industrial construction projects, such as
32 deferred property taxes or sales tax exemptions, which might minimize State and local tax
33 revenues compared to other sites where such incentives are not offered.

34 As with economic impacts, the scale of construction-related tax revenue impacts attributable to
35 the proposed action may range from substantial in small rural economies to minimal in large
36 metropolitan economies, when viewed in the context of baseline revenues of the affected taxing
37 jurisdiction(s) and the size of the proposed action. The staff concludes that if the new reactor
38 project would not generate tax revenues exceeding 5 percent of the revenue of any affected
39 jurisdiction or taxing authority during building, then the impacts would be minor and may be
40 offset by other year-to-year changes in local revenues.

41 The tax revenue impacts of construction and operation of a new reactor are expected to be
42 beneficial; therefore, this is a Category 1 issue. If, during the project-specific environmental
43 review, the NRC staff determines detailed analysis of tax revenue costs and benefits is needed
44 for analysis of the range of alternatives considered or relevant to mitigation, the staff may
45 require further information from the applicant.

1 3.12.2.2 Socioeconomic Consequences of Operations

2 The staff's evaluation of socioeconomic impacts for operating a new reactor primarily focused
3 on workforce-induced migration, the resulting impacts on local community resources and
4 infrastructure, and related economic impacts. Tax revenue impacts from an operating reactor
5 facility also provide beneficial impacts on local taxing jurisdictions. These impacts can vary
6 considerably from site to site and between building and operations. The NRC staff identified four
7 environmental issues for analysis of operation of a new reactor:

- 8 • community services and infrastructure demands (e.g., housing, schools) altered by
9 operations workers and families migrating into the local economic region; and
- 10 • traffic impacts on local site access roadways and associated road networks.
- 11 • economic impacts such as employment, economic output, and local labor income; and
- 12 • tax revenue impacts, such as sales and property taxes.

13 3.12.2.2.1 Community Services and Infrastructure

14 Based on experience with large LWRs in the current fleet, the staff assumes that a new
15 reactor's operations workforce is smaller than its construction workforce, but their presence
16 would be more permanent. The increased number of workers at nuclear power plants during
17 regularly scheduled plant refueling and maintenance outages creates a short-term increase in
18 the demand for temporary housing units in the region around each plant, generally in local
19 hotels and motels, but also in campgrounds and recreational vehicle parks. However, because
20 of the short duration and the repeated nature of these scheduled outages, as well as the
21 general availability of rental housing units (including portable trailers) in the vicinity of nuclear
22 power plants, employment-related housing impacts would have little or no long-term impact on
23 the price and availability of rental housing. Refurbishment or unit replacement impacts would be
24 similar to what is experienced during routine plant refueling and maintenance outages.
25 Consequently, the staff determined that if the PPE assumption holds, the building-related
26 impacts on housing are a Category 1 issue. The staff relied upon the following PPE assumption
27 to reach this determination:

- 28 • The housing vacancy rate in the affected economic region does not change by more than
29 5 percent, or at least 5 percent of the housing stock remains available after accounting for
30 in-migrating operations workers.

31 Experience reviewing new reactors has shown that the operations-related impacts of other
32 community service and infrastructure resources are bounded by the building-related impacts
33 and are generally minor. These include impacts on first-responder resources, public utilities
34 including potable water resources, health care resources, and other public services (e.g.,
35 community financial aid providers, etc. Minor impacts on public school systems might be
36 expected because of the addition of children of the operations workforce, as families migrate
37 into the economic region. However, because much of the building workforce would leave the
38 area once operation begins, the impacts of the in-migrating operations workforce would be
39 bounded by the size of the construction workforce's impact on the school system. If the building
40 impacts on schools met the criteria for a Category 1 issue, then the operations impacts on
41 housing and schools, being bounded by that, must also be Category 1 issue. The staff
42 concludes that, as long as the applicable PPE and SPE assumptions are met, the community
43 services and infrastructure impacts from operating a new reactor can be generically determined
44 to be SMALL and mitigation would not be warranted. Therefore, the socioeconomic impacts

1 from operating a new reactor are a Category 1 issue. The staff relied upon the following PPE
2 assumptions to reach this determination:

- 3 • Student:teacher ratios in the affected economic region do not exceed locally mandated
4 levels after including the school age children of the in-migrating worker families.

5 *3.12.2.2.2 Transportation Systems and Traffic*

6 Transportation impacts depend on the size of the workforce, the capacity of the local road
7 network, traffic patterns, and the availability of alternate commuting routes to and from the plant.
8 Because most sites have only a single access road, there is often congestion on these roads
9 during shift changes. Because rail and barge facilities would only be used intermittently during
10 operations, only minimal physical impacts on transportation systems, apart from roadways
11 (e.g., rail or barge facilities), would be expected during operations.

12 The transportation impact of plant operations would be bounded by the peak construction
13 employment-related impacts and is not likely to result in degradation of LOS values.
14 Operations-related transportation impacts continue for the life of the plant and become well
15 established within the affected communities for all nuclear power plants. The increased number
16 of workers at nuclear power plants during outage activities including unit replacement creates a
17 short-term increase in traffic volumes, and this impact would vary based on the site location and
18 size of the plant. Refurbishment impacts including unit replacement would be similar to what has
19 been experienced during routine plant refueling and maintenance outages. However, because
20 of the relative short duration of these outages, increased traffic volumes have had little or no
21 lasting impact. Therefore, as long as LOS values for affected roadways do not degrade, there
22 would be minor traffic impacts during operations.

23 The staff has determined that transportation system and traffic impacts during operations of a
24 new reactor are a Category 1 issue, as long as the applicable PPE and SPE assumptions are
25 met. The staff assumes any mitigation measures needed to be able to rely on this GEIS for
26 construction impacts would be continued during operations, such that LOS values can be
27 maintained with expected volumes during operations. The staff relied upon the following PPE
28 assumptions to reach this determination:

- 29 • The LOS determination for affected roadways does not change. Mitigation measures may
30 include implementation of traffic flow management, management of shift-change timing, and
31 encouragement of ride-sharing and use of public transportation options, such that LOS
32 values can be maintained with the increased volumes.

33 *3.12.2.2.3 Economic Impacts*

34 Economic multiplier effects during operations, including outages or unit replacement activities,
35 would be bounded by peak construction-related economic impacts, and the staff assumes that
36 at least minor beneficial economic impacts, such as induced increases in local employment,
37 labor income, and output, would result. The magnitude of these impacts would depend on the
38 size and diversity of the local economy. For most anticipated new reactor projects covered by
39 this GEIS, these impacts would be minor in the context of the economic region in which they
40 would occur.

41 The economic impacts of construction and operation of a new reactor are expected to be
42 beneficial; therefore, this is a Category 1 issue. If, during the project-specific environmental
43 review, the NRC staff determines the need for detailed analysis of economic costs and benefits

1 is needed for analysis of the range of alternatives considered or relevant to mitigation, the staff
2 may require further information from the applicant.

3 **3.12.2.2.4 Tax Revenue Impacts**

4 Nuclear power plants and the workers who operate them are an important source of tax revenue
5 for many local governments and public school systems. Tax revenues from nuclear power
6 plants mostly come from property tax payments or other forms of payments such as payments
7 in lieu of (property) taxes, or payments in lieu of taxes payments, although taxes on energy
8 production have also been collected from a number of nuclear power plants. County and
9 municipal governments and public school districts receive tax revenue either directly or
10 indirectly through State tax and revenue-sharing programs.

11 In addition to the potentially substantial contribution of property tax revenues, County and
12 municipal governments in the vicinity of an operating nuclear power plant also receive tax
13 revenue from sales taxes and service fees from the power plant and its employees. Changes in
14 the number of workers and the amount of taxes paid to counties, municipal governments, and
15 public schools can affect socioeconomic conditions in the counties and communities around the
16 nuclear power plant.

17 Outage activities including unit replacement are not expected to have a noticeable effect on the
18 assessed value of nuclear plants, thus only minimal changes in tax revenues would be
19 anticipated from future refurbishment activities. Refurbishment activities involving the one-for-
20 one replacement of existing components and equipment are generally not considered a taxable
21 improvement. The addition of any nuclear reactor units beyond the scope of the license may
22 result in increased assessed value but would be considered under separate licensing actions.
23 Also, property tax assessments; proprietary payments in lieu of taxes stipulations, settlements,
24 and agreements; and State tax laws are continually changing the amount of taxes paid to taxing
25 jurisdictions by nuclear plant owners. These changes are independent of operations activities.

26 The tax revenue impacts of construction and operation of a new reactor are expected to be
27 beneficial; therefore, this is a Category 1 issue. If, during the project-specific environmental
28 review, the NRC staff determines the need for detailed analysis of tax revenue costs and
29 benefits is needed for analysis of the range of alternatives considered or relevant to mitigation,
30 the staff may require further information from the applicant.

31 **3.13 Environmental Justice**

32 **3.13.1 Baseline Conditions and PPE/SPE Values and Assumptions**

33 Executive Order 12898, "Federal Actions to Address Environmental Justice in Minority
34 Populations and Low-Income Populations," (59 FR 7629-TN1450) directs Federal agencies to
35 identify and address, as appropriate, potential disproportionately high and adverse human
36 health and environmental effects of their actions on minority and low-income populations to the
37 greatest extent practicable and permitted by law. Although independent agencies, such as the
38 NRC, were only requested, rather than directed, to comply with the E.O., NRC Chairman Ivan
39 Selin, in a letter to the President, indicated that "the NRC would endeavor to carry out the
40 measures set forth in the E.O. and the accompanying memorandum as part of the NRC's efforts
41 to comply with the requirements of NEPA." Tribal populations are included within the scope of
42 the Order. Additionally, an affected population can be a minority population, a low-income
43 population, or both. In 2004, the Commission issued its "Policy Statement on the Treatment of

1 Environmental Justice Matters in NRC Regulatory and Licensing Actions” (69 FR 52040-
2 TN1009), which states: “The Commission is committed to the general goals set forth in
3 E.O. 12898, and strives to meet those goals as part of its NEPA review process.”²⁶

4 The environmental justice (EJ) issue is not assigned impact levels as Executive Order 12898
5 requires a determination of whether human health and environmental effects of the proposed
6 agency action on minority and low-income populations would be disproportionately high and
7 adverse. Human health and environmental effects have the potential to occur or not occur, and
8 the effects on minority or low-income populations must be both disproportionately high and
9 adverse when compared to the effects on the general population. For EJ populations within the
10 demographic region, an EJ analysis is required to determine whether that population would
11 experience any disproportionately high and adverse human health or environmental effects. The
12 NRC will perform an EJ analysis as part of the project specific NEPA analysis prepared for the
13 proposed agency action.

14 **3.13.2 Environmental Justice Impacts**

15 *3.13.2.1 Environmental Consequences of Construction and Operation*

16 Potential EJ impacts during construction or operations of a new reactor cannot be determined
17 without the consideration of project-specific factors, and therefore is a Category 2 issue.
18 Project-specific factors include the presence, geographic location, and size of specific minority
19 or low-income populations; impact pathways derived from the plant design, layout, or site
20 characteristics; or other community characteristics affecting specific minority or low-income
21 populations. In performing its EJ analysis, the NRC staff will be guided by the Commission’s
22 “Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and
23 Licensing Actions,” which is hereby incorporated by reference into this GEIS.

24 **3.14 Fuel Cycle**

25 **3.14.1 Baseline Conditions and PPE/SPE Values and Assumptions**

26 *3.14.1.1 Uranium Fuel Cycle Environmental Data*

27 As discussed in Section 3.12.1.1, Uranium Fuel Cycle, of the License Renewal GEIS NRC
28 2024-TN10161), the NRC evaluated the environmental impacts that would be associated with
29 operating uranium fuel cycle facilities other than reactors in two NRC documents: WASH-1248
30 (AEC 1974-TN23) and NUREG-0116 (NRC 1976-TN292). The types of facilities and their
31 environmental impacts considered in these two documents include:

- 32 • uranium mining – facilities in which the uranium ore is mined;


²⁶ In April 2021, the Commission issued Staff Requirements Memorandum M210218B (NRC 2021-TN10335) directing the NRC staff to conduct a systematic review of how agency programs, policies, and activities address environmental justice. The NRC staff submitted its assessment and recommendations in SECY-22-0025, “Systematic Review of How Agency Programs, Policies, and Activities Address Environmental Justice” to the Commission in March 2022 (NRC-TN10334). The NRC staff’s review considered the environmental justice practices of other Federal, State, and Tribal agencies, evaluated the adequacy of the NRC’s Environmental Justice Policy Statement, and assessed whether the NRC should address environmental justice beyond the agency’s current practice limited to National Environmental Policy Act environmental reviews.”

- 1 • uranium milling – facilities in which the uranium ore is refined to produce uranium
2 concentrates in the form of triuranium octaoxide;
- 3 • uranium hexafluoride (UF₆) production – facilities in which the uranium concentrates are
4 converted to UF₆;
- 5 • isotopic enrichment – facilities in which the isotopic ratio of the uranium-235 (U-235) isotope
6 in natural uranium is increased to meet the requirements of LWRs;
- 7 • fuel fabrication – facilities in which the enriched UF₆ is converted to uranium dioxide (UO₂)
8 and made into sintered UO₂ pellets. The pellets are subsequently encapsulated in fuel rods,
9 and the rods are assembled into fuel assemblies ready to be inserted into the reactors;
- 10 • reprocessing – facilities that disassemble the spent fuel assemblies, chop up the fuel rods
11 into small sections, chemically dissolve the spent fuel out of sectioned fuel rod pieces, and
12 chemically separate the uranium in spent fuel from the plutonium for reuse and other
13 radionuclides (primarily fission products and actinides); and
- 14 • disposal – facilities in which the radioactive wastes generated at all fuel cycle facilities,
15 including the reactors, are buried. Spent nuclear fuel (SNF) that is removed from the
16 reactors and not reprocessed was also assumed to be disposed of at a geologic repository.

17 In addition to impacts occurring at the above facilities, the impacts associated with the
18 transportation of radioactive materials among these facilities, including the transportation of
19 wastes to disposal facilities, were evaluated. The results were summarized in a table and
20 promulgated as Table S-3 in 10 CFR 51.51(b) (TN250). The analysis in WASH-1248 is based
21 on the principal environmental considerations for each component of the nuclear fuel cycle, and
22 the aggregate considerations, normalized to the annual fuel requirement of a 1,000 MWe
23 (3,000 MWt) model LWR are summarized for the nuclear fuel cycle in Table S-3 (AEC 1974-
24 TN23). This normalization is called the “annual model LWR fuel requirement” throughout
25 WASH-1248 (AEC 1974-TN23).

26 Figure 3-4 displays the uranium fuel cycle for the majority of pathways. Table S-3 addresses
27 their environmental impacts related to the uranium fuel cycle, but this does not include mixed
28 oxide fuel, as shown in the figure. Additional details about the nuclear fuel cycle are provided in
29 Section 1.1, Uranium Fuel Cycle, of a Pacific Northwest National Laboratory (PNNL) report
30 prepared for the NRC (Napier 2020-TN6443). The assumption applied for Table S-3 regarding
31 plutonium recovered from recycling was that the recovered plutonium would be placed into
32 storage for future use (see Figure S-1 of WASH-1248 [AEC 1974-TN23]).

33 The 1996 version of the License Renewal GEIS (NRC 1996-TN288) found the once-through,
34 low-enriched uranium (LEU) fuel cycle to be a Category 1 issue with environmental findings of
35 SMALL. This result was codified into regulations and the findings are provided in 10 CFR
36 Part 51 (TN250), Appendix B, Table B-1, *Summary of Findings on NEPA Issues for License
37 Renewal of Nuclear Power Plants*. Section 4.12.1.1 of the License Renewal GEIS (NRC 2024-
38 TN10161) reassessed the environmental effects listed in Table S-3 and concluded that no new
39 information has been identified that would alter the conclusion in the 1996 version of the
40 License Renewal GEIS. The analyses provided in Section 4.12.1.1 to the License Renewal
41 GEIS are incorporated by reference into this analysis. There are potential fuel cycle options
42 regarding fast spectrum MSRs, as described by Holcomb et al. (e.g., LWR-derived TRU burner)
43 (Holcomb et al. 2011-TN6943), but they are not considered in this GEIS because of the
44 continuing development of the related technology bases.



1 * Reprocessing of spent nuclear fuel, including mixed-oxide (MOX) fuel, is not practiced in the United States.
 2 **Figure 3-4 Options of the Current Fuel Cycle which Includes the Table S-3 Uranium**
 3 **Fuel Cycle. Source: NRC 2019-TN6652.**

4 3.14.1.2 Other Fissile Fuel Cycles

5 Fuel cycles based on fissile or fertile materials other than uranium are possible, such as a
 6 thorium fuel cycle in which thorium is irradiated to create fissile uranium-233 (U-233). This fuel
 7 cycle thus would start with mining of thorium, rather than uranium, and would require irradiation
 8 of the thorium in a reactor using U-235–based fuel to generate the necessary U-233. Thorium is
 9 a commercially available material already mined and processed for use in a variety of
 10 commercial products, such as an alloying element in magnesium and in the manufacturing of
 11 lenses for cameras and scientific instruments (RSC 2020-TN6442). Because this fuel cycle
 12 requires neutron transmutation of thorium-232 (Th-232) to U-233 (typically considered to be
 13 from fission of U-235 but could also be from fission of plutonium-239 [Pu-239]), it can be
 14 considered to be partially part of the uranium cycle of Figure 3-4 and partially a separate cycle.
 15 The processes associated with thorium mining, milling, fuel fabrication, reactor use, storage,
 16 reprocessing, and waste disposal should be similar to, but distinct from, those for the uranium
 17 fuel cycle. Enrichment of thorium is unnecessary; however, irradiated thorium requires
 18 processing to obtain the U-233 necessary to this fuel cycle (WNA 2017-TN6668). Thus, a
 19 thorium fuel cycle should only significantly differ from uranium in that conversion of uranium to a
 20 gas (UF₆) and subsequent enrichment processes are omitted after initial thorium fuel cycle

1 startup; however, reprocessing would be an additional step currently not seen in the once-
2 through uranium fuel cycle. The NRC staff assumes that the thorium fuel cycle will not be
3 significantly different than the uranium fuel cycle, therefore the uranium fuel cycle impacts
4 should bound the thorium fuel cycle impacts.

5 *3.14.1.3 DOE High-Assay Low-Enriched Uranium Availability Program*

6 The High-Assay Low-Enriched Uranium (HALEU) Availability Program by DOE was developed
7 to secure a domestic supply of HALEU fuel following the Energy Act of 2020 (DOE 2024-
8 TN9790).

9 The HALEU Availability Program will acquire HALEU through purchase
10 agreements with domestic industry partners and produce limited initial
11 amounts of material from DOE-owned assets. The HALEU Availability
12 Program is intended to spur demand for additional HALEU production and
13 private investment in the nation's nuclear fuel supply infrastructure – ultimately
14 removing the federal government's initial role as a supplier. (DOE 2024-
15 TN9790)

16 As of the writing of this NR GEIS, DOE is actively seeking partners for enrichment services that
17 include mining, milling, conversion, and enrichment for the production of HALEU as uranium
18 hexafluoride. Additionally, DOE is to seeking partners for deconversion of HALEU stored as
19 uranium hexafluoride to other chemical forms (i.e., metal or oxide) for fuel fabrication purposes.
20 Finally, DOE is seeking partners to develop criticality benchmarks to assist in the transport
21 package licensing and certification process. The development of criticality benchmarks is
22 intended to support further DOE funding opportunities that would result in an NRC Certified
23 HALEU transportation package.

24 DOE has established a HALEU Consortium to further these efforts. The purposes of the
25 consortium are to:

- 26 • Identify demand estimates for domestic commercial use.
- 27 • Purchase HALEU made available to members for commercial use.
- 28 • Conduct HALEU demonstration projects.
- 29 • Identify HALEU supply chain improvements and reliability.

30 The environmental impacts of the DOE HALEU program have been assessed in draft form as
31 DOE/EIS-0559, *Draft Environmental Impact Statement for Department of Energy Activities in*
32 *Support of Commercial Production of High-Assay Low-Enriched Uranium (HALEU)* (DOE/EIA-
33 TN10133).

34 *3.14.1.4 Nuclear Fuel Cycle Regulatory Requirements for New Reactors*

35 As provided in 10 CFR 51.51(a) (TN250), the environmental data of Table S-3 only apply to CP,
36 operating license (OL), ESP, or COL applications for light-water-cooled nuclear power reactors.
37 However, as required in 10 CFR 51.50(b)(3) and 51.50(c) for other than light-water-cooled
38 nuclear power reactors (i.e., non-LWRs), an ER for an ESP or a COL shall contain the basis for
39 evaluating the contribution of the environmental effects of fuel cycle activities for the nuclear
40 power reactor. Any new reactor SNF container (i.e., a storage cask or a transportation container
41 or package) or an ISFSI and dry transfer system (DTS) facilities for the reactor's SNF must
42 satisfy the regulatory requirements of 10 CFR Part 71 (TN301), *Packaging and Transportation*

1 of Radioactive Material, 10 CFR Part 72 (TN4884), *Licensing Requirements for the Independent*
2 *Storage of Spent Fuel, High-Level Radioactive Waste, and Reactor-related Greater Than Class*
3 *C Waste*, and 10 CFR Part 73 (TN423), *Physical Protection of Plants and Materials*. Any fuel
4 cycle facility must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882), *Domestic*
5 *Licensing of Source Material*, and 10 CFR Part 70 (TN4883), *Domestic Licensing of Special*
6 *Nuclear Material*. Any fuel cycle reprocessing must meet the regulatory requirements of 10 CFR
7 Part 50 (TN249), *Domestic Licensing of Production and Utilization Facilities*.

8 3.14.1.5 Changes in the Nuclear Fuel Cycle since WASH-1248

9 Many of the nuclear fuel cycle facilities and processes assessed for Table S-3 still exist today.
10 However, some have undergone several industrial developments and technological advances
11 that have significantly reduced their environmental effects. As discussed in NUREG-2226, the
12 Clinch River ESP FEIS (NRC 2019-TN6136), recent changes in the uranium fuel cycle may
13 have some bearing on environmental impacts. As discussed below, the staff is confident that
14 the contemporary normalized uranium fuel cycle impacts for LWRs are less than those identified
15 in Table S-3. This assertion is true in light of the following recent uranium fuel cycle trends in the
16 United States:

- 17 • Increasing use of in situ leach uranium mining, which does not produce mine tailings and
18 would lower the release of radon gas. A discussion of this subject is provided in
19 Section 3.14.2.1.
- 20 • Transitioning of U.S. uranium enrichment technology from gaseous diffusion to gas
21 centrifugation. The latter process uses only a fraction of the electrical energy per separation
22 unit compared to gaseous diffusion and U.S. gaseous-diffusion plants that relied on
23 electricity derived mainly from the burning of coal. A discussion of this subject is provided in
24 Section 3.14.2.3.
- 25 • Current LWRs are using nuclear fuel more efficiently because of higher levels of fuel
26 burnup. Thus, less uranium fuel per year of reactor operation is required than in the past to
27 generate the same amount of electricity (an increase in the time for refueling (from
28 12 months to 18 months or greater) as applied for Table S-3).

29 The values in Table S-3 were calculated from industry averages for the performance of each
30 type of facility or operation within the fuel cycle. Recognizing that this approach meant that there
31 would be a range of reasonable values for each estimate, the staff chose the assumptions or
32 factors to be applied so that the calculated values would not be underestimated. This approach
33 was intended to make sure that the actual environmental impacts would be less than the
34 quantities shown in Table S-3 for all LWR nuclear power plants within the widest range of
35 operating conditions. The staff recognizes that many of the fuel cycle parameters and
36 interactions vary in small ways from the estimates in Table S-3 and concludes that these
37 variations would have no impacts on the Table S-3 calculations. For example, to determine the
38 quantity of fuel required for a year's operation of a nuclear power plant in Table S-3, the staff
39 defined the reference reactor as a 1,000 MW LWR operating at 80 percent capacity with a
40 12-month fuel-reloading cycle and an average fuel burnup of 33,000 megawatt-day(s) per metric
41 ton of uranium (MWd/MTU). The current LWR fleet is operating with an average factor
42 approximately 95 percent capacity for peak fuel rod burnup of up to 62,000 MWd/MTU with
43 refueling occurring at approximately 2-year intervals (NRC 2019-TN6136).

44 The Table S-3 analysis from the 1970s was also based on most of the electricity generated in
45 the United States being produced in plants that burn fossil fuels and coal composing the bulk of

1 fossil-fuel utilization (AEC 1974-TN23). However, today the energy sources for utility-scale
2 electrical generation are very diverse with (DOE/EIA-TN10133):

- 3 • only 19.5 percent from coal;
- 4 • 39.8 percent from natural gas, for which air emissions are much less than those from coal;
- 5 • 18.2 percent from nuclear power plants;
- 6 • 21.5 percent from renewables (15.3 percent from non-hydroelectric renewables and
7 6.2 percent from hydroelectric); and
- 8 • Less than 1 percent from petroleum and other sources.

9 Therefore, environmental impacts related to air emissions, associated pollutants, and
10 water/thermal impacts from today's electrical generation contribution to the nuclear fuel cycle
11 are clearly less and are bounded by the coal-electrical generation data assessed by
12 WASH-1248 (AEC 1974-TN23) and found in Table S-3. This trend of decreasing reliance on
13 fossil fuels for electrical generation will continue, spurred by actions to combat climate change
14 (DOE/EIA 2020-TN6653). Additional information concerning GHG emission from the fuel cycle
15 is discussed in Section 3.3.2.2.2.

16 Based on several of the items discussed above, the 2013 revision of the License Renewal GEIS
17 states:

18 It was concluded that even though certain fuel cycle operations and fuel
19 management practices have changed over the years, the assumptions and
20 methodology used in preparing Table S-3 were conservative enough that the
21 impacts described by the use of Table S-3 would still be bounding.

22 With Table S-3 still bounding for particular parts of the LWR nuclear fuel cycle, the following
23 sections provide a brief background on the components of the nuclear fuel cycle and discuss
24 their current situation with respect to Table S-3 regarding the advanced nuclear fuel cycle since
25 the publication of the 2013 revision to the License Renewal GEIS (NRC 2024-TN10161).

26 3.14.1.6 PPE Assumptions

27 As discussed above, a review of past LWR projects has revealed a number of trends, which the
28 staff assumes will continue for the fuel cycle for new reactors. Therefore, the following
29 assumptions are made regarding these trends for establishing the PPE for the various new
30 reactor fuel cycle components and are discussed in Section 3.14.2, Fuel Cycle Impacts:

- 31 • increasing use of in situ leach uranium mining,
- 32 • transitioning of U.S. uranium enrichment technology from gaseous diffusion to gas
33 centrifugation for enrichment levels of up to 20 percent,
- 34 • using fuel more efficiently in the current LWRs due to higher levels of fuel burnup,
- 35 • discharging of fewer spent fuel assemblies per reactor-year, and
- 36 • relying less on coal-fired electrical generation plants.

37 In addition, the following are not part of the above-listed current once-through uranium fuel cycle
38 trends, but could be applicable to new reactor fuel cycles:

- 1 • Sources of enriched lithium would be from U.S. stockpiles or from foreign sources (Napier
2 2020-TN6443; GAO 2013-TN6960).
- 3 • The reprocessing capacity would be up to 900 MTU/yr based on analysis in WASH-1248
4 (AEC 1974-TN23).
- 5 • Uranium fuel cycle impacts will bound the thorium fuel cycle impacts.

6 The PPE also assumes that the regulatory requirements of 10 CFR Part 40 (TN4882), *Domestic*
7 *Licensing of Source Material*; 10 CFR Part 50 (TN249), *Domestic Licensing of Production and*
8 *Utilization Facilities*; 10 CFR Part 70 (TN4883), *Domestic Licensing of Special Nuclear Material*;
9 10 CFR Part 71 (TN301), *Packaging and Transportation of Radioactive Material*; 10 CFR
10 Part 72 (TN4884), *Licensing Requirements for the Independent Storage of Spent Fuel,*
11 *High-Level Radioactive Waste, and Reactor-related Greater Than Class C Waste*; and 10 CFR
12 Part 73 (TN423), *Physical Protection of Plants and Materials*, are also met.

13 **3.14.2 Fuel Cycle Impacts**

14 The NRC must still evaluate nuclear fuel cycle impacts of the non-LWR fuels to meet its
15 obligations under NEPA, as has been done for UO₂ fuels for LWRs. The NRC has generically
16 evaluated the environmental effects of the nuclear fuel cycle²⁷ for LWRs that use uranium fuel.
17 The results of the evaluation are presented in 10 CFR 51.51 (TN250), Table S-3, Table of
18 Uranium Fuel Cycle Environmental Data. However, the environmental data of Table S-3 can
19 only be applied to LWRs that use UO₂ fuel. New reactor developers are expected to
20 predominantly still use enriched uranium fuel with close to 20 percent by weight enrichment,
21 also known as high-assay low-enriched uranium or HALEU. Several of the potential non-LWR
22 designs are expected to deploy non-UO₂ fuels (e.g., uranium metal, uranium carbide, uranium in
23 a molten salt, etc.) or rely on recycled fissile material. Some new reactor developers intend to
24 build on a thorium/U-233 fuel cycle. To the extent practicable, this section assesses the nuclear
25 fuel cycle for new reactors for the expected environmental effects compared to the
26 environmental data provided in Table S-3 where possible.

27 The NRC staff identified six environmental issues for analysis of fuel cycle impacts associated
28 with a new reactor:

- 29 • uranium recovery,
- 30 • uranium conversion,
- 31 • enrichment,
- 32 • fuel fabrication,
- 33 • reprocessing, and
- 34 • storage and disposal of radiological wastes.

35 **3.14.2.1 Uranium Recovery**

36 As indicated on the NRC's public website, uranium recovery focuses on extracting (or mining)
37 natural uranium ore from the Earth and concentrating (or milling) that ore (NRC 2020-TN6444).
38 These recovery operations produce a product, called "yellowcake," which is then transported to
39 a fuel cycle facility. There, the yellowcake is transformed into fuel for nuclear power reactors. In

²⁷ In the United States, all currently operating commercial plants are LWRs that use uranium for fuel. Therefore, in this section the term "uranium fuel cycle" is used to describe the current use of nuclear fuel where the principal fissile material is U-235. The term "nuclear fuel cycle" includes the use of other fissile nuclides, such as U-233 applied in a thorium-based fuel cycle.

1 addition to yellowcake, uranium recovery operations generate waste products, called byproduct
2 materials, that contain low levels of radioactivity.

3 For mining activities, the regulatory responsibility depends on the extraction method that the
4 given facility uses. Specifically, conventional mining (where uranium ore is removed from deep
5 underground shafts or shallow open pits) is regulated by the Office of Surface Mining, the U.S.
6 Department of the Interior, and the individual States in which the mines are located. By contrast,
7 the NRC regulates in situ recovery (formerly known as in situ leach recovery), where the
8 uranium ore is chemically altered underground before being pumped to the surface for further
9 processing. Currently, the NRC regulates active uranium recovery operations in New Mexico
10 and Nebraska, but does not directly regulate the active uranium recovery operations in
11 Wyoming, Texas, Colorado, and Utah, because they are Agreement States, meaning that they
12 have entered into strict agreements with the NRC to exercise regulatory authority over this type
13 of material (NRC 2023-TN10135).

14 The NRC has provided information about the past and current practices for uranium recovery on
15 the NRC's public website (NRC 2020-TN6827). The table provided on the public website
16 compares the features of the three main types of uranium recovery facilities, namely
17 conventional uranium mills, heap leach/ion-exchange facilities, and in situ recovery facilities.

18 In general, the primary industrial hazards associated with uranium milling are the occupational
19 hazards found in any metal milling operation that uses chemical extraction, as well as the
20 chemical toxicity of the uranium itself (NRC 2020-TN6444). Because the uranium produced at
21 these facilities is not enriched, there is no criticality hazard and little fire or explosive hazard.
22 Radiological hazards are also low at these facilities, because uranium has little penetrating
23 radiation and only moderate non-penetrating radiation. The primary radiological hazard is
24 attributable to the presence of radium in the waste byproduct material (known as "mill tailings").

25 To facilitate the agency's review of in situ recovery applications, in May 2009 the NRC staff
26 published the *Generic Environmental Impact Statement for In-Situ Leach Uranium Milling*
27 *Facilities* (NUREG-1910; NRC 2009-TN2559), which addresses common environmental issues
28 associated with the construction, operation, and decommissioning of facilities, as well as the
29 groundwater restoration at such in situ recovery facilities, if they are located in particular regions
30 of the western United States (NRC 2020-TN6828). In addressing environmental issues common
31 to the in situ recovery process, the NRC staff applied the generic environmental impact
32 statement for In Situ Leach Uranium Milling Facilities (In Situ Recovery GEIS) as the starting
33 point for its project-specific environmental review of license applications for new in situ recovery
34 facilities. Completed project-specific environmental reviews of new in situ recovery facilities can
35 be found at <https://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1910/> (NRC 2020-
36 TN6829). The analysis of the In Situ Recovery GEIS is incorporated by reference.

37 The Prohibiting Russian Uranium Imports Act, H.R. 1042, bans the import of Russian uranium
38 (DOE 2024-TN10150). H.R. 1042 passed in the U.S. House of Representatives in December
39 2023 and the U.S. Senate in April of 2024 and was signed by the U.S. President in May 2024
40 (NuclearNews 2024-TN10151). The law will allow short-term waivers for Russian imports
41 through 2027 subject to limitations (NuclearNews 2024-TN10151), which should reduce but may
42 not fully eliminate the importation of uranium from Russia. Once fully in effect, it is reasonable to
43 expect uranium recovery operations to increase in the United States.

44 The analyses for Table S-3 regarding uranium recovery were predicated on active uranium
45 mining, heap leaching, and large industrial milling facilities (see Appendix C of the In Situ

1 Recovery GEIS [NRC 2020-TN6828]). There were no active heap leaching sites and two active
2 underground uranium mining sites in the United States in 2019 (DOE/EIA 2024-TN10141). As
3 indicated in the In Situ Recovery GEIS, in situ recovery has removed many of the causes of
4 harmful uranium recovery impacts because this process does not directly remove the uranium
5 ore from a site, transport the uranium ore to a large milling facility, and process large volumes of
6 uranium ore that produce tailing piles and leachate ponds and the associated release of radon
7 gas. Thus, the in situ recovery process avoids many of the environmental impacts of these past
8 uranium recovery processing steps. Therefore, the environmental impacts for in situ recovery
9 are expected to be less than those listed in Table S-3 for uranium recovery facilities and the
10 impacts would be SMALL. This is a Category 1 issue. The staff relied on the following PPE
11 assumptions to reach this conclusion:

- 12 • Table S-3 is expected to bound the impacts for new reactor fuels, because of uranium fuel
13 cycle changes since WASH-1248 (AEC 1974-TN23), including:
 - 14 – Increasing use of in situ leach uranium mining has lower environmental impacts than
15 traditional mining and milling methods.
 - 16 – Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup
17 resulting in less demand for mining and milling activities.
 - 18 – Less reliance on coal-fired electrical generation plants resulting in less gaseous effluent
19 releases from electrical generation sources supporting mining and milling activities.
- 20 • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) Domestic Licensing of
21 Source Material and 10 CFR Part 71 (TN301), Packaging and Transportation of Radioactive
22 Material

23 3.14.2.2 *Uranium Conversion*

24 The processing involved in converting triuranium octaoxide, (also called “yellowcake”) into UF₆
25 for ease of use in uranium enrichment facilities remains the same as that analyzed for
26 Table S-3. The only UF₆ conversion facility in the United States—the Metropolis Works uranium
27 conversion facility operated by Honeywell International Inc.—is in Metropolis, Illinois (NRC
28 2020-TN6837), and is currently in “Operational/idle-ready” status (NRC 2023-TN10140).
29 Honeywell believes they will be ready to support HALEU demand in the future (ConverDyn
30 2020-TN6657).

31 Accident tolerant fuel (ATF) deployment and use with increased enrichment levels would result
32 in greater amount of yellowcake being processed during uranium conversion to UF₆ to support
33 increased enrichments. By applying the UxC Fuel Cost Calculator (UxC 2023-TN8086),
34 increasing enrichment to 8 wt% U-235 would need approximately 2.1 times more yellowcake
35 feedstock than the 4 wt% U-235 that underscores Table S-3 environmental data. Increasing
36 enrichment to 10 wt% U-235 would require approximately 2.6 times more yellowcake for UF₆
37 conversion than for 4 wt% U-235. Furthermore, increasing enrichment to 20 wt% U-235 would
38 require approximately 5.2 times more yellowcake for UF₆ conversion than for 4 wt% U-235 (UxC
39 2023-TN8086).

40 The NRC staff assumes that environmental and process control improvements along with new
41 or amended Federal or State environmental regulations since the publication of WASH-1248 in
42 1974 would reduce operating uranium conversion facility environmental impacts, maintaining
43 them within those listed in Table S-3. For example, the RCRA (42 U.S.C. §§ 6901 et seq.;
44 TN1281) was passed into law in 1976 (EPA 2020-TN6963). Additionally, Honeywell has

1 completed treatment upgrades to the environmental protection facility to provide enhancements
2 to meet new fluoride discharge limits (NRC 2019-TN6964). Therefore, NRC staff assumes
3 Table S-3 will still bound the environmental impacts of a uranium conversion facility operating
4 today and would be SMALL. This is a Category 1 issue. The staff relied on the following PPE
5 assumptions to reach this conclusion:

- 6 • Table S-3 is expected to bound the impacts for new reactor fuels, because of uranium fuel
7 cycle changes since WASH-1248 (AEC 1974-TN23), including:
 - 8 – Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup
9 resulting in less demand for conversion activities.
 - 10 – Less reliance on coal-fired electrical generation plants resulting in fewer gaseous
11 effluent releases from electrical generation sources supporting conversion activities.
- 12 • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) *Domestic Licensing of*
13 *Source Material* and 10 CFR Part 71 (TN301), *Packaging and Transportation of Radioactive*
14 *Material*, and 10 CFR Part 73 (TN423), *Physical Protection of Plants and Materials*.

15 3.14.2.3 Enrichment

16 The uranium enrichment process has undergone significant changes since the analysis of
17 Table S-3 provided in WASH-1248 (AEC 1974-TN23) and NUREG-0116 (NRC 1976-TN292).
18 That analysis was based on gaseous-diffusion enrichment, which had large energy
19 requirements and the electricity needed to run the process was produced by coal-electrical
20 generation plants that featured large air emissions and other environmental conditions, as noted
21 in Table S-3.

22 Gaseous-diffusion enrichment was the first commercial process used in the United States to
23 enrich uranium. The enrichment facilities used massive amounts of electricity and as the
24 centrifuge enrichment technology matured the existing gaseous-diffusion plants became
25 obsolete (NRC 2020-TN6836). Worldwide they have all been replaced by second-generation
26 technology, i.e., centrifuge enrichment technology, which requires far less electric power to
27 produce equivalent amounts of separated uranium. One such nuclear power plant with
28 centrifuge enrichment technology is the Centrus Energy Corp nuclear power plant located on a
29 DOE reservation in Piketon, Ohio (NRC 2023-TN10142); Centrus Energy Corp has successfully
30 demonstrated its HALEU production process and is expanding HALEU production to the rate of
31 900 kg per year (CEC 2023-TN10144). Another gas centrifuge enrichment facility is the
32 Louisiana Energy Services (LES) facility in Eunice, New Mexico (NRC 2024-TN10145) which
33 has been enriching up to 5 wt% Uranium-235 since 2010 (Urenco 2024-TN10146) and has
34 submitted a license amendment request to enrich up to 10 wt% (Urenco 2024-TN10147).
35 Historically, there were two gaseous-diffusion plants under NRC purview in the United States
36 which have been shutdown, namely the facilities at Paducah, Kentucky, and Portsmouth, Ohio
37 (NRC 2020-TN10162). DOE now holds the certificates for these plants and is in charge of the
38 safe decommissioning (SAFSTOR) of the nuclear power plants (DOE Undated-TN10148, DOE
39 Undated-TN10149).

40 There is a significant difference in energy use between gaseous-diffusion and centrifuge
41 enrichment technologies. Separative work unit, or SWU, is the standard measure of the effort
42 required to separate isotopes of uranium (U-235 and uranium-238 [U-238]) during an
43 enrichment process and is independent of the enrichment process (either gaseous or
44 centrifuge). Using a SWU calculator (UxC 2023-TN8086) to obtain 1,000 kg of 4 percent by
45 weight enriched uranium, assuming 0.25 wt% of U-235 in the tails, from a related amount of

1 natural uranium requires 5,832 SWUs, and to obtain 1,000 kg of 20 percent by weight enriched
2 uranium (HALEU) requires 41,576 SWUs. The gaseous-diffusion process consumes about
3 2,500 kilowatt-hour (kWh) per SWU, while modern gas centrifuge plants require only about
4 50 kWh per SWU (WNA 2020-TN6661). Thus, a centrifuge enrichment facility would consume
5 approximately 2,100,000 kWh to reach 20 wt% uranium enrichment, while a gaseous-diffusion
6 plant would need approximately 14,600,000 kWh to reach the 4 wt% uranium enrichment
7 analyzed in WASH-1248 (AEC 1974-TN23) and assessed in Table S-3. Therefore, for the
8 enrichment of uranium, Table S-3 would bound the environmental impacts from a centrifuge
9 enrichment facility to produce HALEU and the impact would be SMALL. This is a Category 1
10 issue. The staff relied on the following PPE assumptions to reach this conclusion:

- 11 • Table S-3 is expected to bound the impacts for new reactor fuels, because of uranium fuel
12 cycle changes since WASH-1248 (AEC 1974-TN23), including:
 - 13 – Transitioning of U.S. uranium enrichment technology from gaseous diffusion to gas
14 centrifugation which requires less electrical usage per SWU.
 - 15 – Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup
16 resulting in less demand for enrichment activities.
 - 17 – Less reliance on coal-fired electrical generation plants resulting in fewer gaseous
18 effluent releases from electrical generation sources supporting enrichment activities.
- 19 • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) *Domestic Licensing of*
20 *Source Material*, 10 CFR Part 70 (TN4883), *Domestic Licensing of Special Nuclear Material*,
21 10 CFR Part 71 (TN301), *Packaging and Transportation of Radioactive Material*, and
22 10 CFR Part 73 (TN423), *Physical Protection of Plants and Materials*.

23 3.14.2.4 Fuel Fabrication

24 Fuel fabrication facilities will need to be licensed, constructed, and operated to produce the
25 necessary new reactor fuel types. The NRC currently regulates several different types of
26 nuclear fuel fabrication operations. For commercial nuclear power plant fuel, three fuel
27 fabrication plants processing LEU (up to 5 percent by weight enrichment of U-235) are currently
28 licensed by the NRC (2020-TN6835):

- 29 • Global Nuclear Fuel-Americas in Wilmington, North Carolina;
- 30 • Westinghouse Columbia Fuel Fabrication Facility in Columbia, South Carolina; and
- 31 • Framatome, Inc. (Framatome), in Richland, Washington.

32 Two other fuel fabrication plants licensed by the NRC produce nuclear fuel for the U.S. Navy
33 and can downblend highly enriched uranium (HEU) with other uranium to create LEU reactor
34 fuel for commercial nuclear power plants. These are the Nuclear Fuel Services plant in Erwin,
35 Tennessee, and the BWX Technologies, Inc. (BWXT) Nuclear Operations Group plant in
36 Lynchburg, Virginia. All five of the abovementioned fuel fabrication facilities were in operation at
37 the time of the WASH-1248 study, as were five other fuel fabrication facilities (AEC 1974-TN23).

38 In Appendix E of WASH-1248 (AEC 1974-TN23), a model fuel fabrication plant that had a
39 capacity of 3 MTU per day and operated 300 days per year was used to assess environmental
40 impacts. The model plant lifetime was taken to be 20 years. WASH-1248 also assumed that the
41 electricity used in fuel fabrication facilities came from coal power plants; some natural gas was
42 used for process heat and other external resources involved land use and water. At the time of
43 WASH-1248, fuel fabrication facilities applied a wet process method for UF₆ to UO₂ conversion,

1 which involves the use of ammonium hydroxide to form an intermediate ammonium diuranate
 2 (ADU) compound prior to final conversion to UO₂.

3 While WASH-1248 notes that a dry conversion process (DCP) was under development at that
 4 time, several of the above mentioned fuel fabrication facilities now apply a dry process
 5 (AEC 1974-TN23). The ADU process was recognized as creating greater waste management
 6 problems than the dry process. The Global Nuclear Fuel-Americas facility converted to DCP in
 7 1997 (NRC 2009-TN6663) and the Framatome facility converted in 1998 (NRC 2009-TN6664).
 8 The BWXT facility currently only packages customer-provided uranium fuel material into fuel
 9 assemblies (NRC 2003-TN6665). The Nuclear Fuel Services facility could provide a variety of
 10 nuclear fuel services such as converting HEU into LEU or HALEU for use in commercial nuclear
 11 power plants (NRC 2011-TN6666). Only the Westinghouse Columbia Fuel Fabrication Facility
 12 currently applies the ADU process for final conversion to commercial nuclear fuel (NRC 2019-
 13 TN6472). Available capacity information for the three commercial nuclear fuel fabricators is
 14 provided in Table 3-8. Note that the rod and assembly capacity number may not be similar to
 15 the conversion and pelletizing capacity because UO₂ pellets could be provided from an outside
 16 source and the fuel fabricator is only inserting these outside source fuel pellets into cladding
 17 pins and then combining them into fuel assemblies.

18 **Table 3-8 Light-Water Reactor Fuel Fabrication Capacity**

| Fabricator | Location | Conversion | | Pelletizing | | Rod/Assembly | |
|--------------------------------|----------------------------|-----------------------|----------------------|-----------------------|----------------------|-----------------------|----------------------|
| | | MTU/yr ^(a) | MTU/d ^(b) | MTU/yr ^(a) | MTU/d ^(b) | MTU/yr ^(a) | MTU/d ^(b) |
| Framatome, Inc. | Richland, Washington | 1,200 | 3.4 | 1,200 | 3.4 | 1,200 | 3.4 |
| Global Nuclear Fuel – Americas | Wilmington, North Carolina | 1,200 | 3.4 | 1,000 | 2.9 | 1,000 | 2.9 |
| Westinghouse | Columbia, South Carolina | 1,600 | 4.6 | 1,594 | 4.6 | 2,154 | 6.2 |

(a) WNA 2021-TN10153.

(b) The metric tons of uranium per day (MTU/d) value is based on a current fuel fabrication facility operating schedule of 350 days per year as opposed to the 300 days assumed in WASH-1248 (AEC 1974-TN23).

19 WASH-1248 states that most of the airborne chemical effluents result from the combustion of
 20 fossil fuels to produce electricity to operate the fabrication plant (AEC 1974-TN23). As
 21 previously described, a large percentage of electricity production today is from generation
 22 sources other than coal. Thus, existing and any new fuel fabrication facilities would have lower
 23 air emissions than those assessed in WASH-1248. The level of environmental impacts for
 24 other aspects of fuel fabrication, as presented in Appendix E of WASH-1248, are provided
 25 in Table 3-9.

26 The establishment of commercial fuel fabrication process lines for new reactor designs has yet
 27 to occur (at the time of publishing this GEIS). It is expected that the majority of new reactor fuel
 28 will use HALEU, but it might not be in the form of UO₂ sintered pellets. New reactor fuel forms
 29 could be TRi-structural ISOtropic (TRISO) fuel, uranium metal, uranium compound in a molten
 30 salt, or in another yet unidentified form. In addition, there is the potential for a new reactor, likely
 31 a MSR design, to be designed with a thorium-based fuel cycle using fissile U-233 (WNA 2017-
 32 TN6668).

1 **Table 3-9 WASH-1248 Fuel Fabrication Environmental Impacts (AEC 1974-TN23)**

| Environmental Impact | Value | WASH-1248 Comments |
|--|--|--|
| Site Size (acres) | A few acres up to a few thousand acres | Less than 5 percent of that committed by the rest of the fuel cycle |
| Building Size (ft ²) | 100,000 | - |
| Annual Water Consumption (gal) | 5,200,000 | About 0.05 percent of that used by the model LWR evaluated by WASH-1248 |
| Power Required (MW and megawatt-hour [MWh]) | 6 MWe and 1,700 MWe-hr | About 0.5 percent of the electricity of the enrichment plant evaluated by WASH-1248 |
| Annual Natural Gas Usage for Process Heat (ft ³) | 3,600,000 | About 4 percent of that consumed by the total nuclear fuel cycle |
| Liquid Waste Stream Volume (gpd) | 25,000 | Combined with about 425,000 gpd of process cooling water in the holding ponds prior to release offsite |
| Annual Solid Waste Volume (MT) | 680 | Calcium fluoride precipitate from the liquid waste stream for retaining on site (11 yd ³) |
| Annual Gaseous Airborne Activity Released (Ci) | 0.005 | Less than 0.1 percent of the applicable 10 CFR Part 20 (TN283) limit |
| Annual Liquid Activity Released (mCi) | 40 | Less than 10 percent of 10 CFR Part 20 (TN283) limits for release to an unrestricted area |
| Annual Solid Activity for Disposal (mCi) | 25 | Activity shipped per annual fuel requirement |

2 **3.14.2.4.1 TRISO Fuel Fabrication**

3 As described in the previously mentioned PNNL report (Napier 2020-TN6443), TRISO fuel is
 4 composed of fuel particles or seeds less than 1 mm in diameter. Each has a kernel (ca. 0.5 mm)
 5 of uranium oxycarbide (or UO₂), and the uranium is likely to be enriched up to 20 wt% of U-235.
 6 This kernel is surrounded by layers of carbon and silicon carbide, giving a containment for
 7 fission products that is expected to be stable up to very high temperatures (up to 1,600 °C
 8 (Napier 2020-TN6443). There are two ways in which these particles can be arranged: either in
 9 blocks—hexagonal “prisms” of graphite; or in billiard ball-sized pebbles of graphite encased in
 10 silicon carbide, each with about 15,000 fuel particles and 9 g of uranium. Either way, the
 11 moderator is graphite. A description of a TRISO fuel fabrication process is also provided in
 12 PNNL-29367 and includes the related environmental emissions (Napier 2020-TN6443).

13 In the United States, BWXT is making HALEU TRISO fuel on an engineering scale, funded by
 14 DOE, and in October 2019 the company announced a planned expansion to commercial scale
 15 within 3 years (WNA 2021-TN10153). As presented in a DOE categorical exclusion document
 16 supporting this work (DOE 2020-TN6735), HEU material would be shipped from the Y-12
 17 National Security Complex in Oak Ridge, Tennessee, to the BWXT facility in Erwin, Tennessee,
 18 for conversion from HEU metal to HEU oxide. BWXT would then ship the HEU oxide to the
 19 BWXT fuel fabrication plant in Lynchburg, Virginia, for downblending and TRISO fabrication.
 20 BWXT was tasked with producing 100 kg of TRISO HALEU fuel. In November 2020, BWXT
 21 announced it had completed its TRISO nuclear fuel line restart project and is actively producing
 22 fuel at its Lynchburg facility (BWXT 2020-TN6756). Test samples of the BWXT TRISO fuel have
 23 been irradiated and examined at the Idaho National Laboratory (INL) Advanced Test Reactor
 24 (Nagley 2020-TN6739). In 2022 the Department of Defense Strategic Capabilities Office
 25 selected BWXT for creation of the Project Pele microreactor. The reactor core will use TRISO

1 produced by BWXT (BWXT 2022-TN10154). The production of this TRISO fuel is being
2 conducted under existing NRC special nuclear material (SNM) licenses and associated
3 environmental assessments (EAs). For the BWXT Lynchburg facility, the license renewal EA,
4 issued in 2006 for a 20-year period under Materials License SNM-42, concluded the BWXT
5 operations would not result in a significant impact on the environment where airborne and liquid
6 effluent releases along with public and occupational doses are below regulatory limits (71 FR
7 16348-TN6785). Therefore, this EA covers the environmental impact of producing 100 kg of
8 TRISO HALEU fuel under DOE funding.

9 A potential new fuel fabricator for TRISO is X-Energy LLC (X-Energy 2020-TN6736). X-Energy
10 has also been producing TRISO fuel on an engineering scale and announced irradiation testing
11 in May 2020 to be performed at the Massachusetts Institute of Technology Nuclear Reactor
12 Laboratory's 6 MW Massachusetts Institute of Technology reactor (WNN 2020-TN6740).
13 X-Energy has developed a pilot TRISO fuel fabrication process and presented an overview of
14 this process to the NRC and during a national HALEU webinar (Pappano 2018-TN6738,
15 Pappano 2020-TN6737).

16 In 2023, Ultra Safe Nuclear Corporation (USNC) and Framatome established a joint venture to
17 produce TRISO (USNC 2023-TN10158). USNC has constructed a pilot fuel fabrication facility
18 for production of TRISO fuel. USNC has produced TRISO for the National Aeronautics and
19 Space Administration, though for use as a nuclear propulsion technology for spacecraft (USNC
20 2023-TN10159). The production of this TRISO fuel is being conducted under existing NRC SNM
21 licenses and associated EAs. Operation of the facility is covered by the Framatome license
22 SNM-1227 and its associated EAs.

23 A direct comparison of existing ADU and DCP fabrication and industry-level TRISO fuel
24 fabrication processes cannot be made at this time. The BWXT TRISO work is being conducted
25 under an existing NRC SNM license but production quantity is limited. Based on the available
26 public information, once the UF₆ feedstock is converted to a solid form, the X-Energy TRISO-X
27 process and NRC's experience with BWXT TRISO fuel fabrication licensing both have similar
28 steps that feature environmental impacts comparable to or less than those of the ADU (the fuel
29 fabrication process associated with Table S-3) and the current DCP fuel fabrication processes
30 (Pappano 2020-TN6737).

31 *3.14.2.4.2 Metallic Uranium Fuel Fabrication*

32 It is anticipated that several new reactor designs, such as microreactors and liquid sodium-
33 cooled reactors, could use a form of metal uranium alloy fuel. Such a fuel type has been
34 employed in a variety of research and test reactors. Supplies of metallic HALEU could become
35 available to commercial developers, at least initially, from DOE's surplus HEU stockpiles. One
36 initial source of metallic uranium is recycled material from the Experimental Breeder Reactor-II
37 (EBR-II) at INL, but it could also be provided by DOE if surplus HEU from the U.S. government's
38 nuclear weapons program is made available for commercial nuclear fuels. The uranium material
39 from EBR-II, up to 10 MT, will be melted into ingots and could be cast into reactor components
40 (DOE 2019-TN6757). INL has developed the Hybrid Zirconium Extraction process, which is
41 used to remove cladding from the fuel, thereby allowing downblending of metallic HEU into
42 HALEU casting (INL 2019-TN6758). The first castings for a new reactor were made in late 2019
43 (Morning Consult 2019-TN6759). INL is also prepared to recover up to 10 MT of former EBR-II
44 fuel for transition into appropriate fuel forms for new reactor fuel developers (DOE 2023-
45 TN10160). INL awarded 5 MT of the former EBR II fuel to Oklo Inc. for recycling and
46 repurposing for Oklo's design (DOE 2023-TN10160).

1 For the case where the initial supply of metallic uranium fuel for a new reactor is supplied from
2 DOE's surplus HEU stock, all of the environmental impacts prior to fuel fabrication already
3 occurred during U.S. government processes years ago. HALEU fuel could use processed spent
4 EBR-II fuel (DOE/EA-2087; DOE 2019-TN6757). Thus, any environmental impacts from the
5 processing of metallic fuel from DOE sources for new reactors related to past mining, milling,
6 enrichment, and conversion have been accounted for in the WASH-1248 analysis (AEC 1974-
7 TN23) and are provided in Table S-3. If the HALEU feedstock is taken from unprocessed
8 irradiated fuel (i.e., EBR-II or spent Navy fuel), then there will be an environmental impact
9 associated with reprocessing the irradiated fuel, likely similar to the impacts associated with
10 previously processed irradiated EBR-II fuel, as described in DOE/EA-2087 (DOE 2019-
11 TN6757). Thus, future commercial production of metallic HALEU fuel would have environmental
12 impacts similar to those previously discussed for all steps prior to fuel fabrication.

13 An overall fuel fabrication process is presented in Section 1.1 of the PNNL report entitled *Metal*
14 *Fuel Fabrication Safety and Hazards* (LaHaye and Burkes 2019-TN6961). The metal fuel
15 fabrication steps, as provided by LaHaye and Burkes (2019-TN6961), are as follows:

- 16 1. Feedstock must be prepared from ore. This includes dissolution, purification, and chemical
17 conversion to the desired chemical state for the next step. Feedstock can also be prepared
18 from used fuel through reprocessing. Enrichment will typically take place between
19 purification and conversion to the final chemical state for reduction but is outside the scope
20 of this effort. (These steps are addressed previously in this section of this GEIS.)
- 21 2. Feedstock must then be reduced to metal. This is traditionally achieved by
22 bomb/metallurgical reduction, but other means can also be employed to convert feedstock
23 to metal.
- 24 3. The metal is alloyed with the desired alloying agent(s) to create a binary, ternary, or other
25 alloy.
- 26 4. The alloy is cast to form a fuel billet.
- 27 5. The fuel billet is machined and/or thermomechanically processed to get it into a desired
28 form.
- 29 6. The formed fuel billet is clad and collected into fuel assemblies.

30 Each of the above metal fuel fabrication process steps is described in detail in subsequent
31 sections by LaHaye and Burkes (2019-TN6961) and is incorporated by reference.

32 For assessing the environmental impacts of metal fuel fabrication, the level of impacts is likely to
33 vary with the source of metal fuel feedstock. If the fuel material is being supplied directly from
34 the enrichment facility or was from downblended HEU, the only radiological hazard would be
35 from the uranium itself. Such a feedstock source should also not need any further purification.
36 For recycled or reprocessed used fuel, the purification to remove fission products and TRU
37 elements could be an initial step in the metal fuel fabrication facility. The effectiveness of this
38 purification process in removing the highly radioactive non-fuel nuclides could affect the kind of
39 processing protections (e.g., remote operations in a highly shielded hot cell versus a glovebox)
40 necessary in the subsequent fabrication steps.

41 Outside of the expected radiological impacts, the effluent releases and wastes streams from the
42 above process steps are not expected to be significantly different than those of most metal
43 fabrication facilities. As described by the European Bank for Reconstruction and Development
44 (EBRD Undated-TN6941) and by LaHaye and Burkes (2019-TN6961), there are likely to be a

1 number of waste streams from metal fabrication. Air emissions from volatile chemicals, fumes,
2 and dust/particulates would be generated from various process steps involving melting,
3 degreasing, cleaning, welding, and grinding operations. Solid waste in the form of chips and
4 scrap metal could be generated from machining, milling, and thermomechanical treatments.
5 Wastewater could also be generated containing various chemical wastes due to the mentioned
6 degreasing, cleaning, treatments, and grinding operations.

7 The NRC staff assumes a metal fuel fabrication facility would have the appropriate process
8 controls (e.g., glove boxes and hot cells as appropriate), ventilation filters (e.g., high-efficiency
9 particulate air [HEPA] and charcoal filter beds), and monitoring to minimize the amount of waste
10 generated and associated environmental impacts. Environmental impacts could be bounded by
11 current fuel fabrication processes. However, there could be noticeable waste streams from
12 casting and from stabilizing uranium scraps (LaHaye and Burkes 2019-TN6961). Therefore, due
13 to the lack of environmental impact information for new reactor metal fuel fabrication, the NRC
14 staff cannot readily assess an environmental impact for such fuel fabrication in relationship to
15 WASH-1248 and Table S-3.

16 3.14.2.4.3 Nuclear Fuel in Molten-Salt Reactors

17 A new reactor classified as a MSR is one where a molten salt is used as the working fluid for
18 heat, transferring the energy from the nuclear core to an industrial process, such as electrical
19 generation or industrial heat processes. The nuclear fuel could be in a form described above in
20 the MSR's own fuel channel. There are also proposed MSR designs in which the nuclear fuel
21 will be mixed in the molten salt and the reactor will be specifically designed so that the reactor
22 vessel's configuration is such that the nuclear core physics support criticality (i.e., a liquid-fuel
23 MSR). As indicated by the World Nuclear Association (WNA), "in the normal or basic MSR
24 concept, the fuel is a molten mixture of lithium and beryllium fluoride salts with dissolved LEU
25 (U-235 or U-233) fluorides (UF₄)" (WNA 2021-TN7072). As further indicated by the WNA,
26 "chloride salts have some attractive features compared with fluorides, in particular the actinide
27 trichlorides form lower melting point solutions and have higher solubility for actinides so can
28 contain significant amounts of transuranic elements" (WNA 2021-TN7072). The type of nuclear
29 fuel could be based on any of the fissile isotopes in the form of HALEU U-235, a mixture of
30 uranium and plutonium (TRU mixture with U-235, Pu-239, and U-238 in a fast neutron
31 spectrum), or thorium-based U-233. A number of MSR developers are examining a variety of
32 molten-salt types (Flanagan 2017-TN6742). Discussions of nuclear fuel salts likely to be
33 employed in MSRs (chloride- and fluoride-based salts) and the general characteristics of
34 reactors that would use those types of salts are provided in Chapter 2 of McFarlane et al. (2019-
35 TN6741).

36 Two prior productions of liquid-fuel MSRs could be used as an indication of the fuel preparation
37 impacts for this type of nuclear fuel (McFarlane et al. 2019-TN6741): the Aircraft Reactor
38 Experiment (ARE) in 1954, and the Molten-Salt Reactor Experiment (MSRE). McFarlane et al.
39 (2019-TN6741) provide a description of the processing of the ARE fuel in Section 2.2.1 of their
40 report, Fuel Loading at ARE:

41 At the ARE, Na₂UF₆ was added to an initially barren mixture of sodium and
42 zirconium fluorides. The procedure to add the ARE fuel involved the successive
43 connection of numerous small concentrate containers to an intermediate transfer
44 pot. The pot was then connected to the fuel system, which injected the
45 concentrate into the pump tank above the liquid level. Since the ARE was not
46 optimized for breeding, its fuel salt contained a higher concentration of uranium.

1 The ARE final fuel mixture consisted of 53.09 mole percent NaF, 40.73 mole
2 percent ZrF₄, and 6.18 mole percent UF₄, with ²³⁵U enriched to 93.4 weight
3 percent. The ARE fuel salt ²³⁵U concentration was increased 8.8 percent over the
4 course of operations (from 0.383 g/cc to 0.416 g/cc) as operational power was
5 increased.

6 McFarlane et al. (2019-TN6741) provide the following description of the MSRE fuel in
7 Section 2.2.2 of their report, Fuel Loading at MSRE:

8 The MSRE reactor fuel mixture nominally consisted of 65 ⁷LiF, 29.1 BeF₂,
9 5 ZrF₄, and 0.9 UF₄ (mole percent). At MSRE, ⁷LiF-UF₄ (73-27 mole %) was
10 separately synthesized and incrementally dissolved into barren carrier salt to
11 start and maintain nuclear operation. Both the MSRE coolant and the flush salt
12 were a binary mixture of 66 mole percent LiF in BeF₂. Initial operation
13 employed 33 weight percent enriched uranium. The operational fuel salt
14 volume was roughly 2,067 liters. All of the lithium used was assayed to be at
15 least 99.99 percent ⁷Li. In 1968, the uranium was removed from the fuel salt
16 and replaced with nearly pure ²³³U. The last few refueling capsules in
17 1969 contained PuF₃ (94 weight percent ²³⁹Pu).

18 McFarlane et al. (2019-TN6741) discuss the processes for synthesizing the carrier salt and
19 related chemical hazards in Chapter 3 of their report. In addition, it is expected there would be
20 onsite processing to add fissile material and to remove certain fission products to maintain MSR
21 operations. While these processes would be like other industrial hazards associated with
22 producing chloride- and fluoride-based compounds, they were not part of the analysis in
23 WASH-1248 (AEC 1974-TN23) and are not addressed in Table S-3.

24 An additional consideration for the liquid-fuel MSRs is that the fission products dissolved in the
25 fuel salt could be continuously removed in an adjacent online reprocessing loop and replaced
26 with fissile uranium, plutonium and other actinides, or, potentially, fertile Th-232 or U-238 (WNA
27 2021-TN7072). Because this is a series of actions that would occur during operations, it is not a
28 fuel fabrication process. For this situation, once the MSR begins operation, only the
29 manufacturing of the chemical form of the fissile material being produced to be compatible
30 with the respective chemistry of the molten salt to be delivered to the MSR is part of the
31 fuel preparation process. Potential waste processing and waste forms associated with
32 MSRs are documented by Riley et al. (2018-TN6942).

33 If the MSR design has a separate fuel channel from the molten-salt coolant then NRC staff
34 assumes the fuel fabrication environmental impacts as described above to be similar to the
35 nuclear fuel form being employed in the reactor design (i.e., oxides, TRISO, and metal).
36 However, due to the lack of environmental impact information about generating liquid-fuel
37 molten salt, the NRC staff cannot readily assess an environmental impact of such fuel
38 fabrication in relationship to WASH-1248 (AEC 1974-TN23) and Table S-3.

39 3.14.2.4.4 Fuel Fabrication Conclusions

40 For the assessment of environmental impacts, Table S-3 is expected to bound the impacts for
41 new reactors that rely on uranium oxycarbide/UO₂ fuels if such fuel fabrication is applying the
42 existing processes of the NRC-licensed fuel fabrication facilities resulting in SMALL impacts. If
43 not, the impacts from new reactor fuel fabrication would need to be bounded by the values
44 provided in Appendix E of WASH-1248 (AEC 1974-TN23), as listed in Table 3-9. Based on the

1 assumption of meeting these values, fuel fabrication is a Category 1 issue. The staff relied on
2 the following PPE assumptions to reach this conclusion:

- 3 • Table S-3 is expected to bound the impacts for new reactor fuels, because of uranium fuel
4 cycle changes since WASH-1248 (AEC 1974-TN23), including:
 - 5 – Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup
6 resulting in fewer discharged fuel assemblies to be fabricated each year and due to
7 longer time periods between refueling
 - 8 – Less reliance on coal-fired electrical generation plants resulting in less gaseous effluent
9 releases from electrical generation sources supporting fabrication
- 10 • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) *Domestic Licensing of*
11 *Source Material*, 10 CFR Part 70 (TN4883), *Domestic Licensing of Special Nuclear Material*,
12 10 CFR Part 71 (TN301), *Packaging and Transportation of Radioactive Material*, and 10
13 CFR Part 73 (TN423), *Physical Protection of Plants and Materials*.

14 Any new reactor fuel fabrication that cannot be bounded by WASH-1248 (AEC 1974-TN23),
15 namely metallic fuel and liquid-fuel MSRs, requires a discussion of the anticipated fuel
16 fabrication process and environmental impacts in the project-specific application. New reactor
17 applications in these cases must include enough information to support the staff's review for
18 reaching an environmental finding. The information needs identified in the PNNL report (Napier
19 2020-TN6443) should be provided in the new reactor application.

20 3.14.2.5 Reprocessing

21 As discussed in Section 1.6.1 of SECY-2011-0163 (NRC 2011-TN6830), the NRC staff
22 considers reprocessing to be defined as the separation of SNF into its constituent components
23 of isotopes of uranium, fission products, and TRU nuclides by aqueous and nonaqueous
24 chemical processing of irradiated fuel for the purpose of recovering reusable fuel material. This
25 definition encompasses the types of materials that would be produced in reprocessing and the
26 various methods of separation that have been proposed. Reprocessing of SNF could occur for
27 some types of new reactor fuels (e.g., fissile material circulating in the molten-salt coolant or a
28 new reactor designed to use reprocessed SNF) and could be internal to the operation of the
29 reactor at the site or could be conducted externally at a remote reprocessing facility. Therefore,
30 the environmental impacts of reprocessing new reactor fuel are addressed in this section.

31 At the time WASH-1248 was published, only U.S. government reprocessing facilities were in
32 operation and applying the plutonium uranium reduction extraction (PUREX) process.²⁸ There
33 were no operational commercial SNF reprocessing facilities. Three U.S. commercial
34 reprocessing facilities were anticipated to be operational later in the 1970s (AEC 1974-TN23).
35 Thus, WASH-1248 and related reports in support of Table S-3 evaluated the environmental
36 impacts of PUREX reprocessing as being maximized for either of the two fuel cycles: uranium
37 only and full recycle. Based on a court decision, the Commission directed the staff to prepare a
38 supplement to WASH-1248 to establish a basis for identifying environmental impacts associated
39 with fuel reprocessing and waste management activities that are attributable to the licensing of a
40 model LWR. These environmental impacts were documented in NUREG-0116, *Environmental*
41 *Survey of the Reprocessing and Waste Management Portions of the LWR Fuel Cycle*
42 (NRC 1976-TN292). No U.S. commercial SNF reprocessing facilities are in operation as of

²⁸ PUREX involves the dissolution of irradiated nuclear fuel in nitric acid, followed by separation of the uranium, plutonium, and fission products by solvent extraction using a mixture of tributyl phosphate in an organic diluent.

1 today, and there are no licensing actions to construct and operate such a nuclear facility at the
2 time of this GEIS; however, DOE and a group composed of commercial entities, universities,
3 and national laboratories are evaluating the potential for recycling and reprocessing spent
4 nuclear fuel (ARPA-E 2022-TN10126).

5 WASH-1248 Table F-1 provides a summary of environmental considerations for irradiated fuel
6 reprocessing normalized to the model LWR annual fuel requirement (AEC 1974-TN23). The
7 table is based on the collective operation of the three anticipated reprocessing facilities,
8 normalized to an annual capacity of 900 MTU/yr, to serve as the selected model reprocessing
9 plant. This capacity is equivalent to the annual fuel requirements of approximately 26 model
10 LWRs at 1,000 MWe each, or 3.46×10^{-2} MTU/yr-MWe.

11 The level of impacts of reprocessing in WASH-1248 (AEC 1974-TN23) correspond to
12 approximately a quarter of the current nuclear operating fleet. This amount of reprocessing
13 capability could support a large number of new reactors. Thus, it is likely that the capacity of an
14 offsite reprocessing process related to one new reactor would be significantly under
15 900 MTU/yr. Therefore, this is a Category 1 issue based on the bounding assumption that the
16 reprocessing capacity for the new reactor, if pursued as an integral part of its fuel cycle, would
17 be less than 900 MTU/yr, and that the contents of Table S-3 would bound the environmental
18 impacts.

19 Table 2-10 in the *Environmental Survey of the Reprocessing and Waste Management Portions*
20 *of the LWR Fuel Cycle* (NUREG-0116) provides a summary of the impacts of reprocessing and
21 waste management per reference reactor-year (RRY) for a 1,000 MWe reactor (assumed to be
22 operating at 80 percent of its maximum capacity for 1 year) (NRC 1976-TN292). Based on the
23 best available information applied in NUREG-0116, the impacts as summarized in Table 2.10 of
24 this NUREG are slightly different from those in WASH-1248 (AEC 1974-TN23). When these
25 impacts are included in the total impacts of the uranium fuel cycle attributable to a single reactor
26 (see new Total column in Table 2.10 of NUREG-0116), the total values are not substantially
27 different from those in WASH-1248; the difference in values is not sufficient to affect the NRC
28 staff's impact determination in this GEIS.

29 Under the Integral Fast Reactor program (ANL 2017-TN6832), a form of pyroprocessing
30 (ANL 2016-TN6831), a pyrochemical/electrochemical reprocessing (PER) method, was
31 developed and tested using the EBR-II fuel and facilities. Pyroprocessing is a nonaqueous
32 reprocessing process in which spent fuel is subjected to high temperatures (typically over 600°C
33 [equivalent])) to facilitate physical or chemical processes for the purpose of separating and
34 recovering fissile and fertile materials (NRC 2011-TN6830). PER is a pyroprocessing operation
35 involving selective reduction and oxidation in molten salts or metals to recover nuclear fuel
36 materials, and management of the resulting waste (NRC 2011-TN6830). However, the Integral
37 Fast Reactor program was cancelled, and further development of PER has been limited since
38 then (Frank et al. 2015-TN6833). Renewed interest in applying PER for reprocessing new
39 reactor fuel has been expressed, so the environmental impacts of a potential PER method are
40 considered in this GEIS. In support of the treatment of sodium-bonded SNF, DOE has evaluated
41 several methods of reprocessing including a PUREX-based and a PER-based treatment (DOE
42 2000-TN6834). As provided in Table S-4 of DOE/EIS-0306 (DOE 2000-TN6834), the PER
43 environmental impacts were shown to be less than those associated with a PUREX treatment
44 process with one exception where there is a small difference in the volume of high-level waste
45 generated (18 m³ for PER vs. 5.6 m³ for PUREX) (DOE 2000-TN6834).

1 The NRC staff finds the above conclusions provided in NUREG-0116 support the conclusions in
2 WASH-1248 resulting in SMALL impacts. Additionally, for the same mass of spent fuel
3 processed as in the PUREX process described in WASH-1248 (AEC 1974-TN23) and
4 NUREG-0116 (NRC 1976-TN292), these environmental impacts should bound or be similar to a
5 PER-based treatment process. This is a Category 1 issue. The staff relied on the following PPE
6 assumptions to reach this conclusion:

- 7 • Table S-3 is expected to bound the impacts for new reactor fuels, because of uranium fuel
8 cycle changes since WASH-1248 (AEC 1974-TN23), including:
 - 9 – Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup
10 resulting in fewer discharged fuel assemblies to be reprocessed each year
 - 11 – Less reliance on coal-fired electrical generation plants resulting in less gaseous effluent
12 releases from electrical generation sources supporting reprocessing
- 13 • Reprocessing capacity up to 900 MTU/yr
- 14 • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) “Domestic Licensing
15 of Source Material,” 10 CFR Part 50 (TN249), “Domestic Licensing of Production and
16 Utilization Facilities,” 10 CFR Part 70 (TN4883), “Domestic Licensing of Special Nuclear
17 Material,” 10 CFR Part 71 (TN301), “Packaging and Transportation of Radioactive Material,”
18 10 CFR Part 72 (TN4884), “Licensing Requirements for the Independent Storage of Spent
19 Fuel, High-Level Radioactive Waste, and Reactor-related Greater Than Class C Waste,”
20 and 10 CFR Part 73 (TN423), “Physical Protection of Plants and Materials.”

21 3.14.2.6 *Storage and Disposal of Radiological Wastes*

22 As with previous LWRs, the NRC must analyze the environmental impacts of the generation of
23 radioactive wastes by a new reactor and their safe storage and ultimate disposal. Appendix G of
24 WASH-1248 presents the analysis of the environmental impacts of managing radioactive
25 wastes from the nuclear fuel cycle activities (AEC 1974-TN23). The analysis is for radioactive
26 wastes that can be categorized as HLWs and other than high-level, or LLRWs. HLWs,
27 generated at fuel reprocessing plants, contain fission products separated from fissile material
28 recovered from irradiated fuel. LLRWs result from operations involving UF₆ production, fuel
29 fabrication, and fuel reprocessing. These include all wastes, regardless of concentration
30 or specific activity, that are not designated as HLWs.

31 While WASH-1248 states the LLRW, which is generated during fuel cycle operations, is variable
32 and difficult to estimate, the total waste volume is estimated to be approximately 14,000 ft³
33 (AEC 1974-TN23). This analysis also assumes that, with no further compaction of the waste,
34 the final volume of packages containing the waste could approximate 20,000 ft³ per annual
35 model LWR fuel requirement. As discussed in Section 3.15, Transportation of Fuel and Waste,
36 in this GEIS, this is a fraction of the annual LLRW from all U.S. sources shipped to the four
37 Agreement State-licensed LLRW disposal facilities.

38 The analysis in WASH-1248 (AEC 1974-TN23) was based on lower burnup levels than are
39 currently allowed for the current fleet of LWRs. The higher burnup levels result in greater
40 utilization of the uranium fuel along with corresponding greater efficiency in extracting energy
41 from the fuel. This has also resulted in extended time between refueling and the removal of
42 fewer fuel assemblies per reactor-year.

1 WASH-1248, while recognizing that a HLW disposal facility, which includes disposal of SNF, did
2 not yet exist, did state that the U.S. Atomic Energy Commission (AEC) was proceeding on a
3 program to design, construct, and operate a surface (or near-surface) facility in which the
4 solidified commercial HLW in sealed canisters would be stored (AEC 1974-TN23). However,
5 this program was never completed. Rather, in the late 1970s, the NRC reexamined an
6 underlying assumption used in licensing reactors up to that time, namely that a repository could
7 be secured for the ultimate disposal of spent fuel generated by nuclear reactors, and that spent
8 fuel could be safely stored in the interim (NRC 2014-TN4117). This analysis was later codified
9 into NRC regulations under 10 CFR 51.23 (TN250), “Temporary storage of spent fuel after
10 cessation of reactor operation – Generic determination of no significant environmental impact”
11 (49 FR 34658-TN3370), or the Waste Confidence decision.

12 3.14.2.6.1 Waste Confidence and the Evaluation of Continued Storage

13 The complete history of the Waste Confidence decision is provided in Section 1.1, History of
14 Waste Confidence, of NUREG-2157, *Generic Environmental Impact Statement for Continued
15 Storage of Spent Nuclear Fuel* (NRC 2014-TN4117) and is incorporated by reference. As a
16 result of legal actions involving the unknown timing of an operational geologic repository for the
17 permanent disposal of SNF, the NRC developed and published NUREG-2157 and revised
18 10 CFR 51.23 (TN250), which became “Environmental impacts of continued storage of SNF
19 beyond the licensed life for operation of a reactor” (79 FR 56238-TN4104).

20 NUREG-2157 analyzes the environmental impacts of continued storage of spent fuel
21 (NRC 2014-TN4117). In it, the NRC analyzed the direct, indirect, and cumulative effects of
22 continued storage for three timeframes:

- 23 • short-term – 60 years beyond licensed life for reactor operations;
- 24 • long-term – 100 years beyond the short-term storage time frame; and
- 25 • indefinite – indefinite storage and handling of spent fuel.

26 These timeframes are discussed in more detail in Section 1.8.2 of NUREG-2157 (NRC 2014-
27 TN4117). The locations of the storage sites related to these impacts were assessed for
28 at-reactor storage, away-from-reactor storage, and cumulative impacts when added to other
29 past, present, and reasonably foreseeable activities. The analyses contained in NUREG-2157
30 provide the regulatory basis for the revisions to 10 CFR 51.23 (TN250), in which 10 CFR
31 51.23(a) states:

32 The Commission has generically determined that the environmental impacts of
33 continued storage of SNF beyond the licensed life for operation of a reactor are
34 those impacts identified in NUREG–2157, “Generic Environmental Impact
35 Statement for Continued Storage of Spent Nuclear Fuel.”

36 The impact levels determined in NUREG-2157 of at-reactor storage, away-from-reactor storage,
37 and cumulative impacts of continued storage when added to other past, present, and
38 reasonably foreseeable activities are summarized in Table 6-4 of NUREG-2157 (NRC 2014-
39 TN4117). The impact levels are denoted as SMALL, MODERATE, and LARGE as a measure of
40 their expected adverse environmental impacts. Most impacts were found to be SMALL and
41 SMALL to MODERATE. For some resource areas, the impact determination language is
42 specific to the authorizing regulation, Executive Order, or guidance. Impact determinations that
43 include a range of impacts reflect uncertainty related to both geographic variability and the

1 temporal scale of the analysis. As a result, based on analyses performed in NUREG-2157, the
2 NRC assumes that further project-specific analysis would be unlikely to result in impact
3 conclusions with different ranges. The analyses of NUREG-2157 were codified into 10 CFR
4 51.23 (79 FR 56238-TN4104).

5 Many of the assumptions provided in Section 1.8.3, Analysis Assumptions, and subsequent
6 analysis in NUREG-2157 are independent of the fuel type because they involve onsite impacts
7 related to the siting, operation, and maintenance of the ISFSI and DTS facilities over all
8 timeframes during continued storage (NRC 2014-TN4117). For example, the waste
9 management resource area involves radioactive and chemical wastes generated by the
10 operation of the ISFSI itself and does not directly involve the SNF in the storage casks. Only a
11 select few topics considered in NUREG-2157 have a connection with the SNF itself and how it
12 could result in offsite environmental impacts, namely related to "Transportation," "Public and
13 Occupational Health," "Postulated Accidents," and "Potential Acts of Terrorism."

14 For the transportation of SNF and for public and occupational health, the staff concluded in
15 NUREG-2157 that the radiological doses would be expected to continue to remain below the
16 regulatory dose limits during continued storage and all of the related activities would have small
17 environmental impacts (NRC 2014-TN4117). The staff reached this conclusion in Sections 4.16
18 and 4.17 of NUREG-2157 because the operations during continued storage would have a
19 smaller workforce, lower volume of traffic and shipment activities, and continued storage
20 represents a fraction of the activities occurring during reactor operations, as previously analyzed
21 in the License Renewal GEIS (NRC 2024-TN10161) and in other NRC studies.

22 Regarding the analysis of postulated accidents in NUREG-2157 (NRC 2014-TN4117), any SNF
23 must be safely stored and decay heat must be appropriately removed once the SNF is removed
24 from the reactor. This includes the protection from and the mitigation of severe accidents, or
25 beyond-design-basis accidents, which are accidents that may challenge safety systems at a
26 level higher than that for which they were designed.

27 The concerns about severe accidents within an ISFSI, whether involving at-reactor or away-
28 from-reactor storage, were analyzed in NUREG-2157 (NRC 2014-TN4117). The lowest
29 consequences events with any radiological release involved dropping a cask. The highest
30 consequences were associated with an impact on the storage cask followed by a fire, such as
31 could occur after an aircraft impact. In all cases, the staff determined the likelihood of the event
32 would be very low and the environmental risk of an accident would be small. The consequences
33 described for cask drops at an ISFSI also provided some insight into the consequences of
34 severe accidents in a DTS. Compliance with NRC regulations for spent fuel handling and
35 storage would likely make the risk of severe accidents in a DTS small. In addition, the
36 consequences of any severe accident in a DTS would likely be comparable to or less than that
37 for the cask drop accident described above. This resulted in the staff concluding in
38 NUREG-2157 that the likely impacts from activities in a DTS also would be small.

39 An assessment of the risks that could potentially result from acts of terrorism or radiological
40 sabotage was also provided in NUREG-2157 (NRC 2014-TN4117). The assessment was
41 based, in part, on the analysis provided in the licensing of the Diablo Canyon ISFSI and
42 accounted for the security and protective measures required by NRC regulations (see
43 Section 4.19 of NUREG-2157). The staff determined that the potential for theft or diversion of
44 LWR spent fuel from the ISFSI with the intent of using the contained SNM for nuclear explosives
45 is not considered credible because of the following:

- 1 • the inherent protection afforded by the massive reinforced concrete storage module and the
2 steel storage canister;
- 3 • the unattractive form of the contained SNM, which is not readily separable from the
4 radioactive fission products; and
- 5 • the immediate hazard posed by the high radiation levels of the spent fuel to persons not
6 provided with radiation protection.

7 The staff concluded in NUREG-2157 (NRC 2014-TN4117) that for acts of terrorism, even
8 though the environmental consequences of a successful attack could be large, the very low
9 probability of a successful attack ensures that the environmental risk would be small for
10 operational ISFSIs and DTSs during continued storage.

11 Finally, the Commission, in the Continued Storage rulemaking, reclassified the offsite
12 radiological impacts of SNF and HLW disposal as a Category 1 issue; no impact level was
13 assigned and the finding column entry was revised to address the existing radiation standards
14 (79 FR 56238-TN4104). Thus, the Commission has concluded that the impacts would not be
15 sufficiently large to require the NEPA conclusion, for any plant, that the option of extended
16 operation under 10 CFR Part 54 (TN4878) should be eliminated (see Table B-1 in 10 CFR
17 Part 51 [TN250]).

18 *3.14.2.6.2 Continued Storage of Spent Advanced Fuel*

19 Many of the new reactor designs currently under development were not part of the analysis of
20 NUREG-2157 (NRC 2014-TN4117), as noted in Section 1.8.6, Issues Eliminated from Review in
21 this GEIS. This is likely due to information provided in a report to Congress in August 2012
22 (NRC 2012-TN6670), which stated:

23 Spent nuclear fuel storage regulations in 10 CFR Part 72 are generally broad
24 enough to address new types of fuel associated with advanced reactor designs.
25 However, minor modifications may be necessary to address new design features
26 from any new class of cask storage technologies associated with advanced
27 reactor fuels. The NRC would need to evaluate the adequacy of new storage
28 cask designs for onsite storage of advanced LWR and non-LWR fuel designs
29 and any other radioactive components not previously reviewed as part of the
30 current LWR technology. The NRC would consider how cask designs may be
31 affected by different discharge and loading operations, since discharged fuel may
32 not be housed in traditional spent fuel pools. Other challenges may involve
33 stacking spent fuel for non-LWRs during refueling operations, as well as
34 detecting, segregating, and processing damaged fuel.

35 Thus, with only limited information about SNFs concerning high-temperature gas-cooled
36 reactors or liquid metal fast reactors, NUREG-2157 designated SNF from these types of
37 advanced reactors as being out of scope (NRC 2014-TN4117). However, if these technologies
38 should become viable and the NRC reviews one or more license applications for an out of
39 scope advanced reactor, then the environmental impacts of continued storage of that spent fuel
40 will be considered in individual licensing proceedings unless the NRC updates NUREG-2157
41 and the corresponding rule to include the environmental impacts of storing this type of fuel after
42 a reactor's licensed life for operation (NRC 2014-TN4117).

1 The same requirements for the shipment of spent fuel to and storage at an offsite ISFSI with
2 respect to NRC and the U.S. Department of Transportation (DOT) regulations would apply to
3 new reactor SNF. Thus, the analysis of NUREG-2157 (NRC 2014-TN4117) for the safe
4 handling, storage, and management of SNF could also apply to any type of new reactor SNF,
5 regardless of its chemical form, and is incorporated here by reference. Several assumptions can
6 be made simply because any such SNF container (i.e., a storage cask or a transportation
7 container or cask) or an ISFSI and DTS facilities for new reactor SNF must satisfy the regulatory
8 requirements of 10 CFR Part 71 (TN301), "Packaging and Transportation of Radioactive
9 Material," 10 CFR Part 72 (TN4884), "Licensing Requirements for the Independent Storage of
10 Spent Fuel, High-Level Radioactive Waste, and Reactor-related Greater Than Class C Waste,"
11 and 10 CFR Part 73 (TN423), "Physical Protection of Plants and Materials."

12 Any new reactor spent fuel storage or shipping containers must demonstrate that the associated
13 fuels can always be safely managed (see 10 CFR Part 71 Subpart E (TN301), *Package*
14 *Approval Standards*, for shipping containers and 10 CFR Part 72 Subpart L (TN4884), *Approval*
15 *of Spent Fuel Storage Casks, for spent fuel storage casks*).

16 Radionuclide inventories and thermal loading limits should not be a significant departure from
17 the performance of currently certified spent fuel shipping and storage containers. For example,
18 the radionuclide inventory and related container shielding for any type of new reactor SNF must
19 meet the regulatory requirements of 10 CFR 71.47 (TN301), *External radiation standards for all*
20 *packages* and 10 CFR 72.236 (TN4884), *Specific requirements for spent fuel storage cask*
21 *approval and fabrication*.

22 If new reactor SNF is not encased in a zirconium alloy, then the highly exothermic chemical
23 reaction called a runaway zirconium oxidation reaction or autocatalytic ignition as assessed in
24 NUREG-2157 (NRC 2014-TN4117) is not possible. Metallic fuels could be encased in a type of
25 stainless steel (e.g., stainless steel [SS] 316, HT9, and D9) rather than a zirconium alloy
26 cladding (FRWG 2018-TN6696). TRISO fuels are encapsulated in ceramic and carbon-based
27 materials, and "are structurally more resistant to neutron irradiation, corrosion, oxidation, and
28 high temperatures (the factors that most impact fuel performance) than traditional reactor fuels"
29 (DOE 2019-TN6786). Several suitable non-zirconium alloys may exist, including
30 high-temperature nickel-based alloys and modified Hastelloy N variants, for showing acceptable
31 compatibility in MSRs (Busby et al. 2019-TN6695).

32 In addition, any shipping or storage container for SNF, including SNF from new reactors, would
33 have to satisfy the regulatory requirements of 10 CFR 71.55 (TN301), "General requirements for
34 fissile material packages," and 10 CFR 72.236 (TN4884), "Specific requirements for spent fuel
35 storage cask approval and fabrication," which include the following:

- 36 • Confine fuel to a known volume.
- 37 • Ensure compliance with criticality safety.
- 38 • Meet specific structural testing requirements.
- 39 • Permit normal handling and retrieval.

40 Because the ISFSI infrastructure and the required physical protection is no different for LWR
41 SNF than for non-LWR SNF, the same considerations provided in NUREG-2157 (NRC 2014-
42 TN4117) of a very low probability of an accident or of a successful terrorist attack with the
43 resulting small environmental risk would apply during continued storage of any new reactor
44 SNF. The one difference identified in NUREG-2157 was that for non-LWR SNF, the period of
45 self-protection from acts of terrorism may be shorter than that of LWR SNF, depending on the

1 burnup level and the isotopic composition of the SNM (i.e., the attractiveness of the material for
2 diversion).

3 Therefore, if the new reactor SNF conforms with the above analysis for this Category 1 issue,
4 then the analysis of NUREG-2157 (NRC 2014-TN4117) would bound the environmental impacts
5 and impacts would be SMALL. The staff relied on the following PPE assumptions to reach this
6 conclusion:

- 7 • Table S-3 is expected to bound the impacts for new reactor fuels, because of uranium fuel
8 cycle changes since WASH-1248 (AEC 1974-TN23), including:
 - 9 – Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup
10 resulting in fewer discharged fuel assemblies to be stored and disposed.
 - 11 – Less reliance on coal-fired electrical generation plants resulting in less gaseous effluent
12 releases from electrical generation sources supporting storage and disposal.
- 13 • Waste and spent fuel inventories, as well as their associated certified spent fuel shipping
14 and storage containers, are not significantly different from what has been considered for
15 LWR evaluations in NUREG-2157 (NRC 2014-TN4117)
- 16 • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) *Domestic Licensing of*
17 *Source Material*, 10 CFR Part 70 (TN4883), *Domestic Licensing of Special Nuclear Material*,
18 10 CFR Part 71 (TN301), *Packaging and Transportation of Radioactive Material*, 10 CFR
19 Part 72 (TN4884), *Licensing Requirements for the Independent Storage of Spent Fuel*,
20 *High-Level Radioactive Waste, and Reactor-related Greater Than Class C Waste*, and
21 10 CFR Part 73 (TN423), *Physical Protection of Plants and Materials*.

22 However, if conditions, such as fuel stability within the uranium spent fuel (ORNL 1970-TN6754,
23 ORNL 1998-TN6755) and the site conditions for construction and operation of an ISFSI
24 including fuel transfers, go beyond what is in NUREG-2157, then a project-specific analysis
25 would be necessary to demonstrate continued safe storage (ORNL 1970-TN6754, ORNL 1998-
26 TN6755).

27 Disposal of new reactor SNF in a deep geological repository would need to demonstrate
28 compliance with radiation standards that are expected to be comparable, if not the same, as the
29 existing radiation standards in Table B-1 in 10 CFR Part 51 (TN250) (e.g., a dose limit of
30 0.15 millisieverts [15 mrem]). Therefore, the offsite radiological impacts of new reactor SNF
31 could be expected to be classified as a Category 1 issue with no impact level assigned.

32 **3.14.3 Staff Conclusions about the Environmental Impacts of a New Reactor Fuel Cycle**

33 It is important to acknowledge that the determinations arrived in this GEIS are based on the
34 staff's current understanding of the proposed plans and designs for the activities associated with
35 new reactor fuel and facilities. The staff reviewed the general literature containing information
36 about expected new reactor (LWR and non-LWR) fuel cycles. The review examined expected
37 uranium and uranium-plutonium fuel forms (oxide, metal, TRISO, salt). The staff review
38 examined available information about uranium extraction, uranium conversion, uranium
39 enrichment, fuel processing/fabrication, nuclear material transportation, irradiated fuel
40 processing, spent fuel management, and radioactive waste management as it is related to
41 expected new reactor systems. The NRC staff assumes that the thorium fuel cycle will not be
42 significantly different from the uranium fuel cycle, therefore the uranium fuel cycle impacts
43 should bound the thorium fuel cycle impacts.

1 Based on its review of the available, general information, the staff believes that new reactor fuel
2 cycles will have SMALL environmental impacts (i.e., impacts that are less than or comparable to
3 those of current LWRs and those discussed in Table S-3), particularly for once-through fuel
4 cycle options. The lower fuel cycle impacts are the result of improved fuel cycle technologies
5 (reduced environmental impact), improved reactor technologies, and waste and spent fuel
6 inventories that are not significantly different from what has been considered for LWR
7 evaluations (e.g., as in Continued Storage Rulemaking) with respect to hazardous
8 radionuclides.

9 A new reactor applicant would have to demonstrate in its ER that the impacts of its fuel cycle fall
10 within the values and assumptions of the PPE for the Category 1 issues above (see
11 Section 1.3.1 of this GEIS). The NRC staff expects the new reactor applicants to describe their
12 planned fuel cycle designs, plans, and activities. The applicant's analysis needs to discuss and
13 analyze any new processes (ones not considered in this NR GEIS) that will be part of their fuel
14 cycle.

15 **3.15 Transportation of Fuel and Waste**

16 **3.15.1 Baseline Conditions and PPE/SPE Values and Assumptions**

17 The NRC has generically evaluated the environmental effects of the transportation of fuel and
18 waste to and from LWRs in 10 CFR 51.52 Table S-4, Environmental effects of transportation of
19 fuel and waste (TN250). However, the environmental data in Table S-4 is only applicable to
20 LWRs that use uranium oxide, or UO₂, fuel that meets specific criteria in 10 CFR 51.52(a) as
21 expanded in Addendum 1 of NUREG-1437, *Generic Environmental Impact Statement for*
22 *License Renewal of Nuclear Plants Addendum to Main Report* (NRC 1999-TN289) and as
23 discussed in Revision 2 of NUREG-1437, *Generic Environmental Impact Statement for License*
24 *Renewal of Nuclear Plants* (NRC 2024-TN10161). Some new reactor developers are expected
25 to use uranium fuel with enrichment levels of up to 20 percent enrichment, known as HALEU. In
26 addition, as discussed in Section 3.14 of this GEIS, several of the potential non-LWR designs
27 are expected to deploy non-UO₂ fuels (e.g., uranium metal, uranium carbide, uranium in a
28 molten salt, etc.) or deploy new reactors based on a Th-232/U-233 fuel cycle. While Table S-4
29 does not apply to new reactors and non-UO₂ fuels, the transportation of fuel and waste is a
30 connected action under NEPA regulations, guidance, and case law. Therefore, the NRC must
31 still evaluate transportation impacts for the non-LWR fuel and waste to meet its obligations
32 under NEPA as has been done for large LWR UO₂ fuels. This section addresses both the
33 radiological and nonradiological environmental impacts from incident-free and accident
34 conditions resulting from (1) shipment of unirradiated fuel to the new reactor site, (2) shipment
35 of LLRW and mixed waste to offsite disposal facilities, and (3) shipment of spent fuel to an
36 interim storage facility or a permanent geologic repository. Air emissions from the transportation
37 of fuel and waste, specifically for greenhouse gases or GHGs, are discussed in Section 3.3 of
38 this GEIS.

39 *3.15.1.1 Table S-4 on the Transportation of Fuel and Waste*

40 The NRC performed a generic analysis of the environmental effects of the transportation of fuel
41 and waste to and from LWRs in the *Environmental Survey of Transportation of Radioactive*
42 *Materials To and From Nuclear Power Plants*, WASH-1238 (AEC 1972-TN22) and in a
43 supplement to WASH-1238, NUREG-75/038 (NRC 1975-TN216), and found the impact to be
44 small. These documents provided the basis for Table S-4 in 10 CFR 51.52 (TN250) that
45 summarizes the environmental impacts of transportation of fuel and waste to and from one LWR

1 of 3,000 to 5,000 MW(t) (1,000 to 1,500 MW(e)). Impacts are provided for normal conditions of
2 transport and accidents in transport for a reference 1,100 MW(e) LWR.²⁹ Dose to transportation
3 workers during normal transportation operations was estimated to result in a collective dose of
4 4 person-rem per RRY. The combined dose to the public along the route and the dose to
5 onlookers were estimated to result in a collective dose of 3 person-rem per RRY.

6 Based on public comments on the 1996 version of NUREG-1437 (NRC 1996-TN288), the NRC
7 reevaluated the transportation issues and the adequacy of Table S-4 for license renewal
8 application reviews. In 1999, the NRC issued an addendum to the 1996 License Renewal GEIS
9 (NRC 1999-TN289) in which the agency evaluated the applicability of Table S-4 to future license
10 renewal proceedings, given that the spent fuel is likely to be shipped to a single repository (as
11 opposed to several destinations, as originally assumed in the preparation of Table S-4) and
12 given that shipments of spent fuel are likely to involve more highly enriched fresh fuel (more
13 than 4 percent as assumed in Table S-4) and higher-burnup spent fuel (higher than
14 33,000 MWd/MTU as assumed in Table S-4). In the addendum, the NRC evaluated the impacts
15 of transporting the spent fuel from reactor sites to the candidate repository at Yucca Mountain
16 and the impacts of shipping more highly enriched fresh fuel and higher-burnup spent fuel. On
17 the basis of the evaluations, the NRC concluded that the values given in Table S-4 would still be
18 bounding, as long as the (1) enrichment of the fresh fuel was 5 percent or less, (2) burnup of the
19 spent fuel was 62,000 MWd/MTU or less, and (3) higher-burnup spent fuel (higher than
20 33,000 MWd/MTU) was cooled for at least 5 years before being shipped offsite. A later study
21 found that the impacts presented in Table S-4 would bound the potential environmental impacts
22 that would be associated with transportation of SNF with up to 75,000 MWd/MTU burnup,
23 provided that the fuel is cooled for at least 5 years before shipment (Ramsdell et al. 2001-
24 TN4545).

25 3.15.1.2 *Additional NRC Studies of the Risk from the Transportation of SNF*

26 Since the publication of WASH-1238 (AEC 1972-TN22) and NUREG-75/038 (NRC 1975-
27 TN216), the NRC has undertaken four studies regarding the risk from the transportation of SNF.
28 Each study improved upon the assumptions and analysis techniques from the prior study for
29 assessing these risks.

30 In September 1977, the NRC published NUREG-0170, *Final Environmental Statement on the*
31 *Transportation of Radioactive Material by Air and Other Modes*, which assessed the adequacy
32 of the regulations in 10 CFR Part 71 (TN301), then entitled *Packaging and Transportation of*
33 *Radioactive Waste* (NRC 1977-TN417, NRC 1977-TN6497). In that assessment, the measure
34 of safety was the risk associated with radiation doses to the public under routine and accident
35 transport conditions, and the risk was found to be acceptable. Since that time, there have been
36 two affirmations of this conclusion for SNF transportation, each using improved tools and
37 information.

38 A 1987 study applied actual accident statistics to projected spent fuel transportation (Fischer
39 et al. 1987-TN4105). This study, known as the "Modal Study," recognized that accidents could
40 be described in terms of the strains they produced in transportation packages (for impacts) and
41 the increase in package temperature (for fires). Like NUREG-0170 (NRC 1977-TN417,
42 NRC 1977-TN6497), the 1987 study based risk estimates on models because the limited
43 number of accidents that had occurred involving spent fuel shipments was not sufficient to

²⁹ Note that the basis for Table S-4 is a 1,100 MW(e) LWR at an 80 percent capacity factor (AEC 1972-TN22; NRC 1975-TN216).

1 support projections or predictions. The Modal Study's refinement of modeling techniques and
2 use of accident frequency data resulted in smaller assessed risks than had been projected in
3 NUREG-0170.

4 In 2000, a study of two generic truck packages and two generic rail packages analyzed the
5 package structures and response to accidents by using computer modeling techniques
6 (Sprung et al. 2000-TN222). The study used semi-trailer truck and rail accident statistics for
7 general freight shipments because, even though more than 1,000 spent fuel shipments had
8 been completed in the United States by the year 2000 and many thousands more had been
9 completed safely internationally, there had been too few accidents involving spent fuel
10 shipments to provide statistically valid accident rates. Sprung et al. 2000 (TN222) used
11 improved technology to analyze the ability of containers to withstand an accident. This study
12 concluded that the risk from the increased number of spent fuel shipments that could occur in
13 the first half of this century would be even smaller than originally estimated in NUREG-0170
14 (NRC 1977-TN417, NRC 1977-TN6497).

15 NUREG-2125, published in January 2014, presented the results of a fourth investigation into the
16 safety of SNF transportation (NRC 2014-TN3231). The selected routes included the origins and
17 destinations analyzed in NUREG/CR-6672 (Sprung et al. 2000-TN222), thereby permitting the
18 results of the studies to be compared. This investigation showed that the risk from the radiation
19 emitted from the packages is a small fraction of naturally occurring background radiation and
20 the risk from accidental release of radioactive material is several orders of magnitude less.
21 Because there have been only minor changes to the radioactive material transportation
22 regulations in NUREG-0170 (NRC 1977-TN417, NRC 1977-TN6497) and NUREG-2125, the
23 calculated dose from the external radiation from the package under routine transport conditions
24 is similar to what was found in earlier studies. The improved analysis tools and techniques,
25 improved data availability, and a reduction in uncertainty have made the estimate of accident
26 risk from the release of radioactive material in NUREG-2125 approximately five orders of
27 magnitude less than what was estimated in NUREG-0170. The results from NUREG-2125 (NRC
28 2014-TN3231) demonstrate that NRC regulations continue to provide adequate protection of
29 public health and safety during the transportation of SNF.

30 The NRC published NUREG-2266, "Environmental Evaluation of Accident Tolerant Fuels with
31 Increased Enrichment and Higher Burnup Levels," in July 2024 to support efficient and effective
32 licensing reviews of ATFs and to reduce the need for a complex site-specific environmental
33 review for each ATF LAR (NRC 2024-TN10333). NUREG-2266 evaluated the reasonably
34 foreseeable impacts of near-term ATF technologies with increased enrichment and higher
35 burnup levels on the uranium fuel cycle, transportation of fuel and waste, and decommissioning
36 for LWRs (i.e., a bounding analysis). To this end, the NRC staff assessed and applied available
37 near-term ATF technology performance analyses, data, and studies; information from prior NRC
38 environmental analyses; and the assessment of other publicly available data sources and
39 studies to complete an evaluation of ATF with increased enrichment and higher burnup levels.
40 Based on the evaluations in this study, the NRC staff determined that Table S-4 of 10 CFR
41 51.52(c) would bound the deployment and use of near-term ATF for up to 8 wt% U-235 and
42 80 GWd/MTU average assembly burnup. This study also indicates there would be no significant
43 adverse environmental impacts for the uranium fuel cycle, transportation of fuel and wastes, and
44 decommissioning associated with deploying near-term ATF.

45 For the assessment of the potential generic impacts of transporting SNF in this GEIS,
46 NUREG-2125 (NRC 2014-TN3231) is examined for environmental impacts because it is the
47 most recent study that applies the latest knowledge and analytical tools.

1 3.15.1.3 *Additional NRC Information Sources*

2 Several NRC EISs regarding the construction and operation of new reactors contain an analysis
3 of the potential environmental impacts due to the transportation of LWR fuel and waste. These
4 transportation assessments were performed by the new reactor applicants to meet the
5 regulatory requirements of 10 CFR 51.52 (TN250). The NRC staff then reviewed the applicant's
6 analyses and made a final assessment of the impacts, normalized with respect to power level
7 and the amount of radioactive material per shipment, to allow for comparison to the results
8 presented in Table S-4 of 10 CFR 51.52. While 10 CFR 51.52 applies only to LWRs, these
9 assessments may help inform the staff's assessment in this GEIS because of the similarities in
10 transportation modes (e.g., packaging, routing, and distances) and the quantities of radioactive
11 material per shipment.

12 In addition to the new reactor EISs, the NRC has published two EISs regarding the proposed
13 licensing of two interim storage facilities (NRC 2021-TN10124, NRC 2022-TN10171). The
14 transportation assessments of these EISs will also be examined for informing the transportation
15 assessments in this GEIS.

16 3.15.1.4 *U.S. Department of Energy Transportation Risk Assessments*

17 The DOE routinely ships radioactive material between their various national laboratories and
18 other nuclear facilities. Examples of these shipments include shipments of LLRW and
19 transuranic wastes to DOE disposal sites at the Nevada Test Site and the Waste Isolation Pilot
20 Plant, respectively. Some DOE LLRW has also been shipped to commercial disposal sites.
21 DOE has also transported SNF as part of various national programs, such as shipments of
22 research quantities of commercial SNF to the INL (INL 2020-TN6500). Hence, DOE developed
23 a transportation risk assessment handbook to provide a methodology for DOE staff and DOE
24 contractors to apply when conducting necessary NEPA analysis related to DOE programs
25 involving shipments of radioactive material (DOE 2002-TN1236). The methodology presented in
26 the DOE handbook is the preferred analytical method for assessing the environmental impacts
27 of the transportation of fuel and waste.

28 DOE has also published a number of reports that include transportation risk assessments as a
29 component of their NEPA analysis in support of a number of DOE program decisions. A majority
30 of these are for specific situations and for a limited number of radioactive material shipments.
31 There are two transportation risk assessments that are more comprehensive with respect to
32 potentially large shipping campaigns. The first of these two assessments is the transportation
33 analysis in support of the licensing of the Yucca Mountain geologic repository (DOE 2002-
34 TN1236). The second study is a series of reports (Monette et al. 1995-TN6505, Monette et al.
35 1995-TN6506; Biwer et al. 1996-TN6502; Monette et al. 1996-TN6501, Monette et al. 1996-
36 TN6503) concerning the transportation of radioactive wastes as part of the production of the
37 DOE Waste Management Programmatic Environmental Impact Statement (DOE 1997-TN6752).
38 Information from these assessments will be used in this evaluation of the environmental impacts
39 of non-LWR waste shipments.

40 3.15.1.5 *Issues for the Transportation of Non-LWR Fuel and Wastes*

41 There is limited information regarding the transportation of several forms of non-LWR fuel due to
42 the expected higher enrichment levels (i.e., HALEU fuel) and the physical form of the non-LWR
43 fuel being shipped. This limited information has been identified in several reports and
44 conference/seminar/workshop presentations and principally involves suitable transportation

1 packages to support the economic use of HALEU materials (Jarrell 2018-TN6508; Eidelpes
2 et al. 2019-TN6507; Reardon et al. 2019-TN6952).

3 Principal issues involve the lack of certified transport packages for unirradiated and irradiated
4 HALEU fuel and radioactive waste. Items being considered for non-LWR fuel and waste
5 transport packages include the following:

- 6 • non-LWR fresh fuel shipments likely to be similar to those for LWRs (except for molten salt);
- 7 • processing operations and transportation for MSR and sodium fast reactors are
8 significantly different than for the current reactor fleet; and
- 9 • uncertainty in the post irradiation forms for transport and storage.

10 Another potential departure from current transportation practices for LWR unirradiated, or fresh,
11 fuel and SNF is the fuel loading in one transport package. Currently, multiple shipments must be
12 made to fuel the LWR core and to remove the SNF from the LWR site. There are non-LWR
13 developers whose relatively small size of the reactor core may lead them to consider
14 transporting the entire and completely assembled reactor core or reactor vessel with the core to
15 and from the reactor site. These are all factors that must be considered in this evaluation to
16 determine if the environmental impacts from the transportation of non-LWR fuel and waste can
17 be generically addressed.

18 3.15.1.6 *Development of the Transportation Plant Parameter Envelope*

19 The effects of incident-free and accident transportation are proportional to the total shipment
20 distance associated with the unirradiated fuel, radioactive waste, or irradiated fuel, i.e., as the
21 number of shipments and the shipping distance increase, the effects from transporting the
22 unirradiated fuel, radioactive waste, or irradiated fuel also increase. For this reason, the total
23 shipment distance was used as the metric for the transportation PPE. The total shipment
24 distance is quantified in terms of the annual one-way shipment distance or the annual round-trip
25 shipment distance.

26 The annual one-way shipment distance is calculated using the formula:

27 • Annual One-Way Shipment Distance (km) = Annual Number of Normalized Shipments ×
28 One-Way Shipping Distance (km)

29 • The annual round-trip shipment distance is calculated using the formula:

30 • Annual Round-Trip Shipment Distance (km) = 2 × Annual Number of Normalized
31 Shipments ×
32 One-Way Shipping Distance (km)

33 In order to develop the transportation PPE, NRC staff examined WASH-1238 and past new
34 reactor EISs to determine the total shipment distances evaluated in these EISs for unirradiated
35 fuel, radioactive waste, or irradiated fuel. The NRC staff also identified factors that could affect
36 the relationship between the effects of incident-free and accident transportation and the total
37 shipment distance.

38 Factors identified by the NRC staff included:

- 1 • The use of different versions of RADTRAN to estimate the effects of transporting
2 unirradiated fuel, radioactive waste, and irradiated fuel: The radiation doses and risks
3 discussed in Sections 3.15.1.7, 3.15.1.8, and 3.15.1.9 below were estimated using the
4 RADTRAN computer code. RADTRAN has changed over time, with Version 5 (Neuhauser
5 et al. 2000-TN6990; Neuhauser and Kanipe 2003-TN6989) being used in EISs published in
6 the period 2006-2008, Version 5.6 (Weiner et al. 2008-TN302) being used in EISs published
7 in the period 2011-2016, and Version 6 being the current version (Weiner et al. 2013-
8 TN3390, Weiner et al. 2014-TN3389). A specific example of how RADTRAN has changed
9 over time is in how it estimates long-term doses after a transportation accident, where
10 RADTRAN 5 and 5.6 estimated a 50-year long-term dose from transportation accidents,
11 while RADTRAN 6 no longer provides 50-year long-term dose estimates (see page 66 and
12 equation 75 in Weiner et al. 2014-TN3389).
- 13 • The use of different census data to estimate the effects of transporting unirradiated fuel,
14 radioactive waste, and irradiated fuel: The radiation doses and risks discussed in
15 Sections 3.15.1.7, 3.15.1.8, and 3.15.1.9 below were estimated using 2000 census and
16 2010 census data; earlier EISs used 2000 census data and later EISs used 2010 census
17 data to estimate transportation impacts. The use of different census data can affect the
18 estimates of the effects of transporting unirradiated fuel, radioactive waste, and irradiated
19 fuel for a transportation route, even if the route remains the same.
- 20 • The use of different sources of transportation accident, injury, and fatality rate data to
21 estimate the effects of transporting unirradiated fuel, radioactive waste, and irradiated fuel:
22 In general, the radiological and nonradiological effects discussed in Sections 3.15.1.7,
23 3.15.1.8, and 3.15.1.9 below were estimated using state-level accident, injury, and fatality
24 rate data from Saricks and Tompkins (1999-TN81). However, other sources of transportation
25 accident, injury, and fatality rate data have been used (e.g., DOT 2013-TN3930). The use of
26 different accident, injury, and fatality rate data can affect the estimates of the effects of
27 transporting unirradiated fuel, radioactive waste, and irradiated fuel.
- 28 • The number of exposed persons along different transportation routes: Lower transportation
29 effects would be estimated for routes through more sparsely populated areas (rural) than for
30 routes through more highly populated areas (urban and suburban), where higher
31 transportation effects would be estimated. The fraction of a route that is urban, suburban,
32 and rural will vary for the same destination depending on the originating site's location and
33 on the states traversed by a transportation route.
- 34 • Differences in the accident, injury, and fatality rates in the various states traversed by a
35 transportation route: The transportation accident effects discussed in Sections 3.15.1.7,
36 3.15.1.8, and 3.15.1.9 below were typically estimated using state-level accident, injury, and
37 fatality rate data (see Saricks and Tompkins 1999-TN81). These rates differ by state, which
38 can yield higher or lower estimates of effects depending on the states traversed by a
39 transportation route.
- 40 • Differences in parameters such as source-to-receptor distances, shielding factors,
41 transportation cask dimensions, etc. used to estimate the effects of transporting unirradiated
42 fuel, radioactive waste, and irradiated fuel: The radiological effects discussed in
43 Sections 3.15.1.7, 3.15.1.8, and 3.15.1.9 below were estimated using specific values of
44 parameters deemed appropriate at the time of the analysis, such as source-to-receptor
45 distances, shielding factors, and transportation cask dimensions. These specific parameter
46 values would affect the calculated values in the tables below.

- 1 • Differences in the radionuclide inventory contained in a transportation cask due to the
2 irradiated fuel having higher or lower burnup: The radiological effects associated with
3 transportation accidents involving irradiated fuel discussed in Section 3.15.1.9 were
4 estimated using a transportation cask with a capacity of 0.5 MTU. However, the burnup
5 associated with the irradiated fuel would be reactor-specific. The burnup affects the
6 radionuclide inventory, which in turn affects the estimates of the estimated radiation doses
7 from transportation accidents involving irradiated fuel.
- 8 • Use of an updated stop model for unirradiated fuel shipments: The transportation effects in
9 the North Anna (NRC 2006-TN7), Clinton (NRC 2006-TN672), and Grand Gulf (NRC 2006-
10 TN674) EISs were estimated using a stop model with a population density of
11 64,300 people/km² in a 1 to 10 m annular ring around the vehicle. In addition, the exposure
12 time was estimated to be 4.5 hours and no shielding was assumed. In later EISs,
13 transportation effects were estimated using the updated stop model described by
14 Griego et al. (1996-TN69).

15 NRC staff found that these factors do not affect the use of the total shipment distance as the
16 metric for the transportation PPE but account for the variations in the calculated values in the
17 subsequent tables.

18 3.15.1.7 *Transportation of Unirradiated New Reactor Fuel*

19 Unirradiated nuclear fuel assemblies, or fresh fuel elements, are transported to the nuclear
20 reactor in protective outer packages designed to prevent damage to the fuel elements in transit
21 (Rhoads 1977-TN6572). Typically, one pressurized water reactor (PWR) or two boiling water
22 reactor fuel elements are placed in a protective overpack designed to protect the valuable fuel
23 element from damage during transport (NRC 2019-TN6511, NRC 2019-TN6512, NRC 2019-
24 TN6513). These overpacks are usually shipped to the nuclear reactor site by truck. Ten
25 containers of PWR fuel (Table B-2 of WEC 2019-TN6510) each containing one assembly or six
26 containers of boiling water reactor fuel each containing two assemblies are typically placed on a
27 standard truck semi-trailer with a current maximum Federal gross vehicle weight limit of
28 80,000 pounds (DOT 2015-TN6753).³⁰ The overpack dimensions appear to be the limiting factor
29 for the number of overpacks in one shipment and not the maximum Federal gross vehicle
30 weight limit.

31 The necessary NRC-certified transport packages for unirradiated new reactor fuel at HALEU
32 enrichment levels are being developed (Jarrell 2018-TN6508; Eidelpes et al. 2019-TN6507;
33 Jarrell and Eidelpes 2020-TN6694). For example, in Section 4, Review and Application of
34 Existing Packaging Designs, in the paper by Eidelpes et al. (2019-TN6507), the authors note
35 that two promising packaging designs were identified that could be adapted for HALEU
36 transportation, and could be readily transported by truck. These are the Transnuclear Americas
37 Long Cask (TN-LC) (NRC 2017-TN6684) and the NAC International Inc. (NAC) International
38 Optimal Modular Universal Shipping for low-activity contents (OPTIMUS™-L) packaging. In
39 addition, review of the NRC-certified transport packages listed on DOE's Radioactive Material
40 Packaging website reveals a small number of transportation packages that are currently
41 certified for shipping HALEU material, such as the VP-55 package (Hennebach and Langston
42 2020-TN6693; NRC 2020-TN6686). The VP-55 package is also certified for various forms of
43 unirradiated TRISO fuel in the form of uranium kernels and TRISO particles, which may be

³⁰ 10 CFR 51.52 (TN250) Table S-4 includes a condition that the truck shipments not exceed 73,000 lb as governed by Federal or State gross vehicle weight restrictions.

1 loose or mixed in a graphite matrix and pressed into compacts of various fuel forms
2 (e.g., annular cylinders, planks, right circular cylinders, spheres, etc.).

3 There are also DOE-certified transport packages that potentially could be applied for shipping
4 HALEU fuel (Jarrell 2018-TN6508). The higher enriched material approved for such certified
5 packages could be in the form of UF₆, TRISO, and research reactor plate fuel. Given the nature
6 of liquid-fueled MSR where the HALEU material is mixed with the chloride- or fluoride-based
7 molten salt, it should be expected that the HALEU material would be shipped from the
8 enrichment site to the MSR site in the form of UF₆ (McFarlane et al. 2019-TN6741).

9 *3.15.1.7.1 Normal Conditions*

10 Normal conditions, sometimes referred to as “incident-free” transportation, are transportation
11 activities during which shipments reach their destination without releasing any radioactive
12 material to the environment (i.e., not being involved in a vehicular accident). Impacts from these
13 shipments would be from the low levels of radiation that penetrate the shielding provided by
14 unirradiated fuel shipping containers. In the case of unirradiated fuel, the radiation would be
15 from the natural decay of the uranium isotopes. Past studies have determined the largest
16 impacts would occur for shipments made by trucks due to a larger number of shipments that
17 would occur versus rail shipments, and these impacts would also have a larger exposure
18 population due to existing travel densities on U.S. roadways.

19 The number of unirradiated fuel shipments for WASH-1238 (AEC 1972-TN22) and new reactor
20 LWR licensing actions are provided in Table 3-10. This table is broken down by shipments for
21 an initial core loading, the number of annual shipments to support core reloading, and the total
22 number of shipments over the lifetime of the operating license (assumed to be 40 years). For
23 example, the Advanced Passive 1000 (AP1000) fuel shipments would have approximately
24 seven PWR overpacks for each truck shipment.³¹ This results in a mass loading of
25 approximately 3.8 MTU per truck shipment. It is anticipated that for an MSR, unirradiated fuel
26 would be shipped in the form of UF₆. For low-enriched UF₆, a standard truck loading is six
27 Type 30B cylinders per truck (USEC 1999-TN6515) for approximately 9.3 MTU per truck. To
28 have the equivalent MTU as the PWR unirradiated fuel shipment would require about three
29 Type 30B cylinders per truck. Assuming equal uranium requirements, this would reduce the
30 number of unirradiated fuel shipments required for an MSR by about 50 percent compared to a
31 large LWR.

32 The radiological impacts provided in WASH-1238 (AEC 1972-TN22) and the previous new
33 reactor EISs, as shown in Table 3-11, were based on annual exposures from the expected
34 number of shipments over a year as normalized to 1,100 MW(e) (or 880 MW(e) net electrical
35 output). Another factor to consider when extending this analysis to new reactors is the
36 assumption applied in WASH-1238 and in the staff’s analysis of new reactor unirradiated fuel
37 shipments that the radiation dose rate at 3.3 ft from the transport vehicle is about 0.1 mrem/hr.
38 This assumption should also be reasonable for new reactors that use HALEU fuel because the
39 HALEU materials would still be low-dose-rate uranium radionuclides and would likely be
40 packaged similarly to those described in WASH-1238 (i.e., inside a metal container that
41 provides little radiation shielding).

³¹ There are 157 fuel assemblies per core loading and 23 initial core loading shipments; therefore, 157/23 ≈ 6.8 rounded to 7 fuel assemblies per shipment.

1 **Table 3-10 Number of Truck Shipments and One-Way Shipping Distances for**
 2 **Unirradiated Fuel**

| Site Name | Number of Shipments Per Site | Number of Shipments Per Site | Number of Shipments Per Site | Number of Shipments Per Site | Number of Shipments Per Site |
|--|------------------------------|------------------------------|------------------------------|--|--------------------------------|
| | Initial Core | Total Reload ^(a) | Total ^(a) | Normalized Annual Shipments ^(b) | One-Way Shipping Distance (km) |
| WASH-1238 (NRC 2006-TN7) | 18 | 234 | 252 | 6.3 | 3,200 |
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | 51 | 780 | 831 | 18.2 | 3,200 |
| Clinton Exelon ESP (NRC 2006-TN672) | 51 | 780 | 831 | 18.2 | 3,200 |
| Grand Gulf ESP (NRC 2006-TN674) | 51 | 780 | 831 | 18.2 | 3,200 |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 23 | 210 | 233 | 5 | 3,200 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | - | - | 298 | 4.4 | 3,200 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | - | - | 372 | 6.6 | 3,200 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | - | - | 233 | 5 | 3,200 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 23 | 210 | 233 | 5 | 1,166 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | - | - | 100 | 1.5 | 3,200 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 38 | 323 | 361 | 5.3 | 3,600 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 23 | 234 | 257 | 6.1 | 3,200 |
| PSEG ESP (NRC 2015-TN6438) | 45 | 300 | 345 | 4.9 | 4,400 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | - | - | 209 | 5 | 3,200 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | - | - | 298 | 4.3 | 4,247 |
| Clinch River ESP (NRC 2019-TN6136) | 36 | 456 | 492 | 15 | 3,944 |
| NUREG-2266 (NRC 2024-TN10333) ^(c) | - | - | - | 5 | 5,129 |

(a) Total shipments of unirradiated fuel over a 40-year plant lifetime.
 (b) Normalized to Reference LWR (880 MW(e) net).
 (c) Largest annual impact for an existing LWR from NUREG-2266 Table 3-6 (NRC 2024-TN10333).

3

1 **Table 3-11 Radiological Impacts Under Normal Conditions of Transporting Unirradiated**
 2 **Fuel from WASH-1238 and New Reactor Sites**

| Site Name | Annual Total One-Way Shipment Distance ^(a) (km) | Population Impacts (person-rem/yr) ^(b) Workers | Population Impacts (person-rem/yr) ^(b) Public Onlookers | Population Impacts (person-rem/yr) ^(b) Public Along Route |
|--|--|---|--|--|
| WASH-1238 (NRC 2006-TN7) | 20,160 | 0.011 | 0.042 | 0.0010 |
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | 58,240 | 0.031 | 0.12 | 0.0029 |
| Clinton Exelon ESP (NRC 2006-TN672) | 58,240 | 0.031 | 0.12 | 0.0029 |
| Grand Gulf ESP (NRC 2006-TN674) | 58,240 | 0.031 | 0.12 | 0.0029 |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 16,000 | 0.0085 | 0.015 | 0.00021 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 14,080 | 0.0076 | 0.016 | 0.00023 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 21,120 | 0.011 | 0.024 | 0.00033 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 16,000 | 0.0085 | 0.018 | 0.00025 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 5,830 | 0.0031 | 0.0076 | 0.00029 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 4,800 | 0.0041 | 0.0071 | 0.000043 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 19,080 | 0.010 | 0.018 | 0.00018 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 19,520 | 0.012 | 0.021 | 0.00029 |
| PSEG ESP (NRC 2015-TN6438) | 21,560 | 0.0071 | 0.016 | 0.00047 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 16,000 | 0.0090 | 0.018 | 0.00025 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 18,262 | 0.0098 | 0.038 | 0.00067 |
| Clinch River ESP (NRC 2019-TN6136) | 59,160 | 0.0078 | 0.044 | 0.0012 |
| NUREG-2266 (NRC 2024-TN10333) ^(c) | 25,645 | 0.0634 | 0.340 | 0.0013 |
| Maximum Estimate | 59,160 | 0.0634 | 0.340 | 0.0029 |

(a) The total shipment distance is based on the number of annual shipments multiplied by the shipping distance.
 (b) Normalized to Reference LWR (880 MW(e) net).
 (c) Largest annual impact for an existing LWR from NUREG-2266 Table 3-6 (NRC 2024-TN10333).

3 The one-way distances should also be bounding for unirradiated HALEU fuel shipments
 4 because the existing fuel fabrication facility locations would still be expected to fabricate HALEU
 5 fuel. Additionally, the distances from enrichment facilities to an MSR site for HALEU UF₆
 6 shipments should also be within these one-way distances.

1 3.15.1.7.2 *Transportation Accidents*

2 Accident risks are a combination of accident frequency and consequence. Accident frequencies
3 for transportation of unirradiated fuel are expected to be lower than those used in the analysis in
4 WASH-1238 (AEC 1972-TN22). This is based on the NRC staff evaluations in previous new
5 reactor EISs where the NRC staff identified the trends in improvements in highway safety and
6 security, and an overall reduction in traffic accident, injury, and fatality rates since WASH-1238
7 was published. Although packages for all types of new reactor unirradiated fuel have not been
8 designed or certified by the NRC, these packages must comply with the packaging
9 requirements contained in 10 CFR Part 71 (TN301) and, for this reason, the impacts of
10 radiological accidents during transport of unirradiated fuel to a new reactor are expected to be
11 smaller than those listed in Table S-4 in 10 CFR 51.52 (TN250).

12 Nonradiological impacts are the human health impacts projected to result from traffic accidents
13 involving shipments of unirradiated fuel to the new reactor site (i.e., the analysis does not
14 consider the radiological or hazardous characteristics of the cargo). Nonradiological impacts
15 include the projected number of traffic accidents, injuries, and fatalities that could result from
16 shipments of unirradiated fuel to the site and return shipments of empty containers from the site.
17 The methodology for determining the nonradiological impacts can be found in any of the new
18 reactor EISs, such as in Section 6.2.1.3, Nonradiological Impacts of Transportation Accidents,
19 of the Clinch River ESP Final EIS (NRC 2019-TN6136). This methodology is incorporated by
20 reference in this GEIS. The nonradiological impacts for unirradiated fuel shipment accidents
21 from WASH-1238 (AEC 1972-TN22) and the new reactor EISs are provided in Table 3-12.

22 3.15.1.7.3 *Summary of PPE Values for Transport of Unirradiated New Reactor Fuel*

23 Based on the above information, Table 3-11 and Table 3-12 present the PPE for transport of
24 unirradiated new reactor fuel. This PPE consists of two components:

- 25 • The maximum annual one-way shipment distance (59,160 km) presented below in
26 Table 3-11. The annual shipments associated with the one-way shipment distance have
27 been normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an
28 80 percent capacity factor from WASH-1238.
- 29 • The maximum annual round-trip shipment distance (118,320 km) presented below in
30 Table 3-12. The annual shipments associated with the round-trip shipment distance have
31 been normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an
32 80 percent capacity factor from WASH-1238.

33 The PPE applies to situations where the enrichment of the unirradiated new reactor fuel is
34 20 percent or less, based on the unlimited A_2 value in Table A-1 in 10 CFR Part 71 for
35 unirradiated uranium enriched to 20 percent or less (10 CFR Part 71-TN301). This PPE does
36 not apply to situations in which a new reactor applicant proposes to ship the unirradiated reactor
37 fuel by air, ship, or barge; or in which a new reactor applicant proposes that an unirradiated fuel
38 transportation package for the new reactor be approved using the provisions of 10 CFR 71.12,
39 10 CFR 71.41(c), or 10 CFR 71.41(d), such as might be applied for when shipping a complete
40 unirradiated reactor core.

1

Table 3-12 Nonradiological Impacts of Transporting Unirradiated Fuel

| Site Name | Annual Total Round-Trip Shipment Distance ^(a) (km) | Accidents per Year ^(b) | Injuries per Year ^(b) | Fatalities per Year ^(b) |
|--|---|-----------------------------------|----------------------------------|------------------------------------|
| WASH-1238 (NRC 2006-TN7) | 40,320 | -(c) | -(c) | -(c) |
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | 116,480 | -(c) | -(c) | -(c) |
| Clinton Exelon ESP (NRC 2006-TN672) | 116,480 | -(c) | -(c) | -(c) |
| Grand Gulf ESP (NRC 2006-TN674) | 116,480 | -(c) | -(c) | -(c) |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 32,000 | 0.0090 | 0.0061 | 0.00029 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 28,160 | 0.013 | 0.0066 | 0.00041 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 42,240 | 0.020 | 0.0098 | 0.00061 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 32,000 | 0.015 | 0.0074 | 0.00046 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 11,660 | 0.0069 | 0.0038 | 0.00031 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 9,600 | 0.0026 | 0.0013 | 0.000087 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 38,160 | 0.018 | 0.0089 | 0.00055 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 39,040 | 0.018 | 0.0090 | 0.00056 |
| PSEG ESP (NRC 2015-TN6438) | 43,120 | 0.024 | 0.012 | 0.00072 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 32,000 | 0.015 | 0.0074 | 0.00046 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 36,524 | 0.14 | 0.0086 | 0.00030 |
| Clinch River ESP (NRC 2019-TN6136) | 118,320 | 0.069 | 0.035 | 0.0018 |
| NUREG-2266 (NRC 2024-TN10333) | 51,290 | 0.0138 | 0.00534 | 0.00046 |
| Maximum Estimate | 118,320 | 0.14 | 0.035 | 0.0018 |

(a) The total shipment distance is based on the number of annual shipments multiplied by the round-trip shipping distance. The round-trip distance is used because nonradiological vehicle accident impacts could occur on the return trip.

(b) Normalized to Reference LWR (880 MW(e) net).

(c) Not analyzed.

Largest annual impact for an existing LWR from NUREG-2266 Table 3-8 (NRC 2024-TN10333).

2 3.15.1.8 Transportation of Radioactive Waste from New Reactors

3 As discussed in Section 3.10 of this GEIS, radioactive waste can consist of a variety of
4 materials with radioactivity levels from just above background radiation levels found in nature to
5 very high radioactivity in certain cases. While SNF is also radioactive waste, it is classified as
6 high-level radioactive waste, or HLW, and will be discussed in Section 3.15.1.8. This section
7 assesses the LLRW generated at a new reactor site that would be stored onsite, either until it
8 has decayed away and can be disposed of as ordinary trash, or until amounts are large enough
9 for shipment to a LLRW disposal site in packages authorized by the DOT (e.g., Type A
10 packages) or approved by the NRC (e.g., Type B transport packages).

1 The characteristics of radioactive waste from new reactors are expected to be the same as
2 those of the radioactive waste generated by the current LWR fleet. Because of the design, size,
3 and the nature of the potential operations at a new reactor, the amount of LLRW likely to be
4 generated annually by a new reactor could be noticeably less than that generated by the current
5 LWRs.

6 The staff has assessed LLRW shipment impacts as part of the environmental review of new
7 reactor ESP and COL applications relative to the annual LLRW shipments shown in Table 3-13.
8 As noted on the NRC website for LLRW disposal (NRC 2020-TN6516), there are four existing
9 commercial LLRW disposal facilities in the United States that accept various classes of LLRW.³²
10 All are in Agreement States. The Low-Level Radioactive Waste Policy Amendments Act of 1985
11 (Public Law 99–240, 99 Stat. 1842; TN6517) gave the States responsibility for the disposal of
12 their LLRW. The Act encouraged the States to enter into compacts that would allow them to
13 dispose of waste at a common disposal facility. Two LLRW disposal facilities only accept wastes
14 from within their Compact. Two other LLRW disposal facilities could accept LLRW regardless of
15 the location of the LLRW generator. One LLRW disposal site will accept Class A LLRW and
16 another LLRW disposal site will accept Class A, B, and C LLRW. Energy *Solutions* Clive
17 Operations, located in Clive, Utah, accepts waste from all regions of the United States. Clive is
18 licensed by the State of Utah for Class A waste only (NRC 2017-TN6518). WCS, LLC, located
19 near Andrews, Texas, accepts waste from the Texas Compact generators and outside
20 generators with permission from the Compact. WCS is licensed by the State of Texas to
21 dispose of Class A, B, and C waste. For the new reactor LLRW transportation impacts, the staff
22 selected the Energy *Solutions* or the WCS LLRW disposal facility if the location was not in a
23 Compact with one of the other two LLRW disposal facilities.

24 The DOE’s Manifest Information Management System (MIMS) is a database used to monitor
25 the management of commercial LLRW in the United States (DOE 2024-TN10120). The LLRW
26 information in MIMS is derived from manifests for waste shipments to one closed and four
27 operating commercial LLRW disposal facilities. MIMS information for the most recent five years
28 for available data (i.e., 2019 to 2023) was compiled for the four commercial LLRW disposal
29 facilities by the different classes of LLRW. Table 3-14 provides the breakdown to each LLRW
30 disposal facility by volume and Table 3-15 does so by activity.

31 As can be seen in a comparison of annual waste volumes in Table 3-13 and Table 3-14, all of
32 the LWR waste streams are a small fraction of the median annual total volumes for the last
33 5 years of data. The annual curie content of the LLRW from new reactors is also expected to be
34 small fraction of the median annual total as provided in Table 3-15.

³² The classes of LLRW are defined under 10 CFR 61.55, “Waste classification” (10 CFR Part 61-TN252).

1 **Table 3-13 Summary of Radioactive Waste Shipments and One-Way Shipping**
 2 **Distances**

| Site Name | Annual Waste Generation per Unit (m ³ /yr-unit) | Number of Radioactive Waste Shipments ^(a) | One-Way Shipping Distance (km) |
|--|--|--|--------------------------------|
| WASH-1238 (NRC 2006-TN7) | 108 | 46 | .. ^(b) |
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | 168 | 51 | .. ^(b) |
| Clinton Exelon ESP (NRC 2006-TN672) | 168 | 51 | .. ^(b) |
| Grand Gulf ESP (NRC 2006-TN674) | 168 | 51 | .. ^(b) |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 56 | 21 | 800 |
| Calvert Cliffs COL (NRC 2011-TN1980) | 208 | 9 | 800 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 99 | 31 | 800 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 56 | 21 | 800 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 56 | 21 | 800 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 433 | 109 | 800 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 449 | 114 | 800 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 56 | 21 | 800 |
| PSEG ESP (NRC 2015-TN6438) | 432.7 | 105.4 | 1110 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 56 | 23 | 800 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 208 | 52 | 800 |
| Clinch River ESP (NRC 2019-TN6136) | 142 | 75 | 1954.3 |

(a) The number of shipments was calculated assuming the average waste shipment capacity of 2.34 m³ (82.6ft³) per shipment applied in WASH-1238 (AEC 1972-TN22) (108 m³/yr divided by 46 shipments/year yields 2.34 m³ per shipment). The number of shipments was also normalized to 880 MW(e).

(b) Not analyzed.

Table 3-14 Low-Level Radioactive Waste by Volume

| Year | Class A Volume (m³) | Class B Volume (m³) | Class C Volume (m³) | Total Volume (m³) |
|----------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|-------------------------------------|
| Barnwell | | | | |
| 2023 | 236.9 | 34.1 | 23.5 | 294.5 |
| 2022 | 156.9 | 23.8 | 18.4 | 199.1 |
| 2021 | 397.0 | 21.1 | 10.2 | 428.3 |
| 2020 | 836.1 | 48.4 | 6.8 | 891.4 |
| 2019 | 246.5 | 39.3 | 19.1 | 305.0 |
| Median | 246.5 | 34.1 | 18.4 | 305.0 |
| Energy Solutions | | | | |
| 2023 | 91,823.0 | 0.0 | 0.0 | 91,823.0 |
| 2022 | 63,994.8 | 0.0 | 0.0 | 63,994.8 |
| 2021 | 25,185.5 | 0.0 | 0.0 | 25,185.5 |
| 2020 | 27,805.3 | 0.0 | 0.0 | 27,805.3 |
| 2019 | 118,516.4 | 0.0 | 0.0 | 118,516.4 |
| Median | 63,994.8 | 0.0 | 0.0 | 63,994.8 |
| Richland | | | | |
| 2023 | 334.7 | 3.8 | 0.0 | 399.0 |
| 2022 | 734.4 | 3.4 | 0.0 | 755.5 |
| 2021 | 512.9 | 6.0 | 0.0 | 566.4 |
| 2020 | 371.2 | 3.6 | 0.0 | 433.0 |
| 2019 | 493.1 | 0.0 | 0.0 | 592.3 |
| Median | 493.1 | 3.6 | 0.0 | 566.4 |
| Waste Control Specialists | | | | |
| 2023 | 769.7 | 140.3 | 47.5 | 957.4 |
| 2022 | 706.1 | 113.5 | 66.4 | 886.0 |
| 2021 | 624.8 | 123.8 | 47.0 | 795.6 |
| 2020 | 803.1 | 57.9 | 32.7 | 893.7 |
| 2019 | 756.6 | 104.2 | 49.7 | 910.4 |
| Median | 756.6 | 113.5 | 47.5 | 893.7 |
| Annual Total | | | | |
| 2023 | 93,164.2 | 178.2 | 70.9 | 93,473.9 |
| 2022 | 65,592.2 | 140.8 | 84.8 | 65,835.4 |
| 2021 | 26,720.2 | 150.9 | 57.2 | 26,975.9 |
| 2020 | 29,815.7 | 110.0 | 39.5 | 30,023.3 |
| 2019 | 120,012.6 | 143.5 | 68.8 | 120,324.3 |
| Median | 65,592.2 | 143.5 | 68.8 | 65,835.4 |

Note: Original units were cubic feet. Cubic feet were converted to cubic meters by multiplying by 0.0283 m³/ft³.

Source: DOE 2024-TN10120.

Table 3-15 Low-Level Radioactive Waste by Activity

| Year | Activity Class A (curies) | Activity Class B (curies) | Activity Class C (curies) | Total Activity (curies) |
|----------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|------------------------------------|
| Barnwell | | | | |
| 2023 | 187.46 | 475.31 | 12,870.47 | 13,533.24 |
| 2022 | 114.58 | 499.60 | 29,134.89 | 29,749.07 |
| 2021 | 133.27 | 743.96 | 46.57 | 923.80 |
| 2020 | 160.02 | 464.81 | 18.28 | 643.11 |
| 2019 | 251.90 | 3,315.23 | 26,986.16 | 30,553.29 |
| Median | 160.02 | 499.60 | 12,870.47 | 13,533.24 |
| Energy Solutions | | | | |
| 2023 | 6,339.55 | 0.00 | 0.00 | 6,339.55 |
| 2022 | 6,969.43 | 0.00 | 0.00 | 6,969.43 |
| 2021 | 6,368.76 | 0.00 | 0.00 | 6,368.76 |
| 2020 | 15,608.41 | 0.00 | 0.00 | 15,608.41 |
| 2019 | 9,553.56 | 0.00 | 0.00 | 9,553.56 |
| Median | 6,969.43 | 0.00 | 0.00 | 6,969.43 |
| Richland | | | | |
| 2023 | 407.34 | 604.93 | 0.00 | 1,017.40 |
| 2022 | 324.16 | 724.76 | 0.00 | 1,048.93 |
| 2021 | 265.51 | 6,321.28 | 0.00 | 6,589.54 |
| 2020 | 999.90 | 7,861.04 | 0.00 | 9,235.54 |
| 2019 | 658.32 | 0.00 | 0.00 | 669.66 |
| Median | 407.34 | 724.76 | 0.00 | 1,048.93 |
| Waste Control Specialists | | | | |
| 2023 | 888.36 | 3,711.31 | 147,140.44 | 151,740.11 |
| 2022 | 979.88 | 4,953.42 | 110,591.00 | 116,524.30 |
| 2021 | 806.38 | 7,681.52 | 98,842.64 | 107,330.54 |
| 2020 | 1,156.49 | 3,081.13 | 19,695.26 | 23,932.89 |
| 2019 | 723.33 | 4,935.57 | 88,333.14 | 93,992.05 |
| Median | 888.36 | 4,935.57 | 98,842.64 | 107,330.54 |
| Annual Total | | | | |
| 2023 | 7,822.71 | 4,791.54 | 160,010.91 | 172,630.29 |
| 2022 | 8,388.05 | 6,177.78 | 139,725.89 | 154,291.74 |
| 2021 | 7,573.93 | 14,746.76 | 98,889.21 | 121,212.65 |
| 2020 | 17,924.83 | 11,406.99 | 19,713.54 | 49,419.95 |
| 2019 | 11,187.11 | 8,250.80 | 115,319.30 | 134,768.56 |
| Median | 8,388.05 | 8,250.81 | 115,319.30 | 134,768.55 |

Source: DOE 2024-TN10120.

1 3.15.1.8.1 Summary of PPE Values for Transport of Radioactive Waste from New Reactors

2 In NUREG-0170, *Final Environmental Statement on the Transportation of Radioactive Material*
3 *by Air and Other Modes* (NRC 1977-TN417, NRC 1977-TN6497), the NRC evaluated the
4 shipment of radioactive material, including shipments of unirradiated fuel, SNF, and radioactive
5 waste to and from nuclear power plants. The NRC concluded in NUREG-0170 that the average
6 radiation dose to the population at risk from normal transportation is a small fraction of the limits
7 recommended for members of the general public from all sources of radiation other than natural
8 and medical sources and is a small fraction of the natural background dose. In addition, the
9 NRC determined that the radiological risk from accidents in transportation is small, amounting to
10 about 0.5 percent of the normal transportation risk on an annual basis. The NRC also
11 determined in NUREG-0170 that the environmental impacts of normal transportation of
12 radioactive materials and the risks attendant to accidents involving radioactive material
13 shipments are sufficiently small to allow continued shipments by all modes. The doses from
14 radioactive waste accidents were negligible when compared to the doses from accidents
15 involving spent fuel shipments.

16 Previous LWR ESP and COL environmental analyses of the nonradiological impacts from
17 accidents involving the transportation of LLRW (injuries and death from physical collisions
18 involving truck LLRW shipments) have shown the risks to be low and the environmental impact
19 finding was SMALL. The results from these environmental analyses are shown in Table 3-16.
20 There is uncertainty as to the design of new reactors and how that relates to the generation of
21 LLRW; most designs are expected to generate lower volumes of LLRW than LWRs due to their
22 having less complex systems, structures, and components. This should result in a much lower
23 number of annual LLRW shipments but will depend on the capacity of the onsite radiological
24 waste storage building.

25 Based on the above information, Table 3-16 presents the PPE for transport of radioactive waste
26 from new reactors. This PPE consists of one component:

27 The maximum annual round-trip shipment distance (293,145 km) presented below in
28 Table 3-16. The annual shipments associated with the round-trip shipment distance have been
29 normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent
30 capacity factor and a shipment volume of 2.34 m³/shipment from WASH-1238.

31 This PPE does not apply to situations where a new reactor applicant proposes shipping the
32 reactor's radioactive waste by air, ship, or barge; or where a new reactor applicant proposes
33 that a radioactive waste transportation package for the new reactor be approved using the
34 provisions of 10 CFR 71.12, 10 CFR 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301).

1 **Table 3-16 Annual Nonradiological Impacts of Transporting Waste from the Site**

| Site Name | Annual Total Round-Trip Shipment Distance ^(a,b) (km) | Accidents per Year ^(b) | Injuries per Year ^(b) | Fatalities per Year ^(b) |
|--|---|-----------------------------------|----------------------------------|------------------------------------|
| WASH-1238 (NRC 2006-TN7) | — ^(c) | — ^(c) | — ^(c) | — ^(c) |
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | — ^(c) | — ^(c) | — ^(c) | — ^(c) |
| Clinton Exelon ESP (NRC 2006-TN672) | — ^(c) | — ^(c) | — ^(c) | — ^(c) |
| Grand Gulf ESP (NRC 2006-TN674) | — ^(c) | — ^(c) | — ^(c) | — ^(c) |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 33,600 | 0.0095 | 0.0065 | 0.00031 |
| Calvert Cliffs COL (NRC 2011-TN1980) | 14,400 | 0.0067 | 0.0033 | 0.00021 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 49,600 | 0.023 | 0.011 | 0.00072 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 33,600 | 0.016 | 0.0078 | 0.00049 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 33,600 | 0.016 | 0.0078 | 0.00049 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 174,400 | 0.077 | 0.040 | 0.0026 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 182,400 | 0.085 | 0.042 | 0.0026 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 33,600 | 0.016 | 0.0078 | 0.00049 |
| PSEG ESP (NRC 2015-TN6438) | 233,988 | 0.17 | 0.097 | 0.0060 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 36,800 | 0.017 | 0.0085 | 0.00053 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 83,200 | 0.076 | 0.0045 | 0.00016 |
| Clinch River ESP (NRC 2019-TN6136) | 293,145 | 0.17 | 0.11 | 0.0049 |
| Maximum Estimate | 293,145 | 0.17 | 0.11 | 0.0060 |

(a) The total shipment distance is based on the number of annual shipments multiplied by the round-trip shipping distance. The round-trip distance is used because nonradiological vehicle accident impacts could occur on the return trip.

(b) In determining the round-trip shipment-km, accidents per year, injuries per year, and fatalities per year, the number of shipments was calculated assuming the average waste shipment capacity of 2.34 m³ (82.6 ft³) per shipment applied in WASH-1238 (AEC 1972-TN22) (108 m³/yr divided by 46 shipments/year yields 2.34 m³ per shipment). The number of shipments was also normalized to 880 MW(e).

(c) Not analyzed.

2 **3.15.1.9 Transportation of SNF from New Reactors**

3 This section discusses the radiological and nonradiological environmental impacts from the
 4 potential shipments of SNF for normal operating, or incident-free conditions and transportation
 5 accidents. For the previous new reactor EISs, the staff performed an independent analysis of
 6 the environmental impacts of transporting spent fuel from the proposed and alternative sites to a
 7 spent fuel disposal repository. The staff has also performed an independent analysis for the
 8 transportation of SNF to a private ISFSI and two Consolidated Interim Storage Facilities (CISFs)
 9 for SNF and HLW, as published in three EISs (NRC 2001-TN6514, NRC 2021-TN10124, NRC
 10 2022-TN10125).

1 For the purposes of these new reactor transportation analyses, the NRC staff considered the
2 proposed Yucca Mountain site in Nevada as a surrogate destination. The NRC has not made a
3 licensing decision about the DOE application for the proposed geologic repository at Yucca
4 Mountain. However, the NRC staff considers an estimate of the impacts of the transportation of
5 spent fuel to a possible repository in Nevada to be a reasonable bounding estimate of the
6 transportation impacts on a spent fuel interim storage or disposal facility because of the
7 distances involved and the representativeness of the distribution of members of the public in
8 urban, suburban, and rural areas (i.e., population distributions) along the shipping routes. In
9 addition, as noted in Section 3.15.1.3, Additional NRC Information Sources, the new reactor
10 transportation analyses using truck shipments of 0.5 MTU were normalized with respect to
11 power level and shipment quantities to allow a comparison to the results presented in Table S-4
12 of 10 CFR 51.52 (TN250). The results of the new reactor transportation analyses for SNF as
13 normalized for comparison to Table S-4 are provided in Table 3-17, Table 3-18, and Table 3-19,
14 for incident-free SNF impacts, radiological accident SNF impacts, and nonradiological accident
15 SNF impacts, respectively.

16 For the licensing action of the Private Fuel Storage Facility (PFSF) ISFSI, the staff analyzed the
17 human health impacts from the transportation of SNF in NUREG-1714, (NRC 2001-TN6514).
18 Section 5.7, Human Health Impacts of SNF Transportation, discusses the radiological and
19 nonradiological human health impacts associated with transportation of SNF from nuclear power
20 plants to the PFSF. For cross-country transportation to the proposed PFSF, only shipments by
21 rail are analyzed because Private Fuel Storage planned to receive only rail transportation
22 packages under its NRC license with the potential for short travel distances by heavy-haul
23 trucks or by barges when necessary. Based on the results of the transportation analysis, the
24 staff found that annual and cumulative radiological impacts of transporting SNF to the proposed
25 PFSF would be small. Also, the analytical results for transportation of SNF to and from the
26 proposed PFSF are consistent with earlier analyses of SNF risks reported in NUREG-0170
27 (NRC 1977-TN417, NRC 1977-TN6497).

28 In the CISF EISs, the staff estimated the potential radiological impacts on workers and the
29 public from the proposed rail transportation of SNF from nuclear power plants and ISFSIs to the
30 proposed CISF based on prior NRC transportation risk estimates in NUREG-2125, *Spent Fuel*
31 *Transportation Risk Assessment* (NRC 2014-TN3231). In the NUREG-2125 analysis, the staff
32 performed a transportation risk assessment to calculate worker and public doses and risks from
33 the transportation of SNF along various representative national routes under incident-free and
34 accident conditions. In that analysis, the staff calculated occupational doses for groups of
35 workers, including rail crew, escorts in transit, and railyard workers, as well as crew and escorts
36 at stops. Because the resulting dose estimates provided in NUREG-2125 were presented for
37 single shipments and for each kilometer traveled and for each hour of transportation, the staff
38 scaled the results by these variables (e.g., number of shipments, distance, and time) to
39 generate estimates that were applicable to the proposed CISF projects. The staff selected a
40 representative route that was bounding for the proposed shipments of SNF to the proposed
41 CISF and scaled the calculated doses to match the number of proposed shipments and, as
42 applicable, the shipment distance and time.

1 **Table 3-17 Incident-Free Radiological Impacts for Shipping Spent Nuclear Fuel to the**
 2 **Yucca Mountain Site**

| Site Name | Annual Shipments ^(a) | Shipping Distance (km) | Annual Total One-Way Shipment Distance ^(a) (km) | Population Impacts (person-rem/yr) ^(b) | | |
|--|---------------------------------|------------------------|--|---|------------------|--------------------|
| | | | | Workers | Public Onlookers | Public Along Route |
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | 90 | 4,410 | 396,900 | 9.2 | 32 | 0.82 |
| Clinton Exelon ESP (NRC 2006-TN672) | 90 | 3,076 | 276,840 | 6.4 | 22 | 0.41 |
| Grand Gulf ESP (NRC 2006-TN674) | 90 | 3,718 | 334,620 | 7.8 | 25 | 0.62 |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 40 | 4,091 | 163,640 | 7.3 | 13 | 0.38 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 46 | 4,568 | 210,128 | 9.4 | 19 | 0.53 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 60 | 2,922 | 175,320 | 8.0 | 17 | 0.37 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 46 | 4,096 | 188,416 | 7.4 | 15 | 0.35 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 40 | 4,520 | 180,800 | 8.2 | 20 | 0.42 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 9.5 | 2,568 | 24,396 | 2.0 | 0.37 | 0.11 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 40.3 | 3,481 | 140,284 | 6.4 | 13 | 0.25 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 39 | 4,041 | 157,599 | 7.5 | 13 | 0.37 |
| PSEG ESP (NRC 2015-TN6438) | 54.5 | 4,470 | 243,615 | 11 | 23 | 0.63 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 60 | 4,977 | 298,620 | 9.9 | 18 | 0.59 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 44 | 4,090 | 179,960 | 4.3 | 14 | 0.35 |
| Clinch River ESP (NRC 2019-TN6136) | 137 | 3,689 | 505,393 | 2.8 | 50 | 0.97 |
| NUREG-2266 (NRC 2024-TN10333) ^(c) | 78 | 4,458 | 347,724 | 4.4 | 11.4 | 0.637 |
| Maximum Estimate | - | - | 505,393 | 11 | 50 | 0.97 |

(a) The total shipment distance is based on the number of annual shipments multiplied by the shipping distance.

(b) Normalized to Reference LWR (880 MW(e) net).

(c) Largest annual impact for an existing LWR from NUREG-2266 Table 3-10 (NRC 2024-TN10333).

1 **Table 3-18 Radiological Accident Impacts for Shipping Spent Nuclear Fuel to the**
 2 **Yucca Mountain Site**

| Site Name | Annual Shipments ^(a) | Shipping Distance (km) | Annual Total One-Way Shipment Distance ^(a) (km) | Population Impacts (person-rem/yr) ^(b) | Burnup (GWd/MTU) |
|--|---------------------------------|------------------------|--|---|---|
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | 90 | 4,410 | 396,900 | 5.00E-04 ^(c) | 62 (LWRs) ^(d) 133 (TRISO) |
| Clinton Exelon ESP (NRC 2006-TN672) | 90 | 3,076 | 276,840 | 2.30E-04 ^(c) | 62 (LWRs) ^(d) 133 (TRISO) |
| Grand Gulf ESP (NRC 2006-TN674) | 90 | 3,718 | 334,620 | 4.10E-04 ^(c) | 62 (LWRs) ^(d) 133 (TRISO) |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 40 | 4,091 | 163,640 | 2.20E-05 | 62 (LWR) ^(d) |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 46 | 4,568 | 210,128 | 8.40E-05 | 52 (LWR) |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 60 | 2,922 | 175,320 | 1.50E-04 | 32.3 (LWR) |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 46 | 4,096 | 188,416 | 1.80E-05 | 50.5 (LWR) |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 40 | 4,520 | 180,800 | 9.20E-05 | 62 (LWR) ^(d) |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 9.5 | 2,568 | 24,396 | 5.90E-05 | 46.2 (LWR) |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 40.3 | 3,481 | 140,284 | 3.10E-06 | 46 (LWR) |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 39 | 4,041 | 157,599 | 7.10E-05 | 62 (LWR) |
| PSEG ESP (NRC 2015-TN6438) | 54.5 | 4,470 | 243,615 | 2.00E-04 | 54.2 (LWR) |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 60 | 4,977 | 298,620 | 5.20E-05 | 50.5 (LWR) |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 44 | 4,090 | 179,960 | 1.28E-04 | 52 (LWR) |
| Clinch River ESP (NRC 2019-TN6136) | 137 | 3,689 | 505,393 | 7.50E-06 | 51 (LWR) |
| NUREG-2266 (NRC 2024-TN10333) ^(e) | 45 | 4,252 | 191,340 | 2.96E-05 | 80 (LWR) |
| Maximum Estimate | - | - | 505,393 | 5.00E-04 | 80 (LWRs) ^(d) 133 (TRISO) |

(a) The total shipment distance is based on the number of annual shipments multiplied by the shipping distance.

(b) Normalized to Reference LWR (880 MW(e) net).

(c) Maximum population impact if multiple reactor types evaluated.

(d) Peak rod burnup.

(e) Largest annual impact for an existing LWR from NUREG-2266 Table 3-14 (NRC 2024-TN10333).

1 **Table 3-19 Nonradiological Accident Impacts for Shipping Spent Nuclear Fuel to the**
 2 **Yucca Mountain Site**

| Site Name | Annual Shipments ^(a) | Shipping Distance (km) | Annual Total Round-Trip Shipment Distance (km) ^(a) | Accidents per Year ^(b) | Injuries per Year ^(b) | Fatalities per Year ^(b) |
|--|---------------------------------|------------------------|---|-----------------------------------|----------------------------------|------------------------------------|
| North Anna Power Station Unit 3 ESP (NRC 2006-TN7) | 90 | 4,410 | 793,800 | -(c) | -(c) | -(c) |
| Clinton Exelon ESP (NRC 2006-TN672) | 90 | 3,076 | 553,680 | -(c) | -(c) | -(c) |
| Grand Gulf ESP (NRC 2006-TN674) | 90 | 3,718 | 669,240 | -(c) | -(c) | -(c) |
| Vogtle Units 3 and 4 ESP (NRC 2008-TN673) | 40 | 4,091 | 327,280 | 0.081 | 0.067 | 0.0036 |
| Calvert Cliffs Unit 3 COL (NRC 2011-TN1980) | 46 | 4,568 | 420,256 | 0.16 | 0.099 | 0.0076 |
| South Texas Units 3 and 4 COL (NRC 2011-TN1722) | 60 | 2,922 | 350,640 | 0.20 | 0.13 | 0.0062 |
| Virgil C. Summer Units 2 and 3 COL (NRC 2011-TN1723) | 46 | 4,096 | 376,832 | 0.11 | 0.071 | 0.0056 |
| Levy Units 1 and 2 COL (NRC 2012-TN1976) | 40 | 4,520 | 361,600 | 0.15 | 0.087 | 0.0062 |
| Comanche Peak Units 3 and 4 COL (NRC 2011-TN6437) | 9.5 | 2,568 | 48,792 | 0.011 | 0.062 | 0.0042 |
| Enrico Fermi Unit 3 COL (NRC 2013-TN6436) | 40.3 | 3,481 | 280,569 | 0.15 | 0.068 | 0.0046 |
| William States Lee Units 1 and 2 COL (NRC 2013-TN6435) | 39 | 4,041 | 315,198 | 0.11 | 0.072 | 0.0056 |
| PSEG ESP (NRC 2015-TN6438) | 54.5 | 4,470 | 487,230 | 0.28 | 0.13 | 0.0080 |
| Turkey Point Units 6 and 7 COL (NRC 2016-TN6434) | 60 | 4,977 | 597,240 | 0.15 | 0.098 | 0.0068 |
| Bell Bend COL (NRC and USACE 2016-TN6562) | 44 | 4,090 | 359,920 | 0.33 | 0.019 | 0.00067 |
| Clinch River ESP (NRC 2019-TN6136) | 137 | 3,689 | 1,010,786 | 0.32 | 0.21 | 0.016 |
| NUREG-2266 (NRC 2024-TN10333) ^(c) | 78 | 4,252 | 331,656 | 0.211 | 0.093 | 0.0077 |
| Maximum Estimate | - | - | 1,010,786 | 0.33 | 0.21 | 0.016 |

(a) The total shipment distance is based on the number of annual shipments multiplied by the round-trip shipping distance. The round-trip distance is used because nonradiological vehicle accident impacts could occur on the return trip.

(b) Normalized to Reference LWR (880 MW(e) net).

(c) Not analyzed.

(d) Largest annual impact for an existing LWR from NUREG-2266 Table 3-16 (NRC 2024-TN10333).

1 3.15.1.9.1 Differences between Truck and Rail Transportation Modes

2 Several differences between the truck and rail transportation modes should be considered when
3 selecting the transportation mode for assessing the impacts of transporting new reactor SNF.
4 First, there is a significant difference in the MTU load that can be carried by each. Truck
5 shipments are likely not to contain more than approximately 2 MTU (e.g., 4 PWR SNF
6 assemblies) where 0.5 MTU has been applied in previous staff analyses for a comparison to
7 Table S-4. Rail transportation packages could contain upwards of approximately 18.5 MTU
8 (e.g., 37 PWR SNF assemblies) (NRC 2020-TN6683, NRC 2018-TN6685). Thus, for a set MTU
9 quantity of new reactor SNF, fewer numbers of shipments are necessary for the rail mode.

10 The rail mode would likely involve less radiation exposure to members of the public because
11 people traveling on roads would be next to truck shipments and there is generally a buffer zone
12 on each side of the rail right-of-way going through residential neighborhoods. There are also
13 access limitations for the shipment of SNF by rail. It is not certain that all new reactor sites
14 would have rail access. Thus, some portion of the transportation route may have to be
15 performed using heavy-haul trucks for rail shipments. Such heavy-haul truck shipments are
16 expected to be heavily monitored and controlled resulting in low to negligible impacts on
17 members of the public.

18 Therefore, it is expected that truck shipments would have larger incident-free impacts than rail
19 shipments due to the larger number of shipments (e.g., as much as 37 times—0.5 MTU versus
20 18.5 MTU) and due to the greater potential for radiation exposure to members of the public. In
21 addition, 49 CFR 397.101 (49 CFR Part 397-TN6621) requires that placarded radioactive
22 material shipments made by truck are operated on routes that minimize radiological risks.
23 Similarly, 49 CFR 172.820 requires that rail routes for highway-route-controlled quantities of
24 radioactive material consider factors that would also serve to minimize radiological risks (see
25 49 CFR Part 172-TN6616, Appendix D).

26 When considering impacts from transportation accidents, both rail and truck packages have a
27 very low probability of a radioactive release. As stated in the summary for Chapter 3, Cask
28 Response to Impact Accidents, of NUREG-2125 (NRC 2014-TN3231):

29 Detailed FE [finite element] analyses performed for two spent fuel transportation
30 rail casks indicate that casks are very robust structures capable of withstanding
31 almost all impact accidents without release of radioactive material. In fact,
32 when spent fuel is transported within an inner welded canister or in a truck
33 cask, no impacts result in release. Even the rail cask without an inner welded
34 canister can withstand impacts much more severe than the regulatory
35 impact without releasing any material.

36 And with respect to truck packages:

37 Assessment of previous analyses performed for spent fuel truck transportation
38 casks, including impacts onto flat rigid targets, into cylindrical rigid targets, by
39 locomotives, and by falling bridge structures, indicate that truck casks will not
40 release their contents in any impact accidents.

1 Chapter 5, Transportation Accidents, of NUREG-2125 (NRC 2014-TN3231) concluded the
2 overall collective dose risks are very small to negligible for the two types of extra-regulatory
3 accidents (accidents involving a release of radioactive material and loss-of-lead-shielding
4 accidents).

5 For transportation accidents involving severe fires, NUREG/CR-7209 (Fort et al. 2017-TN6692)
6 evaluated four severe roadway and railway fires for their potential impact on spent fuel
7 transportation packages. The analyses found that NRC regulations and packaging standards
8 provide a high degree of protection of public health and safety against releases of radioactive
9 material in real-world transportation accidents involving fires.

10 *3.15.1.9.2 Summary of PPE Values for Transport of Irradiated New Reactor Fuel*

11 Based on the above information, Table 3-17 and Table 3-19 present the PPE for transport of
12 irradiated new reactor fuel. This PPE consists of two components:

13 The maximum annual one-way shipment distance (505,393 km) presented below in Table 3-17.
14 The annual shipments associated with the one-way shipment distance have been normalized to
15 a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor and a
16 shipment capacity of 0.5 MTU/shipment from WASH-1238.

17 The maximum annual round-trip shipment distance (1,010,786 km) presented below in
18 Table 3-19. The annual shipments associated with the round-trip shipment distance have been
19 normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent
20 capacity factor and a shipment capacity of 0.5 MTU/shipment from WASH-1238.

21 Based on the radiological accident impacts presented below in Table 3-18, an additional
22 component is established for the PPE:

- 23 • A maximum peak rod burnup of 80 GWd/MTU for UO₂ fuel and peak pellet burnup of
24 133 GWd/MTU for TRISO fuel.

25 This PPE does not apply to situations where a new reactor applicant proposes shipping the
26 irradiated fuel by air, ship, or barge; or where a new reactor applicant proposes that an
27 irradiated fuel transportation package for the new reactor be approved using the provisions of
28 10 CFR 71.12, 10 CFR 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301), such as might
29 be applied for when shipping an entire irradiated reactor core. In addition, the irradiated new
30 reactor fuel must be shipped in a transportation package that meets all of the applicable NRC
31 regulations.

32 **3.15.2 Transportation Impacts**

33 The NRC staff identified the following three environmental issues associated with the
34 radiological and nonradiological environmental impacts from incident-free transportation and
35 transportation accident conditions:

- 36 • shipment of unirradiated fuel to the new reactor site,
- 37 • shipment of LLRW and mixed waste to offsite disposal facilities, and
- 38 • shipment of SNF to an interim storage facility or a permanent geologic repository.

39 This assessment will draw upon previous analyses for their assumptions, shipment parameters,
40 and routing information and provide a basis that a new reactor applicant could apply for

1 bounding the potential environmental impacts for their non-LWR fuel and waste, given there is a
2 certain amount of uncertainty in transport packaging and processing.

3 A couple of notable conditions in this analysis can be accepted without specific new reactor
4 design information. First, it is likely that new reactor developers will use HALEU fuel with
5 resulting longer refueling cycling times than the 2-year refueling frequencies of LWRs that were
6 assessed in the new reactor EISs. Thus, the number of shipments of fresh fuel to the new
7 reactor site and the potential number of SNF shipments from the site could be significantly less
8 than previously assessed for new reactor LWRs. The previous analyses, whether they used
9 existing certified transport packages or not, were based on a specific quantity of nuclear fuel in
10 each shipment. For example, WASH-1238 (AEC 1972-TN22) assumed a 0.5 MTU per SNF
11 truck shipment. Thus, this is another shipment parameter that could be applied as a bounding
12 value for new reactor fuel shipments.

13 Second, there are a number of unknowns or questions related to several aspects of non-LWR
14 fuel shipments. Prior transportation risk assessments were reviewed for their applicability to
15 support resolution of new reactor fuel transportation issues. In addition, PNNL has prepared a
16 report for the NRC regarding transportation analysis for non-LWR reactor designs (Maheras
17 2020-TN6509). While Section 6.2 in NRC RG 4.2 (NRC 2024-TN7081) provides detailed
18 guidance for how to estimate transportation-related impacts for LWRs, the PNNL report
19 provides additional guidance for estimating transportation-related impacts for non-LWRs in the
20 following areas:

- 21 • applicability of NRC and DOT regulations to the shipment of non-LWR fuel and waste;
- 22 • absence of certified packages for shipping the unirradiated fuel, spent fuel, and radioactive
23 waste associated with non-LWRs;
- 24 • external dose rates associated with the shipment of non-LWR unirradiated fuel, spent fuel,
25 and radioactive waste;
- 26 • transportation routing for non-LWR shipments;
- 27 • chemical and physical forms associated with the non-LWR unirradiated fuel, spent fuel, and
28 radioactive waste;
- 29 • number of shipments associated with unirradiated fuel, spent fuel, and radioactive waste
30 shipments;
- 31 • radionuclide inventory per shipment for non-LWR unirradiated fuel, spent fuel, and
32 radioactive waste;
- 33 • conditional probabilities and release fractions associated with transportation accidents
34 involving non-LWR fuel and waste shipments; and
- 35 • comparison of transportation risk assessment results to various criteria.

36 In addition to the PNNL report (Maheras 2020-TN6509), other transportation analysis
37 documents are discussed for their usefulness to support the environmental conclusions in
38 Section 3.15.1.

39 *3.15.2.1 Transportation of Unirradiated New Reactor Fuel*

40 The staff's evaluation of the transport of unirradiated new reactor fuel focused on incident-free
41 radiological impacts and the nonradiological impacts of transportation accidents. This is a

1 Category 1 issue. If the values and assumptions of the PPE that the transport of unirradiated
2 new reactor fuel will fit within the bounds outlined in Table 3-11 and Table 3-12 in
3 Section 3.15.1.7.1 are met, the impacts can be generically determined to be SMALL and the
4 maximum transportation estimates are as listed in Table 3-11 and Table 3-12. The staff relied
5 on the following PPE values and assumptions to reach this conclusion:

- 6 • The maximum annual one-way shipment distance (59,160 km) presented in Table 3-11. The
7 annual shipments associated with the one-way shipment distance have been normalized to
8 a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor
9 from WASH-1238 (AEC 1972-TN22).
- 10 • The maximum annual round-trip shipment distance (118,320 km) presented in Table 3-12.
11 The annual shipments associated with the round-trip shipment distance have been
12 normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent
13 capacity factor from WASH-1238.

14 This requires that the unirradiated new reactor fuel shipments be normalized to a net electrical
15 output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor from WASH-1238.
16 The PPE applies to situations where the enrichment of the unirradiated new reactor fuel is
17 20 percent or less, based on the unlimited A₂ value in Table A-1 in 10 CFR Part 71 (TN301) for
18 unirradiated uranium enriched to 20 percent or less. In addition, the PPE does not apply to
19 situations in which a new reactor applicant proposes shipping the unirradiated fuel by air, ship,
20 or barge; or in which a new reactor applicant proposes that an unirradiated fuel transportation
21 package for the new reactor be approved using the provisions of 10 CFR 71.12, 10 CFR
22 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301). If these assumptions are not met, a
23 project-specific transportation impact analysis must be performed as part of the new reactor
24 application.

25 Some new reactor designs are anticipated to ship a fully loaded but unirradiated reactor core
26 from a manufacturing facility to an appropriately licensed reactor site. In the case of shipping a
27 new reactor core and its unirradiated contents or any other new reactor unirradiated fuel, in
28 which any of the above conditions are not met, then a project-specific transportation impact
29 analysis must be performed as part of the new reactor application.

30 3.15.2.2 *Transportation of Radioactive Waste from New Reactors*

31 The staff's evaluation of the transport of radioactive waste from new reactors focused on the
32 nonradiological impacts of transportation accidents. This is a Category 1 issue. If the values and
33 assumptions of the PPE that the transport of radioactive waste from a new reactor will fit within
34 the bounds outlined in Table 3-16 in Section 3.15.1.8.1 are met, the impacts can be generically
35 determined to be SMALL and the maximum transportation estimates are as listed in Table 3-16.
36 The staff relied on the following PPE value and assumptions to reach this conclusion:

37 The maximum annual round-trip shipment distance (293,145 km) presented in Table 3-16. The
38 annual shipments associated with the round-trip shipment distance have been normalized to a
39 net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor and a
40 shipment volume of 2.34 m³/shipment from WASH-1238 (AEC 1972-TN22).

41 This requires that the radioactive waste shipments from new reactors be normalized to a net
42 electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor and a
43 shipment volume of 2.34 m³/shipment from WASH-1238 (AEC 1972-TN22). In addition, the PPE
44 does not apply to situations in which a new reactor applicant proposes shipping the radioactive

1 waste by air, ship, or barge; or in which a new reactor applicant proposes that a radioactive
2 waste transportation package for the new reactor be approved using the provisions of 10 CFR
3 71.12, 10 CFR 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301). If these assumptions are
4 not met, a project-specific transportation impact analysis must be performed as part of the new
5 reactor application.

6 3.15.2.3 *Transportation of Irradiated Fuel from New Reactors*

7 The staff's evaluation of the transport of irradiated fuel from new reactors focused on incident-
8 free radiological impacts and the radiological and nonradiological impacts of transportation
9 accidents. This is a Category 1 issue. If the values and assumptions of the PPE that the
10 transport of irradiated new reactor fuel will fit within the bounds outlined in Table 3-17 and
11 Table 3-19 are met, the impacts can be generically determined to be SMALL and the maximum
12 transportation estimates are as listed in Table 3-17, Table 3-18, and Table 3-19. The staff relied
13 on the following PPE values and assumptions to reach this conclusion:

- 14 • The maximum annual one-way shipment distance (505,393 km) presented in Table 3-17.
15 The annual shipments associated with the one-way shipment distance have been
16 normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent
17 capacity factor and a shipment capacity of 0.5 MTU/shipment from WASH-1238.
- 18 • The maximum annual round-trip shipment distance (1,010,786 km) presented in Table 3-19.
19 The annual shipments associated with the round-trip shipment distance have been
20 normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent
21 capacity factor and a shipment capacity of 0.5 MTU/shipment from WASH-1238.
- 22 • A maximum assembly averaged burnup of 80 GWd/MTU for UO₂ fuel and peak pellet
23 burnup of 133 GWd/MTU for TRISO fuel (see Table 3-18).

24 This requires that the irradiated fuel shipments from new reactors be normalized to a net
25 electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor and a
26 shipment capacity of 0.5 MTU/shipment from WASH-1238. The PPE also does not apply to
27 situations in which a new reactor applicant proposes shipping the irradiated fuel by air, ship, or
28 barge; or in which a new reactor applicant proposes that an irradiated fuel transportation
29 package for the new reactor be approved using the provisions of 10 CFR 71.12, 10 CFR
30 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301). In addition, the irradiated new reactor
31 fuel must be shipped in a transportation package that meets all of the applicable NRC
32 regulations. If these assumptions are not met, a project-specific transportation impact analysis
33 must be performed as part of the new reactor application.

34 It is recommended that the transportation analysis be performed in manner to the practicable
35 extent possible to apply impact results from previous NRC or DOE analysis. The basis for
36 applying these prior results must be justified to show that the new reactor SNF characteristics fit
37 within the parameters and assumptions applied in the prior transportation analysis, such as was
38 done for the two CISF EIS transportation analyses (NRC 2021-TN10124, NRC 2022-TN10125).

1 **3.16 Decommissioning**

2 **3.16.1 Baseline Conditions and PPE/SPE Values and Assumptions**

3 At the end of the operating life of a power reactor, NRC regulations require that the nuclear
4 facility undergo decommissioning. The NRC defines decommissioning as the safe removal of a
5 facility from service and the reduction of residual radioactivity to a level that permits termination
6 of the NRC license. The regulations governing decommissioning of power reactors are found in
7 10 CFR 50.75 (TN249), 10 CFR 50.82 (TN249), and 10 CFR 52.110 (TN251). The radiological
8 criteria for termination of the NRC license are in 10 CFR Part 20 (TN283), Subpart E. The
9 requirements for the minimization of contamination and generation of radioactive waste for
10 facility design and procedures for operation are addressed in 10 CFR 20.1406 (TN283).

11 If a new reactor applicant submits an application for an operating license or a COL, or applies
12 for a license to construct a new nuclear power plant, there is a requirement in 10 CFR 50.33
13 (TN249) to provide a report (discussed in 10 CFR 50.75 (TN249), and 10 CFR 52.77 refers
14 back to 10 CFR 50.33) that contains a certification indicating how reasonable assurance will be
15 provided that funds will be available to complete decommissioning of the facility. In addition, the
16 regulations for termination of the license in 10 CFR 50.82(a)(4)(i) (TN249) and 10 CFR
17 52.110(d)(1) (TN251) require the licensee to submit a post-shutdown decommissioning activity
18 report (PSDAR) to the NRC and a copy to the affected State(s) either before or not later than
19 2 years after permanent cessation of operations.

20 The PSDAR must include a description of the licensee's planned decommissioning activities, a
21 schedule for the accomplishment of significant milestones, and an estimate of all expected costs
22 for radiological decommissioning (this does not include site restoration). The PSDAR is
23 sometimes referred to as the licensee's decommissioning plan that provides the
24 decommissioning strategy for the reactor. The PSDAR must contain, among other things, a
25 discussion that provides the reasons for concluding that the environmental impacts associated
26 with project-specific decommissioning activities will be bounded by appropriate previously
27 issued EISs.

28 The PSDAR should also document the results of the licensee's evaluation of the environmental
29 impacts associated with project-specific decommissioning activities. The evaluation should
30 include a comparison of the project-specific environmental impacts of the proposed
31 decommissioning to the impacts identified in previously issued environmental statements, that
32 is, NUREG-0586, Supplement 1, *Generic Environmental Impact Statement on*
33 *Decommissioning of Nuclear Facilities Regarding the Decommissioning of Nuclear Power*
34 *Reactors* (the Decommissioning GEIS) (NRC 2002-TN665), NUREG-1496, Volume 1, *Generic*
35 *Environmental Impact Statement in Support of Rulemaking on Radiological Criteria for License*
36 *Termination of NRC-Licensed Nuclear Facilities* (NRC 1997-TN5455), and any previous
37 project-specific environmental NEPA licensing documents. The NRC will determine whether the
38 licensee's PSDAR contains the information required by the regulation. Although the NRC's
39 approval of the PSDAR is not required, if the NRC determines that the information provided by
40 the licensee in the PSDAR does not comply with the regulatory requirements, it will inform the
41 licensee in writing of the additional information required by the regulations and request a
42 response. The licensee is required to provide updates to the NRC for review if there are any
43 significant changes to the PSDAR.

44 The licensee is required to submit a License Termination Plan application with its final status
45 survey strategy to the NRC at least 2 years before they intend to terminate the license. Before

1 the completion of decommissioning, the licensee conducts a final status survey to demonstrate
2 compliance with criteria established in the License Termination Plan; the License Termination
3 Plan is sometimes referred to in layman's terms as the approved decommissioning plan for
4 power reactors. The NRC may verify the survey by one or more of the following: a quality
5 assurance/quality control review, side-by-side or split sampling of a radiological survey of
6 selected areas, and independent confirmatory surveys. When the NRC confirms that the criteria
7 in the License Termination Plan and all other NRC regulatory requirements have been met, the
8 NRC either terminates or amends the license, depending on the licensee's decision to use the
9 licensed area.

10 The Decommissioning GEIS (NRC 2002-TN665) determined the environmental impacts would
11 be SMALL for the following resource areas, would be limited to operational areas, would not be
12 detectable or destabilizing and are expected to have a negligible effect on the impacts of
13 terminating operations and decommissioning:

- 14 • Onsite Land Use
- 15 • Water Use
- 16 • Water Quality
- 17 • Air Quality
- 18 • Aquatic Ecology within the operational area
- 19 • Terrestrial Ecology within the operational area
- 20 • Radiological
- 21 • Radiological Accidents (non-spent-fuel-related)
- 22 • Occupational Issues
- 23 • Socioeconomic
- 24 • Onsite Cultural and Historic Resources for plants where the disturbance of lands beyond the
25 operational areas is not anticipated
- 26 • Aesthetics
- 27 • Noise
- 28 • Transportation
- 29 • Irretrievable Resource

30 Environmental justice and threatened and endangered species are site-specific issues in the
31 Decommissioning GEIS where a generic environmental impact determination could not be
32 reached. In addition, four other issues also do not have generic environmental impact
33 determinations in the Decommissioning GEIS, including offsite land use and aquatic ecology,
34 terrestrial ecology, and historic and cultural resource activities beyond the operational area.

35 The following two environmental issues were not identified in the Decommissioning GEIS and
36 are assessed in the next section:

- 37 • Nonradiological waste
- 38 • Greenhouse gases

1 **3.16.2 Decommissioning Impacts**

2 This section addresses the potential environmental impacts of the decommissioning of the new
3 reactor facility and the management of SNF that may remain at the site until it is removed and
4 the license is terminated. The continued storage of spent fuel during the period of time past
5 permanent cessation of reactor operations is discussed in Section 3.14.2.6, Storage and
6 Disposal of Radiological Wastes.

7 The NRC staff evaluated the environmental impacts during the decommissioning of nuclear
8 power reactors as residual radioactivity at the site is reduced to levels that allow for termination
9 of the NRC license. This evaluation was documented in the Decommissioning GEIS
10 (NUREG-0586, Supplement 1; NRC 2002-TN665). NUREG-0586, Supplement 1, is
11 incorporated here by reference. The License Renewal GEIS (NUREG-1437 Revision 1,
12 Section 4.12.2 [NRC 2024-TN10161]) references the Decommissioning GEIS and describes the
13 impacts associated with decommissioning existing LWRs (a nuclear facility with a large
14 footprint). This section describes and discusses the environmental consequences of terminating
15 nuclear power plant operations and decommissioning, but the only impacts attributable to the
16 proposed action (license renewal) are the effects of an additional 20 years of operations on the
17 impacts of decommissioning. The majority of the impacts associated with plant operations would
18 cease with reactor shutdown; however, some impacts would remain unchanged, while others
19 would continue at reduced or altered levels. Some new impacts might also result directly from
20 terminating nuclear power plant operations. Section 4.12.2.1, Termination of Operations and
21 Decommissioning of Existing Nuclear Power Plants, of the License Renewal GEIS discusses
22 the various impacts by resource area; some could be quantified as having small impacts, such
23 as radiological impacts, while others could have higher impacts, such as socioeconomics (NRC
24 2024-TN10161). The License Renewal GEIS concluded the following:

25 The effects of license renewal on impacts of terminating nuclear power plant
26 operations and decommissioning are considered a single environmental issue.
27 Because the impacts are expected to be SMALL at all plants and for all
28 environmental resources, it is considered a Category 1 issue.

29 The License Renewal GEIS discussion above informs the impacts expected for
30 decommissioning a new reactor and are incorporated here by reference.

31 At the initial licensing stage, new reactor applicants are not required to submit information
32 regarding the specific method chosen for decommissioning or the schedule, but financial
33 planning is required per 10 CFR 50.75 "Reporting and recordkeeping for decommissioning
34 planning" and 10 CFR 50.82(a)(8) "Termination of license" (10 CFR Part 50-TN249). However,
35 a new reactor applicant should provide a discussion in the application's ER that demonstrates
36 whether the environmental impacts of decommissioning discussed in NUREG-0586,
37 Supplement 1 (NRC 2002-TN665) would bound those for the new reactor design.

38 The NRC staff's evaluation of the environmental impacts of decommissioning presented in
39 NUREG-0586, Supplement 1, considered environmental issues for LWRs and three
40 permanently shutdown facilities that included a fast breeder reactor and two high-temperature
41 gas-cooled reactors (NRC 2002-TN665). The Decommissioning GEIS identified whether the
42 environmental issues were considered generic to all decommissioning sites or project-specific. If
43 the issue was considered generic, then it was assigned a significance level of either SMALL,
44 MODERATE or LARGE. For the environmental issues assessed in the Decommissioning GEIS,
45 most impacts were considered generic and SMALL for all plants, regardless of the activities and

1 identified variables. This is because the impacts would be limited to operational areas, would
 2 not be detectable or destabilizing, and are expected to have a negligible effect on the impacts of
 3 terminating operations and decommissioning. The two issues that were determined to require a
 4 project-specific review were EJ and threatened and endangered species. Four issues in the
 5 Decommissioning GEIS were considered to be conditionally project-specific:

- 6 • land use involving offsite areas to support decommissioning activities,
- 7 • aquatic ecology for activities beyond the licensed operational area,
- 8 • terrestrial ecology for activities beyond the licensed operational area, and
- 9 • historic and cultural resources (archaeological, architectural, structural, historic) for activities
 10 within and beyond the licensed operational area with no current (i.e., at the time of
 11 decommissioning) evaluation of resources for NRHP eligibility.³³

12 Table 3-20 provides a summary of the impacts and findings for each of the Decommissioning
 13 GEIS's evaluated environmental issues.

14 **Table 3-20 Summary of the Environmental Impacts from Decommissioning Nuclear**
 15 **Power Facilities (NRC 2002-TN665)**

| Environmental Issue | NUREG-0586 S1 Section No. | Generic | NUREG-0586 S1 Finding | Summary of NUREG-0586 S1 |
|--|--|----------------|----------------------------------|---|
| Onsite Land Use • Onsite land use activities • Offsite land use activities | 4.3.1 | Yes No | SMALL Site-specific | Decommissioning utilizes areas used during construction. Decommissioning activities that affect offsite land use are not expected unless major upgrades to transportation links are required. |
| Water Use | 4.3.2 | Yes | SMALL | Significantly smaller than water use during operation. |
| Water Quality • Surface Water • Groundwater | 4.3.3 | Yes | SMALL SMALL | Application of common BMP's; NPDES permits regulate intentional releases of hazardous materials; considerable attention is placed on minimizing spills |
| Air Quality | 4.3.4 | Yes | SMALL | Activities extend over years and BMPs can be used to minimize fugitive dust |

³³ In some cases, the nuclear power plant itself may be considered a historic property for its unique design or contribution to a significant historic or engineering achievement. Ultimately, historic and cultural resources at each site can be quite different and must be assessed at a plant-specific level and in consultation with SHPOs, Tribal representatives, and other interested parties.

Table 3-20 Summary of the Environmental Impacts from Decommissioning Nuclear Power Facilities (NRC 2002-TN665) (Continued)

| Environmental Issue | NUREG-0586 S1 Section No. | Generic | NUREG-0586 S1 Finding | Summary of NUREG-0586 S1 |
|--|----------------------------------|----------------|------------------------------|--|
| Aquatic Ecology <ul style="list-style-type: none"> • Activities within the operational area • Activities beyond the operational area | 4.3.5 | Yes No | SMALL Site-specific | If decommissioning does not include removal of shoreline or in-water structures, very little aquatic habitat is expected to be disturbed during decommissioning. When there is a decommissioning activity outside the operational area, the significance of the potential impacts is more difficult to define and will depend on site-specific considerations. |
| Terrestrial Ecology <ul style="list-style-type: none"> • Activities within the operational area • Activities beyond the operational area | 4.3.6 | Yes No | SMALL Site-specific | There is a relatively distinct/small operational area where most or all site activities occur. Some sites will require the reconstruction or installation of new transportation links, such as railroad spurs, road upgrades, or barge slips. |
| Threatened and Endangered Species | 4.3.7 | No | Site-specific | The likelihood of impacts to threatened and endangered species is related to their presence or absence |
| Radiological <ul style="list-style-type: none"> • Occupational dose • Dose to the public | 4.3.8 | Yes Yes | SMALL SMALL | Radiological impacts of decommissioning, including demolition debris that is LLRW, will remain within regulatory |

Table 3-20 Summary of the Environmental Impacts from Decommissioning Nuclear Power Facilities (NRC 2002-TN665) (Continued)

| Environmental Issue | NUREG-0586 S1 Section No. | Generic | NUREG-0586 S1 Finding | Summary of NUREG-0586 S1 |
|--|---------------------------|---------|-----------------------|--|
| | | | | limits for both occupational exposures and to members of the public. |
| Radiological Accidents | 4.3.9 | Yes | SMALL | Emergency plans and procedures will remain in place to protect health and safety while the possibility of significant spent fuel pool accidents exists. |
| Occupational Issues | 4.3.10 | Yes | SMALL | Strict adherence to NRC, Occupational Safety and Health Administration, and State safety standards, practices, and procedures during decommissioning. |
| Cost | 4.3.11 | N/A | N/A | Evaluation of decommissioning cost is not a NEPA requirement. |
| Socioeconomic | 4.3.12 | Yes | SMALL | Impacts of plant closure are those that are observed by the community, rather than the impacts from decommissioning activities because they occur at about the same time |
| Environmental Justice | 4.3.13 | No | Site-specific | Needs to be made on a site-by-site basis because their presence and socioeconomic circumstances will be site-specific. |
| Cultural and Historic Resources | 4.3.14 | | | The amount of land required to support the decommissioning process is relatively |
| • Activities within the operational area | | Yes | SMALL | |
| | | No | Site-specific | |

Table 3-20 Summary of the Environmental Impacts from Decommissioning Nuclear Power Facilities (NRC 2002-TN665) (Continued)

| Environmental Issue | NUREG-0586 S1 Section No. | Generic | NUREG-0586 S1 Finding | Summary of NUREG-0586 S1 |
|--|----------------------------------|----------------|------------------------------|---|
| Activities beyond the operational area | | | | small and is a small portion of the overall plant site. Some sites will require the reconstruction or installation of new transportation links, such as railroad spurs, road upgrades, or barge slips |
| Aesthetics | 4.3.15 | Yes | SMALL | BMPs to control many of the potentially adverse impacts of decommissioning activities on aesthetics (e.g., dust and noise) |
| Noise | 4.3.16 | Yes | SMALL | The sources of noise would be sufficiently distant from critical receptors outside the plant boundaries that the noise would be attenuated to nearly ambient levels and would be scarcely noticeable. |
| Transportation | 4.3.17 | Yes | SMALL | Licenses are expected to comply with all applicable regulations when shipping radioactive waste from decommissioning. |
| Irretrievable Resource | 4.3.18 | Yes | SMALL | If the license is terminated for unrestricted use, then the land will be available for other uses and other irretrievable resources are minor. |

1 The NRC staff believes the above impacts, as discussed in Decommissioning GEIS (NRC 2002-
2 TN665), are bounding for large LWRs deployed after 2002. The expected methods and
3 processes for decommissioning new reactors are expected to be similar to existing
4 decommissioning methods and processes for large LWRs. Regulations specified in §
5 50.82(a)(4)(i) and § 52.110(d)(1) require that PSDARs provide the reasons for concluding that
6 appropriate previously issued EISs will bound the environmental impacts from site-specific
7 decommissioning activities. After the PSDAR is submitted, the licensee must remain in
8 compliance with § 50.82(a)(6)(ii) or § 52.110(f)(2), as applicable. The staff assumes the
9 decommissioning of new reactors would likely have no greater impacts than large LWR
10 decommissioning impacts given that the two project-specific and four conditionally
11 project-specific issues would be evaluated and addressed at the time of either early
12 decommissioning (submittal and review of the PSDAR for acceptability) or later (during License
13 Termination Plan NEPA review). In addition, 10 CFR 50.82 (TN249) or 10 CFR 52.110 (TN251),
14 as applicable, provide that a licensee shall not perform any decommissioning activities that
15 result in significant environmental impacts not bounded by previously issued environmental
16 review documents, such as the Decommissioning GEIS. Licensees that are considering
17 decommissioning activities that could result in significant environmental impacts and would
18 otherwise be prohibited by § 50.82(a)(6)(ii) or § 52.110(f)(2), to modify the decommissioning
19 activity so that the impacts would be bounded, decide not to perform the proposed activity, or
20 seek NRC approval of a license amendment or exemption request. If the licensee decides to
21 pursue a license amendment or exemption, its request will trigger an NRC review of the site-
22 specific environmental impacts of the decommissioning activity under NEPA.

23 As discussed in Section 3.16.1, the following two environmental issues were not identified in the
24 Decommissioning GEIS.

25 Regarding nonradiological waste, waste minimization and pollution prevention are important
26 elements of operations at all nuclear power plants (NRC 2024-TN10161. Nonradiological waste
27 can include hazardous waste and nonhazardous waste (see Section 3.10.2 for details on
28 nonradiological waste information). Licensees are required to consider pollution prevention
29 measures as dictated by the Pollution Prevention Act (Public Law 101 5084; TN6607) and the
30 Resource Conservation and Recovery Act of 1976, as amended (Public Law 94 580; TN1281).
31 In addition, licensees have waste minimization programs in place that are aimed at minimizing
32 the quantities of waste sent offsite for treatment or disposal. Waste minimization techniques
33 employed by the licensees may include (1) source reduction, which includes (a) changes in
34 input materials (e.g., using materials that are not hazardous or are less hazardous), (b) changes
35 in technology, and (c) changes in operating practices and (2) recycling of materials either onsite
36 or offsite. The establishment of a waste minimization program is also a requirement for
37 managing hazardous wastes under RCRA. Nonradiological waste will need to be handled in
38 accordance with applicable Federal and State regulations. It is assumed that licensees would
39 continue to adhere to all applicable State and Federal laws and pollution prevention plans as
40 well as applying waste minimization techniques. The staff concludes that, as long as the PPE
41 assumptions associated with decommissioning and waste management (Section 3.10 of this
42 NR GEIS) are met, the nonradiological waste impacts from decommissioning a new reactor can
43 also be generically determined to be SMALL.

44 The Decommissioning GEIS (NRC 2002-TN665) does not specifically address the GHG
45 footprint of decommissioning activities. However, it does list the decommissioning activities and
46 states that the decommissioning workforce would be expected to be smaller than the
47 operational workforce, and that the decontamination and demolition activities could take up to
48 10 years to complete. Finally, it discusses SAFSTOR (also called the SAFSTOR

1 decommissioning option), in which decontamination and dismantlement are delayed for a
2 number of years (within a cumulative time period of a 50-year time frame (6–10 years is
3 equivalent to 50 years for SAFSTOR). Equipment and vehicles used during decommissioning
4 and SAFSTOR activities would emit GHGs, principally CO₂. Combining the PPE values for
5 GHG emissions for these stages listed in Table 3-1 in Section 3.3.1, 74,000 MT CO₂(e) would
6 be emitted during a 10-year decommissioning period and 40-year SAFSTOR period of two
7 1,000 MW reactors, or less than 1,500 MT CO₂(e)/yr on average. For comparison, in 2022,
8 total gross annual U.S. GHG emissions were 6,343.2 MMT of CO₂(e), of which
9 5,199.8 MMT CO₂(e) were from the energy sector (EPA 2024-TN10121). Estimated annual
10 GHGs emissions from equipment used during decommissioning are about 0.00003 percent
11 of the 2019 GHG emissions from the U.S. energy sector.

12 As noted in Section 3.3.2.2.20, the staff has determined that the contribution of plant life-cycle
13 GHG emissions to national emissions is a Category 1 issue. The staff concludes that, as long as
14 the PPE assumptions associated with GHG emissions are met, the GHG impacts from
15 decommissioning a new reactor can also be generically determined to be SMALL. The generic
16 analysis for GHG emissions for decommissioning can be relied on without applying any
17 mitigation measures.

18 Assuming that the decommissioning of a new reactor is similar to current decommissioning
19 practices, the impacts from decommissioning should be within the bounds described in the
20 Decommissioning GEIS (NRC 2002-TN665). Based on the above information, the
21 Decommissioning GEIS can be relied upon for new reactor decommissioning generic or
22 Category 1 issues with SMALL impacts as presented in Table 3-20. Six site specific or
23 conditionally project-specific issues along with climate change and cumulative impacts are
24 Category 2 and their impacts remain undetermined (see Table 3-20 for the environmental
25 issues marked as Category 2 environmental issues). The Category 2 issues will need to be
26 addressed within the site-specific environmental review for each application utilizing this
27 NR GEIS.

4 SUMMARY OF FINDINGS

1
2 Table 4-1 summarizes the findings of this GEIS, for which 121 environmental issues were
3 analyzed. The table identifies issues as Category 1, Category 2, or N/A. A Category 1
4 designation means that the NRC has determined that a generic analysis of environmental
5 impacts is possible, provided that relevant values and assumptions in the PPE and SPE are
6 met. Issues for which the impacts are beneficial are also designated as Category 1. A
7 Category 2 designation means that NRC has determined that a meaningful generic analysis of
8 environmental impacts is not possible without consideration of project-specific information. The
9 two N/A issues relate to exposure to EMFs and do not have a national scientific agreement
10 regarding adverse health effects (i.e., Uncertain impacts).

11 For Category 1 issues involving adverse impacts, the NRC staff will evaluate the applicant's ER
12 as part of the staff's determination of whether the proposed reactor project meets the PPE and
13 SPE for the issue. In its project-specific SEIS, the NRC will set forth its analysis and
14 determination about whether the project meets the PPE and SPE for the issue and will identify
15 whether the NRC staff considered any additional information not provided in the applicant's ER.
16 If the NRC staff finds that the project meets the PPE and SPE for that Category 1 issue, then
17 the environmental impact will be considered SMALL for that issue. The NRC defines SMALL
18 impacts as impacts that are not detectable or are so minor that they will neither destabilize nor
19 noticeably alter any important attribute of the resource. For the purposes of assessing
20 radiological impacts, the Commission has concluded that the impacts that do not exceed
21 permissible levels in the Commission's regulations are considered SMALL.

22 For Category 2 issues, the GEIS does not include either PPE or SPE values or assumptions
23 because a meaningful generic analysis of Category 2 issues is not possible. The applicant will
24 be required to provide a project-specific analysis for each Category 2 issue in its ER. The
25 project-specific analysis for a Category 2 issue may lead to a conclusion of SMALL,
26 MODERATE or LARGE impacts. Because the NRC staff cannot reach a conclusion regarding
27 the impacts for these issues, the impacts are stated as being "Undetermined" in Table 4-1.

28 For the N/A (Uncertain) issues, the staff will continue to monitor research initiatives to evaluate
29 the potential human health effects of EMFs. If the NRC finds that the appropriate Federal health
30 agencies have reached a general agreement on the potential human health effects of exposure
31 to EMFs, the NRC will determine what to require of all new nuclear reactor license applicants.

32 Assumptions including mitigation measures were considered in the analysis of each
33 environmental issue and are discussed in the appropriate sections of Chapter 3 and are
34 summarized in Table 4-1. The staff's generic conclusion for a Category 1 issue may rely on one
35 or more of the values and assumptions for a parameter. However, the Category 1 issue may not
36 use all of the values and assumptions for the parameter. To determine which values and
37 assumptions are applicable to an individual Category 1 issue, the reader should review the
38 resource-specific evaluation section in Chapter 3.
39

Table 4-1 Summary of Findings and Mitigation¹

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---------------------|-----------|----------|---------|---|
| Land Use | | | | |
| <i>Construction</i> | | | | |
| Onsite Land Use | 3.1.2.1.1 | 1 | SMALL | <ul style="list-style-type: none"> The proposed project, including any associated land uses, complies with NRC siting regulations in 10 CFR Part 100 (TN282). The site size is 100 ac or less. The permanent footprint of disturbance includes 30 ac or less of vegetated lands, and the temporary footprint of disturbance includes no more than an additional 20 ac or less of vegetated lands. The proposed project complies with the site’s zoning and is consistent with any relevant land use plans or comprehensive plans. The site would not be situated closer than 0.5 mi to existing residential areas or 1.0 mi to sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation lands; Wild and Scenic Rivers; or Natural Heritage Rivers. The site does not have a history of past industrial use capable of leaving a legacy of contamination requiring cleanup to protect human health and the environment. The total wetland loss from use of the site, including use of any offsite ROWs, would be no more than 0.5 ac. BMPs for erosion, sediment control, and stormwater management would be used. Compliance with any mitigation measures established through zoning ordinances, local building permits, site use permits, or other land use authorizations. |
| Offsite Land Use | 3.1.2.1.2 | 1 | SMALL | <ul style="list-style-type: none"> New offsite ROWs for transmission lines, pipelines, or access roads would be no more than 100 ft in width and total no more than 1 mi in length. No new offsite ROW would be situated closer than 0.5 mi to existing residential areas or sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation lands; Wild and Scenic Rivers; or Natural Heritage Rivers. No existing ROWs in residential areas would be used or widened to accommodate project features. No ROW has a history of past industrial use capable of leaving a legacy of contamination requiring cleanup to protect human health and the environment. The total wetland loss from use of the entire project, including use of the site and any offsite ROWs, would be no more than 0.5 ac. BMPs for erosion, sediment control, and stormwater management would be used. Compliance with any mitigation measures established through zoning ordinances, local building permits, site use permits, or other land use authorizations. |

4.2

¹ For Category 2 issues, the impacts are stated as “Undetermined” because the NRC staff cannot reach a generic conclusion regarding the impacts for these issues.

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|-----------|----------|---------|---|
| Impacts to Prime and Unique Farmland | 3.1.2.1.3 | 1 | SMALL | <ul style="list-style-type: none"> The site size is 100 ac or less. The site does not contain any prime or unique farmland or other farmland of statewide or local importance; or the site does not abut any agricultural land and is not situated in a predominantly agricultural landscape. |
| Coastal Zone and Compliance with the Coastal Zone Management Act (16 U.S.C. §§ 1451 et seq.; TN1243) | 3.1.2.1.4 | 1 | SMALL | <ul style="list-style-type: none"> The site is not situated in any designated coastal zone, or the applicant can demonstrate that the affected state(s) have or will issue a consistency determination or other indication that the project complies with the Coastal Zone Management Act. |
| <i>Operation</i> | | | | |
| Onsite Land Use | 3.1.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> The proposed project, including any associated land uses, complies with NRC siting regulations in 10 CFR Part 100. The site size is 100 ac or less. If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in height; and equipped with drift eliminators. Any makeup water for the cooling towers would be fresh water (less than 1 ppt salinity). BMPs for erosion, sediment control, and stormwater management would be used. |
| Offsite Land Use | 3.1.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> New offsite ROWs for transmission lines, pipelines, or access roads would be no more than 100 ft in width and total no more than 1 mi in length. BMPs for erosion, sediment control, and stormwater management would be used (wherever land is disturbed during the course of ROW management). |
| <i>Visual</i> | | | | |
| <i>Construction</i> | | | | |
| Visual Impacts in Site and Vicinity | 3.2.2.1.1 | 1 | SMALL | <ul style="list-style-type: none"> The site size is 100 ac or less. The site would not be situated closer than 0.5 mi to existing residential areas or 1 mi to sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation lands; Wild and Scenic Rivers; or Natural Heritage Rivers. The maximum proposed building and structure height is no more than 50 ft, except that the maximum height is 200 ft for proposed meteorological towers and 100 ft for transmission line poles/towers and mechanical draft cooling towers. The proposed project structures would not be visible from Federal or State parks or wilderness areas designated as Class 1 under Section 162 of the Clean Air Act (42 U.S.C. § 7472; TN6954); or as a Wild and Scenic River, a Natural Heritage River, or a river of similar State designation. |
| Visual Impacts from | 3.2.2.1.2 | 1 | SMALL | <ul style="list-style-type: none"> New offsite ROWs for transmission lines, pipelines, or access roads would be no more than 100 ft in width and total no more than 1 mi in length. No transmission line structures (poles or towers) would be over 100 ft in height. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-----------|----------|---------|---|
| Transmission Lines | | | | <ul style="list-style-type: none"> The new offsite ROWs would not be situated closer than 1 mi to existing residential areas or sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation lands; Wild and Scenic Rivers; or Natural Heritage Rivers. Any proposed new structures on offsite ROWs would not be visible from Federal or State parks or wilderness areas designated as Class 1 under Section 162 of the Clean Air Act (42 U.S.C. § 7472; TN6954); or as a Wild and Scenic River, a Natural Heritage River, or a river of similar State designation. |
| <i>Operation</i> | | | | |
| Visual Impacts During Operations | 3.2.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> The site would not be situated closer than 1 mi to existing residential areas or sensitive land uses such as Federal, State, or local parks; wildlife refuges; conservation lands; Wild and Scenic Rivers; or Natural Heritage Rivers. The maximum proposed building and structure height would be no more than 50 ft, except that the maximum height would be 200 ft for proposed meteorological towers and 100 ft for proposed transmission line poles/towers and proposed mechanical draft cooling towers. The proposed project structures would not be visible from Federal or State parks or wilderness areas designated as Class 1 under Section 162 of the Clean Air Act (42 U.S.C. § 7472; TN6954); or as a Wild and Scenic River, a Natural Heritage River, or a river of similar State designation. If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in height; and equipped with drift eliminators. Any makeup water for the cooling towers would be fresh water (less than 1 ppt salinity). |
| <i>Air Quality</i> | | | | |
| <i>Construction</i> | | | | |
| Emissions of Criteria Pollutants and Dust During Construction | 3.3.2.1.1 | 1 | SMALL | <ul style="list-style-type: none"> The site size is 100 ac or less. The permanent footprint of disturbance is 30 ac or less of vegetated lands and the temporary footprint of disturbance is an additional 20 ac or less of vegetated land. New offsite ROWs for transmission lines, pipelines, or access roads would be no longer than 1 mi and have a maximum ROW width of 100 ft. Criteria pollutants emitted from vehicles and standby power equipment during construction are less than Clean Air Act de minimis levels set by the EPA if the site is located in a nonattainment or maintenance area, or the site is located in an attainment area. The site is not located within 1 mi of a mandatory Class I Federal area where visibility is an important value. The LOS determination for affected roadways does not change. Mitigation necessary to rely on the generic analysis includes implementation of BMPs for dust control. Compliance with air permits under State and Federal laws that address the impact of air emissions during construction. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-----------|----------|---------|--|
| Greenhouse Gas Emissions During Construction | 3.3.2.1.2 | 1 | SMALL | <ul style="list-style-type: none"> Greenhouse gases emitted by equipment and vehicles during the 97-year GHG life-cycle period would be equal to or less than 2,534,000 MT of CO₂(e). Appendix H of this GEIS contains the staff's methodology for developing this value, which includes emissions from construction, operation, and decommissioning. As long as this total value is met, the impacts for the life-cycle of the project and the individual phases of the project are determined to be SMALL. |
| Operation | | | | |
| Emissions of Criteria and Hazardous Air Pollutants during Operation | 3.3.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> Criteria pollutants emitted from vehicles and standby power equipment during operations are less than Clean Air Act de minimis levels set by the EPA if located in a nonattainment or maintenance area. The site is not located within 1 mi of a mandatory Class I Federal area where visibility is an important value. The LOS determination for affected roadways does not change. The generic analysis can be relied on without applying any mitigation measures. Compliance with air permits under State and Federal laws that address the impact of air emissions. HAP emissions will be within regulatory limits. |
| Greenhouse Gas Emissions During Operation | 3.3.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Greenhouse gases emitted by equipment and vehicles during the 97-year GHG life-cycle period would be equal to or less than 2,534,000 MT of CO₂(e). Appendix H of this GEIS contains the staff's methodology for developing this value, which includes emissions from construction, operation, and decommissioning. As long as this total value is met, the impacts for the life-cycle of the project and the individual phases of the project are determined to be SMALL. |
| Cooling-System Emissions | 3.3.2.2.3 | 1 | SMALL | <ul style="list-style-type: none"> If needed, cooling towers would be mechanical draft, not natural draft. Cooling towers would be equipped with drift eliminators. The site is not located within 1 mi of a mandatory Class I Federal area where visibility is an important value. Mechanical draft cooling towers would be less than 100 ft tall. Makeup water would be fresh (with a salinity less than 1 ppt). Operation of cooling towers is assumed to be subject to State permitting requirements. HAP emissions would be within regulatory limits. No existing residential areas within 0.5 mi of the site. |
| Emissions of Ozone and NO _x during Transmission Line Operation | 3.3.2.2.4 | 1 | SMALL | <ul style="list-style-type: none"> The transmission line voltage would be no higher than 1,200 kilovolts. |
| Water Resources | | | | |
| Construction | | | | |
| Surface Water Use Conflicts | 3.4.2.1.1 | 1 | SMALL | <p>Total Plant Water Demand</p> <ul style="list-style-type: none"> Less than or equal to a daily average of 6,000 gpm. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-----------|----------|--|---|
| during Construction | | | <p>If water is obtained from a flowing water body, then the following PPE/SPE parameter and associated assumptions also apply:</p> <ul style="list-style-type: none"> • Average plant water withdrawals do not reduce discharge from the flowing water body by more than 3 percent of the 95 percent exceedance daily flow and do not prevent the maintenance of applicable instream flow requirements. • The 95 percent exceedance flow accounts for existing and planned future withdrawals. • Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional, or tribal governing authorities. • Water rights for the withdrawal amount are obtainable, if needed. <p>If water is obtained from a non-flowing water body, then the following PPE/SPE parameter and associated value and assumptions also apply:</p> <ul style="list-style-type: none"> • Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and intertidal zones exceeds the amount of water required by the plant. • Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional, or tribal governing authorities. • Water rights for the withdrawal amount are obtainable, if needed. • The Coastal Zone Management Act consistency determination is obtainable, if applicable, for the non-flowing water body. | |
| Groundwater Use Conflicts due to Excavation Dewatering | 3.4.2.1.2 | 1 | SMALL | <ul style="list-style-type: none"> • The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate may be larger). • Dewatering results in negligible groundwater level drawdown at the site boundary. |
| Groundwater Use Conflicts due to Construction-Related Groundwater Withdrawals | 3.4.2.1.3 | 1 | SMALL | <ul style="list-style-type: none"> • Groundwater withdrawal for all plant uses (excluding dewatering) is less than or equal to 50 gpm. • Withdrawal results in no more than 1 ft of groundwater level drawdown at the site boundary. • Withdrawals are not derived from an EPA-designated SSA, or from any aquifer designated by a State, tribe, or regional authority to have special protections to limit drawdown. • Withdrawals meet any applicable State or local permit requirements. |
| Water Quality Degradation due to Construction-Related Discharges | 3.4.2.1.4 | 1 | SMALL | <ul style="list-style-type: none"> • The permanent footprint of disturbance includes 30 ac or less of vegetated lands, and the temporary footprint of disturbance includes no more than an additional 20 ac or less of vegetated lands. • Adherence to requirements in NPDES permits issued by the EPA or State permitting program, and any other applicable permits. • The long-term groundwater dewatering withdrawal rate is less than or equal to 50 gpm. • Dewatering discharge has minimal effects on the quality of the receiving water body (e.g., as demonstrated by conformance with NPDES permit requirements). • There are no planned discharges to the subsurface (by infiltration or injection), including stormwater discharge. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|-----------|----------|---------|--|
| Water Quality Degradation due to Inadvertent Spills during Construction | 3.4.2.1.5 | 1 | SMALL | <ul style="list-style-type: none"> The site size is 100 ac or less. The permanent footprint of disturbance includes 30 ac or less of vegetated lands, and the temporary footprint of disturbance includes no more than an additional 20 ac or less of vegetated lands. Applicable requirements and guidance on spill prevention and control are followed, including relevant BMPs and Integrated Pollution Prevention Plans. |
| Water Quality Degradation due to Groundwater Withdrawal | 3.4.2.1.6 | 1 | SMALL | <p>Groundwater Withdrawal for Excavation or Foundation Dewatering</p> <ul style="list-style-type: none"> The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate may be larger). Dewatering results in negligible groundwater level drawdown at the site boundary. <p>Groundwater Withdrawal for Plant Uses</p> <ul style="list-style-type: none"> Groundwater withdrawal for all plant uses (excluding dewatering) is less than or equal to 50 gpm. Withdrawal results in no more than 1 ft of groundwater level drawdown at the site boundary. Withdrawals are not derived from an EPA-designated SSA, or from any aquifer designated by a State, tribe, or regional authority to have special protections to limit drawdown. Withdrawals meet any applicable State or local permit requirements. |
| Water Quality Degradation due to Offshore or In-Water Construction Activities | 3.4.2.1.7 | 1 | SMALL | <ul style="list-style-type: none"> In-water structures (including intake and discharge structures) are constructed in compliance with provisions of the CWA Section 404 (33 U.S.C. § 1344; TN1019) and Section 10 of the Rivers and Harbors Appropriation Act of 1899 (33 U.S.C. §§ 401 et seq.; TN660). Adverse effects of building activities controlled and localized using BMPs such as installation of turbidity curtains or installation of cofferdams. Construction duration would be less than 7 years. |
| Water Use Conflict Due to Plant Municipal Water Demand | 3.4.2.1.8 | 1 | SMALL | <ul style="list-style-type: none"> The amount available from municipal water systems exceeds the amount of municipal water required by the plant (gpm). Municipal Water Availability accounts for all existing and planned future uses. An agreement or permit for the usage amount can be obtained from the municipality. |
| Degradation of Water Quality from Plant Effluent Discharges to Municipal Systems | 3.4.2.1.9 | 1 | SMALL | <ul style="list-style-type: none"> Municipal Systems' Available Capacity to Receive and Treat Plant Effluent accounts for all existing and reasonably foreseeable future discharges. Agreement to discharge to a municipal treatment system is obtainable. |
| <i>Operation</i> | | | | |
| Surface Water Use Conflicts during Operation due to Water | 3.4.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> Total plant water demand is less than or equal to a daily average of 6,000 gpm. Average plant water withdrawals do not reduce discharge from the flowing water body by more than 3 percent of the 95 percent exceedance daily flow and do not prevent the maintenance of applicable instream flow requirements. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-----------|----------|---------|--|
| Withdrawal from Flowing Waterbodies | | | | <ul style="list-style-type: none"> The 95 percent exceedance flow accounts for existing and planned future withdrawals. Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional, or tribal governing authorities. Water rights for the withdrawal amount are obtainable, if needed. |
| Surface Water Use Conflicts during Operation due to Water Withdrawal from Non-flowing Waterbodies | 3.4.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Total plant water demand is less than or equal to a daily average of 6,000 gpm. Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and intertidal zones exceeds the amount of water required by the plant. Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional, or tribal governing authorities. Water rights for the withdrawal amount are obtainable, if needed. Coastal Zone Management Act of 1972 (16 U.S.C. §§ 1451 et seq.; TN1243) consistency determination is obtainable, if applicable. |
| Groundwater Use Conflicts Due to Building Foundation Dewatering | 3.4.2.2.3 | 1 | SMALL | <ul style="list-style-type: none"> The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate may be larger). Dewatering results in negligible groundwater level drawdown at the site boundary. |
| Groundwater Use Conflicts Due to Groundwater Withdrawals for Plant Uses | 3.4.2.2.4 | 1 | SMALL | <ul style="list-style-type: none"> Groundwater withdrawal for all plant uses (excluding dewatering) is less than or equal to 50 gpm. Withdrawal results in no more than 1 ft of groundwater level drawdown at the site boundary. Withdrawals are not derived from an EPA-designated SSA, or from any aquifer designated by a State, tribe, or regional authority to have special protections to limit drawdown. Withdrawals meet any applicable State or local permit requirements. |
| Surface Water Quality Degradation Due to Physical Effects from Operation of Intake and Discharge Structures | 3.4.2.2.5 | 1 | SMALL | <ul style="list-style-type: none"> Total plant water demand is less than or equal to a daily average of 6,000 gpm. Adhere to best available technology requirements of CWA 316(b) (33 U.S.C. § 1326-TN4823). Operated in compliance with CWA Section 316 (b) and 40 CFR 125.83, including compliance with monitoring and recordkeeping requirements in 40 CFR 125.87 and 40 CFR 125.88, respectively (40 CFR Part 125-TN254). Best available technologies are employed in the design and operation of intake and discharge structures to minimize alterations due to scouring, sediment transport, increased turbidity and erosion. Adherence to requirements in NPDES permits issued by the EPA or a given state. <p>If water is obtained from a flowing water body, then the following PPE/SPE parameter and associated value also apply:</p> <ul style="list-style-type: none"> The average rate of plant withdrawal does not exceed 3 percent of the 95 percent exceedance daily flow for the water body. <p>If water is obtained from a non-flowing water body, then the following PPE/SPE parameters and associated values and assumptions also apply:</p> |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-----------|----------|--------------|---|
| Surface Water Quality Degradation Due to Changes in Salinity Gradients Resulting from Withdrawals | 3.4.2.2.6 | 1 | SMALL | <ul style="list-style-type: none"> Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and intertidal zones exceeds the amount of water required by the plant. Total plant water demand is less than or equal to a daily average of 6,000 gpm. <p>If water is obtained from a flowing water body, then the following PPE/SPE parameter and associated assumptions also apply:</p> <ul style="list-style-type: none"> Average plant water withdrawals do not reduce discharge from the flowing water body by more than 3 percent of the 95 percent exceedance daily flow and do not prevent the maintenance of applicable instream flow requirements. The 95 percent exceedance flow accounts for existing and planned future withdrawals. Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional, or tribal governing authorities. Water rights for the withdrawal amount are obtainable, if needed. If withdrawals are from an estuary or intertidal zone, then changes to salinity gradients are within the normal tidal or seasonal movements that characterize the water body. <p>If water is obtained from a non-flowing water body, then the following PPE/SPE parameter and associated values and assumptions also apply:</p> <ul style="list-style-type: none"> Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and intertidal zones exceeds the amount of water required by the plant. Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional, or tribal governing authorities. Water rights for the withdrawal amount are obtainable, if needed. If withdrawals are from an estuary or intertidal zone, then changes to salinity gradients are within the normal tidal or seasonal movements that characterize the water body. |
| Surface Water Quality Degradation Due to Chemical and Thermal Discharges | 3.4.2.2.7 | 2 | Undetermined | <p>The staff determined that a generic analysis to determine operational impacts on surface water quality due to chemical and thermal discharges was not possible because (1) some States may impose effluent constituent limitations more stringent than those required by the EPA, (2) limitations imposed on effluent constituents may vary among States, and (3) the establishment of a mixing zone may be required. Because all of these issues related to degradation of surface water quality from chemical and thermal discharges require consideration of project-specific information, a project-specific assessment should be performed in the SEIS.</p> |
| Groundwater Quality Degradation Due to Plant Discharges | 3.4.2.2.8 | 1 | SMALL | <ul style="list-style-type: none"> The plant is outside the recharge area for any EPA-designated SSA or any aquifer designated to have special protections by a State, tribal, or regional authority. The plant is outside the wellhead protection area or designated contributing area for any public water supply well. There are no planned discharges to the subsurface (by infiltration or injection). |
| Water Quality Degradation due | 3.4.2.2.9 | 1 | SMALL | <ul style="list-style-type: none"> Applicable requirements and guidance on spill prevention and control are followed, including relevant BMPs and Integrated Pollution Prevention Plans. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|------------|----------|---------|---|
| to Inadvertent Spills and Leaks during Operation | | | | <ul style="list-style-type: none"> • There are no planned discharges to the subsurface (by infiltration or injection), including stormwater discharge. • A groundwater protection program conforming to NEI 07-07 (NEI 2019-TN6775) is established and followed. • The site size is 100 ac or less. • Use of BMPs for soil erosion, sediment control, and stormwater management. • Adherence to requirements in NPDES permits issued by the EPA or a given State, and any other applicable permits. |
| Water Quality Degradation due to Groundwater Withdrawals | 3.4.2.2.10 | 1 | SMALL | <ul style="list-style-type: none"> • The long-term dewatering withdrawal rate is less than or equal to 50 gpm (the initial rate may be larger). • Dewatering results in negligible groundwater level drawdown at the site boundary. • Groundwater withdrawal for all plant uses (excluding dewatering) is less than or equal to 50 gpm. • Withdrawal results in no more than 1 ft of groundwater level drawdown at the site boundary. • Withdrawals are not derived from an EPA-designated SSA, or from any aquifer designated by a State, tribe, or regional authority to have special protections to limit drawdown. • Withdrawals meet any applicable State or local permit requirements. |
| Water Use Conflict from Plant Municipal Water Demand | 3.4.2.2.11 | 1 | SMALL | <ul style="list-style-type: none"> • Usage amount is within the existing capacity of the system(s), accounting for all existing and planned future uses. • An agreement or permit for the usage amount can be obtained from the municipality. |
| Degradation of Water Quality from Plant Effluent Discharges to Municipal Systems | 3.4.2.2.12 | 1 | SMALL | <ul style="list-style-type: none"> • Municipal Systems' Available Capacity to Receive and Treat Plant Effluent accounts for all existing and reasonably foreseeable future discharges. • Agreement to discharge to a municipal treatment system is obtainable. |
| Terrestrial Ecology | | | | |
| <i>Construction</i> | | | | |
| Permanent and Temporary Loss, Conversion, Fragmentation, and Degradation of Habitats | 3.5.2.1.1 | 1 | SMALL | <ul style="list-style-type: none"> • The permanent footprint of disturbance would include 30 ac or less of vegetated lands, and the temporary footprint of disturbance would include no more than an additional 20 ac or less of vegetated lands. • Temporarily disturbed lands would be revegetated using regionally indigenous vegetation once the lands are no longer needed to support building activities. • New offsite ROWs for transmission lines, pipelines, or access roads would be no more than 100 ft in width and total no more than 1 mi in length. • The footprint of disturbance (permanent and temporary) would contain no ecologically sensitive features such as floodplains, shorelines, riparian vegetation, late-successional vegetation, land |

4-10

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-------------|----------|--------------|---|
| | | | | <ul style="list-style-type: none"> specifically designated for conservation, or habitat known to be potentially suitable for one or more Federal or State threatened or endangered species. Total wetland impacts from use of the site and any offsite ROWs would be no more than 0.5 ac. Applicants would demonstrate an effort to minimize fragmentation of terrestrial habitats by using existing ROWs, or widening existing ROWs, to the extent practicable. BMPs would be used for erosion, sediment control, and stormwater management. |
| Permanent and Temporary Loss and Degradation of Wetlands | 3.5.2.1.2 | 1 | SMALL | <ul style="list-style-type: none"> Applicant would provide a delineation of potentially impacted wetlands, including wetlands not under CWA jurisdiction. Total wetland impacts from use of the site and any offsite ROWs would be no more than 0.5 ac. If activities regulated under the CWA are performed, those activities would receive approval under one or more NWP (33 CFR Part 330) or other general permits recognized by the USACE. Temporary groundwater withdrawals for excavation or foundation dewatering would not exceed a long-term rate of 50 gpm. Applicants would be able to demonstrate that the temporary groundwater withdrawals would not substantially alter the hydrology of wetlands connected to the same groundwater resource. Any required State or local permits for wetland impacts would be obtained. Any mitigation measures indicated in the NWPs or other permits would be implemented. BMPs would be used for erosion, sediment control, and stormwater management. |
| Effects of Building Noise on Wildlife | 3.5.2.1.3 | 1 | SMALL | <ul style="list-style-type: none"> Noise generation would not exceed 85 dBA 50 ft from the source. |
| Effects of Vehicular Collisions on Wildlife | 3.5.2.1.4 | 1 | SMALL | <ul style="list-style-type: none"> The site size would be 100 ac or less. The permanent footprint of disturbance would include 30 ac or less of vegetated lands, and the temporary footprint of disturbance would include no more than an additional 20 ac or less of vegetated lands. There would be no decreases in the LOS designation for affected roadways. The licensee would communicate with Federal and State wildlife agencies and implement mitigation actions recommended by those agencies to reduce potential for vehicular injury to wildlife. |
| Bird Collisions and Injury from Structures and Transmission Lines | 3.5.2.1.5 | 1 | SMALL | <ul style="list-style-type: none"> The site size would be 100 ac or less. New offsite ROWs for transmission lines, pipelines, or access roads would be no more than 100 ft in width and total no more than 1 mi in length. No transmission line structures (poles or towers) would be more than 100 ft in height. Licensees would implement common mitigation measures such as those provided by the American Bird Conservancy (ABC 2015-TN6763) for buildings, by FWS (2013-TN6764) for towers, and by the APLIC for transmission lines (APLIC 2012-TN6779). |
| Important Species and Habitats – | 3.5.2.1.6.1 | 2 | Undetermined | The NRC staff is unable to determine the significance of potential impacts without consideration of project-specific factors, including the specific species and habitats affected and the types of ecological changes potentially resulting from each specific licensing action. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|-------------|----------|---------|---|
| Resources Regulated under the Endangered Species Act of 1973 (ESA; 16 U.S.C. §§ 1531 et seq; TN1010) | | | | |
| Important Species and Habitats – Other Important Species and Habitats | 3.5.2.1.6.2 | 1 | SMALL | <ul style="list-style-type: none"> Applicants would communicate with State natural resource or conservation agencies regarding wildlife and plants and implement mitigation recommendations of those agencies. |
| <i>Operation</i> | | | | |
| Permanent and Temporary Loss or Disturbance of Habitats | 3.5.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> Temporarily disturbed lands would be revegetated using regionally indigenous vegetation once the lands are no longer needed to support building activities. The total wetland loss from site disturbance over the operational life of the plant would be no more than 0.5 ac. Any State or local permits for wetland impacts would be obtained. Any mitigation measures indicated in the NWPs or other wetland permits would be implemented. BMPs would be used for erosion, sediment control, and stormwater management. |
| Effects of Operational Noise on Wildlife | 3.5.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Noise generation would not exceed 85 dBA 50 ft from the source. There would be no decreases in the LOS designation for affected roadways. The licensee would communicate with Federal and State wildlife agencies and implement mitigation actions recommended by those agencies to reduce potential for vehicular injury to wildlife. |
| Effects of Vehicular Collisions on Wildlife | 3.5.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Noise generation would not exceed 85 dBA 50 ft from the source. There would be no decreases in the LOS designation for affected roadways. The licensee would communicate with Federal and State wildlife agencies and implement mitigation actions recommended by those agencies to reduce potential for vehicular injury to wildlife. |
| Exposure of Terrestrial Organisms to Radionuclides | 3.5.2.2.3 | 1 | SMALL | <ul style="list-style-type: none"> Applicants would demonstrate in their application that any radiological nonhuman biota doses would be below IAEA (1992-TN712) and NCRP (1991-TN729) guidelines. |
| Cooling-Tower Operational Impacts on Vegetation | 3.5.2.2.4 | 1 | SMALL | <ul style="list-style-type: none"> If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in height; and equipped with drift eliminators. Any makeup water for the cooling towers would be fresh water (less than 1 ppt salinity). |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|--------------|----------|--------------|---|
| Bird Collisions and Injury from Structures and Transmission Lines | 3.5.2.2.5 | 1 | SMALL | <ul style="list-style-type: none"> The site size would be 100 ac or less. New offsite ROWs for transmission lines, pipelines, or access roads would be no more than 100 ft in width and total no more than 1 mi in length. No transmission line structures (poles or towers) would be more than 100 ft in height. Licensees would implement common mitigation measures such as those provided by the American Bird Conservancy (ABC 2015-TN6763) for buildings, by FWS (2013-TN6764) for towers, and by the APLIC for transmission lines (APLIC 2012-TN6779). |
| Bird Electrocutions from Transmission Lines | 3.5.2.2.6 | 1 | SMALL | <ul style="list-style-type: none"> New offsite ROWs for transmission lines, pipelines, or access roads would be no more than 100 ft in width and total no more than 1 mi in length. Common mitigation measures, such as those recommended by APLIC (2006-TN794), would be implemented. |
| Water Use Conflicts with Terrestrial Resources | 3.5.2.2.7 | 1 | SMALL | <ul style="list-style-type: none"> Total plant water demand would be less than or equal to a daily average of 6,000 gpm. If water is withdrawn from flowing water bodies, average plant water withdrawals would not reduce flow by more than 3 percent of the 95 percent exceedance daily flow and would not prevent maintenance of applicable instream flow requirements. Any water withdrawals would be in compliance with any EPA or State permitting requirements. Applicants would be able to demonstrate that hydroperiod changes are within historical or seasonal fluctuations. |
| Effects of Transmission Line ROW Management on Terrestrial Resources | 3.5.2.2.8 | 1 | SMALL | <ul style="list-style-type: none"> Vegetation in transmission line ROWs would be managed following a plan consisting of integrated vegetation management practices. All ROW maintenance work would be performed in compliance with all applicable laws and regulations. Herbicides would be applied by licensed applicators, and only if in compliance with applicable manufacturer label instructions. |
| Effects of Electromagnetic Fields on Flora and Fauna | 3.5.2.2.9 | 1 | SMALL | <ul style="list-style-type: none"> Based on the literature review in the License Renewal GEIS, the staff determined that this is a Category 1 issue and impacts would be SMALL regardless of the length, location, or size of the transmission lines. The staff did not recommend any mitigation in the License Renewal GEIS (NRC 2024-TN10161); hence, none is needed here. The staff did not rely on any PPE and SPE values or assumptions in reaching this conclusion. |
| Important Species and Habitats – Resources Regulated under the ESA of 1973 | 3.5.2.2.10.1 | 2 | Undetermined | The NRC staff is unable to determine the significance of potential impacts without consideration of project-specific factors, including the specific species and habitats affected and the types of ecological changes potentially resulting from each specific licensing action. |
| Important Species and Habitats – Other | 3.5.2.2.10.2 | 1 | SMALL | <ul style="list-style-type: none"> Applicants would communicate with State natural resource or conservation agencies regarding wildlife and plants and implement mitigation recommendations of those agencies. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-------------|----------|--------------|--|
| Important Species and Habitats | | | | |
| Aquatic Ecology | | | | |
| Construction | | | | |
| Runoff and sedimentation from construction areas | 3.6.2.1.1 | 1 | SMALL | <ul style="list-style-type: none"> • BMPs would be used for erosion and sediment control. • Temporarily disturbed lands would be revegetated using regionally indigenous vegetation once the lands are no longer needed to support building activities. |
| Dredging and filling aquatic habitats to build intake and discharge structures | 3.6.2.1.2 | 1 | SMALL | <ul style="list-style-type: none"> • Applicant would obtain approval, if required, under NWP 7 in 33 CFR Part 330. • Applicant would implement any mitigation required under NWP 7 in 33 CFR Part 330. • Applicant would minimize any temporarily disturbed shoreline and riparian lands needed to build the intake and discharge structures and restore those areas with regionally indigenous vegetation suited to those landscape settings once the disturbances are no longer needed. • BMPs would be used for erosion and sediment control. |
| Building transmission lines, pipelines, and access roads across surface waterbodies | 3.6.2.1.3 | 1 | SMALL | <ul style="list-style-type: none"> • If activities regulated under the Clean Water Act are performed, they would receive approval under one or more NWPs (33 CFR Part 330-TN4318) or other general permits recognized by the USACE. • Pipelines would be extended under (or over) surface through directional drilling without physically disturbing shorelines or bottom substrate. • Access roads would span streams and other surface waterbodies with a bridge or ford, and any fords would include placement and maintenance of matting to minimize physical disturbance of shorelines and bottom substrates. • No access roads would be extended across stream channels over 10 ft in width (at ordinary high water). • Any bridges or fords would be removed once no longer needed, and any exposed soils or substrate would be revegetated using regionally indigenous vegetation appropriate to the landscape setting. • Any mitigation measures indicated in the NWPs or other permits would be implemented. • BMPs would be used for erosion and sediment control. |
| Important Species and Habitats – Resources Regulated under the ESA and Magnuson-Stevens Fishery Conservation and Management Act | 3.6.2.1.4.1 | 2 | Undetermined | The NRC staff is unable to determine the significance of potential impacts without consideration of project-specific factors, including the specific species and habitats affected and the types of ecological changes potentially resulting from each specific licensing action. Furthermore, the Endangered Species Act (16 U.S.C. §§ 1531 et seq.; TN1010) and Magnuson-Stevens Fishery Conservation and Management Act (16 U.S.C. §§ 1801 et seq.; TN1061) require consultations for each licensing action that may affect regulated resources. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-------------|----------|---------|--|
| (16 U.S.C. §§ 1801 et seq.; TN1061) | | | | |
| Important species and habitats – Other Important Species and Habitats | 3.6.2.1.4.2 | 1 | SMALL | <ul style="list-style-type: none"> Applicants would communicate with State natural resource or conservation agencies regarding aquatic fish, wildlife, and plants and implement mitigation recommendation of those agencies. |
| <i>Operation</i> | | | | |
| Stormwater runoff | 3.6.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> Preparation, approval by applicable regulatory agencies, and implementation of a stormwater management plan. Obtaining and compliance with any required permits for the storage and use of hazardous materials issued by Federal and State agencies under RCRA. BMPs would be used for stormwater management. |
| Exposure of aquatic organisms to radionuclides | 3.6.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Applicants would demonstrate in their application that any radiological nonhuman biota doses would be below IAEA (1992-TN712) and NCRP (1991-TN729) guidelines. |
| Effects of refurbishment on aquatic biota | 3.6.2.2.3 | 1 | SMALL | <ul style="list-style-type: none"> BMPs would be used for erosion, sediment control, and stormwater management. Exposed soils would be restored as soon as possible with regionally indigenous vegetation. |
| Effects of maintenance dredging on aquatic biota | 3.6.2.2.4 | 1 | SMALL | <ul style="list-style-type: none"> If activities regulated under the Clean Water Act are performed, those activities would receive approval under one or more NWP (33 CFR Part 330) or other general permits recognized by the USACE. Any mitigation measures indicated in the NWP or other permits would be implemented. BMPs would be used for erosion and sediment control. |
| Impacts of transmission line ROW management on aquatic resources | 3.6.2.2.5 | 1 | SMALL | <ul style="list-style-type: none"> Vegetation in transmission line ROWs would be managed following a plan consisting of integrated vegetation management practices. All ROW maintenance work would be performed in compliance with all applicable laws and regulations. Herbicides would be applied by licensed applicators, and only if in compliance with applicable manufacturer label instructions. BMPs would be used for erosion and sediment control. |
| Impingement and entrainment of aquatic organisms | 3.6.2.2.6 | 1 | SMALL | <ul style="list-style-type: none"> Intakes would comply with regulatory requirements established by EPA in 40 CFR 125.84 (TN254) to be protective of fish and shellfish. Best available control technology would be employed in the design of intakes to minimize entrainment and impingement, such as use of screens and intake rates recognized to minimize effects. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|--------------|----------|--------------|---|
| Thermal impacts on aquatic biota | 3.6.2.2.7 | 2 | Undetermined | Staff would have to first review the discharge plume analysis (as described in Section 3.4) and the aquatic biota potentially present before being able to reach a conclusion regarding the possible significance of impacts to that biota. |
| Other effects of cooling-water discharges on aquatic biota | 3.6.2.2.8 | 2 | Undetermined | Staff would have to first review the discharge plume analysis (as described in Section 3.4) and the aquatic biota potentially present before being able to reach a conclusion regarding the possible significance of impacts to that biota. |
| Water use conflicts with aquatic resources | 3.6.2.2.9 | 1 | SMALL | <ul style="list-style-type: none"> • If needed, cooling towers would be mechanical draft, not natural draft; less than 100 ft in height; and equipped with drift eliminators. • Any makeup water for the cooling towers would be fresh water (less than 1 ppt salinity). • Total plant water demand would be less than or equal to a daily average of 6,000 gpm. • If water is withdrawn from flowing waterbodies, average plant water withdrawals would not reduce flow by more than 3 percent of the 95 percent exceedance daily flow, and would not prevent maintenance of applicable instream flow requirements. • Any water withdrawals would be in compliance with any EPA or State permitting requirements. • Applicants would be able to demonstrate that hydroperiod changes are within historical or seasonal fluctuations. |
| Important Species and Habitats – Resources Regulated under the ESA and Magnuson-Stevens Act | 3.6.2.2.10.1 | 2 | Undetermined | The NRC staff is unable to determine the significance of potential impacts without consideration of project-specific factors, including the specific species and habitats affected and the types of ecological changes potentially resulting from each specific licensing action. Furthermore, the Endangered Species Act (16 U.S.C. §§ 1531 et seq.; TN1010) and Magnuson-Stevens Fishery Conservation and Management Act (16 U.S.C. §§ 1801 et seq.; TN1061) require consultations for each licensing action that may affect regulated resources. |
| Important species and habitats – Other Important Species and Habitats | 3.6.2.2.10.2 | 1 | SMALL | <ul style="list-style-type: none"> • Applicants would communicate with State natural resource or conservation agencies regarding aquatic fish, wildlife, and plants and implement mitigation recommendations of those agencies. |
| Historic and Cultural Resources | | | | |
| <i>Construction</i> | | | | |
| Construction impacts on historic and cultural resources | 3.7.2 | 2 | Undetermined | Impacts on historic and cultural resources are analyzed on a project-specific basis. The NRC will perform National Environmental Policy Act (NEPA) and NHPA Section 106 analysis, in accordance with 36 CFR Part 800, in its preparation of the SEIS. The NHPA Section 106 analysis includes consultation with the State and Tribal Historic Preservation Officers, American Indian Tribes, and other interested parties. |
| <i>Operation</i> | | | | |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|-------------|----------|--------------|---|
| Operation impacts on historic and cultural resources | 3.7.2 | 2 | Undetermined | Impacts on historic and cultural resources are analyzed on a project-specific basis. The NRC will perform NEPA and NHPA Section 106 analysis, in accordance with 36 CFR Part 800, in its preparation of the SEIS. The NHPA Section 106 analysis includes consultation with the State and Tribal Historic Preservation Officers, American Indian Tribes, and other interested parties. |
| Radiological Environment | | | | |
| <i>Construction</i> | | | | |
| Radiological dose to construction workers | 3.8.1.2.1 | 1 | SMALL | <ul style="list-style-type: none"> • For protection against radiation, the applicant must meet the regulatory requirements of: <ul style="list-style-type: none"> – 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a license – 10 CFR 20.1201 Occupational dose limits for adults – 10 CFR 20.1301 Dose limits for individual members of the public – Appendix B of 10 CFR Part 20 <i>Annual Limits on Intake (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewerage</i> – 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control releases of radioactive material in effluents—nuclear power reactors – 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors – Application contains sufficient technical information for the staff to complete the detailed technical safety review. – Application will be found to be in compliance by the staff with the above regulations through a radiation protection program and an effluent release monitoring program. |
| <i>Operation</i> | | | | |
| Occupational doses to workers | 3.8.1.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> • For protection against radiation, the applicant must meet the regulatory requirements of: <ul style="list-style-type: none"> – 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a license – 10 CFR 20.1201 Occupational dose limits for adults – Appendix B of 10 CFR Part 20 <i>Annual Limits on Intake (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewerage</i> – 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control releases of radioactive material in effluents—nuclear power reactors – 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors • Application contains sufficient technical information for the staff to complete the detailed technical safety review • Application will be found to be in compliance by the staff with the above regulations through a radiation protection program and an effluent release monitoring program. |
| Maximally exposed individual annual doses | 3.8.1.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> • For protection against radiation, the applicant must meet the regulatory requirements of: <ul style="list-style-type: none"> – 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a license – 10 CFR 20.1301 Dose limits for individual members of the public |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|-------------|----------|-----------|--|
| | | | | <ul style="list-style-type: none"> - Appendix B of 10 CFR Part 20 <i>Annual Limits on Intake (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewerage</i> - 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control releases of radioactive material in effluents—nuclear power reactors - 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors • Application contains sufficient technical information for the staff to complete the detailed technical safety review • Application will be found to be in compliance by the staff with the above regulations through a radiation protection program and an effluent release monitoring program |
| Total population annual doses | 3.8.1.2.2.3 | 1 | SMALL | <ul style="list-style-type: none"> • For protection against radiation, the applicant must meet the regulatory requirements of: <ul style="list-style-type: none"> - 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a license - 10 CFR 20.1301 Dose limits for individual members of the public - Appendix B of 10 CFR Part 20 <i>Annual Limits on Intake (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewerage</i> - 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control releases of radioactive material in effluents—nuclear power reactors - 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors • Application contains sufficient technical information for the staff to complete the detailed technical safety review • Application will be found to be in compliance by the staff with the above regulations through a radiation protection program and an effluent release monitoring program. |
| Nonhuman biota doses | 3.8.1.2.2.4 | 1 | SMALL | <ul style="list-style-type: none"> • Applicants would demonstrate in their application that any radiological nonhuman biota doses would be below IAEA (1992-TN712) and NCRP (1991-TN729) guidelines. |
| Nonradiological Environment | | | | |
| <i>Construction</i> | | | | |
| Building impacts of chemical, biological, and physical nonradiological hazards | 3.8.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> • The applicant must adhere to all applicable Federal, State, local or Tribal regulatory limits and permit conditions for chemical hazards, biological hazards, and physical hazards. • The applicant will follow nonradiological public and occupational health BMPs and mitigation measures, as appropriate. |
| Building impacts of EMFs | 3.8.2.2.1 | N/A | Uncertain | <p>Studies of 60 Hz EMFs have not uncovered consistent evidence linking harmful effects with field exposures. Because the state of the science is currently inadequate, no generic conclusion on human health impacts is possible. If, in the future, the Commission finds that a general agreement has been reached by appropriate Federal health agencies that there are adverse health effects from EMFs, the Commission will require applicants to submit plant-specific reviews of these health effects as part of their application. Until such time, applicants are not required to submit information about this issue.</p> |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|------------|----------|-----------|--|
| <i>Operation</i> | | | | |
| Operation impacts of chemical, biological, and physical nonradiological hazards | 3.8.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> The applicant must adhere to all applicable Federal, State, local or Tribal regulatory limits and permit conditions for chemical hazards, biological hazards, and physical hazards. The applicant will follow nonradiological public and occupational health BMPs and mitigation measures, as appropriate. |
| Operation impacts of EMFs | 3.8.2.2.2 | N/A | Uncertain | Studies of 60 Hz EMFs have not uncovered consistent evidence linking harmful effects with field exposures. Because the state of the science is currently inadequate, no generic conclusion on human health impacts is possible. If, in the future, the Commission finds that a general agreement has been reached by appropriate Federal health agencies that there are adverse health effects from EMFs, the Commission will require applicants to submit plant-specific reviews of these health effects as part of their application. Until such time, applicants are not required to submit information about this issue. |
| <i>Noise</i> | | | | |
| <i>Construction</i> | | | | |
| Construction-related noise | 3.9.2.1 | 1 | SMALL | <ul style="list-style-type: none"> The noise level would be no more than 65 dBA at site boundary, unless a relevant State or local noise abatement law or ordinance sets a different threshold, which would then be the presumptive threshold for PPE purposes. If an applicant cannot meet the 65 dBA threshold through mitigation, then the applicant must obtain a various or exception with the relevant State or local regulator. The project would implement BMPs, including such as modeling, foliage planting, construction of noise buffers, and the timing of construction and/or operation activities. |
| <i>Operation</i> | | | | |
| Operation-related noise | 3.9.2.2 | 1 | SMALL | <ul style="list-style-type: none"> The noise level would be no more than 65 dBA at site boundary, unless a relevant State or local noise abatement law or ordinance sets a different threshold, which would then be the presumptive threshold for PPE purposes. If an applicant cannot meet the 65 dBA threshold through mitigation, then the applicant must obtain a various or exception with the relevant State or local regulator. The project would implement BMPs, including such as modeling, foliage planting, construction of noise buffers, and the timing of construction and/or operation activities. |
| <i>Radiological Waste Management</i> | | | | |
| <i>Operation</i> | | | | |
| LLRW | 3.10.1.2.1 | 1 | SMALL | <ul style="list-style-type: none"> Applicants must meet the regulatory requirements of 10 CFR Part 20 (TN283) (e.g., 20.1406 and Subpart K), 10 CFR Part 61 (TN252), 10 CFR Part 71 (TN301), and 10 CFR Part 72 (TN4884). Quantities of LLRW generated at a new nuclear reactor would be less than the quantities of LLRW generated at existing nuclear power plants, which generate an average of 21,200 ft³ (600 m³) and |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|------------|----------|---------|--|
| | | | | 2,000 Ci (7.4×10^{13} Bq) per year for boiling water reactors and half that amount for pressurized water reactors (NRC 2024-TN10161). |
| Onsite spent nuclear fuel management | 3.10.1.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Compliance with 10 CFR Part 72 (TN4884) |
| Mixed waste | 3.10.1.2.3 | 1 | SMALL | <ul style="list-style-type: none"> RCRA Small Quantity Generator (EPA 2020-TN6590) for Mixed Waste. |
| Nonradiological Waste Management | | | | |
| <i>Construction</i> | | | | |
| Construction nonradiological waste | 3.10.2.2.1 | 1 | SMALL | <ul style="list-style-type: none"> The applicant must meet all the applicable permit conditions, regulations, and BMPs related to solid, liquid, and gaseous waste management. For hazardous waste generation, applicants must meet conformity with hazardous waste quantity generation levels in accordance with RCRA. For sanitary waste, applicants must dispose of sanitary waste in a permitted process. For mitigation measures, the applicant would perform mitigation measures to the extent practicable, such as recycling, process improvements, or the use of a less hazardous substance. |
| <i>Operation</i> | | | | |
| Operation nonradiological waste | 3.10.2.2.2 | 1 | SMALL | <ul style="list-style-type: none"> The applicant must meet all the applicable permit conditions, regulations, and BMPs related to solid, liquid, and gaseous waste management. For hazardous waste generation, applicants must meet conformity with hazardous waste quantity generation levels in accordance with RCRA. For sanitary waste, applicants must dispose of sanitary waste in a permitted process. For mitigation measures, the applicant would perform mitigation measures to the extent practicable, such as recycling, process improvements, or the use of a less hazardous substance. |
| Postulated Accidents | | | | |
| <i>Operation</i> | | | | |
| Design Basis Accidents Involving Radiological Releases | 3.11.2.1 | 1 | SMALL | <ul style="list-style-type: none"> For the exclusion area boundary, the maximum TEDE for any 2-hour period during the radioactivity release should be calculated. For the low-population zone, the TEDE should be calculated for the duration of the accident release (i.e., 30 days, or other duration as justified). <p>The above calculations would compare the DBA doses with the dose criteria given in regulations related to the application (e.g., 10 CFR 50.34(a)(1) [TN249], 10 CFR 52.17(a)(1) and 10 CFR 52.79(a)(1) [10 CFR Part 52-TN251]), standard review plans (e.g., SRP criteria, Table 1 in SRP Section 15.0.3 of NUREG-0800 [NRC 2007/2019-TN6221]), and RGs, (e.g., RG 1.183 [NRC 2000-TN517]), as applicable.</p> |
| Accidents Involving Releases of | 3.11.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Reactor inventory of a regulated substance is less than its TQ. TQs are found in 40 CFR 68.130, Tables 1, 2, 3, and 4 (TN5494); and |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|------------|----------|--------------|--|
| Hazardous Chemicals | | | | <ul style="list-style-type: none"> Reactor inventory of an EHS is less than its TPQ. TPQs are found in 40 CFR Part 355, Appendices A and B (TN5493). |
| Severe Accidents | 3.11.2.3 | 2 | Undetermined | Based on the analysis in the Final Safety Analysis Report/Preliminary Safety Analysis Report regarding severe accidents, if a reactor design has severe accident progressions with radiological or hazardous chemical releases, then an environmental risk evaluation must be performed. |
| Severe Accident Mitigation Design Alternatives | 3.11.2.4 | 1 | SMALL | If a cost-screening analysis determines that the maximum benefit for avoiding an accident is so small that a SAMDA analysis is not justified based on a minimum cost to design an appropriate SAMDA. |
| Acts of Terrorism | 3.11.2.5 | 1 | SMALL | The environmental impacts of acts of terrorism and sabotage only need to be addressed if a reactor facility is subject to the jurisdiction of the U.S. Court of Appeals for the Ninth Circuit. |
| Socioeconomics | | | | |
| <i>Construction</i> | | | | |
| Community Services and Infrastructure | 3.12.1.1.1 | 1 | SMALL | <ul style="list-style-type: none"> The housing vacancy rate in the affected economic region does not change by more than 5 percent, or at least 5 percent of the housing stock remains available after accounting for in-migrating construction workers. Student:teacher ratios in the affected economic region do not exceed locally mandated levels after including the school age children of the in-migrating worker families. |
| Transportation Systems and Traffic | 3.12.1.1.2 | 1 | SMALL | The LOS determination for affected roadways does not change. Mitigation measures may include implementation of traffic flow management, management of shift-change timing, and encouragement of ride-sharing and use of public transportation options, such that LOS values can be maintained with the increased volumes. |
| Economic Impacts | 3.12.1.1.3 | 1 | Beneficial | The economic impacts of construction and operation of a new nuclear reactor are expected to be beneficial; therefore, this is a Category 1 issue. If, during the project-specific environmental review, the NRC staff determines a detailed analysis of economic costs and benefits is needed for analysis of the range of alternatives considered or relevant to mitigation, the staff may require further information from the applicant. |
| Tax Revenue Impacts | 3.12.1.1.4 | 1 | Beneficial | The tax revenue impacts of construction and operation of a new nuclear reactor are expected to be beneficial; therefore, this is a Category 1 issue. If, during the project-specific environmental review, the NRC staff determines a detailed analysis of tax revenue costs and benefits is needed for analysis of the range of alternatives considered or relevant to mitigation, the staff may require further information from the applicant. |
| <i>Operation</i> | | | | |
| Community Services and Infrastructure | 3.12.1.2.1 | 1 | SMALL | <ul style="list-style-type: none"> The housing vacancy rate in the affected economic region does not change by more than 5 percent, or at least 5 percent of the housing stock remains available after accounting for in-migrating construction workers. Student:teacher ratios in the affected economic region do not exceed locally mandated levels after including the school age children of the in-migrating worker families. |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|--|------------|----------|--------------|---|
| Transportation Systems and Traffic | 3.12.1.2.2 | 1 | SMALL | The LOS determination for affected roadways does not change. Mitigation measures may include implementation of traffic flow management, management of shift-change timing, and encouragement of ride-sharing and use of public transportation options, such that LOS values can be maintained with the increased volumes. |
| Economic Impacts | 3.12.1.2.3 | 1 | Beneficial | The economic impacts of construction and operation of a new nuclear reactor are expected to be beneficial; therefore, this is a Category 1 issue. If, during the project-specific environmental review, the NRC staff determines a detailed analysis of economic costs and benefits is needed for analysis of the range of alternatives considered or relevant to mitigation, the staff may require further information from the applicant. |
| Tax Revenue Impacts | 3.12.1.2.4 | 1 | Beneficial | The tax revenue impacts of construction and operation of a new nuclear reactor are expected to be beneficial; therefore, this is a Category 1 issue. If, during the project-specific environmental review, the NRC staff a detailed analysis of tax revenue costs and benefits is needed for analysis of the range of alternatives considered or relevant to mitigation, the staff may require further information from the applicant. |
| Environmental Justice | | | | |
| <i>Construction</i> | | | | |
| Construction Environmental Justice Impacts | 3.13.2.1 | 2 | Undetermined | Project-specific analysis would be necessary, including analysis of the presence and size of specific minority or low-income populations, impact pathways derived from the plant design, layout, or site characteristics, or other community characteristics affecting specific minority or low-income populations. In performing its environmental justice analysis, the NRC staff will be guided by the NRC's "Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions," which was published in the <i>Federal Register</i> on August 24, 2004 (69 FR 52040-TN1009). |
| <i>Operation</i> | | | | |
| Operation Environmental Justice Impacts | 3.13.2.1 | 2 | Undetermined | Project-specific analysis would be necessary, including analysis of the presence and size of specific minority or low-income populations, impact pathways derived from the plant design, layout, or site characteristics, or other community characteristics affecting specific minority or low-income populations. In performing its environmental justice analysis, the NRC staff will be guided by the NRC's "Policy Statement on the Treatment of Environmental Justice Matters in NRC Regulatory and Licensing Actions," which was published in the <i>Federal Register</i> on August 24, 2004 (69 FR 52040-TN1009). |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---------------------------------|----------|----------|---------|---|
| Fuel Cycle | | | | |
| Operation | | | | |
| Uranium Recovery | 3.14.2.1 | 1 | SMALL | <ul style="list-style-type: none"> Table S-3 is expected to bound the impacts for new nuclear reactor fuels, because of uranium fuel cycle changes since WASH-1248 (AEC 1974-TN23), including: <ul style="list-style-type: none"> Increasing use of in situ leach uranium mining has lower environmental impacts than traditional mining and milling methods. Current light-water reactors are using nuclear fuel more efficiently due to higher levels of fuel burnup resulting in less demand for mining and milling activities. Less reliance on coal-fired electrical generation plants is resulting in less gaseous effluent releases from electrical generation sources supporting mining and milling activities. Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) <i>Domestic Licensing of Source Material</i> and 10 CFR Part 71 (TN301), <i>Packaging and Transportation of Radioactive Material</i>. |
| Uranium Conversion | 3.14.2.2 | 1 | SMALL | <ul style="list-style-type: none"> Table S-3 is expected to bound the impacts for new nuclear reactor fuels because of uranium fuel cycle changes since WASH-1248 (AEC 1974-TN23), including: <ul style="list-style-type: none"> Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup resulting in less demand for conversion activities. Less reliance on coal-fired electrical generation plants is resulting in less gaseous effluent releases from electrical generation sources supporting conversion activities. Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) <i>Domestic Licensing of Source Material</i> and 10 CFR Part 71 (TN301), <i>Packaging and Transportation of Radioactive Material</i>, and 10 CFR Part 73 (TN423), <i>Physical Protection of Plants and Materials</i>. |
| Enrichment | 3.14.2.3 | 1 | SMALL | <ul style="list-style-type: none"> Table S-3 is expected to bound the impacts for new nuclear reactor fuels, because of uranium fuel cycle changes since WASH-1248 (AEC 1974-TN23), including: <ul style="list-style-type: none"> Transitioning of U.S. uranium enrichment technology from gaseous diffusion to gas centrifugation, which requires less electrical usage per separative work unit. Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup resulting in less demand for enrichment activities. Less reliance on coal-fired electrical generation plants is resulting in less gaseous effluent releases from electrical generation sources supporting enrichment activities. Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) <i>Domestic Licensing of Source Material</i>, 10 CFR Part 70 (TN4883), <i>Domestic Licensing of Special Nuclear Material</i>, 10 CFR Part 71 (TN301), <i>Packaging and Transportation of Radioactive Material</i>, and 10 CFR Part 73 (TN423), <i>Physical Protection of Plants and Materials</i>. |
| Fuel Fabrication ^(a) | 3.14.2.4 | 1 | SMALL | <ul style="list-style-type: none"> Table S-3 is expected to bound the impacts for new nuclear reactor fuels, because of uranium fuel cycle changes since WASH-1248 (AEC 1974-TN23), including: <ul style="list-style-type: none"> Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup resulting in fewer discharged fuel assemblies to be fabricated each year and due to longer time periods between refueling |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|----------|----------|---------|--|
| Reprocessing | 3.14.2.5 | 1 | SMALL | <ul style="list-style-type: none"> - Less reliance on coal-fired electrical generation plants is resulting in less gaseous effluent releases from electrical generation sources supporting fabrication. • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) <i>Domestic Licensing of Source Material</i>, 10 CFR Part 70 (TN4883), <i>Domestic Licensing of Special Nuclear Material</i>, 10 CFR Part 71 (TN301), <i>Packaging and Transportation of Radioactive Material</i>, and 10 CFR Part 73 (TN423), <i>Physical Protection of Plants and Materials</i>. • Table S–3 is expected to bound the impacts for new nuclear reactor fuels, because of uranium fuel cycle changes since WASH-1248 (AEC 1974-TN23), including: <ul style="list-style-type: none"> - Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup resulting in fewer discharged fuel assemblies to be reprocessed each year. - Less reliance on coal-fired electrical generation plants is resulting in less gaseous effluent releases from electrical generation sources supporting reprocessing. • Reprocessing capacity up to 900 MTU/yr • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) <i>Domestic Licensing of Source Material</i>, 10 CFR Part 50 (TN249) <i>Domestic Licensing of Production and Utilization Facilities</i>, 10 CFR Part 70 (TN4883), <i>Domestic Licensing of Special Nuclear Material</i>, 10 CFR Part 71 (TN301), <i>Packaging and Transportation of Radioactive Material</i>, 10 CFR Part 72 (TN4884), <i>Licensing Requirements for the Independent Storage of Spent Fuel, High-Level Radioactive Waste, and Reactor-related Greater Than Class C Waste</i>, and 10 CFR Part 73 (TN423), <i>Physical Protection of Plants and Materials</i>. |
| Storage and Disposal of Radiological Wastes | 3.14.2.6 | 1 | SMALL | <ul style="list-style-type: none"> • Table S–3 is expected to bound the impacts for new nuclear reactor fuels, because of uranium fuel cycle changes since WASH-1248 (AEC 1974-TN23), including: <ul style="list-style-type: none"> - Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup resulting in fewer discharged fuel assemblies to be stored and disposed. - Less reliance on coal-fired electrical generation plants is resulting in less gaseous effluent releases from electrical generation sources supporting storage and disposal. • Waste and spent fuel inventories, as well as their associated certified spent fuel shipping and storage containers, are not significantly different from what has been considered for LWR evaluations in NUREG-2157 (NRC 2014-TN4117). • Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) <i>Domestic Licensing of Source Material</i>, 10 CFR Part 70 (TN4883), <i>Domestic Licensing of Special Nuclear Material</i>, 10 CFR Part 71 (TN301), <i>Packaging and Transportation of Radioactive Material</i>, 10 CFR Part 72 (TN4884), <i>Licensing Requirements for the Independent Storage of Spent Fuel, High-Level Radioactive Waste, and Reactor-related Greater Than Class C Waste</i>, and 10 CFR Part 73 (TN423), <i>Physical Protection of Plants and Materials</i>. |

4-24

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|-------------------------------------|----------|----------|---------|--|
| Transportation of Fuel and Waste | | | | |
| <i>Operation</i> | | | | |
| Transportation of Unirradiated Fuel | 3.15.2.1 | 1 | SMALL | <ul style="list-style-type: none"> The maximum annual one-way shipment distance (59,160 km) presented in Table 3-11. The annual shipments associated with the one-way shipment distance have been normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor from WASH-1238 (AEC 1972-TN22). The maximum annual round-trip shipment distance (118,320 km) presented in Table 3-12. The annual shipments associated with the round-trip shipment distance have been normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor from WASH-1238 (AEC 1972-TN22). |
| Transportation of Radioactive Waste | 3.15.2.2 | 1 | SMALL | <ul style="list-style-type: none"> The maximum annual round-trip shipment distance (293,145 km) presented in Table 3-16. The annual shipments associated with the round-trip shipment distance have been normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor and a shipment volume of 2.34 m³/shipment from WASH-1238 (AEC 1972-TN22). |
| Transportation of Irradiated Fuel | 3.15.2.3 | 1 | SMALL | <ul style="list-style-type: none"> The maximum annual one-way shipment distance (505,393 km) presented in Table 3-17. The annual shipments associated with the one-way shipment distance have been normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor and a shipment capacity of 0.5 MTU/shipment from WASH-1238 (AEC 1972-TN22). The maximum annual round-trip shipment distance (1,010,786 km) presented in Table 3-19. The annual shipments associated with the round-trip shipment distance have been normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor and a shipment capacity of 0.5 MTU/shipment from WASH-1238 (AEC 1972-TN22). A maximum peak rod burnup of 62 GWd/MTU for UO₂ fuel and peak pellet burnup of 133 GWd/MTU for TRISO fuel (see Table 3-18). |
| Decommissioning | | | | |
| Decommissioning | 3.16.2 | 1 | SMALL | The environmental impacts for the following resource areas were generically addressed in NUREG-0586, Supplement 1, would be limited to operational areas, would not be detectable or destabilizing and are expected to have a negligible effect on the impacts of terminating operations and decommissioning: |

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|-----------------|---------|----------|--|--|
| | | | <ul style="list-style-type: none"> • Onsite land use • Water use • Water quality • Air quality • Aquatic ecology within the operational area • Terrestrial ecology within the operational area • Radiological • Radiological accidents (non-spent-fuel-related) • Occupational issues • Socioeconomic • Onsite cultural and historic resources for plants where the disturbance of lands beyond the operational areas is not anticipated • Aesthetics • Noise • Transportation • Irretrievable resource <p>The following issues were not addressed in NUREG-0586, Supplement 1, but have been determined to be Category 1 issues:</p> <ul style="list-style-type: none"> • Nonradiological waste • Greenhouse gases | |
| Decommissioning | 3.16.2 | 2 | Undetermined | <p>The following two issues were identified in NUREG-0586, Supplement 1, as requiring a project-specific review:</p> <ul style="list-style-type: none"> • Environmental justice • Threatened and endangered species <p>Four conditionally project-specific issues identified in NUREG-0586, Supplement 1, will require a project-specific review if present:</p> <ul style="list-style-type: none"> • Land use involving offsite areas to support decommissioning activities • Aquatic ecology for activities beyond the licensed operational area • Terrestrial ecology for activities beyond the licensed operational area • Historic and cultural resources (archaeological, architectural, structural, historic) for activities within and beyond the licensed operational area with no current (i.e., at the time of decommissioning) evaluation of resources for NRHP eligibility <p>Additionally, the following two environmental resource areas are additional decommissioning impacts that require project-specific review:</p> |

4-26

Table 4-1 Summary of Findings and Mitigation (Continued)

| Issue | Section | Category | Finding | PPE/SPE Values and Assumptions |
|---|-----------|----------|--------------|---|
| | | | | <ul style="list-style-type: none"> Climate change: the effects of climate change are location-specific and cannot, therefore, be evaluated generically (see Section 1.3.3.2.2, Category 2 Issues Applying Across Resources, of this NR GEIS) Cumulative effects: must be considered on a project-specific basis where impacts would depend on regional resource characteristics, the resource specific impacts of the project, and the cumulative significance of other factors affecting the resource. (see Section 1.3.3.2.2, Category 2 Issues Applying Across Resources, of this NR GEIS) |
| Issues Applying Across All Resources | | | | |
| Climate Change | 1.3.3.2.2 | 2 | Undetermined | The effects of climate change are location-specific and cannot, therefore, be evaluated generically. For example, while climate change may cause many areas to receive less than average annual precipitation, other areas may see an increase in average annual precipitation. Therefore, applicants and staff would address the effects of climate change in the environmental documents for new nuclear reactor licensing. |
| Cumulative Impacts | 1.3.2.2.2 | 2 | Undetermined | Applications must individually consider the cumulative impacts from past, present, and reasonably foreseeable future actions known to occur at specific sites for proposed new nuclear reactors, and briefly present those considerations in supplemental NEPA documentation. The staff would explain whether these individualized evaluations of potential cumulative impacts alter any of the generic analyses and conclusions relied upon for Category 1 issues. The individualized cumulative impact analyses may also identify opportunities where staff might rely upon the generic analyses for some Category 1 issues for which certain of the PPE or SPE values and assumptions might be exceeded. |
| Non-Resource Related Issues | | | | |
| Purpose and Need | 1.3.3.2.3 | 2 | Undetermined | Must be described in the environmental report associated with a given application. |
| Need for Power | 1.3.3.2.3 | 2 | Undetermined | Must be described in the environmental report associated with a given application. |
| Site Alternatives | 1.3.3.2.3 | 2 | Undetermined | Must be described in the environmental report associated with a given application. |
| Energy Alternatives | 1.3.3.2.3 | 2 | Undetermined | Must be described in the environmental report associated with a given application. |
| System Design Alternatives | 1.3.3.2.3 | 2 | Undetermined | Must be described in the environmental report associated with a given application. |
| (a) Fuel fabrication impacts for metal fuel and liquid fueled molten salt are not included in the staff's generic analysis. | | | | |

1 **4.1 Unavoidable Adverse Environmental Impacts and Irreversible and**
2 **Irretrievable Commitments of Resources**

3 Unavoidable adverse environmental impacts are those potential impacts of the NRC proposed
4 action that cannot be avoided and for which no practical means of mitigation are available. The
5 term “irreversible and irretrievable commitments of resources” refers to environmental resources
6 that would be irreparably changed by the activities authorized by the NRC, where the
7 environmental resources could not be restored at some later time to the resource’s state before
8 the relevant activities.

9 Because the issuance of the NR GEIS would itself have no impacts and would not approve or
10 license the construction and/or operation of any new nuclear reactor, there would be no
11 unavoidable adverse environmental impacts or any irreversible or irretrievable commitments of
12 resources from development of the NR GEIS.

13 Any project-specific SEIS developed for a proposed new nuclear reactor tiering to the GEIS
14 would be required to analyze the impacts associated with construction and operation of such a
15 facility. The unavoidable adverse environmental impacts associated with the granting of the
16 license would include impacts of construction, preconstruction, and operation and would be
17 described in the project-specific SEIS.

18 The irreversible and irretrievable commitments of resources during construction of the proposed
19 new nuclear reactor generally would be similar to those of any major construction project and
20 would be dependent on the size and scale of the proposed reactor. The NRC would prepare the
21 project-specific SEIS, issue the requisite record of decision in accordance with 10 CFR 51.102
22 (TN250), and assuming approval of the project, describe any such irreversible and irretrievable
23 commitments of resources in the SEIS before the issuance of any license, permit, or other
24 authorization to construct or operate a new nuclear reactor.

25 The NRC staff expects that the use of construction materials in the quantities associated with
26 those expected for new nuclear reactors tiering to the GEIS, while irreversible and irretrievable,
27 would be of small consequence with respect to the availability of such resources. The main
28 resource that would be irreversibly and irretrievably committed during operation of any new
29 nuclear unit would be the fuel. If uranium is the fuel, the availability of uranium ore and existing
30 stockpiles of highly enriched uranium in the United States and Russia that could be processed
31 into fuel is sufficient (OECD/NEA and IAEA 2008-TN3992) so that the irreversible and
32 irretrievable commitment of this resource would be negligible. The irreversible and irretrievable
33 commitment of resources would not be the same for all nuclear power plants and would depend
34 on the specific characteristics of the power plant (e.g., thorium fuel cycle, lithium-based primary
35 fluid, or other resource characteristic) and its resource needs.

36 **4.2 Relationship between Short-Term Use of the Environment and Long-Term**
37 **Productivity**

38 NEPA Section 102(2)(C)(iv) (42 U.S.C. § 4332(C)(iv); TN4880) requires that an EIS include
39 information about the relationship between local short-term uses of the environment and the
40 maintenance and enhancement of long-term productivity.

41 Because the issuance of the NR GEIS would not approve or license the construction and/or
42 operation of any new nuclear reactor, the GEIS itself would not result in either short-term or
43 long-term impacts. However, a project-specific SEIS tiering to the GEIS would consider the

1 relationship between local short-term uses of the environment and the maintenance and
2 enhancement of long-term productivity.

3 Nuclear power plant construction and operations would necessitate short-term use of the
4 environment and commitments of resources. Certain resources (e.g., land and energy) will be
5 committed indefinitely or permanently. Short-term use of the environment can affect long-term
6 productivity of the ecosystem if that use alters the ability of the ecosystem to re-establish an
7 equilibrium that is comparable to that of its original condition.

8 Air emissions from power plant operations would introduce small amounts of radiological and
9 nonradiological constituents to the region around the plant site. Over time, these emissions
10 could result in increased concentrations and exposure, but are not expected to affect air quality
11 or radiation exposure to the extent that public health and long-term productivity of the
12 environment would be impaired. Continued employment, expenditures, and tax revenues
13 generated during power plant operations would directly benefit local, regional, and State
14 economies during the short term. Local governments investing project-generated tax revenues
15 into infrastructure and other required services could enhance economic productivity over the
16 long term. The management and disposal of spent nuclear fuel, low-level waste, hazardous
17 waste, and nonhazardous waste would require an increase in energy and would consume
18 space at treatment, storage, or disposal facilities. Regardless of the location, the use of land to
19 meet waste disposal needs would reduce the long-term productivity of the land. Power plant
20 facilities would be committed to power production over the short term. After decommissioning
21 these facilities and restoring the power plant site, the land would become available for other
22 productive uses. The nature of the relationship between short-term use of the environment and
23 long-term productivity would vary among plants and would depend on the specific
24 characteristics of each plant and its interaction with the environment. This relationship is
25 reactor-specific and would be analyzed in a project-specific SEIS.

26 **4.3 No-Action Alternative Conclusion**

27 Under the No-Action Alternative the NRC would not issue this GEIS. There are no
28 environmental impacts associated with not issuing the GEIS. In this context, the No-Action
29 Alternative would accomplish none of the benefits intended by the GEIS process, which would
30 include (1) reducing the time and resources for the applicant's preparation of the ER,
31 (2) reducing the time and resources for the NRC staff's preparation of the EIS, and (3) focusing
32 the effort of applicant, NRC staff, and decision-makers on issues that involve a potential for
33 significant environmental impacts.

34 Selection of the No-Action Alternative would likely lead to the same magnitude and level of
35 environmental impacts associated with the licensing of new nuclear reactors; these impacts
36 would be addressed in project-specific EISs rather than in supplemental analyses tiering to the
37 NR GEIS. Mitigation measures associated with these projects would be developed on a case-
38 by-case basis rather than comprehensively, as in the GEIS, potentially leading to increased
39 inconsistency and potential greater impacts.

40 **4.4 Cost Benefit**

41 Section 102(B) of NEPA requires that all Federal agencies "identify and develop methods and
42 procedures, in consultation with the Council on Environmental Quality established by Title II of
43 this Act, which will ensure that presently unquantified environmental amenities and values

1 may be given appropriate consideration in decision-making along with economic and
2 technical considerations” (42 U.S.C. § 4332(B); TN4880).

3 However, neither NEPA nor the government-wide NEPA-implementing regulations of the
4 Council on Environmental Quality require the benefits and costs of a proposed action be
5 quantified in dollars or any other common metric. The intent of this section is not to identify and
6 quantify all of the potential societal benefits of the proposed activities and compare them to the
7 potential costs of the proposed activities. Instead, this section focuses on only the benefits and
8 costs of such magnitude or importance that their inclusion in this analysis can inform the
9 decision-making process. This section summarizes the pertinent analytical conclusions reached
10 in earlier chapters of this GEIS.

11 The proposed action of proceeding with the GEIS is expected to improve the efficiency of the
12 environmental review process and avoid duplication of effort, compared to the No-Action
13 Alternative of developing individual project-specific EISs for new nuclear reactor applications.
14 The issues identified as Category 1 in this GEIS have been analyzed and resolved generically;
15 therefore, the resources needed for subsequent staff reviews of environmental issues in
16 individual new nuclear reactor applications would be reduced. In addition, by analyzing
17 Category 1 issues generically, the GEIS would also enhance consistency across environmental
18 reviews, thereby increasing efficiency and streamlining the environmental review process. Use
19 of the GEIS would allow NRC staff and decision-makers to focus on issues that involve a
20 potential for significant environmental impacts. Project-specific environmental reviews would be
21 able to incorporate the GEIS findings by reference, thereby streamlining the review processes.

1

5 REFERENCES

2 18 AAC 70. *Alaska Administrative Code*, Title 18, *Environmental Conservation*, Chapter 70,
3 "Water Quality Standards." TN7039.

4 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, "Standards for
5 Protection Against Radiation." TN283.

6 10 CFR Part 40. *Code of Federal Regulations*, Title 10, *Energy*, Part 40, "Domestic Licensing of
7 Source Material." TN4882.

8 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of
9 Production and Utilization Facilities." TN249.

10 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental
11 Protection Regulations for Domestic Licensing and Related Regulatory Functions." TN250.

12 10 CFR Part 52. *Code of Federal Regulations*, Title 10, *Energy*, Part 52, "Licenses,
13 Certifications, and Approvals for Nuclear Power Plants." TN251.

14 10 CFR Part 54. *Code of Federal Regulations*, Title 10, *Energy*, Part 54, "Requirements for
15 Renewal of Operating Licenses for Nuclear Power Plants." TN4878.

16 10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, "Licensing
17 Requirements for Land Disposal of Radioactive Waste." TN252.

18 10 CFR Part 70. *Code of Federal Regulations*, Title 10, *Energy*, Part 70, "Domestic Licensing of
19 Special Nuclear Material." TN4883.

20 10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, "Packaging and
21 Transportation of Radioactive Material." TN301.

22 10 CFR Part 72. *Code of Federal Regulations*, Title 10, *Energy*, Part 72, "Licensing
23 Requirements for the Independent Storage of Spent Nuclear Fuel, High-Level Radioactive
24 Waste, and Reactor-Related Greater than Class C Waste." TN4884.

25 10 CFR Part 73. *Code of Federal Regulations*, Title 10, *Energy*, Part 73, "Physical Protection of
26 Plants and Materials." TN423.

27 10 CFR Part 100. *Code of Federal Regulations*, Title 10, *Energy*, Part 100, "Reactor Site
28 Criteria." TN282.

29 15 CFR Part 930. *Code of Federal Regulations*, Title 15, *Commerce and Foreign Trade*,
30 Part 930, "Federal Consistency with Approved Coastal Management Programs." TN4475.

31 24 CFR Part 51. *Code of Federal Regulations*, Title 24, *Housing and Urban Development*,
32 Part 51, "Environmental Criteria and Standards." TN1016.

33 29 CFR Part 1910. *Code of Federal Regulations*, Title 29, *Labor*, Part 1910, "Occupational
34 Safety and Health Standards." TN654.

1 29 CFR Part 1926. *Code of Federal Regulations*, Title 29, *Labor*, Part 1926, "Safety and Health
2 Requirements for Construction." TN4455.

3 33 CFR Part 328. *Code of Federal Regulations*, Title 33, *Navigation and Navigable Waters*, Part
4 328, "Definition of Waters of the United States." TN1683.

5 33 CFR Part 330. *Code of Federal Regulations*, Title 33, *Navigation and Navigable Waters*, Part
6 330, "Nationwide Permit Program." TN4318.

7 36 CFR Part 60. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
8 Part 60, "National Register of Historic Places." TN1682.

9 36 CFR Part 61. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
10 Part 61, "Procedures for State, Tribal, and Local Government Historic Preservation Programs."
11 TN4848.

12 36 CFR Part 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
13 Part 800, "Protection of Historic Properties." TN513.

14 40 CFR Part 50. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 50,
15 "National Primary and Secondary Ambient Air Quality Standards." TN1089.

16 40 CFR Part 68. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 68,
17 "Chemical Accident Prevention Provisions." TN5494.

18 40 CFR Part 81. *Code of Federal Regulations*, Title 40, *Air Programs*, Subchapter C, *Protection*
19 *of Environment*, Part 81, "Designation of Areas for Air Quality Planning Purposes." TN7226.

20 40 CFR Part 93. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 93,
21 "Determining Conformity of Federal Actions to State or Federal Implementation Plans." TN2495.

22 40 CFR Part 112. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 112,
23 "Oil Pollution Prevention." TN1041.

24 40 CFR Part 125. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 125,
25 "Criteria and Standards for the National Pollutant Discharge Elimination System." TN254.

26 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
27 "Environmental Radiation Protection Standards for Nuclear Power Operations." TN739.

28 40 CFR Parts 201-211. *Code of Federal Regulations*, Title 40, *Protection of Environment*,
29 Subchapter G, "Noise Abatement Programs." TN7030.

30 40 CFR Part 230. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 230,
31 "Section 404(b)(1) Guidelines for Specification of Disposal Sites for Dredged or Fill Material."
32 TN427.

33 40 CFR Part 261. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 261,
34 "Identification and Listing of Hazardous Waste." TN5092.

35 40 CFR Part 273. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 273,
36 "Standards for Universal Waste Management." TN6587.

1 40 CFR Part 355. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 302,
2 “Emergency Planning and Notification.” TN5493.

3 40 CFR Parts 201-211. *Code of Federal Regulations*, Title 40, *Protection of Environment*,
4 Subchapter G, “Noise Abatement Programs.” TN7030.

5 49 CFR. *Code of Federal Regulations*, Title 49, *Transportation*. TN7054.

6 49 CFR Part 172. *Code of Federal Regulations*, Title 49, *Transportation*, Part 172, “Hazardous
7 Materials Table, Special Provisions, Hazardous Materials Communications, Emergency
8 Response Information, Training Requirements, and Security Plans.” TN6616.

9 49 CFR Part 397. *Code of Federal Regulations*, Title 49, *Transportation*, Part 397,
10 “Transportation of Hazardous Materials; Driving and Parking Rules.” TN6621.

11 45 FR 40101. June 13, 1980. “Nuclear Power Plant Accident Consideration Under the National
12 Environmental Policy Act of 1969.” *Federal Register*, Nuclear Regulatory Commission. TN4270.

13 49 FR 34658. August 31, 1984. “Waste Confidence Decision.” *Federal Register*, Nuclear
14 Regulatory Commission. TN3370.

15 50 FR 32138. August 8, 1985. “Policy Statement on Severe Reactor Accidents Regarding
16 Future Designs and Existing Plants.” Policy Statement, *Federal Register*, Nuclear Regulatory
17 Agency. TN4519.

18 51 FR 30028. August 21, 1986. “Safety Goals for the Operation of Nuclear Power Plants; Policy
19 Statement; Republication.” *Federal Register*, Nuclear Regulatory Commission. TN594.

20 59 FR 7629. February 16, 1994. “Executive Order 12898 of February 11, 1994: Federal Actions
21 To Address Environmental Justice in Minority Populations and Low-Income Populations.”
22 *Federal Register*, Office of the President. TN1450.

23 69 FR 52040. August 24, 2004. “Policy Statement on the Treatment of Environmental Justice
24 Matters in NRC Regulatory and Licensing Actions.” *Federal Register*, Nuclear Regulatory
25 Commission. TN1009.

26 71 FR 16348. March 31, 2006. “Notice of Availability of Environmental Assessment and Finding
27 of No Significant Impact for License Renewal for BWX Technologies, Inc., Lynchburg, VA.”
28 *Federal Register*, Nuclear Regulatory Commission. TN6785.

29 74 FR 66496. December 15, 2009. “Endangerment and Cause or Contribute Findings for
30 Greenhouse Gases Under Section 202(a) of the Clean Air Act.” *Federal Register*,
31 Environmental Protection Agency. TN245.

32 79 FR 56238. September 19, 2014. “Continued Storage of Spent Nuclear Fuel.” Final Rule,
33 *Federal Register*, Nuclear Regulatory Commission. TN4104.

34 84 FR 62559. November 15, 2019. “Agency Action Regarding the Exploratory Process for the
35 Development of an Advanced Nuclear Reactor Generic Environmental Impact Statement.”
36 *Federal Register*, Nuclear Regulatory Commission. TN6470.

1 85 FR 24040. April 30, 2020. "Notice To Conduct Scoping and Prepare an Advanced Nuclear
2 Reactor Generic Environmental Impact Statement." *Federal Register*, Nuclear Regulatory
3 Commission. TN6458.

4 89 FR 35442. May 1, 2024. "National Environmental Policy Act Implementing Regulations
5 Revisions Phase 2." Final Rule, *Federal Register*, Council on Environmental Quality.

6 33 U.S.C. § 1326. U.S. Code Title 33, *Navigation and Navigable Waters*, Section 1326,
7 "Thermal Discharges." TN4823.

8 33 U.S.C. § 1341. U.S. Code Title 33, *Navigation and Navigable Waters*, Chapter 26, "Water
9 Pollution Prevention and Control," Subchapter IV, *Permits and Licenses*, Section 1341
10 "Certification." TN4764.

11 33 U.S.C. § 1342. U.S. Code Title 33, *Navigation and Navigable Waters*, Chapter 26, "Water
12 Pollution Prevention and Control," Subchapter IV, *Permits and Licenses*, Section 1342,
13 "National Pollutant Discharge Elimination System." TN4765.

14 33 U.S.C. § 1344. U.S. Code Title 33, *Navigation and Navigable Waters*, Chapter 26, "Water
15 Pollution Prevention and Control," Subchapter IV, *Permits and Licenses*, Section 404 "Permits
16 for Dredged or Fill Material." TN1019.

17 42 U.S.C. § 4332. National Environmental Policy Act (NEPA) of 1969, Section 102,
18 "Cooperation of Agencies; Reports; Availability of Information; Recommendations; International
19 and National Coordination of Efforts." TN4880.

20 42 U.S.C. § 7412. Clean Air Act Section 112, "Hazardous Air Pollutants." TN7014.

21 42 U.S.C. § 7472. Clean Air Act Section 162, "Initial Classifications." TN6954.

22 42 U.S.C. § 7506. Clean Air Act Section 176, "Limitations on Certain Federal Assistance."
23 TN4856.

24 ABC (American Bird Conservancy). 2015. *Bird-Friendly Building Design*. The Plains, Virginia.
25 Accessed November 17, 2020, at [https://abcbirds.org/wp-content/uploads/2015/05/Bird-friendly-](https://abcbirds.org/wp-content/uploads/2015/05/Bird-friendly-Building-Guide_20151.pdf)
26 [Building-Guide_20151.pdf](https://abcbirds.org/wp-content/uploads/2015/05/Bird-friendly-Building-Guide_20151.pdf). TN6763.

27 Abella, S.R. 2010. "Disturbance and Plant Succession in the Mojave and Sonoran Deserts of
28 the American Southwest." *International Journal of Environmental Research and Public Health*
29 7:1248-1284. Basel, Switzerland. doi:10.3390/ijerph7041248. TN6722.

30 AEC (U.S. Atomic Energy Commission). 1972. *Environmental Survey of Transportation of*
31 *Radioactive Materials to and from Nuclear Power Plants*. WASH-1238, Washington, D.C.
32 ADAMS Accession No. ML14092A626. TN22.

33 AEC (U.S. Atomic Energy Commission). 1974. *Environmental Survey of the Uranium Fuel*
34 *Cycle*. WASH-1248, Washington, D.C. ADAMS Accession No. ML14092A628. TN23.

35 ANL (Argonne National Laboratory). 2016. "Argonne's Pyroprocessing and Advanced Reactor
36 Research Featured on WGN Radio." Nuclear Engineering Division, Lemont, Illinois. ADAMS
37 Accession No. ML21138A944. TN6831.

- 1 ANL (Argonne National Laboratory). 2017. "Nuclear Engineering Division, Reactors Designed
2 by Argonne National Laboratory: Integral Fast Reactor." Lemont, Illinois. ADAMS Accession No.
3 ML21139A088. TN6832.
- 4 APLIC (Avian Power Line Interaction Committee). 2006. *Suggested Practices for Avian
5 Protection on Power Lines: The State of the Art in 2006*. Edison Electric Institute, Washington,
6 D.C. ADAMS Accession No. ML12243A391. TN794.
- 7 APLIC (Avian Power Line Interaction Committee). 2012. *Reducing Avian Collisions with Power
8 Lines: The State of the Art in 2012*. Edison Electric Institute, Washington, D.C. Accessed
9 November 23, 2020, at
10 https://www.aplic.org/uploads/files/15518/Reducing_Avian_Collisions_2012watermarkLR.pdf.
11 TN6779.
- 12 APLIC and EEI (Avian Power Line Interaction Committee and Edison Electric Institute). 2018.
13 *Eagle Risk Framework: A Practical Approach for Power Lines*. Washington, D.C. Accessed
14 January 7, 2021, at [https://www.aplic.org/uploads/files/15798/APLICEagleRISKFramework-
15 APracticalApproachforPowerLines-December132018FinalwAppendixPUBLIC.pdf](https://www.aplic.org/uploads/files/15798/APLICEagleRISKFramework-APracticalApproachforPowerLines-December132018FinalwAppendixPUBLIC.pdf). TN6809.
- 16 ARPA-E (Advanced Research Projects Agency - Energy). 2022. "U.S. Department of Energy
17 Announces \$36 Million to Reduce Waste from Advanced Nuclear Reactors." Washington, D.C.
18 Accessed June 27, 2024, at [https://arpa-e.energy.gov/news-and-media/press-releases/us-
19 department-energy-announces-36-million-reduce-waste-advanced](https://arpa-e.energy.gov/news-and-media/press-releases/us-department-energy-announces-36-million-reduce-waste-advanced). TN10126.
- 20 ASLB (Atomic Safety and Licensing Board). 2007. "In the Matter of Dominion Nuclear North
21 Anna, LLC (Early Site Permit for North Anna ESP Site). Docket No. 52-008-ESP, ASLBP No.
22 04-822-02-ESP, Rockville, Maryland. ADAMS Accession No. ML091340693. TN6826.
- 23 Atomic Energy Act of 1954. 42 U.S.C. § 2011 et seq. Public Law 112-239, as amended. TN663.
- 24 Bald and Golden Eagle Protection Act. 16 U.S.C. § 668-668d et seq. TN1447.
- 25 U.S. Senate (United States Senate). 2019. Letter from J. Barrasso, M.D., Chairman Committee
26 on Environment and Public Works, and M. Braun, Chairman Subcommittee on Clean Air and
27 Nuclear Safety, to K.L. Svinicki, Chairman, U.S. Nuclear Regulatory Commission, dated June
28 25, 2019, regarding "We request you Initiate a Process to Develop a Generic Environmental
29 Impact Statement (GEIS) for the Construction and Operation of Advanced Nuclear Reactors."
30 Washington, D.C. ADAMS Accession No. ML19176A444. TN6465.
- 31 Biber, B.M., F.A. Monette, and S.Y. Chen. 1996. *Risk Assessment for the On-Site
32 Transportation of Radioactive Wastes for the U.S. Department of Energy Waste Management
33 Programmatic Environmental Impact Statement*. ANL/EAD/TM-18, Argonne National
34 Laboratory, Argonne, Illinois. ADAMS Accession No. ML21139A339. TN6502.
- 35 BLM (Bureau of Land Management). 1984. *Visual Resource Management*. Manual 8400,
36 Washington, D.C. ADAMS Accession No. ML12237A194. TN5536.
- 37 BLM (Bureau of Land Management). 1986. *Visual Resource Contrast Rating*. Manual H-8431-1,
38 Washington, D.C. ADAMS Accession No. ML13035A024. TN6403.

1 Boulinier, T., J.D. Nichols, J.E. Hines, J.R. Sauer, C.H. Flather, and K.H. Pollock. 2001. "Forest
2 Fragmentation and Bird Community Dynamics: Inference at Regional Scales." *Ecology*
3 82(4):1159-1169. Washington, D.C. TN6724.

4 Brinson, M.M., F.R. Hauer, L.C. Lee, W.L. Nutter, R.D. Rheinhardt, R.D. Smith, and D.
5 Whigham. 1995. *A Guidebook for Application of Hydrogeomorphic Assessments to Riverine*
6 *Wetlands*. WRP-DE-11. Vicksburg, Mississippi. ADAMS Accession No. ML21139A346. TN6969.

7 Busby, J., L. Garrison, L. Lin, S. Raiman, S. Sham, C. Silva, and H. Wang. 2019. *Technical Gap*
8 *Assessment for Materials and Component Integrity Issues for Molten Salt Reactors*.
9 ORNL/SPR-2019/1089, Oak Ridge National Laboratory, Oak Ridge, Tennessee. ADAMS
10 Accession No. ML19077A137. TN6695.

11 BWXT (BWXT Technologies, Inc.). 2020. "BWXT Accomplishes Restart of TRISO." *News*,
12 November 10, 2020. Lynchburg, Virginia. Webpage accessed November 16, 2020, at
13 [https://www.bwxt.com/news/2020/11/10/BWXT-Accomplishes-Restart-of-TRISO-Nuclear-Fuel-](https://www.bwxt.com/news/2020/11/10/BWXT-Accomplishes-Restart-of-TRISO-Nuclear-Fuel-Manufacturing)
14 [Manufacturing](https://www.bwxt.com/news/2020/11/10/BWXT-Accomplishes-Restart-of-TRISO-Nuclear-Fuel-Manufacturing). TN6756.

15 BWXT (BWXT Technologies, Inc.). 2022. "BWXT Starts Production of TRISO Fuel for First U.S.
16 Generation IV Microreactor." Lynchburg, Virginia. Accessed July 2, 2024, at
17 [https://www.bwxt.com/news/2022/12/07/BWXT-Starts-Production-of-TRISO-Fuel-for-First-US-](https://www.bwxt.com/news/2022/12/07/BWXT-Starts-Production-of-TRISO-Fuel-for-First-US-Generation-IV-Microreactor)
18 [Generation-IV-Microreactor](https://www.bwxt.com/news/2022/12/07/BWXT-Starts-Production-of-TRISO-Fuel-for-First-US-Generation-IV-Microreactor). TN10154.

19 Carmignani, J.R. and A.H. Roy. 2017. "Ecological Impacts of Winter Water Level Drawdowns on
20 Lake Littoral Zones: A Review." *Aquatic Sciences* 79:803-824, Switzerland.
21 <https://doi.org/10.1007/s00027-017-0549-9>. TN6795.

22 CEC (Centrus Energy Corp.). 2023. "Centrus Makes First HALEU Delivery to U.S. Department
23 of Energy." Bethesda, Maryland. Accessed July 1, 2024, at
24 [https://www.centrusenergy.com/news/centrus-makes-first-haleu-delivery-to-u-s-department-of-](https://www.centrusenergy.com/news/centrus-makes-first-haleu-delivery-to-u-s-department-of-energy/)
25 [energy/](https://www.centrusenergy.com/news/centrus-makes-first-haleu-delivery-to-u-s-department-of-energy/). TN10144.

26 CEQ (Council on Environmental Quality). 2016. Memorandum from C. Goldfuss to Heads of
27 Federal Departments and Agencies, dated August 1, 2016, regarding "Final Guidance for
28 Federal Departments and Agencies on Consideration of Greenhouse Gas Emissions and the
29 Effects of Climate Change in National Environmental Policy Act Reviews." Washington, D.C.
30 ADAMS Accession No. ML16266A244. TN4732.

31 CEQ and ACHP (Council on Environmental Quality and Advisory Council on Historic
32 Preservation). 2013. *NEPA and NHPA: A Handbook for Integrating NEPA and Section 106*.
33 Washington, D.C. ADAMS Accession No. ML14172A044. TN4603.

34 Clean Air Act. 42 U.S.C. § 7401 *et seq.* TN1141.

35 Clean Air Act, Part D. 42 U.S.C. Part D. "Plan Requirements for Nonattainment Areas." TN6972.

36 ClearPath. 2019. Letter from R. Powell, to NRC, dated February 19, 2019, regarding "Advanced
37 Nuclear Environmental Permitting Reform." Washington, D.C. ADAMS Accession No.
38 ML19059A426. TN6466.

- 1 Cloern, J.E., A.D. Jassby, T.S. Schraga, E. Nejad, and C. Martin. 2017. "Ecosystem Variability
2 Along the Estuarine Salinity Gradient: Examples from Long-term Study of San Francisco Bay."
3 *Limnology and Oceanography* 62:S272-S291, Waco, Texas. TN6967.
- 4 Coastal Zone Management Act of 1972. 16 U.S.C. § 1451 *et seq.* TN1243.
- 5 Comprehensive Environmental Response, Compensation, and Liability Act, as amended. 42
6 U.S.C. § 9601 *et seq.* TN6592.
- 7 ConverDyn. 2020. "ConverDyn." Presented at the GAIN/EPRI/NEI HALEU Webinar, April 28-29,
8 2020, Idaho National Laboratory, Idaho Falls, Idaho. Greenwood Village, Colorado. Accessed
9 October 16, 2020, at [https://gain.inl.gov/HALEU_Webinar_Presentations/10-
10 Critchley,ConverDyn,Rev1-28Apr2020.pdf](https://gain.inl.gov/HALEU_Webinar_Presentations/10-Critchley,ConverDyn,Rev1-28Apr2020.pdf). TN6657.
- 11 Cowan, J.P. 1994. *Handbook of Environmental Acoustics*. John Wiley & Sons, Inc., New York,
12 New York. TN3905.
- 13 Critical Area Commission (Critical Area Commission for the Chesapeake and Atlantic Coastal
14 Bays). 2000. *A Guide to the Conservation of Forest Interior Dwelling Birds in the Chesapeake
15 Bay Critical Area*. Annapolis, Maryland. Accessed October 1, 2020, at
16 https://dnr.maryland.gov/criticalarea/Documents/forms_navbar/tweetyjune_2000.pdf. TN6564.
- 17 DOD (U.S. Department of Defense). 2004. *Unified Facilities Criteria: Dewatering and
18 Groundwater Control*. UFC 3-220-05, Washington, D.C. ADAMS Accession No. ML21140A407.
19 TN6814.
- 20 DOE (U.S. Department of Energy). 1997. *Final Waste Management Programmatic
21 Environmental Impact Statement*. DOE/EIS-0200-F, Volume 1, Washington, D.C. ADAMS
22 Accession No. ML21141A331. TN6752.
- 23 DOE (U.S. Department of Energy). 2000. *Final Environmental Impact Statement for the
24 Treatment and Management of Sodium-Bonded Spent Nuclear Fuel - Summary*. DOE/EIS-
25 0306, Summary, Washington, D.C. ADAMS Accession No. ML21140A434. TN6834.
- 26 DOE (U.S. Department of Energy). 2002. *A Graded Approach for Evaluating Radiation Doses to
27 Aquatic and Terrestrial Biota*. DOE-STD-1153-2002, Washington, D.C. ADAMS Accession No.
28 ML21140A436. TN4551.
- 29 DOE (U.S. Department of Energy). 2002. *Final Environmental Impact Statement for a Geologic
30 Repository for the Disposal of Spent Nuclear Fuel and High-Level Radioactive Waste at Yucca
31 Mountain, Nye County, Nevada*. DOE/EIS-0250, Office of Civilian Radioactive Waste
32 Management, Washington, D.C. ADAMS Accession No. ML14024A327. TN1236.
- 33 DOE (U.S. Department of Energy). 2004. *RESRAD-BIOTA: A Tool for Implementing a Graded
34 Approach to Biota Dose Evaluation*. ISCORS Technical Report 2004-02, Interagency Steering
35 Committee on Radiation Standards, Washington, D.C. ADAMS Accession No. ML21140A412.
36 TN6460.
- 37 DOE (U.S. Department of Energy). 2019. *Environmental Assessment for Use of DOE-Owned
38 High-Assay Low-Enriched Uranium Stored at Idaho National Laboratory*. DOE/EA-2087,
39 Washington, D.C. ADAMS Accession No. ML21140A414. TN6757.

- 1 DOE (U.S. Department of Energy). 2019. "TRISO Particles: The Most Robust Nuclear Fuel on
2 Earth." Office of Nuclear Energy, Washington, D.C. ADAMS Accession No. ML21140A413.
3 TN6786.
- 4 DOE (U.S. Department of Energy). 2019. *Wetland Assessment for Proposed Tennessee Valley
5 Authority Substation and Associated Transmission Lines at the Paducah Gaseous Diffusion
6 Plant Site, Paducah, Kentucky*. DOE/LX/07-2441, Washington, D.C. ADAMS Accession No.
7 ML21140A423. TN6749.
- 8 DOE (U.S. Department of Energy). 2020. "DOE-ID NEPA CX Determination, Idaho National
9 Laboratory: TRISO Fuel Production Capability." Revision 3, DOE-ID-INL-20-004 R3, Idaho
10 Falls, Idaho. ADAMS Accession No. ML21140A426. TN6735.
- 11 DOE (U.S. Department of Energy). 2023. "Spent Nuclear Fuel from this Retired Government
12 Reactor is Getting a Second Life." Washington, D.C. Accessed July 2, 2024, at
13 [https://www.energy.gov/ne/articles/spent-nuclear-fuel-retired-government-reactor-getting-
14 second-life](https://www.energy.gov/ne/articles/spent-nuclear-fuel-retired-government-reactor-getting-second-life). TN10160.
- 15 DOE (U.S. Department of Energy). 2024. "Biden-Harris Administration Enacts Law Banning
16 Importation of Russian Uranium." Washington, D.C. Accessed July 1, 2024, at
17 [https://www.energy.gov/articles/biden-harris-administration-enacts-law-banning-importation-
18 russian-uranium](https://www.energy.gov/articles/biden-harris-administration-enacts-law-banning-importation-russian-uranium). TN10150.
- 19 DOE (U.S. Department of Energy). 2024. "HALEU Availability Program." Washington, D.C.
20 Accessed March 1, 2024, at <https://www.energy.gov/ne/haleu-availability-program>. TN9790.
- 21 DOE (U.S. Department of Energy). 2024. "Manifest Information Management System, Waste
22 Disposed at Energy Solutions Clive Utah Facility Not in MIMS Database Scope (Cubic Feet)."
23 Washington, D.C. TN10120.
- 24 DOE (Department of Energy). Undated. "Paducah Environmental Remediation." Lexington,
25 Kentucky. Accessed July 1, 2024, at [https://www.energy.gov/pppo/paducah-environmental-
26 remediation](https://www.energy.gov/pppo/paducah-environmental-remediation). TN10149.
- 27 DOE (Department of Energy). Undated. "Portsmouth Cleanup." Lexington, Kentucky. Accessed
28 July 1, 2024, at <https://www.energy.gov/pppo/portsmouth-cleanup>. TN10148.
- 29 DOE/EIA (U.S. Department of Energy/Energy Information Administration). 2023. "Electricity
30 Explained: Electricity Generation, Capacity, and Sales in the United States." Washington, D.C.
31 Accessed Jun 30, 2024, at [https://www.eia.gov/energyexplained/electricity/electricity-in-the-us-
32 generation-capacity-and-sales.php](https://www.eia.gov/energyexplained/electricity/electricity-in-the-us-generation-capacity-and-sales.php). TN10133.
- 33 DOE/EIA (U.S. Department of Energy/Energy Information Administration). 2020. "Form EIA-860
34 Detailed Data with Previous Form Data (EIA-860A/860B)." Final 2019 Data, Washington, D.C.
35 ADAMS Accession No. ML21141A320. TN6653.
- 36 DOE/EIA (U.S. Department of Energy/Energy Information Administration). 2024. *2023
37 Domestic Uranium Production Report, May 2024*. Washington, D.C. Accessed July 1, 2024, at
38 <https://www.eia.gov/uranium/production/annual/pdf/dupr2023.pdf>. TN10141.

- 1 DOT (U.S. Department of Transportation). 2013. *National Transportation Statistics 2013*.
2 Bureau of Transportation Statistics, Washington, D.C. ADAMS Accession No. ML14308A122.
3 TN3930.
- 4 DOT (U.S. Department of Transportation). 2015. Letter from A.R. Foxx, to multiple government
5 recipients, dated November 24, 2015, regarding “Report to Congress, *Compilation of Existing*
6 *State Truck Size and Weight Limit Laws*.” Washington, D.C. ADAMS Accession No.
7 ML21140A437. TN6753.
- 8 DOT (U.S. Department of Transportation). 2017. “Construction Equipment Noise Levels and
9 Ranges.” Chapter 9 in *Construction Noise Handbook*. Federal Highway Administration,
10 Washington, D.C. ADAMS Accession No. ML18059A141. TN5383.
- 11 DOT (U.S. Department of Transportation). 2017. “Highway Traffic Noise Analysis and
12 Abatement Policy and Guidance.” Federal Highway Administration, Washington, D.C. ADAMS
13 Accession No. ML13023A373. TN6567.
- 14 Driscoll, F.G. 1986. *Groundwater and Wells*. Johnson Screens, St. Paul, Minnesota. ADAMS
15 Accession No. ML14237A631. TN6823.
- 16 EBRD (European Bank for Reconstruction and Development). Undated. *Sub-sectoral*
17 *Environmental and Social Guidelines: Metal Fabrication*. London, United Kingdom. Accessed
18 March 5, 2021, at [https://www.ebrd.com/downloads/policies/environmental/metal/metal-](https://www.ebrd.com/downloads/policies/environmental/metal/metal-fabrication.pdf)
19 [fabrication.pdf](https://www.ebrd.com/downloads/policies/environmental/metal/metal-fabrication.pdf). TN6941.
- 20 Eidelpes, E., J.J. Jarrell, H.E. Adkins, B.M. Hom, J.M. Scaglione, R.A. Hall, and B.D. Brickner.
21 2019. *UO2 HALEU Transportation Package Evaluation and Recommendations*. INL/EXT-19-
22 56333, Revision 1, Idaho National Laboratory, Idaho Falls, Idaho. ADAMS Accession No.
23 ML21141A321. TN6507.
- 24 Endangered Species Act of 1973. 16 U.S.C. § 1531 *et seq.* TN1010.
- 25 Engel, E.C. and S.R. Abella. 2011. “Vegetation Recovery in a Desert Landscape after Wildfires:
26 Influences of Community Type, Time Since Fire and Contingency Effects.” *Journal of Applied*
27 *Ecology* 48:1401–1410. London, England. doi: 10.1111/j.1365-2664.2011.02057.x. TN6721.
- 28 EPA (U.S. Environmental Protection Agency). 1994. *Evaluation Of Ecological Impacts From*
29 *Highway Development*. EPA 300-8-94-006, Washington, D.C. ADAMS Accession No.
30 ML21141A332. TN6748.
- 31 EPA (U.S. Environmental Protection Agency). 1996. *An Assessment of the Ecological Impacts*
32 *of Ground Water Overdraft on Wetlands and Riparian Areas in the United States*. EPA 813-S-
33 96-001, Washington, D.C. ADAMS Accession No. ML21141A333. TN6800.
- 34 EPA (U.S. Environmental Protection Agency). 2016. “New Source Review (NSR) Permitting-
35 Learn About New Source Review.” Washington, D.C. ADAMS Accession No. ML21141A335.
36 TN6970.
- 37 EPA (U.S. Environmental Protection Agency). 2018. “Electricity Delivery and its Environmental
38 Impacts.” Washington, D.C. ADAMS Accession No. ML21141A336. TN6747.

- 1 EPA (U.S. Environmental Protection Agency). 2019. "How is Mixed Waste Regulated?"
2 Washington, D.C. ADAMS Accession No. ML21141A337. TN6956.
- 3 EPA (U.S. Environmental Protection Agency). 2020. "Categories of Hazardous Waste
4 Generators." Washington, D.C. ADAMS Accession No. ML21141A344. TN6590.
- 5 EPA (U.S. Environmental Protection Agency). 2020. "Frequent Questions about General
6 Conformity." Washington, D.C. ADAMS Accession No. ML21141A339. TN6773.
- 7 EPA (U.S. Environmental Protection Agency). 2020. "General Conformity De Minimis Tables."
8 Washington, D.C. ADAMS Accession No. ML21141A338. TN6774.
- 9 EPA (U.S. Environmental Protection Agency). 2020. "History of the Resource Conservation and
10 Recovery Act (RCRA). Washington, D.C. ADAMS Accession No. ML21141A347. TN6963.
- 11 EPA (U.S. Environmental Protection Agency). 2020. "NAAQS Designations Process."
12 Washington, D.C. ADAMS Accession No. ML21141A341. TN6772.
- 13 EPA (U.S. Environmental Protection Agency). 2021. "Overview of EPA's Brownfields Program."
14 Washington, D.C. ADAMS Accession No. ML21141A345. TN6848.
- 15 EPA (U.S. Environmental Protection Agency). 2024. "Current Nonattainment Counties for All
16 Criteria Pollutants." EPA Green Book, Data Current as of May 31, 2024. Washington, D.C.
17 TN10122.
- 18 EPA (U.S. Environmental Protection Agency). 2024. *Inventory of U.S. Greenhouse Gas
19 Emissions and Sinks: 1990-2012*. EPA 430-R-24-004, Washington, D.C. Accessed June 27,
20 2024, at [https://www.epa.gov/system/files/documents/2024-04/us-ghg-inventory-2024-main-
21 text_04-18-2024.pdf](https://www.epa.gov/system/files/documents/2024-04/us-ghg-inventory-2024-main-text_04-18-2024.pdf). TN10121.
- 22 EPRI (Electric Power Research Institute). 2015. *Advanced Nuclear Technology: Site Selection
23 and Evaluation Criteria for New Nuclear Power Generation Facilities (Siting Guide)*. Palo Alto,
24 California. TN5285.
- 25 FAA (Federal Aviation Administration). 2020. *Advisory Circular, Obstruction Marking and
26 Lighting*. AC 70/7460-1M, Washington, D.C. TN10130.
- 27 Farmland Protection Policy Act of 1981. 7 U.S.C. § 4201 *et seq.* TN708.
- 28 FCC (Federal Communications Commission). 2017. *Opportunities to Reduce Bird Collisions
29 with Communications Towers While Reducing Tower Lighting Costs*. Washington D.C.
30 Accessed June 28, 2024, at
31 https://www.fcc.gov/sites/default/files/Light_Changes_Information_Update_Jan_2017.pdf.
32 TN10131.
- 33 Federal Insecticide, Fungicide, and Rodenticide Act, as amended. 7 U.S.C. § 136 *et seq.*
34 TN4535.
- 35 Federal Water Pollution Control Act of 1972 (commonly referred to as the Clean Water Act). 33
36 U.S.C. § 1251 *et seq.* TN662.

1 FHWA (Federal Highway Administration). 2017. *Evolving Use of Level of Service Metrics in*
2 *Transportation Analysis: Introduction*. U.S. Department of Transportation, Washington, D.C.
3 ADAMS Accession No. ML21145A247. TN6585.

4 FHWA (Federal Highway Administration). 2018. *Traffic Data Computation Method Pocket*
5 *Guide*. Publication No. FHWA-PL-18-027, U.S. Department of Transportation, Washington, D.C.
6 ADAMS Accession No. ML21145A249. TN6584.

7 Fiscal Responsibility Act of 2023. 2 U.S.C. § 900 Note. Public Law 118-5. TN9775.

8 Fischer, L.E., C.K. Chou, M.A. Gerhard, C.Y. Kimura, R.W. Martin, R.W. Mensing, M.E. Mount,
9 and M.C. Witte. 1987. Shipping Container Response to Severe Highway and Railway Accident
10 Conditions. NUREG/CR-4829, Lawrence Livermore National Laboratory, Livermore, California.
11 ADAMS Accession Nos. ML070810403, ML070810404. TN4105.

12 Flanagan, G. 2017. "Module 8: Fuel Cycle and Safeguards." Oak Ridge National Laboratory,
13 Oak Ridge, Tennessee. Presentation to NRC, November 6-7, 2017, Washington, D.C. ADAMS
14 Accession No. ML17331B121. TN6742.

15 Forman, R.T.T. and L.E. Alexander. 1998. "Roads and their Major Ecological Effects." *Annual*
16 *Review of Ecology, Evolution and Systematics* 29:207–231, Palo Alto, California. TN2250.

17 Fort, J.A., J.M. Cuta, and H.E. Adkins, Jr. 2017. *A Compendium of Spent Fuel Transportation*
18 *Package Response Analyses to Severe Fire Accident Scenarios*. NUREG/CR-7209, Pacific
19 Northwest National Laboratory, Richland, Washington. ADAMS Accession No. ML17066A101.
20 TN6692.

21 Frank, S., W. Ebert, B. Riley, H. Seo Park, Y. Zun Cho, C. Hwa Lee, M. Ku Jeon, J. Hwan Yang,
22 and H. Chul Eun. 2015. *Waste Stream Treatment and Waste Form Fabrication for*
23 *Pyroprocessing of Used Nuclear Fuel*. INL/EXT-14-34014, Idaho National Laboratory, Idaho
24 Falls, Idaho. ADAMS Accession No. ML21145A336. TN6833.

25 Freeze, R.A. and J.A. Cherry. 1979. *Groundwater*. Prentice-Hall, Inc., Upper Saddle River, New
26 Jersey. TN3275.

27 FRWG (Fast Reactor Working Group). 2018. *Nuclear Metal Fuel: Characteristics, Design,*
28 *Manufacturing, Testing, and Operating History*. White Paper 18-01, Washington, D.C. ADAMS
29 Accession No. ML18165A24. TN6696.

30 FWS (U.S. Fish and Wildlife Service). 2013. *2013 U.S. Fish and Wildlife Service (USFWS)*
31 *Revised Voluntary Guidelines for Communication Tower Design, Siting, Construction,*
32 *Operation, Retrofitting, and Decommissioning*. Arlington, Virginia. ADAMS Accession No.
33 ML21145A445. TN6764.

34 FWS (U.S. Fish and Wildlife Service). 2014. "Why Care About Sagebrush?" Denver, Colorado.
35 ADAMS Accession No. ML21145A438. TN6731.

36 GAO (U.S. Government Accountability Office). 2013. *Managing Critical Isotopes, Stewardship of*
37 *Lithium-7 Is Needed to Ensure a Stable Supply*. Washington, D.C. ADAMS Accession No.
38 ML21145A251. TN6960.

- 1 Gehring, J., P. Kerlinger, and A.M. Manville, II. 2011. "The Role of Tower Height and Guy Wires
2 on Avian Collisions With Communication Towers." *The Journal of Wildlife Management*
3 75(4):848–855, Malden, Massachusetts. DOI: 10.1002/jwmg.99. TN6581.
- 4 Griego, N.R., J.D. Smith, and K.S. Neuhauser. 1996. *Investigation of RADTRAN Stop Model*
5 *Input Parameters for Truck Stops*. Sandia National Laboratories, Albuquerque, New Mexico.
6 ADAMS Accession No. ML14111A188. TN69.
- 7 Haddad, N.M., L.A. Brudvig, G. Clobert, K.F. Davies, A. Gonzalez, R.D. Holt, T.E. Lovejoy, J.O.
8 Sexton, M.P. Austin, C.D. Collins, W.M. Cook, E.I. Damschen, R.M. Ewers, and others. 2015.
9 "Habitat Fragmentation and its Lasting Impact on Earth's Ecosystems." *Science Advances* 1(2):
10 e1500052, Washington, D.C. DOI: 10.1126/sciadv.1500052. TN6563.
- 11 Hathcock, C.D., D.C. Keller, and B.E. Thompson. 2017. *Threatened and Endangered Species*
12 *Habitat Management Plan for Los Alamos National Laboratory*. LA-UR-17-29454, Los Alamos
13 National Laboratory, Los Alamos, New Mexico. ADAMS Accession No. ML21145A437. TN6789.
- 14 Hennebach, M. and A. Langston. 2020. "Current and Future Packaging Designs for Shipping
15 ATF and HALEU Fuel Materials." Presented at the GAIN/EPRI/NEI HALEU Webinar, April 28-
16 29, 2020, Idaho National Laboratory, Idaho Falls, Idaho. Greenwood Village, Colorado. ADAMS
17 Accession No. ML21145A246. TN6693.
- 18 Hill, M.T., W.S. Platts, and R.L. Beschta. 1991. "Ecological and Geomorphological Concepts for
19 Instream and Out-of-Channel Flow Requirements." *Rivers* 2(3):198-210. Accessed December 4,
20 2020, at <http://www.nativefishlab.net/library/textpdf/20402.pdf>. TN6791.
- 21 Holcomb, D.E., G.F. Flanagan, B.W. Patton, J.C. Gehin, R.L. Howard, and T.J. Harrison. 2011.
22 *Fast Spectrum Molten Salt Reactor Options*. ORNL/TM-2011/105, Oak Ridge National
23 Laboratory, Oak Ridge, Tennessee. ADAMS Accession No. ML21145A408. TN6943.
- 24 IAEA (International Atomic Energy Agency). 1992. *Effects of Ionizing Radiation on Plants and*
25 *Animals at Levels Implied by Current Radiation Protection Standards*. Technical Report Series
26 332, Vienna, Austria. TN712.
- 27 IAEA (International Atomic Energy Agency). 2020. *Advances in Small Modular Reactor*
28 *Technology Developments A Supplement to: IAEA Advanced Reactors Information System*
29 *(ARIS)*. Vienna, Austria. Accessed March 20, 2021, at
30 https://aris.iaea.org/Publications/SMR_Book_2020.pdf. TN6953.
- 31 ICNIRP (International Commission on Non-Ionizing Radiation Protection). 1998. "Guidelines for
32 Limiting Exposure to Time-Varying Electric, Magnetic, and Electromagnetic Fields (up to 300
33 GHz)." *Health Physics* 74 (4): 494-522, Philadelphia, Pennsylvania. Accessed October 7, 2020,
34 at <https://www.icnirp.org/cms/upload/publications/ICNIRPemfgdl.pdf>. TN6591.
- 35 ICRP (International Commission on Radiological Protection). 2007. "The 2007
36 Recommendations of the International Commission on Radiological Protection." ICRP
37 Publication 103, *Ann. ICRP*, 37(2-4). Amsterdam, The Netherlands. Elsevier. Available at
38 http://journals.sagepub.com/doi/pdf/10.1177/ANIB_37_2-4. TN422.
- 39 IDAPA 58.01.02. *Idaho Administrative Code*, Title 58, *Department of Environmental Quality*,
40 58.01.02, "Water Quality Standards." TN7040.

1 IEEE (Institute of Electrical and Electronics Engineers). 2023. *2023 National Electrical Safety*
2 *Code® (NESC®)*. C2-2023, Piscataway, New Jersey. TN10132.

3 INL (Idaho National Laboratory). 2019. "Hybrid Zirconium Extraction (ZIRCEX) Process
4 Factsheet." 19-50467-05_R3, Gateway for Accelerated Innovation in Nuclear, Idaho Falls,
5 Idaho. ADAMS Accession No. ML21145A258. TN6758.

6 INL (Idaho National Laboratory). 2020. "Frequently Asked Questions: Research Quantities of
7 Commercial Nuclear Fuels." Idaho Falls, Idaho. ADAMS Accession No. ML21145A260.
8 TN6500.

9 IPCC (Intergovernmental Panel on Climate Change). 2023. *Climate Change 2023: Synthesis*
10 *Report*. Core Writing Team, H. Lee and J. Romero, eds. Geneva, Switzerland. doi:
11 10.59327/IPCC/AR6-9789291691647. TN10123.

12 Jarrell, J. 2018. *A Proposed Path Forward for Transportation of High-Assay Low-Enriched*
13 *Uranium*. INL/EXT-18-51518, Revision 1, Idaho National Laboratory, Idaho Falls, Idaho.
14 ADAMS Accession No. ML21140A414. TN6508.

15 Jarrell, J. and E. Eidelpes. 2020. "DOE's Initial Approach for Large-Volume UO₂ Transport."
16 Presented at the GAIN/EPRI/NEI HALEU Webinar, April 28-29, 2020, Idaho National
17 Laboratory, Idaho Falls, Idaho. Greenwood Village, Colorado, April 28-29, 2020. ADAMS
18 Accession No. ML21145A254. TN6694.

19 Kendy, E., C. Apse, and K. Blann. 2012. *A Practical Guide to Environmental Flows for Policy*
20 *and Planning*. The Nature Conservancy, Arlington, Virginia. Accessed December 4, 2020, at
21 [https://www.conservationgateway.org/ConservationByGeography/NorthAmerica/UnitedStates/e](https://www.conservationgateway.org/ConservationByGeography/NorthAmerica/UnitedStates/ed/Documents/ED_freshwater_envflows_Practical%20Guide%20Eflows%20for%20Policy.pdf)
22 [dc/Documents/ED_freshwater_envflows_Practical%20Guide%20Eflows%20for%20Policy.pdf](https://www.conservationgateway.org/ConservationByGeography/NorthAmerica/UnitedStates/ed/Documents/ED_freshwater_envflows_Practical%20Guide%20Eflows%20for%20Policy.pdf).
23 TN6793.

24 Kerlinger, P., J. Guarnaccia, A. Hasch, R.C.E. Culver, R.C. Curry, L. Tran, M.J. Stewart, and D.
25 Riser-Espinoza. 2012. "Avian Collision Mortality at 50- and 60-M Guyed Towers in Central
26 California." *The Condor* 114(3):462–469, Washington, D.C. TN4401.

27 Knick, S.T. and J.T. Rotenberry. 1995. "Landscape Characteristics of Fragmented Shrubsteppe
28 Habitats and Breeding Passerine Birds." *Conservation Biology* 9(5):1059-1071, Washington,
29 D.C. TN6728.

30 Knick, S.T. and J.T. Rotenberry. 2002. "Effects of Habitat Fragmentation on Passerine Birds in
31 Intermountain Shrubsteppe." *Studies in Avian Biology* 25:130-140, Chicago, Illinois. Accessed
32 November 6, 2020, at <https://pubs.er.usgs.gov/publication/70024065>. TN6729.

33 LaHaye, N.L. and D.E. Burkes. 2019. *Metal Fuel Fabrication Safety and Hazards, TO NRC-HQ-*
34 *25-17-T-005, Non-LWR LTD2*. PNNL-28622, Pacific Northwest National Laboratory. ADAMS
35 Accession No. ML19193A057. TN6961.

36 Langeland, K.A. and L.A. Gettys. 2015. *Safe Use of Glyphosate-Containing Products in Aquatic*
37 *and Upland Natural Areas*. SS-AGR-104, University of Florida IFAS Extension, Gainesville,
38 Florida. Accessed August 10, 2020, at <https://edis.ifas.ufl.edu/pdf/AG/AG24800.pdf>.
39 TN6461.

- 1 Longcore, T., C. Rich, and S.A. Gauthreaux, Jr. 2008. "Height, Guy Wires, and Steady-Burning
2 Lights Increase Hazard of Communication Towers to Nocturnal Migrants: A Review and Meta-
3 Analysis." *The Auk* 125(2):485–492, Chicago, Illinois. TN4398.
- 4 Longcore, T., C. Rich, P. Mineau, B. MacDonald, D.G. Bert, L.M. Sullivan, E. Mutrie, S.A.
5 Gauthreaux, Jr., M.L. Avery, R.L. Crawford, A.M. Manville, II, E.R. Travis, and D. Drake. 2013.
6 "Avian Mortality at Communication Towers in the United States and Canada: Which Species,
7 How Many, and Where?" *Biological Conservation* 158:410–419, New York, New York. TN4399.
- 8 Loss, S.R., T. Will, S.S. Loss, and P.P. Marra. 2014. "Bird–Building Collisions in the United
9 States: Estimates of Annual Mortality and Species Vulnerability." *The Condor: Ornithological*
10 *Applications* 116:8–23, Chicago, Illinois. DOI: 10.1650/CONDOR-13-090.1. TN6568.
- 11 Loss, S.R., T. Will, and P.P. Marra. 2014. "Refining Estimates of Bird Collision and Electrocution
12 Mortality at Power Lines in the United States." *Plos One* 9(7): e101565, San Francisco,
13 California. TN9396.
- 14 Low-Level Radioactive Waste Policy Act of 1980. 42 U.S.C. § 2021b *et seq.* Public Law 96-573.
15 TN6606.
- 16 Low-Level Radioactive Waste Policy Amendments Act of 1985, as amended. Public Law 99–
17 240, 99 Stat. 1842. TN6517.
- 18 Lynch, J.F. 1987. "Responses of Breeding Bird Communities to Forest Fragmentation." Chapter
19 10 in: Aunders, D.A., G.W. Arnold, A.A. Burbidge, and A.J.M. Hopkins, eds. *Nature*
20 *Conservation: The Role of Remnants of Native Vegetation*. Surrey Beatty & Sons Pty Limited,
21 Chipping Norton, Australia. TN6726.
- 22 Magnuson-Stevens Fishery Conservation and Management Act, Public Law 94-265, as
23 amended through October 11, 1996. 16 U.S.C. § 1801 *et seq.* TN1061.
- 24 Maheras, S.J. 2020. *Environmental Impacts from Transportation of Fuel and Wastes to and*
25 *from Non-LWRs*. PNNL-29365, Pacific Northwest National Laboratory, Richland, Washington.
26 ADAMS Accession No. ML20267A157. TN6509.
- 27 Manier, D.J., Z.H. Bowen, M.L. Brooks, M.L. Casazza, P.S. Coates, P.A. Deibert, S.E. Hanser,
28 and D.H. Johnson. 2014. *Conservation Buffer Distance Estimates for Greater SageGrouse—A*
29 *Review*. Open-File Report 2014–1239, Reston, Virginia. ADAMS Accession No. ML21145A446.
30 TN6746.
- 31 MBWSR (Minnesota Board of Water & Soil Resources). 2016. "Wetland Impacts from
32 Groundwater Withdrawals." March 2016 Snapshots, St. Paul, Minnesota. Accessed December
33 9, 2020, at [https://bwsr.state.mn.us/sites/default/files/2019-
34 01/March%202016%20Snapshot%20%234%20Groundwater.pdf](https://bwsr.state.mn.us/sites/default/files/2019-01/March%202016%20Snapshot%20%234%20Groundwater.pdf). TN6801.
- 35 McAuliffe, J.R. 1988. "Markovian Dynamics of Simple and Complex Desert Plant Communities."
36 *The American Naturalist* 131(4):459-490. Chicago, Illinois. TN6723.
- 37 McFarlane, J., P. Taylor, D. Holcomb, and W.P. Poore. 2019. *Review of Hazards Associated*
38 *with Molten Salt Reactor Fuel Processing Operations*. ORNL/TM-2019/1195, Oak Ridge
39 National Laboratory, Oak Ridge, Tennessee. ADAMS Accession No. ML19205A386. TN6741.

1 Monette, F.A., B.M. Biber, D.J. LePoire, M.A. Lazaro, A.A. Antonopoulos, H.M. Hartmann, A.J.
2 Policastro, and S.Y. Chen. 1995. *Supplemental Information Related to Risk Assessment for the*
3 *Off-Site Transportation of Low-Level Mixed Waste for the U.S. Department of Energy Waste*
4 *Management Programmatic Environmental Impact Statement*. ANL/EAD/TM-35 (Draft),
5 Argonne National Laboratory, Argonne, Illinois. ADAMS Accession No. ML21139A343. TN6505.

6 Monette, F.A., B.M. Biber, D.J. LePoire, and S.Y. Chen. 1995. *Supplemental Information*
7 *Related to Risk Assessment for the Off-Site Transportation of Low-Level Waste for the U.S.*
8 *Department of Energy Waste Management Programmatic Environmental Impact Statement*.
9 ANL/EAD/TM-23 (Draft), Argonne National Laboratory, Argonne, Illinois. ADAMS Accession No.
10 ML21142A000. TN6506.

11 Monette, F.A., B.M. Biber, D.J. LePoire, and S.Y. Chen. 1996. *Risk Assessment for the Off-Site*
12 *Transportation of High-Level Waste for the U.S. Department of Energy Waste Management*
13 *Programmatic Environmental Impact Statement*. ANL/EAD/TM-21, Argonne National
14 Laboratory, Argonne, Illinois. ADAMS Accession No. ML21139A340. TN6501.

15 Monette, F.A., B.M. Biber, D.J. LePoire, and S.Y. Chen. 1996. *Supplemental Information*
16 *Related to Risk Assessment for the Off-Site Transportation of Transuranic Waste for the U.S.*
17 *Department of Energy Waste Management Programmatic Environmental Impact Statement*.
18 ANL/EAD/TM-27, Argonne National Laboratory, Argonne, Illinois. ADAMS Accession No.
19 ML21139A341. TN6503.

20 Morning Consult. 2019. "Oklo Fabricates Fuel Prototypes at Idaho National Laboratory."
21 Washington, D.C. Accessed August 26, 2020, at [https://morningconsult.com/2019/10/17/oklo-](https://morningconsult.com/2019/10/17/oklo-fabricates-fuel-prototypes-at-idaho-national-laboratory/)
22 [fabricates-fuel-prototypes-at-idaho-national-laboratory/](https://morningconsult.com/2019/10/17/oklo-fabricates-fuel-prototypes-at-idaho-national-laboratory/). TN6759.

23 Nagley, S. 2020. "HA-LEU Supply (Enrichment, De-conversion, Fuel Fab & Transportation)."
24 BWXT Technologies, Inc., Lynchburg, Virginia. Presented at the GAIN/EPRI/NEI HALEU
25 Webinar, April 28-29, 2020, Idaho National Laboratory, Idaho Falls, Idaho. ADAMS Accession
26 No. ML21139A347. TN6739.

27 Napier, B.A. 2020. *Non-LWR Fuel Cycle Environmental Data*. PNNL-29367, Revision 2,
28 Richland, Washington. ADAMS Accession No. ML20267A217. TN6443.

29 National Environmental Policy Act of 1969 (NEPA), as amended. 42 U.S.C. § 4321 *et seq.*
30 TN661.

31 National Historic Preservation Act. 54 U.S.C. § 300101 *et seq.* TN4157.

32 National Research Council. 1997. *Possible Health Effects of Exposure to Residential Electric*
33 *and Magnetic Fields*. National Academy Press, Washington, D.C. Accessed October 9, 2020, at
34 <http://www.emfs.info/health/reviews/nas/>. TN6595.

35 Native American Graves Protection and Repatriation Act. 25 U.S.C. § 3001 *et seq.* TN1686.

36 Navratil, O., M-B. Abert, E. Hérouin, and J-M. Gresillon. 2006. "Determination of Bankfull
37 Discharge Magnitude and Frequency: Comparison of Methods on 16 Gravel-Bed River
38 Reaches." *Earth Surface Processes and Landforms* 31:1345-1363, Hoboken, New Jersey.
39 TN6792.

1 NCRP (National Council on Radiation Protection and Measurements). 1991. *Effects of Ionizing*
2 *Radiation on Aquatic Organisms*. NCRP Report No. 109, Bethesda, Maryland. TN729.

3 NCRP (National Council on Radiation Protection and Measurements). 1995. *Principles and*
4 *Applications of Collective Dose in Radiation Protection*. NCRP Report No. 121, Bethesda,
5 Maryland. TN728.

6 NEI (Nuclear Energy Institute). 2005. *Severe Accident Mitigation Alternatives (SAMA) Analysis*
7 *Guidance Document*. NEI-05-01, Revision A, Washington, D.C. ADAMS Accession No.
8 ML060530203. TN1978.

9 NEI (Nuclear Energy Institute). 2019. *Industry Groundwater Protection Initiative – Final*
10 *Guidance Document, Rev. 1*. NEI-07-07, Revision 1, Washington, D.C. ADAMS Accession No.
11 ML19142A071. TN6775.

12 Neuhauser, K.S. and F.L. Kanipe. 2003. *RADTRAN 5 User Guide*. Revised by R.F. Weiner.
13 SAND2003-2354, Sandia National Laboratories, Albuquerque, New Mexico. Accessed March
14 27, 2021, at
15 [https://www.energy.gov/sites/prod/files/2018/02/f49/Neuhauser%20and%20Kanipe%202003_R](https://www.energy.gov/sites/prod/files/2018/02/f49/Neuhauser%20and%20Kanipe%202003_RADTRAN%205.pdf)
16 [ADTRAN%205.pdf](https://www.energy.gov/sites/prod/files/2018/02/f49/Neuhauser%20and%20Kanipe%202003_RADTRAN%205.pdf). TN6989.

17 Neuhauser, K.S., F.L. Kanipe, and R.F. Weiner. 2000. *RADTRAN 5 Technical Manual*.
18 SAND2000-1256, Sandia National Laboratories, Albuquerque, New Mexico. ADAMS Accession
19 No. ML16013A013. TN6990.

20 NextEra Energy (NextEra Energy Transmission New York, Inc.). 2020. “Wetland Mitigation
21 Plan.” Appendix G of the *Empire State Line Environmental Management and Construction Plan*,
22 Case 18-T-0499, Albany, New York. Accessed November 13, 2020, at
23 [https://www.empirestateline.com/wp-content/uploads/2020/06/Appendix-G-Wetland-Mitigation-](https://www.empirestateline.com/wp-content/uploads/2020/06/Appendix-G-Wetland-Mitigation-Plan.pdf)
24 [Plan.pdf](https://www.empirestateline.com/wp-content/uploads/2020/06/Appendix-G-Wetland-Mitigation-Plan.pdf). TN6750.

25 NIEHS (National Institute of Environmental Health Sciences). 2002. *Electric and Magnetic*
26 *Fields Associated with the Use of Electric Power: Questions and Answers*. National Institutes of
27 Health, Research Triangle Park, North Carolina. ADAMS Accession No. ML112660024.
28 TN6560.

29 NIOSH (National Institute for Occupational Safety and Health). 1996. *EMFs In The Workplace*.
30 Washington, D.C. ADAMS Accession No. ML21145A339. TN6766.

31 NJ Dept. v. U.S. Nuclear (NJ Dept. of Environmental Protection v. NRC). 561 F.3d 132 (3d Cir.
32 2009). U.S. Court of Appeals Third Circuit Decision, March 31, 2009. TN6958.

33 NOAA ORR (National Oceanic and Atmospheric Administration Office of Response and
34 Restoration). 2019. “Acute Exposure Guideline Levels (AEGs).” Silver Spring, Maryland.
35 ADAMS Accession No. ML21145A342. TN7023.

36 NOAA ORR (National Oceanic and Atmospheric Administration Office of Response and
37 Restoration). 2019. “Emergency Response Planning Guidelines (ERPGs).” Silver Spring,
38 Maryland. ADAMS Accession No. ML21145A343. TN7024.

1 NOAA ORR (National Oceanic and Atmospheric Administration Office of Response and
2 Restoration). 2020. "Protective Action Criteria for Chemicals (PACs)." Silver Spring, Maryland.
3 ADAMS Accession No. ML21145A347. TN7026.

4 NOAA ORR (National Oceanic and Atmospheric Administration Office of Response and
5 Restoration). 2020. "Temporary Emergency Exposure Limits (TEELs)." Silver Spring, Maryland.
6 ADAMS Accession No. ML21145A350. TN7025.

7 Noise Control Act of 1972. 42 U.S.C. § 4901 *et seq.* TN4294.

8 NRC (U.S. Nuclear Regulatory Commission). 1975. *Environmental Survey of Transportation of*
9 *Radioactive Materials to and from Nuclear Power Plants, Supplement 1.* NUREG-75/038,
10 Washington, D.C. ADAMS Accession No. ML14091A176. TN216.

11 NRC (U.S. Nuclear Regulatory Commission). 1976. *Environmental Survey of the Reprocessing*
12 *and Waste Management Portions of the LWR Fuel Cycle.* W.P. Bishop and F.J. Miraglia, Jr.
13 (eds.). NUREG-0116 (Supplement 1 to WASH-1248), Washington, D.C. ADAMS Accession
14 No. ML14098A013. TN292.

15 NRC (U.S. Nuclear Regulatory Commission). 1977. *Calculation of Annual Doses to Man from*
16 *Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR*
17 *Part 50, Appendix I.* Regulatory Guide 1.109, Revision 1, Washington, D.C. ADAMS Accession
18 No. ML003740384. TN90.

19 NRC (U.S. Nuclear Regulatory Commission). 1977. *Final Environmental Statement on the*
20 *Transportation of Radioactive Material by Air and Other Modes.* NUREG-0170, Volume 1,
21 Washington, D.C. ADAMS Accession Nos. ML022590265 and ML022590348. TN417.

22 NRC (U.S. Nuclear Regulatory Commission). 1977. *Final Environmental Statement on the*
23 *Transportation of Radioactive Material by Air and Other Modes.* NUREG-0170, Volume 2,
24 Washington, D.C. ADAMS Accession No. ML022590506. TN6497.

25 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement*
26 *for License Renewal of Nuclear Plants.* Volumes 1 and 2, NUREG-1437, Washington, D.C.
27 ADAMS Accession Nos. ML040690705, ML040690738. TN288.

28 NRC (U.S. Nuclear Regulatory Commission). 1997. *Generic Environmental Impact Statement in*
29 *Support of Rulemaking on Radiological Criteria for License Termination of NRC-Licensed*
30 *Nuclear Facilities.* NUREG-1496, Vol. 1, Main Report, Final Report, Washington, D.C. ADAMS
31 Accession No. ML042310492. TN5455.

32 NRC (U.S. Nuclear Regulatory Commission). 1997. *Regulatory Analysis Technical Evaluation*
33 *Handbook.* NUREG/BR-0184, Washington, D.C. ADAMS Accession No. ML050190193.
34 TN676.

35 NRC (U.S. Nuclear Regulatory Commission). 1999. *Generic Environmental Impact Statement*
36 *for License Renewal of Nuclear Plants Addendum to Main Report, NUREG-1437, Volume 1,*
37 *Addendum 1.* Washington, D.C. ADAMS Accession No. ML040690720. TN289.

- 1 NRC (U.S. Nuclear Regulatory Commission). 2000. *Alternative Radiological Source Terms for*
2 *Evaluating Design Basis Accidents at Nuclear Power Reactors*. Regulatory Guide 1.183,
3 Washington, D.C. ADAMS Accession No. ML003716792. TN517.
- 4 NRC (U.S. Nuclear Regulatory Commission). 2000. *Standard Review Plans for Environmental*
5 *Reviews for Nuclear Power Plants: Supplement 1: Operating License Renewal*. NUREG-1555,
6 Revision 1, Washington, D.C. Available at
7 <http://pbadupws.nrc.gov/docs/ML1310/ML13106A246.pdf>. TN3549.
- 8 NRC (U.S. Nuclear Regulatory Commission). 2001. *Final Environmental Impact Statement for*
9 *the Construction and Operation of an Independent Spent Fuel Storage Installation on the*
10 *Reservation of the Skull Valley Band of Goshute Indians and the Related Transportation Facility*
11 *in Tooele County, Utah*. NUREG-1714, Volume 1, Washington, D.C. ADAMS Accession No.
12 ML020150217. TN6514.
- 13 NRC (U.S. Nuclear Regulatory Commission). 2002. "Final Generic Environmental Impact
14 Statement of Decommissioning of Nuclear Facilities (NUREG-0586)." NUREG-0586,
15 Supplement 1, Volumes 1 and 2, Washington, D.C. ADAMS Accession Nos. ML023470327,
16 ML023500228. TN665.
- 17 NRC (U.S. Nuclear Regulatory Commission). 2003. *Environmental Assessment for the Renewal*
18 *of License SNM-1168 Framatome Advanced Nuclear Power, Inc., Lynchburg, Virginia*.
19 Washington, D.C. ADAMS Accession No. ML030940720. TN6665.
- 20 NRC (U.S. Nuclear Regulatory Commission). 2004. Memorandum from A.L. Vietti-Cook to NRC
21 Executive Director for Operations, dated May 13, 2004, regarding "Staff Requirements - SECY-
22 04-0055 - Plan for Evaluating Scientific Information and Radiation Protection
23 Recommendations." SRM-SECY-04-0055, Washington, D.C. ADAMS Accession No.
24 ML041340304. TN7101.
- 25 NRC (U.S. Nuclear Regulatory Commission). 2004. *Policy Issue: Plan for Evaluating Scientific*
26 *Information and Radiation Protection Recommendations*. SECY-04-0055 with attachments,
27 Washington, D.C. ADAMS Package Accession No. ML040820916. TN7100.
- 28 NRC (U.S. Nuclear Regulatory Commission). 2004. *Policy Issue: Request for Approval of Staff*
29 *Comments on the 2005 Recommendations of the International Commission on Radiological*
30 *Protection*. SECY-04-0223, Washington, D.C. ADAMS Accession No. ML043230277. TN6431.
- 31 NRC (U.S. Nuclear Regulatory Commission). 2004. *Regulatory Analysis Guidelines of the U.S.*
32 *Nuclear Regulatory Commission*. NUREG/BR-0058, Revision 4, Washington, D.C. ADAMS
33 Accession No. ML111290876. TN670.
- 34 NRC (U.S. Nuclear Regulatory Commission). 2005. Memorandum from A.L. Vietti-Cook to L.A.
35 Reyes, dated January 4, 2005, regarding "Staff Requirements - SECY-04-0223 - Request for
36 Approval of Staff Comments on the 2005 Recommendations of the International Commission on
37 Radiological Protection." SRM-SECY-04-0223, Washington, D.C. ADAMS Accession No.
38 ML050040487. TN6649.

1 NRC (U.S. Nuclear Regulatory Commission). 2005. Memorandum from A.L. Vietti-Cook to L.A.
2 Reyes, dated January 4, 2005, regarding "Staff Requirements - SECY-06-0168 - Staff
3 Comments on the Draft Recommendations of the International Commission on Radiological
4 Protection." SRM-SECY-06-0168, Washington, D.C. ADAMS Accession No. ML062350176.
5 TN6650.

6 NRC (U.S. Nuclear Regulatory Commission). 2006. *Environmental Impact Statement for an*
7 *Early Site Permit (ESP) at the Exelon ESP Site*. NUREG-1815, Volumes 1 and 2, Washington,
8 D.C. ADAMS Accession Nos. ML061930264, ML061930275. TN672.

9 NRC (U.S. Nuclear Regulatory Commission). 2006. *Environmental Impact Statement for an*
10 *Early Site Permit (ESP) at the Grand Gulf ESP Site*. NUREG-1817, Washington, D.C. ADAMS
11 Accession No. ML060900037. TN674.

12 NRC (U.S. Nuclear Regulatory Commission). 2006. *Environmental Impact Statement for an*
13 *Early Site Permit (ESP) at the North Anna ESP Site, Final Report*. NUREG-1811, Washington,
14 D.C. ADAMS Accession No. ML063470314. TN7.

15 NRC (U.S. Nuclear Regulatory Commission). 2006. *Policy Issue: Staff Comments on the Draft*
16 *Recommendations of the International Commission on Radiological Protection*. SECY-06-0168,
17 Washington, D.C. ADAMS Accession No. ML061950113. TN6430.

18 NRC (U.S. Nuclear Regulatory Commission). 2007. *Environmental Standard Review Plan—*
19 *Standard Review Plans for Environmental Reviews for Nuclear Power Plants*. NUREG-1555,
20 Draft Revision 1, Washington, D.C. ADAMS Accession No. ML18023A205. TN5141.

21 NRC (U.S. Nuclear Regulatory Commission). 2000, 2007. *Environmental Standard Review*
22 *Plan—Standard Review Plans for Environmental Reviews for Nuclear Power Plants*. NUREG-
23 1555, Main Report and 2007 Revisions, Washington, D.C. Available at
24 <http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1555/toc/> and
25 <https://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1555/updates.html>. TN614.

26 NRC (U.S. Nuclear Regulatory Commission). 2007. Memorandum and Order in the Matter of
27 Amergen Energy Company, LLC (License Renewal for Oyster Creek Nuclear Generating
28 Station). CLI-07-08, Washington, D.C. ADAMS Accession No. ML21145A372. TN6957.

29 NRC (U.S. Nuclear Regulatory Commission). 2007. *Meteorological Monitoring Programs for*
30 *Nuclear Power Plants*. Regulatory Guide 1.23, Revision 1, Washington, D.C. ADAMS Accession
31 No. ML070350028. TN278.

32 NRC (U.S. Nuclear Regulatory Commission). 2007. *Standard Review Plan for the Review of*
33 *Safety Analysis Reports for Nuclear Power Plants, LWR Edition*. NUREG-0800, Washington,
34 D.C. ADAMS Accession No. ML070660036. TN613.

35 NRC (U.S. Nuclear Regulatory Commission). 2008. *Final Environmental Impact Statement for*
36 *an Early Site Permit (ESP) at the Vogtle ESP Electric Generating Plant Site*. NUREG-1872,
37 Volumes 1 and 2, Washington, D.C. ADAMS Accession No. ML090120011. TN673.

1 NRC (U.S. Nuclear Regulatory Commission). 2008. *Policy Issue: Options to Revise Radiation*
2 *Protection Regulations and Guidance with Respect to the 2007 Recommendations of the*
3 *International Commission on Radiological Protection*. SECY-08-0197, Washington, D.C.
4 ADAMS Accession No. ML12089A650. TN6432.

5 NRC (U.S. Nuclear Regulatory Commission). 2009. *Environmental Assessment for the Renewal*
6 *of the U.S. Nuclear Regulatory Commission License No. SNM-1097 for Global Nuclear Fuel-*
7 *Americas, Wilmington Fuel Fabrication Facility*. Washington, D.C. ADAMS Accession No.
8 ML091180239. TN6663.

9 NRC (U.S. Nuclear Regulatory Commission). 2009. *Environmental Assessment for the Renewal*
10 *of the U.S. Nuclear Regulatory Commission License No. SNM-1227 for AREVA NP, Inc.*
11 *Richland Fuel Fabrication Facility*. Washington, D.C. ADAMS Accession No. ML090700258.
12 TN6664.

13 NRC (U.S. Nuclear Regulatory Commission). 2009. *Generic Environmental Impact Statement*
14 *for In-Situ Leach Uranium Milling Facilities*. Final Report, NUREG-1910, Volumes 1 and 2,
15 Washington, D.C. ADAMS Accession Nos. ML15093A359 and ML15093A486. TN2559.

16 NRC (U.S. Nuclear Regulatory Commission). 2009. "Memorandum and Order in the Matter of
17 Duke Energy Carolinas, LLC (Combined License Application for William States Lee III Nuclear
18 Station, Units 1 and 2) and Tennessee Valley Authority (Bellefonte Nuclear Power Plant, Units 3
19 and 4)." CLI-09-21, Rockville, Maryland. ADAMS Accession No. ML093070690. TN6406.

20 NRC (U.S. Nuclear Regulatory Commission). 2009. Memorandum from A.L. Vietti-Cook to R.W.
21 Borchardt, dated April 2, 2009, regarding "Staff Requirements - SECY-08-0197 - Options to
22 Revise Radiation Protection Regulations and Guidance with Respect to the 2007
23 Recommendations of the International Commission on Radiological Protection." SRM-SECY-08-
24 0197, Washington, D.C. ADAMS Accession No. ML090920103. TN6651.

25 NRC (U.S. Nuclear Regulatory Commission). 2009. *Radiological Environmental Monitoring for*
26 *Nuclear Power Plants*. Regulatory Guide 4.1, Revision 2, Washington, D.C. ADAMS Accession
27 No. ML091310135. TN3802.

28 NRC (U.S. Nuclear Regulatory Commission). 2010. *Supplemental Environmental Impact*
29 *Statement for the Combined License (COL) for North Anna Power Station Unit 3*. Final Report,
30 NUREG-1917, Washington, D.C. ADAMS Accession No. ML100680117. TN6.

31 NRC (U.S. Nuclear Regulatory Commission). 2011. *Environmental Impact Statement for*
32 *Combined License (COL) for Calvert Cliffs Nuclear Power Plant Unit 3*. NUREG-1936, Volume
33 1, Final Report, Washington, D.C. ADAMS Accession No. ML11129A167. TN1980.

34 NRC (U.S. Nuclear Regulatory Commission). 2011. *Environmental Impact Statement for*
35 *Combined Licenses (COLs) for South Texas Project Electric Generating Station Units 3 and 4*.
36 Final Report, NUREG-1937, Washington, D.C. ADAMS Accession No. ML11049A000. TN1722.

37 NRC (U.S. Nuclear Regulatory Commission). 2011. *Final Environmental Assessment for the*
38 *Proposed Renewal of the U.S. Nuclear Regulatory Commission License No. SNM-124 for*
39 *Nuclear Fuel Services, Inc.* Washington, D.C. ADAMS Accession No. ML112560265. TN6666.

1 NRC (U.S. Nuclear Regulatory Commission). 2011. *Final Environmental Impact Statement for*
2 *Combined Licenses (COLs) for Comanche Peak Nuclear Power Plant Units 3 and 4*. NUREG-
3 1943, Volume 1, Washington, D.C. ADAMS Accession No. ML11131A001. TN6437.

4 NRC (U.S. Nuclear Regulatory Commission). 2011. *Final Environmental Impact Statement for*
5 *Combined Licenses for Virgil C. Summer Nuclear Station Units 2 and 3*. Final Report, NUREG-
6 1939, Washington, D.C. ADAMS Accession No. ML11098A044. TN1723.

7 NRC (U.S. Nuclear Regulatory Commission). 2011. *Final Supplemental Environmental Impact*
8 *Statement for Combined Licenses (COLs) for Vogtle Electric Generating Plant Units 3 and 4*.
9 NUREG-1947, Washington, D.C. ADAMS Accession No. ML11076A010. TN6439.

10 NRC (U.S. Nuclear Regulatory Commission). 2011. *Reprocessing Rulemaking: Draft Regulatory*
11 *Basis and Path Forward*. SECY-11-0163, Washington, D.C. ADAMS Package Accession
12 ML113202350. TN6830.

13 NRC (U.S. Nuclear Regulatory Commission). 2012. *Environmental Impact Statement for*
14 *Combined Licenses (COLs) for Levy Nuclear Plant Units 1 and 2, Final Report*. NUREG-1941,
15 Volumes 1, 2, and 3. Washington, D.C. ADAMS Accession Nos. ML12100A063, ML12100A068,
16 ML12100A070. TN1976.

17 NRC (U.S. Nuclear Regulatory Commission). 2012. *Report to Congress: Advanced Reactor*
18 *Licensing*. Washington, D.C. ADAMS Accession No. ML12153A014. TN6670.

19 NRC (U.S. Nuclear Regulatory Commission). 2012. *Terrestrial Environmental Studies for*
20 *Nuclear Power Stations*. Regulatory Guide 4.11, Revision 2, Washington, D.C. ADAMS
21 Accession No. ML113350385. TN1967.

22 NRC (U.S. Nuclear Regulatory Commission). 2013. *Final Environmental Impact Statement for*
23 *Combined Licenses (COLs) for William States Lee III Nuclear Station Units 1 and 2*. NUREG-
24 2111, Volume 1, Washington, D.C. ADAMS Accession No. ML13340A005. TN6435.

25 NRC (U.S. Nuclear Regulatory Commission). 2013. *Final Environmental Impact Statement for*
26 *the Combined License (COL) for Enrico Fermi Unit 3*. NUREG-2105, Volume 1, Washington,
27 D.C. ADAMS Accession No. ML12307A172. TN6436.

28 NRC (U.S. Nuclear Regulatory Commission). 2013. Letter from R.K. Johnson, Chief Fuel
29 Manufacturing Branch Division of Fuel Cycle Safety and Safeguards, Office of Nuclear Materials
30 Safety and Safeguards, to D.W. Johnson, Director, Office of Technical Programs and
31 Coordination Activities, Department of Labor Occupational Safety and Health Administration,
32 dated July 29, 2013, regarding "Memorandum of Understanding Between the U.S. Nuclear
33 Regulatory Commission and the Occupational Safety and Health Administration." Washington,
34 D.C. ADAMS Accession No. ML11354A411. TN10165.

35 NRC (U.S. Nuclear Regulatory Commission). 2013. *Standard Review Plans for Environmental*
36 *Reviews of Nuclear Power Plants, Supplement 1: Operating License Renewal*. Final Report,
37 NUREG-1555, Supplement 1, Revision 1, Washington, D.C. ADAMS Accession No.
38 ML13106A246. TN3547.

- 1 NRC (U.S. Nuclear Regulatory Commission). 2014. *Attachment 1: Staff Guidance for*
2 *Greenhouse Gas and Climate Change Impacts for New Reactor Environmental Impact*
3 *Statements, COL/ESP-ISG-026*. Washington, D.C. ADAMS Accession No. ML14100A157.
4 TN3768.
- 5 NRC (U.S. Nuclear Regulatory Commission). 2014. *General Site Suitability Criteria for Nuclear*
6 *Power Stations*. Regulatory Guide 4.7, Revision 3, Washington, D.C. ADAMS Accession No.
7 ML12188A053. TN3550.
- 8 NRC (U.S. Nuclear Regulatory Commission). 2014. *Generic Environmental Impact Statement*
9 *for Continued Storage of Spent Nuclear Fuel*. Final Report, NUREG–2157, Washington, D.C.
10 ADAMS Package Accession No. ML14198A440. TN4117.
- 11 NRC (U.S. Nuclear Regulatory Commission). 2014. *Interim Staff Guidance on Environmental*
12 *Issues Associated with New Reactors*. COL/ESP–ISG–026, Washington, D.C. ADAMS
13 Accession No. ML14092A402. TN3767.
- 14 NRC (U.S. Nuclear Regulatory Commission). 2014. *Specific Environmental Guidance for Light*
15 *Water Small Modular Reactors Reviews*. Interim Staff Guidance, COL/ESP-ISG-027,
16 Washington, D.C. ADAMS Accession No. ML14100A648. TN3774.
- 17 NRC (U.S. Nuclear Regulatory Commission). 2014. *Spent Fuel Transportation Risk*
18 *Assessment, Final Report*. NUREG–2125, Washington, D.C. ADAMS Accession No.
19 ML14031A323. TN3231.
- 20 NRC (U.S. Nuclear Regulatory Commission). 2015. *Environmental Impact Statement for an*
21 *Early Site Permit (ESP) at the PSEG Site*. NUREG-2168, Volume 1, Washington, D.C. ADAMS
22 Accession No. ML15316A283. TN6438.
- 23 NRC (U.S. Nuclear Regulatory Commission). 2016. *Environmental Impact Statement for*
24 *Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7*. NUREG-2176,
25 Volume 1, Washington, D.C. ADAMS Accession No. ML16300A104. TN6434.
- 26 NRC (U.S. Nuclear Regulatory Commission). 2016. *Environmental Impact Statement for*
27 *Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7*. NUREG-2176,
28 Volume 2, Washington, D.C. ADAMS Accession No. ML16300A137. TN6840.
- 29 NRC (U.S. Nuclear Regulatory Commission). 2016. “NRC Inspection Manual, Inspection
30 Procedure 71124 Attachment 07.” Washington, D.C. ADAMS Accession No. ML15345A067.
31 TN6463.
- 32 NRC (U.S. Nuclear Regulatory Commission). 2017. *Aquatic Environmental Studies for Nuclear*
33 *Power Stations*. Regulatory Guide 4.24, Washington, D.C. ADAMS Accession No.
34 ML15309A219. TN6720.
- 35 NRC (U.S. Nuclear Regulatory Commission). 2017. *Certificate of Compliance for Radioactive*
36 *Material Packages, Certificate Number 9358, Revision 4*. Washington, D.C. ADAMS Accession
37 No. ML17354A797. TN6684.
- 38 NRC (U.S. Nuclear Regulatory Commission). 2017. “Locations of Low-Level Waste Disposal
39 Facilities.” Washington, D.C. ADAMS Accession No. ML21145A386. TN6518.

- 1 NRC (U.S. Nuclear Regulatory Commission). 2017. "Low-Level Waste." Washington, D.C.
2 ADAMS Accession No. ML21145A387. TN6545.
- 3 NRC (U.S. Nuclear Regulatory Commission). 2018. *Certificate of Compliance for Radioactive*
4 *Material Packages, Certificate Number 9373, Revision 1.* Washington, D.C. ADAMS Accession
5 No. ML18332A027. TN6685.
- 6 NRC (U.S. Nuclear Regulatory Commission). 2018. *Guidance for Developing Principal Design*
7 *Criteria for Non-Light-Water Reactors.* Regulatory Guide 1.232, Revision 0, Washington, D.C.
8 ADAMS Accession No. ML17325A611. TN7066.
- 9 NRC (U.S. Nuclear Regulatory Commission). 2018. *Preparation of Environmental Reports for*
10 *Nuclear Power Stations.* Regulatory Guide 4.2, Revision 3, Washington, D.C. ADAMS
11 Accession No. ML18071A400. TN6006.
- 12 NRC (U.S. Nuclear Regulatory Commission). 2019. *2019-2020 Information Digest.* NUREG-
13 1350, Volume 31, Washington, D.C. ADAMS Accession No. ML19242D326. TN6652.
- 14 NRC (U.S. Nuclear Regulatory Commission). 2019. *Certificate of Compliance for Radioactive*
15 *Material Packages, Certificate Number 9297, Revision 11.* Washington, D.C. ADAMS Accession
16 No. ML19109A137. TN6511.
- 17 NRC (U.S. Nuclear Regulatory Commission). 2019. *Certificate of Compliance for Radioactive*
18 *Material Packages, Certificate Number 9309, Revision 12.* Washington, D.C. ADAMS Accession
19 No. ML19025A105. TN6512.
- 20 NRC (U.S. Nuclear Regulatory Commission). 2019. *Certificate of Compliance for Radioactive*
21 *Material Packages, Certificate Number 9372, Revision 2.* Washington, D.C. ADAMS Accession
22 No. ML19070A021. TN6513.
- 23 NRC (U.S. Nuclear Regulatory Commission). 2019. *Environmental Assessment for the*
24 *Proposed Renewal of Source Material License SUB-526 Metropolis Works Uranium Conversion*
25 *Facility (Massac County, Illinois).* Washington, D.C. ADAMS Accession No. ML19273A012.
26 TN6964.
- 27 NRC (U.S. Nuclear Regulatory Commission). 2019. *Environmental Assessment for the Renewal*
28 *of SNM-1107 Columbia Fuel Fabrication Facility in Richland County, South Carolina.* Draft for
29 Comment, Westinghouse Electric Company, LLC, Hopkins, South Carolina. ADAMS Accession
30 No. ML19228A278. TN6472.
- 31 NRC (U.S. Nuclear Regulatory Commission). 2019. *Environmental Considerations Associated*
32 *with Micro-Reactors.* Draft Interim Staff Guidance, COL-ISG-029, Washington, D.C. ADAMS
33 Accession No. ML19234A216. TN6523.
- 34 NRC (U.S. Nuclear Regulatory Commission). 2019. *Environmental Impact Statement for an*
35 *Early Site Permit (ESP) at the Clinch River Nuclear Site.* NUREG-2226, Washington, D.C.
36 ADAMS Package Accession No. ML19087A266. TN6136.

1 NRC (U.S. Nuclear Regulatory Commission). 2019. *Generic Environmental Impact Statement*
2 *for License Renewal of Nuclear Plants, Supplement 5, Second Renewal, Regarding*
3 *Subsequent License Renewal for Turkey Point Nuclear Generating Unit Nos. 3 and 4.*
4 NUREG-1437, Supplement 5, Second Renewal, Washington, D.C. ADAMS Accession No.
5 ML19290H346. TN6824.

6 NRC (U.S. Nuclear Regulatory Commission). 2019. "Greater-Than-Class C and Transuranic
7 Waste." Washington, D.C. ADAMS Accession No. ML21145A383. TN6440.

8 NRC (U.S. Nuclear Regulatory Commission). 2019. Letter from K.L. Svinicki to Senator J.A.
9 Barrasso, dated July 29, 2019, regarding "Response to Request that NRC Initiate a Process to
10 Develop a Generic Environmental Impact Statement for the Construction and Operation of
11 Advanced Nuclear Reactors." Washington, D.C. ADAMS Accession No. ML19192A267.
12 TN6467.

13 NRC (U.S. Nuclear Regulatory Commission). 2007/2019. *Standard Review Plan for the Review*
14 *of Safety Analysis Reports for Nuclear Power Plants, LWR Edition.* NUREG-0800, with
15 updates. Available at <https://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr0800/>.
16 Washington, D.C. TN6221.

17 NRC (U.S. Nuclear Regulatory Commission). 2020. *Certificate of Compliance for Radioactive*
18 *Material Packages, Certificate Number 9342, Revision 15.* Washington, D.C. ADAMS Accession
19 No. ML20139A034. TN6686.

20 NRC (U.S. Nuclear Regulatory Commission). 2020. *Certificate of Compliance for Radioactive*
21 *Material Packages, Certificate Number 9356, Revision 2.* Washington, D.C. ADAMS Accession
22 No. ML20139A104. TN6683.

23 NRC (U.S. Nuclear Regulatory Commission). 2020. "Comparison of Conventional Mill, Heap
24 Leach, and In Situ Recovery Facilities." Washington, D.C. ADAMS Accession No.
25 ML21145A373. TN6827.

26 NRC (U.S. Nuclear Regulatory Commission). 2020. *Environmental Considerations Associated*
27 *with Micro-Reactors.* Final COL-ISG-029, Washington, D.C. ADAMS Accession No.
28 ML20252A076. TN6710.

29 NRC (U.S. Nuclear Regulatory Commission). 2020. "Fuel Fabrication." Washington, D.C.
30 ADAMS Accession No. ML21145A378. TN6835.

31 NRC (U.S. Nuclear Regulatory Commission). 2020. "Generic Environmental Impact Statement
32 for In Situ Leach Uranium Milling Facilities." Washington, D.C. ADAMS Accession No.
33 ML21145A380. TN6828.

34 NRC (U.S. Nuclear Regulatory Commission). 2020. "Generic Environmental Impact Statement
35 for In Situ Leach Uranium Milling Facilities (NUREG-1910)." Washington, D.C. ADAMS
36 Accession No. ML21145A382. TN6829.

1 NRC (U.S. Nuclear Regulatory Commission). 2020. *Guidance for a Technology-Inclusive, Risk-*
2 *Informed, and Performance-Based Methodology to Inform the Licensing Basis and Content of*
3 *Applications for Licenses, Certifications, and Approvals for Non-Light-Water Reactors.*
4 Regulatory Guide 1.233, Revision 0, Washington, D.C. ADAMS Accession No. ML20091L698.
5 TN6441.

6 NRC (U.S. Nuclear Regulatory Commission). 2020. "High-Level Waste." Washington, D.C.
7 ADAMS Accession No. ML21145A384. TN6955.

8 NRC (U.S. Nuclear Regulatory Commission). 2020. "Low-Level Waste Disposal." Washington,
9 D.C. ADAMS Accession No. ML21145A388. TN6516.

10 NRC (U.S. Nuclear Regulatory Commission). 2020. Memorandum from A.L. Vietti-Cook to M.M.
11 Doane, dated September 21, 2020, regarding Staff Requirements - SECY-20-0020 - Results of
12 Exploratory Process for Developing a Generic Environmental Impact Statement for the
13 Construction and Operation of Advanced Nuclear Reactors." SRM-SECY-20-0020, Washington,
14 D.C. ADAMS Accession No. ML20265A112. TN6492.

15 NRC (U.S. Nuclear Regulatory Commission). 2020. *Policy Issue: Results of Exploratory*
16 *Process for Developing a Generic Environmental Impact Statement for the Construction and*
17 *Operation of Advanced Nuclear Reactors.* SECY-20-0020, Washington, D.C. ADAMS
18 Accession No. ML20052D175. TN6493.

19 NRC (U.S. Nuclear Regulatory Commission). 2020. *Scoping Summary Report for the Advanced*
20 *Nuclear Reactor Generic Environmental Impact Statement Public Scoping Period.* Washington,
21 D.C. ADAMS Accession No. ML20269A317. TN6593.

22 NRC (U.S. Nuclear Regulatory Commission). 2020. *Summary of Public Scoping Meeting*
23 *Conducted for the Advanced Reactor Generic Environmental Impact Statement, May 28, 2020.*
24 Washington, D.C. ADAMS Package Accession No. ML20161A339. TN6459.

25 NRC (U.S. Nuclear Regulatory Commission). 2020. "Uranium Conversion." Washington, D.C.
26 ADAMS Accession No. ML21145A400. TN6837.

27 NRC (U.S. Nuclear Regulatory Commission). 2020. "Uranium Enrichment." Washington, D.C.
28 ADAMS Accession No. ML21145A401. TN6836.

29 NRC (U.S. Nuclear Regulatory Commission). 2020. "Uranium Enrichment." Washington, D.C.
30 Accessed July 2, 2024, at <https://www.nrc.gov/materials/fuel-cycle/fac/ur-enrichment.html>.
31 TN10162.

32 NRC (U.S. Nuclear Regulatory Commission). 2020. "Uranium Recovery." Washington, D.C.
33 ADAMS Accession No. ML21145A406. TN6444.

34 NRC (U.S. Nuclear Regulatory Commission). 2021. *Cooling Tower Air Quality Impacts in New*
35 *Reactor EISs.* Washington, D.C. ADAMS Accession No. ML21145A374. TN7037.

36 NRC (U.S. Nuclear Regulatory Commission). 2021. *Environmental Impact Statement for Interim*
37 *Storage Partners LLC's License Application for a Consolidated Interim Storage Facility for Spent*
38 *Nuclear Fuel in Andrews County, Texas, Final Report.* NUREG-2239, Washington, D.C.
39 ADAMS Accession No. ML21209A955. TN10124.

1 NRC (U.S. Nuclear Regulatory Commission). 2021. Memorandum from A.L. Vietti-Cook,
2 Secretary, to M.M. Doane, Executive Director for Operations, and M.L. Zobler, General
3 Counsel, dated April 23, 2021, regarding, "Staff Requirements – Briefing on Equal Employment
4 Opportunity, Affirmative Employment, and Small Business, 10:00 A.M., Thursday, February 18,
5 2021, Video Conference Meeting (Open to Public Via Webcast and Teleconference)."
6 Washington, D.C. ADAMS Accession No. ML21113A070. TN10335.

7 NRC (U.S. Nuclear Regulatory Commission). 2021. *Rulemaking Issue Notation Vote: Proposed*
8 *Rule: Advanced Nuclear Reactor Generic Environmental Impact Statement (RIN 3150-AK55;*
9 *NRC-2020-0101)*. SECY-21-0098, Washington, D.C. ADAMS Accession No. ML21222A044.
10 TN10127.

11 NRC (U.S. Nuclear Regulatory Commission). 2022. *Environmental Impact Statement for the*
12 *Holtec International's License Application for a Consolidated Interim Storage Facility for Spent*
13 *Nuclear Fuel in Lea County, New Mexico, Final Report*. NUREG-2237, Washington, D.C.
14 ADAMS Accession No. ML22181B094. TN10125.

15 NRC (U.S. Nuclear Regulatory Commission). 2022. *Environmental Impact Statement for the*
16 *Holtec International's License Application for a Consolidated Interim Storage Facility for Spent*
17 *Nuclear Fuel in Lea County, New Mexico, Supplement 1*. NUREG-2237, Washington,
18 D.C. ADAMS Accession No. ML22299A238. TN10171.

19 NRC (U.S. Nuclear Regulatory Commission). 2022. *Policy Issue (Notation Vote): Systematic*
20 *Review of How Agency Programs, Policies, and Activities Address Environmental*
21 *Justice*. SECY-22-0025, Washington D.C. ADAMS Accession No. ML22031A063. TN10334.

22 NRC (U.S. Nuclear Regulatory Commission). 2023. "Centrus Energy Corp./American Centrifuge
23 Operating, LLC (formerly USEC Inc.) Gas Centrifuge Enrichment Facility Licensing."
24 Washington, D.C. Accessed July 1, 2024, at [https://www.nrc.gov/materials/fuel-cycle-](https://www.nrc.gov/materials/fuel-cycle-fac/usecfacility.html)
25 [fac/usecfacility.html](https://www.nrc.gov/materials/fuel-cycle-fac/usecfacility.html). TN10142.

26 NRC (U.S. Nuclear Regulatory Commission). 2023. "Honeywell." Washington, D.C. Accessed
27 July 1, 2024, at <https://www.nrc.gov/info-finder/fc/honeywell-works-uranium-conv-il-ic.html>.
28 TN10140.

29 NRC (U.S. Nuclear Regulatory Commission). 2023. "Plant Sites with Licensed Radioactive
30 Material in Groundwater." Washington, D.C. Accessed June 28, 2024, at
31 <https://www.nrc.gov/reactors/operating/ops-experience/tritium/sites-grndwtr-contam.html>.
32 TN10129.

33 NRC (U.S. Nuclear Regulatory Commission). 2023. "Uranium Recovery." Washington, D.C.
34 Accessed July 1, 2024, at <https://www.nrc.gov/materials/uranium-recovery.html>. TN10135.

35 NRC (U.S. Nuclear Regulatory Commission). 2023. *Rulemaking Issue Notation Vote: Options*
36 *for Licensing and Regulating Fusion Energy Systems*. SECY-23-0001, Washington, D.C.
37 ADAMS Accession No. ML22273A178. TN10128.

38 NRC (U.S. Nuclear Regulatory Commission). 2023. *Environmental Impact Statement for the*
39 *Construction Permit for the Kairos Hermes Test Reactor, Final Report*. NUREG-2263,
40 Washington, D.C. ADAMS Accession No. ML23214A269. TN9771.

1 NRC (U.S. Nuclear Regulatory Commission). 2024. "Louisiana Energy Services (LES)."
2 Washington, D.C. Accessed July 1, 2024, at [https://www.nrc.gov/info-finder/fc/urenco-](https://www.nrc.gov/info-finder/fc/urenco-enrichment-fac-nm-lc.html)
3 [enrichment-fac-nm-lc.html](https://www.nrc.gov/info-finder/fc/urenco-enrichment-fac-nm-lc.html). TN10145.

4 NRC (U.S. Nuclear Regulatory Commission). 2024. *Draft Guide-4032, Proposed Revision 4 to*
5 *Regulatory Guide 4.2, Preparation of Environmental Reports for Nuclear Power Stations.*
6 Washington, D.C. ADAMS Accession No. ML24176A228. TN7081.

7 NRC (U.S. Nuclear Regulatory Commission). 2024. *Environmental Assessment for the*
8 *Construction Permit Application for the Abilene Christian University Molten Salt Research*
9 *Reactor.* Washington, D.C. ADAMS Accession No. ML23300A053. TN10337.

10 NRC (U.S. Nuclear Regulatory Commission). 2024. *Environmental Evaluation of Accident*
11 *Tolerant Fuels with Increased Enrichment and Higher Burnup Levels, Final Report.* NUREG-
12 2266, Washington, D.C. ADAMS Accession No. ML24207A210. TN10333.

13 NRC (U.S. Nuclear Regulatory Commission). 2024. *Generic Environmental Impact Statement*
14 *for License Renewal of Nuclear Plants.* NUREG-1437, Volume 1-3, Revision 2, Washington,
15 D.C. ADAMS Accession No. ML24087A133. TN10161.

16 NRC and USACE (U.S. Nuclear Regulatory Commission and U.S. Army Corps of Engineers).
17 2016. *Environmental Impact Statement for the Combined License (COL) for the Bell Bend*
18 *Nuclear Power Plant.* NUREG-2179, Volume 1, NRC Office of New Reactors, Washington,
19 D.C., and USACE Baltimore District, State College, Pennsylvania. ADAMS Accession No.
20 ML16111B169. TN6562.

21 NRIC (National Reactor Innovation Center). 2021. *Advanced Nuclear Reactor Plant Parameter*
22 *Envelope and Guidance.* NRIC-21-ENG-0001, Washington, D.C. ADAMS Accession No.
23 ML21145A416. TN6940.

24 Nuclear Energy Innovation and Modernization Act. 42 U.S.C. § 2011 Note. Public Law 115-439,
25 January 14, 2019, 132 Stat. 5565. TN6469.

26 Nuclear Energy Innovation Capabilities Act of 2017. Public Law 115–248. 132 Stat. 3160.
27 TN6468.

28 NuclearNews. 2024. "Fuel cycle players signal next moves as Russian uranium ban becomes
29 law." La Grange Park, Illinois. TN10151.

30 NuScale (NuScale Power LLC). 2020. *NuScale Standard Plant Design Certification Application:*
31 *Part 3, Applicant's Environmental Report - Standard Design Certification.* Revision 5, Tigard,
32 Oregon. ADAMS Accession No. ML20224A512. TN6811.

33 Occupational Safety and Health Act of 1970, as amended. 29 U.S.C. § 651 *et seq.* TN4453.

34 OECD/NEA and IAEA (Organisation for Economic Co-Operation and Development/Nuclear
35 Energy Agency and International Atomic Energy Agency). 2008. *Uranium 2007: Resources,*
36 *Production and Demand.* NEA No. 6345, Paris, France. Available at [https://www.oecd-](https://www.oecd-nea.org/ndd/pubs/2008/6345-uranium-2007.pdf)
37 [nea.org/ndd/pubs/2008/6345-uranium-2007.pdf](https://www.oecd-nea.org/ndd/pubs/2008/6345-uranium-2007.pdf). TN3992.

- 1 ORNL (Oak Ridge National Laboratory). 1970. *Fluorine Production and Recombination in*
2 *Frozen MSR Salts After Reactor Operation*. ORNL-TM-3144, Oak Ridge, Tennessee. ADAMS
3 Accession No. ML21145A409. TN6754.
- 4 ORNL (Oak Ridge National Laboratory). 1998. "Ending the MSRE." *Ridgelines*, Number 32,
5 November 12, 1998. Oak Ridge, Tennessee. ADAMS Accession No. ML21145A407. TN6755.
- 6 Paige, C. and S.A. Ritter. 1999. *Birds in a Sagebrush Sea: Managing Sagebrush Habitats for*
7 *Bird Communities*. Partners in Flight Western Working Group, Boise, Idaho. Accessed
8 November 6, 2020, at [https://www.sagegrouseinitiative.com/wp-](https://www.sagegrouseinitiative.com/wp-content/uploads/2013/09/Birdsinasagebrushsea.pdf)
9 [content/uploads/2013/09/Birdsinasagebrushsea.pdf](https://www.sagegrouseinitiative.com/wp-content/uploads/2013/09/Birdsinasagebrushsea.pdf). TN6802.
- 10 Pappano, P. 2018. "TRISO-X Fuel Fabrication Facility Overview." X-Energy LLC, Greenbelt,
11 Maryland. NRC Presentation, August 24, 2018, Rockville, Maryland. ADAMS Accession No.
12 ML18254A086. TN6738.
- 13 Pappano, P. 2020. "Fuel & HALEU Needs." X-Energy LLC, Greenbelt, Maryland. Presented at
14 the GAIN/EPRI/NEI HALEU Webinar, April 28-29, 2020, Idaho National Laboratory, Idaho Falls,
15 Idaho. ADAMS Accession No. ML21145A447. TN6737.
- 16 Parker, P.L. and T.F. King. 1998. "Guidelines for Evaluating and Documenting Traditional
17 Cultural Properties." *National Register Bulletin 38*, National Park Service, Washington, D.C.
18 ADAMS Accession No. ML13011A335. TN5840.
- 19 Patten, D.T., L. Rouse, and J.C. Stromberg. 2007. "Isolated Spring Wetlands in the Great Basin
20 and Mojave Deserts, USA: Potential Response of Vegetation to Groundwater Withdrawal."
21 *Environmental Management* 41:398-413, New York, New York. DOI 10.1007/s00267-007-9035-
22 9. TN6968.
- 23 Petrich, C.H. 1982. "Assessing Aesthetic Impacts in Siting a Nuclear Power Plant: The Case of
24 Greene County, New York." *Environmental Impact Assessment Review* 3(4): 311-332,
25 Amsterdam, The Netherlands. TN6810.
- 26 Poff, N.L., D. Allan, M.B. Bain, J.R. Darr, K.L. Prestegard, B.D. Richter, R.E. Sparks, and J.C.
27 Stromberg. 1997. "The Natural Flow Regime: A Paradigm for River Conservation and
28 Restoration." *Bioscience* 47(11):769-784, Reston, Virginia. TN6794.
- 29 Pollution Prevention Act of 1990. 42 U.S.C. § 13101 *et seq.* TN6607.
- 30 PSEG (PSEG Power LLC and PSEG Nuclear LLC). 2014. *PSEG Site Early Site Permit*
31 *Application*; Part 3, "Environmental Report." Revision 3, Newark, New Jersey. ADAMS
32 Accession No. ML14093B256. TN3452.
- 33 Quiet Communities Act of 1978. 42 U.S.C. § 4901 *et seq.* Public Law 95-609, 92 STAT. 3079.
34 TN7029.
- 35 Ramsdell, J.V. Jr., C.E. Beyer, D.D. Lanning, U.P. Jenquin, R.A. Schwarz, D.L. Strenge, P.M.
36 Daling, and R.T. Dahowski. 2001. *Environmental Effects of Extending Fuel Burnup Above 60*
37 *GWd/MTU*. NUREG/CR-6703, Pacific Northwest National Laboratory, Richland, Washington.
38 ADAMS Accession No. ML010310298. TN4545.

- 1 Reardon, B.T., G.F. Flanagan, D.E. Holcomb, and A.T. Nelson. 2019. "Seminar on Advanced
2 Technology Fuel for LWRs and non-LWR Technologies for NMSS Applications." Presented to
3 the NRC, July 17-18, 2019, in Rockville, Maryland. Oak Ridge National Laboratory, Oak Ridge,
4 Tennessee. ADAMS Accession No. ML19198A011. TN6952.
- 5 Resource Conservation and Recovery Act of 1976. 42 U.S.C § 6901 *et seq.* Public Law 94-580,
6 90 Stat. 2795. TN1281.
- 7 Rhoads, R.E. *An Overview of Transportation in the Nuclear Fuel Cycle*. BNWL-2066, Battelle
8 Pacific Northwest Laboratories, Richland, Washington. TN6572.
- 9 Rich, A.C., D.S. Dobkin, and L.J. Niles. 1994. "Defining Forest Fragmentation by Corridor Width:
10 The Influence of Narrow Forest-Dividing Corridors on Forest Nesting Birds in Southern New
11 Jersey." *Conservation Biology* 8(4):1109-1121, Washington, D.C. Accessed November 6, 2020,
12 at <https://conbio.onlinelibrary.wiley.com/doi/epdf/10.1046/j.1523-1739.1994.08041109.x>.
13 TN6732.
- 14 Riley, B.J., J. McFarlane, G.D. DeCul, J.D. Vienna, C.I. Contescu, L.M. Hay, A.V. Savino, and
15 H.E. Adkins. 2018. *Identification of Potential Waste Processing and Waste Form Options for
16 Molten Salt Reactors*. NTRD-MSR-2018-000379, Washington, D.C. ADAMS Accession No.
17 ML21145A248. TN6942.
- 18 Rivers and Harbors Appropriation Act of 1899. 33 U.S.C. § 401 *et seq.* TN660.
- 19 Rolstad, J. 2008. "Consequences of Forest Fragmentation for the Dynamics of Bird Populations:
20 Conceptual Issues and the Evidence." *Biological Journal of the Linnean Society* 42(2):149-163.
21 Oxford University Press, Oxford, United Kingdom. TN6725.
- 22 RSC (Royal Society of Chemistry). 2020. "Periodic Table: Thorium." Washington, D.C.
23 Webpage accessed August 27, 2020, at <https://www.rsc.org/periodic-table/element/90/thorium>.
24 TN6442.
- 25 Safe Drinking Water Act of 1974, as amended. 42 U.S.C. § 300f *et seq.* TN1337.
- 26 Samia, D.S.M., S. Nakagawa, F. Nomura, T.F. Rangel, and D.T. Blumstein. 2015. "Increased
27 Tolerance to Humans Among Disturbed Wildlife." *Nature Communications* 6:8877. McMillan
28 Publishers Limited, New York, New York. DOI: 10.1038/ncomms9877. TN6790.
- 29 San Luis Obispo Peace v. Nuclear Regulatory Commission (San Luis Obispo Mothers for Peace
30 v. NRC). 2006. 449 F.3d 1016 (9th Cir. 2006). U.S. Court of Appeals Ninth Circuit Decision,
31 June 2, 2006. TN6959.
- 32 Saricks, C.L. and M.M. Tompkins. 1999. *State-Level Accident Rates of Surface Freight
33 Transportation: A Reexamination*. ANL/ESD/TM-150, Argonne National Laboratory, Argonne,
34 Illinois. ADAMS Accession No. ML091060020. TN81.
- 35 Schoeberl, B.C. 2003. "Influence of Fragmentation on Shrubsteppe-Obligate Passerines." Boise
36 State University Theses and Dissertations, 707, Boise, Idaho. Available at
37 <https://scholarworks.boisestate.edu/td/707/>. TN6727.

1 SFWMD (South Florida Water Management District). 1995. *Literature Review of the Effects of*
2 *Groundwater Drawdowns on Isolated Wetlands*. Technical Publication 96-01 (WRE #330), West
3 Palm Beach, Florida. Accessed December 8, 2020, at
4 <http://dpanther.fiu.edu/sobek/FI12090425/00001>. TN6799.

5 Shannon, G., M.F. McKenna, L.M. Angeloni, K.R. Crooks, K.M. Fristrup, E. Brown, K.A. Warner,
6 M.D. Nelson, C. White, J. Briggs, S. McFarland, and G. Wittemyer. 2016. "A Synthesis of Two
7 Decades of Research Documenting the Effects of Noise on Wildlife." *Biological Reviews* 91(4):
8 982-1005. Bethesda, Maryland. doi: 10.1111/brv.12207. TN6566.

9 Smith, T.J. 2016. "Landscape to Local: A Multi-Scale Evaluation of Voluntary Efforts to Reduce
10 Fragmentation and Enhance Management of Rangelands for Sage-Grouse." PhD. Dissertation,
11 University of Montana, Missoula, Montana. Accessed November 6, 2020, at
12 <https://scholarworks.umt.edu/etd/10902/>. TN6730.

13 Soldat, J.K., N.M. Robinson, and D.A. Baker. 1974. *Models and Computer Codes for Evaluating*
14 *Environmental Radiation Doses*. BNWL-1754, Battelle, Pacific Northwest Laboratories,
15 Richland, Washington. ADAMS Accession No. ML12223A187. TN710.

16 Sprung, J.L., D.J. Ammerman, N.L. Breivik, R.J. Dukart, F.L. Kanipe, J.A. Koski, G.S. Mills, K.S.
17 Neuhauser, H.D. Radloff, R.F. Weiner, and H.R. Yoshimura. 2000. *Reexamination of Spent*
18 *Fuel Shipment Risk Estimates*. NUREG/CR-6672, Sandia National Laboratories, Albuquerque,
19 New Mexico. ADAMS Accession No. ML003698324. TN222.

20 TN 0400-40-03. *Tennessee Administrative Code*, Chapter 0400-40-03, "General Water Quality
21 Criteria." TN7038.

22 Toxic Substances Control Act, as amended. 15 U.S.C. § 2601 *et seq.* TN4454.

23 Trapp, H., Jr. and M.A. Horn. 1997. *Ground Water Atlas of the United States—Delaware,*
24 *Maryland, New Jersey, North Carolina, Pennsylvania, Virginia, West Virginia*. HA 730-L, U.S.
25 Geological Survey, Reston, Virginia. ADAMS Accession No. ML093280441. TN1865.

26 TVA (Tennessee Valley Authority). 2019. "Clinch River Nuclear Site Early Site Permit
27 Application, Part 03—*Environmental Report (Revision 2)*." Chattanooga, Tennessee. ADAMS
28 Package Accession No. ML19030A478. TN5854.

29 TVA (Tennessee Valley Authority). 2019. "Plant Description." Chapter 3 in *Clinch River Nuclear*
30 *Site Early Site Permit Application, Part 03, "Environmental Report (Revision 2)*." Chattanooga,
31 Tennessee. ADAMS Accession No. ML19030A420. TN6589.

32 Urenco. 2024. "History." Buckinghamshire, United Kingdom. Accessed July 1, 2024, at
33 <https://www.urengo.com/about/history>. TN10146.

34 Urenco. 2024. "NRC Accepts Urenco USA's License Amendment Request for LEU+."
35 Buckinghamshire, United Kingdom. Accessed July 1, 2024, at
36 <https://www.urengo.com/news/usa/2024/nrc-accepts-uusas-license-amendment-request-for-leu>.
37 TN10147.

- 1 USACE (U.S. Army Corps of Engineers). 1987. *Corps of Engineers Wetlands Delineation*
2 *Manual*. Wetlands Research Program Technical Report Y-87-1, Environmental Laboratory,
3 Vicksburg, Mississippi. ADAMS Accession No. ML042790476. TN2066.
- 4 USACE (U.S. Army Corps of Engineers). 1999. *The Highway Methodology Workbook*
5 *Supplement: Wetland Functions and Values, A Descriptive Approach*. NAEEP-360-1-30a, New
6 England District, Concord, Massachusetts. ADAMS Accession No. ML13274A145. TN1793.
- 7 USACE and NRC (U.S. Army Corps of Engineers and U.S. Nuclear Regulatory Commission).
8 2008. "Memorandum of Understanding Between U.S. Army Corps of Engineers and U.S.
9 Nuclear Regulatory Commission on Environmental Reviews Related to the Issuance of
10 Authorizations to Construct and Operate Nuclear Power Plants." Washington, D.C. ADAMS
11 Accession No. ML082540354. TN637.
- 12 USBR (U.S. Bureau of Reclamation). 2004. *Banks Lake Drawdown Final Environmental Impact*
13 *Statement*. Boise, Idaho. ADAMS Accession No. ML21139A345. TN6796.
- 14 USEC (USEC Inc.). 1999. *The UF6 Manual*. USEC-651, Revision 8, Bethesda, Maryland.
15 ADAMS Accession No. ML060590112. TN6515.
- 16 USGCRP (U.S. Global Change Research Program). 2014. *Climate Change Impacts in the*
17 *United States: The Third National Climate Assessment*. J.M. Melillo, T.C. Richmond, and G.W.
18 Yohe (eds.). U.S. Government Printing Office, Washington, D.C. ADAMS Accession No.
19 ML14129A233. TN3472.
- 20 USGCRP (U.S. Global Change Research Program). 2023. *The Fifth National Climate*
21 *Assessment*. A.R. Crimmins, C.W. Avery, D.R. Easterling, K.E. Kunkel, B.C. Stewart, and T.K.
22 Maycock, Eds. Washington, D.C. Available at <https://doi.org/10.7930/NCA5.2023>. TN9762.
- 23 USGS (U.S. Geological Survey). 1990. *Ground Water Atlas of the United States: Alabama,*
24 *Florida, Georgia, and South Carolina*. HA 730-G. J.A. Miller (editor), Reston, Virginia. ADAMS
25 Accession No. ML100290484. TN6648.
- 26 USNC (Ultra Safe Nuclear Corporation). 2023. "Framatome Inc. and Ultra Safe Nuclear
27 Corporation execute an agreement to establish a joint venture to manufacture fourth-generation
28 reactor fuel. Seattle, Washington. Accessed July 2, 2024, at [https://www.usnc.com/framatome-](https://www.usnc.com/framatome-inc-and-ultra-safe-nuclear-corporation-execute-an-agreement-to-establish-a-joint-venture-to-manufacture-fourth-generation-reactor-fuel/)
29 [inc-and-ultra-safe-nuclear-corporation-execute-an-agreement-to-establish-a-joint-venture-to-](https://www.usnc.com/framatome-inc-and-ultra-safe-nuclear-corporation-execute-an-agreement-to-establish-a-joint-venture-to-manufacture-fourth-generation-reactor-fuel/)
30 [manufacture-fourth-generation-reactor-fuel/](https://www.usnc.com/framatome-inc-and-ultra-safe-nuclear-corporation-execute-an-agreement-to-establish-a-joint-venture-to-manufacture-fourth-generation-reactor-fuel/). TN10158.
- 31 USNC (Ultra Safe Nuclear Corporation). 2023. "USNC Delivers TRISO Particle Fuel for NASA
32 Programs." Seattle, Washington. Accessed July 2, 2024, at [https://www.usnc.com/usnc-](https://www.usnc.com/usnc-delivers-triso-particle-fuel-for-nasa-programs/)
33 [delivers-triso-particle-fuel-for-nasa-programs/](https://www.usnc.com/usnc-delivers-triso-particle-fuel-for-nasa-programs/). TN10159.
- 34 UxC (The Ux Consulting Company, LLC). 2023. "UxC Fuel Quantity & Cost Calculator."
35 Roswell, Georgia. Accessed March 27, 2023, at
36 <https://www.uxc.com/p/tools/FuelCalculator.aspx>. TN8086.
- 37 WEC (Westinghouse Electric Company, LLC). 2019. *Environmental Report for the Columbia*
38 *Fuel Fabrication Facility*. Report Revision, Enclosure 4, Hopkins, South Carolina. ADAMS
39 Accession No. ML19088A100. TN6510.

- 1 Weiner, R.F., D.M. Osborn, D. Hinojosa, T.J. Heames, J. Penisten, and D. Orcutt. 2008.
2 *RADCAT 2.3 User Guide*. SAND2006–6315, Sandia National Laboratories, Albuquerque, New
3 Mexico. ADAMS Accession No. ML12192A238. TN302.
- 4 Weiner, R.F., D. Hinojosa, T.J. Heames, C. Ottinger Farnum, and E.A. Kalinina. 2013.
5 *RADTRAN 6/RadCat 6 User Guide*. SAND2013–8095, Sandia National Laboratories,
6 Albuquerque, New Mexico. ADAMS Accession No. ML14286A092. TN3390.
- 7 Weiner, R.F., K.S. Neuhauser, T.J. Heames, B.M. O'Donnell, and M.L. Dennis. 2014.
8 *RADTRAN 6 Technical Manual*. SAND2013-0780, Sandia National Laboratories, Albuquerque,
9 New Mexico. ADAMS Accession No. ML14286A085. TN3389.
- 10 WHO (World Health Organization). 2020. "What are Electromagnetic Fields?" Geneva,
11 Switzerland. Accessed October 1, 2020, at [https://www.who.int/peh-](https://www.who.int/peh-emf/about/WhatisEMF/en/index3.html)
12 [emf/about/WhatisEMF/en/index3.html](https://www.who.int/peh-emf/about/WhatisEMF/en/index3.html). TN6561.
- 13 WNA (World Nuclear Association). 2017. "Thorium." London, United Kingdom. Accessed
14 October 16, 2020, at [https://www.world-nuclear.org/information-library/current-and-future-](https://www.world-nuclear.org/information-library/current-and-future-generation/thorium.aspx)
15 [generation/thorium.aspx](https://www.world-nuclear.org/information-library/current-and-future-generation/thorium.aspx). TN6668.
- 16 WNA (World Nuclear Association). 2020. "Uranium Enrichment." London, United Kingdom.
17 Webpage accessed October 16, 2020, at [https://www.world-nuclear.org/information-](https://www.world-nuclear.org/information-library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/uranium-enrichment.aspx)
18 [library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/uranium-enrichment.aspx](https://www.world-nuclear.org/information-library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/uranium-enrichment.aspx).
19 TN6661.
- 20 WNA (World Nuclear Association). 2021. "Molten Salt Reactors." London, United Kingdom.
21 Webpage accessed June 7, 2021, at [https://www.world-nuclear.org/information-library/current-](https://www.world-nuclear.org/information-library/current-and-future-generation/molten-salt-reactors.aspx)
22 [and-future-generation/molten-salt-reactors.aspx](https://www.world-nuclear.org/information-library/current-and-future-generation/molten-salt-reactors.aspx). TN7072.
- 23 WNA (World Nuclear Association). 2021. "Nuclear Fuel and its Fabrication." London, United
24 Kingdom. Accessed July 2, 2024, at [https://world-nuclear.org/information-library/nuclear-fuel-](https://world-nuclear.org/information-library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/fuel-fabrication)
25 [cycle/conversion-enrichment-and-fabrication/fuel-fabrication](https://world-nuclear.org/information-library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/fuel-fabrication). TN10153.
- 26 WNN (World Nuclear News). 2020. "X-energy TRISO-X Fuel to be Irradiated at MIT." London,
27 United Kingdom. Webpage accessed November 9, 2020, at [https://world-nuclear-](https://world-nuclear-news.org/Articles/X-energy-TRISO-X-fuel-to-be-irradiated-at-MIT)
28 [news.org/Articles/X-energy-TRISO-X-fuel-to-be-irradiated-at-MIT](https://world-nuclear-news.org/Articles/X-energy-TRISO-X-fuel-to-be-irradiated-at-MIT). TN6740.
- 29 WSDOT (Washington State Department of Transportation). 2017. "Construction Noise Impact
30 Assessment." Chapter 7 in *Biological Assessment Preparation for Transportation Projects –*
31 *Advanced Training Manual*. Olympia, Washington. Available at
32 http://www.wsdot.wa.gov/sites/default/files/2018/01/18/Env-FW-BA_ManualCH07.pdf. TN5313.
- 33 X-Energy (X-Energy, LLC). 2020. "TRISO-X." Greenbelt, Maryland. Webpage accessed August
34 25, 2020, at <https://x-energy.com/fuel/triso-x>. TN6736.
- 35 Yahner, R.H. 2000. *Eastern Deciduous Forest: Ecology and Wildlife Conservation*. University of
36 Minnesota Press, Minneapolis, Minnesota. DOI: 10.5749/j.ctttsrbh. TN6565.

1 **APPENDIX A**

2

3 **CONTRIBUTORS TO THE ENVIRONMENTAL IMPACT STATEMENT**

4 Members of the U.S. Nuclear Regulatory Commission prepared this generic environmental
5 impact statement with assistance and support from Pacific Northwest National Laboratory and a
6 commercial contractor. The table below identifies each contributor’s name, affiliation, and
7 function or expertise.

8 **Table A-1 U.S. Nuclear Regulatory Commission Preparers**

| Name | Affiliation | Review Area/Expertise |
|-----------------------------|--|--|
| Jack Cushing ^(a) | Office of Nuclear Material Safety and Safeguards | Project Management, Historic and Cultural Resources, Cumulative Impacts |
| Stacey Imboden | Office of Nuclear Material Safety and Safeguards | Project Management, Meteorology and Air Quality, Climate Change, Nonradiological Environment |
| Laura Willingham | Office of Nuclear Material Safety and Safeguards | Project Management, Meteorology and Air Quality, Climate Change |
| Dan Barnhurst | Office of Nuclear Material Safety and Safeguards | Surface Water and Groundwater Resources, Project Management |
| Jennifer Davis | Office of Nuclear Material Safety and Safeguards | Historic and Cultural Resources |
| Peyton Doub | Office of Nuclear Material Safety and Safeguards | Land Use, Terrestrial Ecology, Aquatic Ecology, Visual Resources, Alternatives, Executive Summary |
| Kevin Folk | Office of Nuclear Material Safety and Safeguards | Surface Water and Groundwater Resources |
| Dan Mussatti ^(b) | Office of Nuclear Material Safety and Safeguards | Visual Resources, Noise, Socioeconomics, Environmental Justice, Need for Project |
| Donald Palmrose | Office of Nuclear Material Safety and Safeguards | Radiological Environment, Accidents, Radiological Waste Management, Fuel Cycle, Transportation of Fuel and Waste, Decommissioning, Continued Storage |
| Jeffrey Rikhoff | Office of Nuclear Material Safety and Safeguards | Environmental Justice |

(a) Retired from the U.S. Nuclear Regulatory Commission in 2021.

(b) Retired from the U.S. Nuclear Regulatory Commission in 2023.

Table A-2 Pacific Northwest National Laboratory^(a) Preparers

| Name | Review Area/Expertise |
|---|---|
| Bo Saulsbury ^(b) | Project Management |
| Dave Goodman | Project Management, Land Use, Visual Resources, Noise, Alternatives Analysis, Cumulative Impacts |
| Andrew Kugler | Project Management, Plant and Site Parameter Envelopes, Alternatives |
| Terri Miley/Sadie Montgomery | Comment Response |
| Bruce McDowell/Saikat Ghosh | Air Quality |
| Rajiv Prasad/Kazi Tamaddun | Surface Water Resources |
| Philip Meyer/Rebecka Bence | Groundwater Resources |
| Stephanie Larson/Tracy Fuentes/Jim Becker | Terrestrial Ecology |
| Ann Miracle/Stephanie Larson | Aquatic Ecology |
| Tara O'Neil/Lindsey Renaud/Ellen Kennedy | Historic and Cultural Resources |
| Dave Anderson | Socioeconomics, Environmental Justice |
| Kim Leigh/Seema Verma | Nonradiological Environment |
| Caitlin Condon/Jon Napier/Steve Maheras | Radiological Environment, Waste Management, Fuel Cycle, Decommissioning, Accidents, Transportation of Fuel and Waste, Continued Storage |

(a) Pacific Northwest National Laboratory (PNNL) is managed for the U.S. Department of Energy by Battelle Memorial Institute.

(b) Formerly of PNNL.

APPENDIX B

OUTREACH

This appendix provides a description of outreach activities and the Federal, State, and Tribal agencies and groups that the U.S. Nuclear Regulatory Commission (NRC) contacted during the preparation of this *Generic Environmental Impact Statement for Licensing New Nuclear Reactors* (NR GEIS). The NRC did not identify any cooperating agencies for the environmental review or receive any formal requests for cooperating agency status. The NRC staff conducted extensive outreach during preparation of the draft NR GEIS and rule.

B.1 Exploratory Process

On November 15, 2019, the NRC staff issued the following *Federal Register* Notices (84 FR 62559-TN6470, 84 FR 67299-TN7085, and 84 FR 68194-TN7084) announcing an exploratory process and soliciting comments to determine the possibility of developing a GEIS for licensing advanced nuclear reactors. The exploratory process included two public meetings, a comprehensive public workshop attended by multiple stakeholders, and a site visit to the Idaho National Laboratory, a location that is being contemplated for advanced reactors (NRC 2019-TN7087, NRC 2019-TN7086, NRC 2020-TN7088).

B.2 Public Meetings and Webinars

On May 28, 2020 from 1:00 p.m. to 4:00 p.m. the NRC staff held a webinar with the public as part of the scoping process to gather information necessary to prepare a GEIS for advanced nuclear reactors (85 FR 24040-TN6458).

B.3 Obtaining Comments

The staff collected comments from the public three ways during the public comment period associated with the initial scoping process, held from April 30, 2020 to June 30, 2020 (85 FR 24040-TN6458).

- **Federal Rulemaking website:** The public submitted comments to the NRC staff through the Federal Rulemaking website at <https://www.regulations.gov> using Docket ID NRC-2020-0101.
- **Advanced Reactors-GEIS Email:** The NRC staff used an email account, AdvancedReactors-GEIS@nrc.gov, to receive comments from the public during the initial scoping process for the GEIS.
- **Mail:** The NRC staff requested that comments be sent by mail, if desired, to Office of Administration, Mail Stop TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555-0001.

B.4 Distribution of the Scoping Summary Report

The NRC staff summarized the comments received during the scoping process and the staff's related responses in a report titled, *Environmental Impact Statement Scoping Process Summary Report: The Advanced Nuclear Reactor Generic Environmental Impact Statement Public Scoping Period* (NRC 2020-TN6593). This scoping report was issued in September 2020.

1 **B.5 NRC Website**

2 Throughout the development of the NR GEIS and the rulemaking process, the NRC maintained
3 a webpage at: <https://www.nrc.gov/reactors/new-reactors/advanced/details.html#advRxGEIS>
4 (NRC 2021-TN7099). The NRC regularly updated the website, which contained a description of
5 the purpose of the GEIS and rulemaking, the history of the GEIS development and rulemaking,
6 and the schedule for the GEIS and rule. The website also provided an overview of key
7 communications between the staff and Commission (SECY-20-0020 [NRC 2020-TN6493] and
8 SRM-SECY-20-0020 [NRC 2020-TN6492]) and the public. In addition there is a website for the
9 rulemaking effort associated with the NR GEIS at [https://www.nrc.gov/reading-rm/doc-
10 collections/rulemaking-ruleforum/active/rule/details.html?id=1139](https://www.nrc.gov/reading-rm/doc-collections/rulemaking-ruleforum/active/rule/details.html?id=1139) (NRC 2021-TN7103). This
11 website provides the public with rulemaking information such as the schedule, the NRC docket
12 ID, and the rulemaking project manager information along with other information.

13 **B.6 Advanced Reactor Stakeholder Meetings**

14 On at least nine occasions, the NRC staff has taken part in the periodic Advanced Reactor
15 Stakeholder Meetings to provide an overview of the GEIS development and answer questions.
16 All meetings were open to the public and associated slides may be found at
17 <https://www.nrc.gov/reactors/new-reactors/advanced/details.html#stakeholder> (NRC 2021-
18 TN7099).

19 **B.7 Tribal Contact**

20 The NRC staff contacted federally recognized Tribes via a State and Tribal Correspondence
21 letter regarding scoping for the ANR GEIS (NRC 2020-TN7095). The staff distributed the
22 scoping summary report to Tribes via LYRIS distribution through the NRC Tribal liaison branch
23 (NRC 2020-TN7094, NRC 2020-TN7093, NRC 2020-TN7092, NRC 2020-TN7091, NRC 2020-
24 TN7090, NRC 2020-TN7089). Another State and Tribal Correspondence letter was sent to invite
25 Tribes to attend the July 15, 2021 Advanced Reactors Stakeholder meeting (NRC 2021-
26 TN7096).

27 **B.8 Other Federal Agencies**

28 On April 1, 2020, the NRC reached out to the Advisory Council on Historic Preservation and the
29 U.S. Environmental Protection Agency via email to notify them of the NRC's intent to conduct a
30 scoping process for the ANR GEIS and to inform the agencies that the NRC would issue a
31 *Federal Register* Notice (NRC 2021-TN7097, NRC 2021-TN7098).

32 **B.9 References**

33 84 FR 62559. November 15, 2019. "Agency Action Regarding the Exploratory Process for the
34 Development of an Advanced Nuclear Reactor Generic Environmental Impact Statement."
35 *Federal Register*, Nuclear Regulatory Commission. TN6470.

36 84 FR 67299. December 9, 2019. "Agency Action Regarding the Exploratory Process for the
37 Development of an Advanced Nuclear Reactor; Generic Environmental Impact Statement."
38 *Federal Register*, Nuclear Regulatory Commission. TN7085.

1 84 FR 68194. December 13, 2019. "Agency Action Regarding the Exploratory Process for the
2 Development of an Advanced Nuclear Reactor; Generic Environmental Impact Statement;
3 Correction." *Federal Register*, Nuclear Regulatory Commission. TN7084.

4 85 FR 24040. April 30, 2020. "Notice To Conduct Scoping and Prepare an Advanced Nuclear
5 Reactor Generic Environmental Impact Statement." *Federal Register*, Nuclear Regulatory
6 Commission. TN6458.

7 NRC (U.S. Nuclear Regulatory Commission). 2019. Memorandum from M.A. Sutton to B.G.
8 Beasley, Office of Nuclear Reactor Regulation, dated December 10, 2019, regarding "Summary
9 of November 15 and 20, 2019, Public Meetings to Discuss Exploratory Process for Developing
10 an Advanced Nuclear Reactor Generic Environmental Impact Statement." Washington, D.C.
11 ADAMS Accession No. ML19337C862. TN7086.

12 NRC (U.S. Nuclear Regulatory Commission). 2019. Public Meeting Announcement and Agenda,
13 November 15 and 20, 2019, "Meeting to Discuss the Environmental Information Needed to
14 Develop a Generic Environmental Impact Statement for Advanced Nuclear Reactors."
15 Washington, D.C. ADAMS Accession No. ML19304B011. TN7087.

16 NRC (U.S. Nuclear Regulatory Commission). 2020. Email from J. Olmstead to NRC, dated
17 November 17, 2020, regarding "Scoping Summary Report for the Advanced Reactor Generic
18 Environmental Impact Statement." Washington, D.C. ADAMS Accession No. ML21224A280.
19 TN7089.

20 NRC (U.S. Nuclear Regulatory Commission). 2020. Email from L. Willingham to the Hopi Tribe,
21 dated November 17, 2020, regarding "U.S. Nuclear Regulatory Commission - Advanced
22 Reactor Generic Environmental Impact Statement Scoping Summary Report." Washington, D.C.
23 ADAMS Accession No. ML21224A293. TN7091.

24 NRC (U.S. Nuclear Regulatory Commission). 2020. Email from L. Willingham to the Miami Tribe
25 of Oklahoma, dated November 17, 2020, regarding "U.S. Nuclear Regulatory Commission -
26 Advanced Reactor Generic Environmental Impact Statement Scoping Summary Report."
27 Washington, D.C. ADAMS Accession No. ML21224A296. TN7090.

28 NRC (U.S. Nuclear Regulatory Commission). 2020. Email from L. Willingham to the Navajo
29 Nation, dated November 17, 2020, regarding "U.S. Nuclear Regulatory Commission - Advanced
30 Reactor Generic Environmental Impact Statement Scoping Summary Report." Washington, D.C.
31 ADAMS Accession No. ML21224A292. TN7092.

32 NRC (U.S. Nuclear Regulatory Commission). 2020. Email from L. Willingham to the San Manuel
33 Band of Mission Indians, dated November 17, 2020, regarding "U.S. Nuclear Regulatory
34 Commission - Advanced Reactor Generic Environmental Impact Statement Scoping Summary
35 Report." Washington, D.C. ADAMS Accession No. ML21224A291. TN7093.

36 NRC (U.S. Nuclear Regulatory Commission). 2020. Email from L. Willingham to the Shoshone-
37 Bannock Tribe, dated November 17, 2020, regarding "U.S. Nuclear Regulatory Commission -
38 Advanced Reactor Generic Environmental Impact Statement Scoping Summary Report."
39 Washington, D.C. ADAMS Accession No. ML21216A202. TN7094.

1 NRC (U.S. Nuclear Regulatory Commission). 2020. Letter from L.Y. Cuadrado to All Agreement
2 and Non-Agreement States, State Liaison Officers, and All Federally Recognized Indian Tribes,
3 dated April 30,2020, regarding “Notification of the Intent to Conduct a Scoping Process and
4 Prepare a Generic Environmental Impact Statement for Advanced Nuclear Reactors.”
5 Washington, D.C. ADAMS Accession No. ML20114E140. TN7095.

6 NRC (U.S. Nuclear Regulatory Commission). 2020. Memorandum from A.L. Vietti-Cook to M.M.
7 Doane, dated September 21, 2020, regarding Staff Requirements - SECY-20-0020 - Results of
8 Exploratory Process for Developing a Generic Environmental Impact Statement for the
9 Construction and Operation of Advanced Nuclear Reactors.” SRM-SECY-20-0020, Washington,
10 D.C. ADAMS Accession No. ML20265A112. TN6492.

11 NRC (U.S. Nuclear Regulatory Commission). 2020. *Policy Issue: Results of Exploratory*
12 *Process for Developing a Generic Environmental Impact Statement for the Construction and*
13 *Operation of Advanced Nuclear Reactors.* SECY-20-0020, Washington, D.C. ADAMS
14 Accession No. ML20052D175. TN6493.

15 NRC (U.S. Nuclear Regulatory Commission). 2020. Public Meeting Announcement and Agenda,
16 January 08, 2020, “Workshop to Discuss the Environmental Information Needed to Develop a
17 Generic Environmental Impact Statement for Advanced Nuclear Reactors.” Washington, D.C.
18 ADAMS Accession No. ML19347A733. TN7088.

19 NRC (U.S. Nuclear Regulatory Commission). 2020. *Scoping Summary Report for the Advanced*
20 *Nuclear Reactor Generic Environmental Impact Statement Public Scoping Period.* Washington,
21 D.C. ADAMS Accession No. ML20269A317. TN6593.

22 NRC (U.S. Nuclear Regulatory Commission). 2021. “Advanced Reactors Details.” Washington,
23 D.C. ADAMS Accession No. ML21232A543. TN7099.

24 NRC (U.S. Nuclear Regulatory Commission). 2021. Email from NRC to ACHP, dated April 1,
25 2021. regarding “NRC Preparing an Advance Nuclear Reactor Generic Environmental Impact
26 Statement (GEIS).” Washington, D.C. ADAMS Accession No. ML21219A001. TN7097.

27 NRC (U.S. Nuclear Regulatory Commission). 2021. Email from NRC to EPA, dated April 1,
28 2021. regarding “NRC Preparing an Advance Nuclear Reactor Generic Environmental Impact
29 Statement (GEIS).” Washington, D.C. ADAMS Accession No. ML21218A186. TN7098.

30 NRC (U.S. Nuclear Regulatory Commission). 2021. Letter from M. Arribas-Colon to All
31 Agreement States, Connecticut, Indiana, Non-Agreement States, State Liaison Officers, and
32 Federally Recognized Indian Tribes, dated July 12, 2021, regarding “Opportunity to Observe the
33 U.S. Nuclear Regulatory Commission Periodic Advanced Reactor Stakeholder Meeting (STC-
34 21-044).” Washington, D.C. ADAMS Accession No. ML21190A285. TN7096.

35 NRC (U.S. Nuclear Regulatory Commission). 2021. “Planned Rulemaking Activities - Rule.”
36 Washington, D.C. ADAMS Accession No. ML21232A497. TN7103.

APPENDIX C

CHRONOLOGY OF NRC STAFF ENVIRONMENTAL REVIEW CORRESPONDENCE RELATED TO THE ADVANCED REACTOR GENERIC ENVIRONMENTAL IMPACT STATEMENT

- 6 This appendix contains a chronological listing of correspondence between the U.S. Nuclear
7 Regulatory Commission (NRC) staff and external parties as part of its development of the
8 *Generic Environmental Impact Statement for Licensing New Nuclear Reactors*.
- 9 All documents, with the exception of those containing proprietary information, are available
10 electronically in the NRC's Library, which is found on the Internet at the following Web address:
11 <http://www.nrc.gov/reading-rm.html>. From this site, the public can gain access to the NRC's
12 Agencywide Documents Access and Management System (ADAMS), which provides text and
13 image files of the NRC's public documents. The ADAMS accession number for each document
14 is included below. If you need assistance in accessing or searching in ADAMS, contact the
15 Public Document Room staff at 1-800-397-4209.
- 16 November 15, 2019 NRC *Federal Register* Notice (FRN) Announcing an Exploratory Process
17 and Soliciting Comments on a Possible ANR GEIS (84 FR 62559)
18 (Accession No. ML19302G126)
- 19 February 28, 2020 SECY-20-0020, Results of Exploratory Process for Developing a GEIS for
20 the Construction and Operation of Advanced Nuclear Reactors (Package
21 Accession No. ML20052D175)
- 22 April 1, 2020 Scoping e-mail to NRC, from J. Eddins, Advisory Council on Historic
23 Preservation, Regarding Preparation of a GEIS for Advanced Reactors
24 (Accession No. ML21219A001)
- 25 April 1, 2020 Scoping email to M. Roundtree, Environmental Protection Agency, from
26 NRC, Regarding Preparation of an Advance Nuclear Reactor GEIS
27 (Accession No. ML21218A186)
- 28 April 21, 2020 NRC FRN Announcing an Exploratory Process, Public Meetings, and
29 Soliciting Comments on an ANR GEIS (Accession No. ML20111A308)
- 30 April 30, 2020 NRC FRN Providing Notice of Intent to Conduct Scoping and Prepare an
31 ANR GEIS (85 FR 24040) (Accession No. ML20111A308)
- 32 April 30, 2020 NRC Notification to All Agreement and Non-Agreement States, State
33 Liaison Officers, and All Federally Recognized Indian Tribes, Regarding
34 Notice of Intent to Conduct Scoping and Prepare an ANR GEIS (STC-20-
35 036) (Accession No. ML20114E140)
- 36 April 30, 2020 Public Meeting Notice to Discuss the Scope of the GEIS for ANRs
37 (Accession No. ML20148M245)

1 May 14, 2020 E-mail to NRC, from K. Jensen, The Yocha Dehe Wintun Nation,
2 Regarding the Generic EIS for Small Scale ANR (Accession No.
3 ML21220A000)

4 May 14, 2020 E-mail to L. Bill, The Yocha Dehe Wintun Nation, from NRC, Regarding
5 Yocha Dehe Wintun Nation Notification Response (Accession No.
6 ML21220A001)

7 May 27, 2020 E-mail to M. Bremer, The Pueblo de San Ildefonso Tribe, from NRC,
8 Regarding the Generic EIS for ANR (Accession No. ML21220A003)

9 June 3, 2020 E-mail from A. McCleary, The San Manuel Band of Mission Indians,
10 Regarding attending the scoping meeting (Accession No. ML21223A341)

11 June 10, 2020 Letter to D. True, Nuclear Energy Institute, from NRC, Regarding the
12 Nuclear Energy Institute's March 5, 2020 letter "Recommendations for
13 Streamlining Environmental Reviews for Advanced Reactors" (Accession
14 No. ML20147A540)

15 July 2, 2020 NRC Memorandum: Scoping Meeting Summary (Package Accession No.
16 ML20161A339)

17 July 23, 2020 Letter to NRC, from Senators J. Barrasso, M. Braun, and M. Crapo,
18 Regarding the ANR GEIS (Accession No. ML20206K923)

19 August 19, 2020 E-mail to D. Hunter, The Miami Tribe of Oklahoma, from NRC, Regarding
20 Notification of Intent to Review and update the Generic EIS (Accession
21 No. ML20233A558)

22 August 27, 2020 Letter to Senator J. Barrasso, from NRC, Regarding the Senator's July
23 23, 202p letter on the ANR GEIS (Accession No. ML20225A074)

24 September 21, 2020 Staff Requirements Memorandum (SRM) 20-0020, Results of Exploratory
25 Process for Developing a GEIS for the Construction and Operation of
26 ANRs (Accession No. ML20265A112)

27 September 22, 2020 E-mail to Mr. Koyiyumptewa, The Hopi Tribe, from NRC, Regarding the
28 Hopi Tribe Response to the NRC's April 30, 2020 letter (Accession No.
29 ML21223A408)

30 September 25, 2020 ANR GEIS Scoping Summary Report (Package Accession No.
31 ML20260H180)

32 November 17, 2020 Email to T. Martin, The Shoshone Bannock Tribe, from NRC, Regarding
33 the ANR GEIS Scoping Summary Report (Accession No. ML21216A202)

34 November 17, 2020 E-mail to A. McCleary, The San Manuel Band of Mission Indians,
35 transmitting the ANR GEIS Scoping Summary Report (Accession No.
36 ML21224A291)

1 November 17, 2020 E-mail to Mr. Karr, Navajo Nation, Department of Justice, transmitting the
2 ANR GEIS Scoping Summary Report (Accession No. ML21224A292)

3 November 17, 2020 E-mail to Mr. Koyiyumptewa, The Hopi Tribe, transmitting the ANR GEIS
4 Scoping Summary Report (Accession No. ML21224A293)

5 November 17, 2020 Email to D. Hunter, The Miami Tribe of Oklahoma, transmitting the ANR
6 GEIS Scoping Summary Report (Accession No. ML21224A296)

7 November 17, 2020 Email from Joan Olmstead transmitting the Scoping summary report to
8 Tribal and State Liaison Contacts (Accession No. ML21224A280)

9 December 14, 2021 Submittal of Proposed Rule: Advanced Nuclear Reactor Generic
10 Environmental Impact Statement (Accession No. ML21222A044)

11 April 18, 2024 Staff Requirements Memorandum – SECY-21-0098 – Proposed Rule:
12 Advanced Nuclear Reactor Generic Environmental Impact Statement
13 (Accession No. ML24108A200)

1 **APPENDIX D**

2
3 **DISTRIBUTION LIST**

4 The U.S. Nuclear Regulatory Commission (NRC) is providing copies of the *Generic*
5 *Environmental Impact Statement for Licensing New Nuclear Reactors* (NR GEIS) to the
6 organizations and individuals listed below. In addition, the NRC will issue a State and Tribal
7 Correspondence letter to notify all federally recognized Tribes and State liaison contacts. The
8 NRC will also send the NR GEIS to over 3,000 private citizens that provided scoping comments
9 during the scoping period held for the GEIS from April to June 2020. The NRC will provide hard
10 copies to other interested organizations and individuals upon request.

11 **Table D-1 Distribution List**

| Name | Affiliation |
|--|---|
| Federal Agencies | |
| John Eddins | Advisory Council on Historic Preservation |
| William James | U.S. Army Corps of Engineers |
| Robert Tomiak | U.S. Environmental Protection Agency (EPA) Office of Federal Activities |
| Other Organizations and Individuals | |
| Bud Albright | U.S. Nuclear Industry Council |
| Peter Hastings | Kairos |
| Edwin Lyman | Union of Concerned Scientists |
| Nicholas McMurray | ClearPath |
| Marcus Nichol | Nuclear Energy Institute |
| Caleb Ward | U.S. Nuclear Industry Council |

APPENDIX E

COMMENTS ON THE GEIS

E.1 Public Scoping

On April 30, 2020, the U.S. Nuclear Regulatory Commission (NRC) issued, for public comment, a notice of intent to prepare an advanced nuclear reactor (ANR) generic environmental impact statement (GEIS) and to conduct a scoping process to gather the information necessary to prepare such a GEIS for small-scale ANRs (85 FR 24040-TN6458). The NRC held a webinar on May 28, 2020, to receive comments from the public on the scope of the GEIS (NRC 2020-TN6459).

The NRC received a number of comments about the scope of this GEIS both during the May 28, 2020 webinar and throughout the scoping comment period. The NRC staff and its contractor reviewed the transcript from the webinar and all written materials received during the public comment period. All comments were considered. The NRC staff issued a summary of the scoping comments, and the staff's responses to those comments, on September 25, 2020 (NRC 2020-TN6593).

In accordance with 10 CFR 51.29(b) (TN250), this scoping summary report has been made publicly available at the NRC Public Document Room, located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, or from the Agencywide Documents Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible through the NRC's public website, www.nrc.gov. The accession number for the scoping summary report is ML20269A317.

E.2 Comments on the Draft GEIS

(Reserved for future use.)

E.3 References

10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, "Environmental Protection Regulations for Domestic Licensing and Related Regulatory Functions." TN250.

85 FR 24040. April 30, 2020. "Notice To Conduct Scoping and Prepare an Advanced Nuclear Reactor Generic Environmental Impact Statement." *Federal Register*, Nuclear Regulatory Commission. TN6458.

NRC (U.S. Nuclear Regulatory Commission). 2020. *Scoping Summary Report for the Advanced Nuclear Reactor Generic Environmental Impact Statement Public Scoping Period*. Washington, D.C. ADAMS Accession No. ML20269A317. TN6593.

NRC (U.S. Nuclear Regulatory Commission). 2020. *Summary of Public Scoping Meeting Conducted for the Advanced Reactor Generic Environmental Impact Statement, May 28, 2020*. Washington, D.C. ADAMS Package Accession No. ML20161A339. TN6459.

APPENDIX F

LAWS, REGULATIONS, AND OTHER AUTHORIZATIONS

F.1 Introduction

This appendix presents a brief discussion of Federal and State laws, regulations, and other requirements that may affect the application for and issuance of a license for a new nuclear reactor. The Federal and State laws, regulations, and other requirements listed herein are designed to protect the environment and address the following topics: land and water use, air quality, aquatic resources, terrestrial resources, radiological impacts, waste management, chemical impacts, and socioeconomic conditions. Title 10 of the *Code of Federal Regulations* (10 CFR) 51.45(d) (TN250), "Status of compliance," states:

The environmental report shall list all Federal permits, licenses, approvals, and other entitlements which must be obtained in connection with the proposed action and shall describe the status of compliance with these requirements. The environmental report shall also include a discussion of the status of compliance with applicable environmental quality standards and requirements including, but not limited to, applicable zoning and land-use regulations, and thermal and other water pollution limitations or requirements which have been imposed by Federal, State, regional, and local agencies having responsibility for environmental protection. The discussion of alternatives in the report shall include a discussion of whether the alternatives will comply with such applicable environmental quality standards and requirements.

The U.S. Nuclear Regulatory Commission (NRC) uses compliance with other laws and regulations designed to protect the environment in the assessment of environmental impacts in its environmental impact statement (EIS).

This appendix is intended to provide a basic overview to assist the applicant in identifying environmental and natural resources laws that may affect the new nuclear reactor licensing process. The descriptions of the laws, regulations, Executive Orders, and other directives are general in nature and are not intended to provide a comprehensive analysis or explanation of any of the items listed. In addition, the list itself is not intended to be comprehensive, and an applicant for a new nuclear reactor license is reminded that a variety of additional Federal, State, or local requirements may apply to their application.

Section F.2 identifies Federal laws and regulations that may be applicable to the new nuclear reactor licensing process. Section F.3 discusses relevant environmental Executive Orders, and Section F.4 identifies applicable NRC regulations. Section F.5 discusses State laws, regulations, and agreements, and Section F.6 discusses emergency management and response laws, regulations, and Executive Orders. Section F.7 discusses laws that contain requirements for consultation with agencies and federally recognized American Indian Nations.

F.2 Federal Laws and Regulations

The Federal laws and regulations that are identified and briefly discussed in this section are presented in alphabetical order.

1 **American Indian Religious Freedom Act of 1978 (42 United States Code [U.S.C.] § 1996;**
2 TN5281) – The American Indian Religious Freedom Act protects Native Americans’ rights of
3 freedom to believe, express, and exercise traditional religions.

4 **Antiquities Act of 1906, as amended (54 U.S.C. §§ 320301–320303 and 18 U.S.C.**
5 **§ 1866(b); TN6602)** – The Antiquities Act protects historic and prehistoric ruins, monuments,
6 and antiquities, including paleontological resources, on federally controlled lands from
7 appropriation, excavation, injury, and destruction without permission.

8 **Archeological and Historic Preservation Act of 1974, as amended (54 U.S.C. §§ 312501**
9 **et seq.; TN4844)** – The Archeological and Historic Preservation Act establishes procedures for
10 preserving historical and archaeological resources. Analysis of environmental compliance
11 included assessing the energy alternatives for possible impacts on prehistoric, historic, and
12 traditional cultural resources.

13 **Archaeological Resources Protection Act of 1979, as amended (54 U.S.C. §§ 302101**
14 **et seq.; TN1687)** – The Archaeological Resources Protection Act requires a permit for any
15 excavation or removal of archaeological resources from Federal or American Indian lands.
16 Excavations must be undertaken for the purpose of furthering archaeological knowledge in the
17 public interest, and resources removed are to remain the property of the United States. Consent
18 must be obtained from the American Indian Tribe or the Federal agency that has authority over
19 the land, on which a resource is located, before issuance of a permit. The permit must contain
20 terms and conditions requested by the Tribe or Federal agency.

21 **Atomic Energy Act of 1954 (42 U.S.C. §§ 2011 et seq.; TN663)** – The 1954 Atomic Energy
22 Act (AEA), as amended, and the Energy Reorganization Act of 1974 (42 U.S.C. § 5801 et seq.;
23 TN4466) gives the NRC the licensing and regulatory authority for nuclear energy uses within the
24 commercial sector. It gives the NRC responsibility for licensing and regulating commercial uses
25 of atomic energy and allows the NRC to establish dose and concentration limits for protection of
26 workers and the public for activities under NRC jurisdiction. The NRC implements its
27 responsibilities under the AEA through regulations set forth in 10 CFR.

28 **Bald and Golden Eagle Protection Act of 1940, as amended (16 U.S.C. §§ 668–668d;**
29 **TN1447)** – The Bald and Golden Eagle Protection Act makes it unlawful to take, pursue, molest,
30 or disturb bald and golden eagles, their nests, or their eggs anywhere in the United States. The
31 U.S. Fish and Wildlife Service (FWS) may issue take permits to individuals, government
32 agencies, or other organizations to authorize limited, non-purposeful disturbance of eagles, in
33 the course of conducting lawful activities such as operating utilities or conducting scientific
34 research.

35 **Clean Air Act of 1970, as amended (42 U.S.C. §§ 7401 et seq.; TN1141)** – The Clean Air Act
36 (CAA) is intended to “protect and enhance the quality of the nation’s air resources so as to
37 promote the public health and welfare and the productive capacity of its population.” The CAA
38 establishes regulations to ensure maintenance of air quality standards and authorizes individual
39 States to manage permits. Section 118 of the CAA requires each Federal agency, with
40 jurisdiction over properties or facilities engaged in any activity that might result in the discharge
41 of air pollutants, to comply with all Federal, State, interstate, and local requirements with regard
42 to the control and abatement of air pollution. Section 109 of the CAA directs the U.S.
43 Environmental Protection Agency (EPA) to set National Ambient Air Quality Standards
44 (NAAQSs) for criteria pollutants. The EPA has identified and set NAAQSs for the following
45 criteria pollutants: particulate matter, sulfur dioxide, carbon monoxide, ozone, nitrogen dioxide,

1 and lead. Section 111 of the CAA requires establishment of national performance standards for
2 new or modified stationary sources of atmospheric pollutants. Section 160 of the CAA requires
3 that specific emission increases must be evaluated prior to permit approval in order to prevent
4 significant deterioration of air quality. Section 112 requires specific standards for release of
5 hazardous air pollutants (including radionuclides). These standards are implemented through
6 plans developed by each State and approved by the EPA. The CAA requires sources to meet
7 standards and obtain permits to satisfy those standards. Nuclear power plants may be required
8 to comply with the CAA Title V, Sections 501–507, for sources subject to new source
9 performance standards or sources subject to National Emission Standards for Hazardous Air
10 Pollutants. Emissions of air pollutants are regulated by the EPA in 40 CFR Parts 50 to 99
11 (TN5264).

12 **Clean Water Act (33 U.S.C. §§ 1251 et seq.; TN662)** – The Clean Water Act (CWA; formerly
13 the Federal Water Pollution Control Act of 1972) was enacted to “restore and maintain the
14 chemical, physical, and biological integrity of the Nation’s water.” The Act requires all branches
15 of the Federal government, with jurisdiction over properties or facilities engaged in any activity
16 that might result in a discharge or runoff of pollutants to surface waters, to comply with Federal,
17 State, interstate, and local requirements.

18 As authorized by the CWA, the National Pollutant Discharge Elimination System (NPDES)
19 permit program controls water pollution by regulating point sources that discharge pollutants into
20 waters of the United States. The NPDES program requires that all facilities that discharge
21 pollutants from any point source into waters of the United States obtain an NPDES permit. An
22 NPDES permit is developed with two levels of controls: technology-based limits and water
23 quality-based limits. NPDES permit terms may not exceed 5 years, and the applicant must
24 reapply at least 180 days prior to the permit expiration date. A nuclear power plant may also
25 participate in the NPDES General Permit for Industrial Stormwater due to stormwater runoff
26 from industrial or commercial facilities to waters of the United States. The EPA is authorized
27 under the CWA to directly implement the NPDES program; however, the EPA has authorized
28 many States to implement all or parts of the national program. Section 401 of the CWA requires
29 that an applicant for a Federal license or permit, whose activities may cause a discharge of
30 regulated pollutants into navigable waters, provide the Federal licensing or permitting agency
31 with a certification from the State or appropriate water pollution control agency in which the
32 discharge originates or will originate. This water quality certification implies that discharges from
33 the activity or project to be licensed or permitted will comply with CWA requirements, as
34 applicable, including that the discharge will not cause or contribute to a violation of applicable
35 water quality standards.

36 The U.S. Army Corps of Engineers (USACE) is the lead agency for enforcement of CWA
37 wetland requirements (33 CFR Part 320-TN424). Under Section 401 of the CWA, the EPA or a
38 delegated State agency has the authority to review and approve, condition, or deny all permits
39 or licenses that might result in a discharge to waters of the State, including wetlands. CWA
40 Section 401 [33 U.S.C. 1341(a)(1)] states: “No license or permit shall be granted until the
41 certification required by this section has been obtained or has been waived as provided in the
42 preceding sentence. No license or permit shall be granted if certification has been denied by the
43 State, inter-State agency, or the Administrator, as the case may be.” Therefore, the NRC cannot
44 issue its license without a 401 certification or an NRC determination that a waiver has occurred,
45 in accordance with 40 CFR 121.9(c) (TN6718). In accordance with 10 CFR 50.54(aa) (TN249),
46 conditions in the 401 Certification become a condition of the NRC’s license.

1 A Section 404 permit would need to be obtained from the USACE before implementing any
2 action, such as earthmoving activities and certain erosion controls, which could disturb
3 wetlands. Federal and State permits/certifications are obtained using the same form and permit
4 applications for activities affecting waterways, and wetlands are reviewed by the USACE in
5 consultation with the FWS, the Soil Conservation Service, the EPA, and the delegated State
6 agency.

7 **Coastal Zone Management Act of 1972, as amended (16 U.S.C. §§ 1451 et seq.; TN1243)** –
8 Congress enacted the Coastal Zone Management Act in 1972 to address the increasing
9 pressures of over-development upon the nation’s coastal resources. The National Oceanic and
10 Atmospheric Administration administers the Act. The Coastal Zone Management Act
11 encourages States to preserve, protect, develop, and, where possible, restore or enhance
12 valuable natural coastal resources such as wetlands, floodplains, estuaries, beaches, dunes,
13 barrier islands, and coral reefs, as well as the fish and wildlife using those habitats. Participation
14 by States is voluntary. To encourage States to participate, the Coastal Zone Management Act
15 makes Federal financial assistance available to any coastal State or territory, including those on
16 the Great Lakes, that are willing to develop and implement a comprehensive coastal
17 management program.

18 **Comprehensive Environmental Response, Compensation, and Liability Act as amended**
19 **by the Superfund Amendments and Reauthorization Act (42 U.S.C. §§ 9601 et seq.;**
20 **TN6592)** – The Comprehensive Environmental Response, Compensation, and Liability Act
21 (CERCLA) includes an emergency response program to respond to a release of a hazardous
22 substance to the environment. Releases of source, byproduct, or special nuclear material from a
23 nuclear incident are excluded from CERCLA requirements if the releases are subject to the
24 financial protection requirements of the AEA. CERCLA is intended to provide a response to, and
25 cleanup of, environmental problems that are not covered adequately by the permit programs of
26 the many other environmental laws, including the CAA; CWA; Safe Drinking Water Act (SDWA);
27 Marine Protection, Research, and Sanctuaries Act (33 U.S.C. §§ 1401 et seq.; TN6637);
28 Resource Conservation and Recovery Act (RCRA); and AEA. Under Section 120 of CERCLA,
29 each department, agency, and instrumentality (e.g., a municipality) of the United States is
30 subject to, and must comply with, CERCLA in the same manner as any nongovernmental entity
31 (except for requirements for bonding, insurance, financial responsibility, or applicable time
32 period). Under CERCLA, the EPA would have the authority to regulate hazardous substances at
33 a facility in the event of a release or a “substantial threat of a release” of those materials.
34 Releases greater than reportable quantities would be reported to the National Response Center.
35 Assessment of alternatives for environmental compliance includes consideration of whether
36 hazardous substances, in reportable quantity amounts, could be present at power plants during
37 the license term.

38 **Emergency Planning and Community Right-to-Know Act of 1986 (42 U.S.C. §§ 11001**
39 **et seq.; TN6603) (also known as “SARA Title III”)** – The Emergency Planning and
40 Community Right-to-Know Act of 1986 (EPCRA), which is the major amendment to CERCLA
41 (42 U.S.C. § 9601; TN6592), establishes the requirements for Federal, State, and local
42 governments, American Indian Tribes, and industry regarding emergency planning and
43 “Community Right-to-Know” reporting on hazardous and toxic chemicals. The “Community
44 Right-to-Know” provisions increase the public’s knowledge and access to information about
45 chemicals at individual facilities, their uses, and releases into the environment. States and
46 communities working with facilities can use the information to improve chemical safety and
47 protect public health and the environment. This Act requires emergency planning and notice
48 to communities and government agencies concerning the presence and release of

1 specific chemicals. The EPA implements this Act under regulations found in 40 CFR
2 Part 355 (TN5493), Part 370 (TN6612), and Part 372 (TN6613).

3 **Endangered Species Act of 1973 (16 U.S.C. § 1531–1544; TN1010)** – The Endangered
4 Species Act (ESA) was enacted to prevent the further decline of endangered and threatened
5 species and to restore those species and their critical habitats. Section 7 of the Act requires
6 Federal agencies to consult with the FWS or the National Marine Fisheries Service (NMFS) for
7 Federal actions that may affect listed species or designated critical habitats.

8 **Environmental Standards for Uranium Fuel Cycle (40 CFR Part 190, Subpart B; TN739)** –
9 These regulations establish maximum doses to the body or organs of members of the public as
10 a result of normal operational releases from uranium fuel cycle activities, including uranium
11 enrichment. These regulations were promulgated by the EPA under the authority of the AEA, as
12 amended, and have been incorporated by reference in the NRC regulations in 10 CFR
13 20.1301(e) (TN283).

14 **Federal Insecticide, Fungicide, and Rodenticide Act, as amended (7 U.S.C. §§ 136 et seq.;**
15 **TN4535)** – The Federal Insecticide, Fungicide, and Rodenticide Act, as amended, by the
16 Federal Environmental Pesticide Control Act and subsequent amendments, requires the
17 registration of all new pesticides with the EPA before they are used in the United States.
18 Manufacturers are required to develop toxicity data for their pesticide products. Toxicity data
19 may be used to determine permissible discharge concentrations for an NPDES permit.

20 **Fiscal Responsibility Act of 2023 (Public Law 118-5)** – The Fiscal Responsibility Act enacted
21 amendments to the National Environmental Policy Act (NEPA), aimed at streamlining the
22 decision-making process and codifying existing structures for cooperation between Federal
23 agencies. The Act established page and time limits for the environmental review process.
24 Environmental assessments are limited to 75 pages, not including citations or appendices, while
25 EISs are limited to 150 pages, with a 300-page limit for EISs that address an agency action of
26 “extraordinary complexity,” not including citations or appendices. The environmental
27 assessment are required to take no more than 1 year to complete, while EISs are limited to
28 2 years. The Act also allows for common categorical exclusions to be used between agencies
29 and codifies agency use of programmatic environmental documents to facilitate the NEPA
30 review process.

31 **Fish and Wildlife Conservation Act of 1980 (16 U.S.C. §§ 2901 et seq.; TN6604)** – The Fish
32 and Wildlife Conservation Act provides Federal technical and financial assistance to States for
33 the development of conservation plans and programs for nongame fish and wildlife. Fish and
34 Wildlife Conservation Act conservation plans identify significant problems that may adversely
35 affect nongame fish and wildlife species and their habitats and appropriate conservation actions
36 to protect the identified species. The Act also encourages Federal agencies to conserve and
37 promote the conservation of nongame fish and wildlife and their habitats.

38 **Fish and Wildlife Coordination Act of 1934, as amended (16 U.S.C. §§ 661–666e; TN4467)**
39 – The Fish and Wildlife Coordination Act requires Federal agencies that construct, license, or
40 permit water resource development projects to consult with the FWS (or NMFS, when
41 applicable) and State wildlife resource agencies for any project that involves an impoundment of
42 more than 10 ac (4 ha), diversion, channel deepening, or other waterbody modification
43 regarding the impacts of that action to fish and wildlife and any mitigative measures to reduce
44 adverse impacts.

1 **Fixing America’s Surface Transportation Act (42 U.S.C. §§ 4370m et seq.; TN6392)** –
2 Title 41 of the Fixing America’s Surface Transportation Act (FAST-41) established new
3 coordination and oversight procedures for infrastructure projects being reviewed by Federal
4 agencies. FAST-41 is intended to accomplish the following:

- 5 • Increase predictability
 - 6 – through the publication of project-specific permitting timetables and
 - 7 – clear processes to modify permitting timetables and resolve issues.
- 8 • Increase transparency and accountability over the
 - 9 – Federal environmental review and
 - 10 – authorization process.
- 11 • Improve early coordination of agencies’ schedules and synchronization of environmental
12 reviews and authorizations.

13 FAST-41 established the Federal Permitting Improvement Steering Council, which is composed
14 of agency representatives from various Federal agencies.

15 To be eligible for FAST-41, a proposal must meet the definition of a “covered project” under the
16 statute. A covered project is one that: (1) is subject to the NEPA; (2) is likely to require a total
17 investment of more than \$200,000,000; and (3) does not qualify for abbreviated authorization or
18 environmental review processes under any applicable law. A covered project can also be one
19 that is subject to NEPA and is of the size and complexity which, in the opinion of Federal
20 Permitting Improvement Steering Council, make the project likely to benefit from enhanced
21 oversight and coordination, including a project likely to require (1) authorization from or
22 environmental review involving more than two Federal agencies; or (2) the preparation of an EIS
23 under NEPA.”

24 **Hazardous Materials Transportation Act, as amended (49 U.S.C. §§ 5101 et seq.; TN6605)**
25 – The Hazardous Materials Transportation Act regulates the transportation of hazardous
26 material (including radioactive material) in and between States. According to the Act, States
27 may regulate the transport of hazardous material as long as their regulation is consistent with
28 the Act or the U.S. Department of Transportation regulations provided in 49 CFR Parts 171
29 through 177 (TN5466). Other regulations regarding packaging for transportation of radionuclides
30 are contained in 49 CFR Part 173, Subpart I (TN298).

31 **Low-Level Radioactive Waste Policy Act of 1980, as amended (42 U.S.C. §§ 2021b et seq.;**
32 **TN6606)** – The Low-Level Radioactive Waste Policy Act amended the AEA to improve the
33 procedures for the implementation of compacts providing for the establishment and operation of
34 regional low-level radioactive waste disposal facilities. It also allows for Congress to grant
35 consent for certain inter-State compacts. The amended Act sets forth the responsibilities for
36 disposal of low-level waste by States or inter-State compacts. The Act states the amount of
37 waste that certain low-level waste recipients can receive over a set time period. The amount of
38 low-level radioactive waste generated from both pressurized and boiling water reactor types is
39 allocated over a transition period until a local waste facility is operational.

1 **Magnuson-Stevens Fishery Conservation and Management Act, as amended**
2 **(16 U.S.C. §§ 1801–1884; TN1061)** – The Magnuson-Stevens Fishery Conservation and
3 Management Act governs marine fisheries management in U.S. Federal waters. The Act
4 created eight regional fishery management councils and includes measures to rebuild
5 overfished fisheries, protect essential fish habitat, and reduce bycatch. Under Section 305 of the
6 Act, Federal agencies are required to consult with NMFS for any Federal actions that may
7 adversely affect essential fish habitat.

8 **Marine Mammal Protection Act of 1972 (16 U.S.C. §§ 1361 et seq.; TN4478)** – The Marine
9 Mammal Protection Act (MMPA) was enacted to protect and manage marine mammals and
10 their products (e.g., the use of hides and meat). The primary authority for implementing the Act
11 belongs to the FWS and NMFS. The FWS manages walruses, polar bears, sea otters, dugongs,
12 marine otters, and the West Indian, Amazonian, and West African manatees. The NMFS
13 manages whales, porpoises, seals, and sea lions. The two agencies may issue permits under
14 MMPA Section 104 (16 U.S.C. § 1374) to persons, including Federal agencies, that authorize
15 the taking or importing of specific species of marine mammals.

16 After the Secretary of the Interior or the Secretary of Commerce approves a State’s program,
17 the State can take over responsibility for managing one or more marine mammals. The MMPA
18 also established a Marine Mammal Commission whose duties include reviewing laws and
19 international conventions related to marine mammals, studying the condition of these mammals,
20 and recommending steps to Federal officials (e.g., listing a species as endangered) that should
21 be taken to protect marine mammals. Federal agencies are directed by MMPA Section 205
22 (16 U.S.C. § 1405) to cooperate with the Commission by permitting it to use their facilities or
23 services.

24 **Migratory Bird Treaty Act of 1918, as amended (16 U.S.C. §§ 703 et seq.; TN3331)** – The
25 Migratory Bird Treaty Act is intended to protect birds that have common migration patterns
26 between the United States and Canada, Mexico, Japan, and Russia. The Act stipulates that,
27 except as permitted by regulations, it is unlawful at any time, by any means, or in any manner to
28 pursue, hunt, take, capture, or kill any migratory bird.

29 **National Environmental Policy Act of 1969, as amended (42 U.S.C. § 4321 et seq.)** – NEPA
30 requires, in part, that Federal agencies integrate environmental values into their decision-
31 making process by considering the reasonably foreseeable environmental effects (impacts) of
32 proposed Federal actions and a reasonable range of alternatives to those actions. NEPA
33 establishes policy, sets goals (in Section 101), and provides means (in Section 102) for carrying
34 out the policy. Section 102(2) contains action-forcing provisions to ensure that Federal agencies
35 follow the letter and spirit of the Act. For major Federal actions significantly affecting the quality
36 of the human environment, Section 102(2)(C) of NEPA, consistent with the provisions of NEPA
37 except where compliance would be inconsistent with other statutory requirements, requires
38 Federal agencies to prepare a detailed statement that includes the reasonably foreseeable
39 environmental effects of the proposed action and other specified information. This generic
40 environmental impact statement (GEIS) has been prepared in accordance with NEPA
41 requirements and NRC regulations (10 CFR Part 51) for implementing NEPA to ensure
42 compliance with Section 102(2).

43 **National Historic Preservation Act of 1966, as amended (54 U.S.C. §§ 300101 et seq.;**
44 **TN4157)** – The National Historic Preservation Act (NHPA) was enacted to create a national
45 historic preservation program, including the National Register of Historic Places and the
46 Advisory Council on Historic Preservation. Section 106 of the Act requires Federal agencies

1 to take into account the effects of their undertakings on historic properties. The Advisory Council
2 on Historic Preservation regulations implementing Section 106 of the Act are found in
3 36 CFR Part 800 (TN513). The regulations call for public involvement in the Section 106
4 consultation process, including American Indian Tribes and other interested members of the
5 public, as applicable.

6 **Native American Graves Protection and Repatriation Act of 1990 (25 U.S.C. § 3001;**
7 **TN1686)** – The Native American Graves Protection and Repatriation Act establishes provisions
8 for the treatment of inadvertent discoveries of American Indian remains and cultural objects.
9 When discoveries are made during ground-disturbing activities, the activity in the area must
10 immediately stop, and reasonable protective efforts, proper notifications, and appropriate
11 disposition of the discovered items must be pursued.

12 **Noise Control Act of 1972 (42 U.S.C. §§ 4901 et seq.; TN4294)** – The Noise Control Act
13 delegates the responsibility of noise control to State and local governments. Commercial
14 facilities are required to comply with Federal, State, interstate, and local requirements regarding
15 noise control. Section 4 of the Noise Control Act directs Federal agencies to carry out programs
16 in their jurisdictions “to the fullest extent within their authority” and in a manner that furthers a
17 national policy of promoting an environment free from noise that jeopardizes health and welfare.

18 **Nuclear Energy Innovation and Modernization Act of 2019 (NEIMA, Public Law 115-439;**
19 **TN6469)** – NEIMA’s purpose is to establish transparency and accountability measures on the
20 NRC’s budget and fee recovery programs as well as to require the Commission to develop the
21 regulatory framework necessary to enable the licensing of ANRs. The Act enables the licensing
22 of ANRs by, among other things, requiring the Commission to develop and implement risk-
23 informed, performance-based licensing policies and guidance. The Act also defines the term
24 “advanced nuclear reactor.” The Act authorizes appropriations sums necessary for the
25 Commission to carry out the requirements of Section 103 of NEIMA.

26 **Nuclear Regulatory Commission License Termination Rule (10 CFR Part 20, Subpart E;**
27 **TN283)** – The AEA assigns NRC the responsibility for licensing and regulating commercial uses
28 of atomic energy. When a licensed facility has completed its mission, the facility must meet
29 standards for cleanup in order to terminate its license. The License Termination Rule
30 establishes that the NRC will consider a site acceptable for unrestricted use if (1) the residual
31 radioactivity that is distinguishable from background radiation results in a total effective dose
32 equivalent to an average member of the critical group that does not exceed 25 mrem per year,
33 including that from groundwater sources of drinking water, and (2) the residual radioactivity has
34 been reduced to levels that are as low as reasonably achievable. The critical group is the group
35 of individuals reasonably expected to receive the greatest exposure to residual radioactivity for
36 any applicable set of circumstances.

37 The License Termination Rule also provides for land-use restrictions or other types of
38 institutional controls to allow for the termination of NRC licenses and the release of sites under
39 restricted conditions if decommissioning criteria for unrestricted use cannot be met. Plus, the
40 License Termination Rule establishes alternate criteria for license termination if the licensee
41 provides assurance that public health and safety would continue to be protected, and that it is
42 unlikely that the dose from all manufactured sources combined, other than medical, would be
43 more than 100 mrem per year.

44 **Nuclear Waste Policy Act of 1982 (42 U.S.C. §§ 10101 et seq.; TN740)** – The Nuclear Waste
45 Policy Act provides for the research and development of repositories for the disposal of

1 high-level radioactive waste, spent nuclear fuel, and low-level radioactive waste. Title I includes
2 the provisions for the disposal and storage of high-level radioactive waste and spent nuclear
3 fuel. Subtitle A of Title I delineates the requirements for site characterization and construction of
4 the repository and the participation of States and other local governments in the selection
5 process. Subtitles B, C, and D of Title I deal with the specific issues for interim storage,
6 monitored retrievable storage, and low-level radioactive waste.

7 **Occupational Safety and Health Act of 1970 (29 U.S.C. §§ 651 et seq.; TN4453)** – The
8 Occupational Safety and Health Act establishes standards to enhance safe and healthy working
9 conditions in places of employment throughout the United States. The Act is administered and
10 enforced by the Occupational Safety and Health Administration (OSHA), a U.S. Department of
11 Labor agency. Employers who fail to comply with OSHA standards can be penalized by the
12 Federal government. The Act allows States to develop and enforce OSHA standards if such
13 programs have been approved by the Secretary of Labor.

14 **Pollution Prevention Act of 1990 (42 U.S.C. §§ 13101 et seq.; TN6607)** – The Pollution
15 Prevention Act establishes a national policy for waste management and pollution control that
16 focuses first on source reduction, then on environmental issues, safe recycling, treatment, and
17 disposal.

18 **Resource Conservation and Recovery Act as amended by the Hazardous and Solid
19 Waste Amendments (42 U.S.C. §§ 6901 et seq.; TN1281)** – The RCRA requires the EPA to
20 define and identify hazardous waste; establish standards for its transportation, treatment,
21 storage, and disposal; and require permits for persons engaged in hazardous waste activities.
22 Section 3006 (42 U.S.C. § 6926) allows States to establish and administer these permit
23 programs with EPA approval. EPA regulations implementing the RCRA are found in 40 CFR
24 Parts 239 through 283 (TN6618). Regulations imposed on a generator or on a treatment,
25 storage, and/or disposal facility vary according to the type and quantity of material or waste
26 generated, treated, stored, and/or disposed. The method of treatment, storage, and/or disposal
27 also affects the extent and complexity of the requirements.

28 **Rivers and Harbors Act of 1899, Section 10 (33 U.S.C. § 403)** – The Rivers and Harbors Act
29 of 1899 (33 U.S.C. §§ 401 et seq.) requires USACE authorization in order to protect navigable
30 waters in the development of harbors and other construction and excavation. Section 10 of the
31 Rivers and Harbors Act of 1899 (33 U.S.C. § 403) prohibits the unauthorized obstruction or
32 alteration of any navigable water of the United States. That section provides that the
33 construction of any structure in or over any navigable water of the United States, or the
34 accomplishment of any other work affecting the course, location, condition, or physical capacity
35 of such waters is unlawful unless the work has been authorized by the Secretary of the Army
36 through the USACE. Activities requiring Section 10 permits include structures (e.g., piers,
37 wharfs, breakwaters, bulkheads, jetties, weirs, transmission lines) and work such as dredging or
38 disposal of dredged material, or excavation, filling, or other modifications to the navigable
39 waters of the United States.

40 **Safe Drinking Water Act of 1974 (42 U.S.C. §§ 300(f) et seq.; TN1337)** – The SDWA was
41 enacted to protect the quality of public water supplies and sources of drinking water and
42 establishes minimum national standards for public water supply systems in the form of
43 maximum contaminant levels for pollutants, including radionuclides. Other programs established
44 by the SDWA include the Sole Source Aquifer Program, the Wellhead Protection Program, and
45 the Underground Injection Control Program. In addition, the Act provides underground sources
46 of drinking water with protection from contaminated releases and spills.

1 If a nuclear power plant is located within an area designated as being a Sole Source Aquifer
2 pursuant to Section 1424(e) of the SDWA, the supplemental EIS would be subject to EPA
3 review. If the EPA review raises concerns that plant operations are not protective of
4 groundwater quality, specific mitigation recommendations or additional pollution prevention
5 requirements may be required.

6 **Toxic Substances Control Act (15 U.S.C. §§ 2601 et seq.; TN4454)** – The Toxic Substances
7 Control Act (TSCA) regulates the manufacture, processing, distribution, and use of certain
8 chemicals not regulated by RCRA or other statutes, including asbestos-containing material and
9 polychlorinated biphenyls. Any TSCA-regulated waste removed from structures (e.g.,
10 polychlorinated biphenyls-contaminated capacitors or asbestos) or discovered during the
11 implementation phase (e.g., contaminated media) would be managed in compliance with TSCA
12 requirements in 40 CFR Part 761 (TN6610).

13 **F.3 Environmental Executive Orders**

14 Executive Orders establish policies and requirements for Federal agencies. Executive Orders
15 do not have the force of law or regulation. Generally, Executive Orders are applicable to most
16 Federal agencies, although they may or may not be binding upon independent regulatory
17 agencies such as the NRC.

18 **Executive Order 11514, *Protection and Enhancement of Environmental Quality***
19 **(35 FR 4247-TN6608)** – This Order (regulated by 40 CFR Parts 1500 through 1508; TN6611)
20 requires Federal agencies to continually monitor and control their activities to (1) protect and
21 enhance the quality of the environment, and (2) develop procedures to ensure the fullest
22 practicable provision of timely public information and understanding of the Federal plans and
23 programs that may have potential environmental impacts so that the views of interested parties
24 can be obtained.

25 **Executive Order 11593, *Protection and Enhancement of the Cultural Environment***
26 **(36 FR 8921-TN6609)** – This Order directs Federal agencies to locate, inventory, and nominate
27 qualified properties under their jurisdiction or control to the National Register of Historic Places.

28 **Executive Order 11988, *Floodplain Management* (42 FR 26951-TN270)** – This Order requires
29 Federal agencies to avoid direct or indirect support of floodplain development whenever there is
30 a practicable alternative. A Federal agency is required to evaluate the potential effects of any
31 actions it may take in a floodplain. Federal agencies are also required to encourage and provide
32 appropriate guidance to applicants to evaluate the effects of their proposals on floodplains prior
33 to submitting applications for Federal licenses, permits, loans, or grants.

34 **Executive Order 11990, *Protection of Wetlands* (42 FR 26961-TN269)** – This Order requires
35 Federal agencies to avoid any short- or long-term adverse impacts on wetlands, whenever there
36 is a practicable alternative and to provide opportunity for early public review of any plans or
37 proposals for new construction in wetlands. Federal agencies are required to evaluate the
38 potential effects of any actions they may take on wetlands when carrying out their
39 responsibilities (e.g., planning, regulating, and licensing activities). However, this Executive
40 Order does not apply to the issuance by Federal agencies of permits, licenses, or allocations to
41 private parties for activities involving wetlands on non-Federal property.

1 **Executive Order 12088, *Federal Compliance with Pollution Control Standards*** (43 FR
2 47707-TN6623), **as amended by Executive Order 12580, *Superfund Implementation*** (52 FR
3 2923-TN6624) – This Order directs Federal agencies to comply with applicable administrative
4 and procedural pollution controls standards established by, but not limited to, the CAA, the
5 Noise Control Act, the CWA, the SDWA, the TSCA, and the RCRA.

6 **Executive Order 12148, *Federal Emergency Management*** (44 FR 43239-TN6614) – This
7 Order transfers functions and responsibilities associated with Federal emergency management
8 to the Director of the Federal Emergency Management Agency. The Order assigns the Director
9 the responsibility to establish Federal policies for, and to coordinate all civil defense and civil
10 emergency planning, management, mitigation, and assistance functions of, Executive agencies.

11 **Executive Order 12580, *Superfund Implementation*** (52 FR 2923-TN6624), **as amended by**
12 **Executive Order 13308** (68 FR 37691-TN6625) – This Order delegates to the heads of
13 Executive Departments and agencies the responsibility of undertaking remedial actions for
14 releases or threatened releases that are not on the National Priorities List, and removal actions,
15 other than emergencies, where the release is from any facility under the jurisdiction or control of
16 Executive Departments and agencies.

17 **Executive Order 12656, *Assignment of Emergency Preparedness Responsibilities***
18 (53 FR 47491-TN6626) – This Order assigns emergency preparedness responsibilities to
19 Federal departments and agencies.

20 **Executive Order 12898, *Federal Actions to Address Environmental Justice in Minority***
21 ***Populations and Low-Income Populations*** (59 FR 7629-TN1450) – This Order calls for
22 Federal agencies to address environmental justice in minority populations and low-income
23 populations, and directs Federal agencies to identify and address, as appropriate,
24 disproportionately high and adverse health or environmental effects of their programs, policies,
25 and activities on minority and low-income populations. In response to this Executive Order, the
26 NRC has issued a final policy statement on the “Treatment of Environmental Justice Matters in
27 NRC Regulatory and Licensing Actions” (69 FR 52040-TN1009) and environmental justice
28 procedures to be followed in NEPA documents.

29 **Executive Order 13007, *Indian Sacred Sites*** (61 FR 26771-TN6629) – This Order directs
30 Federal agencies, to the extent permitted by law and not inconsistent with agency missions, to
31 avoid adverse effects on sacred sites and to provide access to those sites to Native Americans
32 for religious practices. The Order directs agencies to plan projects and provide protection of and
33 access to sacred sites to the extent compatible with the project.

34 **Executive Order 13045, *Protection of Children from Environmental Health Risks and***
35 ***Safety Risks*** (62 FR 19885-TN6630), **as amended by Executive Order 13229** (66 FR 52013-
36 TN6631), **as amended by Executive Order 13296** (68 FR 19931-TN6632) – This Order
37 requires Federal Executive branch agencies to make it a high priority to identify and assess
38 environmental health risks and safety risks that may disproportionately affect children and to
39 ensure that its policies, programs, activities, and standards address disproportionate risks to
40 children that result from environmental health or safety risks.

41 **Executive Order 13112, *Invasive Species*** (64 FR 6183-TN4477) – This Order directs Federal
42 agencies to act to prevent the introduction of or to monitor and control, invasive (non-native)
43 species, to provide for restoration of native species, to conduct research, to promote
44 educational activities, and to exercise care in taking actions that could promote the introduction

1 or spread of invasive species. During the implementation phase, rehabilitation of disturbed
2 areas would be accomplished by reseeding or revegetating areas with native plants and trees.

3 **Executive Order 13123, Greening the Government through Efficient Energy Management**
4 **(64 FR 30851-TN6634)** – This Order sets goals for agencies to reduce greenhouse gas
5 emissions from facility energy use, reduce energy consumption per gross square foot of
6 facilities, reduce energy consumption per gross square foot or unit of production, expand use of
7 renewable energy, reduce the use of petroleum within facilities, reduce source energy use, and
8 reduce water consumption and associated energy use.

9 **Executive Order 13175, Consultation and Coordination with Indian Tribal Governments**
10 **(65 FR 67249-TN4846)** – This Order directs Federal agencies to establish regular and
11 meaningful consultation and collaboration with tribal governments in the development of Federal
12 policies that have tribal implications, to strengthen U.S. government-to-government relationships
13 with American Indian Tribes, and to reduce the imposition of unfunded mandates on tribal
14 governments. On January 9, 2017, the NRC published its Tribal Policy Statement, which
15 describes best practices and principles in conducting the agency's government-to-government
16 interactions with American Indian and Alaska Native tribes (82 FR 2402-TN5500).

17 **Executive Order 13990, Protecting Public Health and the Environment and Restoring**
18 **Science to Tackle the Climate Crisis (86 FR 7037-TN7028)** – This Order lays out a broad
19 policy related to science, public health, environmental protection, environmental justice, and
20 associated job creation. The Order directs Federal agency heads to “immediately” review
21 actions taken during the Trump Administration “that are or may be inconsistent with, or present
22 obstacles to,” this policy and to develop and submit to certain Administration officials lists of
23 planned agency actions to rectify the identified issues. The Order also establishes an
24 Interagency Working Group on the Social Cost of Greenhouse Gases and revokes or
25 temporarily suspends a number of prior Orders and other White House issuances related to
26 environmental, infrastructure, and energy issues that were issued by President Trump.

27 **Executive Order 14008, Tackling the Climate Crisis at Home and Abroad (86 FR 7619-**
28 **TN7027)** – This Order addresses a number of areas related to climate change, including making
29 climate change issues central to U.S. foreign policy and national security and pursuing various
30 government-wide domestic initiatives. The aspects of the Order with the most direct applicability
31 to the NRC are the provisions addressing the sustainability and climate-related resilience of a
32 Federal agency’s own operations. For example, the NRC will submit a draft action plan
33 describing steps the agency can take with regard to its facilities and operations to bolster
34 adaptation and increase resilience to the impacts of climate change and will also release
35 publicly progress reports as updates on the agency’s implementation efforts.

36 **Executive Order 14096, Revitalizing Our Nation’s Commitment to Environmental Justice**
37 **for All (88 FR 25251)** – This Order builds on and supplements the foundational efforts of
38 Executive Order 12898, “Federal Actions To Address Environmental Justice in Minority
39 Populations and Low-Income Populations,” issued in 1994, to address environmental justice. It
40 calls for a government-wide approach to environmental justice for all and establishment of a
41 new White House Office of Environmental Justice within the existing Council on Environmental
42 Quality (CEQ). The Order also directs Federal agencies in the executive branch to develop
43 Environmental Justice Strategic Plans that are tied to specific performance and accountability
44 measures outlined in Section 4 of Executive Order 14096. The Order also states, “Independent
45 regulatory agencies are strongly encouraged to comply with the provisions of this order and to

1 provide notice to the Chair of CEQ of their intention to do so. The Chair of CEQ shall make such
2 notices publicly available and maintain a list online of such agencies.”

3 **F.4 U.S. Nuclear Regulatory Commission Regulations and Guidance**

4 The AEA, as amended, allows the NRC to issue licenses for commercial power reactors to
5 operate up to 40 years. This license is based on adherence of the licensee to the NRC’s
6 regulations that are set forth in Chapter 1 of Title 10 of the CFR.

7 The new nuclear reactor license process includes two reviews: an environmental review and a
8 safety review. The reviews are based on the regulations published in 10 CFR Part 51 (TN250)
9 for the environmental review and 10 CFR Part 50 (TN249) or Part 52 (TN251) for the safety
10 review. These regulations prescribe the format and content of license applications, as well as,
11 the methods and criteria used by NRC staff in evaluating these applications.

12 The environmental review relies upon the following regulations and guidance:

- 13 • *Code of Federal Regulations* – The scope of the environmental review is based on the
14 regulations provided in 10 CFR Part 51 (TN250), *Environmental Protection Regulations for*
15 *Domestic Licensing and Related Regulatory Functions*.
- 16 • *Preparation of Environmental Reports for Nuclear Power Stations* (Regulatory Guide 4.2;
17 NRC 2024-TN7081) – This document outlines the format and content to be used by the
18 applicant to discuss the environmental aspects of its license application. It also defines the
19 information and analyses the applicant must include in its environmental report submitted as
20 part of the application.
- 21 • *Standard Review Plan for Environmental Reviews for Nuclear Power Plants* (NUREG-1555)
22 – This document provides guidance to the staff in implementing provisions of 10 CFR
23 Part 51 (TN250), *Environmental Protection Regulations for Domestic Licensing and Related*
24 *Regulatory Functions*, related to new site/plant applications.
- 25 • “Interim Staff Guidance Environmental Considerations Associated with Micro-reactors”
26 (COL-ISG-029; NRC 2020-TN6710) – This document provides supplemental guidance to
27 assist the NRC staff in determining the scope and scale of environmental reviews of
28 microreactor applications.
- 29 • *Generic Environmental Impact Statement for Licensing New Nuclear Reactors (NR GEIS)*
30 (NUREG-2249; NRC 2021-TN7080) – This document discusses the environmental impacts
31 from new nuclear reactor licensing that are common to all or most nuclear power facilities.
32 The GEIS allows the applicant and the NRC to focus on environmental issues specific to
33 each site seeking a renewed operating license. The staff’s review results in a project-
34 specific supplement to the GEIS for each plant site.

35 **F.5 State Laws, Regulations, and Other Requirements**

36 The AEA authorizes States to establish programs to assume NRC regulatory authority for
37 certain activities (the NRC’s Agreement State Program). The New York State Department of
38 Labor and Department of Environmental Conservation, for example, have established
39 requirements under this Agreement State Program. New York State Department of Labor has
40 jurisdiction in New York over commercial and industrial uses of radioactive material. Under the
41 New York Agreement State Program, New York State Department of Labor and Department of
42 Environmental Conservation has jurisdiction over discharges of radioactive material to the

1 environment, including releases to the air and water, and the disposal of radioactive wastes in
 2 the ground. In addition, States have enacted their own laws to protect public health and safety,
 3 and the environment. State laws may supplement or implement various Federal laws for
 4 protection of air, water quality, and groundwater. State laws may also address solid waste
 5 management programs, locally rare or endangered species, and historic and cultural resources.

6 In addition, the CWA allows for primary enforcement and administration through State agencies,
 7 provided the State program (1) is at least as stringent as the Federal program and (2) conforms
 8 to the CWA. The primary CWA mechanism for controlling water pollution is the requirement that
 9 direct dischargers obtain an NPDES permit or, in the case of States in which the authority has
 10 been delegated from the EPA, a State permit.

11 One important difference between Federal regulations and certain State regulations is the
 12 definition of “waters” regulated by the State. Certain State regulations may include underground
 13 waters, while the CWA only regulates the navigable waters of the United States. For example, a
 14 State permit is required under New York State law for all discharges to both surface waters and
 15 groundwater.

16 **F.6 State Environmental Requirements**

17 Certain environmental requirements, including some discussed earlier, may have been
 18 delegated to State authorities for implementation, enforcement, or oversight. Table F-1 provides
 19 a list of representative State environmental requirements that may affect new nuclear reactor
 20 applications for nuclear power plants.

21 **Table F-1 State Environmental Requirements**

| Law/Regulation | Requirements |
|---|---|
| Air Quality Protection | |
| Title V Permit Rules | Establishes the policies and procedures by which a State will administer the Title V permit program under the CAA. Requires Title V sources to apply for and obtain a Title V permit prior to operation of the source facility. |
| Permits to Install New Sources of Pollution | Requires a permit prior to the installation of a new source of air pollutants or the modification of an air contaminant source. Discusses exemptions and conditions under which approval will be granted. Also requires an impact analysis to determine if the air contaminant source will cause or contribute to violations of the NAAQs. |
| Air Permits to Operate and Variances | Requires a permit prior to the operation or use of any air contaminant source in violation of any applicable air pollution control law, unless a variance has been applied for and obtained from the State agency. |
| Accidental Release Prevention Program | Requires the owner or operator of a stationary source, that has more than a threshold quantity of a regulated substance, to comply with all the provisions of the rule, including creating a hazard assessment, risk management plan, a prevention program, and an emergency response program. |
| General Conformity Rules | Rules on “general conformity” are mandated by the CAA to ensure that Federal actions do not contribute to air quality violations within the State. Discusses which Federal actions are subject to the conformity requirements, the procedures for conformity analysis, public participation/consultation, and the final conformity determination. |

Table F-1 State Environmental Requirements (Continued)

| Law/Regulation | Requirements |
|--|---|
| Water Resources Protection | |
| National Pollutant Discharge Elimination System Permits | Requires a permit prior to the discharge of pollutants from any point source into waters of the United States. Each permit holder must comply with authorized discharge levels, monitoring requirements, and other appropriate requirements in the permit. |
| Permits to Install New Sources of Pollution | Requires a permit prior to the installation of a new source of water pollutants or the modification of any pollutant discharge source. |
| Water Quality Standards | Establishes water quality standards for surface waters in the State, including beneficial use designations, numeric water quality criteria, and the anti-degradation waterbody classification system. Water quality standards are enforced through the NPDES permit. |
| Section 401 Water Quality Certifications | Requires a Section 401 water quality certification and payment of applicable fees before the issuance of any Federal permit or license to conduct any activity that may result in discharges to waters of the State. |
| Public Water Systems Licenses to Operate | Requires a public water system license prior to operating or maintaining a public water system. |
| Design, Construction, Installation, and Upgrading for Underground Storage Tank Systems | Establishes performance standards and upgrading requirements for underground storage tanks containing petroleum (e.g., diesel fuel) or other regulated substances. Requires an installation or upgrading permit for each location where such installation or upgrading is to occur prior to beginning either an installation or upgrading of a tank or piping comprising an underground storage tank system. |
| Registration of Underground Storage Tank System | Establishes annual registration requirements for underground storage tanks containing petroleum or other regulated substances. |
| Flammable and Combustible Liquids | Requires a permit to install, remove, repair, or alter a stationary tank for the storage of flammable or combustible liquids or modify or replace any line or dispensing device. |
| Waste Management and Pollution Prevention | |
| Generator Standards | Requires any person who generates waste to determine if that waste is hazardous. Requires a generator identification number from the EPA or State agency prior to treatment, storage, disposal, transport, or offer for transport of hazardous waste. |
| Licensing Requirements for Solid Waste, Construction, and Demolition Debris Facilities | Requires an annual license for any municipal solid waste landfill, industrial solid waste landfill, residual solid waste landfill, compost facility, transfer facility, infectious waste treatment facility, or solid waste incineration facility prior to operation. New facilities must obtain a permit to install, prior to construction. Also, requires a license to establish, modify, operate, or maintain a construction and demolition debris facility. |
| Radiation Generator and Broker Reporting Requirements | Requires completion of a low-level radioactive waste generator report within 60 days of beginning to generate low-level waste. Also requires each generator to submit an annual report about the state of low-level waste activities in their facility and pay applicable fees. |
| Hazardous Waste Management System Permits | Requires operation permits for any new or existing hazardous waste facility. |

Table F-1 State Environmental Requirements (Continued)

| Law/Regulation | Requirements |
|---|--|
| Emergency Planning and Response | |
| Hazardous Chemical Reporting | Requires the submission of Material Safety Data Sheets and an annual Emergency and Hazardous Chemical Inventory to local emergency response officials for any hazardous chemicals that are produced, used, or stored at the facility in an amount that equals or exceeds the threshold quantity. |
| Emergency Planning Requirements of Subject Facilities | Requires any facility that has an extremely hazardous substance present in an amount equal to, or exceeding the threshold planning quantity, to notify the emergency response commission and the local emergency planning committee within 60 days after onsite storage begins. Also requires the designation of a facility representative who will participate in the local emergency planning process as a facility emergency coordinator. |
| Toxic Chemical Release Reporting | Establishes reporting requirements and a schedule for each toxic chemical known to be manufactured (including imported), processed, or otherwise used in excess of an applicable threshold quantity. Applies only to facilities of a certain classification. |
| Biotic Resources Protection | |
| State Endangered Plant Species Protection | Establishes criteria for identifying threatened or endangered species of native plants and prohibits injuring or removing endangered species without permission. |
| State Endangered Fish and Wildlife Species Protection | Establishes and requires periodic updates to a State list of endangered fish and wildlife species. |
| Permits for Impacts on Isolated Wetlands | Requires a general or individual isolated wetland permit prior to engaging in an activity that involves the filling of an isolated wetland. |
| Cultural Resources Protection | |
| State Registry of Archaeological Landmarks | Establishes a State registry of archaeological landmarks. Prohibits any person from excavating or destroying such land, or from removing skeletal remains or artifacts from any land, placed on the registry without first notifying the State Historic Preservation Office. |
| Survey and Salvage; Discoveries; Preservation | Directs State departments, agencies, and political subdivisions to cooperate in the preservation of archaeological and historic sites and the recovery of scientific information from such sites. Also, requires State agencies and contractors performing work on public improvements to cooperate with archaeological and historic survey and salvage efforts and to notify the State historic preservation office about archaeological discoveries. |

1 F.7 Operating Permits and Other Requirements

- 2 Several operating permit applications may be prepared and submitted, and regulatory approval
 3 and/or permits would be received, prior to license approval by the NRC. Table F-2 lists
 4 representative Federal, State, and local permits.

Table F-2 Federal, State, and Local Permits and Other Requirements

| License, Permit, or Other Required Approval | Responsible Agency | Authority | Relevance and Status |
|---|---------------------------|--|--|
| Air Quality Protection | | | |
| Title V Operating Permit: Required for sources that are not exempt and are major sources, affected sources subject to the Acid Rain Program, sources subject to new source performance standards, or sources subject to National Emission Standards for Hazardous Air Pollutants. | EPA or State agency | CAA, Title V, Sections 501–507 (U.S.C., Title 42, §§ 7661–7661f [42 U.S.C. §§ 7661–7661f; TN1141]) | Nuclear power plants are subject to 40 CFR Part 61, Subpart H (TN3289), “National Emissions Standards for Emissions of Radionuclides,” which is included in the terms and conditions of the Title V Operating Permit. |
| Risk Management Plan: Required for any stationary source that has a regulated substance (e.g., chlorine, hydrogen fluoride, nitric acid) in any process (including storage) in a quantity that is over the threshold level. | EPA or State agency | CAA, Title 1, Section 112(R)(7) (42 U.S.C. § 7412-TN7014) | These regulated substances stored in quantities that exceed the threshold levels would require a risk management plan. |
| CAA Conformity Determination: Required for each criteria pollutant (i.e., sulfur dioxide, particulate matter, carbon monoxide, ozone, nitrogen dioxide, and lead) where the total of direct and indirect emissions in a nonattainment or maintenance area caused by a Federal action would equal or exceed threshold rates. | EPA or State agency | CAA, Title 1, Section 176(c) (42 U.S.C. § 7506-TN4856) | CAA conformity determination would be required at nuclear power plants located in nonattainment areas with NAAQSSs for criteria pollutants or maintenance areas for any criteria pollutant that would be emitted as a result of new nuclear reactor licensing. |
| Water Resources Protection | | | |
| NPDES Permit: Construction Site Stormwater: Required before making point source discharges of stormwater from a construction project that disturbs more than 2 hectares (5 acres) of land. | EPA or State agency | CWA (33 U.S.C. §§ 1251 et seq.; TN662); 40 CFR Part 122 (TN2769) | Any plant refurbishment involving construction of more than 2 hectares (5 acres) of land would require a Stormwater Pollution Prevention Plan and construction site stormwater discharge permit. |

Table F-2 Federal, State, and Local Permits and Other Requirements (Continued)

| License, Permit, or Other Required Approval | Responsible Agency | Authority | Relevance and Status |
|---|---------------------------|---|---|
| NPDES Permit: Industrial Facility Stormwater: Required before making point source discharges of stormwater from an industrial site. | EPA or State agency | CWA (33 U.S.C. §§ 1251 et seq.; TN662); 40 CFR Part 122 (TN2769) | Stormwater would be discharged from the nuclear power plants during operations. Stormwater would discharge through existing outfalls covered by a permit. |
| NPDES Permit: Process Water Discharge: Required before making point source discharges of industrial process wastewater. | EPA or State agency | CWA (33 U.S.C. §§ 1251 et seq.; TN662); 40 CFR Part 122 (TN2769) | Process industrial wastewater would be discharged through existing outfalls covered by the permit. |
| Spill Prevention Control and Countermeasures Plan: Required for any facility that could discharge diesel fuel in harmful quantities into navigable waters or onto adjoining shorelines. | EPA or State agency | CWA (33 U.S.C. §§ 1251 et seq.; TN662); 40 CFR Part 112 (TN1041) | A Spill Prevention Control and Countermeasures Plan is required at nuclear power plants storing large volumes of diesel fuel and/or other petroleum products. |
| CWA Section 401 Water Quality Certification: Required to be submitted to the agency responsible for issuing any Federal license or permit to conduct an activity that may result in a discharge of pollutants into waters of a State. | EPA or State agency | CWA, Section 401 (33 U.S.C. § 1341-TN4764); Chapters 119 and 6111 | Certification for operation of a nuclear power plant may require a Federal license or permit (e.g., a CWA Section 404 Permit). |
| New Underground Storage Tanks System Registration: Required within 30 days of bringing a new underground storage tank system into service. | EPA or State agency | RCRA, as amended, Subtitle I (42 U.S.C. §§ 6991a–6991i; TN1281); 40 CFR 280.22 (TN6619) | Required if new underground storage tank systems would be installed at a nuclear power plant. |
| Aboveground Storage Tank: A permit is required to install, remove, repair, or alter any stationary tank for the storage of flammable or combustible liquids. | State Fire Marshal | | Required if new aboveground diesel fuel storage tanks would be installed at a nuclear power plant. |

Table F-2 Federal, State, and Local Permits and Other Requirements (Continued)

| License, Permit, or Other Required Approval | Responsible Agency | Authority | Relevance and Status |
|---|--|--|---|
| Waste Management and Pollution Prevention | | | |
| Registration and Hazardous Waste Generator Identification Number: Required before a person who generates over 100 kg (220 lb) per calendar month of hazardous waste ships the hazardous waste offsite. | EPA or State agency | RCRA, as amended (42 U.S.C. §§ 6901 et seq.; TN1281), Subtitle C | Generators of hazardous waste must notify the EPA that the wastes exist and require management in compliance with RCRA. |
| Hazardous Waste Facility Permit: Required if hazardous waste will undergo nonexempt treatment by the generator, be stored onsite for longer than 90 days by the generator of 1,000 kg (2,205 lb) or more of hazardous waste per month, be stored onsite for longer than 180 days by the generator of between 100 and 1,000 kg (220 and 2,205 lb) of hazardous waste per month, disposed of onsite, or be received from offsite for treatment or disposal. | EPA or State agency | RCRA, as amended (42 U.S.C. §§ 6901 et seq.; TN1281), Subtitle C | Hazardous wastes are usually not disposed of onsite at nuclear power plants. Hazardous wastes generated onsite are not generally stored for more than 90 days. However, should a nuclear power plant store waste onsite for greater than 90 days for characterization, profiling, or scheduling for treatment or disposal, a Hazardous Waste Facility Permit would be required. |
| Emergency Planning and Response | | | |
| List of Material Safety Data Sheets: Submission of a list of Material Safety Data Sheets is required for hazardous chemicals (as defined in 29 CFR Part 1910-TN654) that are stored onsite in excess of their threshold quantities. | State and local emergency planning agencies | EPCRA, Section 311 (42 U.S.C. § 11021; TN6603); 40 CFR 370.20 (TN6612) | Nuclear power plant operators are required to submit a list of Material Safety Data Sheets to State and local emergency planning agencies. |
| Annual Hazardous Chemical Inventory Report: The report must be submitted when hazardous chemicals have been stored at a facility during the preceding year in amounts that exceed threshold quantities. | State and local emergency response agencies; local fire department | EPCRA, Section 312 (42 U.S.C. § 11022; TN6603); 40 CFR 370.25 (TN6612) | If hazardous chemicals have been stored at a nuclear power plant during the preceding year in amounts that exceed threshold quantities, then plant operators would be required to submit an annual Hazardous Chemical Inventory Report. |

Table F-2 Federal, State, and Local Permits and Other Requirements (Continued)

| License, Permit, or Other Required Approval | Responsible Agency | Authority | Relevance and Status |
|---|--|--|--|
| List of Material Safety Data Sheets: Submission of a list of Material Safety Data Sheets is required for hazardous chemicals (as defined in 29 CFR Part 1910-TN654) that are stored onsite in excess of their threshold quantities. | State and local emergency planning agencies | EPCRA, Section 311 (42 U.S.C. § 11021; TN6603); 40 CFR 370.20 (TN6612) | Nuclear power plant operators are required to submit a list of Material Safety Data Sheets to State and local emergency planning agencies. |
| Annual Hazardous Chemical Inventory Report: The report must be submitted when hazardous chemicals have been stored at a facility during the preceding year in amounts that exceed threshold quantities. | State and local emergency response agencies; local fire department | EPCRA, Section 312 (42 U.S.C. § 11022; TN6603); 40 CFR 370.25 (TN6612) | If hazardous chemicals have been stored at a nuclear power plant during the preceding year in amounts that exceed threshold quantities, then plant operators would be required to submit an annual Hazardous Chemical Inventory Report. |
| Annual Hazardous Chemical Inventory Report: The report must be submitted when hazardous chemicals have been stored at a facility during the preceding year in amounts that exceed threshold quantities. | State and local emergency response agencies; local fire department | EPCRA, Section 312 (42 U.S.C. § 11022; TN6603); 40 CFR 370.25 (TN6612) | If hazardous chemicals have been stored at a nuclear power plant during the preceding year in amounts that exceed threshold quantities, then plant operators would be required to submit an annual Hazardous Chemical Inventory Report. |
| Notification of Onsite Storage of an Extremely Hazardous Substance: Submission of the notification is required within 60 days after onsite storage begins of an extremely hazardous substance in a quantity greater than the threshold planning quantity. | State and local emergency response agencies | EPCRA, Section 304 (42 U.S.C. § 11004; TN6603); 40 CFR 355.30 (TN5493) | If an extremely hazardous substance will be stored at a nuclear power plant in a quantity greater than the threshold planning quantity, plant operators would prepare and submit the Notification of Onsite Storage of an Extremely Hazardous Substance. |
| Annual Toxics Release Inventory Report: Required for facilities that have 10 or more full-time employees and are assigned certain Standard Industrial Classification Codes. | EPA or State agency | EPCRA, Section 313 (42 U.S.C. § 11023; TN6603); 40 CFR Part 372 (TN6613) | If required, nuclear power plant operators would prepare and submit a Toxics Release Inventory Report to the EPA. |
| Transportation of Radioactive Wastes and Conversion Products | U.S. Department of Transportation | Hazardous Materials Transportation Act (49 U.S.C. §§ 5101 et seq.; TN6605); AEA, | When shipments of radioactive materials are made, nuclear power |

Table F-2 Federal, State, and Local Permits and Other Requirements (Continued)

| License, Permit, or Other Required Approval | Responsible Agency | Authority | Relevance and Status |
|--|--|--|--|
| Packaging, Labeling, and Routing Requirements for Radioactive Materials: Required for packages containing radioactive materials that will be shipped by truck or rail. | | as amended (42 U.S.C. §§ 2011 et seq.; TN663); 49 CFR Part 172 (TN6616), Part 173 (TN298), Part 174 (TN6622), Part 177 (TN6620), and Part 397 (TN6621) | plant operators would comply with U.S. Department of Transportation packaging, labeling, and routing requirements. |
| Biotic Resource Protection | | | |
| Threatened and Endangered Species Consultation: Required between the responsible Federal agencies and FWS and/or NMFS to ensure that the project is not likely to: (1) jeopardize the continued existence of any species listed at the Federal or State level as endangered or threatened, or (2) result in destruction of critical habitat of such species. | FWS and NMFS | ESA of 1973, as amended (16 U.S.C. §§ 1531 et seq.; TN1010) | For actions that may affect listed species or designated critical habitat, the NRC would consult with the FWS and/or NMFS under Section 7 of the ESA. |
| Essential Fish Habitat Consultation: Required between the responsible Federal agency and NMFS to ensure that Federal actions authorized, funded, or undertaken do not adversely affect essential fish habitat. | NMFS | Magnuson-Stevens Fishery Conservation and Management Act, as amended (16 U.S.C. §§ 1801–1884; TN1061) | For actions that may adversely affect essential fish habitat, the NRC would consult with NMFS in accordance with 50 CFR Part 600, Subpart J (TN1342). |
| CWA Section 404 (Dredge and Fill) Permit: Required to place dredged or fill material into waters of the United States, including areas designated as wetlands, unless such placement is exempt or authorized by a nationwide permit or a regional permit; a notice must be filed if a nationwide or regional permit applies. | USACE | CWA (33 U.S.C. §§ 1251 et seq.; TN662); 33 CFR Part 323 (TN4827) and Part 330 (TN4318) | Dredging or placement of fill material into wetlands within the jurisdiction of the USACE at a nuclear power plant would require a Section 404 permit. |
| Cultural Resources Protection | | | |
| Archaeological and Historical Resources Consultation: Required before a Federal agency | State Historic Preservation Officer and/or Tribal Historic | NHPA of 1966, as amended (54 U.S.C. §§ 300101 et seq.; TN4157); Archeological and Historical Preservation Act of | The NRC would consult with the State and/or Tribal Historic Preservation Officers and |

Table F-2 Federal, State, and Local Permits and Other Requirements (Continued)

| License, Permit, or Other Required Approval | Responsible Agency | Authority | Relevance and Status |
|--|----------------------|---|---|
| approves a project in an area where archaeological or historic resources might be located. | Preservation Officer | 1974 (54 U.S.C. §§ 312501 et seq.; TN4844); Antiquities Act of 1906 (54 U.S.C. §§ 320301–320303 and 18 U.S.C. § 1866(b); TN6602); Archaeological Resources Protection Act of 1979, as amended (16 U.S.C. §§ 470aa–mm; TN1687) | representative American Indian Tribes regarding the impacts of licensing new nuclear reactors and the results of archaeological and architectural surveys of nuclear power plant sites. |

1 **F.8 Emergency Management and Response Laws, Regulations, and Executive**
 2 **Orders**

3 This section discusses the response laws, regulations, and Executive Orders that address the
 4 protection of public health and worker safety and require the establishment of emergency plans.
 5 These laws, regulations, and Executive Orders relate to the operation of nuclear power plants.
 6 To make things easier for readers, certain items are repeated from previous sections in this
 7 appendix.

8 **F.9 Federal Emergency Management Response Laws**

9 **Emergency Planning and Community Right-to-Know Act of 1986 (42 U.S.C. §§ 11001**
 10 **et seq.; TN6603) (also known as “SARA Title III”) –** EPCRA, which is the major amendment
 11 to CERCLA (42 U.S.C. § 9601; TN6592), establishes the requirements for Federal, State, and
 12 local governments, American Indian Tribes, and industry regarding emergency planning and
 13 “Community Right-to-Know” reporting on hazardous and toxic chemicals. The “Community
 14 Right-to-Know” provisions increase the public’s knowledge and access to information about
 15 chemicals at individual facilities, their uses, and releases into the environment. States and
 16 communities working with facilities can use the information to improve chemical safety and
 17 protect public health and the environment. This Act requires emergency planning and notice to
 18 communities and government agencies concerning the presence and release of specific
 19 chemicals. The EPA implements this Act under regulations found in 40 CFR Part 355 (TN5493),
 20 Part 370 (TN6612), and Part 372 (TN6613).

21 **Comprehensive Environmental Response, Compensation, and Liability Act of 1980**
 22 **(42 U.S.C. § 9604(I); TN6592) (also known as “Superfund”) –** This Act provides authority for
 23 Federal and State governments to respond directly to hazardous substance incidents. The Act
 24 requires reporting of spills, including radioactive spills, to the National Response Center.

25 **Robert T. Stafford Disaster Relief and Emergency Assistance Act of 1988 (42 U.S.C.**
 26 **§ 5121; TN6638) –** This Act, as amended, provides an orderly, continuing means of providing
 27 Federal government assistance to State and local governments in managing their
 28 responsibilities to alleviate suffering and damage resulting from disasters. The President, in
 29 response to a State governor’s request, may declare an “emergency” or “major disaster” to
 30 provide Federal assistance under this Act. The President, in Executive Order 12148 (44 FR
 31 43239-TN6614), delegated all functions except those in Sections 301, 401, and 409 to the
 32 Director of the Federal Emergency Management Agency. The Act provides for the appointment
 33 of a Federal coordinating officer who will operate in the designated area with a State

1 coordinating officer for the purpose of coordinating State and local disaster assistance efforts
2 with those of the Federal government.

3 **Justice Assistance Act of 1984 (42 U.S.C. § 3701–3799; TN6639)** – This Act establishes
4 emergency Federal law enforcement assistance to State and local governments in responding
5 to a law enforcement emergency. The Act defines the term “law enforcement emergency” as an
6 uncommon situation that requires law enforcement, that is or threatens to become of serious or
7 epidemic proportions, and with respect to which State and local resources are inadequate to
8 protect the lives and property of citizens or to enforce the criminal law. Emergencies that are not
9 of an ongoing or chronic nature (for example, the Mount St. Helens volcanic eruption) are
10 eligible for Federal law enforcement assistance including funds, equipment, training, intelligence
11 information, and personnel.

12 **Price-Anderson Act (42 U.S.C. § 2210; TN4522)** – The Price-Anderson Act provides insurance
13 protection to victims of a nuclear accident. The main purpose of the Act is to partially indemnify
14 the nuclear industry against liability claims arising from nuclear incidents, while still ensuring
15 compensation coverage for the general public. The Act establishes a no-fault insurance-type
16 system in which the first \$12.6 billion (as of 2011) is industry-funded as described in the Act
17 (any claims above the \$12.6 billion would be covered by the Federal government).

18 The Act requires NRC licensees and U.S. Department of Energy contractors to enter into
19 agreements of indemnification to cover personal injury and property damage to those harmed
20 by a nuclear or radiological incident, including the costs of incident response or precautionary
21 evacuation, costs of investigating and defending claims, and settling suits for such damages.

22 **F.10 Federal Emergency Management and Response Regulations**

23 **Quantities of Radioactive Materials Requiring Consideration of the Need for an**
24 **Emergency Plan for Responding to a Release (10 CFR 30.72, Schedule C; TN4881)** – This
25 section of the regulations provides a list that is the basis for both the public and private sector to
26 determine whether the radiological materials they handle must have an emergency response
27 plan for unscheduled releases.

28 **Occupational Safety and Health Administration Emergency Response, Hazardous Waste**
29 **Operations, and Worker Right-to-Know (29 CFR Part 1910; TN654)** – This regulation
30 establishes OSHA requirements for employee safety in a variety of working environments. It
31 addresses employee emergency and fire prevention plans (Section 1910.38), hazardous waste
32 operations and emergency response (Section 1920.120), and hazards communication
33 (Section 1910.1200) to make employees aware of the dangers they face from hazardous
34 materials in their workplace. These regulations do not directly apply to Federal agencies.
35 However, Section 19 of the Occupational Safety and Health Act (29 U.S.C. § 668) requires all
36 Federal agencies to have occupational safety programs “consistent” with Occupational Safety
37 and Health Act standards. There is a Memorandum of Understanding between the NRC and
38 OSHA (NRC 2013-TN10165). The memorandum states its purpose is to “to delineate the
39 general areas of responsibility of each agency, to describe generally the efforts of the agencies
40 to achieve worker protection at facilities licensed by the NRC, and to provide guidelines for
41 coordination of activities between the two agencies regarding occupational safety and health.

42 **Emergency Management and Assistance (44 CFR Section 1.1; TN6615)** – This regulation
43 contains the policies and procedures for the Federal Emergency Management Act, National
44 Flood Insurance Program, Federal Crime Insurance Program, Fire Prevention and Control

1 Program, Disaster Assistance Program, and Preparedness Program, including radiological
2 planning and preparedness.

3 **Hazardous Materials Tables and Communications, Emergency Response Information**
4 **Requirements (49 CFR Part 172; TN6616)** – This regulation defines the regulatory
5 requirements for marking, labeling, placarding, and documenting hazardous material shipments.
6 The regulation also specifies the requirements for providing hazardous material information and
7 training.

8 **F.11 Emergency Management and Response Executive Orders**

9 **Executive Order 12148, Federal Emergency Management (44 FR 43239-TN6614)** – This
10 Order transfers functions and responsibilities associated with Federal emergency management
11 to the Director of the Federal Emergency Management Agency. The Order assigns the Director
12 the responsibility to establish Federal policies and to coordinate all civil defense and civil
13 emergency planning for the management, mitigation, and assistance functions of Executive
14 agencies.

15 **Executive Order 12656, Assignment of Emergency Preparedness Responsibilities**
16 **(53 FR 47491-TN6626)** – This Order assigns emergency preparedness responsibilities to
17 Federal departments and agencies.

18 **Executive Order 12938, Proliferation of Weapons of Mass Destruction (59 FR 59099-**
19 **TN6640)** – This Order states that the proliferation of nuclear, biological, and chemical weapons
20 (“weapons of mass destruction”) and the means of delivering such weapons constitutes an
21 unusual and extraordinary threat to the national security, foreign policy, and economy of the
22 United States, and that a national emergency would be declared to deal with that threat.

23 **F.12 Consultations with Agencies and Federally Recognized American Indian** 24 **Nations**

25 Certain laws, such as the ESA (16 U.S.C. §§ 1531 et seq.; TN1010), the Fish and Wildlife
26 Coordination Act (16 U.S.C. §§ 661 et seq.; TN4467), and the NHPA (54 U.S.C.
27 §§ 300101 et seq.; TN4157), require consultation and coordination by the NRC with other
28 governmental entities, including other Federal, State, and local agencies and federally
29 recognized American Indian Tribes. These consultations must occur on a timely basis and are
30 generally required before any land disturbance can begin. Most of these consultations are
31 related to biotic resources, historic properties, cultural resources, and recognizes NRC’s Federal
32 trust responsibility to American Indian Tribes. The biotic resource consultations generally pertain
33 to the potential for activities to disturb sensitive species or habitats. Cultural resource
34 consultations relate to the potential for disruption of important cultural resources and
35 archaeological sites. Consultations with American Indian Tribes are conducted on a
36 government-to-government basis.

37 **F.13 References**

38 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, “Standards for
39 Protection Against Radiation.” TN283.

40 10 CFR Part 30. *Code of Federal Regulations*, Title 10, *Energy*, Part 30, “Rules of General
41 Applicability to Domestic Licensing of Byproduct Material.” TN4881.

- 1 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of
2 Production and Utilization Facilities.” TN249.
- 3 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
4 Protection Regulations for Domestic Licensing and Related Regulatory Functions.” TN250.
- 5 10 CFR Part 52. *Code of Federal Regulations*, Title 10, *Energy*, Part 52, “Licenses,
6 Certifications, and Approvals for Nuclear Power Plants.” TN251.
- 7 29 CFR Part 1910. *Code of Federal Regulations*, Title 29, *Labor*, Part 1910, “Occupational
8 Safety and Health Standards.” TN654.
- 9 33 CFR Part 320. *Code of Federal Regulations*, Title 33, *Navigation and Navigable Waters*, Part
10 320, “General Regulatory Policies.” TN424.
- 11 33 CFR Part 323. *Code of Federal Regulations*, Title 33, *Navigation and Navigable Waters*, Part
12 323, “Permits for Discharge of Dredged or Fill Material into Waters of the United States.”
13 TN4827.
- 14 33 CFR Part 330. *Code of Federal Regulations*, Title 33, *Navigation and Navigable Waters*, Part
15 330, “Nationwide Permit Program.” TN4318.
- 16 36 CFR Part 800. *Code of Federal Regulations*, Title 36, *Parks, Forests, and Public Property*,
17 Part 800, “Protection of Historic Properties.” TN513.
- 18 40 CFR Parts 50-99. *Code of Federal Regulations*, Title 40, *Protection of the Environment*,
19 Subchapter C, Parts 50-99, “Air Programs.” TN5264.
- 20 40 CFR Part 61. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 61,
21 “National Emission Standards for Hazardous Air Pollutants.” TN3289.
- 22 40 CFR Part 112. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 112,
23 “Oil Pollution Prevention.” TN1041.
- 24 40 CFR Part 121. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 121,
25 “State Certification of Activities Requiring a Federal License or Permit.” TN6718.
- 26 40 CFR Part 122. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 122,
27 “EPA Administered Permit Programs: The National Pollutant Discharge Elimination System.”
28 TN2769.
- 29 40 CFR Part 190. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 190,
30 “Environmental Radiation Protection Standards for Nuclear Power Operations.” TN739.
- 31 40 CFR Parts 239–283. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Parts
32 239–283, EPA Regulations Implementing RCRA. TN6618.
- 33 40 CFR Part 280. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 280,
34 “Technical Standards and Corrective Action Requirements for Owners and Operators of
35 Underground Storage Tanks (UST).” TN6619.

1 40 CFR Part 355. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 302,
2 “Emergency Planning and Notification.” TN5493.

3 40 CFR Part 370. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 370,
4 “Hazardous Chemical Reporting: Community Right-To-Know.” TN6612.

5 40 CFR Part 372. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 372,
6 “Toxic Chemical Release Reporting: Community Right-To-Know.” TN6613.

7 40 CFR Part 761. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 761,
8 “Polychlorinated Biphenyls (PCBs) Manufacturing, Processing, Distribution in Commerce, and
9 Use Prohibitions.” TN6610.

10 40 CFR Parts 1500–1508. *Code of Federal Regulations*, Title 40, *Protection of Environment*,
11 Subchapter A, “National Environmental Policy Act Implementing Regulations.” TN6611.

12 44 CFR Part 1. *Code of Federal Regulations*, Title 44, *Emergency Management and*
13 *Assistance*, Part 1, “Rulemaking, Policy, and Procedures.” TN6615.

14 49 CFR Parts 171-177. *Code of Federal Regulations*, Title 49, *Transportation*, Subchapter C,
15 “Hazardous Materials Regulations (49 CFR Parts 171-177).” TN5466.

16 49 CFR Part 172. *Code of Federal Regulations*, Title 49, *Transportation*, Part 172, “Hazardous
17 Materials Table, Special Provisions, Hazardous Materials Communications, Emergency
18 Response Information, Training Requirements, and Security Plans.” TN6616.

19 49 CFR Part 173. *Code of Federal Regulations*, Title 49, *Transportation*, Part 173, “Shippers—
20 General Requirements for Shipments and Packagings.” TN298.

21 49 CFR Part 174. *Code of Federal Regulations*, Title 49, *Transportation*, Part 174, “Carriage by
22 Rail.” TN6622.

23 49 CFR Part 177. *Code of Federal Regulations*, Title 49, *Transportation*, Part 177, “Carriage by
24 Public Highway.” TN6620.

25 49 CFR Part 397. *Code of Federal Regulations*, Title 49, *Transportation*, Part 397,
26 “Transportation of Hazardous Materials; Driving and Parking Rules.” TN6621.

27 50 CFR Part 600. *Code of Federal Regulations*. Title 50, *Wildlife and Fisheries*, Part 600,
28 “Magnuson-Stevens Act Provisions.” TN1342.

29 35 FR 4247. March 7, 1970. “Executive Order 11514 of March 5, 1970: Protection and
30 Enhancement of Environmental Quality.” *Federal Register*, Office of the President. TN6608.

31 36 FR 8921. May 15, 1971. “Executive Order 11593 of May 13, 1971: Protection and
32 Enhancement of the Cultural Environment.” *Federal Register*, Office of the President. TN6609.

33 42 FR 26951. May 25, 1977. “Executive Order 11988 of May 24, 1977: Floodplain
34 Management.” *Federal Register*, Office of the President. TN270.

35 42 FR 26961. May 25, 1977. “Executive Order 11990 of May 24, 1977: Protection of Wetlands.”
36 *Federal Register*, Office of the President. TN269.

1 43 FR 47707. October 17, 1978. "Executive Order 12088 of October 13, 1978: Federal
2 Compliance with Pollution Control Standards." *Federal Register*, Office of the President.
3 TN6623.

4 44 FR 43239. July 24, 1979. "Executive Order 12148 of July 28, 1979: Federal Emergency
5 Management" *Federal Register*, Office of the President. TN6614.

6 52 FR 2923. January 29, 1987. "Executive Order 12580 of January 23, 1987: "Superfund
7 Implementation." *Federal Register*, Office of the President. TN6624.

8 53 FR 47491. November 23, 1988. "Executive Order 12656 of November 18, 1988: Assignment
9 of Emergency Preparedness Responsibilities." *Federal Register*, Office of the President.
10 TN6626.

11 59 FR 7629. February 16, 1994. "Executive Order 12898 of February 11, 1994: Federal Actions
12 To Address Environmental Justice in Minority Populations and Low-Income Populations."
13 *Federal Register*, Office of the President. TN1450.

14 59 FR 59099. November 16, 1994. "Executive Order 12938 of November 14, 1994: Proliferation
15 of Weapons of Mass Destruction." *Federal Register*, Office of the President. TN6640.

16 61 FR 26771. May 29, 1996. "Executive Order 13007 of May 24, 1996: Indian Sacred Sites."
17 *Federal Register*, Office of the President. TN6629.

18 62 FR 19885. April 23, 1997. "Executive Order 13045 of April 21, 1997: Protection of Children
19 from Environmental Health Risks and Safety Risks." *Federal Register*, Office of the President.
20 TN6630.

21 64 FR 6183. February 8, 1999. "Executive Order 13112 of February 3, 1999: Invasive Species."
22 *Federal Register*, Office of the President. TN4477.

23 64 FR 30851. June 8, 1999. "Executive Order 13123 of June 3, 1999: Greening the Government
24 Through Efficient Energy Management." *Federal Register*, Office of the President. TN6634.

25 65 FR 67249. November 9, 2000. "Executive Order 13175 of November 6, 2000—Consultation
26 and Coordination with Indian Tribal Governments." *Federal Register*, Office of the President.
27 TN4846.

28 66 FR 52013. October 11, 2001. "Executive Order 13229 of October 9, 2001: Amendment to
29 Executive Order 13045, Extending the Task Force on Environmental Health Risks and Safety
30 Risks to Children." *Federal Register*, Office of the President. TN6631.

31 68 FR 19931. April 23, 2003. "Executive Order 13296 of April 18, 2003: Amendments to
32 Executive Order 13045, Protection of Children from Environmental Health Risks and Safety
33 Risks." *Federal Register*, Office of the President. TN6632.

34 68 FR 37691. June 24, 2003. "Executive Order 13308 of June 20, 2003: Further Amendment to
35 Executive Order 12580, as amended, Superfund Implementation. *Federal Register*, Office of the
36 President. TN6625.

- 1 69 FR 52040. August 24, 2004. "Policy Statement on the Treatment of Environmental Justice
2 Matters in NRC Regulatory and Licensing Actions." *Federal Register*, Nuclear Regulatory
3 Commission. TN1009.
- 4 82 FR 2402. January 9, 2017. "Tribal Policy Statement." *Federal Register*, Nuclear Regulatory
5 Commission. TN5500.
- 6 86 FR 7037. January 25, 2021. "Executive Order 13990 of January 20, 2021: Protecting Public
7 Health and the Environment and Restoring Science To Tackle the Climate Crisis." *Federal*
8 *Register*, Office of the President. TN7028.
- 9 86 FR 7619. February 1, 2021. "Executive Order 14008 of January 27, 2021: Tackling the
10 Climate Crisis at Home and Abroad." *Federal Register*, Office of the President. TN7027.
- 11 33 U.S.C. § 1341. U.S. Code Title 33, *Navigation and Navigable Waters*, Chapter 26, "Water
12 Pollution Prevention and Control," Subchapter IV, *Permits and Licenses*, Section 1341
13 "Certification." TN4764.
- 14 42 U.S.C. § 7412. Clean Air Act Section 112, "Hazardous Air Pollutants." TN7014.
- 15 42 U.S.C. § 7506. Clean Air Act Section 176, "Limitations on Certain Federal Assistance."
16 TN4856.
- 17 American Indian Religious Freedom Act, as amended. 42 U.S.C. § 1996 *et seq.* TN5281.
- 18 Antiquities Act of 1906, as amended. 54 U.S.C. § 320301–320303 and 18 U.S.C. § 1866(b).
19 TN6602.
- 20 Archaeological Resources Protection Act of 1979, as amended. 54 U.S.C. § 302101 *et seq.*
21 TN1687.
- 22 Archeological and Historic Preservation Act of 1974, as amended. 54 U.S.C. § 312501 *et seq.*
23 TN4844.
- 24 Atomic Energy Act of 1954. 42 U.S.C. § 2011 *et seq.* Public Law 112-239, as amended. TN663.
- 25 Bald and Golden Eagle Protection Act. 16 U.S.C. § 668-668d *et seq.* TN1447.
- 26 Clean Air Act. 42 U.S.C. § 7401 *et seq.* TN1141.
- 27 Coastal Zone Management Act of 1972. 16 U.S.C. § 1451 *et seq.* TN1243.
- 28 Comprehensive Environmental Response, Compensation, and Liability Act, as amended. 42
29 U.S.C. § 9601 *et seq.* TN6592.
- 30 Emergency Planning and Community Right-to-Know Act of 1986. 42 U.S.C. § 11001 *et seq.*
31 TN6603.
- 32 Endangered Species Act of 1973. 16 U.S.C. § 1531 *et seq.* TN1010.
- 33 Energy Reorganization Act of 1974, as amended. 42 U.S.C. § 5801 *et seq.* TN4466.

- 1 Federal Insecticide, Fungicide, and Rodenticide Act, as amended. 7 U.S.C. § 136 et seq.
2 TN4535.
- 3 Federal Water Pollution Control Act of 1972 (commonly referred to as the Clean Water Act). 33
4 U.S.C. § 1251 et seq. TN662.
- 5 Fish and Wildlife Conservation Act of 1980. 16 U.S.C. § 2901 et seq. TN6604.
- 6 Fish and Wildlife Coordination Act, as amended. 16 U.S.C. § 661 et seq. TN4467.
- 7 Fixing America’s Surface Transportation Act. 42 U.S.C. § 4370m et seq. TN6392.
- 8 Hazardous Materials Transportation Act. 49 U.S.C. § 5101 et seq. TN6605.
- 9 Justice Assistance Act of 1984. 42 U.S.C. § 3701–3799. TN6639.
- 10 Low-Level Radioactive Waste Policy Act of 1980. 42 U.S.C. § 2021b et seq. Public Law 96-573.
11 TN6606.
- 12 Magnuson-Stevens Fishery Conservation and Management Act, Public Law 94-265, as
13 amended through October 11, 1996. 16 U.S.C. § 1801 et seq. TN1061.
- 14 Marine Mammal Protection Act of 1972, as amended. 16 U.S.C. § 1361 et seq. TN4478.
- 15 Marine Protection, Research, and Sanctuaries Act of 1972. 33 U.S.C. § 1401 et seq. TN6637.
- 16 Migratory Bird Treaty Act of 1918. 16 U.S.C. § 703 et seq. TN3331.
- 17 National Historic Preservation Act. 54 U.S.C. § 300101 et seq. TN4157.
- 18 Native American Graves Protection and Repatriation Act. 25 U.S.C. § 3001 et seq. TN1686.
- 19 Noise Control Act of 1972. 42 U.S.C. § 4901 et seq. TN4294.
- 20 NRC (U.S. Nuclear Regulatory Commission). 2013. Letter from R.K. Johnson, Chief Fuel
21 Manufacturing Branch Division of Fuel Cycle Safety and Safeguards, Office of Nuclear Materials
22 Safety and Safeguards, to D.W. Johnson, Director, Office of Technical Programs and
23 Coordination Activities, Department of Labor Occupational Safety and Health Administration,
24 dated July 29, 2013, regarding “Memorandum of Understanding Between the U.S. Nuclear
25 Regulatory Commission and the Occupational Safety and Health Administration.” Washington,
26 D.C. ADAMS Accession No. ML11354A411. TN10165.
- 27 NRC (U.S. Nuclear Regulatory Commission). 2020. *Environmental Considerations Associated*
28 *with Micro-Reactors*. Final COL-ISG-029, Washington, D.C. ADAMS Accession No.
29 ML20252A076. TN6710.
- 30 NRC (U.S. Nuclear Regulatory Commission). 2024. *Generic Environmental Impact Statement*
31 *for Advanced Nuclear Reactors, Draft Report for Comment*. NUREG-2249, Washington, D.C.
32 ADAMS Accession No. ML24176A220. TN7080.

- 1 NRC (U.S. Nuclear Regulatory Commission). 2024. *Draft Guide-4032, Proposed Revision 4 to*
2 *Regulatory Guide 4.2, Preparation of Environmental Reports for Nuclear Power Stations.*
3 Washington, D.C. ADAMS Accession No. ML24176A228. TN7081.
- 4 Nuclear Energy Innovation and Modernization Act. 42 U.S.C. § 2011 Note. Public Law 115-439,
5 January 14, 2019, 132 Stat. 5565. TN6469.
- 6 Nuclear Waste Policy Act of 1982. 42 U.S.C. § 10101 et seq. TN740.
- 7 Occupational Safety and Health Act of 1970, as amended. 29 U.S.C. § 651 et seq. TN4453.
- 8 Pollution Prevention Act of 1990. 42 U.S.C. § 13101 et seq. TN6607.
- 9 Price-Anderson Act of 1957, as amended. 42 U.S.C. § 2210 et seq. TN4522.
- 10 Resource Conservation and Recovery Act of 1976. 42 U.S.C § 6901 et seq. Public Law 94-580,
11 90 Stat. 2795. TN1281.
- 12 Robert T. Stafford Disaster Relief and Emergency Assistance Act of 1988. 42 U.S.C. § 5121
13 et seq. TN6638.
- 14 Safe Drinking Water Act of 1974, as amended. 42 U.S.C. § 300f et seq. TN1337.
- 15 Toxic Substances Control Act, as amended. 15 U.S.C. § 2601 et seq. TN4454.

APPENDIX G

PLANT PARAMETER ENVELOPE AND SITE PARAMETER ENVELOPE

The interdisciplinary team of subject matter experts assigned to prepare the new nuclear nuclear reactor generic environmental impact statement (GEIS) used the following methodology to develop the plant parameter envelope (PPE) and site parameter envelope (SPE) values and assumptions in this appendix:

- regulatory limits and permitting requirements relevant to the resource as established by Federal, State, or local agencies
- relevant information obtained from other U.S. Nuclear Regulatory Commission (NRC) GEISs, including the License Renewal GEIS (NRC 2024-TN10161) and the Continued Storage GEIS (NRC 2014-TN4117)
- empirical knowledge gained from conducting evaluations and analyses for past new nuclear reactor environmental impact statements (EISs)
- values and assumptions derived from other documents applying a PPE/SPE approach (such as the National Reactor Innovation Center PPE Report [NRIC 2021-TN6940])
- subject matter expertise and/or development of calculations and formulas based upon education and experience with the resource

For details about the PPE and SPE values and assumptions, see the applicable resource section in Chapter 3. The PPE and SPE values and assumptions are used only to support the findings for Category 1 issues. Category 2 issues do not have PPE and SPE values and assumptions.

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors

| Parameter | Values and Assumptions | Basis/Methodology |
|------------------------|---|---|
| Reactor Site Criteria | <p>10 CFR Part 100 (TN282) Subpart B Evaluation Factors for Stationary Power Reactor Site Applications on or After January 10, 1997</p> <p>Reactor siting factors to be considered by the applicant shall include:</p> <ol style="list-style-type: none"> 10 CFR 100.20 Factors to be considered when evaluating sites 10 CFR 100.21 Non-seismic siting criteria 10 CFR 100.23 Geologic and seismic siting criteria | Adherence to siting criteria regulations has been determined to minimize impacts associated with environmental review evaluations. |
| Site Size and Location | <ol style="list-style-type: none"> 100 ac Complies with applicable zoning Consistent with the objectives of any relevant land use plans Complies with the Coastal Zone Management Act of 1972 (16 U.S.C. § 1451 et seq; TN1243) and the Farmland Protection Policy Act of 1981 (7 U.S.C. §§ 4201 et seq.; TN708), if applicable Completed structures would not be sited within 1 mi of and would not be visible from Federal or State parks or wilderness areas, areas designated as Class I under Section 162 of the Clean Air Act (42 U.S.C. § 7472-TN6954), or a Wild and Scenic River or a National Heritage River, or a river of similar State designation No existing residential areas within 0.5 mi of site | The NRC staff recognizes that, without a detailed consideration of specific land use conditions, as much as 100 ac of land can be dedicated to a project within a feasible setting without noticeably influencing the availability of land for other purposes. The NRC staff assumes any proposed project would meet NRC siting regulations in 10 CFR Part 100 (TN282), or the applicable NRC siting regulations in place at the time the application is docketed. Establishing industrial facilities close to residences can affect the use and enjoyment of residences who desire home environments that are less influenced by the sights, noise, odors, and other parameters acceptable to industrial and commercial workplace settings. A minimum distance of 0.5 mi bounds a generic determination that potential conflicts with residences would be SMALL, although a consideration of specific site conditions could indicate that closer distances could still be SMALL. An even greater distance (1 mi) is needed to bound a generic determination that a project would have only a SMALL potential for adversely affecting features such as Federal or State parks and conservation areas, whose qualities are even more sensitive to industrial influences. |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|------------------------------------|---|--|
| Permanent Footprint of Disturbance | <ol style="list-style-type: none"> 1. 30 ac of vegetated lands 2. Counts only land that supports vegetation as of project baseline 3. No prime or unique farmland, or other farmland of statewide or local importance (see Section 3.1.1 for definitions); or site does not abut actively managed agricultural land and is not situated in a predominantly agricultural landscape 4. No floodplains, surface water features, riparian habitat, late-successional vegetation, or dedicated conservation land 5. No more than 0.5 ac of wetlands in permanent or temporary disturbance on the site or ROWs 6. The site and any existing ROWs do not have legacy contamination requiring cleanup to protect human health or the environment 7. No Individual Permits required under Section 404 of the Clean Water Act (33 U.S.C. § 1344-TN1019) 8. Use of best management practices (BMPs) for soil erosion, sediment control, and stormwater management 9. Implementation of mitigation specified in Clean Water Act permits 10. Habitat is not known to be potentially suitable for one or more Federal or State threatened or endangered species | <p>The total footprint of disturbance within areas of existing vegetation (30 ac permanent plus an additional 20 ac of temporary for a total of 50 ac) constitutes an estimate by NRC staff of how much natural habitat excluding unusually sensitive habitats can be disturbed, regardless of geometric shape, in almost any landscape without noticeably altering wildlife numbers or behavior. The value of 0.5 ac of wetlands corresponds to the upper ceiling for project-wide impacts on wetlands under many Nationwide Permits (33 CFR Part 330; TN4318) determined by the U.S. Army Corps of Engineers to constitute minimal impact.</p> |
| Temporary Footprint of Disturbance | <ol style="list-style-type: none"> 1. Additional 20 ac of vegetated land 2. Counts only land that supports vegetation as of project baseline 3. Meets assumptions for permanent footprint 4. Restored to original grade and seeded or planted with indigenous vegetation once construction is complete | <p>This additional temporary disturbance is factored together with the assumption of no more than 30 ac permanent disturbance into the overall disturbance area of 50 ac (see above). Temporary disturbance of most natural habitats followed by restoration constitutes less impact per acre than permanent or long-term disturbance. The limit of 0.5 ac of wetland impacts in most Nationwide Permits (33 CFR Part 330; TN4318) is a project-wide limit, inclusive of all associated permanent and temporary impacts.</p> |
| Offsite rights-of-way (ROW) | <ol style="list-style-type: none"> 1. No longer than 1 mi and no wider than 100 ft, but allows for unlimited additional mileage for linear features built within existing ROWs or directly adjacent to existing ROWs or public highways 2. Does not cause the total project-wide wetland fill to exceed 0.5 ac | <p>Dimensions of up to 1 mi long and 100 ft wide constitutes an upper estimate by the NRC staff as to how much new ROW can be established anywhere in most rural landscapes without noticeably affecting fragmented land uses or natural habitats, without consideration of project-specific factors. The staff, based</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|--|--|--|
| | <ol style="list-style-type: none"> 3. Would not involve ground disturbance to streams greater than 10 ft in width 4. Does not cross or pass within 1 mi of parks, wildlife refuges, or conservation lands 5. Does not cross or pass within 1 mi of, or is not visible from, Federal or State parks or wilderness areas, areas designated as Class I under Section 162 of the Clean Air Act (42 U.S.C. § 7472-TN6954), or a Wild and Scenic River or a National Heritage River, or a river of similar State designation 6. May span wetlands, waters of the United States, floodplains, shoreline, or riparian lands 7. Any new transmission poles or towers would be constructed outside of wetlands and floodplains 8. Pipelines or buried utilities would be directionally drilled under surface waters to avoid physical disturbance of shorelines or bottom substrates 9. Use of BMPs for soil erosion, sediment control, and stormwater management 10. Implementation of mitigation specified in Clean Water Act permits 11. No physical disturbance to streams greater than 10 ft in width below the ordinary high-water mark 12. Access roads crossing non-jurisdictional surface water features meet the substantive requirements of Nationwide Permits 12 or 14 regarding limits on disturbance and requirements for mitigation | <p>on its experience conducting environmental reviews, concludes that co-location of new facilities within existing ROWs or in new ROWs immediately adjacent to existing ROWs or along existing roadways results in minimal land use or ecological impacts. Such ROWs do not fragment existing land uses or natural habitats or introduce utility structures to settings previously lacking such facilities. Additional assumptions address sensitive facilities, which, if present, would necessitate a project-specific analysis to assess the significance of impacts. The limit of 0.5 ac of wetland impacts in most Nationwide Permits (33 CFR Part 330; TN4318) is a project-wide limit, inclusive of impacts from all project elements, including offsite features.</p> |
| <p>Maximum Building and Structure Height</p> | <ol style="list-style-type: none"> 1. 50 ft, except 200 ft for meteorological towers and 100 feet for mechanical draft cooling towers 2. None of the structures would be built within or be visible from Federal or State parks or wilderness areas, other areas designated as Class I under Section 162 of the Clean Air Act (42 U.S.C. § 7472-TN6954), or designated Wild and Scenic Rivers 3. No transmission poles/towers over 100 ft | <p>Fifty feet constitutes a conservative estimate of building heights that would not likely result in significant visual intrusion or wildlife collision mortality in most settings. This conclusion is based upon NRC reviews in past reactor EISs. The staff recognizes that meteorological towers must be taller to function, and that there would be no need for more than one or two meteorological towers per site. A transmission line with poles or towers taller than 100 ft would be visible in a forested area and would be highly visible in an open area. Most poles shorter than 100 ft are not highly distinct visually from the distribution poles for lower voltage electric lines that are</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|---|--|---|
| | | common visual features in most settings. Mechanical draft cooling towers are typically 50–100 ft in height based on previous new nuclear reactor EIS analyses. |
| Intake and Discharge | <ol style="list-style-type: none"> 1. Adhere to the best available technology requirements of Clean Water Act (CWA) 316(b) (33 U.S.C. § 1326-TN4823) 2. Operated in compliance with CWA Section 316 (b) and 40 CFR 125.83 (TN254), including compliance with monitoring and recordkeeping requirements in 40 CFR 125.87 and 40 CFR 125.88, respectively 3. Best available technologies are employed in the design and operation of intake and discharge structures to minimize alterations due to scouring, sediment transport, increased turbidity, and erosion 4. Adherence to requirements in National Pollutant Discharge Elimination System (NPDES) permits issued by the U.S. Environmental Protection Agency (EPA) or a given State | Requirements established in the subject regulations have been developed to be protective of aquatic biota, including protection of aquatic biota from excessive impingement or entrainment. |
| In-Water Structures (including intake and discharge structures) | <ol style="list-style-type: none"> 1. Constructed in compliance with provisions of the CWA Section 404 (33 U.S.C. § 1344-TN1019) and Section 10 of the Rivers and Harbors Appropriation Act of 1899 (33 U.S.C. §§ 401 et seq.; TN660) 2. Adverse effects of building activities controlled and localized using BMPs such as installation of turbidity curtains or installation of cofferdams 3. Any shorelines or other areas temporarily disturbed to build intake and discharge structures would be restored using regionally indigenous vegetation 4. Construction duration would be less than 7 years | Requirements of existing regulations related to in-water construction are protective of aquatic resources and have been found to keep the adverse impacts of building activities localized and temporary. |
| Cooling Towers | <ol style="list-style-type: none"> 1. No natural draft cooling towers 2. Would be equipped with drift eliminators 3. Makeup water would be fresh (salinity less than 1 ppt) | Various past new nuclear reactor EISs indicate that natural draft cooling towers are tall structures over 200 ft in height that may be visible from substantial distances and from which salt drift and fogging may affect substantial areas of offsite land. |

G-5

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|--|--|--|
| Other Cooling Features | <ol style="list-style-type: none"> 1. No once-through cooling 2. No new cooling ponds 3. No new reservoirs 4. No spray irrigation ponds | Once-through cooling systems have a substantial potential for significant impacts on aquatic biota from entrainment and impingement and are essentially not possible due to Section 316(b) of the Clean Water Act (33 U.S.C. § 1326-TN4823). Operation of cooling ponds can have potentially significant effects on aquatic and terrestrial biota. Building reservoirs can affect large areas of aquatic and terrestrial habitats, including sensitive wetland, floodplain, and riparian habitats. |
| Copper Alloy Tubes | <ol style="list-style-type: none"> 1. No use of copper alloy tubes | According to the License Renewal GEIS, copper alloy tubes can introduce metal contaminants into discharged blowdown water that can be harmful to aquatic biota. |
| Criteria Pollutant and Hazardous Air Pollutant Emissions | <ol style="list-style-type: none"> 1. Criteria pollutants emitted from vehicles and standby power equipment during construction and operations are less than Clean Air Act de minimis levels set by the EPA if located in a nonattainment or maintenance area 2. Hazardous Air Pollutant emissions will be within regulatory limits 3. Construction and operation activities meet the permitting requirements of applicable State and local agencies 4. Use of BMPs for dust control | Requirements of existing regulations related to air emissions have been found to be protective of human health and the environment. |
| Greenhouse Gas Emissions | New reactor construction and operation, including uranium fuel cycle activities, transportation of fuel and waste, and decommissioning will emit no more than 2,534,000 metric tonnes (MT) CO ₂ (e) for the lifespan of the project of 97 years | <p>Appendix H provides estimates of emissions of greenhouse gases associated with building, operation, fuel cycle, transportation of fuel and waste, and decommissioning. Estimates of uranium fuel cycle emissions are based on 5% enrichment.</p> <ol style="list-style-type: none"> 1. Construction equipment would emit 78,000 MT CO₂(e) during a 7-year construction period 2. Construction workforce would emit 86,000 MT CO₂(e) during a 7-year construction period 3. Plant operations would emit 362,000 MT CO₂(e) during a 40- year period 4. Plant workforce would emit 272,000 MT CO₂(e) during a 40- year period 5. The uranium fuel cycle would emit 1,620,000 MT CO₂(e) during a 40-year period. Transportation of Fuel |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|--|---|--|
| | | <p>and Waste would emit 42,000 MT CO₂(e) during a 40-year period</p> <ol style="list-style-type: none"> 6. Decommissioning equipment would emit 38,000 MT CO₂(e) during a 10-year period 7. Decommissioning workforce would emit 16,000 MT CO₂(e) during a 10-year period 8. SAFe STORAge workforce would emit 20,000 MT CO₂ equivalent during a 40-year period <p>Previous new nuclear reactor reviews which have a larger fuel cycle contribution based on Table S-3 have concluded that the impact of the contribution of greenhouse gases is SMALL.</p> |
| Cooling-System Air Quality | <ol style="list-style-type: none"> 1. Hazardous Air Pollutant emissions will be within regulatory limits 2. Subject to State permitting requirements | <p>The License Renewal GEIS (NRC 2024-TN10161) and supplemental EISs for individual plant relicensing evaluated the impact of continued operation of cooling towers, including natural draft cooling towers, at existing power plants for an additional 20 years and found the impacts to be SMALL.</p> |
| Ozone and Nitrogen Oxide (NOx) Emissions | <p>Transmission line voltage no higher than 1200 kilovolt(s)</p> | <p>Impacts of existing transmission lines on air quality are addressed in the License Renewal GEIS (NRC 2024-TN10161) and Supplemental EISs for individual plant relicensing, which have found impacts to be SMALL. The License Renewal GEIS evaluated lines up to 1,200 kilovolts.</p> |
| Total Plant Water Demand | <ol style="list-style-type: none"> 1. Less than or equal to a daily average 6,000 gpm 2. The total plant water demand accounts for the maximum amount of water supply required for all plant needs 3. The total plant water demand may include water from multiple sources (e.g., surface water, groundwater, and/or municipal water sources to meet certain water quality criteria) | <p>The NRC staff developed the total plant water demand PPE by considering water requirements for all plant systems from the set of currently known advanced nuclear reactor designs considered by National Reactor Innovation Center (2021-TN6940). The NRC staff rounded this value up to the nearest 1,000 gpm to derive the PPE.</p> |
| Municipal Water Availability | <p>The amount available from municipal water systems exceeds the amount of municipal water required by the plant (gpm)</p> <p>If municipal water is used for plant water supply:</p> | <p>Municipal water availability at a site is the amount of excess capacity in the municipal systems that is available after accounting for all existing and planned future uses. The NRC staff can generically conclude that the proposed project's municipal water requirements would not noticeably affect water resources at the site, if</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|--|--|---|
| | <ol style="list-style-type: none"> Municipal Water Availability accounts for all existing and planned future uses An agreement or permit for the usage amount can be obtained from the municipality | <p>bounded by municipal water availability and the capacity of the municipal systems.</p> |
| <p>Surface Water Availability – Flowing (Stream or River) (not applicable if plant does not use cooling water)</p> | <ol style="list-style-type: none"> The average rate of plant withdrawal does not exceed 3 percent of the 95 percent exceedance daily flow for the waterbody (cubic feet per second) Average plant water withdrawals do not reduce discharge from the flowing waterbody by more than 3 percent of the 95 percent exceedance daily flow and do not prevent the maintenance of applicable instream flow requirements The 95 percent exceedance daily flow accounts for existing and planned future withdrawals Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional or tribal governing authorities Water rights for the withdrawal amount are obtainable, if needed Changes in littoral zone water levels and hydroperiod resulting from surface water withdrawals are within historical annual or seasonal fluctuations If withdrawals are from an estuary or intertidal zone, then changes to salinity gradients are within the normal tidal or seasonal movements that characterize the waterbody | <p>The staff reviewed surface water withdrawals from and related impacts on flowing waterbodies versus low-flow metrics at the of currently operating and newly licensed large light-water reactors (LWRs). In the reviews of previous analyses, the staff found that water withdrawal rates at or below 3 percent of the water available during low flow conditions did not result in noticeable impacts. Therefore, the NRC staff generically concluded that plant surface water withdrawals that do not exceed 3 percent of the 95 percent exceedance daily flow in the flowing waterbody used as the source, while accounting for all existing and planned withdrawals, would not noticeably affect surface water resources at the site.</p> <p>Plant water withdrawal may alter salinity gradients in flowing water bodies. The License Renewal GEIS (NRC 1996-TN288 and NRC 2024-TN10161) evaluated the impact of plant withdrawals on altering salinity gradients at operating plants and found the impacts to be SMALL if they are localized and are within the normal tidal or seasonal movements of salinity gradients that characterize the waterbody.</p> |
| <p>Surface Water Availability – Non-Flowing (not applicable if plant does not use cooling water)</p> | <ol style="list-style-type: none"> Water availability of the Great Lakes, the Gulf of Mexico, oceans, estuaries, and intertidal zones exceeds the amount of water required by the plant Water availability is demonstrated by the ability to obtain a withdrawal permit issued by State, regional or tribal governing authorities Water rights for the withdrawal amount are obtainable, if needed Changes in littoral zone water levels and hydroperiod resulting from surface water withdrawals are within historical annual or seasonal fluctuations | <p>The staff can generally conclude that the total plant water demand of 6,000 gpm would not result in water use conflicts in the Great Lakes, the Gulf of Mexico, oceans, estuaries, and intertidal zones, because the plant demand would be negligible as compared to water availability. The staff acknowledges, however, that smaller non-flowing surface waterbodies (e.g., inland lakes, man-made ponds, and reservoirs) have limited water availability. These waterbodies are not included in the staff's generic analysis.</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|---|---|--|
| | <ol style="list-style-type: none"> 5. If withdrawals are from an estuary or intertidal zone, then changes to salinity gradients are within the normal tidal or seasonal movements that characterize the waterbody 6. Coastal Zone Management Act of 1972 (16 U.S.C. §§ 1451 et seq.; TN1243) consistency determination is obtainable, if applicable | <p>Plant water withdrawal may alter salinity gradients in non-flowing waterbodies. The License Renewal GEIS (NRC 1996-TN288 and NRC 2024-TN10161) evaluated the impact of plant withdrawals on altering salinity gradients at operating plants and found the impacts to be SMALL if they are localized and are within the normal tidal or seasonal movements of salinity gradients that characterize the waterbody.</p> |
| Municipal Systems' Available Capacity to Receive and Treat Plant Effluent | <ol style="list-style-type: none"> 1. The available capacity of the municipal systems to treat effluent exceeds the expected amount of plant effluent (gpm) 2. Municipal Systems' Available Capacity to Receive and Treat Plant Effluent accounts for all existing and planned future discharges 3. Agreement to discharge to a municipal treatment system is obtainable | <p>Municipal systems' available receiving and treatment capacity is determined while accounting for all existing and reasonably foreseeable future discharges. The NRC staff can generically conclude that plant effluent treated by a municipal system would not noticeably affect water resources at the site, if bounded by the municipal systems' available capacity. The constituents present in plant effluent are addressed in the municipal systems' discharge permits.</p> |
| Groundwater Withdrawal for Plant Uses | <ol style="list-style-type: none"> 1. Less than or equal to 50 gpm 2. Withdrawal results in no more than 1 ft of drawdown at the site boundary 3. Withdrawals are not derived from an EPA-designated Sole Source Aquifer, or from any aquifer designated by a State, tribe, or regional authority to have special protections to limit drawdown 4. Withdrawals meet the permitting requirements of applicable State and local agencies 5. Changes in wetland water levels and hydroperiod resulting from groundwater use are within historical annual or seasonal fluctuations 6. Parameter value of 50 gpm is the total withdrawal for all plant uses (excluding dewatering) | <p>This site parameter was based on the staff's determination in the License Renewal GEIS that ≤ 100 gpm groundwater withdrawal creates negligible or small impacts at operating nuclear power plants because this use rate would not generally lower groundwater levels beyond the site boundary. The groundwater withdrawal rate parameter was adjusted lower based on simplified modeling showing that effects on groundwater levels at the site boundary from pumping 50 gpm on a 100 ac site would approximate the effects from pumping 100 gpm on a larger site the size of a typical large LWR. The staff assumed that groundwater withdrawals for plant uses would result in less than a 1 ft reduction in groundwater levels at the site boundary. The threshold of 1 ft was selected as a de minimis value likely to be less than the natural annual fluctuations in groundwater levels at most sites.</p> |
| Groundwater Withdrawal for Excavation or Foundation Dewatering | <ol style="list-style-type: none"> 1. Dewatering rate less than or equal to 50 gpm 2. Dewatering results in negligible drawdown at the site boundary | <p>The groundwater dewatering parameter was based on the staff's determination that impacts would be small if dewatering would not lower groundwater levels beyond the site boundary, which is consistent with the License</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|------------------------------------|---|--|
| | <ol style="list-style-type: none"> 3. Dewatering discharge has minimal effects on the quality of the receiving waterbody (e.g., as demonstrated by conformance with NPDES permit requirements) 4. Changes in wetland water levels and hydroperiod resulting from dewatering are within historical annual or seasonal fluctuations 5. Parameter value of 50 gpm represents the long-term dewatering rate (the initial rate may be larger) | <p>Renewal GEIS. Based on simplified modeling, the staff determined that, relative to the plant site area, the effects on groundwater levels caused by dewatering withdrawals of 50 gpm at a 100 ac site would be similar to the effects caused by dewatering withdrawals of 100 gpm on a larger site the size of a typical large LWR. Consistent with the site area for the new nuclear reactor, the staff assumed in this simplified modeling that the area to be dewatered and the depth of groundwater drawdown at the excavation/foundation would be smaller than for a typical large LWR.</p> |
| Groundwater Quality | <ol style="list-style-type: none"> 1. The plant is outside the recharge area for any EPA-designated Sole Source Aquifer or any aquifer designated to have special protections by a State, tribal, or regional authority 2. The plant is outside the wellhead protection area or designated contributing area for any public water supply well 3. No planned plant discharges to the subsurface (by infiltration or injection), including stormwater discharge 4. Applicable requirements and guidance on spill prevention and control are followed, including relevant BMPs and Integrated Pollution Prevention Plan 5. A groundwater protection program conforming to NEI 07-07 (NEI 2019-TN6775) is established and followed | <p>Because groundwater quality degradation would have the greatest effects on other users of the resource when groundwater at the plant site contributes to the source water for other users, the potential impacts on groundwater quality from plant construction and operation will be minimized when the plant is located outside the recharge areas for critical groundwater supplies and when there are no planned discharges to the subsurface. In addition, spill prevention/control requirements and a groundwater protection program help prevent releases of contaminants to groundwater and to minimize the impacts of any releases that inadvertently occur.</p> |
| Impacts on Aquatic Biota | <ol style="list-style-type: none"> 1. Adherence to regulatory limits in 40 CFR 125.84 (TN254) 2. Adherence to requirements in NPDES permits issued by the EPA or a given State | <p>Requirements of existing regulations related to aquatic biota impacts are protective of aquatic resources and have been found to keep adverse impacts localized and temporary.</p> |
| Radiological Environmental Hazards | <p>For protection against radiation, the applicant must meet the regulatory requirements of:</p> <ul style="list-style-type: none"> • 10 CFR 20.1101 Radiation Protection Programs (10 CFR Part 20-TN283) if issued a license • 10 CFR 20.1201 Occupational dose limits for adults • 10 CFR 20.1301 Dose limits for individual members of the public • Appendix B of 10 CFR Part 20 Annual Limits on Intake (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for | <p>Requirements of existing regulations related to radiological health have been found to be protective of workers and members of the public and are minimized through a radiation protection program that implements ALARA (as low as is reasonably achievable).</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|---------------------------------------|--|---|
| | <p>Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewerage</p> <ul style="list-style-type: none"> • 10 CFR 50.34a (10 CFR Part 50-TN249) Design objectives for equipment to control releases of radioactive material in effluents—nuclear power reactors • 10 CFR 50.36a Technical specifications on effluents from nuclear power reactors <p>Applicants would demonstrate in their application that any radiological nonhuman biota doses would be below IAEA (1992-TN712) and National Council on Radiation Protection and Measurements (NCRP) (1991-TN729) guidelines</p> <p>Application contains sufficient technical information for the staff to complete the detailed technical safety review</p> <p>Application will be found to be in compliance by the staff with the above regulations through a radiation protection program and an effluent release monitoring program</p> | |
| Nonradiological Environmental Hazards | <ol style="list-style-type: none"> 1. The applicant must adhere to all applicable Federal, State, local, or tribal regulatory limits and permit conditions for chemical hazards, biological hazards, and physical hazards from a proposed advanced reactor 2. The applicant will follow nonradiological public and occupational health BMPs and mitigation measures, as appropriate, to govern building and operations-related activities | Requirements of existing regulations related to nonradiological environmental hazards are protective of human health and have been found to keep the adverse impacts of building and operations-related activities localized and temporary. |
| Wildlife-Related Noise Generation | 85 decibel(s) on the A-weighted scale (dBA) 50 ft from the source | NRC staff has historically relied upon the Federal Highway Administration Construction Noise Handbook (WSDOT 2017-TN5313) to determine that a noise level of 85 dBA 50 ft from the source is typical. |
| Human-Related Noise Generation | <ol style="list-style-type: none"> 1. 65 dBA at site boundary, unless a relevant State or local noise abatement law or ordinance sets a different threshold, which would then be the presumptive threshold for PPE purposes. 2. If an applicant cannot meet the 65 dBA threshold through mitigation, then the applicant must obtain a various or exception with the relevant State or local regulator. | The License Renewal GEIS (NUREG-1437; NRC 2024-TN10161) determined that noise levels are considered acceptable if the day-night average sound level outside a residence is less than 65 dBA. This limit is also included in the NRC Environmental Standard Review Plans (NUREG-1555; NRC 2000-TN614). |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|----------------------------------|---|--|
| | 3. Project will implement BMPs, including such as modeling, foliage planting, construction of noise buffers, and the timing of construction and/or operation activities. | |
| Radiological Waste Management | Applicants must meet the regulatory requirements of 10 CFR Part 20 (TN283) (e.g., 20.1406 and Subpart K), 10 CFR Part 61 (TN252), 10 CFR Part 71 (TN301), and 10 CFR Part 72 (TN4884) LLRWs at existing nuclear power plants generate an average of 21,200 ft ³ (600 m ³) and 2,000 Ci (7.4 × 10 ¹³ Bq) per year for boiling water reactors and half that amount for pressurized water reactors (NRC 2024-TN10161) Resource Conservation and Recovery Act (RCRA) Small Quantity Generator (EPA 2020-TN6590) for Mixed Waste | Requirements of existing regulations related to radiological waste management have been found to be protective of human health and the environment. |
| Nonradiological Waste Management | 1. Applicants must meet all applicable permit conditions, regulations, and BMPs related to solid, liquid, and gaseous waste management 2. For hazardous waste generation, applicants must meet the conformity with the appropriate hazardous waste quantity generation level in accordance with RCRA (EPA 2020-TN6590) 3. For sanitary waste, applicants must treat sanitary waste in a permitted process 4. Perform mitigation measures, to the extent practicable, such as recycling, process improvements, or using a less hazardous substance | Requirements of existing regulations and applicable permits related to nonradiological waste management have been found to be protective of human health and the environment and have been found to keep the adverse impacts of building and operation activities localized and temporary. |
| Postulated Accidents | For design basis accidents, ¹ the exclusion area boundary maximum total effective dose equivalent for any 2-hour period and the low-population zone maximum total effective dose equivalent for the duration of the accident release | Requirements of existing regulations related to postulated accidents are protective of human health. The applicant would have to demonstrate meeting the dose requirements contained in 10 CFR 50.34(a)(1) |

G-12

¹ For the purposes of this GEIS, "Design Basis Accidents" are related to a spectrum of accidents that will be evaluated for satisfying siting requirements (e.g., 10 CFR Part 100-TN282) and the safety analysis requirements (e.g., 10 CFR Part 50-TN249, 10 CFR Part 52-TN251) or the applicable NRC safety and siting regulations in place at the time the application is docketed).

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|-----------------|---|--|
| | <p>For accidents involving releases of hazardous chemicals:</p> <ul style="list-style-type: none"> • New reactor inventory of a regulated substance is less than its Threshold Quantity (TQ). TQs are found in 40 CFR 68.130, Tables 1, 2, 3, and 4 (TN5494); and • New reactor inventory of an EHS is less than its Threshold Planning Quantity (TPQ). TPQs are found in 40 CFR Part 355, Appendices A and B (TN5493). <p>A cost-screening analysis determines that the maximum benefit for avoiding an accident is so small that a severe accident mitigation alternative (SAMDA) analysis is not justified based on a minimum cost to design an appropriate SAMDA.</p> <p>The proposed site is not within the jurisdiction of the United States Court of Appeals for the Ninth Circuit</p> | <p>(TN249) Design objectives for equipment to control releases of radioactive material in effluents – nuclear power reactors, or 10 CFR 52.17(a)(1) (TN251), Contents of applications; technical information, or 10 CFR 52.79(a)(1)(A), Contents of applications; technical information in Final Safety Analysis Report, as applicable.</p> <p>For hazardous chemical accidents, the applicant would make a comparison of hazardous chemical inventories to the TQs found in 40 CFR 68.130, Tables 1, 2, 3, and 4 (TN5494); and the TPQs in 40 CFR Part 355, Appendices A and B (TN5493).</p> <p>For SAMDAs, the staff expects that the safety analysis would have core damage frequencies (CDFs) that would likely be substantially less than CDFs associated with the current reactor fleet. For non-LWR severe accident mitigation alternative screening and assessments, event or release category frequency could be used in place of CDFs. In such cases a cost screening could determine that the maximum benefit for avoiding an accident is so small that a SAMDA is not justified based on a minimum cost to design an appropriate SAMDA. This cost-screening process would be based on the available risk information from the safety analysis report and apply the cost formulas from NUREG/BR-0058 (NRC 2020-TN6806).</p> <p>Acts of terrorism: If within the jurisdiction of the United States Court of Appeals for the Ninth Circuit, appropriate staff analysis would be performed based in part on the physical protection requirements under 10 CFR Part 73 (TN423).</p> |
| Site Employment | Peak project-related in-migrating workforce including families does not exceed established local planning and growth projections for infrastructure and service demands | Some construction and operations workers and their families are assumed to relocate to the economic region of the proposed project. Staff assumes growth planning for the affected infrastructure and services would factor these |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|---|--|--|
| | | changes into baseline service demand projections. This assumption is based on staff experience since 2005 for more than 20 license application reviews. Peak project-related workforce increases are assumed to cause minimal effects on most services and infrastructure as long as increases are within local government planning projections. |
| Community Services and Infrastructure (e.g., housing availability; school capacities) | <ol style="list-style-type: none"> 1. the housing vacancy rate in the affected economic region remains at least 5 percent of the housing stock after removing sufficient rental units to accommodate the in-migrating construction workers, 2. student:teacher ratios in the affected economic region do not decline below the locally mandated levels after including the school age children of the in-migrating construction worker families housing and education resources would be the only resource areas where noticeable impacts might occur | This assumption is based on staff experience since 2005 with more than 20 license application reviews. Staff experience indicates a healthy housing market maintains a vacancy rate of five percent of the total housing stock, and any local, regional, or State mandated threshold (e.g., a student:teacher ratio) establishes the point of inflection from a SMALL impact to a MODERATE impact. |
| Transportation Systems and Traffic | Level of service (LOS) determination for affected roadways does not change | Movement between LOS classes (A, B, C, D, E, F) would be noticeable to drivers. Increased traffic that does not trigger a movement between these classes would be a minor impact. This assumption is based on the industry-standard LOS approach that has been used in previous NRC NEPA assessments since 2005. |
| Fuel Cycle | <p>Table S–3 bounds the impacts for the proposed reactor, because of uranium fuel cycle changes since WASH-1248 (AEC 1974-TN23), including:</p> <ul style="list-style-type: none"> • Increasing use of in situ leach uranium mining • Transitioning of U.S. uranium enrichment technology from gaseous diffusion to gas centrifugation. • Current LWRs are using nuclear fuel more efficiently due to higher levels of fuel burnup • Less reliance on coal-fired electrical generation plants <p>Reprocessing capacity up to 900 metric tonnes uranium/year (MTU/yr)</p> | <p>Advances in the uranium fuel cycle (as noted in the values and assumptions columns) have reduced the various impacts of the fuel cycle from what is presented in Table S–3. For example, higher burnup levels allow for longer periods of time between refueling thus reducing the annual number of fuel assemblies discharged from a reactor.</p> <p>Requirements of existing regulations related to the safe processing, storage, transportation, and security of nuclear material have been found to be protective of workers and members of the public.</p> |

G-14

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|-------------------------------------|---|--|
| | <p>Uranium fuel cycle impacts will bound the thorium fuel cycle impacts</p> <p>Waste and spent fuel inventories, as well as their associated certified spent fuel shipping and storage containers, are not significantly different from what has been considered for LWR evaluations in NUREG-2157 (NRC 2014-TN4117)</p> <p>Must satisfy the regulatory requirements of 10 CFR Part 40 (TN4882) <i>Domestic Licensing of Source Material</i>, 10 CFR Part 50 (TN249) <i>Domestic Licensing of Production and Utilization Facilities</i>, 10 CFR Part 70 (TN4883), <i>Domestic Licensing of Special Nuclear Material</i>, 10 CFR Part 71 (TN301), <i>Packaging and Transportation of Radioactive Material</i>, 10 CFR Part 72 (TN4884), <i>Licensing Requirements for the Independent Storage of Spent Fuel, High-Level Radioactive Waste, and Reactor-related Greater Than Class C Waste</i>, and 10 CFR Part 73 (TN423), <i>Physical Protection of Plants and Materials</i>.</p> | <p>Fuel fabrication impacts for metal fuel and liquid fueled molten salt are not included in the staff's generic analysis.</p> |
| Transportation of Unirradiated Fuel | <p>Consistency with thresholds for the maximum shipment distances in Tables 3.15-2 and 3.15-3, 59,160 km and 118,320 km respectively.</p> <p>The shipments are normalized to a net electrical output of 880 MW(e), i.e., 1,100 MW(e) with an 80 percent capacity factor from WASH-1238 (AEC 1972-TN22)</p> <p>The parameter does not apply to situations where a new nuclear reactor applicant proposes shipping the unirradiated fuel by air, ship or barge; or where an applicant proposes that an unirradiated fuel transportation package be approved using the provisions of 10 CFR 71.12, 10 CFR 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301)</p> | <p>Accident frequencies for transportation of unirradiated fuel are expected to be lower than those used in the analysis in WASH-1238 (AEC 1972-TN22). This is based on the NRC staff review of the trends in improvements in highway safety and security, and an overall reduction in traffic accident, injury, and fatality rates since WASH-1238 was published. Although packages for all types of unirradiated fuel have not been designed or certified by the NRC, these packages must comply with the packaging requirements contained in 10 CFR Part 71 (TN301) and for this reason, the impacts of radiological accidents during transport of unirradiated fuel are expected to be smaller than those listed in Table S-4 in 10 CFR 51.52 (TN250).</p> <p>The PPE applies to situations where the enrichment of the unirradiated fuel is 20 percent or less, based on the unlimited A₂ value in Table A-1 in 10 CFR Part 71 for</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|-------------------------------------|---|--|
| Transportation of Radioactive Waste | <p>Consistency with thresholds for the maximum shipment distance in Table 3-16, 293,145 km.</p> <p>The shipments are normalized to a net electrical output of 880 megawatt(s) electrical (MWe,) i.e., 1,100 MWe with an 80 percent capacity factor and a shipment volume of 2.34 m³/shipment from WASH-1238 (AEC 1972-TN22).</p> <p>This PPE does not apply to situations where a new nuclear reactor applicant proposes shipping the radioactive waste by air, ship or barge; or where an applicant proposes that a radioactive waste transportation package be approved using the provisions of 10 CFR 71.12, 10 CFR 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301)</p> | <p>unirradiated uranium enriched to 20 percent or less (10 CFR Part 71-TN301).</p> <p>Reviewed impacts from previous LWR early site permit (ESP) and combined license (COL) environmental analyses, which have concluded that the impacts of transportation of radioactive waste were SMALL.</p> |
| Transportation of Irradiated Fuel | <p>Consistency with the thresholds for the maximum shipment distances, and burnup included in Tables 3.15-8 through 3.15-10, 505,393 km and 1,010,786 km.</p> <p>The shipments are normalized to a net electrical output of 880 MWe, i.e., 1,100 MWe with an 80 percent capacity factor and a shipment capacity of 0.5 MTU/shipment from WASH-1238 (AEC 1972-TN22)</p> <p>This PPE is based on a maximum peak rod burnup of 62 GWd/MTU for uranium oxide fuel and 133 GWd/MTU for TRi-structural ISOtropic fuel</p> <p>This PPE does not apply to situations where a new nuclear reactor applicant proposes shipping the irradiated fuel by air, ship or barge; or where a new nuclear reactor applicant proposes that an irradiated fuel transportation package be approved using the provisions of 10 CFR 71.12, 10 CFR 71.41(c), or 10 CFR 71.41(d) (10 CFR Part 71-TN301) such as might be applied for when shipping a complete irradiated reactor core</p> | <p>Reviewed impacts from previous LWR ESP and COL environmental analyses, which have concluded that the impacts of transportation of irradiated fuel were SMALL.</p> |

G-16

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|-----------------|---|---|
| | <p>In addition, the irradiated fuel must be shipped in a transportation package that meets all of the applicable NRC regulations</p> | |
| Decommissioning | <p>The environmental impacts for the following resource areas were generically addressed in NUREG-0586, Supplement 1, would be limited to operational areas, would not be detectable or destabilizing and are expected to have a negligible effect on the impacts of terminating operations and decommissioning:</p> <ul style="list-style-type: none"> • Onsite land use • Water use • Water quality • Air quality • Aquatic ecology within the operational area • Terrestrial ecology within the operational area • Radiological • Radiological accidents (non-spent-fuel-related) • Occupational issues • Socioeconomic • Onsite cultural and historic resources for plants where the disturbance of lands beyond the operational areas is not anticipated • Aesthetics • Noise • Transportation • Irretrievable resource <p>The following issues were not addressed in NUREG-0586, Supplement 1, but have been determined to be Category 1 issues:</p> <ul style="list-style-type: none"> • Nonradiological waste • Greenhouse gases <p>The following two issues were identified in NUREG-0586, Supplement 1, as requiring a project-specific review:</p> <ul style="list-style-type: none"> • Environmental justice • Threatened and endangered species | <p>NUREG-0586 Supplement 1 Decommissioning GEIS (NRC 2002-TN665)</p> <p>Requirements of existing regulations related to decommissioning activities have been found to be protective of workers, members of the public, and the environment.</p> |

Table G-1 Plant Parameter Envelope and Site Parameter Envelope for New Reactors (Continued)

| Parameter | Values and Assumptions | Basis/Methodology |
|---------------------------------|--|---|
| | <p>Four conditionally project-specific issues identified in NUREG-0586, Supplement 1, will require a project-specific review if present:</p> <ul style="list-style-type: none"> • Land use involving offsite areas to support decommissioning activities • Aquatic ecology for activities beyond the licensed operational area • Terrestrial ecology for activities beyond the licensed operational area • Historic and cultural resources (archaeological, architectural, structural, historic) for activities within and beyond the licensed operational area with no current (i.e., at the time of decommissioning) evaluation of resources for NRHP eligibility <p>Additionally, the following two environmental resource areas are additional decommissioning impacts that require project-specific review:</p> <ul style="list-style-type: none"> • Climate change: the effects of climate change are location-specific and cannot, therefore, be evaluated generically (see Section 1.3.3.2.2, Category 2 Issues Applying Across Resources, of this NR GEIS) <p>Cumulative effects: must be considered on a project-specific basis where impacts would depend on regional resource characteristics, the resource specific impacts of the project, and the cumulative significance of other factors affecting the resource. (see Section 1.3.3.2.2, Category 2 Issues Applying Across Resources, of this NR GEIS)</p> | |
| Operational Life of the Plant | 40-year operational life, assuming a 40-year license | 10 CFR 50.51(a) (TN249) and 52.104 (TN251). |
| Construction Phase of the Plant | 7-year construction life to complete construction activities | Based off previous new nuclear reactor EIS reviews. |

G-18

1 **G.1 References**

- 2 10 CFR Part 20. *Code of Federal Regulations*, Title 10, *Energy*, Part 20, “Standards for
3 Protection Against Radiation.” TN283.
- 4 10 CFR Part 40. *Code of Federal Regulations*, Title 10, *Energy*, Part 40, “Domestic Licensing of
5 Source Material.” TN4882.
- 6 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, “Domestic Licensing of
7 Production and Utilization Facilities.” TN249.
- 8 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
9 Protection Regulations for Domestic Licensing and Related Regulatory Functions.” TN250.
- 10 10 CFR Part 52. *Code of Federal Regulations*, Title 10, *Energy*, Part 52, “Licenses,
11 Certifications, and Approvals for Nuclear Power Plants.” TN251.
- 12 10 CFR Part 61. *Code of Federal Regulations*, Title 10, *Energy*, Part 61, “Licensing
13 Requirements for Land Disposal of Radioactive Waste.” TN252.
- 14 10 CFR Part 70. *Code of Federal Regulations*, Title 10, *Energy*, Part 70, “Domestic Licensing of
15 Special Nuclear Material.” TN4883.
- 16 10 CFR Part 71. *Code of Federal Regulations*, Title 10, *Energy*, Part 71, “Packaging and
17 Transportation of Radioactive Material.” TN301.
- 18 10 CFR Part 72. *Code of Federal Regulations*, Title 10, *Energy*, Part 72, “Licensing
19 Requirements for the Independent Storage of Spent Nuclear Fuel, High-Level Radioactive
20 Waste, and Reactor-Related Greater than Class C Waste.” TN4884.
- 21 10 CFR Part 73. *Code of Federal Regulations*, Title 10, *Energy*, Part 73, “Physical Protection of
22 Plants and Materials.” TN423.
- 23 10 CFR Part 100. *Code of Federal Regulations*, Title 10, *Energy*, Part 100, “Reactor Site
24 Criteria.” TN282.
- 25 33 CFR Part 330. *Code of Federal Regulations*, Title 33, *Navigation and Navigable Waters*, Part
26 330, “Nationwide Permit Program.” TN4318.
- 27 40 CFR Part 68. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 68,
28 “Chemical Accident Prevention Provisions.” TN5494.
- 29 40 CFR Part 125. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 125,
30 “Criteria and Standards for the National Pollutant Discharge Elimination System.” Washington,
31 D.C. TN254.
- 32 40 CFR Part 355. *Code of Federal Regulations*, Title 40, *Protection of Environment*, Part 302,
33 “Emergency Planning and Notification.” TN5493.
- 34 33 U.S.C. § 1326. U.S. Code Title 33, *Navigation and Navigable Waters*, Section 1326,
35 “Thermal Discharges.” TN4823.

- 1 33 U.S.C. § 1344. U.S. Code Title 33, *Navigation and Navigable Waters*, Chapter 26, “Water
2 Pollution Prevention and Control,” Subchapter IV, *Permits and Licenses*, Section 404 “Permits
3 for Dredged or Fill Material.” TN1019.
- 4 42 U.S.C. § 7472. Clean Air Act Section 162, “Initial Classifications.” TN6954.
- 5 AEC (U.S. Atomic Energy Commission). 1972. *Environmental Survey of Transportation of*
6 *Radioactive Materials to and from Nuclear Power Plants*. WASH–1238, Washington, D.C.
7 ADAMS Accession No. ML14092A626. TN22.
- 8 AEC (U.S. Atomic Energy Commission). 1974. *Environmental Survey of the Uranium Fuel*
9 *Cycle*. WASH–1248, Washington, D.C. ADAMS Accession No. ML14092A628. TN23.
- 10 Coastal Zone Management Act of 1972. 16 U.S.C. § 1451 et seq. TN1243.
- 11 EPA (U.S. Environmental Protection Agency). 2020. “Categories of Hazardous Waste
12 Generators.” Washington, D.C. ADAMS Accession No. ML21141A344. TN6590.
- 13 Farmland Protection Policy Act of 1981. 7 U.S.C. § 4201 et seq. TN708.
- 14 IAEA (International Atomic Energy Agency). 1992. *Effects of Ionizing Radiation on Plants and*
15 *Animals at Levels Implied by Current Radiation Protection Standards*. Technical Report Series
16 332, Vienna, Austria. TN712.
- 17 NCRP (National Council on Radiation Protection and Measurements). 1991. *Effects of Ionizing*
18 *Radiation on Aquatic Organisms*. NCRP Report No. 109, Bethesda, Maryland. TN729.
- 19 NEI (Nuclear Energy Institute). 2019. *Industry Groundwater Protection Initiative – Final*
20 *Guidance Document, Rev. 1*. NEI-07-07, Revision 1, Washington, D.C. ADAMS Accession No.
21 ML19142A071. TN6775.
- 22 NRC (U.S. Nuclear Regulatory Commission). 1996. *Generic Environmental Impact Statement*
23 *for License Renewal of Nuclear Plants*. Volumes 1 and 2, NUREG–1437, Washington, D.C.
24 ADAMS Accession Nos. ML040690705, ML040690738. TN288.
- 25 NRC (U.S. Nuclear Regulatory Commission). 2000. *Environmental Standard Review Plan—*
26 *Standard Review Plans for Environmental Reviews for Nuclear Power Plants*. NUREG–1555,
27 Main Report and 2007 Revisions, Washington, D.C. Available at [http://www.nrc.gov/reading-](http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1555/toc/)
28 [rm/doc-collections/nuregs/staff/sr1555/toc/](http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr1555/toc/). TN614.
- 29 NRC (U.S. Nuclear Regulatory Commission). 2002. *Final GEIS of Decommissioning of Nuclear*
30 *Facilities: Regarding the Decommissioning of Nuclear Power Reactors*. NUREG–0586,
31 Supplement 1, Volumes 1 and 2, Washington, D.C. ADAMS Accession Nos. ML023470327,
32 ML023500228. TN665.
- 33 NRC (U.S. Nuclear Regulatory Commission). 2013. *Generic Environmental Impact Statement*
34 *for License Renewal of Nuclear Plants* [GEIS]. NUREG–1437, Revision 1, Washington, D.C.
35 ADAMS Package Accession No. ML13107A023. TN2654.

1 NRC (U.S. Nuclear Regulatory Commission). 2014. *Generic Environmental Impact Statement*
2 *for Continued Storage of Spent Nuclear Fuel*. Final Report, NUREG–2157, Washington, D.C.
3 ADAMS Package Accession No. ML14198A440. TN4117.

4 NRC (U.S. Nuclear Regulatory Commission). 2020. *Policy Issue: Draft Final NUREG/BR-0058,*
5 *Revision 5, “Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission.”*
6 SECY-20-0008, Washington, D.C. ADAMS Pkg. Accession No. ML19261A277. TN6806.

7 NRIC (National Reactor Innovation Center). 2021. *Advanced Nuclear Reactor Plant Parameter*
8 *Envelope and Guidance*. NRIC-21-ENG-0001, Washington, D.C. ADAMS Accession No.
9 ML21145A416. TN6940.

10 Rivers and Harbors Appropriation Act of 1899. 33 U.S.C. § 401 et seq. TN660.

11 WSDOT (Washington State Department of Transportation). 2017. “Construction Noise Impact
12 Assessment.” Chapter 7 in *Biological Assessment Preparation for Transportation Projects –*
13 *Advanced Training Manual*. Olympia, Washington. Available at
14 http://www.wsdot.wa.gov/sites/default/files/2018/01/18/Env-FW-BA_ManualCH07.pdf. TN5313.
15

APPENDIX H

GREENHOUSE GAS EMISSIONS ESTIMATES FOR A REFERENCE 1,000 MWE REACTOR

The U.S. Nuclear Regulatory Commission (NRC) staff estimated the greenhouse gas (GHG) emissions of various activities associated with the building, operation, and decommissioning of nuclear power plants. The GHG emission estimates include direct emissions from the nuclear facility and indirect emissions from workforce and fuel transportation, decommissioning, and the uranium fuel cycle. The estimates are based on a single installation of 1,000 megawatt(s) electrical (MWe) output with an 80 percent capacity factor henceforth referred to as the reference 1,000 MWe reactor. The estimates may be roughly linearly scaled from the reference 1,000 MWe reactor for other reactor outputs¹ This appendix discusses the calculation of GHG emission estimates for the reference 1,000 MWe reactor.

The estimated emissions from equipment used to build a nuclear power plant listed in Table H-1 are based on hours of equipment use estimated for a single nuclear power plant at a site requiring a moderate amount of terrain modification (UniStar 2007-TN1564). Construction equipment carbon monoxide (CO) emission estimates were derived from the hours of equipment use, and carbon dioxide (CO₂) emissions were then estimated from the CO emissions using a scaling factor of 172 tons of CO₂ per ton of CO (Chapman et al. 2012-TN2644). The scaling factor is based on the ratio of CO₂ to CO emission factors for diesel fuel industrial engines as reported in Table 3.3-1 of AP-42 *Compilation of Air Pollutant Emission Factors* (EPA 2012-TN2647). A CO₂ to total GHG equivalency factor of 0.991 is used to account for the emissions from other GHGs, such as methane (CH₄) and nitrous oxide (N₂O) (Chapman et al. 2012-TN2644). The equivalency factor is based on non-road/construction equipment in accordance with relevant guidance (NRC 2014-TN3768; Chapman et al. 2012-TN2644). Equipment emissions estimates for decommissioning are assumed to be one-half of those for construction equipment. Data on equipment emissions for decommissioning are not available; the one-half factor is based on the assumption that decommissioning would involve less earthmoving and hauling of material, as well as fewer labor hours, compared to those involved in building activities (Chapman et al. 2012-TN2644).

Table H-2 lists the NRC staff's estimates of the CO₂(e)² emissions associated with workforce transportation. Construction workforce estimates for the reference 1,000 MWe reactor are conservatively based on estimates in various combined license (COL) applications (Chapman et al. 2012-TN2644), and the operational and decommissioning workforce estimates are based on Supplement 1 to NUREG-0586 (NRC 2002-TN665). Table H-2 lists the assumptions used to estimate total miles traveled by each workforce and the factors used to convert total miles to metric tons of CO₂(e). The workers are assumed to travel in gasoline-powered passenger vehicles (cars, trucks, vans, and sport utility vehicles) that get an average of 21.6 mi/gal of gasoline (FHWA 2012-TN2645). Conversion from gallons of gasoline burned to CO₂(e) is based on U.S. Environmental Protection Agency (EPA) emission factors (EPA 2012-TN2643).

¹ The term "model LWR" has also been used to describe a 1,000 MWe light water reactor for the purpose of evaluating the environmental considerations of the supporting fuel cycle to the annual reactor operations (WASH-1248, AEC 1974-TN23). It is assumed there are no significant differences between the 1,000 MWe reactor evaluated in WASH-1248 and the 1,000 MWe reference reactor evaluated in this appendix.

² A measure to compare the emissions from various GHGs on the basis of their global warming potential (GWP), defined as the ratio of heat trapped by one unit mass of the GHG to that of one unit mass of CO₂ over a specific time period.

1 **Table H-1 Green House Gas Emissions from Equipment Used in Building**
 2 **and Decommissioning (metric tonnes [MT] CO₂(e))**

| Equipment | Building Total ^(a) | Decommissioning Total ^(b) |
|--------------------------|-------------------------------|--------------------------------------|
| Earthwork and dewatering | 12,000 | 6,000 |
| Batch plant operations | 3,400 | 1,700 |
| Concrete | 5,400 | 2,700 |
| Lifting and rigging | 5,600 | 2,800 |
| Shop fabrication | 1,000 | 500 |
| Warehouse operations | 1,400 | 700 |
| Equipment maintenance | 10,000 | 5,000 |
| Total ^(c) | 39,000 | 19,000 |

(a) Based on hours of equipment usage over a 7-year period.

(b) Based on equipment usage over a 10-year period.

(c) Results are rounded to the nearest 1,000 MT CO₂ equivalent (CO₂(e)).

3 **Table H-2 Workforce Green House Gas Footprint Estimates**

| | Construction Workforce | Operational Workforce | Decommissioning Workforce | SAFe STORAGE Workforce |
|--|------------------------|-----------------------|---------------------------|------------------------|
| Commuting Trips (round trips per day) | 1,000 | 550 | 200 | 40 |
| Commute Distance (miles per round-trip) | 40 | 40 | 40 | 40 |
| Commuting Days (days per year) | 365 | 365 | 250 | 365 |
| Duration (years) | 7 | 40 | 10 | 40 |
| Total Distance Traveled (miles) ^(a) | 102,000,000 | 321,000,000 | 20,000,000 | 23,000,000 |
| Average Vehicle Fuel Efficiency ^(b) (miles per gallon) | 21.6 | 21.6 | 21.6 | 21.6 |
| Total Fuel Burned ^(a) (gallons) | 4,700,000 | 14,900,000 | 900,000 | 1,100,000 |
| CO ₂ Emitted Per Gallon ^(c) (MT CO ₂) | 0.00892 | 0.00892 | 0.00892 | 0.00892 |
| Total CO ₂ Emitted ^(a) (MT CO ₂) | 42,000 | 133,000 | 8,000 | 10,000 |
| CO ₂ Equivalency Factor ^(c) (MT CO ₂ /MT CO ₂ (e)) | 0.977 | 0.977 | 0.977 | 0.977 |
| Total GHG Emitted ^(a) (MT CO ₂ (e)) | 43,000 | 136,000 | 8,000 | 10,000 |

(a) Results are rounded.

(b) Source: FHWA 2012-TN2645.

(c) Source: EPA 2012-TN2643.

1 Title 10 of the *Code of Federal Regulations* 51.51(a) (10 CFR 51.51(a); TN250) states that
2 every environmental report³ prepared for an early site permit or COL stage of a light-water-
3 cooled nuclear power reactor shall use Table S–3, Table of Uranium Fuel Cycle Environmental
4 Data, as set forth in 10 CFR 51.51(b) (TN250) as the basis for evaluating the contribution of the
5 environmental effects of uranium fuel-cycle activities to the environmental costs of licensing the
6 nuclear power reactor. Section 51.51(a) (TN250) further states that Table S–3 shall be included
7 in the environmental report and may be supplemented by a discussion of the environmental
8 significance of the data set forth in the table as weighted in the project-specific analysis for the
9 proposed facility.

10 Table S–3 of 10 CFR 51.51(b) (TN250) does not directly apply to non-light-water reactors
11 (LWRs), nor does it provide an estimate of GHG emissions associated with the uranium fuel
12 cycle; it only addresses pollutants that were of concern when the table was promulgated in the
13 1970s. However, Table S–3 states that 323,000 MWh is the assumed annual electric energy
14 use for the Table S–3 reference 1,000 MWe nuclear power plant and that this 323,000 MWh of
15 annual electric energy is assumed to be generated by a 45 MWe coal-fired power plant burning
16 118,000 MT of coal. These assumptions are based upon 1970s uranium enrichment technology,
17 which has changed substantially since then. The older, energy-intensive gaseous-diffusion
18 plants have been replaced with more efficient centrifuge-based systems. The current operating
19 gas centrifuge uranium enrichment facility in the United States is URENCO-USA (Louisiana
20 Energy Services), which is located in Eunice, New Mexico. The URENCO-USA facility does not
21 rely solely upon coal as an energy source (Napier 2020-TN6443). If a 1,000 MWe plant is
22 assumed to operate at 35 percent thermal efficiency and use uranium fuel enriched to 5 percent
23 in uranium-235 (U-235) with an average burnup of 40,000 megawatt-day/metric tonnes
24 (MWd/MT) for 40 years, then it will require about 1,043 tons of enriched uranium for fuel. To
25 produce 1 ton of 5 percent enriched uranium with 0.25 percent U-235 in the depleted uranium
26 stream requires extraction of 10.3 tons of natural uranium and 7,923 separative work units, or
27 SWUs (Napier 2020-TN6443). The 1,043 tons of uranium enriched to 5 percent U-235 required
28 over the 40-year life of the 1,000 MWe plant would then require 8,264,000 SWUs. Because a
29 centrifuge enrichment facility requires about 50 kWh per SWU (WNA 2020-TN6661), a total of
30 413,200 MWh is needed to produce 40 years' worth of uranium enriched to 5 percent U-235 for
31 fuel for the lifetime operation of the 1,000 MWe plant. For the existing U.S. centrifuge
32 enrichment plant, the regional average CO₂ emission factor is 1,248 lb/MWh,⁴ and the total CO₂
33 emission is about 243,000 MT.

34 Table S–3 also assumes that approximately 135,000,000 standard cubic feet of natural gas is
35 required per year to generate process heat for certain portions of the uranium fuel cycle. The
36 NRC staff estimates that burning 135,000,000 standard cubic feet of natural gas per year results
37 in approximately 7,440 MT of CO₂(e) being emitted into the atmosphere per year because of the
38 process heat requirements of the uranium fuel cycle.⁵ For a 40-year operational life, this is
39 298,000 MT of CO₂(e). This amount is in addition to the CO₂(e) emissions from the enrichment
40 process.

³ The NRC requires most applicants, including all reactor applicants, to submit an environmental report as part of the application. 10 CFR 51.45 and 10 CFR 51.50 (10 CFR Part 51-TN250).

⁴ The EPA provides estimates of emissions from electricity production for different regions in the United States at <https://www.epa.gov/energy/emissions-generation-resource-integrated-database-egrid> for CO₂ in units of pounds per kilowatt-hour (lb/kWh). The value for southeastern New Mexico has been applied here.

⁵ The conversion is 0.0551 (metric tons CO₂/thousand standard cubic feet (<https://www.epa.gov/energy/greenhouse-gases-equivalencies-calculator-calculations-and-references>)).

1 The NRC staff estimated GHG emissions related to plant operations from the typical usage of
 2 various onsite diesel generators (UniStar 2007-TN1564). CO emission estimates were derived
 3 assuming an average of 600 hours of emergency diesel generator operation per year (four
 4 generators, each operating 150 hr/yr) and 200 hours of station blackout diesel generator
 5 operation per year (two generators, each operating 100 hr/yr) (Chapman et al. 2012-TN2644). A
 6 scaling factor of 172 was then applied to convert the CO emissions to CO₂ emissions, and a
 7 CO₂ to total GHG equivalency factor of 0.991 was used to account for the emissions from other
 8 GHGs such as CH₄ and N₂O (Chapman et al. 2012-TN2644).

9 The number of shipments and shipping distances for transport of fresh nuclear fuel to and spent
 10 nuclear fuel and radioactive wastes are presented in Table S-5 of Supplement 1 to WASH-1238
 11 [NRC 1975-TN216], for a 1,100 MWe LWR with an 80 percent capacity factor. WASH-1248
 12 (AEC 1974-TN23) assumes that truck casks weigh 50,000 lb (23 MT) and rail casks weigh
 13 100 T (91 MT). For this analysis, emission rates of CO₂ for trucks are taken to be 64.7 g/T-mi
 14 (44.2 g/MT-km) and for rail are taken to be 32.2 g/T-mi (22 g/MT-km) (Cefic and ECTA 2011-
 15 TN6966). For the calculation, it is also assumed that return trips with empty casks double the
 16 total miles traveled by truck or rail. Table H-3 presents estimated annual CO₂e emissions from
 17 shipments associated with the reference 1,000 MWe reactor.

18 **Table H-3 Annual Number of Shipments for the Reference 1,000 MWe Reactor**

| Material | Annual Number of Shipments for the Reference 1,000 MWe Reactor ¹ | Typical Distance, mi ^(a) | Annual CO ₂ (e) Emissions ^(b) |
|---------------------------|---|-------------------------------------|---|
| Unirradiated fuel (truck) | 6 | 1,000 | 19 |
| Spent fuel (truck) | 60 | 1,000 | 194 |
| Spent fuel (rail) | 10 | 1,000 | 64 |
| Radioactive waste (truck) | 46 | 500 | 74 |

(a) Source: NRC (1975-TN216), Table S-5.

(b) Results are rounded to the nearest 1000 MT CO₂(e).

19 The total GHG emissions for fuel and waste transportation are approximately 352 MT per
 20 reference reactor-year from Table H-3. Over a 40-year operating life for the reference
 21 1,000 MWe reactor, the total is approximately 14,000 MT of CO₂(e) emitted.

22 Given the various sources of GHG emissions discussed above, the NRC staff estimated the
 23 total lifetime GHG footprint for the reference 1,000 MWe reactor to be about 990,000 MT
 24 CO₂(e), with a 7-year building phase, 40 years of operation, and 10 years of active
 25 decommissioning.⁶ These components of the GHG emissions footprint are summarized in
 26 Table H-4. The uranium fuel cycle component of the footprint is the largest portion of the overall
 27 estimated GHG emissions and is directly related to the assumed power generated by the plant.
 28 The GHG emission estimates for the uranium fuel cycle are based on newer enrichment
 29 technology, assuming that the energy required for enrichment is provided by modern regional
 30 electric systems.

⁶ Under the NRC's regulations, a reactor licensee has up to 60 years to complete the decommissioning of a reactor facility commencing with the licensee's certification that it has permanently ceased reactor operations (10 CFR 50.82(a)(3); TN249). The 60-year decommissioning period may be exceeded subject to NRC approval if necessary to protect "public health and safety." *Id.* The estimated 10-year decommissioning period is a subset of the 60-year decommissioning period, during which significant demolition and earth-moving activities may occur (e.g., deployment and operation of equipment at the decommissioning site and shipments by truck or rail to remove irradiated soil, rubble, and debris from the site), as discussed in Supplement 1 to NUREG-0586 (NRC 2002-TN665).

1

Table H-4 Nuclear Power Plant Life-Cycle Green House Footprint

| Source | Activity Duration (yr) ^(a) | Total Emissions (MT CO ₂ (e)) |
|-------------------------------|---------------------------------------|--|
| Construction equipment | 7 | 39,000 |
| Construction workforce | 7 | 43,000 |
| Plant operations | 40 | 181,000 |
| Operations workforce | 40 | 136,000 |
| Uranium fuel cycle | 40 | 540,000 |
| Fuel and waste transportation | 40 | 14,000 |
| Decommissioning equipment | 10 | 19,000 |
| Decommissioning workforce | 10 | 8,000 |
| SAFe STORAge workforce | 40 | 10,000 |
| TOTAL^(b) | | 990,000 |

(a) Nuclear power plant life-cycle for estimating GHG is assumed to be 97 years which includes construction (7 years), operations (40 years), and decommissioning (50 years).

(b) Results are rounded to the nearest 1,000 MT CO₂e.

2 The Intergovernmental Panel on Climate Change (IPCC) released a special report about
3 renewable energy sources and climate change mitigation in 2012 (IPCC 2012-TN2648).
4 Annex II of the IPCC report includes an assessment of previously published works on life-cycle
5 GHG emissions from various electric generation technologies, including nuclear energy. The
6 IPCC report included only reference material that passes certain screening criteria for quality
7 and relevance in its assessment. The IPCC screening yielded 125 estimates of nuclear energy
8 life-cycle GHG emissions from 32 separate references. The IPCC-screened estimates of the
9 life-cycle GHG emissions associated with nuclear energy, as shown in Table A.II.4 of the IPCC
10 report, ranged from 1 to 220 g of CO₂(e)/kWh, with 25th percentile, 50th percentile, and 75th
11 percentile values of 8 g CO₂(e)/kWh, 16 g CO₂(e)/kWh, and 45 g CO₂(e)/kWh, respectively. The
12 range of the IPCC estimates is due, in part, to assumptions regarding the type of enrichment
13 technology employed, how the electricity used for enrichment is generated, the grade of mined
14 uranium ore, the degree of processing and enrichment required, and the assumed operating
15 lifetime of a nuclear power plant. The NRC staff's life-cycle GHG estimate of approximately
16 990,000 MT CO₂(e) for the reference 1,000 MWe reactor is equal to about 3.5 g CO₂(e)/kWh,
17 which places the NRC staff's estimate at the lower end of the IPCC estimates in Table A.II.4 of
18 the IPCC report. This placement is primarily because the IPCC estimates were for LWRs that
19 used enrichment technologies that were based on the use of coal-fired generation as the
20 electricity source.

21 The GHG emissions presented in Chapter 3 of this generic environmental impact statement use
22 the values presented in this appendix but are scaled based on previous new nuclear reactor
23 reviews. The GHG emissions for building and operation (including the fuel waste and
24 transportation of fuel and waste) are discussed in Section 3.3, and in Section 3.16 for
25 decommissioning.

26 **H.1 References**

27 10 CFR Part 50. *Code of Federal Regulations*, Title 10, *Energy*, Part 50, "Domestic Licensing of
28 Production and Utilization Facilities." TN249.

- 1 10 CFR Part 51. *Code of Federal Regulations*, Title 10, *Energy*, Part 51, “Environmental
2 Protection Regulations for Domestic Licensing and Related Regulatory Functions.” TN250.
- 3 AEC (U.S. Atomic Energy Commission). 1972. *Environmental Survey of Transportation of*
4 *Radioactive Materials to and from Nuclear Power Plants*. WASH–1238, Washington, D.C.
5 ADAMS Accession No. ML14092A626. TN22.
- 6 AEC (U.S. Atomic Energy Commission). 1974. *Environmental Survey of the Uranium Fuel*
7 *Cycle*. WASH–1248, Washington, D.C. ADAMS Accession No. ML14092A628. TN23.
- 8 Cefic and ECTA (European Chemical Industry Council and European Chemical Transport
9 Association). 2011. *Guidelines for Measuring and Managing CO₂ Emission from Freight*
10 *Transport Operations*. Brussels, Belgium. Accessed March 21, 2021, at
11 [https://www.ecta.com/resources/Documents/Best%20Practices%20Guidelines/guideline_for_m](https://www.ecta.com/resources/Documents/Best%20Practices%20Guidelines/guideline_for_measuring_and_managing_co2.pdf)
12 [easuring_and_managing_co2.pdf](https://www.ecta.com/resources/Documents/Best%20Practices%20Guidelines/guideline_for_measuring_and_managing_co2.pdf). TN6966.
- 13 Chapman, E.G., J.P. Rishel, J.M. Niemeyer, K.A. Cort, and S.E. Gulley. 2012. *Assumptions,*
14 *Calculations, and Recommendations Related to a Proposed Guidance Update on Greenhouse*
15 *Gases and Climate Change*. PNNL-21494, Pacific Northwest National Laboratory, Richland,
16 Washington. ADAMS Accession No. ML12310A212. TN2644.
- 17 EPA (U.S. Environmental Protection Agency). 2012. “Clean Energy: Calculations and
18 References.” Washington, D.C. ADAMS Accession No. ML12292A648. TN2643.
- 19 EPA (U.S. Environmental Protection Agency). 2012. “Stationary Internal Combustion Sources.”
20 Chapter 3 in *Technology Transfer Network Clearinghouse for Inventories & Emissions Factors:*
21 *AP-42*. Fifth Edition, Research Triangle Park, North Carolina. ADAMS Accession No.
22 ML12292A637. TN2647.
- 23 FHWA (Federal Highway Administration). 2012. “Highway Statistics 2010 (Table VM-1).” Office
24 of Highway Policy Information, Washington, D.C. ADAMS Accession No. ML12292A645.
25 TN2645.
- 26 IPCC (Intergovernmental Panel on Climate Change). 2012. *Renewable Energy Sources and*
27 *Climate Change Mitigation—Special Report of the Intergovernmental Panel on Climate Change*.
28 Cambridge University Press, Cambridge, United Kingdom. TN2648.
- 29 Napier, B.A. 2020. *Non-LWR Fuel Cycle Environmental Data*. PNNL-29367, Revision 2,
30 Richland, Washington. ADAMS Accession No. ML20267A217. TN6443.
- 31 NRC (U.S. Nuclear Regulatory Commission). 1975. *Environmental Survey of Transportation of*
32 *Radioactive Materials to and from Nuclear Power Plants, Supplement 1*. NUREG–75/038,
33 Washington, D.C. ADAMS Accession No. ML14091A176. TN216.
- 34 NRC (U.S. Nuclear Regulatory Commission). 2002. *Final Generic Environmental Impact*
35 *Statement of Decommissioning of Nuclear Facilities: Regarding the Decommissioning of*
36 *Nuclear Power Reactors*. NUREG–0586, Supplement 1, Volumes 1 and 2, Washington, D.C.
37 ADAMS Accession Nos. ML023470327, ML023500228. TN665.

- 1 NRC (U.S. Nuclear Regulatory Commission). 2014. *Attachment 1: Staff Guidance for*
2 *Greenhouse Gas and Climate Change Impacts for New Reactor Environmental Impact*
3 *Statements, COL/ESP-ISG-026*. Washington, D.C. ADAMS Accession No. ML14100A157.
4 TN3768.
- 5 UniStar (UniStar Nuclear Energy, LLC). 2007. *Technical Report in Support of Application of*
6 *UniStar Nuclear Energy, LLC and UniStar Nuclear Operating Services, LLC for Certificate of*
7 *Public Convenience and Necessity Before the Maryland Public Service Commission for*
8 *Authorization to Construct Unit 3 at Calvert Cliffs Nuclear Power Plant and Associated*
9 *Transmission Lines*. Public Service Commission of Maryland, Baltimore, Maryland. ADAMS
10 Accession No. ML090680053. TN1564.
- 11 WNA (World Nuclear Association). 2020. "Uranium Enrichment." London, United Kingdom.
12 Webpage accessed October 16, 2020, at [https://www.world-nuclear.org/information-](https://www.world-nuclear.org/information-library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/uranium-enrichment.aspx)
13 [library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/uranium-enrichment.aspx](https://www.world-nuclear.org/information-library/nuclear-fuel-cycle/conversion-enrichment-and-fabrication/uranium-enrichment.aspx).
14 TN6661.


| | | | | | | | |
|---|---|---|---|------|-----------|------|--|
| NRC FORM 335 (12-2010) NRCMD 3.7 | U.S. NUCLEAR REGULATORY COMMISSION BIBLIOGRAPHIC DATA SHEET <i>(See instructions on the reverse)</i> | | 1. REPORT NUMBER (Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.) <p style="text-align: center;">NUREG-2249 Draft Report</p> | | | | |
| 2. TITLE AND SUBTITLE Generic Environmental Impact Statement for Licensing of New Nuclear Reactors Draft Report for Comment | 3. DATE REPORT PUBLISHED <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;">MONTH</td> <td style="width: 50%; text-align: center;">YEAR</td> </tr> <tr> <td style="text-align: center;">September</td> <td style="text-align: center;">2024</td> </tr> </table> | | MONTH | YEAR | September | 2024 | |
| MONTH | YEAR | | | | | | |
| September | 2024 | | | | | | |
| | 4. FIN OR GRANT NUMBER | | | | | | |
| 5. AUTHOR(S) See Appendix A of this Report | 6. TYPE OF REPORT <p style="text-align: center;">Technical</p> | | 7. PERIOD COVERED (Inclusive Dates) | | | | |
| 8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.) Office of Nuclear Material Safety and Safeguards U.S. Nuclear Regulatory Commission Washington, DC 20555-0001 | | | | | | | |
| 9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above", if contractor, provide NRC Division, Office or Region, U. S. Nuclear Regulatory Commission, and mailing address.) Same as 8 above. | | | | | | | |
| 10. SUPPLEMENTARY NOTES | | | | | | | |
| 11. ABSTRACT (200 words or less) <p>The U.S. Nuclear Regulatory Commission (NRC) staff prepared this generic environmental impact statement (GEIS) in accordance with the National Environmental Policy Act of 1969 (NEPA), as amended, to address the NRC licensing of the building and operation of new nuclear reactors in the United States. In this GEIS, the NRC staff uses the values and assumptions in a technology-neutral plant parameter envelope (PPE) for a new nuclear reactor to evaluate the environmental impacts of constructing and operating a nuclear reactor. In addition, this GEIS assumes that a new reactor might be built anywhere in the United States that meets the requirements of the NRC's siting regulations. To accommodate this broad range of siting possibilities, the staff developed a site parameter envelope (SPE) that provides limiting values and assumptions related to the site. The results from this GEIS will be codified in Title 10 of the Code of Federal Regulations Part 51.</p> | | | | | | | |
| 12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.) Generic Environmental Impact Statement for Licensing of New Nuclear Reactors New Reactor GEIS NUREG-2249 National Environmental Policy Act NEPA New Reactor Licensing | | 13. AVAILABILITY STATEMENT <p style="text-align: center;">unlimited</p> 14. SECURITY CLASSIFICATION <i>(This Page)</i> <p style="text-align: center;">unclassified</p> <i>(This Report)</i> <p style="text-align: center;">unclassified</p> | | | | | |
| | | 15. NUMBER OF PAGES | | | | | |
| | | 16. PRICE | | | | | |



Federal Recycling Program



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555-0001
OFFICIAL BUSINESS



**NUREG-2249
Draft**

Generic Environmental Impact Statement for Licensing of New Nuclear Reactors

September 2024