
This content is from the eCFR and is authoritative but unofficial.

Title 33 —Navigation and Navigable Waters

Chapter I —Coast Guard, Department of Homeland Security

Subchapter L —Waterfront Facilities

Part 127 —Waterfront Facilities Handling Liquefied Natural Gas and Liquefied Hazardous Gas

Subpart C —Waterfront Facilities Handling Liquefied Hazardous Gas

Fire Protection

Source: CGD 88-049, 60 FR 39796, Aug. 3, 1995, unless otherwise noted.

Authority: 33 U.S.C. 1504(j)(2); 46 U.S.C. 70011 and 70034; 46 U.S.C. Chapter 701; DHS Delegation No. 00170.1, Revision No. 01.2, paragraph (II)(92)(a).

Source: CGD 78-038, 53 FR 3376, Feb. 7, 1988, unless otherwise noted.

§ 127.1603 Hotwork.

Each operator of a waterfront facility handling LHG must ensure that no person conducts welding, torch cutting, or other hotwork on the facility, or on a vessel moored to the facility, unless—

- (a) The COTP has issued a permit for that hotwork; and
- (b) The conditions of the permit are met.

[CGD 88-049, 60 FR 39796, Aug. 3, 1995, as amended by USCG-2019-0444, 87 FR 5692, Feb. 2, 2022]